



DEECO Inc.
3404 Lake Woodard Road
Raleigh, NC 27604
(919) 250-0285 (ph); (919) 250-1835 (Fax)

www.deeco.com

REPORT NO: 010324-3313

PROJECT: 23-3313

DATE: January 3, 2024

TYPE: **Emission Test Report**

**Hydrogen Cyanide, Hydrogen Fluoride
and Diatomic Chlorine
from
a Portland Cement Plant;
Line 1 and Line 2**

**Holcim (US) Inc.
Midlothian, TX**

AUTHOR: Scott Steinsberger, Ph.D.

TEST DATES: November 15-17, 2023

FIELD TEAM: Lee Harris, Gage Mayer, Michael Powell, and Scott Steinsberger

PREPARED FOR: Holcim (US) Inc.
1800 Dove Lane
Midlothian, TX 76065

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1. INTRODUCTION.....	1
2. SUMMARY OF RESULTS.....	5
3. SAMPLING AND ANALYTICAL PROCEDURES.....	10
3.1 Sampling Point Determination - EPA Method 1.....	10
3.2 Flue Gas Velocity and Volumetric Flow Rate - EPA Method 2.....	13
3.3 Outlet Flue Gas Composition - EPA Method 3A.....	13
3.3.1 Calibration Gases.....	14
3.3.2 Sampling Procedures.....	14
3.4 Flue Gas Moisture Content - EPA Method 4.....	14
3.5 Hydrogen Fluoride and Diatomic Chlorine - EPA Method 26A.....	14
3.6 Hydrogen Cyanide and Hydrogen Fluoride - EPA Method 320.....	18
3.6.1 Laboratory QA/QC Activities Before Field Test Program.....	19
3.6.2 QA/QC Activities During Field Test Program.....	19
4. QA/QC PROCEDURES AND RESULTS.....	23
4.1 Sampling Equipment.....	23
4.1.1 Manual Sampling Equipment Calibrations.....	23
4.2 Analytical QA/QC Results.....	24
Appendix A - Emission Summary Tables	
Appendix B - Field Data and CEM/FTIR Data	
Appendix C - Ion Chromatography Analytical Report Data	
Appendix D - Plant Process Data	
Appendix E - Calibration Documents	
Appendix F - Test Participants	
Appendix G - RTR Sampling and Analytical Protocol	

LIST OF TABLES

<u>Table No.</u>		<u>Page</u>
TABLE 1.1	SUMMARY OF HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 1 AND LINE 2; NOVEMBER 15-17, 2023.....	2
TABLE 1.2	SUMMARY OF SAMPLING AND ANALYTICAL PROTOCOLS FOR.	4
TABLE 2.1	HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 1 KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL ON; NOVEMBER 15, 2023.	6
TABLE 2.2	HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 1 KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL OFF; NOVEMBER 15, 2023.....	7
TABLE 2.3	HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 2 KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL OFF; NOVEMBER 16, 2023.....	8
TABLE 2.4	HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 1 KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL ON; NOVEMBER 17, 2023.	9
TABLE 3.1	PAIRED METHOD 26A SAMPLING TRAIN DIATOMIC CHLORINE CONCENTRATION COMPARISON RESULTS FOR THE LINE 1 AND LINE 2 KILN MAIN STACKS; NOVEMBER 15-17, 2023.	17
TABLE 3.2	FTIR PRETEST AND FIELD TEST QA/QC SUMMARY.....	20
TABLE 3.3	ETHYLENE CALIBRATION TRANSFER STANDARD (CTS) AND HYDROGEN CYANIDE ANALYTE SPIKING TEST RESULTS FOR THE LINE 1 AND LINE 2 KILN MAIN STACKS; NOVEMBER 15-17, 2023.	22

LIST OF FIGURES

<u>Figure No.</u>		<u>Page</u>
Figure 3.1	Schematic of the Line 1 Stack Sampling Location.	11
Figure 3.2	Schematic of the Line 2 Stack Sampling Location.	12

1. INTRODUCTION

The United States Environmental Protection Agency (US EPA) has directed the portland cement industry (SIC 3241) to conduct emissions testing as part of the US EPA Risk and Technology Review (RTR). This document provides the emission test results and supporting quality assurance/quality control (QA/QC) measures used to produce standardized data having known precision and accuracy. Collection of accurate, representative, and standardized data for facilities with low emissions is necessary especially in view of MACT standard setting procedures.

The Holcim (US) Inc. facility located in Ellis County, Texas has been included in this request. Holcim operates two in-line kiln/raw mill systems at the facility in Midlothian, Texas. Emissions from the kiln, alkali bypass, clinker cooler and coal mills for each kiln line are ducted to a common stack.

The processes tested at the Midlothian facility are two preheater/precalciner pyro-processing systems, each with an inline raw mill, producing portland cement, referred to as Line 1 and Line 2. Line 1 incorporates a Fuller Flash Furnace inline calciner, and Line 2 is equipped with a KHD inline calciner in their respective process. Clinker production is permitted at 1.3 Million tons-per-year, each.

The kilns are fueled by a variety of fuels including, but not limited to, coal, pet coke, natural gas, tire-derived fuel (TDF), wood waste, non-hazardous waste solids, fuel oil, non-hazardous waste liquids and oil filter fluff.

The air pollution control equipment for Line 1 consists of three control devices. A dry sorbent injection system utilizing lime is used to control acid gas emissions. Combined emissions from the clinker cooler and the kiln/raw mill and alkali bypass directed through respective fabric filters for particulate removal. The kiln/raw mill exiting the fabric filter is sent to a selective catalytic reduction (SCR) system for reducing organic emissions. Exhaust from the SCR and the alkali bypass are combined and sent to scrubber for final particulate removal and acid gas control before exhausting through the Line 1 Main Stack.

The air pollution control equipment for Line 2 consists of three control devices. A dry sorbent injection system utilizing lime is used to control acid gas emissions. Combined emissions from the clinker cooler and the kiln/raw mill and alkali bypass directed through respective fabric filters for particulate removal. The kiln/raw mill exiting the fabric filter is sent to a regenerative thermal oxidizer (RTO) system for reducing organic emissions. Exhaust from the RTO and the alkali bypass are combined and sent to scrubber for final particulate removal and acid gas control before exhausting through the Line 2 Main Stack. A more detailed description of the processes is provided in Section 2 of the RTR Sampling and Analytical Protocol reproduced in Appendix

The Holcim (US) Inc. retained DEECO Inc. (DEECO) to conduct emission tests for hydrogen cyanide (HCN), hydrogen fluoride (HF), and diatomic chlorine (Cl₂). All sampling runs were be one hour long. Concurrent measurements to determine volumetric flow rate were made.

A summary of the test results is shown in Table 1.1.

TABLE 1.1 SUMMARY OF HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 1 AND LINE 2; NOVEMBER 15-17, 2023

Test Parameters	Main Stack Raw Mill On	Main Stack Raw Mill Off
Line 1 Main Stack; November 15, 2023		
Hydrogen Cyanide (FTIR) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	57.7 34.2 0.237	53.2 36.4 0.252
Hydrogen Fluoride (FTIR) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	Invalidated See Section 2 for discussion	<0.08 <0.04 <0.0003
Hydrogen Fluoride (Method 26A) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.29 <0.13 <0.0009	<0.25 <0.13 <0.0009
Diatomic Chlorine (Method 26A) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.19 <0.29 <0.0020	<0.45 <0.82 <0.0059
Line 2 Main Stack; November 16 and 17, 2023		
Hydrogen Cyanide (FTIR) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	52.7 39.5 0.290	51.5 33.1 0.243
Hydrogen Fluoride (FTIR) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.08 <0.043 <0.0003	<0.07 ¹ <0.03 ¹ <0.0002 ¹
Hydrogen Fluoride (Method 26A) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.28 <0.16 <0.0012	<0.35 <0.17 <0.0012
Diatomic Chlorine (Method 26A) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	0.38 0.76 0.0055	0.77 1.31 0.0096

¹The FTIR hydrogen fluoride results for Run 1 are considered to be invalid due to sample line off gassing and are not included in the average. See Section 2 for discussion.

The sampling and analytical procedures followed are summarized in Table 1.2 and discussed in detail in Section 3.

Testing was performed on the Line 1 main stack under two conditions, Raw Mill On and Raw Mill Off. Testing on Line 1 was conducted on November 15, 2023. Testing was performed on the Line 2 main stack under two conditions, Raw Mill On and Raw Mill Off. Testing on Line 2 was conducted on November 16 and 17, 2023.

Sampling was conducted by personnel from DEECO, Inc. of Raleigh, North Carolina. All questions regarding sampling and analytical data should be directed to Dr. Scott Steinsberger of DEECO at (800) 733-3261. The field sampling was completed by Lee Harris, Gage Mayer, Michael Powell, and Scott Steinsberger of DEECO.

The remainder of this document summarizes the results, procedures and quality control measures followed for this program. Section 2 contains tabulated air emission results for each parameter of interest. Section 3 summarizes the air emission sampling and analytical procedures performed by DEECO, with a brief description and/or reference to the applicable methodologies. Section 4 discusses the basic quality control elements in place for this program to assure the collection of representative, accurate air emission data.

The appendices provided in this document contain all of the necessary information to verify the reported results. Included as Appendices are: Appendix A - Emission Summary Tables; Appendix B - Field Data and CEM/FTIR Data; Appendix C - Ion Chromatography Analytical Report Data; Appendix D - Plant Process Data; Appendix E - Calibration Documents; Appendix F - Test Participants; Appendix G - RTR Sampling and Analytical Protocol

TABLE 1.2 SUMMARY OF SAMPLING AND ANALYTICAL PROTOCOLS FOR HOLCIM (US) INC, MIDLOTHIAN, TEXAS FACILITY

Location and Frequency	Test Parameter	Sampling Method	Sampling Procedure	Analysis Method	Analysis Procedure
Line 1 and Line 2 Kiln Main Stacks	Volumetric Flow Rate and cyclonic check	EPA Methods 1 and 2	Velocity and temperature traverses	EPA Methods 1 and 2	Manometer for differential pressure and thermocouple for temperature
	Oxygen and Carbon Dioxide and Stratification Check	EPA Method 3A	Continuous; extractive sample	EPA Method 3A	Paramagnetic for O ₂ and NDIR for CO ₂
	Moisture	EPA Method 4	Condensation	EPA Method 4	Gravimetric
	Hydrogen Fluoride and Diatomic Chlorine (Cl ₂)	EPA Method 26A	Isokinetic integrated sample	EPA Method 26A	Ion chromatography
	Hydrogen Fluoride and Hydrogen Cyanide	EPA Method 320	Continuous; extractive sample	EPA Method 320	Fourier Transform Infrared (FTIR) Spectroscopy

2. SUMMARY OF RESULTS

Emissions sampling was conducted at the Holcim facility located in Midlothian, TX. Sampling was conducted for stack gas flow rate (EPA Methods 1 and 2), stack gas oxygen and carbon dioxide (EPA Method 3A), stack gas moisture (EPA Method 4), stack gas hydrogen fluoride and diatomic chlorine (EPA Method 26A) and stack gas hydrogen cyanide and hydrogen fluoride (EPA Method 320).

Testing was conducted on the Line 1 main stack under two conditions; Raw Mill On and Raw Mill Off and the results are summarized in Tables 2.1 and 2.2, respectively.

During the Raw Mill On test runs on Line 1, the hydrogen fluoride FTIR concentration started at 0.3 parts-per-million and five hours later was below detection. Method 26A samples from the Line 1 Raw Mill On test runs were all non-detect for hydrogen fluoride. The hydrogen fluoride FTIR results for the Raw Mill On test runs on Line 1 are provided in Appendix B but not included in the Tables 1.1 and 2.1. **Based on this evidence, the hydrogen fluoride results from the FTIR is considered to be invalid for the Line 1 Raw Mill On condition.**

Testing was conducted on the Line 2 main stack under two conditions; Raw Mill Off and Raw Mill On and the results are summarized in Tables 2.3 and 2.4, respectively.

Similar to Line 1, during the Raw Mill Off test on Line 2, the hydrogen fluoride concentration FTIR started at 0.6 parts-per-million and dropped to below detection before the end of the Run 1. Method 26A samples from the Line 2 Raw Mill Off test runs were all non-detect for hydrogen fluoride. The hydrogen fluoride FTIR results from the Raw Mill Off Run 1 are provided in Appendix B. **Based on this evidence, the hydrogen fluoride FTIR results from the Raw Mill Off Run 1 considered to be invalid and are not included in the averages in Tables 1.1 and 2.3.**

TABLE 2.1 HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 1 KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL ON; NOVEMBER 15, 2023

Test Parameter	Main Stack Raw Mill On Run 1	Main Stack Raw Mill On Run 2	Main Stack Raw Mill On Run 3	Main Stack Raw Mill On Average
Time	09:00-10:09	10:32-11:41	12:02-13:11	November 15, 2023
Flow Rate (dscfm)	349,250	349,600	351,900	350,300
Oxygen	15.2%	15.2%	15.5%	15.3%
Carbon Dioxide	9.0%	9.0%	9.0%	9.0%
Moisture	17.1%	17.2%	17.0%	17.1%
Hydrogen Cyanide (FTIR)				
ppm _{dry} at 7% O ₂	56.6	56.4	60.1	57.7
pounds-per-hour	34.1	34.0	34.6	34.2
pounds-per-ton of clinker	0.236	0.236	0.239	0.237
Hydrogen Fluoride (Method 26A)				
ppm _{dry} at 7% O ₂	<0.26	<0.30	<0.32	<0.29
pounds-per-hour	<0.115	<0.136	<0.134	<0.128
pounds-per-ton of clinker	<0.0008	<0.0009	<0.0009	<0.0009
Diatomic Chlorine (Method 26A)				
ppm _{dry} at 7% O ₂	<0.11	<0.26	<0.20	<0.19
pounds-per-hour	<0.17	<0.41	<0.30	<0.29
pounds-per-ton of clinker	<0.0012	<0.0029	<0.0021	<0.0020

TABLE 2.2 HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 1 KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL OFF; NOVEMBER 15, 2023

Test Parameter	Main Stack Raw Mill Off Run 1	Main Stack Raw Mill Off Run 2	Main Stack Raw Mill Off Run 3	Main Stack Raw Mill Off Average
Time	14:32-15:41	15:56-17:05	17:19-18:28	November 15, 2023
Flow Rate (dscfm)	338,000	329,650	313,950	327,200
Oxygen	14.1%	14.0%	13.6%	13.9%
Carbon Dioxide	10.7%	10.8%	11.4%	11.0%
Moisture	18.4%	17.8%	18.8%	18.3%
Hydrogen Cyanide (FTIR)				
ppm _{dry} at 7% O ₂	58.3	52.6	48.8	53.2
pounds-per-hour	39.2	36.2	33.8	36.4
pounds-per-ton of clinker	0.271	0.251	0.234	0.252
Hydrogen Fluoride (FTIR)				
ppm _{dry} at 7% O ₂	<0.08	<0.08	<0.08	<0.08
pounds-per-hour	<0.04	<0.04	<0.04	<0.04
pounds-per-ton of clinker	<0.0003	<0.0003	<0.0003	0.0003
Hydrogen Fluoride (Method 26A)				
ppm _{dry} at 7% O ₂	<0.25	<0.26	<0.23	<0.25
pounds-per-hour	<0.13	<0.14	<0.12	<0.13
pounds-per-ton of clinker	<0.0009	<0.0009	<0.0008	<0.0009
Diatomic Chlorine (Method 26A)				
ppm _{dry} at 7% O ₂	0.72	0.40	<0.30	<0.45
pounds-per-hour	1.31	0.72	0.55	<0.82
pounds-per-ton of clinker	0.0091	0.0050	<0.0038	<0.059

TABLE 2.3 HOLLIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 2 KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL OFF; NOVEMBER 16, 2023

Test Parameter	Main Stack Raw Mill Off Run 1	Main Stack Raw Mill Off Run 2	Main Stack Raw Mill Off Run 3	Main Stack Raw Mill Off Average
Time	14:20-15:57	16:19-17:25	17:41-18:47	November 16, 2023
Flow Rate (dscfm)	268,350	265,400	266,100	266,600
Oxygen	13.0%	12.9%	12.9%	12.9%
Carbon Dioxide	12.7%	13.2%	13.3%	13.1%
Moisture	18.5%	20.6%	20.0%	19.7%
Hydrogen Cyanide (FTIR)				
ppm _{dry} at 7% O ₂	49.2	52.5	52.8	51.5
pounds-per-hour	31.6	33.7	34.0	33.1
pounds-per-ton of clinker	0.231	0.247	0.250	0.243
Hydrogen Fluoride (FTIR)				
ppm _{dry} at 7% O ₂	0.32 ¹	<0.07	<0.07	<0.07
pounds-per-hour	0.15 ¹	<0.03	<0.03	<0.03
pounds-per-ton of clinker	0.0011 ¹	<0.0002	<0.0002	<0.0002
Hydrogen Fluoride (Method 26A)				
ppm _{dry} at 7% O ₂	<0.41	<0.33	<0.31	<0.35
pounds-per-hour	<0.20	<0.15	<0.15	<0.17
pounds-per-ton of clinker	<0.0014	<0.0011	<0.0011	<0.0012
Diatomic Chlorine (Method 26A)				
ppm _{dry} at 7% O ₂	0.69	0.78	0.85	0.77
pounds-per-hour	1.17	1.32	1.44	1.31
pounds-per-ton of clinker	0.0086	0.0097	0.0106	0.0096

¹The FTIR hydrogen fluoride results for Run 1 are considered to be invalid due to sample line off gassing and are not included in the average

TABLE 2.4 HOLCIM (US) INC., MIDLOTHIAN, TX FACILITY; LINE 1 KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL ON; NOVEMBER 17, 2023

Test Parameter	Main Stack Raw Mill On Run 1	Main Stack Raw Mill On Run 2	Main Stack Raw Mill On Run 3	Main Stack Raw Mill On Average
Time	08:06-09:12	09:30-10:36	10:58-12:04	November 17, 2023
Flow Rate (dscfm)	355,200	356,750	353,550	355,200
Oxygen	14.0%	13.9%	13.9%	13.9%
Carbon Dioxide	11.3%	11.4%	11.5%	11.4%
Moisture	18.2%	19.5%	18.9%	18.9%
Hydrogen Cyanide (FTIR)				
ppm _{dry} at 7% O ₂	53.5	52.3	52.4	52.7
pounds-per-hour	39.7	39.5	39.3	39.5
pounds-per-ton of clinker	0.291	0.290	0.288	0.290
Hydrogen Fluoride (FTIR)				
ppm _{dry} at 7% O ₂	<0.08	<0.08	<0.08	<0.08
pounds-per-hour	<0.043	<0.043	<0.044	<0.043
pounds-per-ton of clinker	<0.0003	<0.0003	<0.0003	<0.0003
Hydrogen Fluoride (Method 26A)				
ppm _{dry} at 7% O ₂	<0.31	<0.26	<0.28	<0.28
pounds-per-hour	<0.17	<0.15	<0.15	<0.16
pounds-per-ton of clinker	<0.0013	<0.0011	<0.0011	<0.0012
Diatomic Chlorine (Method 26A)				
ppm _{dry} at 7% O ₂	0.33	0.43	0.39	0.38
pounds-per-hour	0.64	0.86	0.77	0.76
pounds-per-ton of clinker	0.0047	0.0063	0.0056	0.0055

3. SAMPLING AND ANALYTICAL PROCEDURES

Table 1.2 presents a summary of the overall sampling and analytical protocols used for the test program for the Line 1 and Line 2 main stacks at Holcim's Midlothian, TX facility. All sampling and analytical methods employed for this test program were performed in accordance with the procedures outlined in the Reference Test Methods contained in the Code of Federal Regulations, Title 40, Part 60, Appendix A (40 CFR 60, Appendix A) and 40 CFR 63, Appendix A.

3.1 Sampling Point Determination - EPA Method 1

The Line 1 Main stack is a vertically-oriented circular stack with an inside diameter of 161.5" inside diameter. The stack gas sampling ports are located approximately 101' 7" (approximately 7.55 duct diameters) above the ID fan breaching and approximately 38' 6" (approximately 2.86 duct diameters) from the stack outlet.


The Line 2 Main stack is a vertically-oriented circular stack with an inside diameter of 164.063" inside diameter. The stack gas sampling ports are located approximately 102' 9" (approximately 7.52 duct diameters) above the ID fan breaching and approximately 83' 6" (approximately 6.11 duct diameters) from the stack outlet.

Both sampling locations met the minimum specifications for selection of a measurement site as outlined in EPA Method 1. Cyclonic flow checks, as described in EPA Method 1 Section 2.4, using the Type-S pitot null procedure and angle measurements at the stack test location were conducted.

A twelve (12) point sampling traverse were made using 3 points in each of 4 sampling ports at the Line 1 Main stack and Line 2 Main stack. Each traverse was made at each sampling location using a type-S pitot tube in accordance with EPA Methods 2 procedures. Gas temperatures were measured using calibrated Type K thermocouples and digital readout devices. All measurements were performed in accordance with the procedures in EPA Methods 2, and 26A.

Schematics of the Line 1 Main stack and Line 2 Main stack are provided in Figures 3-1 and 3-2, respectively.

6-pt Traverse Points
 2 Axes
 6 points/axis
 4 ports
 3 points/port
 12 total points



Traverse Distance from Outside Sample Port
 56¹/₈ in.
 72⁵/₈ in.
 96³/₄ in.
 162³/₄ in.
 186⁷/₈ in.
 203³/₈ in.

Section K-K





Figure 3.1 Schematic of the Line 1 Stack Sampling Location

6-pt Traverse Points
 2 Axes
 6 points/axis
 4 ports
 3 points/port
 12 total points



Traverse Distance from Outside Sample Port
 14¼ in.
 31 in.
 55½ in.
 122½ in.
 147⅞ in.
 163⅞ in.

Section K-K




Figure 3.2 Schematic of the Line 2 Stack Sampling Location

The number and location of the sampling or traverse points were determined according to the procedures outlined in EPA Method 1. All points were at least 1.0 inches from the stack wall, per Method 1.

3.2 Flue Gas Velocity and Volumetric Flow Rate - EPA Method 2

The flue gas velocity and volumetric flow rate were determined according to the procedures outlined in EPA Method 2. Velocity measurements were using type S pitot tubes conforming to the calibration specifications outlined in EPA Method 2, Section 10.1. Each Type-S pitot tube, calibrated according to these standards, had an assigned coefficient. Differential pressures were measured with fluid manometers. Effluent gas temperatures were measured with chromel-alumel thermocouples equipped with digital readouts.

3.3 Outlet Flue Gas Composition - EPA Method 3A

Outlet flue gas analysis for oxygen (O₂) and carbon dioxide (CO₂) concentrations, and the calculation of percent excess air and flue gas dry molecular weight was performed in accordance with EPA Method 3A.

To evaluate the sampling location and points for FTIR and O₂ sampling, a three-point O₂ concentration stratification test on a line passing through the centroidal area at (for stacks is greater than 2.4 meters) at 0.4, 1.2 and 2.0 meters from the stack or duct wall. The procedures in Section 8.1.2 of Method 7E were followed, using oxygen as allowed by fourth sentence in Section 8.1.2. The plant O₂ CEMS was used as a control. A criteria of <5% variation from combined mean for each point was used as indication of non-stratification to allow single point sampling at the point closest to the mean.

Per EPA Method 3A for determining molecular weight, continuous extractive sampling was obtained using the same Method 320 sampling system described in Section 3.6.

A portion of the hot, wet gas sample was sent through a condensing system to remove the stack moisture. A portion of the moisture-free gas sample was sent to an O₂/CO₂ analyzer.

Calibration procedures were performed in accordance with EPA methodology. Analyzers were calibrated before and after each test and a calibration check between each test run.

The pretest calibrations consisted of the following steps:

- Internal (direct) calibration of each analyzer to adjust calibration and check linearity.
- External (through the entire sampling system) calibration to check the system bias on zero and span gases.

The post test calibration consisted of an external system bias calibration check.

The analyzer calibrated using a certified zero and span (mid or high range) gas. Zero and span gases were directed to each analyzer through the appropriate plumbing, the calibration gas flow rates were adjusted to the correct flow rate and the analyzer was adjusted with the appropriate span pot.

After the analyzer was properly adjusted the linearity was checked using a low and high range calibration gas. The maximum allowable limit for linearity is 2% of the analyzer range and all analyzers were shown to be linear within these limits before proceeding.

The external calibration bias check were performed by placing the CEM system in sampling mode and injecting a zero and span gas into the sample line at the probe exit. This check showed if there is any sampling system related bias, and also checks the integrity of the sample line.

3.3.1 Calibration Gases

DEECO used EPA Protocol and/or $\pm 2\%$ NIST Traceable gases for calibration as required by the various reference methods employed in this test program. Calibration gases were selected from previous experience with similar sources and/or from information obtained from the facility engineer prior to sampling. In some cases if the gases that are selected are out of the optimum range of operation then no significant impact of data quality is expected due to the linear nature of the analyzers that were used.

Specific HCN gases were manufactured for this test program in the range of 50-100 ppm to provide spikes in the 5-10 ppm range, or lower; with an SF₆ or appropriate tracer used to calculate the exact spike gas dilution ratio of 10% or less

No audit gases from a federal or a state agency were provided.

3.3.2 Sampling Procedures

At the completion of the pretest calibration routine, the CEM system was ready for operation. No further adjustments of sample flow rates, analyzer zero or span adjustments, or other critical CEM operating parameters were made until testing and post test calibration were complete.

Each sampling run was one hour. At the completion for each test run, calibration gases were used to check between test runs. A zero and the upscale calibration gas closest to the actual emission concentrations were used for the pretest and post test calibrations.

3.4 Flue Gas Moisture Content - EPA Method 4

The flue gas moisture content was determined in conjunction with the EPA Method 26A trains according to the sampling and analytical procedures outlined in EPA Method 4. (**NOTE:** In order to maintain isokinetic sampling, the sampling rate used may have been required to temporarily exceed the EPA Method 4-specified maximum sampling rate of 0.75 CFM, based on observed stack gas pitot readings.) The impingers were connected in series and contained reagents as described below. The impingers were contained in an ice bath in order to assure condensation of the moisture in the flue gas stream. Any moisture that is not condensed in the impingers was captured in the silica gel, therefore all moisture was weighed and entered into moisture content calculations.

3.5 Hydrogen Fluoride and Diatomic Chlorine - EPA Method 26A

Sampling and analytical procedures were those outlined in EPA Method 26A to determine primarily diatomic chlorine (Cl₂) emissions and hydrogen fluoride (HF) emissions at main stack

outlet sampling locations. Duplicate simultaneous trains (a.k.a “paired trains”) for each test run were used to determine precision.

Sample was collected through a heated glass probe, followed by a heated Teflon filter, where stack gas HF and Cl₂ were collected in a series of chilled impingers. The sampling train impingers contained 100 ml of 0.1N sulfuric acid in the first and second, an empty third impinger, 100 ml of 0.1N NaOH in the fourth and fifth and 200 grams of silica gel in the last impinger

Sampling was conducted isokinetically (±10%) with readings of flue gas parameters recorded at traverse points selected according to EPA Method 1. Leak-checks on the Method 26A sampling train were performed before and after each sampling run and optionally for any port change. The sampling train leak-checks and leakage rate (where applicable) were documented on the field test data sheet for each respective run. All leak checks were acceptable.

The glass button hook nozzle and probe liner was constructed of borosilicate glass. The filter holder was constructed of borosilicate glass with a Teflon frit filter support and a sealing gasket. A PTFE-bonded glass fiber filter was used. The probe and filter housing were heated to above 248 °F and not exceed an upper boundary of 273 °F. Probe liners and filter holders were cleaned thoroughly prior to testing.

The Method 26A trains was operated isokinetically for a minimum of 60 minutes and collected a minimum of 1 dry, standard cubic meter (DSCM). Pretest preparations, preliminary determinations, and leak check procedures were those outlined in EPA Method 5.

After completion of sampling the train was leak checked and transferred to the sample recovery trailer. All leak checks were acceptable. The impingers were weighed to determine moisture gain in accordance with EPA Method 4.

Sample recovery involved quantitative recovery of the sulfuric acid impinger contents and the NaOH impinger contents into separate tare-weighed, precleaned polyethylene sample containers.

The nozzle, probe, filter and filter housing were not recovered.

The contents of sulfuric acid impingers, including the contents if any of the empty (2nd knockout or third) impinger were quantitatively transferred to the tare-weighed, precleaned polyethylene sample container, followed by three rinses with deionized (DI) water of the impingers and all connecting glassware (including the connecting glassware to the first impinger) placed in the same H₂SO₄ container. The container was labeled and weighed to determine the final sample volume.

The contents NaOH impingers were quantitatively transferred to a second tare-weighed, precleaned polyethylene sample container, followed by three rinses with DI water of the impingers and all connecting glassware placed in the same NaOH container. The container was labeled and weighed to determine the final sample volume.

Sample recovery from each train included:

1. Container No. 1 - Contents of H₂SO₄ impingers and knockout impinger and, and DI rinse of impingers and connecting glassware; and

2. Container No. 2 - Contents NaOH impingers, and DI rinse of impingers and connecting glassware.

Additional quality control consisted of collecting and analyzing a field blank train for every three test runs. The blank train was assembled from a used train, leak checked and sat for a period equal to the sampling time (i.e, 1-hr). The blank train data was to be used to determine the method detection limit for the test program target analytes (ie. The lowest number that could be detected), and compared to stack emissions.

Reagent blanks of 0.1 N H₂SO₄, 0.1N NaOH, and DI water were collected and archived for later analysis should there be any issues with the field blank train samples

The H₂SO₄ impinger solutions were analyzed using ion chromatography techniques for fluoride ions (F⁻) (EPA SW-9057). Duplicate analyses performed on the samples and field blanks. Precision was demonstrated by duplicate injection of each sample, the results of each individual analysis being within 5% of their mean to be acceptable.

The NaOH impinger solutions was treated with sodium thiosulfate to ensure complete conversion of hypochlorous acid (HClO) to chloride ions (Cl⁻). The resulting solution was analyzed using ion chromatography techniques for chloride ions (EPA SW-9057). Duplicate analyses was performed on the samples and field blanks. Precision was demonstrated by duplicate injection of each sample, the results of each individual analysis being within 5% of their mean to be acceptable

All EPA Method 26A HF/Cl₂ samples were analyzed by Element One of Wilmington NC. Refer to Section 1, Figure 1.1 of the RTR Sampling and Analytical Protocol for contact information.

For this test program, the relative deviation (RD) was to be calculated as described in EPA Method 30B between the Cl₂ concentrations measured with the paired trains. A criteria of a less than 10% relative deviation or 0.2 ppm absolute difference was required.

The absolute differences between the Cl₂ concentrations measured with the paired trains is summarized in Table 3.1. For each paired run, Cl₂ concentrations met the 0.2 ppm absolute difference criteria.

TABLE 3.1 PAIRED METHOD 26A SAMPLING TRAIN DIATOMIC CHLORINE CONCENTRATION COMPARISON RESULTS FOR THE LINE 1 AND LIINE 2 KILN MAIN STACKS; NOVEMBER 15-17, 2023

Run	Time	Train A Diatomic Chlorine Concentration (ppm,dry)	Train B Diatomic Chlorine Concentration (ppm,dry)	Absolute Difference (ppm,dry)
November 15, 2023; Line 1 Main Stack Raw Mill On				
Run 1	09:00-10:09	<0.04	<0.05	0.01
Run 2	10:32-11:41	0.14	<0.08	0.06
Run 3	12:02-13:11	<0.07	<0.08	0.01
November 15, 2023; Line 1 Main Stack Raw Mill Off				
Run 1	14:32-15:41	0.33	0.37	0.04
Run 2	15:56-17:05	0.13	0.26	0.13
Run 3	17:19-18:28	0.25	<0.07	0.18
November 16, 2023; Line 1 Main Stack Raw Mill Off				
Run 1	14:20-15:57	0.35	0.43	0.08
Run 2	16:19-17:25	0.52	0.39	0.13
Run 3	17:41-18:47	0.49	0.50	0.01
November 17, 2023; Line 1 Main Stack Raw Mill Off				
Run 1	08:06-09:12	0.17	0.15	0.02
Run 2	09:30-10:36	0.23	0.22	0.01
Run 3	10:58-12:04	0.19	0.21	0.02

3.6 Hydrogen Cyanide and Hydrogen Fluoride - EPA Method 320

EPA Method 320 was performed to determine emissions of concentrations of HCN and HF. Three, 1-hour sampling runs were conducted under each representative process and control system operating conditions.

The gas sample was extracted from the stack through a glass-lined probe and filter heated to 375° F. For external calibration checks and analyte spikes, the gases were introduced in front of the heated filter. Any excess calibration gas was diverted through the sample probes into the source. Outflow of gas from the heated filter enclosure was transported through a Teflon sample line heated to 375° F. For these sources approximately 300' of sample line was required. The heated sample line was connected directly to the FTIR sample cell. Using heat-traced Teflon tubing the exit of the FTIR cell was connected to a sample pump with a heated stainless steel pump head. The pump discharge was directed to a proprietary chiller-type gas conditioner to remove moisture prior to delivery sample gas to the O₂/CO₂ monitor.

The distribution of the gas sample to the monitors was accomplished using a panel equipped with valves and rotometers. The gas sample was then divided and directed to the O₂/CO₂ analyzer.

FTIR sample cell was maintained at 191° C and connected to a MKS Instruments Multigas 2030 Fourier Transform Infrared Spectrometer and Detector.

The FTIR spectrometer measured vapor phase organic or inorganic compounds which absorb energy in the mid-infrared spectral region, about 400 to 4000 cm⁻¹ (25 to 2.5 μm). Continuous measurement were made by matching sample absorbance bands with bands in reference spectra, and comparing sample band intensities with reference band intensities.

The principle limitation to FTIR spectroscopy are the presence of interfering compounds that also absorb energy in the mid-infrared spectral region. In a cement kiln stack gas matrix, water vapor (H₂O) and carbon dioxide (CO₂) are the primary interferents that must be incorporated into the identification and quantitation method.

The FTIR software performs the computation for a single compound by subtracting all the other compounds (interferants and target) from the absorbance spectra and quantifies the single compound based on the remain absorbance. The FTIR software provides a Standard Error Calculation (SEC) value that is an indication of how well the identification and quantitation has been performed. A high SEC indicates that other interferants have not been accounted for in the analysis method, and a low SEC is indicative of greater confidence measurement.

The instrument is operated with a resolution of 0.5 cm⁻¹ with 4x zero filling. Beer-Norton Medium apodization is used with amplitude phase correction.

For this RTR test program, following specific QA/QC activities for EPA Method 320 were performed and are summarized in Table 3.2

3.6.1 Laboratory QA/QC Activities Before Field Test Program

Before field testing occurs, the following QA/QC activities were conducted;

- 1) Seven consecutive samples of dry nitrogen through the sampling system was acquired and used to calculate the standard deviation for each of the test program target analytes multiplied by a factor of 3. These data were considered representative of detection limits (DL) for this test program and were below the 0.5 ppm required DL for both HCN and HF;
- 2) From these seven dry nitrogen samples, the results for the Signal-to-Noise Ratio (SNR) @ 2500 cm^{-1} was >2500, at 64 scans and the results for single beam intensity @ 2500 cm^{-1} was >0.9; and
- 3) The HCN calibration gases was analyzed directly and the FTIR responses agreed with tag value within 5%

3.6.2 QA/QC Activities During Field Test Program

During the field test program, following QA/QC activities were be performed and criterium met;

- 1) On each test day prior to any testing, an instrument background was collected using dry nitrogen directed to the gas cell. The background was collected with at least 128 scans;
- 2) The probe, filter, sample line and all sample system components in contact with effluent were be maintained at or above 375°F or 191°C (consistent with FTIR calibration temperature) to avoid any possible “cold spots;”
- 3) A system zero with all sampling system components at operating temperature was performed by injecting nitrogen at the sample probe and through sample filter and entire measurement system. After zero equilibration was achieved, all measurement components were quantified for at least 128 scans;
- 4) The sample probe was position at effluent measurement point and sampling was continue until equilibration of the measurement system has been achieved. At this point, the effluent concentrations was quantified with two consecutive 64-scan samples as the initial native concentration for the dynamic spike;
- 5) Analyte spiking was conducted for HCN before the first test run, and after each successive test run for a minimum of 4 spikes per test condition. These results were used to determine accuracy and are summarized in Table 3.3;
- 6) The spike gas injections was maintained at 10% or less of total sample volume. The spike gas concentration and flow rate was be selected to approximately double the native effluent concentration. Spike recovery results were within $\pm 20\%$ of the expected value. An SF_6 tracer was used to calculate the exact spike gas dilution ratio of 10% or less;

TABLE 3.2 FTIR PRETEST AND FIELD TEST QA/QC SUMMARY

Spectrum	HCN	SF6	HF	SNR 2500	sBeam @2500
Seven consecutive samples of dry nitrogen for detection limit					
SPC_000837.LAB	-0.051		-0.002	6223.51	1.42
SPC_000838.LAB	-0.032		-0.000	5809.30	1.42
SPC_000839.LAB	0.046		-0.017	3759.60	1.42
SPC_000840.LAB	-0.011		0.016	4373.66	1.42
SPC_000841.LAB	0.080		0.002	5347.95	1.42
SPC_000842.LAB	0.059		-0.012	5012.46	1.42
SPC_000843.LAB	-0.029		-0.006	4706.13	1.42
Standard Deviation X 3	0.156		0.032		
Averages				5033.23	1.42
HCN Standard (CC768233; 199.1 ppm HCN/10.0 ppm SF6)					
SPC_000863.LAB	198.2	9.6			
SPC_000864.LAB	198.4	9.6			
SPC_000865.LAB	198.7	9.6			
SPC_000866.LAB	197.5	9.6			
Averages	198.2	9.6			
HCN Standard (CC768222; 49.9 ppm HCN/5.0 ppm SF6)					
SPC_000873.LAB	49.83	4.86			
SPC_000874.LAB	49.91	4.86			
SPC_000875.LAB	49.85	4.85			
SPC_000876.LAB	49.90	4.86			
Averages	49.87	4.86			
Residuals for Post HCN analyte spike native scans					
SPC_001501.LAB					
Concentration	22.3		0.21		
MDC3	0.52		0.19		
MDC3%	2.3%		NA		
SPC_001502.LAB					
Concentration	21.1		0.23		
MDC3	0.45		0.17		
MDC3%	2.1%		NA		
Final SNR @ 2500 cm⁻¹ and single beam intensity @ 2500 cm⁻¹					
SPC_002711.LAB				3548.4	1.16

- 7) After the dynamic spike, nitrogen was sent through the sampling system until all traces of spike gas removed and lines proven below DL for target analytes;
- 8) The nitrogen purge was discontinued and the sampling system was allowed to equilibrate with stack gas before starting a test run. The first two consecutive 64-scan samples of a sample run was used for the final native concentration. Residual results for HCN and HF were verified to be less than 0.2-0.3 ppm for data acceptance, or less than 5% of the measured value, whichever was least restrictive.
- 9) The final SNR @ 2500 cm^{-1} , at 64 scans, and the results for single beam intensity @ 2500 cm^{-1} were verified to met the >2500 and >0.9 criterium; respectively.

TABLE 3.3 ETHYLENE CALIBRATION TRANSFER STANDARD (CTS) AND HYDROGEN CYANIDE ANALYTE SPIKING TEST RESULTS FOR THE LINE 1 AND LINE 2 KILN MAIN STACKS; NOVEMBER 15-17, 2023

Run	Time	Average Native Hydrogen Cyanide Concentration (ppm,wet)	Spike plus Average Hydrogen Cyanide Native Concentration (ppm,wet)	Hydrogen Cyanide Spike Recovery	CTS Error
November 15, 2023; Line 1 Main Stack Raw Mill On					
Pre Run 1	08:47-08:59	22.15	34.39	83.8%	-2.1%
Post Run 1	10:16-10:34	19.88	32.39	84.7%	
Post Run 2	11:42-11:56	19.01	29.89	81.4%	
Post Run 3	13:16-13:56	19.88	31.61	80.3%	-1.8%
November 15, 2023; Line 1 Main Stack Raw Mill Off					
Pre Run 1	14:15-14:37	22.60	34.97	82.4%	-2.2%
Post Run 1	15:42-16:08	21.64	34.21	83.3%	
Post Run 2	17:07-17:36	20.30	32.14	80.4%	
Post Run 3	18:30-18:54	21.44	34.11	83.3%	-1.9%
November 16, 2023; Line 1 Main Stack Raw Mill Off					
Pre Run 1	13:46-14:07	19.80	34.73	92.8%	-2.3%
Post Run 1	15:57-16:14	23.52	35.54	82.4%	
Post Run 2	17:32-17:48	23.51	37.85	90.1%	
Post Run 3	18:48-19:09	23.90	37.06	85.2%	-2.3%
November 17, 2023; Line 1 Main Stack Raw Mill Off					
Pre Run 1	07:50-08:11	21.23	33.57	84.7%	-2.5%
Post Run 1	09:13-09:27	21.24	34.52	83.3%	
Post Run 2	10:42-10:57	21.11	33.10	86.1%	
Post Run 3	12:06-12:31	20.57	33.10	87.2%	-2.2%

4. QA/QC PROCEDURES AND RESULTS

The objective of a quality assurance/quality control (QA/QC) program is to assure that the precision and accuracy of all environmental data generated by DEECO for clients are commensurate with data quality objectives (DQO's). DQO's are based on a common understanding of the intended end use(s) of the data, the measurement process, and the availability of resources. Once DQO's are established, formally or informally, QC protocol can be defined for the measurements.

In this project, the final data user is Holcim. The data quality objectives in this project are to generate scientifically sound data to be used for compliance purposes.

4.1 Sampling Equipment

All of the sampling equipment used was calibrated according to the procedures outlined in the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III, EPA-600/4-77-027b.

4.1.1 Manual Sampling Equipment Calibrations

For sampling Methods 1, 2, and 4 the procedures and equipment used to measure stack gas velocity and temperature measurements and the metering system used to maintain constant rate sampling conditions and to determine the sample gas volume were subjected to pretest and posttest calibrations and/or inspections as required by the appropriate EPA methods.

Barometer - Barometric pressure values were obtained from a calibrated barometer, verified by phone call to a local airport, and corrected for elevation to sample port level (0.01 inches Hg per 10 ft. elevation).

Pitot Tubes - Each pitot tube used in sampling meets the design specifications for type-S pitot tubes in EPA Method 2. Therefore, a maximum value baseline coefficient (C_p) of 0.84 is assigned to each pitot tube. Calibration by the manufacturer for pitot face-opening alignment included measuring the external tubing diameter (dimension D_t), the base-to-opening plane distance (dimensions P_a and P_b), and the face opening misalignment angles, with all terms as described in EPA Method 2. Pitot tubes were visually inspected for structural integrity at the completion of each test. Inspection sheets for pitot tubes are included in Appendix E.

Calibration Meter and Metering System - The secondary reference meter equipment arrangement for calibration is shown in Figure 5.7 of EPA Method 5. The prescribed procedures were followed. A wet test meter with a 1 ft³/rev capacity and ± 1 percent accuracy is used as the primary calibrant. The dry gas meter's pump is run for a minimum of 5 minutes at a flow rate of 0.35 cfm to condition the interior surface of the wet test meter. Leak checks are performed and if satisfactory, triplicate runs at each of no less than five different flow rates are done. A calibration curve is prepared and the meter is recalibrated after 200 hours of operation or annually, whichever comes first.

The calibration set-up for the dry gas metering system using the secondary reference meter in lieu of the wet test meter is given in Figure 5.5 of EPA Method 5. A leak check of the metering system before calibration was performed as shown in Figure 5.4 of EPA Method 5. The metering system's pump is operated for 5 minutes at an orifice manometer setting of 0.5 inches H₂O to heat up the pump and system to stabilize the meter inlet and outlet temperatures. Values for the orifice setting (ΔH), wet test meter volume (V_w), corresponding dry test meter volume (V_d), dry test meter inlet and outlet gas temperatures (t_{di} and t_{dn}), and time are recorded for the initial calibration. Then the ratio of the wet test meter to the dry test meter (γ) and the orifice pressure differential that equates to 0.75 cfm at standard conditions ($\Delta H@$) are calculated.

A post-test meter calibration was made on the dry gas meter used during the test to check its accuracy against the pre-test calibration. This post-test calibration check was made using the average orifice setting obtained during each test run and setting the vacuum at the maximum value obtained during each test run. These test runs were made against DEECO's secondary reference dry gas meter which was calibrated against a wet test meter. The calibration data sheets for the dry gas meters are included in Appendix E.

Thermocouples and Digital Indicators - Thermocouples were calibrated by comparing them against an ASTM-3F mercury-in-glass thermometer at approximately 32 °F (ice water), ambient temperature, and at approximately 220 °F. Each thermocouple was calibrated against temperature ranges to which it is typically exposed during test conditions, and they agreed within 1.5 percent (expressed in °R) of the reference thermometer throughout the entire calibration range. Also, thermocouples were checked at ambient temperature at the test site to verify calibration. The calibration data sheets for the thermocouples are included in Appendix E.

Pretest and Posttest Leak Checks of Sampling Trains - Each Method 4 sampling train was subjected to pretest leak checks and posttest leak checks. For all sampling runs the posttest leak checks were acceptable (less than 4% of the sampling rate at the highest vacuum recorded during the test run).

4.2 Analytical QA/QC Results

Analytical measurements of precision and accuracy were made on stack gas samples, and are summarized in a separate report.

Appendix A
Emission Summary Tables

Company: Holcim; Midlothian TX
Source: Line 1 Main Stack; Raw Mill On
Job ID: 23-3313
Train Type: EPA Method 26A

NOTE: Average INCLUDES Non-detect runs' results

"ND()" denotes values below detection limits

		1A		1B		2A		2B		3A		3B		Average			
		11/15/23		11/15/23		11/15/23		11/15/23		11/15/23		11/15/23					
		900-1009		900-1009		1032-1141		1032-1141		1202-1311		1202-1311					
Hydrogen Fluoride	Catch Wt, mg	ND(0.126)	ND(0.132)	ND(0.155)	ND(0.149)	ND(0.139)	ND(0.155)	ND(0.143)	ND(0.089)	ND(0.106)	ND(0.098)	ND(0.106)	ND(0.143)	ND(0.098)	0.143		
	Conc., mg/dscm	ND(0.089)	ND(0.087)	ND(0.105)	ND(0.102)	ND(0.098)	ND(0.106)	ND(0.098)	ND(0.216)	ND(0.211)	ND(0.255)	ND(0.249)	ND(0.252)	ND(0.272)	ND(0.243)	0.243	
	Conc., mg/dscm @ 7% O2	ND(0.216)	ND(0.211)	ND(0.255)	ND(0.249)	ND(0.252)	ND(0.272)	ND(0.243)	ND(0.118)	ND(0.115)	ND(0.139)	ND(0.136)	ND(0.131)	ND(0.141)	ND(0.130)	0.130	
	Conc., mg/dscm @ 12% CO2	ND(0.118)	ND(0.115)	ND(0.139)	ND(0.136)	ND(0.131)	ND(0.141)	ND(0.130)	ND(0.107)	ND(0.104)	ND(0.126)	ND(0.123)	ND(0.118)	ND(0.127)	ND(0.117)	0.117	
	Conc., ppmvd	ND(0.107)	ND(0.104)	ND(0.126)	ND(0.123)	ND(0.118)	ND(0.127)	ND(0.117)	ND(0.260)	ND(0.254)	ND(0.307)	ND(0.300)	ND(0.303)	ND(0.327)	ND(0.292)	0.292	
	Conc., ppmvd @ 7% O2	ND(0.260)	ND(0.254)	ND(0.307)	ND(0.300)	ND(0.303)	ND(0.327)	ND(0.292)	ND(0.142)	ND(0.139)	ND(0.168)	ND(0.164)	ND(0.157)	ND(0.169)	ND(0.156)	0.156	
	Conc., ppmvd @ 12% CO2	ND(0.142)	ND(0.139)	ND(0.168)	ND(0.164)	ND(0.157)	ND(0.169)	ND(0.156)	Emission Rate, lb/hr	ND(0.111)	ND(0.118)	ND(0.135)	ND(0.136)	ND(0.127)	ND(0.141)	ND(0.128)	0.128
	Emission Rate, lb/hr	ND(0.111)	ND(0.118)	ND(0.135)	ND(0.136)	ND(0.127)	ND(0.141)	ND(0.128)	Clinker Rates (mtph and lbs/ton)	130.96	ND(0.0008)	130.96	ND(0.0009)	130.96	ND(0.0009)	ND(0.0009)	0.0009
	Clinker Rates (mtph and lbs/ton)	130.96	ND(0.0008)	130.96	ND(0.0009)	130.96	ND(0.0009)	ND(0.0009)									
Chlorine	Catch Wt, mg	ND(0.176)	ND(0.203)	0.582	ND(0.348)	ND(0.300)	ND(0.350)	< 0.327	ND(0.124)	ND(0.133)	0.393	ND(0.239)	ND(0.211)	ND(0.238)	< 0.223	0.223	
	Conc., mg/dscm	ND(0.124)	ND(0.133)	0.393	ND(0.239)	ND(0.211)	ND(0.238)	< 0.223	ND(0.302)	ND(0.324)	0.958	ND(0.582)	ND(0.544)	ND(0.613)	< 0.554	0.554	
	Conc., mg/dscm @ 7% O2	ND(0.302)	ND(0.324)	0.958	ND(0.582)	ND(0.544)	ND(0.613)	< 0.554	ND(0.165)	ND(0.177)	0.524	ND(0.318)	ND(0.282)	ND(0.318)	< 0.297	0.297	
	Conc., mg/dscm @ 12% CO2	ND(0.165)	ND(0.177)	0.524	ND(0.318)	ND(0.282)	ND(0.318)	< 0.297	Conc., ppmvd	ND(0.042)	ND(0.045)	0.133	ND(0.081)	ND(0.072)	ND(0.081)	< 0.076	0.076
	Conc., ppmvd	ND(0.042)	ND(0.045)	0.133	ND(0.081)	ND(0.072)	ND(0.081)	< 0.076	Absolute Difference, ppmvd (<0.2 required)	ND(0.102)	ND(0.110)	0.325	ND(0.198)	ND(0.184)	ND(0.208)	< 0.188	0.188
	Absolute Difference, ppmvd (<0.2 required)	ND(0.102)	ND(0.110)	0.325	ND(0.198)	ND(0.184)	ND(0.208)	< 0.188	Conc., ppmvd @ 7% O2	ND(0.056)	ND(0.060)	0.178	ND(0.108)	ND(0.096)	ND(0.108)	< 0.101	0.101
	Conc., ppmvd @ 7% O2	ND(0.056)	ND(0.060)	0.178	ND(0.108)	ND(0.096)	ND(0.108)	< 0.101	Emission Rate, lb/hr	ND(0.156)	ND(0.181)	0.507	ND(0.317)	ND(0.274)	ND(0.319)	< 0.292	0.292
	Emission Rate, lb/hr	ND(0.156)	ND(0.181)	0.507	ND(0.317)	ND(0.274)	ND(0.319)	< 0.292	Clinker Rates (mtph and lbs/ton)	130.96	ND(0.0012)	130.96	ND(0.0029)	130.96	ND(0.0021)	< 0.0020	0.0020
	Clinker Rates (mtph and lbs/ton)	130.96	ND(0.0012)	130.96	ND(0.0029)	130.96	ND(0.0021)	< 0.0020									

Helcim Midlothian TX
 Line 1 Main Stack: Raw Mill On
 Run 2

Spectrum	Date	Time	HCN:PCA 191c R1 191c	HF ppm (10) 19 SF6 (10) 191C	Ethylene (100:3000) 191C H2O% (40) 191C	CO2% (40) 191C
SPC_001589.LAB	11/15/23	10:32:31.133	20.280	0.092	5.967	14.675
SPC_001590.LAB	11/15/23	10:33:35.046	20.108	-0.007	5.985	15.492
SPC_001591.LAB	11/15/23	10:34:39.019	20.112	-0.004	5.828	15.948
SPC_001592.LAB	11/15/23	10:35:42.803	19.453	-0.006	5.891	17.156
SPC_001593.LAB	11/15/23	10:36:46.766	19.477	-0.007	5.801	17.525
SPC_001594.LAB	11/15/23	10:37:50.605	19.279	-0.006	5.787	17.744
SPC_001595.LAB	11/15/23	10:38:54.842	19.421	-0.005	5.685	17.809
SPC_001596.LAB	11/15/23	10:39:58.409	19.444	-0.004	5.758	17.499
SPC_001597.LAB	11/15/23	10:41:02.352	19.468	-0.003	5.790	17.663
SPC_001598.LAB	11/15/23	10:42:06.264	19.665	-0.006	5.682	17.613
SPC_001599.LAB	11/15/23	10:43:10.152	19.687	-0.004	5.750	17.181
SPC_001600.LAB	11/15/23	10:44:14.349	19.554	-0.004	5.678	17.428
SPC_001601.LAB	11/15/23	10:45:17.907	19.561	-0.004	5.662	17.226
SPC_001602.LAB	11/15/23	10:46:21.853	19.710	-0.005	5.691	17.227
SPC_001603.LAB	11/15/23	10:47:25.752	19.542	-0.003	5.614	17.274
SPC_001604.LAB	11/15/23	10:48:29.655	19.512	-0.004	5.609	17.214
SPC_001605.LAB	11/15/23	10:49:33.514	19.660	-0.004	5.720	17.723
SPC_001606.LAB	11/15/23	10:50:37.372	19.380	-0.007	5.814	18.012
SPC_001607.LAB	11/15/23	10:51:41.405	19.518	-0.002	5.663	17.621
SPC_001608.LAB	11/15/23	10:52:45.581	19.291	-0.005	5.655	17.983
SPC_001609.LAB	11/15/23	10:53:49.159	19.095	-0.006	5.665	18.401
SPC_001610.LAB	11/15/23	10:54:53.048	19.509	-0.003	5.640	17.335
SPC_001611.LAB	11/15/23	10:55:57.317	19.346	-0.006	5.728	17.343
SPC_001612.LAB	11/15/23	10:57:00.814	19.472	-0.006	5.600	17.498
SPC_001613.LAB	11/15/23	10:58:04.716	19.384	-0.005	5.596	17.443
SPC_001614.LAB	11/15/23	10:59:08.617	19.666	-0.006	5.596	17.562
SPC_001615.LAB	11/15/23	11:00:12.565	19.096	-0.006	5.551	18.311
SPC_001616.LAB	11/15/23	11:01:16.411	19.125	-0.004	5.600	17.781
SPC_001617.LAB	11/15/23	11:02:20.320	19.189	-0.004	5.594	17.416
SPC_001618.LAB	11/15/23	11:03:24.216	19.065	-0.004	5.654	17.801
SPC_001619.LAB	11/15/23	11:04:28.209	19.130	-0.007	5.611	17.592
SPC_001620.LAB	11/15/23	11:05:32.025	19.007	-0.006	5.804	17.949
SPC_001621.LAB	11/15/23	11:06:35.951	18.947	-0.006	5.855	17.635
SPC_001622.LAB	11/15/23	11:07:39.911	19.026	-0.005	5.785	17.459
SPC_001623.LAB	11/15/23	11:08:43.722	18.603	-0.009	5.749	18.566
SPC_001624.LAB	11/15/23	11:09:47.902	19.045	-0.004	5.719	17.355
SPC_001625.LAB	11/15/23	11:10:51.901	18.927	-0.005	5.693	17.596
SPC_001626.LAB	11/15/23	11:11:55.811	19.186	-0.006	5.713	17.340
SPC_001627.LAB	11/15/23	11:12:59.374	19.051	-0.007	5.674	17.587
SPC_001628.LAB	11/15/23	11:14:03.259	19.034	-0.004	5.640	17.689
SPC_001629.LAB	11/15/23	11:15:07.165	19.174	-0.003	5.643	17.335
SPC_001630.LAB	11/15/23	11:16:11.094	18.905	-0.009	5.710	17.769
SPC_001631.LAB	11/15/23	11:17:14.922	19.088	-0.004	5.657	18.094
SPC_001632.LAB	11/15/23	11:18:18.825	19.009	-0.006	5.691	17.864
SPC_001633.LAB	11/15/23	11:19:22.787	18.650	-0.003	5.641	18.757
SPC_001634.LAB	11/15/23	11:20:26.623	18.724	-0.008	5.644	17.804
SPC_001635.LAB	11/15/23	11:21:30.525	18.747	-0.005	5.687	18.019
SPC_001636.LAB	11/15/23	11:22:34.421	18.441	-0.006	5.602	18.546
SPC_001637.LAB	11/15/23	11:23:38.321	18.442	-0.006	5.635	18.443
SPC_001638.LAB	11/15/23	11:24:42.224	18.615	-0.004	5.507	17.950
SPC_001639.LAB	11/15/23	11:25:46.501	18.389	-0.006	5.619	18.531
SPC_001640.LAB	11/15/23	11:26:50.050	18.652	-0.005	5.644	17.604
SPC_001641.LAB	11/15/23	11:27:54.010	18.650	-0.006	5.628	17.712
SPC_001642.LAB	11/15/23	11:28:57.813	18.546	-0.006	5.743	17.969
SPC_001643.LAB	11/15/23	11:30:02.099	18.929	-0.004	5.760	17.627
SPC_001644.LAB	11/15/23	11:31:05.993	18.995	-0.005	5.858	17.474
SPC_001645.LAB	11/15/23	11:32:09.508	19.258	-0.005	5.834	17.184
SPC_001646.LAB	11/15/23	11:33:13.505	19.204	-0.008	5.933	17.346
SPC_001647.LAB	11/15/23	11:34:17.609	18.880	-0.006	5.846	17.346
SPC_001648.LAB	11/15/23	11:35:21.209	18.900	-0.005	5.822	18.014
SPC_001649.LAB	11/15/23	11:36:25.139	18.852	-0.006	5.891	17.746
SPC_001650.LAB	11/15/23	11:37:29.054	18.785	-0.005	5.847	18.001
SPC_001651.LAB	11/15/23	11:38:32.907	18.954	-0.006	5.957	17.842
SPC_001652.LAB	11/15/23	11:39:36.810	18.624	-0.004	5.856	18.362
SPC_001653.LAB	11/15/23	11:40:40.813	18.879	-0.004	5.866	17.805
SPC_001654.LAB	11/15/23	11:41:44.813	19.159	-0.005	5.725	17.625

Mill On Run 2 Averages
 Oxygen 15.2% (actual)
 DSCFM 349.600 (ppm.dry@7% O2)
 metric tons/hr 130.96 (lbs/hr)
 metric tons/hr 34.039 (lbs/ton clinker)
 0.236

M26A Average Moisture
 17.2

Helcim Midlothian TX
Line 1 Main Stack: Raw Mill On

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191c SF6 (10) 191c	Ethylene (100,3000) 191c H2O% (40) 191c	CO2% (40) 191c
SFC_001672.LAB	11/15/23	12:02:55.133	19.107	-0.005	5.758	6.832
SFC_001673.LAB	11/15/23	12:03:59.071	18.788	-0.006	5.831	6.868
SFC_001674.LAB	11/15/23	12:05:02.927	19.155	-0.004	5.831	6.866
SFC_001675.LAB	11/15/23	12:06:07.136	18.582	-0.003	5.864	6.784
SFC_001676.LAB	11/15/23	12:07:10.682	19.064	-0.003	5.841	6.745
SFC_001677.LAB	11/15/23	12:08:14.616	18.763	-0.005	5.762	6.943
SFC_001678.LAB	11/15/23	12:09:18.523	18.869	-0.005	5.902	6.824
SFC_001679.LAB	11/15/23	12:10:22.419	19.032	-0.005	5.876	7.125
SFC_001680.LAB	11/15/23	12:11:26.395	19.196	-0.001	5.984	6.833
SFC_001681.LAB	11/15/23	12:12:30.270	19.064	-0.004	5.814	6.904
SFC_001682.LAB	11/15/23	12:13:34.161	19.133	-0.004	5.857	6.775
SFC_001683.LAB	11/15/23	12:14:38.395	19.176	-0.005	5.867	6.880
SFC_001684.LAB	11/15/23	12:15:41.967	19.351	-0.004	5.909	6.858
SFC_001685.LAB	11/15/23	12:16:46.122	19.186	-0.007	5.867	6.798
SFC_001686.LAB	11/15/23	12:17:50.020	19.530	-0.006	5.922	6.825
SFC_001687.LAB	11/15/23	12:18:53.919	19.340	-0.005	5.979	6.864
SFC_001688.LAB	11/15/23	12:19:57.515	19.589	-0.005	5.982	6.875
SFC_001689.LAB	11/15/23	12:21:01.499	19.889	-0.007	6.010	6.872
SFC_001690.LAB	11/15/23	12:22:05.384	19.748	-0.005	6.008	6.874
SFC_001691.LAB	11/15/23	12:23:09.170	19.814	-0.005	6.031	6.898
SFC_001692.LAB	11/15/23	12:24:13.063	19.325	-0.005	5.931	6.859
SFC_001693.LAB	11/15/23	12:25:17.017	19.514	-0.006	6.034	7.036
SFC_001694.LAB	11/15/23	12:26:20.908	19.174	-0.005	6.122	7.226
SFC_001695.LAB	11/15/23	12:27:25.134	19.445	-0.005	6.137	7.005
SFC_001696.LAB	11/15/23	12:28:29.031	19.126	-0.006	6.059	6.961
SFC_001697.LAB	11/15/23	12:29:32.650	19.173	-0.006	5.997	6.868
SFC_001698.LAB	11/15/23	12:30:36.453	18.847	-0.005	6.073	6.900
SFC_001699.LAB	11/15/23	12:31:40.417	19.126	-0.004	5.967	6.875
SFC_001700.LAB	11/15/23	12:32:44.255	18.940	-0.006	6.075	6.978
SFC_001701.LAB	11/15/23	12:33:48.151	18.921	-0.004	5.923	6.812
SFC_001702.LAB	11/15/23	12:34:52.048	19.074	-0.005	5.954	6.848
SFC_001703.LAB	11/15/23	12:35:55.963	19.229	-0.004	6.049	6.962
SFC_001704.LAB	11/15/23	12:36:59.846	18.883	-0.005	6.016	6.972
SFC_001705.LAB	11/15/23	12:38:03.743	19.373	-0.006	6.048	6.958
SFC_001706.LAB	11/15/23	12:39:07.709	19.281	-0.005	5.889	6.865
SFC_001707.LAB	11/15/23	12:40:11.539	19.211	-0.003	5.948	6.900
SFC_001708.LAB	11/15/23	12:41:15.797	19.104	-0.005	5.883	7.017
SFC_001709.LAB	11/15/23	12:42:19.344	19.173	-0.005	5.946	7.087
SFC_001710.LAB	11/15/23	12:43:23.236	19.504	-0.004	5.973	6.938
SFC_001711.LAB	11/15/23	12:44:27.135	19.319	-0.006	5.866	6.845
SFC_001712.LAB	11/15/23	12:45:31.039	19.264	-0.004	5.881	6.861
SFC_001713.LAB	11/15/23	12:46:34.990	19.666	-0.005	5.805	6.753
SFC_001714.LAB	11/15/23	12:47:38.829	19.503	-0.003	5.876	6.821
SFC_001715.LAB	11/15/23	12:48:42.734	19.370	-0.003	5.871	6.750
SFC_001716.LAB	11/15/23	12:49:46.627	19.339	-0.005	5.786	6.886
SFC_001717.LAB	11/15/23	12:50:50.524	19.622	-0.005	5.914	6.916
SFC_001718.LAB	11/15/23	12:51:54.468	19.660	-0.005	5.904	6.928
SFC_001719.LAB	11/15/23	12:52:58.375	19.547	-0.005	6.047	6.980
SFC_001720.LAB	11/15/23	12:54:02.307	19.291	-0.007	6.089	6.850
SFC_001721.LAB	11/15/23	12:55:06.128	19.636	-0.004	6.084	6.832
SFC_001722.LAB	11/15/23	12:56:10.137	19.517	-0.008	6.164	6.870
SFC_001723.LAB	11/15/23	12:57:13.946	19.287	-0.004	6.167	7.091
SFC_001724.LAB	11/15/23	12:58:17.874	19.734	-0.008	6.394	7.255
SFC_001725.LAB	11/15/23	12:59:21.718	19.521	-0.005	6.298	7.012
SFC_001726.LAB	11/15/23	13:00:25.681	20.001	-0.006	6.322	6.916
SFC_001727.LAB	11/15/23	13:01:29.520	20.005	-0.007	6.238	6.836
SFC_001728.LAB	11/15/23	13:02:33.478	19.735	-0.004	6.125	6.867
SFC_001729.LAB	11/15/23	13:03:37.327	19.909	-0.006	6.167	6.781
SFC_001730.LAB	11/15/23	13:04:41.218	19.763	-0.006	5.907	6.851
SFC_001731.LAB	11/15/23	13:05:45.112	19.743	-0.005	5.907	6.857
SFC_001732.LAB	11/15/23	13:06:49.013	19.831	-0.005	5.864	6.781
SFC_001733.LAB	11/15/23	13:07:52.951	19.629	-0.003	6.008	6.956
SFC_001734.LAB	11/15/23	13:08:56.913	19.819	-0.005	5.880	6.818
SFC_001735.LAB	11/15/23	13:10:01.094	19.602	-0.005	5.875	6.893
SFC_001736.LAB	11/15/23	13:11:04.806	19.993	-0.006	5.868	6.880
Mill On Run 3 Averages		(actual)	60.065	-0.006	5.963	6.956
Oxygen		(ppm_dry @7% O2)	34.554	0.088	5.970	6.901
DSCFM		(lbs/hr)	0.239	0.117		
metric tons/hr		(lbs/ton clinker)	0.001	0.001		
M26A Average Moisture					17.0	

Company: Holcim; Midlothian TX
Source: Line 1 Main Stack; Raw Mill Off
Job ID: 23-3313
Train Type: EPA Method 26A

"ND()" denotes values below detection limits
Note: Average EXCLUDES Non-detect runs' results

		4A		4B		5A		5B		6A		6B		Average	
		11/15/23		11/15/23		11/15/23		11/15/23		11/15/23		11/15/23			
		1432-1541		1432-1541		1556-1705		1556-1705		1719-1828		1719-1828			
Hydrogen Fluoride	Catch Wt, mg	ND(0.113)	ND(0.161)	ND(0.147)	ND(0.142)	ND(0.15)) (0.121)	D(0.139)							
	Conc., mg/dscm	ND(0.090)	ND(0.110)	ND(0.108)	ND(0.104)	ND(0.115)) (0.090)	D(0.103)							
	Conc., mg/dscm @7% O2	ND(0.184)	ND(0.224)	ND(0.218)	ND(0.209)	ND(0.218)) (0.172)	D(0.204)							
	Conc., mg/dscm @12% CO2	ND(0.101)	ND(0.123)	ND(0.120)	ND(0.116)	ND(0.121)) (0.095)	D(0.113)							
	Conc., ppmvd	ND(0.108)	ND(0.132)	ND(0.130)	ND(0.125)	ND(0.138)) (0.109)	D(0.124)							
	Conc., ppmvd @7% O2	ND(0.221)	ND(0.269)	ND(0.262)	ND(0.252)	ND(0.262)) (0.207)	D(0.246)							
	Conc., ppmvd @12% CO2	ND(0.121)	ND(0.148)	ND(0.145)	ND(0.139)	ND(0.145)) (0.114)	D(0.135)							
	Emission Rate, lb/hr	ND(0.107)	ND(0.146)	ND(0.133)	ND(0.129)	ND(0.132)) (0.108)	D(0.126)							
	Clinker Rates (mtp and lbs/ton)	130.96	ND(0.0009)	130.96	ND(0.0009)	130.96	ND(0.0008)) (0.0008)	D(0.0009)						
	Chlorine	Catch Wt, mg	1.24	1.59	0.533	1.05	0.945) (0.285)	0.893						
Conc., mg/dscm		0.986	1.082	0.393	0.769	0.721) (0.213)	0.658							
Conc., mg/dscm @7% O2		2.015	2.212	0.791	1.548	1.374) (0.406)	1.323							
Conc., mg/dscm @12% CO2		1.105	1.214	0.436	0.854	0.759) (0.224)	0.728							
Conc., ppmvd		0.334	0.367	0.133	0.261	0.245) (0.072)	0.223							
Absolute Difference, ppmvd (<0.2 required)			0.03		0.13		0.17								
Conc., ppmvd @7% O2		0.684	0.751	0.268	0.525	0.466) (0.138)	0.449							
Conc., ppmvd @12% CO2		0.375	0.412	0.148	0.290	0.258) (0.076)	0.247							
Emission Rate, lb/hr		1.180	1.445	0.481	0.956	0.835) (0.255)	0.816							
Clinker Rates (mtp and lbs/ton)	130.96	0.0091	130.96	0.0050	130.96	ND(0.0038)	< 0.0059								

Helcim Midchlorian TX

Line 1 Main Stack; Raw Mill Off

Run 1

Spectrum	Date	Time	HCN PCA 191c-R1 191c	HF ppm (10) 19 SF6 (10) 191c	Ethylene (100.3000) 19-H2O% (40) 191c	CO2% (40) 191c
SFC_001807.LAB	11/15/23	14:32:58.170	23.681	0.113	6.878	16.004
SFC_001808.LAB	11/15/23	14:34:01.784	24.114	0.055	6.856	16.768
SFC_001809.LAB	11/15/23	14:35:05.967	23.916	0.129	6.854	17.709
SFC_001810.LAB	11/15/23	14:36:09.778	22.876	-0.008	6.858	8.237
SFC_001811.LAB	11/15/23	14:37:13.381	23.189	-0.011	6.824	19.171
SFC_001812.LAB	11/15/23	14:38:17.278	22.797	0.049	6.871	8.180
SFC_001813.LAB	11/15/23	14:39:21.525	22.672	-0.007	6.841	8.191
SFC_001814.LAB	11/15/23	14:40:25.072	22.649	-0.009	6.836	8.057
SFC_001815.LAB	11/15/23	14:41:28.968	22.759	-0.007	6.844	8.148
SFC_001816.LAB	11/15/23	14:42:33.166	22.563	-0.005	6.855	8.153
SFC_001817.LAB	11/15/23	14:43:37.119	22.852	0.020	6.873	8.230
SFC_001818.LAB	11/15/23	14:44:40.664	22.589	-0.008	6.919	8.938
SFC_001819.LAB	11/15/23	14:45:44.561	22.286	-0.002	6.872	8.180
SFC_001820.LAB	11/15/23	14:46:48.837	22.740	0.015	6.749	8.157
SFC_001821.LAB	11/15/23	14:47:52.399	22.503	-0.003	6.809	8.066
SFC_001822.LAB	11/15/23	14:48:56.251	22.789	-0.007	6.817	8.277
SFC_001823.LAB	11/15/23	14:50:00.150	22.789	-0.007	6.817	8.277
SFC_001824.LAB	11/15/23	14:51:04.046	22.789	-0.001	6.782	8.303
SFC_001825.LAB	11/15/23	14:52:07.946	22.942	-0.008	6.703	8.158
SFC_001826.LAB	11/15/23	14:53:11.887	22.773	0.001	6.608	8.192
SFC_001827.LAB	11/15/23	14:54:16.115	22.923	-0.008	6.762	18.616
SFC_001828.LAB	11/15/23	14:55:19.638	22.945	-0.009	6.648	18.488
SFC_001829.LAB	11/15/23	14:56:23.562	22.723	0.010	6.567	8.843
SFC_001830.LAB	11/15/23	14:57:27.564	22.828	-0.001	6.682	18.681
SFC_001831.LAB	11/15/23	14:58:31.814	22.979	-0.005	6.673	8.060
SFC_001832.LAB	11/15/23	14:59:35.579	22.972	-0.012	6.768	8.119
SFC_001833.LAB	11/15/23	15:00:39.123	22.941	-0.008	6.640	8.127
SFC_001834.LAB	11/15/23	15:01:43.285	22.461	-0.010	6.931	8.134
SFC_001835.LAB	11/15/23	15:02:46.964	22.383	-0.001	6.888	8.006
SFC_001836.LAB	11/15/23	15:03:50.907	22.469	-0.013	6.487	18.773
SFC_001837.LAB	11/15/23	15:04:54.712	22.595	-0.027	6.474	18.499
SFC_001838.LAB	11/15/23	15:05:58.608	22.417	-0.021	6.465	8.877
SFC_001839.LAB	11/15/23	15:07:02.504	22.058	-0.035	6.391	18.948
SFC_001840.LAB	11/15/23	15:08:06.821	22.347	-0.009	6.299	18.548
SFC_001841.LAB	11/15/23	15:09:10.299	22.464	-0.025	6.307	8.116
SFC_001842.LAB	11/15/23	15:10:14.255	22.148	-0.039	6.228	19.079
SFC_001843.LAB	11/15/23	15:11:18.146	22.328	-0.015	6.317	8.016
SFC_001844.LAB	11/15/23	15:12:22.412	22.498	-0.035	6.321	8.134
SFC_001845.LAB	11/15/23	15:13:26.890	22.533	-0.018	6.275	8.094
SFC_001846.LAB	11/15/23	15:14:29.817	22.352	-0.041	6.380	8.082
SFC_001847.LAB	11/15/23	15:15:33.687	22.061	-0.032	6.336	7.955
SFC_001848.LAB	11/15/23	15:16:37.584	22.445	-0.027	6.557	8.022
SFC_001849.LAB	11/15/23	15:17:41.467	22.362	-0.008	6.346	8.018
SFC_001850.LAB	11/15/23	15:18:45.377	21.815	-0.040	6.201	7.975
SFC_001851.LAB	11/15/23	15:19:49.353	22.086	-0.008	6.015	7.960
SFC_001852.LAB	11/15/23	15:20:53.171	22.039	-0.009	6.039	7.960
SFC_001853.LAB	11/15/23	15:21:57.074	21.958	-0.036	5.998	8.239
SFC_001854.LAB	11/15/23	15:23:00.969	21.888	-0.034	5.988	8.103
SFC_001855.LAB	11/15/23	15:24:04.869	22.188	-0.044	6.032	8.103
SFC_001856.LAB	11/15/23	15:25:08.764	22.503	-0.031	6.186	8.081
SFC_001857.LAB	11/15/23	15:26:12.708	22.162	-0.036	6.206	8.068
SFC_001858.LAB	11/15/23	15:27:16.563	22.234	-0.036	6.147	8.110
SFC_001859.LAB	11/15/23	15:28:20.458	21.870	-0.036	6.071	8.153
SFC_001860.LAB	11/15/23	15:29:24.355	21.915	-0.030	6.225	8.225
SFC_001861.LAB	11/15/23	15:30:28.297	21.762	-0.039	6.302	8.250
SFC_001862.LAB	11/15/23	15:31:32.151	21.917	-0.039	6.368	8.229
SFC_001863.LAB	11/15/23	15:32:36.049	21.640	-0.044	6.374	18.052
SFC_001864.LAB	11/15/23	15:33:39.947	22.444	-0.047	6.281	19.563
SFC_001865.LAB	11/15/23	15:34:43.843	22.866	-0.047	6.487	8.079
SFC_001866.LAB	11/15/23	15:35:47.743	22.444	-0.047	6.487	8.163
SFC_001867.LAB	11/15/23	15:36:51.675	21.739	-0.033	6.206	8.031
SFC_001868.LAB	11/15/23	15:37:55.580	21.666	-0.044	5.925	8.212
SFC_001869.LAB	11/15/23	15:38:59.432	22.011	-0.036	5.959	8.381
SFC_001870.LAB	11/15/23	15:40:03.382	22.166	-0.034	5.891	8.162
SFC_001871.LAB	11/15/23	15:41:07.261	21.916	-0.040	5.936	8.169
SFC_001872.LAB	11/15/23	15:42:11.140	21.812	-0.052	5.983	8.070
SFC_001873.LAB	11/15/23	15:43:15.019	22.464	-0.024	5.889	8.105
SFC_001874.LAB	11/15/23	15:44:18.900	22.523	-0.032	6.452	8.168

Mill Off Run 1 Averages
 Oxygen 14.1% (actual)
 DSCFM 339.000 (lbs/hr)
 metric tons/hr 130.96 (lbs/ton Clinker) 0.271

M2EA Average Moisture 18.4
 0.080
 0.041
 0.003

Holcim Midlothian TX
Line 1 Main Stack, Raw Mill Off

Run 2	Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 19-Sf6 (10) 191C	Ethylene (100,3000) 191C H2O% (40) 191C	CO2% (40) 191C
SFC_001885.LAB	11/15/23	15:57:40.634	22.397	-0.025	-0.008	6.834	18.029
SFC_001886.LAB	11/15/23	15:58:44.529	22.263	-0.028	-0.006	7.012	18.289
SFC_001887.LAB	11/15/23	15:59:48.781	22.465	-0.038	-0.007	7.049	18.270
SFC_001888.LAB	11/15/23	16:00:52.328	22.517	-0.031	-0.005	6.999	18.897
SFC_001889.LAB	11/15/23	16:01:56.224	22.294	-0.039	-0.009	6.809	18.888
SFC_001890.LAB	11/15/23	16:03:00.213	22.261	-0.035	-0.004	6.702	18.436
SFC_001891.LAB	11/15/23	16:04:04.063	22.235	-0.040	-0.007	6.702	18.717
SFC_001892.LAB	11/15/23	16:05:08.316	22.363	-0.034	-0.007	6.459	18.161
SFC_001893.LAB	11/15/23	16:06:11.815	22.481	-0.032	-0.004	6.348	18.567
SFC_001894.LAB	11/15/23	16:07:16.099	22.003	-0.042	-0.007	6.108	19.164
SFC_001895.LAB	11/15/23	16:08:19.609	21.750	-0.034	-0.005	5.960	19.065
SFC_001896.LAB	11/15/23	16:09:23.508	21.714	-0.036	-0.007	6.014	18.821
SFC_001897.LAB	11/15/23	16:10:27.407	21.980	-0.050	-0.006	5.871	18.907
SFC_001898.LAB	11/15/23	16:11:31.306	21.368	-0.062	-0.006	5.846	19.815
SFC_001899.LAB	11/15/23	16:12:35.329	21.827	-0.045	-0.008	5.981	18.725
SFC_001900.LAB	11/15/23	16:13:39.620	21.719	-0.037	-0.007	6.075	18.449
SFC_001901.LAB	11/15/23	16:14:43.048	21.672	-0.044	-0.004	6.114	18.629
SFC_001902.LAB	11/15/23	16:15:46.943	21.482	-0.027	-0.005	6.117	19.029
SFC_001903.LAB	11/15/23	16:16:50.892	21.275	-0.044	-0.006	6.208	19.229
SFC_001904.LAB	11/15/23	16:17:54.739	21.517	-0.037	-0.005	6.340	18.556
SFC_001905.LAB	11/15/23	16:18:58.686	21.546	-0.037	-0.008	6.401	18.869
SFC_001906.LAB	11/15/23	16:20:02.488	21.542	-0.035	-0.006	6.288	19.751
SFC_001907.LAB	11/15/23	16:21:06.444	21.219	-0.035	-0.007	6.410	19.180
SFC_001908.LAB	11/15/23	16:22:10.524	21.610	-0.040	-0.007	6.586	18.711
SFC_001909.LAB	11/15/23	16:23:14.182	21.709	-0.040	-0.007	6.379	18.900
SFC_001910.LAB	11/15/23	16:24:18.465	21.170	-0.042	-0.006	6.404	19.265
SFC_001911.LAB	11/15/23	16:25:22.023	21.532	-0.055	-0.004	6.410	18.916
SFC_001912.LAB	11/15/23	16:26:25.876	21.734	-0.047	-0.007	6.415	18.829
SFC_001913.LAB	11/15/23	16:27:29.848	21.498	-0.047	-0.006	6.332	19.305
SFC_001914.LAB	11/15/23	16:28:33.688	21.614	-0.043	-0.007	6.346	19.394
SFC_001915.LAB	11/15/23	16:29:37.567	21.573	-0.036	-0.007	6.363	19.365
SFC_001916.LAB	11/15/23	16:30:41.945	21.512	-0.053	-0.007	6.460	18.936
SFC_001917.LAB	11/15/23	16:31:45.403	21.560	-0.069	-0.008	6.519	18.969
SFC_001918.LAB	11/15/23	16:32:49.256	21.773	-0.052	-0.006	6.471	18.859
SFC_001919.LAB	11/15/23	16:33:53.150	21.638	-0.045	-0.006	6.529	19.056
SFC_001920.LAB	11/15/23	16:34:57.074	21.622	-0.042	-0.005	6.586	18.976
SFC_001921.LAB	11/15/23	16:36:01.335	21.636	-0.046	-0.008	6.464	19.209
SFC_001922.LAB	11/15/23	16:37:04.894	21.447	-0.044	-0.006	6.439	19.653
SFC_001923.LAB	11/15/23	16:38:08.743	21.453	-0.040	-0.007	6.287	19.658
SFC_001924.LAB	11/15/23	16:39:12.931	21.359	-0.050	-0.008	6.400	19.454
SFC_001925.LAB	11/15/23	16:40:16.578	21.318	-0.064	-0.005	6.340	19.523
SFC_001926.LAB	11/15/23	16:41:20.840	21.027	-0.049	-0.010	6.570	19.269
SFC_001927.LAB	11/15/23	16:42:24.719	20.984	-0.045	-0.009	6.686	19.599
SFC_001928.LAB	11/15/23	16:43:28.627	21.270	-0.049	-0.009	6.659	19.537
SFC_001929.LAB	11/15/23	16:44:32.172	21.162	-0.053	-0.006	6.570	19.548
SFC_001930.LAB	11/15/23	16:45:36.025	21.277	-0.044	-0.006	6.243	19.592
SFC_001931.LAB	11/15/23	16:46:40.306	21.116	-0.063	-0.005	6.166	19.949
SFC_001932.LAB	11/15/23	16:47:43.318	20.984	-0.042	-0.009	6.016	20.024
SFC_001933.LAB	11/15/23	16:48:47.715	21.186	-0.048	-0.008	5.916	19.984
SFC_001934.LAB	11/15/23	16:49:51.875	21.276	-0.068	-0.008	5.857	20.169
SFC_001935.LAB	11/15/23	16:50:55.552	21.145	-0.056	-0.007	5.711	20.293
SFC_001936.LAB	11/15/23	16:51:59.404	20.989	-0.066	-0.006	5.792	20.262
SFC_001937.LAB	11/15/23	16:53:03.408	21.148	-0.055	-0.009	5.655	20.299
SFC_001938.LAB	11/15/23	16:54:07.298	20.919	-0.053	-0.007	5.608	20.353
SFC_001939.LAB	11/15/23	16:55:11.130	20.594	-0.063	-0.006	5.584	20.563
SFC_001940.LAB	11/15/23	16:56:14.993	20.607	-0.080	-0.006	5.514	20.293
SFC_001941.LAB	11/15/23	16:57:18.889	20.618	-0.068	-0.009	5.820	19.931
SFC_001942.LAB	11/15/23	16:58:23.173	20.678	-0.048	-0.008	5.937	20.066
SFC_001943.LAB	11/15/23	16:59:26.680	20.967	-0.059	-0.008	6.007	20.524
SFC_001944.LAB	11/15/23	17:00:30.668	21.115	-0.058	-0.006	6.164	19.949
SFC_001945.LAB	11/15/23	17:01:34.523	21.081	-0.056	-0.007	6.226	20.409
SFC_001946.LAB	11/15/23	17:02:38.377	20.972	-0.050	-0.007	6.319	20.615
SFC_001947.LAB	11/15/23	17:03:42.275	21.077	-0.067	-0.008	6.356	19.782
SFC_001948.LAB	11/15/23	17:04:46.556	20.786	-0.033	-0.008	6.519	20.751
Mill Off Run 2 Averages		(actual)	21.477	< 0.032	< 0.007	6.285	19.948
Oxygen		(ppm.dry @7% O2)	52.634	< 0.078			8.335
DSCFM		(lbst/hr)	36.243	< 0.040			8.185
metric tons/hr		(lbst/ton clinker)	0.251	< 0.0003			17.8

M25A Average Moisture

Holcim Midlothian TX
 Line 1 Main Steek Raw Mill Off
 Run 3

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 19-SFs (10) 191c	Ethylene (100,3000) 191c H2O% (40) 191c	CO2% (40) 191c
SFC_001962.LAB	11/15/23	17:19:40.737	21.027	-0.044	6.823	19.261
SFC_001963.LAB	11/15/23	17:20:45.019	21.196	-0.010	6.745	19.643
SFC_001964.LAB	11/15/23	17:21:48.882	21.034	-0.045	6.745	19.643
SFC_001965.LAB	11/15/23	17:22:52.430	21.180	-0.039	6.706	19.689
SFC_001966.LAB	11/15/23	17:23:56.675	21.472	-0.036	6.632	20.476
SFC_001967.LAB	11/15/23	17:25:00.224	21.563	-0.052	6.738	20.688
SFC_001968.LAB	11/15/23	17:26:04.239	21.468	-0.042	6.640	19.749
SFC_001969.LAB	11/15/23	17:27:08.021	21.710	-0.065	6.860	20.685
SFC_001970.LAB	11/15/23	17:28:12.029	21.539	-0.049	6.571	20.084
SFC_001971.LAB	11/15/23	17:29:16.820	21.388	-0.055	6.670	21.301
SFC_001972.LAB	11/15/23	17:30:19.713	20.772	-0.049	6.822	20.506
SFC_001973.LAB	11/15/23	17:31:23.605	20.933	-0.058	6.711	21.497
SFC_001974.LAB	11/15/23	17:32:27.503	20.213	-0.061	6.537	21.000
SFC_001975.LAB	11/15/23	17:33:31.403	20.122	-0.050	6.417	20.483
SFC_001976.LAB	11/15/23	17:34:35.298	19.833	-0.053	6.349	20.693
SFC_001977.LAB	11/15/23	17:35:39.304	19.468	-0.047	6.306	20.700
SFC_001978.LAB	11/15/23	17:36:43.210	19.565	-0.052	6.151	20.776
SFC_001979.LAB	11/15/23	17:37:46.988	19.240	-0.021	6.275	20.829
SFC_001980.LAB	11/15/23	17:38:51.275	19.396	-0.060	6.286	20.521
SFC_001981.LAB	11/15/23	17:39:54.880	19.406	-0.075	6.175	20.441
SFC_001982.LAB	11/15/23	17:40:58.680	19.651	-0.076	6.121	21.270
SFC_001983.LAB	11/15/23	17:42:02.820	19.686	-0.076	6.112	21.034
SFC_001984.LAB	11/15/23	17:43:06.571	19.706	-0.076	6.047	20.645
SFC_001985.LAB	11/15/23	17:44:10.374	19.959	-0.075	6.089	20.139
SFC_001986.LAB	11/15/23	17:45:14.272	20.232	-0.072	6.336	20.015
SFC_001987.LAB	11/15/23	17:46:18.205	20.249	-0.066	6.465	20.160
SFC_001988.LAB	11/15/23	17:47:22.121	20.527	-0.070	6.416	20.553
SFC_001989.LAB	11/15/23	17:48:25.963	20.349	-0.065	6.080	20.160
SFC_001990.LAB	11/15/23	17:49:29.963	20.562	-0.065	5.982	20.958
SFC_001991.LAB	11/15/23	17:50:33.757	20.312	-0.063	5.958	20.261
SFC_001992.LAB	11/15/23	17:51:37.655	20.553	-0.070	5.926	21.125
SFC_001993.LAB	11/15/23	17:52:41.553	20.321	-0.067	6.214	19.894
SFC_001994.LAB	11/15/23	17:53:45.449	20.621	-0.073	6.125	20.934
SFC_001995.LAB	11/15/23	17:54:49.345	20.165	-0.059	6.214	20.021
SFC_001996.LAB	11/15/23	17:55:53.355	20.634	-0.090	6.203	20.838
SFC_001997.LAB	11/15/23	17:56:57.458	20.402	-0.072	6.184	19.982
SFC_001998.LAB	11/15/23	17:58:01.438	20.461	-0.064	6.060	21.778
SFC_001999.LAB	11/15/23	17:59:05.202	20.298	-0.064	5.990	20.267
SFC_002000.LAB	11/15/23	18:00:08.832	20.313	-0.064	5.968	21.251
SFC_002001.LAB	11/15/23	18:01:12.775	20.161	-0.048	5.918	20.303
SFC_002002.LAB	11/15/23	18:02:16.672	20.018	-0.074	6.075	20.551
SFC_002003.LAB	11/15/23	18:03:20.536	20.018	-0.068	6.076	20.551
SFC_002004.LAB	11/15/23	18:04:24.494	20.289	-0.076	6.076	20.551
SFC_002005.LAB	11/15/23	18:05:28.700	20.292	-0.059	6.246	21.396
SFC_002006.LAB	11/15/23	18:06:32.576	20.521	-0.083	6.095	19.965
SFC_002007.LAB	11/15/23	18:07:36.113	20.205	-0.066	6.099	20.749
SFC_002008.LAB	11/15/23	18:08:40.016	20.448	-0.059	6.045	19.754
SFC_002009.LAB	11/15/23	18:09:43.906	20.286	-0.065	6.220	19.606
SFC_002010.LAB	11/15/23	18:10:48.191	20.585	-0.071	6.345	20.465
SFC_002011.LAB	11/15/23	18:11:51.803	20.737	-0.076	6.345	20.791
SFC_002012.LAB	11/15/23	18:12:55.597	20.912	-0.068	6.616	20.376
SFC_002013.LAB	11/15/23	18:14:00.048	21.145	-0.077	6.630	20.509
SFC_002014.LAB	11/15/23	18:15:03.394	21.317	-0.059	6.902	20.193
SFC_002015.LAB	11/15/23	18:16:07.290	21.432	-0.067	6.917	20.111
SFC_002016.LAB	11/15/23	18:17:11.319	21.511	-0.062	7.059	19.473
SFC_002017.LAB	11/15/23	18:18:15.086	21.855	-0.080	7.181	19.222
SFC_002018.LAB	11/15/23	18:19:18.980	22.337	-0.060	7.203	19.081
SFC_002019.LAB	11/15/23	18:20:22.878	21.975	-0.053	7.114	19.796
SFC_002020.LAB	11/15/23	18:21:27.162	22.260	-0.075	7.105	18.999
SFC_002021.LAB	11/15/23	18:22:30.714	22.462	-0.067	6.984	19.789
SFC_002022.LAB	11/15/23	18:23:34.611	22.329	-0.051	6.901	20.017
SFC_002023.LAB	11/15/23	18:24:38.500	22.946	-0.071	6.682	20.056
SFC_002024.LAB	11/15/23	18:25:42.753	22.644	-0.074	6.792	19.823
SFC_002025.LAB	11/15/23	18:26:46.279	22.803	-0.064	6.703	19.827
SFC_002026.LAB	11/15/23	18:27:50.156	22.524	-0.069	6.806	20.025
SFC_002027.LAB	11/15/23	18:28:53.994	22.794	-0.032	6.432	20.316
Mill Off Run 34 Averages	13.6%	(actual)	<	<	18.8	
Oxygen	313.950	(ppm,dry @% O2)	<	0.039		
DSCFM	130.96	(lbs/hr)	<	0.075		
metric tons/hr		(lbs/ton clinker)	<	0.0003		
M26A Average Moisture						

Company: Holcim; Midlothian TX
Source: Line 2 Main Stack; Raw Mill Off
Job ID: 23-3313
Train Type: EPA Method 26A

NOTE: Average INCLUDES Non-detect runs' results

"ND()" denotes values below detection limits

		1A		1B		2A		2B		3A		3B		Average
		11/16/23		11/16/23		11/16/23		11/16/23		11/16/23		11/16/23		
		1420-1557		1420-1557		1619-1725		1619-1725		1741-1847		1741-1847		
Hydrogen Fluoride	Catch Wt, mg	ND(0.247)	ND(0.161)	ND(0.168)	ND(0.153)	ND(0.155)	ND(0.155)	ND(0.173)						
	Conc., mg/dscm	ND(0.238)	ND(0.150)	ND(0.163)	ND(0.150)	ND(0.145)	ND(0.150)	ND(0.166)						
	Conc., mg/dscm @ 7% O2	ND(0.418)	ND(0.264)	ND(0.284)	ND(0.260)	ND(0.252)	ND(0.260)	ND(0.290)						
	Conc., mg/dscm @ 12% CO2	ND(0.224)	ND(0.142)	ND(0.148)	ND(0.136)	ND(0.131)	ND(0.135)	ND(0.153)						
	Conc., ppmvd	ND(0.286)	ND(0.181)	ND(0.196)	ND(0.180)	ND(0.174)	ND(0.180)	ND(0.199)						
	Conc., ppmvd @ 7% O2	ND(0.502)	ND(0.318)	ND(0.341)	ND(0.313)	ND(0.303)	ND(0.313)	ND(0.348)						
	Conc., ppmvd @ 12% CO2	ND(0.270)	ND(0.171)	ND(0.178)	ND(0.164)	ND(0.157)	ND(0.162)	ND(0.184)						
	Emission Rate, lb/hr	ND(0.241)	ND(0.153)	ND(0.162)	ND(0.149)	ND(0.144)	ND(0.149)	ND(0.166)						
	Clinker Rates (mtph and lbs/ton)	123.76	ND(0.0014)	123.76	ND(0.0011)	123.72	ND(0.0011)	ND(0.0012)						
Chlorine	Catch Wt, mg	1.08	1.350	1.560	1.160	1.53	1.52	1.37						
	Conc., mg/dscm	1.038	1.259	1.516	1.136	1.430	1.467	1.308						
	Conc., mg/dscm @ 7% O2	1.827	2.216	2.634	1.974	2.484	2.549	2.281						
	Conc., mg/dscm @ 12% CO2	0.981	1.190	1.378	1.033	1.290	1.324	1.199						
	Conc., ppmvd	0.352	0.427	0.514	0.385	0.485	0.498	0.444						
	Absolute Difference, ppmvd (<0.2 required)		0.07		0.13		0.01							
	Conc., ppmvd @ 7% O2	0.620	0.752	0.894	0.670	0.843	0.865	0.774						
	Conc., ppmvd @ 12% CO2	0.333	0.404	0.468	0.350	0.438	0.449	0.407						
	Emission Rate, lb/hr	1.055	1.282	1.507	1.129	1.425	1.462	1.310						
	Clinker Rates (mtph and lbs/ton)	123.76	0.0086	123.76	0.0097	123.72	0.0106	0.0096						

Helcim Midlothian TX

Line 2 Main Stack; Raw Mill Off

Run 1

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C
SPC_002138.LAB	11/16/23	14:20:49.160	22.622	0.393	-0.014	8.059	21.088	9.364
SPC_002139.LAB	11/16/23	14:21:53.320	22.054	0.397	-0.015	8.016	20.273	9.455
SPC_002140.LAB	11/16/23	14:22:56.961	22.621	0.361	-0.012	7.864	21.633	9.337
SPC_002141.LAB	11/16/23	14:24:00.902	22.009	0.329	-0.014	8.145	20.680	9.486
SPC_002142.LAB	11/16/23	14:25:04.815	22.415	0.334	-0.016	7.944	21.858	9.420
SPC_002143.LAB	11/16/23	14:26:08.000	22.163	0.326	-0.015	8.012	20.960	9.523
SPC_002144.LAB	11/16/23	14:27:12.572	21.358	0.313	-0.013	7.857	21.057	9.524
SPC_002145.LAB	11/16/23	14:28:16.486	21.169	0.316	-0.014	7.604	20.701	9.528
SPC_002146.LAB	11/16/23	14:29:20.422	21.525	0.285	-0.012	7.331	21.393	9.480
SPC_002147.LAB	11/16/23	14:30:24.324	21.165	0.276	-0.011	7.466	20.525	9.489
SPC_002148.LAB	11/16/23	14:31:28.185	21.252	0.266	-0.014	7.713	21.289	9.500
SPC_002149.LAB	11/16/23	14:32:32.063	21.600	0.275	-0.012	8.074	20.206	9.507
SPC_002150.LAB	11/16/23	14:33:35.982	22.690	0.258	-0.013	7.871	21.075	9.454
SPC_002151.LAB	11/16/23	14:34:39.888	22.744	0.235	-0.010	8.236	20.863	9.545
SPC_002152.LAB	11/16/23	14:35:44.042	23.304	0.226	-0.011	8.307	20.712	9.658
SPC_002153.LAB	11/16/23	14:36:47.730	22.893	0.228	-0.012	8.308	21.254	9.675
SPC_002154.LAB	11/16/23	14:37:51.594	22.678	0.222	-0.009	8.356	20.540	9.611
SPC_002155.LAB	11/16/23	14:38:55.534	22.410	0.220	-0.013	8.270	21.118	9.630
SPC_002156.LAB	11/16/23	14:39:59.481	22.282	0.210	-0.010	8.529	20.785	9.680
SPC_002157.LAB	11/16/23	14:41:03.291	22.119	0.214	-0.013	8.483	20.683	9.746
SPC_002158.LAB	11/16/23	14:42:07.239	22.434	0.195	-0.012	8.362	20.787	9.747
SPC_002159.LAB	11/16/23	14:43:11.386	22.225	0.188	-0.011	8.023	21.381	9.717
SPC_002160.LAB	11/16/23	14:44:14.988	22.013	0.199	-0.013	8.091	20.619	9.746
SPC_002161.LAB	11/16/23	14:45:18.961	21.845	0.203	-0.012	7.800	21.575	9.594
SPC_002162.LAB	11/16/23	14:46:22.920	21.905	0.180	-0.012	7.964	21.101	9.578
SPC_002163.LAB	11/16/23	14:47:27.031	21.186	0.189	-0.013	8.698	21.344	9.886
SPC_002164.LAB	11/16/23	14:48:30.663	21.417	0.175	-0.015	8.261	22.093	9.787
SPC_002165.LAB	11/16/23	14:49:34.500	21.913	0.177	-0.014	8.117	21.588	9.522
SPC_002166.LAB	11/16/23	14:50:38.412	21.649	0.191	-0.014	7.923	22.007	9.516
SPC_002167.LAB	11/16/23	14:51:42.300	22.243	0.190	-0.011	8.221	20.304	9.723
SPC_002168.LAB	11/16/23	14:52:46.201	21.322	0.167	-0.013	7.864	21.339	9.511
SPC_002169.LAB	11/16/23	14:53:50.122	22.122	0.144	-0.009	7.926	20.572	9.706
SPC_002170.LAB	11/16/23	14:54:54.011	22.032	0.134	-0.012	7.870	21.654	9.544
SPC_002171.LAB	11/16/23	14:55:58.259	22.155	0.148	-0.015	8.013	20.551	9.475
SPC_002172.LAB	11/16/23	14:57:02.107	22.095	0.148	-0.015	7.870	21.285	9.301
SPC_002173.LAB	11/16/23	14:58:05.740	22.259	0.153	-0.011	8.263	20.991	9.588
SPC_002174.LAB	11/16/23	14:59:09.736	23.287	0.120	-0.013	8.395	20.745	9.578
SPC_002175.LAB	11/16/23	15:00:13.519	23.876	0.145	-0.015	8.550	21.931	9.425
SPC_002176.LAB	11/16/23	15:01:17.402	21.160	0.129	-0.013	7.316	20.490	7.994
Lost RT0								
SPC_002203.LAB	11/16/23	15:30:02.782	19.466	0.103	-0.012	7.211	18.516	7.412
SPC_002204.LAB	11/16/23	15:31:06.993	22.852	0.012	-0.010	8.160	18.652	8.665
SPC_002205.LAB	11/16/23	15:32:10.518	22.140	0.042	-0.010	7.582	18.865	8.239
SPC_002206.LAB	11/16/23	15:33:14.447	21.181	0.032	-0.011	7.160	18.656	7.641
SPC_002207.LAB	11/16/23	15:34:18.595	21.081	0.041	-0.013	7.099	17.399	7.762
SPC_002208.LAB	11/16/23	15:35:22.255	23.333	0.064	-0.012	8.529	18.064	9.180
SPC_002209.LAB	11/16/23	15:36:26.225	23.523	0.067	-0.013	8.162	19.015	8.957
SPC_002210.LAB	11/16/23	15:37:30.344	23.838	0.019	-0.013	8.461	19.249	9.248
SPC_002211.LAB	11/16/23	15:38:33.918	23.658	0.017	-0.014	8.335	19.511	9.223
SPC_002212.LAB	11/16/23	15:39:37.821	25.336	0.034	-0.014	8.649	19.266	9.593
SPC_002213.LAB	11/16/23	15:40:42.051	25.179	0.039	-0.013	8.737	20.229	9.728
SPC_002214.LAB	11/16/23	15:41:45.628	24.118	0.038	-0.011	8.800	20.473	9.733
SPC_002215.LAB	11/16/23	15:42:49.819	24.868	0.020	-0.012	8.954	19.509	9.844
SPC_002216.LAB	11/16/23	15:43:53.422	24.570	0.028	-0.012	8.806	19.776	9.908
SPC_002217.LAB	11/16/23	15:44:57.330	24.677	0.005	-0.012	8.705	20.469	9.801
SPC_002218.LAB	11/16/23	15:46:01.481	24.921	-0.000	-0.011	8.705	20.275	9.766
SPC_002219.LAB	11/16/23	15:47:05.478	24.567	0.002	-0.011	8.661	20.038	9.904
SPC_002220.LAB	11/16/23	15:48:09.028	23.893	0.005	-0.013	9.162	20.465	10.287
SPC_002221.LAB	11/16/23	15:49:13.265	24.391	0.033	-0.011	9.255	20.415	9.959
SPC_002222.LAB	11/16/23	15:50:16.882	23.509	0.019	-0.011	9.054	21.288	9.669
SPC_002223.LAB	11/16/23	15:51:20.728	24.843	0.030	-0.012	8.639	20.477	9.754
SPC_002224.LAB	11/16/23	15:52:24.623	24.721	0.007	-0.012	8.784	20.991	9.700
SPC_002225.LAB	11/16/23	15:53:28.611	24.665	0.006	-0.012	8.757	20.633	9.791
SPC_002226.LAB	11/16/23	15:54:32.431	24.696	0.008	-0.013	8.777	21.200	9.769
SPC_002227.LAB	11/16/23	15:55:36.328	24.398	0.028	-0.013	8.812	20.324	9.849
SPC_002228.LAB	11/16/23	15:56:40.526	23.732	-0.007	-0.012	8.746	21.958	9.659
Mill Off Run 1 Averages		(actual)	22.773	0.147	-0.012	8.235	20.565	9.458
Oxygen		(ppm, dry @ 7% O2)	49.165	0.318				
DSCFM		(lbs/hr)	268.350	0.151				
metric tons/hr		(lbs/ton clinker)	123.76	0.231				
M26A Average Moisture								18.5

Helcim Midlothian TX

Line 2 Main Stack; Raw Mill Off

Run 2

Spectrum	Date	Time	HCN PCA 191c RT 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C
SPC_002247.LAB	11/16/23	16:19:41.050	23.615	-0.031	-0.015	8.187	21.774	9.564
SPC_002248.LAB	11/16/23	16:20:44.979	24.003	-0.005	-0.012	8.349	20.830	9.720
SPC_002249.LAB	11/16/23	16:21:46.899	23.246	-0.024	-0.011	8.064	21.796	9.814
SPC_002250.LAB	11/16/23	16:22:52.801	23.591	-0.029	-0.011	8.337	21.267	9.631
SPC_002251.LAB	11/16/23	16:23:56.739	23.381	-0.031	-0.013	8.184	21.968	9.632
SPC_002252.LAB	11/16/23	16:25:00.609	23.865	-0.031	-0.014	8.192	21.577	9.483
SPC_002253.LAB	11/16/23	16:26:04.453	23.714	-0.040	-0.014	7.904	22.302	9.384
SPC_002254.LAB	11/16/23	16:27:08.354	23.965	0.000	-0.011	8.350	20.978	9.659
SPC_002255.LAB	11/16/23	16:28:12.293	23.391	-0.042	-0.013	8.112	21.495	9.501
SPC_002256.LAB	11/16/23	16:29:16.151	24.020	-0.015	-0.013	8.754	20.392	9.744
SPC_002257.LAB	11/16/23	16:30:20.053	24.479	0.003	-0.015	8.406	21.631	9.538
SPC_002258.LAB	11/16/23	16:31:24.391	24.421	-0.005	-0.013	8.597	20.379	9.642
SPC_002259.LAB	11/16/23	16:32:27.840	24.043	-0.038	-0.010	8.793	21.771	9.829
SPC_002260.LAB	11/16/23	16:33:31.869	24.106	0.008	-0.012	8.606	20.454	9.698
SPC_002261.LAB	11/16/23	16:34:35.640	24.269	-0.023	-0.013	8.380	21.457	9.570
SPC_002262.LAB	11/16/23	16:35:39.541	24.259	-0.001	-0.012	8.688	20.051	9.876
SPC_002263.LAB	11/16/23	16:36:43.768	23.154	-0.038	-0.011	8.468	22.026	9.611
SPC_002264.LAB	11/16/23	16:37:47.378	23.733	-0.021	-0.013	8.715	20.517	9.758
SPC_002265.LAB	11/16/23	16:38:51.603	22.952	0.057	-0.016	8.437	22.248	9.503
SPC_002266.LAB	11/16/23	16:39:55.157	23.625	0.073	-0.015	8.318	21.386	9.548
SPC_002267.LAB	11/16/23	16:40:59.044	24.751	0.032	-0.010	8.557	20.693	9.727
SPC_002268.LAB	11/16/23	16:42:02.944	23.591	-0.012	-0.016	8.387	21.804	9.587
SPC_002269.LAB	11/16/23	16:43:06.847	23.521	-0.017	-0.015	8.149	21.385	9.550
SPC_002270.LAB	11/16/23	16:44:10.736	23.436	-0.014	-0.011	8.035	21.272	9.607
SPC_002271.LAB	11/16/23	16:45:14.686	23.276	-0.006	-0.011	8.088	22.312	9.500
SPC_002272.LAB	11/16/23	16:46:18.798	23.348	-0.019	-0.015	8.418	21.895	9.605
SPC_002273.LAB	11/16/23	16:47:22.740	23.140	-0.027	-0.013	8.584	21.077	9.794
SPC_002274.LAB	11/16/23	16:48:26.339	22.759	-0.021	-0.013	8.528	22.315	9.754
SPC_002275.LAB	11/16/23	16:49:30.246	22.745	-0.016	-0.014	8.756	22.056	9.675
SPC_002276.LAB	11/16/23	16:50:34.359	23.692	-0.026	-0.013	9.024	20.155	9.819
SPC_002277.LAB	11/16/23	16:51:38.351	23.104	-0.020	-0.016	8.564	21.112	9.571
SPC_002278.LAB	11/16/23	16:52:42.060	23.435	-0.026	-0.015	8.593	21.578	9.527
SPC_002279.LAB	11/16/23	16:53:45.839	25.289	-0.003	-0.013	8.729	20.765	9.798
SPC_002280.LAB	11/16/23	16:54:49.758	23.989	-0.031	-0.013	8.605	21.323	9.577
SPC_002281.LAB	11/16/23	16:55:53.650	24.487	-0.006	-0.011	9.128	20.551	9.715
SPC_002282.LAB	11/16/23	16:56:57.528	25.370	-0.012	-0.012	9.582	20.932	9.804
SPC_002283.LAB	11/16/23	16:58:01.520	24.204	-0.003	-0.013	8.893	21.785	9.685
SPC_002284.LAB	11/16/23	16:59:05.374	24.856	-0.007	-0.010	8.881	20.259	9.766
SPC_002285.LAB	11/16/23	17:00:09.264	24.930	-0.027	-0.015	8.659	21.464	9.588
SPC_002286.LAB	11/16/23	17:01:13.164	24.061	-0.009	-0.013	8.923	20.400	9.790
SPC_002287.LAB	11/16/23	17:02:17.019	24.278	-0.011	-0.013	9.003	20.762	9.841
SPC_002288.LAB	11/16/23	17:03:20.911	23.834	-0.032	-0.011	8.756	21.319	9.655
SPC_002289.LAB	11/16/23	17:04:25.136	24.551	-0.015	-0.014	8.882	20.461	9.784
SPC_002290.LAB	11/16/23	17:05:28.715	24.391	-0.009	-0.015	8.391	21.299	9.545
SPC_002291.LAB	11/16/23	17:06:32.626	23.517	-0.033	-0.015	8.068	22.243	9.469
SPC_002292.LAB	11/16/23	17:07:36.951	24.856	-0.025	-0.015	8.874	20.570	9.728
SPC_002293.LAB	11/16/23	17:08:40.456	24.261	-0.023	-0.015	8.278	22.551	9.439
SPC_002294.LAB	11/16/23	17:09:44.419	24.328	-0.005	-0.016	8.408	22.079	9.518
SPC_002295.LAB	11/16/23	17:10:48.250	24.474	-0.019	-0.011	8.996	21.263	9.723
SPC_002296.LAB	11/16/23	17:11:52.360	23.630	-0.051	-0.013	9.111	22.021	9.620
SPC_002297.LAB	11/16/23	17:12:56.011	24.066	-0.044	-0.013	8.793	21.108	9.583
SPC_002298.LAB	11/16/23	17:14:00.038	24.187	-0.031	-0.014	8.541	20.507	9.681
SPC_002299.LAB	11/16/23	17:15:04.074	24.765	-0.015	-0.013	8.635	21.643	9.656
SPC_002300.LAB	11/16/23	17:16:07.714	23.722	-0.047	-0.013	8.671	20.599	9.765
SPC_002301.LAB	11/16/23	17:17:11.924	23.866	-0.047	-0.014	9.074	20.974	9.807
SPC_002302.LAB	11/16/23	17:18:15.759	23.633	-0.037	-0.014	9.169	20.758	9.727
SPC_002303.LAB	11/16/23	17:19:19.397	24.913	-0.048	-0.012	8.873	21.069	9.665
SPC_002304.LAB	11/16/23	17:20:23.618	24.378	-0.016	-0.015	8.534	21.216	9.525
SPC_002305.LAB	11/16/23	17:21:27.331	24.492	-0.023	-0.013	8.553	20.643	9.607
SPC_002306.LAB	11/16/23	17:22:31.094	23.750	-0.072	-0.011	8.544	21.960	9.607
SPC_002307.LAB	11/16/23	17:23:35.350	24.641	-0.041	-0.014	8.727	20.835	9.724
SPC_002308.LAB	11/16/23	17:24:39.150	24.692	-0.027	-0.011	8.561	21.434	9.697
SPC_002309.LAB	11/16/23	17:25:42.900	23.959	0.032	-0.013	8.587	21.271	9.645

Mill Off Run 2 Averages
 Oxygen 12.9% (ppm_ary @% O2)
 DSCFM 265,400 (lbs/hr)
 metric tons/hr 123.76 (lbs/ton clinker) 0.247

M26A Average Moisture
 20.6

Holcim Middleham TX
Line 2 Main Stack; Raw Mill Off
Run 3

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C
SFC_002327.LAB	11/16/23	17:46:36.902	23.893	-0.046	-0.013	8.210	21.482	9.595
SFC_002328.LAB	11/16/23	17:46:40.808	23.948	-0.021	-0.011	8.671	20.394	9.808
SFC_002329.LAB	11/16/23	17:47:44.702	23.831	-0.062	-0.015	9.550	21.217	10.248
SFC_002330.LAB	11/16/23	17:48:46.605	23.474	-0.061	-0.013	9.208	21.921	9.660
SFC_002331.LAB	11/16/23	17:49:52.503	23.819	-0.058	-0.013	9.342	21.606	9.762
SFC_002332.LAB	11/16/23	17:50:56.414	24.255	-0.030	-0.016	8.884	21.409	9.520
SFC_002333.LAB	11/16/23	17:52:00.327	24.744	-0.026	-0.015	8.715	21.384	9.571
SFC_002334.LAB	11/16/23	17:53:04.196	24.756	-0.022	-0.012	8.849	21.341	9.706
SFC_002335.LAB	11/16/23	17:54:08.128	24.459	-0.036	-0.015	8.787	21.464	9.711
SFC_002336.LAB	11/16/23	17:55:11.993	24.082	-0.063	-0.016	8.624	21.977	9.542
SFC_002337.LAB	11/16/23	17:56:15.881	24.285	-0.044	-0.011	8.767	21.478	9.624
SFC_002338.LAB	11/16/23	17:57:19.786	24.951	-0.020	-0.011	8.900	20.248	9.794
SFC_002339.LAB	11/16/23	17:58:23.704	24.990	-0.050	-0.012	8.718	20.902	9.681
SFC_002340.LAB	11/16/23	17:59:27.577	24.408	-0.036	-0.015	8.515	21.385	9.559
SFC_002341.LAB	11/16/23	18:00:31.525	25.447	-0.039	-0.013	8.675	20.918	9.708
SFC_002342.LAB	11/16/23	18:01:35.850	24.037	-0.063	-0.012	8.507	21.487	9.624
SFC_002343.LAB	11/16/23	18:02:39.728	24.576	-0.050	-0.012	8.906	20.713	9.779
SFC_002344.LAB	11/16/23	18:03:43.259	24.775	-0.052	-0.013	8.608	21.444	9.669
SFC_002345.LAB	11/16/23	18:04:47.124	24.394	-0.036	-0.015	8.286	21.630	9.484
SFC_002346.LAB	11/16/23	18:05:51.124	24.269	-0.042	-0.014	8.700	20.703	9.797
SFC_002347.LAB	11/16/23	18:06:54.899	24.839	-0.052	-0.012	8.894	20.615	9.823
SFC_002348.LAB	11/16/23	18:07:58.765	24.209	-0.080	-0.013	8.572	22.032	9.620
SFC_002349.LAB	11/16/23	18:09:02.665	24.158	-0.041	-0.013	9.237	20.338	9.814
SFC_002350.LAB	11/16/23	18:10:06.883	23.379	-0.075	-0.013	8.857	21.846	9.688
SFC_002351.LAB	11/16/23	18:11:10.469	23.579	-0.077	-0.016	8.276	21.615	9.556
SFC_002352.LAB	11/16/23	18:12:14.682	23.837	-0.064	-0.008	8.761	20.238	9.792
SFC_002353.LAB	11/16/23	18:13:18.396	23.460	-0.060	-0.013	8.421	22.238	9.576
SFC_002354.LAB	11/16/23	18:14:22.171	23.603	-0.073	-0.012	8.709	21.786	9.706
SFC_002355.LAB	11/16/23	18:15:26.317	24.027	-0.079	-0.016	8.714	21.835	9.511
SFC_002356.LAB	11/16/23	18:16:29.963	24.838	-0.045	-0.012	8.947	20.758	9.723
SFC_002357.LAB	11/16/23	18:17:34.213	24.303	-0.055	-0.015	8.994	22.138	9.542
SFC_002358.LAB	11/16/23	18:18:38.013	25.207	-0.033	-0.015	8.914	20.828	9.369
SFC_002359.LAB	11/16/23	18:19:41.667	23.408	-0.056	-0.011	10.181	21.218	9.850
SFC_002360.LAB	11/16/23	18:20:45.555	24.101	-0.048	-0.012	9.063	21.019	9.658
SFC_002361.LAB	11/16/23	18:21:49.482	25.466	-0.063	-0.011	9.077	20.580	9.699
SFC_002362.LAB	11/16/23	18:22:53.647	23.850	-0.081	-0.013	8.714	21.412	9.632
SFC_002363.LAB	11/16/23	18:23:57.506	24.436	-0.045	-0.010	8.562	20.314	9.712
SFC_002364.LAB	11/16/23	18:25:01.601	25.154	-0.060	-0.013	8.767	20.707	9.800
SFC_002365.LAB	11/16/23	18:26:05.145	23.921	-0.097	-0.014	8.414	22.005	9.588
SFC_002366.LAB	11/16/23	18:27:08.947	24.029	-0.090	-0.012	8.469	21.377	9.640
SFC_002367.LAB	11/16/23	18:28:12.846	24.546	-0.045	-0.012	8.722	20.165	9.722
SFC_002368.LAB	11/16/23	18:29:16.754	25.114	-0.058	-0.017	8.624	22.019	9.333
SFC_002369.LAB	11/16/23	18:30:20.648	22.524	-0.088	-0.015	11.443	20.792	10.227
SFC_002370.LAB	11/16/23	18:31:24.582	25.068	-0.041	-0.013	9.144	21.463	9.630
SFC_002371.LAB	11/16/23	18:32:28.444	24.318	-0.059	-0.017	8.746	22.144	9.554
SFC_002372.LAB	11/16/23	18:33:32.431	24.445	-0.071	-0.014	8.932	21.621	9.708
SFC_002373.LAB	11/16/23	18:34:36.608	24.931	-0.050	-0.013	8.524	21.119	9.612
SFC_002374.LAB	11/16/23	18:35:40.236	22.947	-0.089	-0.017	9.259	21.983	9.821
SFC_002375.LAB	11/16/23	18:36:44.060	25.079	-0.059	-0.018	8.865	21.116	9.663
SFC_002376.LAB	11/16/23	18:37:48.259	24.328	-0.067	-0.010	8.562	21.884	9.672
SFC_002377.LAB	11/16/23	18:38:51.838	23.610	-0.064	-0.015	8.831	22.477	9.649
SFC_002378.LAB	11/16/23	18:39:55.777	24.749	-0.062	-0.015	8.727	20.434	9.579
SFC_002379.LAB	11/16/23	18:40:59.659	25.137	-0.070	-0.013	8.509	21.722	9.543
SFC_002380.LAB	11/16/23	18:42:03.525	24.525	-0.051	-0.016	8.397	21.934	9.568
SFC_002381.LAB	11/16/23	18:43:07.751	24.722	-0.075	-0.015	8.630	21.907	9.562
SFC_002382.LAB	11/16/23	18:44:11.327	25.294	-0.061	-0.015	9.009	20.321	9.877
SFC_002383.LAB	11/16/23	18:45:15.222	23.868	-0.074	-0.011	9.229	21.297	9.703
SFC_002384.LAB	11/16/23	18:46:19.162	24.319	-0.059	-0.012	9.368	21.012	9.862
SFC_002385.LAB	11/16/23	18:47:23.039	24.204	-0.090	-0.013	9.141	22.044	9.718
SFC_002386.LAB	11/16/23	18:48:26.922	24.322	0.032	-0.013	8.859	21.295	9.681
Mill Off Run 3 Averages		(actual)	<	<	<			
Oxygen		12.9% (ppm.dry @7% O2)	52.825	<	<			
DSCFM		(lbs/hr)	34.044	<	<			
metric tons/hr		(lbs/ton clinker)	0.250	<	<	M26A Average Moisture	20.0	

Company: Hoicim; Midlothian TX
 Source: Line 2 Main Stack; Raw Mill On
 Job ID: 23-3313
 Train Type: EPA Method 26A

	4A	4B	5A	5B	6A	6B	Average
	11/17/23	11/17/23	11/17/23	11/17/23	11/17/23	11/17/23	
	806-912	806-912	930-1036	930-1036	1058-1204	1058-1204	
Initial Meter Volume, ft ³	705.736	160.151	758.867	206.376	810.735	254.891	
Final Meter Volume, ft ³	756.120	206.222	810.588	253.666	861.545	302.737	
Intra-Port Volume and/or Leak Check Correction, ft ³	0.000	0.000	0.000	0.000	0.000	0.000	
Total Sample Volume, cf	50.384	46.071	51.721	47.290	50.810	47.846	49.020
DGM Calibration Factor	0.975	1.014	0.975	1.014	0.975	1.014	0.995
Average DGM Temp, F	64.3	61.9	66.2	63.5	68.0	67.3	65.2
Average DGM delta H, "H ₂ O	2.21	2.15	2.28	2.22	2.23	2.16	2.21
Barometric Pressure, "Hg	28.70	28.70	28.70	28.70	28.70	28.70	28.70
Corrected Sample Vol, dsfc	47.693	45.556	48.790	46.627	47.761	46.828	47.209
Corrected Sample Vol, dscm	1.351	1.290	1.382	1.320	1.352	1.326	1.337
Sample Volume (at Stack Conditions), acf	69.491	65.892	72.181	68.384	69.989	68.284	69.037
Sample Volume (at Stack Conditions), acm	1.968	1.866	2.044	1.936	1.982	1.934	1.955
Oxygen, %	14.0	14.0	13.9	13.9	13.9	13.9	13.9
Carbon Dioxide, %	11.3	11.3	11.4	11.4	11.5	11.5	11.4
Nitrogen, %	74.7	74.7	74.7	74.7	74.6	74.6	74.7
Stack Gas Excess Air, %	244.7	244.7	238.8	238.8	239.9	239.9	241.1
Total Moisture Catch Weight, grams	229.6	211.0	255.1	233.2	239.0	228.5	233.6
Stack Gas Moisture, %	18.5	17.9	19.8	19.1	19.1	18.7	18.9
Stack Gas Dry Molecular Weight, lb/lbmole	30.37	30.37	30.38	30.38	30.40	30.40	30.38
Stack Gas Wet Molecular Weight, lb/lbmole	28.08	28.15	27.93	28.02	28.03	28.08	28.05
Average Stack Temp, F	140.8	140.8	140.3	140.3	139.8	139.8	140.3
Stack Static (Gauge) Pressure, "H ₂ O	-0.35	-0.35	-0.35	-0.35	-0.35	-0.35	-0.35
Stack Gas Actual Pressure, "Hg	28.67	28.67	28.67	28.67	28.67	28.67	28.67
Average Sqrt delta P *	0.933	0.933	0.949	0.949	0.935	0.935	0.939
Pitot Tube Coefficient	0.85	0.85	0.85	0.85	0.85	0.85	0.85
Stack Gas Velocity, ft/second	58.57	58.50	59.71	59.61	58.70	58.65	58.96
Nozzle Inside Diameter, inches	0.250	0.250	0.250	0.250	0.250	0.250	0.250
Total Sample Time, min	60	60	60	60	60	60	60
Isokinetic Rate, %	96.7	91.8	98.6	93.5	97.2	94.9	95.5
Stack Dimensions	34.063 in. ID	34.063 in. ID	34.063 in. ID	34.063 in. ID	34.063 in. ID	34.063 in. ID	
Stack Area, sq ft	146.81	146.81	146.81	146.81	146.81	146.81	146.81
Actual Stack Gas Flow Rate, acfm	515,900	515,300	526,000	525,100	517,100	516,600	519,300
Actual Stack Gas Flow Rate, acmm	14,609	14,592	14,895	14,869	14,643	14,629	14,706
Stack Gas Flow Rate, dsfcfm	354,100	356,300	355,500	358,000	352,800	354,300	355,200
Stack Gas Flow Rate, dsccmm	10,027	10,089	10,067	10,137	9,990	10,033	10,057
ASTM 7459-08: Max Sampling Deviation	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
ASTM 7459-08: Stack Flow Deviation	4.2%	4.2%	2.0%	2.0%	4.6%	4.6%	4.6%
ALT-009 Post Test Calibration	pass	FAIL	pass	FAIL	pass	pass	pass

Company: Holcim; Midlothian TX
 Source: Line 2 Main Stack; Raw Mill On
 Job ID: 23-3313
 Train Type: EPA Method 26A

NOTE: Average INCLUDES Non-detect runs' results

"ND()" denotes values below detection limits

		4A	4B	5A	5B	6A	6B	Average
		11/17/23	11/17/23	11/17/23	11/17/23	11/17/23	11/17/23	
		806-912	806-912	930-1036	930-1036	1058-1204	1058-1204	
Hydrogen Fluoride	Catch Wt, mg	ND(0.161)	ND(0.178)	ND(0.147)	ND(0.147)	ND(0.147)	ND(0.165)	ND(0.158)
	Conc., mg/dscm	ND(0.119)	ND(0.138)	ND(0.106)	ND(0.111)	ND(0.109)	ND(0.124)	ND(0.118)
	Conc., mg/dscm @ 7% O2	ND(0.240)	ND(0.278)	ND(0.211)	ND(0.221)	ND(0.216)	ND(0.247)	ND(0.236)
	Conc., mg/dscm @ 12% CO2	ND(0.127)	ND(0.147)	ND(0.112)	ND(0.117)	ND(0.113)	ND(0.130)	ND(0.124)
	Conc., ppmvd	ND(0.143)	ND(0.166)	ND(0.128)	ND(0.134)	ND(0.131)	ND(0.150)	ND(0.142)
	Conc., ppmvd @ 7% O2	ND(0.289)	ND(0.334)	ND(0.254)	ND(0.266)	ND(0.260)	ND(0.297)	ND(0.283)
	Conc., ppmvd @ 12% CO2	ND(0.152)	ND(0.176)	ND(0.135)	ND(0.141)	ND(0.136)	ND(0.156)	ND(0.149)
	Emission Rate, lb/hr	ND(0.158)	ND(0.184)	ND(0.142)	ND(0.149)	ND(0.144)	ND(0.165)	ND(0.157)
	Clinker Rates (mtph and lbs/ton)	123.78	ND(0.0013)	123.78	ND(0.0011)	123.76	ND(0.0011)	ND(0.0012)
Chlorine	Catch Wt, mg	0.684	0.586	0.911	0.825	0.748	0.804	0.760
	Conc., mg/dscm	0.506	0.454	0.659	0.625	0.553	0.606	0.567
	Conc., mg/dscm @ 7% O2	1.020	0.915	1.309	1.241	1.099	1.204	1.131
	Conc., mg/dscm @ 12% CO2	0.538	0.482	0.694	0.658	0.577	0.633	0.597
	Conc., ppmvd	0.172	0.154	0.224	0.212	0.188	0.206	0.192
	Absolute Difference, ppmvd (<0.2 required)		0.02		0.01		0.02	
	Conc., ppmvd @ 7% O2	0.346	0.310	0.444	0.421	0.373	0.408	0.384
	Conc., ppmvd @ 12% CO2	0.182	0.164	0.235	0.223	0.196	0.215	0.203
	Emission Rate, lb/hr	0.672	0.606	0.878	0.838	0.731	0.805	0.755
Clinker Rates (mtph and lbs/ton)	123.78	0.0047	123.78	0.0063	123.76	0.0056	0.0055	

Holtcim Midlothian TX
Line 2 Main Stack: Raw Mill On

Run 1	Specnum	Date	Time	HCN PCA, 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C
SPC_002465.LAB	11/17/23	08:07:21.238	20.815	-0.027	-0.010	8.341	20.444	8.402	
SPC_002466.LAB	11/17/23	08:08:25.137	21.812	-0.037	-0.011	8.580	18.688	8.508	
SPC_002467.LAB	11/17/23	08:09:29.286	21.790	-0.028	-0.012	8.471	18.274	8.547	
SPC_002468.LAB	11/17/23	08:10:32.985	21.875	-0.020	-0.014	8.057	18.943	8.388	
SPC_002469.LAB	11/17/23	08:11:36.827	22.272	-0.038	-0.014	8.248	18.280	8.467	
SPC_002470.LAB	11/17/23	08:12:40.759	21.939	-0.022	-0.014	8.274	18.954	8.494	
SPC_002471.LAB	11/17/23	08:13:44.708	22.512	-0.031	-0.012	8.403	18.134	8.521	
SPC_002472.LAB	11/17/23	08:14:48.524	22.633	-0.020	-0.013	8.766	18.314	8.593	
SPC_002473.LAB	11/17/23	08:15:52.417	22.353	-0.028	-0.014	8.953	18.473	8.735	
SPC_002474.LAB	11/17/23	08:16:56.633	22.340	-0.022	-0.016	8.794	18.749	8.648	
SPC_002475.LAB	11/17/23	08:18:00.251	21.989	-0.023	-0.015	8.679	18.840	8.651	
SPC_002476.LAB	11/17/23	08:19:04.169	22.295	-0.015	-0.010	8.750	18.348	8.603	
SPC_002477.LAB	11/17/23	08:20:08.095	22.165	-0.039	-0.012	8.755	18.485	8.639	
SPC_002478.LAB	11/17/23	08:21:11.907	22.335	-0.021	-0.012	8.782	18.591	8.596	
SPC_002479.LAB	11/17/23	08:22:16.236	21.695	-0.033	-0.013	8.841	19.333	8.514	
SPC_002480.LAB	11/17/23	08:23:19.813	21.988	-0.037	-0.013	8.669	19.251	8.478	
SPC_002481.LAB	11/17/23	08:24:23.646	22.527	-0.027	-0.013	8.603	19.359	8.532	
SPC_002482.LAB	11/17/23	08:25:27.537	22.256	-0.022	-0.013	8.306	19.988	8.469	
SPC_002483.LAB	11/17/23	08:26:31.387	22.636	-0.027	-0.014	8.342	19.067	8.508	
SPC_002484.LAB	11/17/23	08:27:35.601	22.038	-0.049	-0.013	8.566	19.694	8.532	
SPC_002485.LAB	11/17/23	08:28:39.181	22.285	-0.037	-0.013	8.566	19.622	8.464	
SPC_002486.LAB	11/17/23	08:29:43.078	22.266	-0.041	-0.014	8.073	19.404	8.421	
SPC_002487.LAB	11/17/23	08:30:46.980	21.333	-0.043	-0.014	8.203	19.505	8.386	
SPC_002488.LAB	11/17/23	08:31:50.878	21.827	-0.047	-0.012	8.431	19.924	8.407	
SPC_002489.LAB	11/17/23	08:32:55.060	22.253	-0.039	-0.014	8.427	18.959	8.448	
SPC_002490.LAB	11/17/23	08:33:59.759	22.286	-0.038	-0.011	8.359	18.551	8.528	
SPC_002491.LAB	11/17/23	08:35:02.558	21.906	-0.033	-0.012	8.703	18.302	8.665	
SPC_002492.LAB	11/17/23	08:36:06.500	21.886	-0.046	-0.014	8.568	19.072	8.486	
SPC_002493.LAB	11/17/23	08:37:10.447	21.682	-0.044	-0.012	8.646	18.768	8.606	
SPC_002494.LAB	11/17/23	08:38:14.259	22.104	-0.058	-0.012	8.747	18.305	8.582	
SPC_002495.LAB	11/17/23	08:39:18.394	21.483	-0.034	-0.013	8.000	18.660	8.653	
SPC_002496.LAB	11/17/23	08:40:22.088	22.023	-0.040	-0.013	8.748	18.383	8.537	
SPC_002497.LAB	11/17/23	08:41:25.936	21.687	-0.052	-0.014	8.093	19.680	8.435	
SPC_002498.LAB	11/17/23	08:42:30.126	21.450	-0.048	-0.011	8.186	18.981	8.554	
SPC_002499.LAB	11/17/23	08:43:33.728	21.782	-0.057	-0.010	8.528	18.134	8.692	
SPC_002500.LAB	11/17/23	08:44:37.715	21.425	-0.048	-0.013	8.570	18.613	8.642	
SPC_002501.LAB	11/17/23	08:45:41.525	21.384	-0.040	-0.015	8.507	19.214	8.532	
SPC_002502.LAB	11/17/23	08:46:45.435	21.985	-0.061	-0.015	8.788	18.692	8.504	
SPC_002503.LAB	11/17/23	08:47:49.317	21.630	-0.046	-0.012	8.682	19.190	8.617	
SPC_002504.LAB	11/17/23	08:48:53.658	21.073	-0.030	-0.014	9.184	19.762	8.647	
SPC_002505.LAB	11/17/23	08:49:57.148	20.616	-0.047	-0.010	9.213	19.608	8.581	
SPC_002506.LAB	11/17/23	08:51:01.313	21.120	-0.059	-0.018	8.657	19.490	8.510	
SPC_002507.LAB	11/17/23	08:52:05.178	21.671	-0.061	-0.014	8.770	20.114	8.439	
SPC_002508.LAB	11/17/23	08:53:08.818	21.589	-0.052	-0.013	8.523	20.251	8.470	
SPC_002509.LAB	11/17/23	08:54:12.695	21.743	-0.054	-0.012	8.781	19.433	8.599	
SPC_002510.LAB	11/17/23	08:55:16.907	21.386	-0.051	-0.012	8.695	19.725	8.522	
SPC_002511.LAB	11/17/23	08:56:20.503	21.779	-0.049	-0.014	8.766	19.302	8.553	
SPC_002512.LAB	11/17/23	08:57:24.390	21.412	-0.044	-0.013	8.585	19.925	8.527	
SPC_002513.LAB	11/17/23	08:58:28.275	21.799	-0.053	-0.012	8.629	18.859	8.573	
SPC_002514.LAB	11/17/23	08:59:32.175	21.502	-0.043	-0.013	8.545	19.263	8.555	
SPC_002515.LAB	11/17/23	09:00:36.318	21.242	-0.045	-0.011	8.834	18.862	8.677	
SPC_002516.LAB	11/17/23	09:01:39.964	21.152	-0.065	-0.013	8.618	19.479	8.543	
SPC_002517.LAB	11/17/23	09:02:43.912	21.475	-0.058	-0.012	8.843	18.517	8.648	
SPC_002518.LAB	11/17/23	09:03:47.854	21.351	-0.049	-0.012	8.600	18.869	8.617	
SPC_002519.LAB	11/17/23	09:04:51.749	21.034	-0.059	-0.012	8.946	18.997	8.714	
SPC_002520.LAB	11/17/23	09:05:55.565	20.758	-0.046	-0.014	9.445	19.321	8.718	
SPC_002521.LAB	11/17/23	09:06:59.488	20.986	-0.038	-0.011	8.986	18.338	8.640	
SPC_002522.LAB	11/17/23	09:08:03.436	20.764	-0.052	-0.011	9.216	19.081	8.599	
SPC_002523.LAB	11/17/23	09:09:07.291	21.571	-0.042	-0.012	8.766	18.678	8.508	
SPC_002524.LAB	11/17/23	09:10:11.176	21.569	-0.035	-0.013	8.630	18.548	8.533	
SPC_002525.LAB	11/17/23	09:11:15.073	21.261	-0.039	-0.010	9.169	18.746	8.645	
SPC_002526.LAB	11/17/23	09:12:18.993	21.148	-0.047	-0.013	9.028	20.030	8.488	
Mill On Run 1 Averages			21.741	< 0.032	< -0.013	8.664	19.070	8.551	
Oxygen			14.0%						
DSCFM			355.280						
metric tons/hr			123.78						
M26A Average Moisture			0.291					18.2	

Helcim Midlothian TX
 Line 2 Main Stack; Raw Mill On
 Run 3

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191K	SF6 (10) 191C	Ethylene (100.3000) 191C	H2O% (40) 191C	CO2% (40) 191C
SFC_002625.LAB	11/17/23	10:59:24.511	20.457	-0.062	-0.011	8.881	19.336	8.722
SFC_002626.LAB	11/17/23	11:00:28.418	20.728	-0.075	-0.014	8.617	18.894	8.671
SFC_002627.LAB	11/17/23	11:01:32.650	20.289	-0.063	-0.014	8.849	18.811	8.716
SFC_002628.LAB	11/17/23	11:02:36.225	20.529	-0.079	-0.015	9.151	18.889	8.792
SFC_002629.LAB	11/17/23	11:03:40.135	21.031	-0.082	-0.013	8.708	19.258	8.647
SFC_002630.LAB	11/17/23	11:04:44.292	21.194	-0.068	-0.010	8.707	19.318	8.580
SFC_002631.LAB	11/17/23	11:05:47.894	21.188	-0.092	-0.012	8.505	19.171	8.627
SFC_002632.LAB	11/17/23	11:06:51.841	21.691	-0.072	-0.012	8.608	18.910	8.662
SFC_002633.LAB	11/17/23	11:07:55.722	21.130	-0.076	-0.012	8.734	18.660	8.619
SFC_002634.LAB	11/17/23	11:08:59.600	21.464	-0.071	-0.013	9.024	18.484	8.666
SFC_002635.LAB	11/17/23	11:10:03.519	21.691	-0.085	-0.015	8.962	18.591	8.647
SFC_002636.LAB	11/17/23	11:11:07.361	21.422	-0.074	-0.014	9.033	18.619	8.605
SFC_002637.LAB	11/17/23	11:12:11.316	21.568	-0.081	-0.015	9.104	18.726	8.639
SFC_002638.LAB	11/17/23	11:13:15.169	21.250	-0.069	-0.016	9.341	19.427	8.611
SFC_002639.LAB	11/17/23	11:14:19.355	21.798	-0.080	-0.010	9.187	19.756	8.573
SFC_002640.LAB	11/17/23	11:15:22.945	21.398	-0.093	-0.011	8.724	20.055	8.468
SFC_002641.LAB	11/17/23	11:16:26.850	21.522	-0.081	-0.014	8.625	19.963	8.416
SFC_002642.LAB	11/17/23	11:17:30.740	21.772	-0.088	-0.013	8.337	19.993	8.359
SFC_002643.LAB	11/17/23	11:18:34.633	21.824	-0.086	-0.013	8.177	20.209	8.385
SFC_002644.LAB	11/17/23	11:19:38.537	22.112	-0.077	-0.012	8.135	19.855	8.392
SFC_002645.LAB	11/17/23	11:20:42.433	21.552	-0.085	-0.011	8.340	20.216	8.455
SFC_002646.LAB	11/17/23	11:21:46.362	20.947	-0.092	-0.014	8.232	20.294	8.505
SFC_002647.LAB	11/17/23	11:22:50.223	20.832	-0.080	-0.013	8.434	20.007	8.511
SFC_002648.LAB	11/17/23	11:23:54.116	20.642	-0.085	-0.013	8.574	20.001	8.569
SFC_002649.LAB	11/17/23	11:24:58.320	21.323	-0.082	-0.013	8.430	19.484	8.538
SFC_002650.LAB	11/17/23	11:26:01.921	21.221	-0.085	-0.013	8.474	19.038	8.553
SFC_002651.LAB	11/17/23	11:27:05.811	21.639	-0.083	-0.012	8.569	19.002	8.513
SFC_002652.LAB	11/17/23	11:28:09.775	21.905	-0.072	-0.012	8.404	19.008	8.533
SFC_002653.LAB	11/17/23	11:29:13.610	21.805	-0.071	-0.010	8.459	19.076	8.524
SFC_002654.LAB	11/17/23	11:30:17.505	21.320	-0.064	-0.012	8.302	19.527	8.442
SFC_002655.LAB	11/17/23	11:31:21.725	21.223	-0.079	-0.013	8.611	18.880	8.611
SFC_002656.LAB	11/17/23	11:32:25.304	21.359	-0.076	-0.014	8.366	18.827	8.602
SFC_002657.LAB	11/17/23	11:33:29.487	21.773	-0.067	-0.009	8.268	18.825	8.600
SFC_002658.LAB	11/17/23	11:34:33.380	21.605	-0.074	-0.011	8.315	18.796	8.682
SFC_002659.LAB	11/17/23	11:35:37.268	21.699	-0.079	-0.015	8.345	18.534	8.675
SFC_002660.LAB	11/17/23	11:36:41.166	21.341	-0.083	-0.011	8.466	18.572	8.660
SFC_002661.LAB	11/17/23	11:37:44.813	21.289	-0.085	-0.011	8.319	18.776	8.658
SFC_002662.LAB	11/17/23	11:38:48.663	20.912	-0.082	-0.012	8.327	19.178	8.542
SFC_002663.LAB	11/17/23	11:39:52.545	21.218	-0.070	-0.012	8.369	19.729	8.431
SFC_002664.LAB	11/17/23	11:40:56.450	21.028	-0.074	-0.012	8.136	20.353	8.409
SFC_002665.LAB	11/17/23	11:42:00.354	20.920	-0.067	-0.010	8.673	19.748	8.469
SFC_002666.LAB	11/17/23	11:43:04.273	21.346	-0.089	-0.012	8.980	19.883	8.387
SFC_002667.LAB	11/17/23	11:44:08.133	21.917	-0.078	-0.014	8.449	19.875	8.364
SFC_002668.LAB	11/17/23	11:45:12.037	21.806	-0.090	-0.012	8.415	19.901	8.371
SFC_002669.LAB	11/17/23	11:46:15.929	22.119	-0.080	-0.012	8.219	19.752	8.423
SFC_002670.LAB	11/17/23	11:47:20.132	21.069	-0.083	-0.012	8.698	19.995	8.544
SFC_002671.LAB	11/17/23	11:48:23.725	20.972	-0.084	-0.011	8.657	20.179	8.735
SFC_002672.LAB	11/17/23	11:49:27.621	21.416	-0.089	-0.010	8.529	19.958	8.457
SFC_002673.LAB	11/17/23	11:50:31.548	21.264	-0.086	-0.011	8.712	19.354	8.473
SFC_002674.LAB	11/17/23	11:51:35.867	22.184	-0.090	-0.013	8.604	18.769	8.484
SFC_002675.LAB	11/17/23	11:52:39.663	22.431	-0.092	-0.012	8.288	18.396	8.454
SFC_002676.LAB	11/17/23	11:53:43.228	21.988	-0.077	-0.011	8.231	18.935	8.535
SFC_002677.LAB	11/17/23	11:54:47.128	22.096	-0.093	-0.012	8.391	18.881	8.567
SFC_002678.LAB	11/17/23	11:55:51.000	21.733	-0.080	-0.014	8.594	18.647	8.671
SFC_002679.LAB	11/17/23	11:56:54.897	21.701	-0.090	-0.015	8.440	18.756	8.569
SFC_002680.LAB	11/17/23	11:57:59.092	21.591	-0.081	-0.010	8.077	19.137	8.476
SFC_002681.LAB	11/17/23	11:59:02.736	20.788	-0.084	-0.012	8.522	18.582	8.649
SFC_002682.LAB	11/17/23	12:00:06.638	21.550	-0.093	-0.013	8.470	18.508	8.589
SFC_002683.LAB	11/17/23	12:01:10.487	20.943	-0.078	-0.012	8.304	19.002	8.563
SFC_002684.LAB	11/17/23	12:02:14.658	21.286	-0.073	-0.012	8.343	18.540	8.533
SFC_002685.LAB	11/17/23	12:03:18.366	21.429	-0.082	-0.010	8.140	18.706	8.546
SFC_002686.LAB	11/17/23	12:04:22.184	21.827	-0.081	-0.014	7.958	19.074	8.429
Milt On Run 3 Averages		(actual)	21.404	< 0.032	< -0.012	8.530	19.257	8.551
Oxygen		(ppm, dry @7% O2)	52,408	< 0.078				
DSCFM		(lbs/hr)	353,550	< 0.943				
metric tons/hr		(lbs/ton clinker)	123.76	< 0.8003		M26A Average Moisture	18.9	

Appendix B

**Field Data
and
CEM/FTIR Data**



EPA Method 2 Gas Velocity and Cyclonic Flow Check

Plant LafargeHolcim Midlothian Facility Run Date 11 / 3 / 20
 City Midlothian, TX Clock Time 15:00
 Sampling Location Kiln System #1 Stack
 Operator HF/JH/KW/mk Run No.
 Ambient Temperature ~70 deg. F
 Barometric Pressure 29.5.0 in. Hg Mol. Wt. ~28.3
 Static Pressure - 0.67 in. H2O Pitot Cp 0.84
 Stack ID Side 1 161.5 in.
 Side 2 161.5 in.

Traverse point number	Position in.	Velocity head Δp in. H2O	Stack temperature deg. F	Cyclonic Flow Determination	
				Δp at 0° reference	Angle (α) which yields a null Δp
1	See		139		10
2	M.1		140		10
3	Down		140		8
1			140		12
2		141		11	
3		139		7	
1		141		7	
2		141		6	
3		140		7	
1		142		14	
2		139		9	
3		138		7	
Average angle (α)*				9.0°	

* Average of α must be $\leq 20^\circ$ to be acceptable

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23		Kiln System Stack		Method 26A		Kiln 1 - ON OFF - M5-3 / A	
OPERATOR		AMBIENT PRESS (in. Hg)		AMBIENT TEMP (deg. F)		PITOT Cp		PROBE LENGTH AND LINER TYPE	
M. Powell		29.22		33		0.41 0.84		8' eff., 9' Glass Liner (K1) 5' eff., 6' Glass Liner (K2)	
ASSUMED MOISTURE (%)		DGM H@		DGM CAL FACTOR (Y)		LEAK CHECK (INITIAL)		O2 CONTENT %	
~17 - 20%		172		1.074		0.0021 CU. FT @ 10 "Hg		14 - 12.5% On - Off	
TRaverse ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		PROBE TEMP (deg. F)		FILTER OVEN TEMP (deg. F)	
A-1 0		900		751.876		255		252	
2 5				755.99		256		253	
3 10				760.26		255		261	
15 15				764.59		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
B-1 15		918		764.59		2.5		254	
2 20				768.62		2.2		255	
3 25				772.77		2.2		255	
30 30		935		776.879		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
C-1 30		936		776.879		2.2		256	
2 35				780.66		2.4		256	
3 40				785.23		2.4		249	
45 45		951		789.375		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
D-1 45		954		789.375		2.2		257	
2 50				793.56		2.3		257	
3 55				797.81		2.5		259	
60 60		1009		802.152		End of Port			
TOTAL TIME 60 Min.		DGM VOLUME		AVE SQRT delta P		AVE delta H		AVE. TEMP.	

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/15/23
 Run No. Kiln 1 Run 3 Mill ON OFF-26A-1A Recovered by GG
 Filter Number(s) NA 905

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		806.4	838.5	647.6	759.7	775.2	950.6	g
Initial weight		752.2	738.4	617.1	745.7	769.7	934.7	g
Net weight		54.2	100.1	30.5	54.0	105.5	15.9	g

Description of impinger water clean 13.0 5.5 % spent
30 % spent
Blw Sil gel color
 Total moisture = 219.2 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter NA

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run 1 Mill ON OFF-26A-H2SO4- 1A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln (Run 1 Mill ON OFF-26A-NaOH - 1A

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23		Kiln System Stack		Method 26A		Kiln - ON OFF -M5- LB	
OPERATOR		AMBIENT PRESS (in. Hg)		AMBIENT TEMP (deg. F)		STACK ID (In.)		PROBE LENGTH AND LINER TYPE	
T. J. ...		~ 29.80		~ 60		161.5" (K1) 164.063" (K2)		0.84 8' eff., 9' Glass Liner (K1) 5' eff., 6' Glass Liner (K2)	
ASSUMED DGM MOISTURE BOX No. (%)		DGM H@		DGM CAL FACTOR (Y)		PITOT LEAK CHECK		NOZZLE DIAMETER	
~ 17-20%		1.05		1.015		K -M5- FAILED		.250 .250	
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		delta P VELOCITY HEAD (In. H2O)		CO2 CONTENT %	
A-1 0		9:00		261.182		1		13-14% On - Off	
2 5				266.11		1.2		14-12.5% On - Off	
3 10				271.48		1.1		13-14% On - Off	
15		9:15		276.623		End of Port		KFACTOR 2.68	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
B-1 15		9:18		276.623		.85		6	
2 20				281.54		.88		6	
3 25				286.05		.81		6	
30		9:33		291.391		End of Port		6	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
C-1 30		9:36		290.371		.90		6	
2 35				295.51		.96		6	
3 40				299.59		.90		6	
45		9:51		303.792		End of Port		6	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
D-1 45		9:54		303.792		.87		6	
2 50				308.23		.85		6	
3 55				312.73		.83		6	
60		10:09		317.241		End of Port		6	
TOTAL TIME		DGM VOLUME		AVE SQRT delta P		AVE. TEMP.		AVE. TEMP.	
60 Min.		317.241		2.3		134		64	

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23		Kiln System Stack		Method 26A		Kiln - ON OFF -M5- LB	
OPERATOR		AMBIENT PRESS (in. Hg)		AMBIENT TEMP (deg. F)		STACK ID (In.)		PROBE LENGTH AND LINER TYPE	
T. J. ...		~ 29.80		~ 60		161.5" (K1) 164.063" (K2)		0.84 8' eff., 9' Glass Liner (K1) 5' eff., 6' Glass Liner (K2)	
ASSUMED DGM MOISTURE BOX No. (%)		DGM H@		DGM CAL FACTOR (Y)		PITOT LEAK CHECK		NOZZLE DIAMETER	
~ 17-20%		1.05		1.015		K -M5- FAILED		.250 .250	
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		delta P VELOCITY HEAD (In. H2O)		CO2 CONTENT %	
A-1 0		9:00		261.182		1		13-14% On - Off	
2 5				266.11		1.2		14-12.5% On - Off	
3 10				271.48		1.1		13-14% On - Off	
15		9:15		276.623		End of Port		KFACTOR 2.68	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
B-1 15		9:18		276.623		.85		6	
2 20				281.54		.88		6	
3 25				286.05		.81		6	
30		9:33		291.391		End of Port		6	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
C-1 30		9:36		290.371		.90		6	
2 35				295.51		.96		6	
3 40				299.59		.90		6	
45		9:51		303.792		End of Port		6	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
D-1 45		9:54		303.792		.87		6	
2 50				308.23		.85		6	
3 55				312.73		.83		6	
60		10:09		317.241		End of Port		6	
TOTAL TIME		DGM VOLUME		AVE SQRT delta P		AVE. TEMP.		AVE. TEMP.	
60 Min.		317.241		2.3		134		64	

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/15/22
 Run No. Kiln Run Mill ON OFF-26A-13 Recovered by GLS
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		795.6	809.0	706.7	783.2	786.5	933.4	g
Initial weight		737.2	751.8	667.9	755.9	767.1	893.8	g
Net weight		58.4	57.2	38.8	27.3	14.4	39.6	g

Description of impinger water clean 60 % spent
B/W Sil gel color
 Total moisture = _____ grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run / Mill ON OFF-26A-H2SO4- 13

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run / Mill ON OFF-26A-NaOH 13

Liquid level marked/sealed

A

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER									
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23		Klin System Stack		Method 26A		Klin 1 - ON OFF - M5- 4 A									
OPERATOR		AMBIENT PRESS (In. Hg)		AMBIENT TEMP (deg. F)		STACK ID (In.)		PROBE LENGTH AND LINER TYPE									
A. Powell		21.02		80		161.5" (K1) 164.063" (K2)		-280 -380 DIAMETER									
ASSUMED MOISTURE (%)		DGM H@		DGM CAL FACTOR (Y)		DGM VELOCITY HEAD (In. H2O)		LEAK CHECK (INITIAL)		LEAK CHECK (FINAL)		CO2 CONTENT (%)					
~17 - 20%		1.72		1.014		.93 .89 .93		0.001 @ 10 "Hg		0.001 @ 9 "Hg		13 - 14% On - Off					
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING (cu. ft.)		delta P VELOCITY HEAD (In. H2O)		delta H ORIFICE (In. H2O)		PROBE TEMP (deg. F)		DGM IN/OUT TEMP (deg. F)		FILTER OVEN TEMP (deg. F)		SAMPLE TRAIN VAC (in. Hg)	
0		10 32		805.53		.81		.22		256		52		253		48	
5		10 37		806.96		.93		2.5		255		53		254		48	
10		10 42		811.29		.85		2.3		254		54		253		47	
15		10 47		815.655		End of Port		End of Port		End of Port		End of Port		End of Port		End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg											
B-1		15 1050		815.655		.81		2.2		286		53		281		48	
2		20		819.38		.93		2.5		255		54		254		46	
3		25		823.97		.85		2.3		254		54		253		46	
30		11 05		828.242		End of Port		End of Port		End of Port		End of Port		End of Port		End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg											
C-1		30 1108		828.242		.92		2.5		253		52		251		47	
2		35		832.66		.99		2.7		255		52		260		47	
3		40		837.14		.85		2.3		255		53		254		47	
45		11 23		841.256		End of Port		End of Port		End of Port		End of Port		End of Port		End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg											
D-1		45 1126		841.256		.87		2.4		255		53		252		48	
2		50		845.45		.85		2.3		286		54		256		49	
3		55		849.71		.83		2.3		255		54		259		50	
60		11 41		854.001		End of Port		End of Port		End of Port		End of Port		End of Port		End of Port	
TOTAL TIME 60 Min.		DGM VOLUME		AVE SQRT delta P		AVE TEMP.		DGM VOLUME		AVE SQRT delta H		AVE TEMP.		DGM VOLUME		AVE TEMP.	
		854.001		2.3		134		854.001		2.3		134		854.001		134	

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/14/23
 Run No. Kiln 1 Run 2 Mill ON OFF-26A-2A Recovered by gcl
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		834.5	846.9	655.0	747.7	758.1	939.5	g
Initial weight		742.8	751.0	643.6	740.3	755.2	925.4	g
Net weight		91.7	95.9	11.4	7.4	2.9	14.1	g

Description of impinger water clear 30 % spent
BW Sil gel color
 Total moisture = 223.4 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter NA

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 1 Run 2 Mill ON OFF-26A-H2SO4- 2A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 1 Run 2 Mill ON OFF-26A-NaOH- 2A

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE TYPE	RUN NUMBER
Holcim (US) Inc; Midlothian, TX	11/15/23	Kiln 1 System Stack	Method 26A	4
OPERATOR	AMBIENT PRESS (in. Hg)	STATIC PRESSURE (in. Water)	PITOT Cp	NOZZLE DIAMETER
<i>Chris Meyer</i>	22.00	-1.36	0-820-84	.250-.250
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (Y)	LEAK CHECK (INITIAL)	CO2 CONTENT %
~17-20%	1.65	0.75	1.0	13-14% On - Off
TRaverse ELAPSED TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	LEAK CHECK (FINAL)	STACK ID (In.)
0	10:32	317.864	1.0	161.5" (K1)
5		322.08	1.0	164.063" (K2)
10		326.48	1.0	
15	10:47	330.936	1.0	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)				
15				
20				
25				
30				
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)				
15				
20				
25				
30				
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)				
30				
35				
40				
45				
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)				
45				
50				
55				
60				
TOTAL TIME	DGM VOLUME	AVERAGE SQRT delta P	AVERAGE TEMP.	AVERAGE TEMP.
60 Min.	372.771	2.7	83	78

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/15/23
 Run No. Kiln / Run 2 Mill ON OFF-26A-2B Recovered by SCS
 Filter Number(s) 124

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight	886.5	804.8	804.8	620.6	752.9	752.2	943.1	g
Initial weight		748.4	743.9	612.8	743.0	748.6	930.5	g
Net weight		138.2	60.9	7.8	9.9	3.6	12.6	g

Description of impinger water clean 30 % spent
B/W Sil gel color
 Total moisture = 233.0 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter NA

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run 2 Mill ON OFF-26A-H2SO4-2B

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run 2 Mill ON OFF-26A-NaOH-2B

Liquid level marked/sealed

A

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23		Kiln System Stack		Method 26A		Kiln (ON/OFF) -M5-	
OPERATOR		AMBIENT PRESS (in. Hg)		AMBIENT TEMP (deg. F)		STACK ID (in.)		PROBE LENGTH AND LINER TYPE	
M. Powell		29.7		80		161.5" (K1)		8' eff., 9' Glass Liner (K1)	
		-33				164.063" (K2)		5' eff., 6' Glass Liner (K2)	
ASSUMED MOISTURE (%)		DGM H@		DGM CAL FACTOR (Y)		LEAK CHECK (INITIAL)		LEAK CHECK (FINAL)	
~17-20%		1.72		1014		0.00 @ 10"		13 - 14% On - Off	
TRaverse ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		delta P VELOCITY HEAD (in. H2O)		delta H ORIFICE (in. H2O)	
0		1202		854.291		.84		2.4	
5				856.67		.83		2.3	
10				862.34		.83		2.3	
15		1217		867.249		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
B-1		15 1220		.82		135		50	
2				.96		134		50	
3				.82		135		51	
30		1235		876.842		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
C-1		30 1238		.93		134		52	
2				.97		135		52	
3				.91		136		53	
45		1253		891.711		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
D-1		45 1256		.93		137		53	
2				.86		134		54	
3				.92		135		55	
60		1311		904.052		End of Port			
TOTAL TIME 60 Min.		DGM VOLUME		AVE SQRT delta P		AVE. TEMP.		KFACTOR	
		891.711		2.5		137		2.72	
		896.01		2.3		134			
		900.02		2.5		135			
		904.052		2.5		135			
				AVE SQRT delta H		AVE. TEMP.			
				2.5		137			
				2.3		134			
				2.5		135			
				2.5		135			
				2.5		137			
				2.3		134			
				2.5		135			
				2.5		135			

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/15/23
 Run No. Kiln / Run 3 Mill ON OFF-26A-3A Recovered by CS
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		831.5	828.8	629.2	752.4	746.0	968.1	g
Initial weight		746.4	739.9	619.2	744.7	744.3	950.6	g
Net weight		85.1	88.9	10.0	7.7	1.7	17.5	g

Description of impinger water clear 60 % spent
B/W Sil gel color
 Total moisture = 240.9 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter NA

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 1 Run 3 Mill ON OFF-26A-H2SO4-3A Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 1 Run 3 Mill ON OFF-26A-NaOH-3A Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE	SAMPLING LOCATION		SAMPLE TYPE	RUN NUMBER							
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23	Kiln	System Stack	Method 26A	5							
OPERATOR		AMBIENT PRESS (In. Hg)	STATIC PRESSURE (in. Water)	AMBIENT TEMP (deg. F)	PITOT Cp	NOZZLE NUMBER							
D-0-01g, W-0-01g		29.80	- .36	~ 55	505	250-250							
DGM H@		DGM CAL FACTOR (Y)	DGM VELOCITY HEAD (In. H2O)	DELTA H ORIFICE (In. H2O)	LEAK CHECK (INITIAL)	LEAK CHECK (FINAL)							
1.68		1.75	1.0	2.7	136	81							
~17-20% 15%		PITOT LEAK CHECK	DELTA P VELOCITY HEAD (In. H2O)	DELTA H ORIFICE (In. H2O)	STACK TEMP (deg. F)	DGM IN / OUT TEMP (deg. F)							
		15% PASSED	1.0	2.7	138	82							
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	DELTA H ORIFICE (In. H2O)	PROBE TEMP (deg. F)	OROVAT NO.	STACK ID (In.)	STACK FILTER NUMBERS	AMBIENT TEMP (deg. F)	Kiln System Stack	PROBE LENGTH AND LINER TYPE	Kiln	NOZZLE
0		12:02	378.500	1.0	254	254	161.5" (K1)	NA	~ 55	161.5" (K1)	8' eff., 9' Glass Liner (K1)	Kiln	-M5-313
5			377.62	1.0	257	257	164.063" (K2)			164.063" (K2)	5' eff., 6' Glass Liner (K2)		
10			382.13	1.0	257	257							
15		12:17	387.023	End of Port	End of Port	End of Port							
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL	LEAK RATE: CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg
B-1		15	12:30	387.023	86	2.6	248	138	138	138	82	253	61
2		20		392.48	89	2.4	249	138	138	138	82	251	58
3		25		396.44	83	2.2	255	137	137	137	84	252	56
30		12:35	401.086	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL	LEAK RATE: CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg
C-1		30	12:38	401.086	92	2.5	245	138	138	138	81	257	59
2		35		405.91	96	2.6	249	138	138	138	81	253	59
3		40		410.91	98	2.65	255	136	136	136	83	255	59
45		12:53	415.205	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL	LEAK RATE: CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg	CU.FT @ INCHES Hg
D-1		45	12:56	415.205	87	2.3	257	138	138	138	81	254	59
2		50		420.03	84	2.3	256	136	136	136	82	254	57
3		55		424.93	89	2.2	257	134	134	134	83	258	56
60		13:11	428.654	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port	End of Port
TOTAL TIME		DGM VOLUME	AVE SQRT delta P	AVE delta H	AVE TEMP.	AVE TEMP.	AVE TEMP.	AVE TEMP.	AVE TEMP.	AVE TEMP.	AVE TEMP.	AVE TEMP.	AVE TEMP.
60 Min.		428.654	2.3	257	81	254	81	254	81	254	81	254	81

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln MILL ON OFF Recovery Date 11/15/23
 Run No. Kiln / Run 3 Mill ON OFF-26A-3B Recovered by 425
 Filter Number(s) _____

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		892.8	795.9	680.8	763.7	765.3	954.8	g
Initial weight		738.5	745.7	670.4	761.0	763.3	940.7	g
Net weight		154.3	50.3	10.4	2.7	2.0	14.1	g

Description of impinger water Clear 50 % spent
B/W Sil gel color
 Total moisture = 233.8 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run 3 Mill ON OFF-26A-H2SO4-3B

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run 3 Mill ON OFF-26A-NaOH-3B

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER			
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23	Klin / System Stack	Method 26A		Klin (- ON OFF) -M5- 421					
OPERATOR		AMBIENT PRESS (In. Hg)		STATIC PRESSURE (in. Water)		AMBIENT TEMP (deg. F)		PROBE LENGTH AND LINER TYPE			
M. Bondi		29.97	0.0	0.0	0.0	0.0	0.0	8' eff., 9' Glass Liner (K1)	NOZZLE NUMBER		
ASSUMED MOISTURE (%)		DGM H@	DGM CAL FACTOR (Y)	STACK THERM NO.	STACK PITOT NO.	STACK ID (In.)	ORSAT NO.	LEAK CHECK (INITIAL)	LEAK CHECK (FINAL)	CO2 CONTENT %	K FACTOR
~17-20%	M5-22	1.72	1.014	81	84	161.5" (K1)	-M5-	0.001 CU. FT @ 10" Hg	0.001 CU. FT @ 10" Hg	14 - 12.5% On - Off	2.72
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		VELOCITY HEAD (In. H2O)		ORIFICE (In. H2O)		delta P	
A-1	0	1432	904.888	0.68	1.8	256	256	256	256	59	59
2	5		908.55	0.68	1.8	254	254	254	254	59	59
3	10		911.599	0.64	1.7	253	253	253	253	60	60
15	15	1447	915.019	End of Port							
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ INCHES Hg		CU.FT @ INCHES Hg		CU.FT @ INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
B-1	15	1450	915.019	0.69	1.9	256	256	256	256	59	59
2	20		918.92	0.62	1.7	256	256	256	256	60	60
3	25		922.79	0.68	1.8	253	253	253	253	61	61
30	30	1505	926.616	End of Port							
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ INCHES Hg		CU.FT @ INCHES Hg		CU.FT @ INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
C-1	30	1508	926.616	0.56	1.5	256	256	256	256	61	61
2	35		929.321	0.69	1.9	255	255	255	255	62	62
3	40		933.93	0.65	1.8	253	253	253	253	62	62
45	45	1523	937.679	End of Port							
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ INCHES Hg		CU.FT @ INCHES Hg		CU.FT @ INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
D-1	45	1526	937.679	0.65	1.8	252	252	252	252	62	62
2	50		941.441	0.69	1.9	251	251	251	251	63	63
3	55		945.13	0.65	1.8	251	251	251	251	63	63
60	60	1541	948.713	End of Port							
TOTAL TIME 60 Min.		DGM VOLUME		AVE SORT delta P		AVE delta H		AVE TEMP.		AVE TEMP.	
		948.713		1.8		251		130		256	
				1.8		251		131		253	
				1.8		251		130		256	
				1.8		252		129		254	
				1.9		251		131		253	
				1.8		251		130		256	
				1.8		252		129		254	
				1.9		251		131		253	
				1.8		251		130		256	
				1.8		252		129		254	
				1.9		251		131		253	
				1.8		251		130		256	

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/15/23
 Run No. Kiln Run 4 Mill ON OFF-26A-4A Recovered by hcs
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		836.0	823.9	658.4	750.3	759.7	951.6	g
Initial weight		744.0	736.8	645.2	746.3	758.9	939.4	g
Net weight		192.0	87.1	13.2	4.0	0.8	12.2	g

Description of impinger water clear 65 % spent
B/W Sil gel color
 Total moisture = 209.3 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln Run 4 Mill ON OFF-26A-H2SO4-4A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln Run 4 Mill ON OFF-26A-NaOH-4A

Liquid level marked/sealed

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/27
 Sample Location Kiln Mill ON OFF Recovery Date 11/15/23
 Run No. Kiln (Run / Mill ON OFF)-26A-413 Recovered by gcs
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		913.3	806.5	620.2	751.7	755.3	956.0	g
Initial weight		746.0	750.9	613.7	745.3	751.6	942.7	g
Net weight		167.3	55.6	6.5	6.4	3.7	13.3	g

Description of impinger water clean 50 % spent
B/W Sil gel color
 Total moisture = 252.8 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run / Mill ON OFF-26A-H2SO4-413

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run / Mill ON OFF-26A-NaOH-413

Liquid level marked/sealed

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/15/23
 Run No. Kiln / Run 5 Mill ON OFF-26A-5A Recovered by GLS
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		847.6	841.5	627.5	767.1	742.9	986.9	g
Initial weight		750.2	755.2	616.9	761.4	741.3	968.0	g
Net weight		97.4	86.3	10.6	2.7	1.6	18.9	g

Description of impinger water clear 90 % spent
B/W Sil gel color
 Total moisture = 217.5 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run 5 Mill ON OFF-26A-H2SO4-5A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run 5 Mill ON OFF-26A-NaOH 5A

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23		Kiln System Stack		Method 26A		Kiln - ON OFF - M5- 7B	
OPERATOR		AMBIENT PRESS (in. Hg)		FILTER NUMBERS		PITOT Cp		NOZZLE NUMBER DIAMETER	
DGM H@		STATIC PRESSURE (in. Water)		STACK ID (In.)		PROBE LENGTH AND LINER TYPE		NUMBER DIAMETER	
1.68		- .36		161.5" (K1)		8' eff., 9' Glass Liner (K1)		250	
DGM CAL FACTOR (Y)		STACK THERM NO.		ORSAT NO.		LEAK CHECK (INITIAL)		250	
.975		5/1		K -M5-		.001 CU.FT @ 13" Hg			
PITOT LEAK CHECK		STACK PITOT NO.		FAILED		LEAK CHECK (FINAL)		CO2 CONTENT %	
15		5/1		K -M5-		.001 CU.FT @ 13" Hg		13 - 14% On - Off	
TRAVEL ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		DGM IN / OUT TEMP (deg. F)		FILTER TEMP (deg. F)	
0		15:56		484.860		141		857	
5		16:11		490.19		138		262	
10				494.23		136		256	
15				498.479		141		257	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		SAMPLE TRAIN VAC (in. Hg)	
B-1		16:14		.81		144		10	
2		16:20		.84		142		12	
3		16:25		.83		142		14	
30		16:30		.80		142		13	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg			
C-1		16:32		.78		141		61	
2		16:35		.77		140		61	
3		16:40		.69		140		62	
45		16:47		.69		140		62	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg			
D-1		16:50		.79		143		64	
2		16:50		.78		143		64	
3		16:55		.78		146		64	
60		17:05		.78		146		64	
TOTAL TIME 60 Min.		DGM VOLUME		AVE SQRT delta P		AVE. TEMP.		AVE. TEMP.	
		537.081		2.1		146		85	

13

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/15/23
 Run No. Kiln Run 5 Mill ON OFF-26A-5B Recovered by GLS
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		909.2	809.2	677.3	741.6	749.0	968.9	g
Initial weight		742.7	761.2	668.1	739.3	746.7	954.6	g
Net weight		166.5	148.0	9.2	2.3	2.3	14.3	g

Description of impinger water clear 80 % spent
B/W Sil gel color
 Total moisture = 292.6 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run 5 Mill ON OFF-26A-H2SO4- 5B

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run 5 Mill ON OFF-26A-NaOH 5B

Liquid level marked/sealed

A

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim (US) Inc; Midlothian, TX		11 / 15 / 23		Kiln / System Stack		Method 26A		Kiln / - ON / OFF - M56-6A	
OPERATOR		AMBIENT PRESS (in. Hg)		FILTER NUMBERS		PITOT Cp		NOZZLE NUMBER DIAMETER	
M. Powell		20.97		11		0.82 0.84		260 260	
ASSUMED MOISTURE (%)		DGM CAL FACTOR (Y)		STACK THERM NO.		LEAK CHECK (INITIAL)		CO2 CONTENT %	
~17 - 20%		1.014		84		0.00 1.00		13 - 14% On - Off	
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		delta P VELOCITY HEAD (in. H2O)		DGM IN / OUT TEMP (deg. F)		FILTER OVEN TEMP (deg. F)	
A-1 0		1719		.96		144		252	
2 5		1001.27		.95		146		283	
3 10		1006.31		.97		145		255	
15		1010.861		End of Port					
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg			
B-1 15		1737 1010.861		.83 2.3		144 64		252 62	
2 20		1015.02		.84 2.3		143 64		249 60	
3 25		1019.05		.79 2.1		143 65		250 60	
30		1022.937		End of Port					
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg			
C-1 30		1755 1022.937		.64 1.7		142 64		256 61	
2 35		1026.51		.68 1.8		143 65		259 59	
3 40		1030.09		.62 1.7		143 66		258 58	
45		1033.471		End of Port					
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CUFT @ CUFT @		INCHES Hg INCHES Hg			
D-1 45		1813 1033.471		.63 1.7		141 66		252 60	
2 50		1036.96		.59 1.6		144 67		257 60	
3 55		1040.416		.62 1.7		142 68		255 61	
60		1044.125		End of Port					
TOTAL TIME 60 Min.		DGM VOLUME		AVE SQR delta P		AVE. TEMP.		AVE. TEMP.	

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/16/23
 Run No. Kiln Run 6 Mill ON OFF-26A-6A Recovered by GLG
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		968.0	795.5	658.4	745.8	735.6	972.9	g
Initial weight		745.0	737.2	642.9	740.4	735.4	951.6	g
Net weight		123.0	58.3	15.5	5.4	0.2	21.3	g

Description of impinger water Clear 90 % spent
BlW Sil gel color
 Total moisture = 223.7 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln Run 6 Mill ON OFF-26A-H2SO4-6A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln Run 6 Mill ON OFF-26A-NaOH-6A

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE TYPE	RUN NUMBER
Holcim (US) Inc; Midlothian, TX	11/15/23	Kiln i System Stack	Method 26A	Kiln - ON OFF -M58 613
OPERATOR	AMBIENT PRESS (In. Hg)	STATIC PRESSURE (in. Water)	PITOT Cp	NOZZLE NUMBER DIAMETER
Vogel, Wanda	27.04	2.36	0.85	1250.850 .250
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (Y)	LEAK CHECK (INITIAL)	CO2 CONTENT %
~17-20%	1.655	0.75	1.00	13-14% On - Off
TRaverse ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	LEAK CHECK (FINAL)	CO2 CONTENT %
0	17:19	537.4910	1.00	14-12.5% On - Off
5	17:24	543.123	1.00	13-14% On - Off
10	17:29	547.81	1.00	13-14% On - Off
15	17:34	552.148	1.00	13-14% On - Off
INTRA-PORT LEAK CHECK?	DGM VOLUME (CU. FT)	LEAK RATE: CUFT @ INCHES Hg	PROBE TEMP (deg. F)	SAMPLE TRAIN VAC (in. Hg)
	558.178	2.2	260	11
	557.02	2.2	260	11
	560.93	2.1	255	11
	565.079	2.1	255	11
INTRA-PORT LEAK CHECK?	DGM VOLUME (CU. FT)	LEAK RATE: CUFT @ INCHES Hg	PROBE TEMP (deg. F)	SAMPLE TRAIN VAC (in. Hg)
	565.079	1.7	256	10
	569.69	1.8	255	10
	572.83	1.7	256	10
	576.520	1.7	256	10
INTRA-PORT LEAK CHECK?	DGM VOLUME (CU. FT)	LEAK RATE: CUFT @ INCHES Hg	PROBE TEMP (deg. F)	SAMPLE TRAIN VAC (in. Hg)
	576.520	1.7	256	10
	580.13	1.6	249	10
	585.20	1.6	247	10
	588.199	1.7	252	10
TOTAL TIME	DGM VOLUME	Ave Sqrt delta P	Ave. Temp.	Ave. Temp.
60 Min.	558.178	1.7	255	10

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/16/23
 Run No. Kiln Run 6 Mill ON OFF-26A-6B Recovered by SCS
 Filter Number(s) _____

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		903.7	790.7	617.2	736.5	733.7	970.4	g
Initial weight		743.0	741.3	610.4	732.3	731.9	956.0	g
Net weight		160.7	49.4	6.8	4.2	-1.2	14.4	g

Description of impinger water clear 80 % spent
B/W Sil gel color
 Total moisture = 231.3 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run 6 Mill ON OFF-26A-H2SO4- 6B

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run 6 Mill ON OFF-26A-NaOH- 6B

Liquid level marked/sealed

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/16/27
 Sample Location Kiln Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln / Run Mill ON OFF-26A- FB Recovered by ELS
 Filter Number(s) _____

Field Blank #1

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		741.2	753.3	667.5	749.6	743.6	969.7	g
Initial weight		748.7	753.1	667.1	749.3	743.3	969.0	g
Net weight		-0.5						g

Description of impinger water clean 75 % spent
B/W Sil gel color
 Total moisture = _____ grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run Mill ON OFF-26A-H2SO4- FB

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run Mill ON OFF-26A-NaOH- FB

Liquid level marked/sealed

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/15/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/16/23
 Run No. Kiln Run Mill ON OFF-26A- FB Recovered by SC9
 Filter Number(s) _____
Field Blank #12

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		746.6	744.0	615.5	736.6	747.5	987.3	g
Initial weight		746.8	743.9	615.7	736.3	747.6	986.9	g
Net weight								g

Description of impinger water _____ 20 % spent
 _____ B/w Sil gel color
 Total moisture = _____ grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln / Run Mill ON OFF-26A-H2SO4- FB

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln / Run Mill ON OFF-26A-NaOH FB

Liquid level marked/sealed

Client: Holcim Midlothian
 Test Location: Line 1 Main Stack; Raw Mill On
 Date: Nov 15, 2023 Start Time: 09:00:18
 Run number 1
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
9:01:16 AM	15.2	8.8
9:02:16 AM	15.3	8.8
9:03:16 AM	15.3	8.7
9:04:16 AM	15.2	8.8
9:05:16 AM	15.3	8.7
9:06:16 AM	15.3	8.8
9:07:16 AM	15.2	8.8
9:08:16 AM	15.3	8.7
9:09:16 AM	15.2	8.8
9:10:16 AM	15.3	8.7
9:11:16 AM	15.3	8.7
9:12:16 AM	15.2	9.0
9:13:16 AM	15.2	9.1
9:14:16 AM	15.2	8.9
9:15:16 AM	15.3	8.8
9:16:16 AM	15.3	8.8
9:17:16 AM	15.2	8.9
9:18:16 AM	15.3	8.7
9:19:16 AM	15.3	8.7
9:20:16 AM	15.2	8.7
9:21:16 AM	15.3	8.7
9:22:16 AM	15.2	8.7
9:23:16 AM	15.3	8.7
9:24:16 AM	15.2	8.7
9:25:16 AM	15.3	8.7
9:26:16 AM	15.2	8.7
9:27:16 AM	15.2	8.8
9:28:16 AM	15.2	8.9
9:29:16 AM	15.2	9.0
9:30:16 AM	15.2	9.0
9:31:16 AM	15.2	8.8
9:32:16 AM	15.2	8.8
9:33:16 AM	15.2	8.7
9:34:16 AM	15.2	8.8
9:35:16 AM	15.2	8.8
9:36:16 AM	15.2	8.7
9:37:16 AM	15.2	8.8
9:38:16 AM	15.3	8.6
9:39:16 AM	15.3	8.6
9:40:16 AM	15.3	8.6
9:41:16 AM	15.4	8.5
9:42:16 AM	15.4	8.6
9:43:16 AM	15.4	8.5
9:44:16 AM	15.4	8.7
9:45:16 AM	15.3	8.9
9:46:16 AM	15.3	8.8
9:47:16 AM	15.3	8.7
9:48:16 AM	15.4	8.5
9:49:16 AM	15.4	8.5
9:50:16 AM	15.4	8.5
9:51:16 AM	15.4	8.6
9:52:16 AM	15.3	8.8
9:53:16 AM	15.2	8.8
9:54:16 AM	15.3	8.7
9:55:16 AM	15.3	8.7
9:56:16 AM	15.3	8.7
9:57:16 AM	15.2	8.7
9:58:16 AM	15.3	8.7
9:59:16 AM	15.3	8.8
10:00:16 AM	15.2	9.0
10:01:16 AM	15.2	9.0
10:02:16 AM	15.2	8.9
10:03:16 AM	15.3	8.8
10:04:16 AM	15.2	8.7
10:05:16 AM	15.2	8.7
10:06:16 AM	15.3	8.7
10:07:16 AM	15.3	8.7
10:08:16 AM	15.3	8.7
10:09:16 AM	15.3	8.7
10:10:16 AM	15.2	8.9
10:11:16 AM	15.3	8.7
Run Avgs	15.3	8.7
Cal Gas	12.0	10.2
Initial Zero	0.3	0.1
Final Zero	0.5	0.1
Initial cal.	12.2	9.9
Final Cal.	12.1	9.9
Corrected Average	15.2	9.0

Client: Holcim Midlothian
 Test Location: Line 1 Main Stack; Raw Mill On
 Date: Nov 15, 2023 Start Time: 10:33:34
 Run number 2
 One Minute Averages

	Out O2 %dry	Out CO2 %dry
10:34:32 AM	15.2	8.8
10:35:32 AM	15.2	8.8
10:36:32 AM	15.2	8.7
10:37:32 AM	15.3	8.7
10:38:32 AM	15.3	8.6
10:39:32 AM	15.3	8.7
10:40:32 AM	15.3	8.8
10:41:32 AM	15.4	8.6
10:42:32 AM	15.3	8.7
10:43:32 AM	15.4	8.6
10:44:32 AM	15.4	8.6
10:45:32 AM	15.3	8.8
10:46:32 AM	15.4	8.7
10:47:32 AM	15.4	8.6
10:48:32 AM	15.4	8.9
10:49:32 AM	15.3	9.0
10:50:32 AM	15.3	8.8
10:51:32 AM	15.4	8.6
10:52:32 AM	15.4	8.6
10:53:32 AM	15.4	8.6
10:54:32 AM	15.4	8.5
10:55:32 AM	15.4	8.6
10:56:32 AM	15.5	8.5
10:57:32 AM	15.5	8.5
10:58:32 AM	15.4	8.6
10:59:32 AM	15.4	8.6
11:00:32 AM	15.4	8.6
11:01:32 AM	15.4	8.6
11:02:32 AM	15.4	8.7
11:03:32 AM	15.4	8.7
11:04:32 AM	15.3	8.9
11:05:32 AM	15.3	9.1
11:06:32 AM	15.2	8.9
11:07:32 AM	15.3	8.7
11:08:32 AM	15.3	8.6
11:09:32 AM	15.4	8.6
11:10:32 AM	15.4	8.6
11:11:32 AM	15.4	8.6
11:12:32 AM	15.4	8.7
11:13:32 AM	15.4	8.6
11:14:32 AM	15.4	8.6
11:15:32 AM	15.4	8.7
11:16:32 AM	15.4	8.6
11:17:32 AM	15.4	8.6
11:18:32 AM	15.4	8.6
11:19:32 AM	15.4	8.5
11:20:32 AM	15.3	9.0
11:21:32 AM	15.3	9.0
11:22:32 AM	15.4	8.7
11:23:32 AM	15.4	8.6
11:24:32 AM	15.5	8.5
11:25:32 AM	15.4	8.6
11:26:32 AM	15.4	8.5
11:27:32 AM	15.4	8.5
11:28:32 AM	15.4	8.7
11:29:32 AM	15.4	8.7
11:30:32 AM	15.4	8.7
11:31:32 AM	15.4	8.6
11:32:32 AM	15.4	8.6
11:33:32 AM	15.4	8.7
11:34:32 AM	15.4	8.6
11:35:32 AM	15.4	8.6
11:36:32 AM	15.3	9.0
11:37:32 AM	15.3	8.9
11:38:32 AM	15.2	9.0
11:39:32 AM	15.4	8.7
11:40:32 AM	15.4	8.7
11:41:32 AM	15.3	8.7
Run Avgs	15.4	8.7
Cal Gas	12.0	10.2
Initial Zero	0.3	0.1
Final Zero	0.5	0.1
Initial cal.	12.1	9.9
Final Cal.	12.3	9.8
Corrected Average	15.2	9.0

Client: Holcim Midlothian
 Test Location: Line 1 Main Stack; Raw Mill On
 Date: Nov 15, 2023 Start Time: 12:02:28
 Run number 3
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
12:03:26 PM	15.4	8.6
12:04:26 PM	15.4	8.6
12:05:26 PM	15.4	8.6
12:06:26 PM	15.5	8.6
12:07:26 PM	15.5	8.5
12:08:26 PM	15.4	8.9
12:09:26 PM	15.4	8.9
12:10:26 PM	15.5	8.6
12:11:26 PM	15.4	8.7
12:12:26 PM	15.5	8.5
12:13:26 PM	15.4	8.7
12:14:26 PM	15.5	8.6
12:15:26 PM	15.5	8.5
12:16:26 PM	15.4	8.6
12:17:26 PM	15.5	8.6
12:18:26 PM	15.4	8.6
12:19:26 PM	15.4	8.6
12:20:26 PM	15.4	8.6
12:21:26 PM	15.4	8.7
12:22:26 PM	15.4	8.6
12:23:26 PM	15.5	8.6
12:24:26 PM	15.4	9.0
12:25:26 PM	15.3	9.0
12:26:26 PM	15.3	8.8
12:27:26 PM	15.4	8.7
12:28:26 PM	15.4	8.7
12:29:26 PM	15.4	8.7
12:30:26 PM	15.4	8.6
12:31:26 PM	15.3	8.7
12:32:26 PM	15.4	8.6
12:33:26 PM	15.5	8.5
12:34:26 PM	15.3	8.7
12:35:26 PM	15.4	8.7
12:36:26 PM	15.4	8.8
12:37:26 PM	15.4	8.7
12:38:26 PM	15.4	8.6
12:39:26 PM	15.4	8.7
12:40:26 PM	15.5	8.9
12:41:26 PM	15.4	8.9
12:42:26 PM	15.5	8.7
12:43:26 PM	15.5	8.5
12:44:26 PM	15.5	8.6
12:45:26 PM	15.5	8.5
12:46:26 PM	15.5	8.5
12:47:26 PM	15.5	8.5
12:48:26 PM	15.5	8.6
12:49:26 PM	15.5	8.7
12:50:26 PM	15.5	8.6
12:51:26 PM	15.4	8.7
12:52:26 PM	15.4	8.6
12:53:26 PM	15.5	8.5
12:54:26 PM	15.4	8.6
12:55:26 PM	15.5	8.6
12:56:26 PM	15.4	9.0
12:57:26 PM	15.3	9.0
12:58:26 PM	15.4	8.7
12:59:26 PM	15.4	8.6
1:00:26 PM	15.5	8.5
1:01:26 PM	15.5	8.5
1:02:26 PM	15.5	8.5
1:03:26 PM	15.6	8.5
1:04:26 PM	15.5	8.6
1:05:26 PM	15.6	8.5
1:06:26 PM	15.5	8.6
1:07:26 PM	15.6	8.5
1:08:26 PM	15.6	8.5
1:09:26 PM	15.5	8.6
1:10:26 PM	15.5	8.6
1:11:26 PM	15.5	8.6
Run Avgs	15.5	8.6
Cal Gas	12.0	10.2
Initial Zero	0.5	0.1
Final Zero	0.5	0.1
Initial cal.	12.3	9.8
Final Cal.	12.3	9.7
Corrected Average	15.2	9.0

Holcim, Midlothian TX

Line 1 Main Stack; Raw Mill On

November 15, 2023

Operator *ES*

Cylinder ID	Gas Type	Value	Internal Response	Cal Error	Run No. 1			Run No. 2			Run No. 3					
					Pre Run Bias	Post Run Bias	Percent Bias	Pre Run Bias	Post Run Bias	Percent Bias	Pre Run Bias	Post Run Bias	Percent Bias			
	O2 Zero	Zero N2	0.0%	0.00%	0.3%	1.36%	0.00%	0.3%	1.36%	2.27%	0.91%	0.5%	2.27%	0.5%	2.27%	0.00%
CC194988	O2 Mid	12.0%	12.0%	0.23%	12.1%	0.45%	-0.45%	12.1%	0.45%	12.3%	0.91%	12.3%	1.36%	12.3%	1.36%	0.00%
CC427971	O2 Span	22.1%	21.9%	-0.73%												
	CO2 Zero	Zero N2	0.0%	0.00%	0.1%	0.55%	0.00%	0.1%	0.55%	0.1%	0.00%	0.1%	0.55%	0.1%	0.55%	0.00%
CC194988	CO2 Mid	10.2%	10.0%	-0.88%	9.9%	-0.55%	0.00%	9.9%	-0.55%	9.8%	-0.55%	9.8%	-1.10%	9.7%	-1.10%	-0.55%
CC427971	CO2 Span	18.2%	18.3%	0.66%												

09:00-10:09

10:32-11:41

12:02-13:11

Client: Holcim Midlothian
 Test Location: Line 1 Main Stack; Raw Mill Off
 Date: Nov 15, 2023 Start Time: 14:32:06
 Run number 1
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
2:33:04 PM	14.0	10.9
2:34:04 PM	14.1	10.6
2:35:04 PM	14.1	10.6
2:36:04 PM	14.1	10.5
2:37:04 PM	14.1	10.4
2:38:04 PM	14.1	10.5
2:39:04 PM	14.2	10.3
2:40:04 PM	14.1	10.4
2:41:04 PM	14.1	10.5
2:42:04 PM	14.1	10.4
2:43:04 PM	14.0	10.5
2:44:04 PM	14.1	10.4
2:45:04 PM	14.1	10.5
2:46:04 PM	14.1	10.4
2:47:04 PM	14.2	10.3
2:48:04 PM	14.1	10.8
2:49:04 PM	14.1	10.8
2:50:04 PM	14.1	10.6
2:51:04 PM	14.2	10.5
2:52:04 PM	14.2	10.5
2:53:04 PM	14.2	10.5
2:54:04 PM	14.2	10.3
2:55:04 PM	14.2	10.2
2:56:04 PM	14.2	10.3
2:57:04 PM	14.3	10.2
2:58:04 PM	14.2	10.3
2:59:04 PM	14.2	10.3
3:00:04 PM	14.2	10.5
3:01:04 PM	14.2	10.4
3:02:04 PM	14.3	10.2
3:03:04 PM	14.2	10.3
3:04:04 PM	14.2	10.6
3:05:04 PM	14.1	10.7
3:06:04 PM	14.2	10.5
3:07:04 PM	14.2	10.3
3:08:04 PM	14.2	10.3
3:09:04 PM	14.2	10.3
3:10:04 PM	14.2	10.3
3:11:04 PM	14.2	10.2
3:12:04 PM	14.3	10.2
3:13:04 PM	14.2	10.3
3:14:04 PM	14.3	10.2
3:15:04 PM	14.3	10.2
3:16:04 PM	14.2	10.3
3:17:04 PM	14.3	10.2
3:18:04 PM	14.3	10.3
3:19:04 PM	14.3	10.2
3:20:04 PM	14.3	10.3
3:21:04 PM	14.2	10.5
3:22:04 PM	14.3	10.4
3:23:04 PM	14.2	10.4
3:24:04 PM	14.2	10.3
3:25:04 PM	14.3	10.2
3:26:04 PM	14.2	10.4
3:27:04 PM	14.2	10.4
3:28:04 PM	14.2	10.4
3:29:04 PM	14.1	10.5
3:30:04 PM	14.1	10.5
3:31:04 PM	14.1	10.4
3:32:04 PM	14.2	10.3
3:33:04 PM	14.1	10.4
3:34:04 PM	14.1	10.4
3:35:04 PM	14.2	10.3
3:36:04 PM	14.1	10.7
3:37:04 PM	14.3	10.6
3:38:04 PM	14.3	10.3
3:39:04 PM	14.3	10.3
3:40:04 PM	14.3	10.3
3:41:04 PM	14.2	10.3
3:42:04 PM	14.3	10.2
3:43:04 PM	14.2	10.3
Run Avgs	14.2	10.4
Cal Gas	12.0	10.2
Initial Zero	0.3	0.1
Final Zero	0.3	0.1
Initial cal.	12.2	9.9
Final Cal.	12.1	9.9
Corrected Average	14.1	10.7

Client: Holcim Midlothian
 Test Location: Line 1 Main Stack; Raw Mill Off
 Date: Nov 15, 2023 Start Time: 15:58:28
 Run number 2
 One Minute Averages

	Out O2 %dry	Out CO2 %dry
3:59:26 PM	14.2	10.3
4:00:26 PM	14.2	10.3
4:01:26 PM	14.1	10.4
4:02:26 PM	14.2	10.4
4:03:26 PM	14.2	10.5
4:04:26 PM	14.2	10.4
4:05:26 PM	14.2	10.4
4:06:26 PM	14.2	10.3
4:07:26 PM	14.3	10.3
4:08:26 PM	14.2	10.8
4:09:26 PM	14.2	10.6
4:10:26 PM	14.3	10.3
4:11:26 PM	14.3	10.3
4:12:26 PM	14.3	10.2
4:13:26 PM	14.3	10.3
4:14:26 PM	14.2	10.3
4:15:26 PM	14.3	10.3
4:16:26 PM	14.2	10.3
4:17:26 PM	14.2	10.3
4:18:26 PM	14.2	10.3
4:19:26 PM	14.2	10.3
4:20:26 PM	14.2	10.3
4:21:26 PM	14.2	10.4
4:22:26 PM	14.2	10.3
4:23:26 PM	14.2	10.4
4:24:26 PM	14.1	10.8
4:25:26 PM	14.2	10.6
4:26:26 PM	14.2	10.4
4:27:26 PM	14.3	10.3
4:28:26 PM	14.2	10.3
4:29:26 PM	14.2	10.3
4:30:26 PM	14.3	10.2
4:31:26 PM	14.2	10.3
4:32:26 PM	14.3	10.2
4:33:26 PM	14.2	10.3
4:34:26 PM	14.2	10.3
4:35:26 PM	14.3	10.2
4:36:26 PM	14.2	10.3
4:37:26 PM	14.3	10.2
4:38:26 PM	14.3	10.2
4:39:26 PM	14.3	10.3
4:40:26 PM	14.1	10.8
4:41:26 PM	14.0	10.9
4:42:26 PM	14.0	10.6
4:43:26 PM	14.0	10.5
4:44:26 PM	14.0	10.6
4:45:26 PM	14.1	10.3
4:46:26 PM	14.0	10.5
4:47:26 PM	14.1	10.3
4:48:26 PM	14.2	10.2
4:49:26 PM	14.2	10.3
4:50:26 PM	14.2	10.3
4:51:26 PM	14.2	10.4
4:52:26 PM	14.2	10.4
4:53:26 PM	14.2	10.4
4:54:26 PM	14.1	10.5
4:55:26 PM	14.2	10.4
4:56:26 PM	14.1	10.8
4:57:26 PM	14.0	10.8
4:58:26 PM	14.0	10.7
4:59:26 PM	14.0	10.7
5:00:26 PM	14.0	10.7
5:01:26 PM	13.9	10.7
5:02:26 PM	13.9	10.7
5:03:26 PM	14.0	10.7
5:04:26 PM	13.9	10.8
5:05:26 PM	13.9	10.8
5:06:26 PM	13.8	10.9
5:07:26 PM	13.8	10.8
Run Avgs	14.2	10.4
Cal Gas	12.0	10.2
Initial Zero	0.3	0.1
Final Zero	0.4	0.1
Initial cal.	12.1	9.9
Final Cal.	12.2	9.8
Corrected Average	14.0	10.8

Client: Holcim Midlothian
 Test Location: Line 1 Main Stack; Raw Mill Off
 Date: Nov 15, 2023 Start Time: 17:22:32
 Run number 3
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
5:23:30 PM	14.0	10.7
5:24:30 PM	13.9	10.8
5:25:30 PM	13.9	10.7
5:26:30 PM	13.9	10.7
5:27:30 PM	13.9	10.8
5:28:30 PM	13.9	11.0
5:29:30 PM	13.8	11.1
5:30:30 PM	13.9	10.9
5:31:30 PM	13.9	10.8
5:32:30 PM	14.0	10.7
5:33:30 PM	14.1	10.4
5:34:30 PM	14.0	10.5
5:35:30 PM	14.1	10.4
5:36:30 PM	14.1	10.4
5:37:30 PM	14.0	10.5
5:38:30 PM	14.1	10.4
5:39:30 PM	14.0	10.5
5:40:30 PM	14.0	10.5
5:41:30 PM	14.0	10.6
5:42:30 PM	14.0	10.7
5:43:30 PM	14.0	10.7
5:44:30 PM	13.9	11.1
5:45:30 PM	13.9	11.0
5:46:30 PM	13.9	10.9
5:47:30 PM	13.9	10.9
5:48:30 PM	14.0	10.7
5:49:30 PM	14.0	10.6
5:50:30 PM	14.0	10.7
5:51:30 PM	14.0	10.7
5:52:30 PM	13.9	10.8
5:53:30 PM	13.9	10.8
5:54:30 PM	13.9	10.8
5:55:30 PM	13.9	10.8
5:56:30 PM	13.9	10.9
5:57:30 PM	13.8	10.9
5:58:30 PM	13.9	10.7
5:59:30 PM	13.9	10.8
6:00:30 PM	13.8	11.2
6:01:30 PM	13.9	11.0
6:02:30 PM	13.9	10.9
6:03:30 PM	13.9	10.8
6:04:30 PM	13.9	10.8
6:05:30 PM	13.8	10.9
6:06:30 PM	13.9	10.9
6:07:30 PM	13.8	10.9
6:08:30 PM	13.9	10.8
6:09:30 PM	13.8	10.9
6:10:30 PM	13.8	10.9
6:11:30 PM	13.8	10.9
6:12:30 PM	13.7	11.1
6:13:30 PM	13.7	11.1
6:14:30 PM	13.7	11.1
6:15:30 PM	13.7	11.2
6:16:30 PM	13.6	11.5
6:17:30 PM	13.6	11.5
6:18:30 PM	13.6	11.3
6:19:30 PM	13.6	11.2
6:20:30 PM	13.6	11.1
6:21:30 PM	13.7	11.0
6:22:30 PM	13.7	11.1
6:23:30 PM	13.8	11.0
6:24:30 PM	13.8	11.1
6:25:30 PM	13.8	11.1
6:26:30 PM	13.8	11.0
6:27:30 PM	13.8	11.1
6:28:30 PM	13.8	11.0
6:29:30 PM	13.8	11.0
6:30:30 PM	13.8	11.0
Run Avgs	13.9	10.9
Cal Gas	12.0	10.2
Initial Zero	0.4	0.1
Final Zero	0.5	0.1
Initial cal.	12.2	9.8
Final Cal.	12.3	9.7
Corrected Average	13.6	11.4

Holcim, Midlothian TX Line 1 Mill Off Main Stack November 15, 2023 Operator

Cylinder ID	Gas Type	Value	Internal Response	Cal Error	Run No. 4			Run No. 5			Run No. 6		
					Pre Run Bias	Post Run Bias	Percent Bias	Pre Run Bias	Post Run Bias	Percent Bias	Pre Run Bias	Post Run Bias	Percent Bias
	O2 Zero	Zero N2	0.0%	0.00%	0.3%	0.3%	1.36%	0.4%	1.81%	0.4%	1.81%	0.5%	2.27%
CC194988	O2 Mid	12.0%	12.1%	0.68%	12.2%	12.1%	0.00%	12.2%	0.45%	12.2%	0.45%	12.3%	0.91%
CC427971	O2 Span	22.1%	22.2%	0.63%									
	CO2 Zero	Zero N2	0.0%	0.00%	0.1%	0.1%	0.55%	0.1%	0.55%	0.1%	0.55%	0.1%	0.55%
CC194988	CO2 Mid	10.2%	10.0%	-0.88%	9.9%	9.9%	-0.55%	9.8%	-1.10%	9.8%	-1.10%	9.7%	-1.65%
CC427971	CO2 Span	18.2%	18.2%	0.11%									

Operator

**Holcim
Midlothian TX
Line 1 Main Stack; Mill On
HCN Analyte Spikes**

Date		11/15/23	11/15/23	11/15/23	11/15/23
Time		08:47-08:59	10:16-10:34	11:42-11:56	13:16-13:56
		Main Pre 1	Main Post 1	Main Post 2	Main Post 3
		HCN	HCN	HCN	HCN
Cs	Spike Direct, ppm	197.48	197.48	197.48	197.48
	SF6 Tracer Direct, ppm	9.55	9.55	9.55	9.55
SF6	Diluted SF6 Tracer, ppm	0.829	0.826	0.747	0.805
	Diluted SF6 Tracer, ppm	0.803	0.795	0.720	0.811
	Average Diluted SF6 Tracer, ppm	0.816	0.811	0.734	0.808
DF	Dilution Ratio	11.71	11.79	13.02	11.82
	Total, ppm	34.551	32.644	29.886	31.374
	Total, ppm	34.229	32.137	29.895	31.851
Ct	Average Total, ppm	34.390	32.391	29.891	31.613
	Pre Spike Native , ppm	23.322	19.618	18.623	19.615
	Pre Spike Native , ppm	21.885	19.511	18.494	18.694
	Post Spike Native , ppm	22.264	20.280	19.480	21.048
	Post Spike Native , ppm	21.122	20.108	19.447	20.155
Cn	Average Native , ppm	22.148	19.879	19.011	19.878
	Spike Recovery	83.8%	84.7%	81.4%	80.3%
	CTS Direct (CC426155)				
	Ethylene Expected (ppm)	75.47			75.47
	Ethylene Measured (ppm)	73.88			74.09
	CTS Error	-2.1%			-1.8%

**Holcim
Midlothian TX
Line 1 Main Stack; Mill Off
HCN Analyte Spikes**

Date		11/15/23	11/15/23	11/15/23	11/15/23
Time		14:15-14:37	15:42-16:08	17:07-17:36	18:30-18:54
		Main Pre 1	Main Post 1	Main Post 2	Main Post 3
		HCN	HCN	HCN	HCN
Cs	Spike Direct, ppm	197.48	197.48	197.48	197.48
	SF6 Tracer Direct, ppm	9.55	9.55	9.55	9.55
SF6	Diluted SF6 Tracer, ppm	0.844	0.843	0.816	0.840
	Diluted SF6 Tracer, ppm	0.841	0.839	0.818	0.852
	Average Diluted SF6 Tracer, ppm	0.843	0.841	0.817	0.846
DF	Dilution Ratio	11.34	11.36	11.69	11.29
	Total, ppm	35.036	33.941	32.031	33.916
	Total, ppm	34.896	34.479	32.256	34.300
Ct	Average Total, ppm	34.966	34.210	32.144	34.108
	Pre Spike Native , ppm	22.763	21.069	20.882	22.309
	Pre Spike Native , ppm	21.666	21.738	20.981	20.938
	Post Spike Native , ppm	23.189	22.003	19.833	21.508
	Post Spike Native , ppm	22.797	21.750	19.508	21.015
Cn	Average Native , ppm	22.604	21.640	20.301	21.443
	Spike Recovery	82.4%	83.3%	80.4%	83.3%
	CTS Direct				
	Ethylene Expected (ppm)	75.48			75.48
	Ethylene Measured (ppm)	73.81			74.01
	CTS Error	-2.2%			-1.9%

Holcim Midlothian TX
Line 1 Main Stack; Raw Mill On
Pre Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA	191C 191c	SF6 (10) 191C
SPC__001491.LAB	11/15/23	08:46:04.170	23.528		-0.007
SPC__001492.LAB	11/15/23	08:47:08.083	23.322		-0.005
SPC__001493.LAB	11/15/23	08:48:11.985	21.885		-0.006
SPC__001494.LAB	11/15/23	08:49:15.930	20.761		0.015
SPC__001495.LAB	11/15/23	08:50:19.805	33.724		0.846
SPC__001496.LAB	11/15/23	08:51:23.771	34.551		0.829
SPC__001497.LAB	11/15/23	08:52:27.616	34.229		0.803
SPC__001498.LAB	11/15/23	08:53:31.573	33.270		0.742
SPC__001499.LAB	11/15/23	08:54:35.478	18.845		0.774
SPC__001500.LAB	11/15/23	08:55:39.321	0.606		0.014
SPC__001501.LAB	11/15/23	08:58:13.641	22.264		-0.005
SPC__001502.LAB	11/15/23	08:59:17.595	21.122		-0.005

Holcim Midlothian TX
 Line 1 Main Stack; Raw Mill On
 Post Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__001573.LAB	11/15/23	10:14:54.758	19.636	-0.004
SPC__001574.LAB	11/15/23	10:15:58.905	19.618	-0.003
SPC__001575.LAB	11/15/23	10:17:02.564	19.511	-0.004
SPC__001576.LAB	11/15/23	10:18:06.513	18.787	0.007
SPC__001577.LAB	11/15/23	10:19:10.386	24.148	0.361
SPC__001578.LAB	11/15/23	10:20:14.597	37.417	1.345
SPC__001579.LAB	11/15/23	10:21:18.153	5.002	0.011
SPC__001580.LAB	11/15/23	10:22:22.068	19.021	-0.003
SPC__001581.LAB	11/15/23	10:23:25.930	29.965	0.691
SPC__001582.LAB	11/15/23	10:24:30.119	32.644	0.826
SPC__001583.LAB	11/15/23	10:25:34.128	32.137	0.795
SPC__001584.LAB	11/15/23	10:26:37.720	32.350	0.826
SPC__001585.LAB	11/15/23	10:27:41.526	19.642	0.781
SPC__001586.LAB	11/15/23	10:28:45.819	1.158	0.008
SPC__001587.LAB	11/15/23	10:29:49.346	0.208	0.003
SPC__001588.LAB	11/15/23	10:31:27.468	7.029	0.001
SPC__001589.LAB	11/15/23	10:32:31.133	20.280	-0.007
SPC__001590.LAB	11/15/23	10:33:35.046	20.108	-0.007

Holcim Midlothian TX
Line 1 Main Stack; Raw Mill On
Post Run 2 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__001653.LAB	11/15/23	11:40:40.813	18.879	-0.004
SPC__001654.LAB	11/15/23	11:41:44.649	18.623	-0.006
SPC__001655.LAB	11/15/23	11:42:48.507	18.494	-0.006
SPC__001656.LAB	11/15/23	11:43:52.452	18.019	0.009
SPC__001657.LAB	11/15/23	11:44:56.342	24.679	0.424
SPC__001658.LAB	11/15/23	11:46:00.241	29.886	0.747
SPC__001659.LAB	11/15/23	11:47:04.152	29.895	0.720
SPC__001660.LAB	11/15/23	11:48:08.116	38.774	1.200
SPC__001661.LAB	11/15/23	11:49:11.888	6.433	0.206
SPC__001662.LAB	11/15/23	11:50:15.859	0.403	0.003
SPC__001663.LAB	11/15/23	11:51:19.686	0.302	0.007
SPC__001664.LAB	11/15/23	11:52:23.683	8.407	0.000
SPC__001665.LAB	11/15/23	11:53:27.505	19.794	-0.003
SPC__001666.LAB	11/15/23	11:54:31.510	19.890	-0.003
SPC__001667.LAB	11/15/23	11:55:35.294	19.684	-0.004
SPC__001668.LAB	11/15/23	11:56:39.196	19.480	-0.006
SPC__001669.LAB	11/15/23	11:57:43.088	19.447	-0.004

Holcim Midlothian TX
 Line 1 Main Stack; Raw Mill On
 Post Run 3 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__001739.LAB	11/15/23	13:14:16.384	19.574	-0.005
SPC__001740.LAB	11/15/23	13:15:20.237	19.396	-0.008
SPC__001741.LAB	11/15/23	13:16:24.231	19.615	-0.005
SPC__001742.LAB	11/15/23	13:17:28.092	18.694	0.006
SPC__001743.LAB	11/15/23	13:18:31.891	22.960	0.274
SPC__001744.LAB	11/15/23	13:19:35.833	29.425	0.699
SPC__001745.LAB	11/15/23	13:20:39.735	31.732	0.811
SPC__001746.LAB	11/15/23	13:21:43.629	31.374	0.805
SPC__001747.LAB	11/15/23	13:22:47.483	31.851	0.811
SPC__001748.LAB	11/15/23	13:23:51.712	30.971	0.738
SPC__001749.LAB	11/15/23	13:24:55.274	26.032	0.789
SPC__001750.LAB	11/15/23	13:25:59.167	4.697	0.007
SPC__001751.LAB	11/15/23	13:27:03.064	0.268	0.002
SPC__001752.LAB	11/15/23	13:28:06.967	-0.024	0.002
SPC__001753.LAB	11/15/23	13:29:10.916	12.067	-0.001
SPC__001754.LAB	11/15/23	13:30:15.075	21.048	-0.008
SPC__001755.LAB	11/15/23	13:31:18.783	20.155	-0.005

Holcim Midlothian TX

Line 1 Main Stack; Raw Mill On

Post Run 3 HCN Analyte Spike

Spectrum	Date	Time	Ethylene (100,3000) 191C
SPC__001776.LAB	11/15/23	13:53:40.521	73.896
SPC__001777.LAB	11/15/23	13:54:44.421	74.082
SPC__001778.LAB	11/15/23	13:55:48.323	74.093
SPC__001779.LAB	11/15/23	13:56:52.213	34.189

Holcim Midlothian TX
Line 1 Main Stack; Raw Mill Off
Pre Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__001796.LAB	11/15/23	14:21:14.943	23.961	-0.007
SPC__001797.LAB	11/15/23	14:22:18.854	22.763	-0.008
SPC__001798.LAB	11/15/23	14:23:22.710	21.666	-0.004
SPC__001799.LAB	11/15/23	14:24:26.603	31.170	0.677
SPC__001800.LAB	11/15/23	14:25:30.500	33.561	0.776
SPC__001801.LAB	11/15/23	14:26:34.408	34.100	0.783
SPC__001802.LAB	11/15/23	14:27:38.458	35.036	0.844
SPC__001803.LAB	11/15/23	14:28:42.192	34.896	0.841
SPC__001804.LAB	11/15/23	14:29:46.080	27.287	0.887
SPC__001805.LAB	11/15/23	14:30:49.973	0.757	0.005
SPC__001806.LAB	11/15/23	14:31:53.877	1.508	0.010
SPC__001807.LAB	11/15/23	14:32:58.170	23.681	-0.008
SPC__001808.LAB	11/15/23	14:34:01.784	24.114	-0.008
SPC__001809.LAB	11/15/23	14:35:05.967	23.518	-0.008
SPC__001810.LAB	11/15/23	14:36:09.778	22.876	-0.009
SPC__001811.LAB	11/15/23	14:37:13.381	23.189	-0.009
SPC__001812.LAB	11/15/23	14:38:17.278	22.797	-0.007
SPC__001813.LAB	11/15/23	14:39:21.525	22.672	-0.009

Holcim Midlothian TX
 Line 1 Main Stack; Raw Mill Off
 Post Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__001871.LAB	11/15/23	15:41:07.261	21.812	-0.004
SPC__001872.LAB	11/15/23	15:42:11.129	21.069	-0.008
SPC__001873.LAB	11/15/23	15:43:15.136	21.738	-0.005
SPC__001874.LAB	11/15/23	15:45:23.326	24.427	0.226
SPC__001875.LAB	11/15/23	15:46:27.224	30.655	0.630
SPC__001876.LAB	11/15/23	15:47:31.259	32.245	0.704
SPC__001877.LAB	11/15/23	15:48:35.011	33.941	0.843
SPC__001878.LAB	11/15/23	15:49:38.913	34.479	0.839
SPC__001879.LAB	11/15/23	15:50:42.902	40.431	1.213
SPC__001880.LAB	11/15/23	15:51:46.688	1.284	0.016
SPC__001881.LAB	11/15/23	15:52:51.013	0.410	0.002
SPC__001882.LAB	11/15/23	15:53:54.491	1.104	0.008
SPC__001883.LAB	11/15/23	15:54:58.491	23.758	-0.006
SPC__001884.LAB	11/15/23	15:56:02.299	23.611	-0.005
SPC__001885.LAB	11/15/23	15:57:40.634	22.397	-0.008
SPC__001886.LAB	11/15/23	15:58:44.529	22.253	-0.006
SPC__001887.LAB	11/15/23	15:59:48.781	22.485	-0.007
SPC__001888.LAB	11/15/23	16:00:52.328	22.517	-0.005
SPC__001889.LAB	11/15/23	16:01:56.224	22.294	-0.009
SPC__001890.LAB	11/15/23	16:03:00.213	22.261	-0.004
SPC__001891.LAB	11/15/23	16:04:04.063	22.235	-0.007
SPC__001892.LAB	11/15/23	16:05:08.316	22.363	-0.007
SPC__001893.LAB	11/15/23	16:06:11.815	22.481	-0.004
SPC__001894.LAB	11/15/23	16:07:16.099	22.003	-0.007
SPC__001895.LAB	11/15/23	16:08:19.609	21.750	-0.005

Holcim Midlothian TX
 Line 1 Main Stack; Raw Mill Off
 Post Run 2 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__001946.LAB	11/15/23	17:02:38.377	21.165	-0.007
SPC__001947.LAB	11/15/23	17:03:42.275	20.882	-0.008
SPC__001948.LAB	11/15/23	17:04:46.556	20.981	-0.008
SPC__001949.LAB	11/15/23	17:05:50.121	21.122	-0.008
SPC__001950.LAB	11/15/23	17:06:53.968	21.330	-0.008
SPC__001951.LAB	11/15/23	17:07:57.907	20.158	-0.002
SPC__001952.LAB	11/15/23	17:09:02.144	24.616	0.308
SPC__001953.LAB	11/15/23	17:10:05.670	32.031	0.816
SPC__001954.LAB	11/15/23	17:11:09.555	32.256	0.818
SPC__001955.LAB	11/15/23	17:12:13.838	40.879	1.298
SPC__001956.LAB	11/15/23	17:13:17.323	3.530	0.026
SPC__001957.LAB	11/15/23	17:14:21.322	0.202	0.003
SPC__001958.LAB	11/15/23	17:15:25.515	1.230	0.008
SPC__001959.LAB	11/15/23	17:16:29.042	21.698	-0.010
SPC__001960.LAB	11/15/23	17:17:33.326	21.275	-0.008
SPC__001961.LAB	11/15/23	17:18:36.839	20.966	-0.006
SPC__001962.LAB	11/15/23	17:19:40.737	21.027	-0.010
SPC__001963.LAB	11/15/23	17:20:45.019	21.196	-0.010
SPC__001964.LAB	11/15/23	17:21:48.882	21.034	-0.009
SPC__001965.LAB	11/15/23	17:22:52.430	21.180	-0.009
SPC__001966.LAB	11/15/23	17:23:56.675	21.472	-0.006
SPC__001967.LAB	11/15/23	17:25:00.224	21.563	-0.010
SPC__001968.LAB	11/15/23	17:26:04.239	21.468	-0.007
SPC__001969.LAB	11/15/23	17:27:08.021	21.710	-0.011
SPC__001970.LAB	11/15/23	17:28:12.029	21.539	-0.007
SPC__001971.LAB	11/15/23	17:29:15.820	21.388	-0.008
SPC__001972.LAB	11/15/23	17:30:19.713	20.772	-0.009
SPC__001973.LAB	11/15/23	17:31:23.605	20.933	-0.009
SPC__001974.LAB	11/15/23	17:32:27.503	20.213	-0.006
SPC__001975.LAB	11/15/23	17:33:31.403	20.122	-0.010
SPC__001976.LAB	11/15/23	17:34:35.298	19.833	-0.010
SPC__001977.LAB	11/15/23	17:35:39.304	19.508	-0.008
SPC__001978.LAB	11/15/23	17:36:43.210	19.466	-0.007

Holcim Midlothian TX

Line 1 Main Stack; Raw Mill Off

Post Run 3 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__002027.LAB	11/15/23	18:28:54.053	22.543	-0.009	6.742
SPC__002028.LAB	11/15/23	18:29:57.952	22.386	-0.009	6.790
SPC__002029.LAB	11/15/23	18:31:01.851	22.309	-0.008	6.751
SPC__002030.LAB	11/15/23	18:32:05.746	20.938	0.005	6.268
SPC__002031.LAB	11/15/23	18:33:09.643	30.949	0.676	6.385
SPC__002032.LAB	11/15/23	18:34:13.926	33.916	0.840	6.239
SPC__002033.LAB	11/15/23	18:35:17.437	34.300	0.852	6.325
SPC__002034.LAB	11/15/23	18:36:21.314	43.068	1.349	6.008
SPC__002035.LAB	11/15/23	18:37:25.210	2.086	0.038	0.092
SPC__002036.LAB	11/15/23	18:38:29.212	0.477	0.004	0.230
SPC__002037.LAB	11/15/23	18:39:33.059	5.616	0.006	1.755
SPC__002038.LAB	11/15/23	18:40:36.950	23.034	-0.010	6.812
SPC__002039.LAB	11/15/23	18:41:41.137	22.640	-0.008	6.594
SPC__002040.LAB	11/15/23	18:42:44.719	21.960	-0.008	6.586
SPC__002041.LAB	11/15/23	18:43:48.617	21.948	-0.006	6.509
SPC__002042.LAB	11/15/23	18:44:52.514	21.508	-0.009	6.292
SPC__002043.LAB	11/15/23	18:45:56.402	21.015	-0.006	6.041
SPC__002044.LAB	11/15/23	18:47:00.671	9.307	-0.005	2.416
SPC__002045.LAB	11/15/23	18:48:04.288	0.055	0.002	0.092
SPC__002046.LAB	11/15/23	18:49:08.080	-0.018	0.003	0.044
SPC__002047.LAB	11/15/23	18:50:12.085	-0.236	0.002	0.076
SPC__002048.LAB	11/15/23	18:51:15.865	-0.267	-0.006	11.843
SPC__002049.LAB	11/15/23	18:52:19.953	-0.129	-0.012	73.697
SPC__002050.LAB	11/15/23	18:53:23.666	-0.275	-0.014	74.026
SPC__002051.LAB	11/15/23	18:54:27.603	-0.227	-0.011	74.004
SPC__002052.LAB	11/15/23	18:55:31.556	-0.214	-0.018	42.212

Holcim Midlothian TX

Line 1 Main Stack

CTS and HCN Analyte Spike Direct

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__001443.LAB	11/15/23	07:46:34.518	-0.290	-0.002	0.012
SPC__001444.LAB	11/15/23	07:47:38.632	-0.350	0.000	0.004
SPC__001445BKG.LAB	11/15/23	07:50:17.074	0.000	0.000	0.000
SPC__001446.LAB	11/15/23	07:51:27.137	-0.100	-0.002	0.006
SPC__001447BKG.LAB	11/15/23	07:54:08.833	0.000	0.000	0.000
SPC__001448.LAB	11/15/23	07:55:19.307	0.007	-0.001	0.000
SPC__001449BKG.LAB	11/15/23	07:57:54.271	0.000	0.000	0.000
SPC__001450.LAB	11/15/23	07:59:04.430	-0.107	-0.001	0.033
SPC__001451BKG.LAB	11/15/23	08:01:34.658	0.000	0.000	0.000
SPC__001452.LAB	11/15/23	08:02:45.164	-0.008	-0.000	0.009
SPC__001453.LAB	11/15/23	08:03:49.323	-0.119	0.000	-0.036
SPC__001454BKG.LAB	11/15/23	08:06:33.203	0.000	0.000	0.000
SPC__001455.LAB	11/15/23	08:07:43.583	-0.017	0.000	-0.046
SPC__001456.LAB	11/15/23	08:08:47.528	-0.104	-0.018	35.255
SPC__001457.LAB	11/15/23	08:09:51.498	0.105	-0.014	73.910
SPC__001458.LAB	11/15/23	08:10:55.291	-0.064	-0.011	73.820
SPC__001459.LAB	11/15/23	08:11:59.198	-0.012	-0.016	73.934
SPC__001460.LAB	11/15/23	08:13:03.139	-0.171	-0.012	43.711
SPC__001461.LAB	11/15/23	08:14:06.995	108.496	4.835	4.737
SPC__001462.LAB	11/15/23	08:15:10.936	73.565	3.412	1.234
SPC__001463.LAB	11/15/23	08:16:14.803	190.561	9.217	-0.507
SPC__001464.LAB	11/15/23	08:17:18.710	197.204	9.549	-0.735
SPC__001465.LAB	11/15/23	08:18:22.657	197.345	9.554	-0.747
SPC__001466.LAB	11/15/23	08:19:26.512	197.512	9.557	-0.778
SPC__001467.LAB	11/15/23	08:20:30.796	197.446	9.550	-0.868
SPC__001468.LAB	11/15/23	08:21:34.434	197.240	9.552	-0.807
SPC__001469.LAB	11/15/23	08:22:38.221	196.159	9.537	-0.704
SPC__001470.LAB	11/15/23	08:23:42.507	195.611	9.529	-0.826



EPA Method 2 Gas Velocity and Cyclonic Flow Check

Plant	<u>LafargeHolcim Midlothian Facility</u>	Run Date	<u>111 5 120</u>
City	<u>Midlothian, TX</u>	Clock Time	<u>12 55</u>
Sampling Location	<u>Kiln System #2 Stack</u>	Run No.	<u>6762</u>
Operator	<u>MH/HE/SH/KW</u>	Ambient Temperature	<u>~75</u> deg. F
Barometric Pressure	<u>29.35</u> in. Hg	Mol. Wt.	<u>~27.9</u>
Static Pressure	<u>-0.51</u> in. H2O	Pitot Cp	<u>0.84</u>
Stack ID	Side 1 <u>164.063 in.</u>		
	Side 2 <u>164.063 in.</u>		

Traverse point number	Position in.	Velocity head Δp in. H2O	Stack temperature deg. F	Cyclonic Flow Determination	
				Δp at 0° reference	Angle (α) which yields a null Δp
1	See		138		12
2	M1		137		11
3	D&W		136		8
1			137		14
2			136		10
3			136		9
1			137		15
2			137		12
3			135		8
1			138		12
2			136		9
3			136		7
Average angle (α)*					10.6°

* Average of α must be $\leq 20^\circ$ to be acceptable

METHOD 26A FIELD DATA SHEET

PLANT AND CITY Holcim (US) Inc, Midlothian, TX	DATE 11 / 16 / 23	SAMPLING LOCATION Kiln 2 - System Stack	SAMPLE NO. Method 26A	RUN NUMBER Kiln 2 - 800 EFF - M36 1A
OPERATOR Grupe Maynard	AMBIENT PRESS (in. Hg) 29.97	STATIONARY AMBIENT TEMP (deg. F) 63	STACK FILTER NUMBERS 161.5" (K1) 164.063" (K2)	NOZZLE NUMBER 250
ASSUMED MOISTURE (%) 17-20%	DGM CAL FACTOR (1) 1.0	STACK TEMPERATURE (deg. F) 574	ORSAT NO. K -M5-	CO2 CORRECTION FACTOR 13-14% On - Off
TRAVEL TIME (MIN) 0	PITOT LEAK CHECK PASSED	STACK PITOT NO. 574	LEAK CHECK (INITIAL) 0.001 CU. FT @ 15" Hg	STACK PITOT COEFFICIENT 2.55
CLOCK TIME (24-HR) 14:30	DGM VELOCITY (in. H2O) 586.362	VELOCITY CORRECTION (in. H2O) 1.3	STACK TEMP (deg. F) 253	SAMPLE TRAIN (in. Hg) 4
TEST TIME (MIN) 5	DGM VELOCITY (in. H2O) 593.58	ORIFICE (in. H2O) 1.4	PROBE TEMP (deg. F) 251	4
POINT NO. 3	DGM VELOCITY (in. H2O) 593.58	ORIFICE (in. H2O) 1.4	PROBE TEMP (deg. F) 250	5
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT) 15:35 606.949	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG
INITIAL 14:37	FINAL 597.049	INITIAL 14:37	FINAL 600.54	INITIAL 14:37
15	48	1.2	255	133
20	600.54	1.2	256	134
25	603.90	1.3	254	134
30	606.949	End of Port	End of Port	End of Port
INITIAL 14:52	FINAL 606.949	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG
30	606.949	INITIAL 14:52	FINAL 610.34	INITIAL 14:52
35	610.34	58	54	1.3
40	613.93	54	54	1.4
45	616.620	End of Port	End of Port	End of Port
INITIAL 15:10	FINAL 616.620	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG
45	616.620	INITIAL 15:10	FINAL 619.32	INITIAL 15:10
50	619.32	48	47	1.2
55	622.119	46	46	1.2
60	625.646	End of Port	End of Port	End of Port
INITIAL 15:57	FINAL 625.646	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG	LEAK RATE: CU.FT @ CU.FT @ INCHES HG INCHES HG
45	625.646	INITIAL 15:57	FINAL 625.646	INITIAL 15:57
50	625.646	48	47	1.2
55	625.646	46	46	1.2
60	625.646	End of Port	End of Port	End of Port
TOTAL TIME 60 Min.	DGM VOLUME 625.646	AVERAGE delta P 1.2	AVERAGE delta H 134	AVERAGE TEMP 134

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/16/23
 Sample Location Kiln/ Mill ON OFF Recovery Date 11/16/23
 Run No. Kiln² Run / Mill ON (OFF-26A- 1A Recovered by GCJ
 Filter Number(s) N/A

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		762.5	757.2	653.1	784.9	890.2	978.1	g
Initial weight		749.1	741.6	645.4	754.3	761.3	967.1	g
Net weight		13.4	15.6	7.7	30.6	128.9	11	g

Description of impinger water clean 10 % spent
B/W Sil gel color
 Total moisture = 207.2 grams

RECOVERED SAMPLE

Filter container number(s) Noty Appliacable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln²Run \ Mill ON (OFF-26A-H2SO4- 1A

Liquid level
 marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln²Run (Mill ON (OFF-26A-NaOH - 1A

Liquid level
 marked/sealed

Train B

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE TYPE	RUN NUMBER
Holcim (US) Inc; Midlothian, TX	11/16/23	Klin 2 System Stack	Method 26A	Klin 2 - ON(OFF) -MSB-KB
OPERATOR	AMBIENT PRESS (In. Hg)	AMBIENT TEMP (deg F)	STACK FILTER NUMBERS	STACK ID (In.)
M. Powell	28.75	63	1577	161.5" (K1) 164.063" (K2)
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (%)	STACK THERM NO.	STACK PITOT NO.
~17-20%	MS-22	1.014	277	277
TRaverse ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING (in. cu. ft.)	DELTA P (in. H2O)	DELTA H ORIFICE (in. H2O)
A-1	0	1420	45.696	.51
2	5		49.06	1.4
3	10		52.34	1.5
15	1435	55.555		
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)				
B-1	15	1437	55.555	1.3
2	20		58.75	1.3
3	25		61.78	1.4
30	1452	64.879		
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)				
C-1	30	1454	64.879	1.4
2	35		67.96	1.4
3	40		72.21	1.4
45	1540	75.409		
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)				
D-1	45	1542	75.409	1.3
2	50		78.56	1.2
3	55		81.63	1.2
60	1557	84.622		
TOTAL TIME 60 Min.				
DGM VOLUME		DGM VOLUME		AVE delta P
DGM VOLUME		DGM VOLUME		AVE delta H
DGM VOLUME		DGM VOLUME		AVE TEMP
DGM VOLUME		DGM VOLUME		AVE TEMP

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/16/27
 Sample Location Kiln Mill ON OFF Recovery Date 11/16/27
 Run No. Kiln 2 Run 1 Mill ON OFF-26A-1B Recovered by GC5
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		867.5	777.2	615.9	755.4	754.8	984.8	g
Initial weight		743.4	740.8	612.4	750.4	753.9	973.9	g
Net weight		124.1	36.4	3.5	5.0	0.9	10.9	g

Description of impinger water clean 15 % spent
B/W Sil gel color
 Total moisture = 150.8 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 1 Mill ON OFF-26A-H2SO4-1B Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 1 Mill ON OFF-26A-NaOH-1B Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE RUN NUMBER
Holcim (US) Inc, Midlothian, TX	11 / 16 / 23	Klin System Stack	Method 26A
OPERATOR	AMBIENT PRESS (In. Hg)	AMBIENT TEMP (deg. F)	NOZZLE NUMBER
Gage Mayel	23.75	69	250
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (M)	K FACTOR
~17 - 20%	1.69	0.915	2.55
TRaverse ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	LEAK CHECK (INITIAL)
A-1 0	16.19	625.768	0.55084
2 5		629.02	0.55084
3 10		633.13	0.55084
15 16.34		636.161	0.55084
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ INCHES Hg	INCHES Hg
B-1 15	16.36	636.161	1.41
2 20	639.06	642.31	1.41
3 25	642.31	644.869	1.42
30 16.51			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ INCHES Hg	INCHES Hg
C-1 30	16.53	644.868	1.42
2 35		648.33	1.41
3 40		651.43	1.41
45 17.06		654.701	1.41
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ INCHES Hg	INCHES Hg
D-1 45	17.10	654.701	1.40
2 50		658.54	1.39
3 55		661.52	1.38
60 17.25		664.560	1.38
TOTAL TIME	DGM VOLUME	AVERAGE delta P	AVERAGE TEMP
60 Min.	664.560	1.4	55

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/16/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/16/23
 Run No. Kiln 2 Run 2 Mill ON OFF-26A-2A Recovered by GC
 Filter Number(s) N/A

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		895.3	802.5	604.4	765.5	726.4	930.5	g
Initial weight		757.2	745.2	619.3	762.7	725.9	920.4	g
Net weight		138.1	57.3	5.1	2.8	0.5	10.1	g

Description of impinger water clay 20 % spent
B/W Sil gel color
 Total moisture = 213.9 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 2 Mill ON OFF-26A-H2SO4- 2A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 2 Mill ON OFF-26A-NaOH 2A

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE NO.	RUN NUMBER
Holcim (US) Inc, Midlothian, TX	11 / 16 / 23	Klin 2 System Stack	Method 26A	Klin 2 - ON OFF -M2-26
OPERATOR	AMBIENT PRESS (In. Hg)	AMBIENT TEMP (deg. F)	STACK FILTER NUMBERS	STACK ID (In.)
M. Powell	28.75	-0.25	AA	161.5" (K1) 164.063" (K2)
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (M)	STACK THERM NO.	STACK PITOT NO.
~17-20%	M5-22	1.01	5A	5A
TRaverse ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING (Vt. GL. L.)	delta P (in. H2O)	delta H ORIFICE (in. H2O)
A-1	0 1619	84.844	.53	1.4
2	5	88.13	.54	1.4
3	10	91.38	.55	1.4
15	1634	94.371	End of Port	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg	
B-1	15 1636	94.371	.49	1.3
2	20	97.57	.50	1.3
3	25	100.67	.51	1.3
30	1651	103.816	End of Port	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg	
C-1	30 1653	103.816	.53	1.4
2	35	107.26	.54	1.4
3	40	110.24	.54	1.4
45	1708	113.291	End of Port	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg	
D-1	45 1710	113.291	.49	1.3
2	50	116.16	.48	1.3
3	55	114.65	.46	1.2
60	1725	122.165	End of Port	End of Port
TOTAL TIME	DGM VOLUME	delta P	delta H	Ave Temp
60 Min.				

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/16/23
 Sample Location Kiln 2 Mill ON OFF Recovery Date 11/16/23
 Run No. Kiln 2 Run Mill ON OFF-26A-213 Recovered by SCS
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		907.9	783.3	675.5	750.0	755.3	961.0	g
Initial weight		747.9	757.1	672.0	748.1	755.0	957.9	g
Net weight		160	26.2	7.5	1.9	0.3	9.1	g

Description of impinger water clean 20 % spent
Blv Sil gel color
 Total moisture = 206.0 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 2 Mill ON OFF-26A-H2SO4-213

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 2 Mill ON OFF-26A-NaOH-213

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE RUN NUMBER
Holcim (US) Inc, Midlothian, TX	11/16/23	Kiln 2 System Stack	Method 26A
OPERATOR	AMBIENT PRESS (In. Hg)	AMBIENT TEMP (deg. F)	NOZZLE
Grady Wray	29.75	6.3	250-250
ASSUMED MOISTURE (%)	DGM H ₂ O	DGM CAL FACTOR (M)	CO ₂ FACTOR
~17 - 20%	1.68	0.97	255
TRAVEL ELAPSED (MIN)	CLOCK TIME (24-HR)	DGM READING (V/F (CU. FT.))	LEAK CHECK (INITIAL)
0	17:41	665.199	140
5		668.75	140
10		671.62	138
15	17:56	674.799	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg
B-1	17:58 674.799	0.48 1.2 257	68 257 56 3
2	678.98	0.49 1.2 257	68 255 56 3
3	681.59	0.52 1.3 253	69 255 58 4
30	683.576	End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg
C-1	18:15 683.596	0.51 1.3 258	70 253 59 4
2	686.17	0.54 1.4 262	70 255 62 4
3		0.53 1.4 259	71 256 63 4
45	693.340	End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg
D-1	18:32 693.340	0.47 1.3 255	69 256 60 3
2	697.42	0.47 1.2 253	70 249 58 3
3	702.54	0.46 1.2 255	71 255 55 4
60	705.513	End of Port	
TOTAL TIME	DGM VOLUME	AVERAGE SORT delta P	AVERAGE TEMP
60 Min.	705.513		

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/16/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/16/23
 Run No. Kiln 2 Run 3 Mill ON OFF-26A-3A Recovered by SLG
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		909.9	771.4	648.1	745.8	742.6	993.7	g
Initial weight		747.2	737.4	642.6	743.9	742.0	978.1	g
Net weight		162.7	34.0	5.5	1.9	0.6	15.6	g

Description of impinger water clear 25 % spent
Blw Sil gel color
 Total moisture = 220.3 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 3 Mill ON OFF-26A-H2SO4-3A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 3 Mill ON OFF-26A-NaOH-3A

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE NAME	RUN NUMBER
Holcim (US) Inc; Midlothian, TX	11/16/23	Kiln 2 System Stack	Method 26A	Kiln 2 - ON OFF -M26-33
OPERATOR	AMBIENT PRESS (In. Hg)	STATIC PRESSURE (In. Water)	AMBIENT TEMP (deg. F)	STACK FILTER NUMBERS
M. Powell	28.75	-0.25	6.5	161.5" (K1) 164.063" (K2)
ASSUMED MOISTURE (%)	DGM H ₂ O	DGM CAL FACTOR (Y)	STACK THERM NO.	STACK PITOT NO.
~17-20%	1.72	1.014	854	57
TRaverse ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	VELOCITY HEAD (in. H ₂ O)	delta H ORIFICE (in. H ₂ O)
0	1741	122.214	.51	1.3
5		124.92	.56	1.5
10		128.42	.56	1.5
15	1756	131.704	End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg	
B-1	15 1758	131.704	.48	1.3
2		135.02	.49	1.3
3		138.56	.52	1.4
30	1813	141.568	End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg	
C-1	30 1815	141.568	.51	1.3
2		144.78	.54	1.4
3		148.99	.53	1.4
45	1830	151.016	End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg	
D-1	45 1832	151.016	.47	1.2
2		154.21	.47	1.2
3		157.05	.46	1.2
60	1847	160.054	End of Port	
TOTAL TIME	DGM VOLUME	Ave SQRT delta H	Ave. Temp	
60 Min.				

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/16/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/16/23
 Run No. Kiln² Run³ Mill ON OFF-26A-3B Recovered by SGS
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		896.0	766.5	619.1	741.6	741.9	1000.2	g
Initial weight		745.6	737.5	615.6	738.3	741.0	984.7	g
Net weight		150.4	31.0	3.5	3.3	0.9	15.5	g

Description of impinger water clear 30 % spent
B/W Sil gel color
 Total moisture = 209.6 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln² Run³ Mill ON OFF-26A-H2SO4-3B

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln² Run³ Mill ON OFF-26A-NaOH 3B

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE RUN NUMBER
Holcim (US) Inc, Midlothian, TX	11 / 17 / 23	Kiln 2 System Stack	Method 26A
OPERATOR	AMBIENT PRESS (In. Hg)	AMBIENT TEMP (deg F)	NOZZLE NUMBER, DIAMETER
Operator	28.70	25-35	250.150
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR	K FACTOR
17	1.68	0.975	2.55
TRaverse ELAPSED TIME (MIN)	CLOCK TIME (24-HR)	DGM READING (in. H ₂ O)	STACK VELOCITY (in. H ₂ O)
A-1 0	8:06	715.936	7.9
2 5		709.93	8.4
3 10		714.18	8.3
15	8:21	718.417	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL	FINAL	LEAK RATE: CU.FT @ INCHES Hg
B-1 15	8:23	718.417	0.85
2 20		722.61	0.86
3 25		726.79	0.87
30	8:38	730.944	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL	FINAL	LEAK RATE: CU.FT @ INCHES Hg
C-1 30	8:40	730.944	0.88
2 35		735.16	0.91
3 40		739.21	0.90
45	8:55	743.235	End of Port
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL	FINAL	LEAK RATE: CU.FT @ INCHES Hg
D-1 45	8:57	743.235	0.92
2 50		747.44	0.89
3 55		751.67	0.90
60	9:12	756.120	End of Port
TOTAL TIME	DGM VOLUME	AVERAGE SQRT delta P	AVERAGE TEMP
60 Min.	956.120	2.3	57

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/17/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln² Run⁴ Mill ON OFF-26A-4A Recovered by AGM
 Filter Number(s) _____

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		899.7	786.4	624.0	748.1	749.6	948.4	g
Initial weight		740.3	746.1	616.6	744.8	748.7	930.1	g
Net weight		159.4	40.3	7.4	3.3	0.9	18.3	g

Description of impinger water Clear 60° 10 % spent
B/W Sil gel color
 Total moisture = 229.6 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln² Run⁴ Mill ON OFF-26A-H2SO4-4A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln² Run⁴ Mill ON OFF-26A-NaOH 4A

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE TYPE	RUN NUMBER																																																																		
Holcim (US) Inc, Midlothian, TX	11/17/23	Klin 2 System Stack	Method 26A	Klin 2 - ON OFF -MS6-413																																																																		
OPERATOR	AMBIENT PRESS (In. Hg)	STATIC PRESSURE (In. Water)	AMBIENT TEMP (deg. F)	STACK FILTER NUMBERS																																																																		
M. Powell	29.70	-.55	65	11A																																																																		
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (M)	STACK THERM NO.	STACK PITOT NO.																																																																		
~17-20%	MS-32	1.014	5A	5A																																																																		
TRaverse ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (0.1 Ft.)	delta P (In. H2O)	delta H ORIFICE (In. H2O)																																																																		
A-1 0	806	160.151	.79	2.6																																																																		
2 5		164.18	.84	2.1																																																																		
3 10		167.75	.83	2.1																																																																		
15		171.89																																																																				
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg																																																																			
B-1 15	823	171.889	.85	2.1																																																																		
2 20		175.41	.86	2.1																																																																		
3 25		179.24	.87	2.1																																																																		
30		183.068																																																																				
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg																																																																			
C-1 30	840	183.068	.88	2.2																																																																		
2 35		186.84	.91	2.2																																																																		
3 40		190.92	.90	2.2																																																																		
45		194.485																																																																				
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg																																																																			
D-1 45	857	194.485	.92	2.3																																																																		
2 50		198.57	.89	2.2																																																																		
3 55		202.33	.90	2.2																																																																		
60		206.22																																																																				
TOTAL TIME 60 Min.																																																																						
TRaverse PORT/POINT NO.	ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (0.1 Ft.)	delta P (In. H2O)	delta H ORIFICE (In. H2O)	PROBE TEMP (deg. F)	STACK TEMP (deg. F)	STACK TEMP (deg. F)	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg	INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg	TRaverse PORT/POINT NO.	ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (0.1 Ft.)	delta P (In. H2O)	delta H ORIFICE (In. H2O)	PROBE TEMP (deg. F)	STACK TEMP (deg. F)	STACK TEMP (deg. F)	LEAK RATE: CU.FT @ CU.FT @	INCHES Hg INCHES Hg																																													
A-1	0	806	160.151	.79	2.6	254	139	139	254	140	141	254	140	141	5	0	823	171.889	.85	2.1	254	142	141	254	141	5	15	840	183.068	.88	2.2	252	140	141	252	141	5	30	857	194.485	.92	2.3	257	143	141	254	141	5	45	874	206.22	.92	2.3	254	141	141	254	141	5	60	891	206.22	.92	2.3	254	141	141	254	141	5

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/17/23
 Sample Location Kiln 2 Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln 2 Run 4 Mill ON OFF-26A-4B Recovered by LOH
 Filter Number(s) NA

MOISTURE 745.7

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		882.2	785.4	676.3	751.6	741.9 ^g	976.5	g
Initial weight		731.0	746.3	688.9	748.9	744.7	960.9	g
Net weight		149.2	39.1	7.4	2.7	1.0	19.6	g

Description of impinger water clean 50% % spent
B/W Sil gel color
 Total moisture = 211.0 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 4 Mill ON OFF-26A-H2SO4-4B

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 4 Mill ON OFF-26A-NaOH 4B

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TIME	
Holcim (US) Inc, Midlothian, TX		11 / 17 / 23		Kiln 2 - System Stack		Method 26A	
OPERATOR		AMBIENT PRESS (In. Hg)		AMBIENT TEMP (deg. F)		STACK ID (In.)	
Gokh. Maged		28.70		65		161.5" (K1) 164.063" (K2)	
ASSUMED MOISTURE (%)		DGM CAL FACTOR		DGM CAL FACTOR		DGM CAL FACTOR	
~17 - 20%		1.64		0.975		0.975	
TRAVEL ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING (cu. ft.)		DGM READING (cu. ft.)	
33		9:30		758.867		758.867	
A-1 0		9:30		762.95		762.95	
2 5		9:30		767.12		767.12	
3 10		9:45		771.549		771.549	
15		9:45		771.549		771.549	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES HG INCHES HG	
B-1 15		9:47		771.549		771.549	
2 20		9:47		775.98		775.98	
3 25		9:47		780.37		780.37	
30		10:02		784.756		784.756	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES HG INCHES HG	
C-1 30		10:04		784.756		784.756	
2 35		10:04		789.08		789.08	
3 40		10:04		793.51		793.51	
45		10:19		797.938		797.938	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES HG INCHES HG	
D-1 45		10:21		797.938		797.938	
2 50		10:21		802.52		802.52	
3 55		10:21		806.84		806.84	
60		10:36		810.568		810.568	
TOTAL TIME		DGM VOLUME		DGM VOLUME		DGM VOLUME	
60 Min.		810.568		810.568		810.568	
TRAVEL ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING (cu. ft.)		DGM READING (cu. ft.)	
A-1 0		9:30		758.867		758.867	
2 5		9:30		762.95		762.95	
3 10		9:30		767.12		767.12	
15		9:45		771.549		771.549	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES HG INCHES HG	
B-1 15		9:47		771.549		771.549	
2 20		9:47		775.98		775.98	
3 25		9:47		780.37		780.37	
30		10:02		784.756		784.756	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES HG INCHES HG	
C-1 30		10:04		784.756		784.756	
2 35		10:04		789.08		789.08	
3 40		10:04		793.51		793.51	
45		10:19		797.938		797.938	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES HG INCHES HG	
D-1 45		10:21		797.938		797.938	
2 50		10:21		802.52		802.52	
3 55		10:21		806.84		806.84	
60		10:36		810.568		810.568	
TOTAL TIME		DGM VOLUME		DGM VOLUME		DGM VOLUME	
60 Min.		810.568		810.568		810.568	

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/17/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln 2 Run 5 Mill (ON) OFF-26A-5A Recovered by LGN
 Filter Number(s) _____

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		923.9	800.7	649.2	751.6	746.7	1010.2	g
Initial weight		748.1	751.8	641.7	749.3	745.8	993.5	g
Net weight		175.8	48.9	7.5	5.3	0.9	16.7	g

Description of impinger water clean 80 % spent
B/W Sil gel color
 Total moisture = 255.1 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 5 Mill (ON) OFF-26A-H2SO4-5A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 5 Mill (ON) OFF-26A-NaOH-5A

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim (US) Inc; Midlothian, TX		11 / 17 / 23		Kiln 2 System Stack		Method 26A		Kiln 2 - ON OFF -M5-2-413	
OPERATOR		AMBIENT PRESS (In. Hg)		FILTER NUMBER		STACK ID (In.)		NOZZLE NUMBER	
M. Powell		-055		NA		161.5" (K1) 164.063" (K2)		.250 .250 .250	
ASSUMED MOISTURE (%)		DGM H@		STACK PITOT NO.		LEAK CHECK (INITIAL)		K FACTOR	
~17 - 20%		1.72		NA		0.02 CU. FT @ 10 "Hg		2.47	
TRaverse ELAPSED TEST TIME (MIN)		DGM CAL FACTOR (%)		DGM VELOCITY (In. H2O)		PROBE TEMP (deg. F)		STACK OVEN TEMP (deg. F)	
A-1 0		1.014		.88		250		255	
2 5				.87		251		256	
3 10				.89		253		263	
15		218.165		End of Port		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		CLOCK TIME (24-HR)		LEAK RATE:		INCHES Hg		INCHES Hg	
DGM VOLUME (CU. FT)		945		INITIAL / FINAL		141 / 141		141 / 141	
B-1 15		218.165		.90		254		261	
2 20		222.14		.88		252		259	
3 25		226.23		.91		253		255	
30		229.96		End of Port		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		CLOCK TIME (24-HR)		LEAK RATE:		INCHES Hg		INCHES Hg	
DGM VOLUME (CU. FT)		1002		INITIAL / FINAL		141 / 141		141 / 141	
C-1 30		229.96		.92		256		258	
2 35		233.88		.91		254		256	
3 40		237.71		.89		257		258	
45		241.682		End of Port		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		CLOCK TIME (24-HR)		LEAK RATE:		INCHES Hg		INCHES Hg	
DGM VOLUME (CU. FT)		1019		INITIAL / FINAL		140 / 140		140 / 140	
D-1 45		241.682		.93		259		257	
2 50		245.73		.92		257		255	
3 55		249.72		.90		254		258	
60		253.666		End of Port		End of Port		End of Port	
TOTAL TIME		DGM VOLUME		AVE delta P		AVE delta H		AVE TEMP	
60 Min.		253.666		2.3		139		58	
				2.3		140		56	
				2.2		143		56	

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 4/17/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln 2 Run 5 Mill ON OFF-26A-5B Recovered by LGH
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		917.4	803.6	614.2	744.9	741.7	1014.9	g
Initial weight		759.4	755.7	613.4	739.0	741.2	999.8	g
Net weight		158.0	47.9	5.8	5.9	0.5	15.1	g

Description of impinger water clear 40 % spent
B/W Sil gel color
 Total moisture = 233.2 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 5 Mill ON OFF-26A-H2SO4-5B

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 5 Mill ON OFF-26A-NaOH-5B

Liquid level marked/sealed

METHOD 26A FIELD DATA SHEET

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim (US) Inc; Midlothian, TX		4/17/23		Kiln 2, System Stack		Method 26A		Kiln - ON OFF -MEL-6A-	
OPERATOR		AMBIENT PRESS (In. Hg)		AMBIENT TEMP (deg. F)		STACK PRESS (In. Hg)		STACK TEMP (deg. F)	
Gregg Massey		20.70		65		161.5" (K1)		184.063" (K2)	
ASSUMED MOISTURE (%)		DGM H@		DGM CAL FACTOR (M)		ORIGAT NO		ORIGAT NO	
~17 - 20%		4.75		1.66		5.8		5.8	
TRAVEL ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING (In. H ₂ O)		DELTA H ORIFICE (In. H ₂ O)		DELTA P VELOCITY HEAD (In. H ₂ O)	
2.5%		11:15		810.735		2.0		.79	
A-1 0		10:58		814.94		2.1		.83	
2 5				818.27		2.1		.84	
3 10				823.981		2.1		.84	
15		11:13		End of Port		End of Port		End of Port	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		INCHES Hg INCHES Hg	
B-1 15		11:15		822.981		2.2		.86	
2 20				826.94		2.2		.87	
3 25				830.49		2.2		.85	
30		11:30		836.071		2.2		.85	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		INCHES Hg INCHES Hg	
C-1 30		11:32		836.071		2.3		.89	
2 35				840.13		2.3		.90	
3 40				844.72		2.3		.91	
45		11:47		848.925		2.3		.91	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg		INCHES Hg INCHES Hg	
D-1 45		11:49		848.925		2.4		.93	
2 50				853.16		2.3		.91	
3 55				857.33		2.3		.90	
60		12:04		861.545		2.3		.90	
TOTAL TIME		DGM VOLUME		AVE SORT delta P		AVE delta H		AVE TEMP	
60 Min.		861.545		861.545		861.545		861.545	

DATE	TEMP
6/8	68
6/8	68
6/8	60

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/17/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln 2 Run 6 Mill ON OFF-26A- 6A Recovered by LGT
 Filter Number(s) WA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		916.8	791.1	624.3	748.9	748.1	959.8	g
Initial weight		748.0	748.6	617.5	745.7	746.5	948.2	g
Net weight		168.8	42.5	6.8	3.2	1.6	11.6	g

Description of impinger water clean 75 % spent
B/W Sil gel color
 Total moisture = 234.5 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicable Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 6 Mill ON OFF-26A-H2SO4- 6A

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 6 Mill ON OFF-26A-NaOH 6A

Liquid level marked/sealed

B

METHOD 26A FIELD DATA SHEET

PLANT AND CITY	DATE	SAMPLING LOCATION	SAMPLE NO.	RUN NUMBER					
Hoicim (US) Inc, Midlothian, TX	11 / 17 / 23	Kiln System Stack	Method 26A	Kiln 2 - ON OFF -M5-3					
OPERATOR	AMBIENT PRESS (In. Hg)	STATIC PRESSURE (In. Water)	AMBIENT TEMP (deg. F)	STACK FILTER NUMBERS					
M. Powell	29.70	-0.35	65	161.5" (K1) 164.063" (K2)					
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (%)	STACK THERM NO.	STACK PITOT NO.					
~17-20%	1.72	1.014	5A	5A					
TRaverse ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (cu. ft)	DELTA P (in. H2O)	DELTA H ORIFICE (in. H2O)					
A-1 0	1058	254.891	.79	2.0					
2 5		258.83	.83	2.1					
3 10		261.99	.84	2.1					
15 15	1113	266.067	End of Port						
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CUFT @ CUFT @	INCHES HG INCHES HG	INCHES HG INCHES HG					
B-1 15	1115	266.067	46	2.1	262	139	66	282	58
2 20		270.64	.87	2.1	259	138	67	262	57
3 25		274.56	.85	2.1	257	136	68	259	56
30 30	1130	278.522	End of Port						
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CUFT @ CUFT @	INCHES HG INCHES HG	INCHES HG INCHES HG					
C-1 30	1132	278.522	.89	2.2	255	138	66	252	56
2 35		282.34	.90	2.2	257	140	68	265	57
3 40		286.83	.92	2.3	255	142	69	285	60
45 45	1147	290.744	End of Port						
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)	INITIAL FINAL	LEAK RATE: CUFT @ CUFT @	INCHES HG INCHES HG	INCHES HG INCHES HG					
D-1 45	1149	290.744	.93	2.3	254	143	68	255	61
2 50		294.86	.91	2.2	251	143	69	255	62
3 55		298.72	.90	2.2	255	141	70	255	61
60 60	1204	302.737	End of Port						
TOTAL TIME	DGM VOLUME	AVE SORT delta P	AVE SORT delta H	AVE TEMP					
60 Min.									

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/17/23
 Sample Location Kiln 2 Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln 2 Run 6 Mill ON OFF-26A-6B Recovered by LCM
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		842.7	811.4	728.8	751.9	747.5	987.6	g
Initial weight		752.9	752.8	666.3	747.8	744.9	976.4	g
Net weight		89.8	58.6	62.3	4.0	2.6	11.2	g

Description of impinger water clear 70 % spent
B/W Sil gel color
 Total moisture = 228.5 grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run 6 Mill ON OFF-26A-H2SO4-6B

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run 6 Mill ON OFF-26A-NaOH-6B

Liquid level marked/sealed

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/17/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln 2 Run Mill ON OFF-26A-Field Blank Recovered by LCB
 Filter Number(s) NA

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		739.0	748.0	644.0	741.7	742.1	1010.4	g
Initial weight		739.0	748.1	644.2	741.8	742.2	1010.2	g
Net weight								g

Description of impinger water Clear 75 % spent
B/W Sil gel color
 Total moisture = _____ grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run Mill ON OFF-26A-H2SO4- F13

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run Mill ON OFF-26A-NaOH F13

Liquid level marked/sealed

METHOD 26A
RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim USA- Midlothian, TX Sample Date 11/16/23
 Sample Location Kiln Mill ON OFF Recovery Date 11/17/23
 Run No. Kiln 2 Run 4 Mill ON OFF-26A-4A FB Recovered by LGH
 Filter Number(s) Field Blank

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		741.7	741.3	615.7	746.4	743.8	930.3	g
Initial weight		745.8	741.4	615.8	746.5	743.8	930.4	g
Net weight								g

Description of impinger water clear 25 % spent
B/W Sil gel color
 Total moisture = _____ grams

RECOVERED SAMPLE

Filter container number(s) Noty Applicabile Sealed _____
 Description of particulate on filter _____

H₂SO₄ Impingers 1, 2, 3 and Knockout contents and water rinse
 container no. Kiln 2 Run Mill ON OFF-26A-H2SO4- FB

Liquid level marked/sealed

NaOH Impingers 5 and 6 contents and water rinse
 container no. Kiln 2 Run Mill ON OFF-26A-NaOH FB

Liquid level marked/sealed

Client: Holcim Midlothian
 Test Location: Line 2 Main Stack; Raw Mill Off
 Date: Nov 16, 2023 Start Time: 14:20:22
 Run number 1
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
2:21:20 PM	13.2	12.4
2:22:20 PM	13.3	12.4
2:23:20 PM	13.2	12.6
2:24:20 PM	13.2	12.5
2:25:20 PM	13.1	12.6
2:26:20 PM	13.1	12.7
2:27:20 PM	13.1	12.6
2:28:20 PM	13.2	12.5
2:29:20 PM	13.2	12.5
2:30:20 PM	13.1	12.6
2:31:20 PM	13.1	12.5
2:32:20 PM	13.2	12.4
2:33:20 PM	13.2	12.5
2:34:20 PM	13.1	12.5
2:35:20 PM	13.0	12.7
2:36:20 PM	13.0	12.7
2:37:20 PM	13.0	12.7
2:38:20 PM	13.0	12.7
2:39:20 PM	13.0	12.7
2:40:20 PM	13.0	12.8
2:41:20 PM	13.0	12.8
2:42:20 PM	13.0	12.8
2:43:20 PM	13.0	12.9
2:44:20 PM	13.0	12.7
2:45:20 PM	13.0	12.8
2:46:20 PM	12.9	13.0
2:47:20 PM	12.9	13.2
2:48:20 PM	12.9	12.9
2:49:20 PM	13.0	12.7
2:50:20 PM	13.0	12.8
2:51:20 PM	13.0	12.7
2:52:20 PM	13.0	12.7
2:53:20 PM	13.0	12.8
2:54:20 PM	13.1	12.6
2:55:20 PM	13.2	12.4
2:56:20 PM	13.2	12.4
2:57:20 PM	13.1	12.7
2:58:20 PM	13.1	12.7
2:59:20 PM	13.1	12.7
3:00:20 PM	14.2	11.0
3:01:20 PM	14.8	10.0
3:02:00 PM	Process Problem/Down	
3:29:32 PM	Run Resumed	
3:29:54 PM	14.6	10.3
3:30:54 PM	14.0	11.3
3:31:54 PM	14.9	10.0
3:32:54 PM	14.9	9.8
3:33:54 PM	14.7	10.2
3:34:54 PM	13.8	11.6
3:35:54 PM	13.8	11.5
3:36:54 PM	13.6	11.8
3:37:54 PM	13.6	11.8
3:38:54 PM	13.4	12.3
3:39:54 PM	13.2	12.6
3:40:54 PM	13.1	12.7
3:41:54 PM	13.1	12.7
3:42:54 PM	13.1	12.8
3:43:54 PM	13.1	12.8
3:44:54 PM	13.1	12.7
3:45:54 PM	13.1	12.8
3:46:54 PM	13.0	13.1
3:47:54 PM	12.8	13.4
3:48:54 PM	13.0	12.8
3:49:54 PM	13.0	12.8
3:50:54 PM	13.1	12.7
3:51:54 PM	13.0	12.7
3:52:54 PM	13.0	12.8
3:53:54 PM	13.0	12.8
3:54:54 PM	13.0	12.9
3:55:54 PM	12.9	12.9
3:56:54 PM	13.0	12.8
3:57:54 PM	13.2	12.6
3:58:54 PM	13.3	12.2
3:59:54 PM	13.2	11.9
Run Avgs	13.2	12.4
Cal Gas	12.0	10.2
Initial Zero	0.2	0.1
Final Zero	0.4	0.3
Initial cal.	12.2	10.0
Final Cal.	12.3	10.0
Corrected Average	13.0	12.7

Client: Holcim Midlothian
 Test Location: Line 2 Main Stack; Raw Mill Off
 Date: Nov 16, 2022 Start Time: 16:19:32
 Run number 2
 One Minute Averages

	Out O2 %dry	Out CO2 %dry
4:20:30 PM	13.1	12.8
4:21:30 PM	13.0	12.8
4:22:30 PM	13.1	12.8
4:23:30 PM	13.1	12.8
4:24:30 PM	13.2	12.6
4:25:30 PM	13.2	12.6
4:26:30 PM	13.1	12.7
4:27:30 PM	13.1	12.6
4:28:30 PM	13.0	12.8
4:29:30 PM	13.2	12.6
4:30:30 PM	13.2	12.6
4:31:30 PM	13.1	12.7
4:32:30 PM	13.1	12.7
4:33:30 PM	13.1	12.7
4:34:30 PM	13.1	12.7
4:35:30 PM	13.0	12.9
4:36:30 PM	13.0	12.9
4:37:30 PM	13.0	12.7
4:38:30 PM	13.1	12.7
4:39:30 PM	13.1	12.7
4:40:30 PM	13.1	12.7
4:41:30 PM	13.1	12.8
4:42:30 PM	13.1	12.7
4:43:30 PM	13.1	12.7
4:44:30 PM	13.1	12.7
4:45:30 PM	13.0	12.8
4:46:30 PM	13.0	12.9
4:47:30 PM	13.0	13.1
4:48:30 PM	13.0	12.9
4:49:30 PM	13.0	12.9
4:50:30 PM	13.0	12.8
4:51:30 PM	13.1	12.7
4:52:30 PM	13.2	12.7
4:53:30 PM	13.2	12.7
4:54:30 PM	13.1	12.7
4:55:30 PM	13.0	12.8
4:56:30 PM	13.0	12.9
4:57:30 PM	13.1	12.7
4:58:30 PM	13.1	12.8
4:59:30 PM	13.1	12.7
5:00:30 PM	13.1	12.8
5:01:30 PM	13.1	12.8
5:02:30 PM	13.1	12.8
5:03:30 PM	13.0	12.8
5:04:30 PM	13.1	12.7
5:05:30 PM	13.2	12.6
5:06:30 PM	13.1	12.8
5:07:30 PM	13.2	12.7
5:08:30 PM	13.1	12.7
5:09:30 PM	13.1	12.7
5:10:30 PM	13.0	12.9
5:11:30 PM	13.0	12.8
5:12:30 PM	13.2	12.6
5:13:30 PM	13.1	12.8
5:14:30 PM	13.1	12.7
5:15:30 PM	13.0	12.9
5:16:30 PM	13.0	12.9
5:17:30 PM	13.0	12.8
5:18:30 PM	13.1	12.7
5:19:30 PM	13.2	12.6
5:20:30 PM	13.2	12.6
5:21:30 PM	13.2	12.7
5:22:30 PM	13.1	12.7
5:23:30 PM	13.1	12.8
5:24:30 PM	13.2	12.6
5:25:30 PM	13.1	12.8
5:26:30 PM	13.0	13.0
5:27:30 PM	13.0	12.9
Run Avgs	13.1	12.7
Cal Gas	12.0	10.2
Initial Zero	0.4	0.3
Final Zero	0.5	0.3
Initial cal.	12.3	10.0
Final Cal.	12.2	9.8
Corrected Average	12.9	13.2

Client: Holcim Midlothian
 Test Location: Line 2 Main Stack; Raw Mill Off
 Date: Nov 16, 2023 Start Time: 17:41:20
 Run number 3
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
5:42:18 PM	12.8	11.7
5:43:18 PM	13.1	12.8
5:44:18 PM	13.2	12.6
5:45:18 PM	13.1	12.8
5:46:18 PM	13.0	12.9
5:47:18 PM	12.8	13.5
5:48:18 PM	13.0	12.8
5:49:18 PM	13.0	13.0
5:50:18 PM	13.2	12.6
5:51:18 PM	13.2	12.7
5:52:18 PM	13.1	12.8
5:53:18 PM	13.0	12.9
5:54:18 PM	13.1	12.7
5:55:18 PM	13.1	12.8
5:56:18 PM	13.1	12.7
5:57:18 PM	13.1	12.7
5:58:18 PM	13.2	12.7
5:59:18 PM	13.2	12.6
6:00:18 PM	13.2	12.7
6:01:18 PM	13.1	12.8
6:02:18 PM	13.2	12.7
6:03:18 PM	13.2	12.7
6:04:18 PM	13.2	12.7
6:05:18 PM	13.1	12.8
6:06:18 PM	13.1	12.8
6:07:18 PM	13.2	12.7
6:08:18 PM	13.0	12.9
6:09:18 PM	13.0	12.9
6:10:18 PM	13.1	12.7
6:11:18 PM	13.1	12.8
6:12:18 PM	13.1	12.8
6:13:18 PM	13.0	13.0
6:14:18 PM	13.1	12.8
6:15:18 PM	13.2	12.7
6:16:18 PM	13.0	12.8
6:17:18 PM	13.2	12.6
6:18:18 PM	13.3	12.6
6:19:18 PM	13.1	12.7
6:20:18 PM	13.1	12.8
6:21:18 PM	13.2	12.6
6:22:18 PM	13.1	12.8
6:23:18 PM	13.2	12.7
6:24:18 PM	13.2	12.8
6:25:18 PM	13.1	12.8
6:26:18 PM	13.2	12.7
6:27:18 PM	13.1	12.7
6:28:18 PM	13.3	12.4
6:29:18 PM	13.0	13.2
6:30:18 PM	13.1	12.8
6:31:18 PM	13.2	12.7
6:32:18 PM	13.1	12.8
6:33:18 PM	13.1	12.8
6:34:18 PM	13.2	12.8
6:35:18 PM	13.0	13.1
6:36:18 PM	13.2	12.7
6:37:18 PM	13.0	12.9
6:38:18 PM	13.1	12.9
6:39:18 PM	13.3	12.5
6:40:18 PM	13.3	12.6
6:41:18 PM	13.3	12.5
6:42:18 PM	13.3	12.6
6:43:18 PM	13.2	12.7
6:44:18 PM	13.0	13.0
6:45:18 PM	13.1	12.8
6:46:18 PM	13.0	12.9
6:47:18 PM	13.1	12.9
Run Avgs	13.1	12.8
Cal Gas	12.0	10.2
Initial Zero	0.5	0.3
Final Zero	0.5	0.3
Initial cal.	12.2	9.8
Final Cal.	12.3	9.9
Corrected Average	12.9	13.3

Client: Holcim Midlothian
 Test Location: Line 2 Main Stack; Raw Mill On
 Date: Nov 17, 2023 Start Time: 08:06:12
 Run number 1
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
8:07:10 AM	13.9	10.9
8:08:10 AM	14.0	10.8
8:09:10 AM	14.0	10.8
8:10:10 AM	14.1	10.7
8:11:10 AM	14.1	10.8
8:12:10 AM	14.1	10.7
8:13:10 AM	14.1	10.8
8:14:10 AM	14.0	10.9
8:15:10 AM	13.9	11.2
8:16:10 AM	13.9	11.0
8:17:10 AM	13.9	11.1
8:18:10 AM	14.0	11.0
8:19:10 AM	13.9	11.0
8:20:10 AM	14.0	10.9
8:21:10 AM	13.9	11.0
8:22:10 AM	14.0	10.9
8:23:10 AM	13.9	10.9
8:24:10 AM	14.0	11.0
8:25:10 AM	14.0	11.0
8:26:10 AM	14.0	10.9
8:27:10 AM	13.9	11.0
8:28:10 AM	14.0	10.9
8:29:10 AM	14.0	10.8
8:30:10 AM	14.1	10.8
8:31:10 AM	14.0	10.9
8:32:10 AM	14.0	10.8
8:33:10 AM	14.0	10.9
8:34:10 AM	13.9	11.0
8:35:10 AM	14.0	10.9
8:36:10 AM	13.9	11.0
8:37:10 AM	14.0	10.9
8:38:10 AM	13.9	11.0
8:39:10 AM	13.9	11.0
8:40:10 AM	14.0	10.9
8:41:10 AM	14.0	10.9
8:42:10 AM	14.0	11.0
8:43:10 AM	13.9	11.1
8:44:10 AM	14.0	11.0
8:45:10 AM	13.9	10.9
8:46:10 AM	14.0	10.9
8:47:10 AM	13.9	11.1
8:48:10 AM	13.9	11.2
8:49:10 AM	13.9	11.1
8:50:10 AM	13.8	11.0
8:51:10 AM	13.9	10.9
8:52:10 AM	13.9	11.0
8:53:10 AM	13.9	11.1
8:54:10 AM	13.9	11.0
8:55:10 AM	13.9	11.0
8:56:10 AM	13.9	11.1
8:57:10 AM	13.9	11.0
8:58:10 AM	13.9	11.0
8:59:10 AM	13.9	11.0
9:00:10 AM	13.9	11.1
9:01:10 AM	13.9	11.0
9:02:10 AM	13.9	11.0
9:03:10 AM	13.9	11.0
9:04:10 AM	13.9	11.2
9:05:10 AM	13.8	11.2
9:06:10 AM	13.9	11.1
9:07:10 AM	13.9	11.1
9:08:10 AM	13.9	10.9
9:09:10 AM	14.0	10.8
9:10:10 AM	13.9	11.0
9:11:10 AM	13.9	11.0
9:12:10 AM	13.9	11.0
9:13:10 AM	13.9	11.0
Run Avgs	13.9	11.0
Cal Gas	12.0	10.2
Initial Zero	0.2	0.2
Final Zero	0.2	0.2
Initial cal.	12.0	10.0
Final Cal.	12.0	9.9
Corrected Average	14.0	11.3

Client: Holcim Midlothian
 Test Location: Line 2 Main Stack: Raw Mill On
 Date: Nov 17, 2023 23 Start Time: 09:30:04
 Run number 2
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
9:31:02 AM	13.9	11.0
9:32:02 AM	14.0	10.9
9:33:02 AM	14.1	10.9
9:34:02 AM	14.0	11.0
9:35:02 AM	13.9	11.1
9:36:02 AM	13.9	11.1
9:37:02 AM	14.0	10.9
9:38:02 AM	14.0	10.9
9:39:02 AM	14.1	10.9
9:40:02 AM	14.0	11.0
9:41:02 AM	14.0	11.0
9:42:02 AM	13.9	11.1
9:43:02 AM	14.0	11.0
9:44:02 AM	14.0	11.0
9:45:02 AM	14.1	10.8
9:46:02 AM	14.1	10.9
9:47:02 AM	14.0	11.0
9:48:02 AM	14.0	11.1
9:49:02 AM	14.0	11.0
9:50:02 AM	14.1	10.9
9:51:02 AM	14.0	10.9
9:52:02 AM	14.0	11.0
9:53:02 AM	13.9	11.1
9:54:02 AM	13.9	11.1
9:55:02 AM	13.9	11.0
9:56:02 AM	14.0	10.9
9:57:02 AM	13.9	11.1
9:58:02 AM	14.0	11.0
9:59:02 AM	14.0	10.9
10:00:02 AM	14.0	10.9
10:01:02 AM	14.0	10.9
10:02:02 AM	14.0	11.1
10:03:02 AM	13.9	11.1
10:04:02 AM	14.0	11.0
10:05:02 AM	14.1	10.9
10:06:02 AM	13.9	11.1
10:07:02 AM	13.8	11.1
10:08:02 AM	13.9	11.1
10:09:02 AM	14.0	11.0
10:10:02 AM	13.8	11.3
10:11:02 AM	13.9	11.2
10:12:02 AM	14.0	11.1
10:13:02 AM	14.0	11.1
10:14:02 AM	13.9	11.1
10:15:02 AM	14.0	11.0
10:16:02 AM	14.0	11.1
10:17:02 AM	14.0	11.1
10:18:02 AM	14.0	11.1
10:19:02 AM	14.0	11.1
10:20:02 AM	14.1	11.0
10:21:02 AM	14.0	11.1
10:22:02 AM	13.9	11.2
10:23:02 AM	14.0	11.1
10:24:02 AM	14.0	11.0
10:25:02 AM	14.0	10.9
10:26:02 AM	14.0	11.1
10:27:02 AM	13.9	11.1
10:28:02 AM	13.9	11.1
10:29:02 AM	14.0	11.0
10:30:02 AM	14.0	11.0
10:31:02 AM	14.1	10.9
10:32:02 AM	14.1	10.9
10:33:02 AM	14.0	11.1
10:34:02 AM	14.0	11.0
10:35:02 AM	14.0	11.0
10:36:02 AM	14.0	11.0
10:37:02 AM	14.0	11.1
Run Avgs	14.0	11.0
Cal Gas	12.0	10.2
Initial Zero	0.2	0.2
Final Zero	0.5	0.2
Initial cal.	12.0	9.9
Final Cal.	12.2	9.8
Corrected Average	13.9	11.4

Client: Holcim Midlothian
 Test Location: Line 2 Main Stack; Raw Mill On
 Date: Nov 17, 2023
 Run number 3
 One Minute Averages

	Out O2 %,dry	Out CO2 %,dry
11:01:08 AM	14.0	11.0
11:02:08 AM	14.0	11.0
11:03:08 AM	14.1	11.0
11:04:08 AM	14.2	10.9
11:05:08 AM	14.1	11.0
11:06:08 AM	14.0	11.1
11:07:08 AM	14.0	11.0
11:08:08 AM	14.1	10.9
11:09:08 AM	14.0	11.0
11:10:08 AM	14.0	11.0
11:11:08 AM	14.0	11.1
11:12:08 AM	14.2	11.1
11:13:08 AM	14.0	11.0
11:14:08 AM	14.1	10.9
11:15:08 AM	14.1	11.0
11:16:08 AM	14.2	10.9
11:17:08 AM	14.1	11.0
11:18:08 AM	14.2	11.1
11:19:08 AM	14.0	11.0
11:20:08 AM	13.9	10.9
11:21:08 AM	14.1	11.0
11:22:08 AM	14.0	11.0
11:23:08 AM	14.1	11.0
11:24:08 AM	14.1	11.0
11:25:08 AM	14.2	10.9
11:26:08 AM	14.0	11.0
11:27:08 AM	13.9	10.9
11:28:08 AM	14.0	11.1
11:29:08 AM	14.0	11.3
11:30:08 AM	14.2	10.9
11:31:08 AM	14.1	11.0
11:32:08 AM	14.0	11.1
11:33:08 AM	14.0	11.0
11:34:08 AM	14.1	10.9
11:35:08 AM	14.0	11.0
11:36:08 AM	14.0	11.0
11:37:08 AM	14.0	11.1
11:38:08 AM	14.0	11.0
11:39:08 AM	14.1	10.9
11:40:08 AM	14.2	10.8
11:41:08 AM	14.0	11.0
11:42:08 AM	14.0	10.9
11:43:08 AM	14.1	10.9
11:44:08 AM	14.1	10.8
11:45:08 AM	14.2	10.9
11:46:08 AM	14.0	11.1
11:47:08 AM	13.9	11.3
11:48:08 AM	14.0	11.2
11:49:08 AM	14.0	11.0
11:50:08 AM	14.1	10.9
11:51:08 AM	14.1	10.9
11:52:08 AM	14.2	10.8
11:53:08 AM	14.1	10.9
11:54:08 AM	14.1	11.0
11:55:08 AM	14.0	11.1
11:56:08 AM	14.0	11.0
11:57:08 AM	14.1	10.9
11:58:08 AM	14.0	11.0
11:59:08 AM	14.0	11.0
12:00:08 PM	14.0	11.0
12:01:08 PM	14.1	11.0
12:02:08 PM	14.2	10.9
12:03:08 PM	14.2	11.0
12:04:08 PM	14.2	10.9
12:05:08 PM	14.1	11.0
12:06:08 PM	14.0	11.0
12:07:08 PM	14.1	10.8
Run Avgs	14.1	11.0
Cal Gas	12.0	10.2
Initial Zero	0.5	0.2
Final Zero	0.5	0.3
Initial cal.	12.2	9.8
Final Cal.	12.2	9.8
Corrected Average	13.9	11.5

**Holcim
Midlothian TX
Line 2 Main Stack; Mill Off
HCN Analyte Spikes**

Date		11/16/23	11/16/23	11/16/23	11/16/23
Time		13:46-14:07	15:57-16:14	17:32-17:48	18:48-19:09
		Main Pre 1	Main Post 1	Main Post 2	Main Post 3
		HCN	HCN	HCN	HCN
Cs	Spike Direct, ppm	196.66	196.66	196.66	196.66
	SF6 Tracer Direct, ppm	9.53	9.53	9.53	9.53
SF6	Diluted SF6 Tracer, ppm	0.884	0.796	0.898	0.879
	Diluted SF6 Tracer, ppm	0.863	0.857	0.881	0.867
	Average Diluted SF6 Tracer, ppm	0.874	0.827	0.890	0.873
DF	Dilution Ratio	10.91	11.53	10.71	10.91
	Total, ppm	35.309	34.810	37.940	36.968
	Total, ppm	34.141	36.264	37.760	37.158
Ct	Average Total, ppm	34.725	35.537	37.850	37.063
	Pre Spike Native , ppm	19.192	23.732	23.417	24.079
	Pre Spike Native , ppm	20.943	23.424	22.836	23.525
	Post Spike Native , ppm	19.334	23.644	23.948	23.285
	Post Spike Native , ppm	19.734	23.274	23.831	24.712
Cn	Average Native , ppm	19.801	23.519	23.508	23.900
	Spike Recovery	92.8%	82.4%	90.1%	85.2%
	CTS Direct				
	Ethylene Expected (ppm)	75.48			75.48
	Ethylene Measured (ppm)	73.78			73.72
	CTS Error	-2.3%			-2.3%

Holcim Midlothian TX
 Line 2 Main Stack; Raw Mill Off
 Pre Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__002109.LAB	11/16/23	13:45:22.116	16.589	-0.004
SPC__002110.LAB	11/16/23	13:46:25.702	19.192	-0.013
SPC__002111.LAB	11/16/23	13:47:29.605	20.943	-0.014
SPC__002112.LAB	11/16/23	13:48:33.504	22.692	0.114
SPC__002113.LAB	11/16/23	13:49:37.405	25.291	0.203
SPC__002114.LAB	11/16/23	13:50:41.691	34.526	0.901
SPC__002115.LAB	11/16/23	13:51:45.211	35.309	0.884
SPC__002116.LAB	11/16/23	13:52:49.380	34.141	0.863
SPC__002117.LAB	11/16/23	13:53:53.027	26.011	0.282
SPC__002118.LAB	11/16/23	13:54:56.898	26.134	0.636
SPC__002119.LAB	11/16/23	13:56:00.790	0.989	0.016
SPC__002120.LAB	11/16/23	13:57:04.827	0.452	0.009
SPC__002121.LAB	11/16/23	13:58:08.595	0.291	0.009
SPC__002122.LAB	11/16/23	13:59:12.543	0.259	0.008
SPC__002123.LAB	11/16/23	14:00:16.439	0.193	0.006
SPC__002124.LAB	11/16/23	14:01:20.299	0.214	0.006
SPC__002125.LAB	11/16/23	14:05:09.442	20.182	-0.012
SPC__002126.LAB	11/16/23	14:06:13.046	19.334	-0.012
SPC__002127.LAB	11/16/23	14:07:17.355	19.734	-0.012
SPC__002128.LAB	11/16/23	14:08:20.796	19.941	-0.014

Holcim Midlothian TX
 Line 2 Main Stack; Raw Mill Off
 Post Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__002227.LAB	11/16/23	15:55:36.328	24.398	-0.013
SPC__002228.LAB	11/16/23	15:56:40.526	23.732	-0.012
SPC__002229.LAB	11/16/23	15:57:44.137	23.424	-0.016
SPC__002230.LAB	11/16/23	15:58:48.289	24.290	-0.016
SPC__002231.LAB	11/16/23	15:59:52.251	23.058	0.003
SPC__002232.LAB	11/16/23	16:00:56.153	26.699	0.297
SPC__002233.LAB	11/16/23	16:01:59.726	34.349	0.801
SPC__002234.LAB	11/16/23	16:03:03.627	34.810	0.796
SPC__002235.LAB	11/16/23	16:04:07.853	36.264	0.857
SPC__002236.LAB	11/16/23	16:05:11.461	34.253	0.689
SPC__002237.LAB	11/16/23	16:06:15.385	24.250	0.606
SPC__002238.LAB	11/16/23	16:07:19.456	0.772	0.007
SPC__002239.LAB	11/16/23	16:08:23.127	0.368	0.006
SPC__002240.LAB	11/16/23	16:09:27.091	0.160	0.008
SPC__002241.LAB	11/16/23	16:10:30.919	18.622	-0.010
SPC__002242.LAB	11/16/23	16:11:35.160	26.667	-0.011
SPC__002243.LAB	11/16/23	16:12:38.841	23.644	-0.013
SPC__002244.LAB	11/16/23	16:13:42.640	23.274	-0.011

Holcim Midlothian TX
 Line 2 Main Stack; Raw Mill Off
 Post Run 2 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__002314.LAB	11/16/23	17:31:02.652	23.343	-0.016
SPC__002315.LAB	11/16/23	17:32:06.478	23.417	-0.015
SPC__002316.LAB	11/16/23	17:33:10.079	22.836	-0.006
SPC__002317.LAB	11/16/23	17:34:14.276	24.768	0.130
SPC__002318.LAB	11/16/23	17:35:18.175	34.445	0.653
SPC__002319.LAB	11/16/23	17:36:21.780	35.633	0.752
SPC__002320.LAB	11/16/23	17:37:25.732	37.940	0.898
SPC__002321.LAB	11/16/23	17:38:30.034	37.760	0.881
SPC__002322.LAB	11/16/23	17:39:33.449	36.585	1.180
SPC__002323.LAB	11/16/23	17:40:37.347	0.920	0.013
SPC__002324.LAB	11/16/23	17:41:41.335	0.404	0.001
SPC__002325.LAB	11/16/23	17:42:45.395	10.794	0.003
SPC__002326.LAB	11/16/23	17:43:49.063	27.846	-0.009
SPC__002327.LAB	11/16/23	17:45:36.902	23.893	-0.013
SPC__002328.LAB	11/16/23	17:46:40.808	23.948	-0.011
SPC__002329.LAB	11/16/23	17:47:44.702	23.831	-0.015

Holcim Midlothian TX
 Line 2 Main Stack; Raw Mill Off
 Post Run 3 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__002385.LAB	11/16/23	18:47:23.039	24.045	-0.013	9.141
SPC__002386.LAB	11/16/23	18:48:26.987	24.079	-0.011	8.936
SPC__002387.LAB	11/16/23	18:49:30.819	23.525	-0.001	8.313
SPC__002388.LAB	11/16/23	18:50:35.085	28.754	0.383	7.960
SPC__002389.LAB	11/16/23	18:51:38.655	36.968	0.879	7.574
SPC__002390.LAB	11/16/23	18:52:42.514	37.158	0.867	7.743
SPC__002391.LAB	11/16/23	18:53:46.386	34.553	1.119	4.674
SPC__002392.LAB	11/16/23	18:54:50.303	0.711	0.010	0.024
SPC__002393.LAB	11/16/23	18:55:54.294	0.228	0.001	0.248
SPC__002394.LAB	11/16/23	18:56:58.088	4.152	0.003	1.569
SPC__002395.LAB	11/16/23	18:58:01.993	28.849	-0.014	10.189
SPC__002396.LAB	11/16/23	18:59:05.913	23.285	-0.016	8.907
SPC__002397.LAB	11/16/23	19:00:09.850	24.712	-0.015	8.607
SPC__002398.LAB	11/16/23	19:01:13.674	16.489	-0.007	6.144
SPC__002399.LAB	11/16/23	19:02:17.571	0.245	0.002	0.050
SPC__002400.LAB	11/16/23	19:03:21.502	-0.033	0.002	0.098
SPC__002401.LAB	11/16/23	19:04:25.774	0.202	0.004	-0.000
SPC__002402.LAB	11/16/23	19:05:29.296	0.069	0.001	-0.003
SPC__002403.LAB	11/16/23	19:06:33.535	0.058	0.001	0.085
SPC__002404.LAB	11/16/23	19:07:37.052	-0.020	-0.011	69.197
SPC__002405.LAB	11/16/23	19:08:40.957	-0.080	-0.010	73.724

Holcim Midlothian TX
 Line 2 Main Stack; Raw Mill Off
 CTS and HCN Analyte Spike Direrct

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__002064.LAB	11/16/23	12:55:37.434	-0.209	-0.012	73.689
SPC__002065.LAB	11/16/23	12:56:41.313	-0.233	-0.010	73.844
SPC__002066.LAB	11/16/23	12:57:45.099	-0.174	-0.013	73.713
SPC__002067.LAB	11/16/23	12:58:48.996	-0.074	-0.011	73.538
SPC__002068.LAB	11/16/23	12:59:52.898	39.520	1.606	58.869
SPC__002069.LAB	11/16/23	13:00:56.893	194.229	9.453	-0.191
SPC__002070.LAB	11/16/23	13:02:01.062	196.494	9.511	-0.623
SPC__002071.LAB	11/16/23	13:03:04.968	196.644	9.521	-0.662
SPC__002072.LAB	11/16/23	13:04:08.525	196.685	9.533	-0.523
SPC__002073.LAB	11/16/23	13:05:12.422	170.579	7.987	1.992
SPC__002074.LAB	11/16/23	13:06:16.322	0.419	0.013	-0.013
SPC__002075.LAB	11/16/23	13:07:20.231	0.083	0.001	0.008

**Holcim
Midlothian TX
Line 2 Main Stack; Mill On
HCN Analyte Spikes**

Date		11/17/23	11/17/23	11/17/23	11/17/23
Time		07:50-08:11	09:13-09:27	10:42-10:57	12:06-12:31
		Main Pre 1	Main Post 1	Main Post 2	Main Post 3
		HCN	HCN	HCN	HCN
Cs	Spike Direct, ppm	197.32	197.32	197.32	197.32
	SF6 Tracer Direct, ppm	9.58	9.58	9.58	9.58
SF6	Diluted SF6 Tracer, ppm	0.810	0.886	0.776	0.790
	Diluted SF6 Tracer, ppm	0.810	0.893	0.768	0.795
	Average Diluted SF6 Tracer, ppm	0.810	0.890	0.772	0.793
DF	Dilution Ratio	11.83	10.77	12.41	12.09
	Total, ppm	33.484	34.274	33.058	33.206
	Total, ppm	33.647	34.760	33.139	32.990
Ct	Average Total, ppm	33.566	34.517	33.099	33.098
	Pre Spike Native , ppm	21.251	21.813	21.153	20.515
	Pre Spike Native , ppm	20.013	21.120	21.005	20.912
	Post Spike Native , ppm	21.790	20.765	21.588	20.145
	Post Spike Native , ppm	21.875	21.259	20.691	20.711
Cn	Average Native , ppm	21.232	21.239	21.109	20.571
	Spike Recovery	84.7%	83.3%	86.1%	87.2%
	CTS Direct				
	Ethylene Expected (ppm)	75.48			75.48
	Ethylene Measured (ppm)	73.59			73.84
	CTS Error	-2.5%			-2.2%

Holcim Midlothian TX
 Line 2 Main Stack; Raw Mill On
 Pre Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__002448.LAB	11/17/23	07:49:15.007	21.117	-0.013
SPC__002449.LAB	11/17/23	07:50:18.933	21.251	-0.010
SPC__002450.LAB	11/17/23	07:51:22.774	20.013	-0.011
SPC__002451.LAB	11/17/23	07:52:27.009	24.868	0.284
SPC__002452.LAB	11/17/23	07:53:30.610	29.891	0.575
SPC__002453.LAB	11/17/23	07:54:34.464	30.517	0.591
SPC__002454.LAB	11/17/23	07:55:38.368	33.550	0.800
SPC__002455.LAB	11/17/23	07:56:42.261	33.734	0.812
SPC__002456.LAB	11/17/23	07:57:46.441	33.484	0.810
SPC__002457.LAB	11/17/23	07:58:50.064	33.647	0.810
SPC__002458.LAB	11/17/23	07:59:54.283	28.004	0.417
SPC__002459.LAB	11/17/23	08:00:57.866	28.247	0.622
SPC__002460.LAB	11/17/23	08:02:01.766	0.923	0.010
SPC__002461.LAB	11/17/23	08:03:05.616	0.328	0.009
SPC__002462.LAB	11/17/23	08:04:09.563	4.213	0.004
SPC__002463.LAB	11/17/23	08:05:13.758	24.859	-0.014
SPC__002464.LAB	11/17/23	08:06:17.666	22.626	-0.013
SPC__002465.LAB	11/17/23	08:07:21.238	20.815	-0.010
SPC__002466.LAB	11/17/23	08:08:25.137	21.812	-0.011
SPC__002467.LAB	11/17/23	08:09:29.286	21.790	-0.012
SPC__002468.LAB	11/17/23	08:10:32.965	21.875	-0.010
SPC__002469.LAB	11/17/23	08:11:36.827	22.272	-0.014

Holcim Midlothian TX
Line 2 Main Stack; Raw Mill On
Post Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__002526.LAB	11/17/23	09:12:18.993	21.148	-0.013
SPC__002527.LAB	11/17/23	09:13:22.840	21.813	-0.014
SPC__002528.LAB	11/17/23	09:14:26.721	21.120	-0.002
SPC__002529.LAB	11/17/23	09:15:30.621	24.625	0.269
SPC__002530.LAB	11/17/23	09:16:34.511	32.079	0.725
SPC__002531.LAB	11/17/23	09:17:38.407	34.274	0.886
SPC__002532.LAB	11/17/23	09:18:42.359	34.760	0.893
SPC__002533.LAB	11/17/23	09:19:46.218	38.418	1.191
SPC__002534.LAB	11/17/23	09:20:50.111	16.687	-0.004
SPC__002535.LAB	11/17/23	09:21:54.076	0.512	0.004
SPC__002536.LAB	11/17/23	09:22:58.237	0.279	-0.001
SPC__002537.LAB	11/17/23	09:24:01.776	14.523	-0.008
SPC__002538.LAB	11/17/23	09:25:06.008	22.850	-0.013
SPC__002539.LAB	11/17/23	09:26:09.579	20.765	-0.013
SPC__002540.LAB	11/17/23	09:27:13.801	21.259	-0.011

Holcim Midlothian TX
Line 2 Main Stack; Raw Mill On
Post Run 2 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C
SPC__002609.LAB	11/17/23	10:41:22.742	21.229	-0.012
SPC__002610.LAB	11/17/23	10:42:26.638	21.153	-0.013
SPC__002611.LAB	11/17/23	10:43:30.867	21.005	-0.012
SPC__002612.LAB	11/17/23	10:44:34.488	20.682	-0.003
SPC__002613.LAB	11/17/23	10:45:38.317	24.057	0.261
SPC__002614.LAB	11/17/23	10:46:42.252	30.888	0.668
SPC__002615.LAB	11/17/23	10:47:46.484	31.482	0.706
SPC__002616.LAB	11/17/23	10:48:50.006	33.058	0.776
SPC__002617.LAB	11/17/23	10:49:53.899	33.139	0.768
SPC__002618.LAB	11/17/23	10:50:57.887	38.296	1.172
SPC__002619.LAB	11/17/23	10:52:01.781	1.116	0.010
SPC__002620.LAB	11/17/23	10:53:05.557	0.321	-0.002
SPC__002621.LAB	11/17/23	10:54:09.522	2.636	0.004
SPC__002622.LAB	11/17/23	10:55:13.474	23.010	-0.013
SPC__002623.LAB	11/17/23	10:56:17.352	21.588	-0.013
SPC__002624.LAB	11/17/23	10:57:21.199	20.691	-0.011

Holcim Midlothian TX
 Line 2 Main Stack; Raw Mill On
 Post Run 3 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__002687.LAB	11/17/23	12:05:26.060	21.076	-0.013	7.905
SPC__002688.LAB	11/17/23	12:06:29.959	20.515	-0.011	8.237
SPC__002689.LAB	11/17/23	12:07:34.154	20.912	-0.013	8.886
SPC__002690.LAB	11/17/23	12:08:37.743	20.522	0.003	7.681
SPC__002691.LAB	11/17/23	12:09:41.679	29.442	0.617	7.747
SPC__002692.LAB	11/17/23	12:10:45.968	33.206	0.790	7.613
SPC__002693.LAB	11/17/23	12:11:49.424	32.990	0.795	7.745
SPC__002694.LAB	11/17/23	12:12:53.401	33.780	1.100	5.091
SPC__002695.LAB	11/17/23	12:13:57.178	0.705	0.008	0.028
SPC__002696.LAB	11/17/23	12:15:01.169	0.118	0.006	0.376
SPC__002697.LAB	11/17/23	12:16:05.325	15.154	-0.009	5.246
SPC__002698.LAB	11/17/23	12:17:09.148	22.070	-0.009	8.252
SPC__002699.LAB	11/17/23	12:18:12.812	20.145	-0.011	8.153
SPC__002700.LAB	11/17/23	12:19:16.708	20.711	-0.013	8.570
SPC__002701.LAB	11/17/23	12:20:20.609	16.700	-0.006	6.700
SPC__002702.LAB	11/17/23	12:21:24.490	2.768	0.000	0.969
SPC__002703.LAB	11/17/23	12:22:28.383	3.121	0.000	1.041
SPC__002704.LAB	11/17/23	12:23:32.282	0.339	-0.000	0.102
SPC__002705.LAB	11/17/23	12:24:36.175	0.067	0.001	0.057
SPC__002706.LAB	11/17/23	12:25:40.029	0.074	-0.001	0.038
SPC__002707.LAB	11/17/23	12:26:43.945	0.270	-0.004	-0.288
SPC__002708.LAB	11/17/23	12:27:47.814	0.199	-0.019	29.452
SPC__002709.LAB	11/17/23	12:28:51.718	-0.234	-0.014	73.658
SPC__002710.LAB	11/17/23	12:29:55.615	-0.049	-0.014	73.833
SPC__002711.LAB	11/17/23	12:30:59.536	-0.137	-0.018	73.840
SPC__002712.LAB	11/17/23	12:32:03.432	-0.325	-0.015	72.072

Holcim Midlothian TX
 Line 2 Main Stack; Raw Mill On
 CTS and HCN Analyte Spike Direct

Spectrum	Date	Time	HCN (200) PCA 191C 191c	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__002406BKG.LAB	11/17/23	06:54:22.814	0.000	0.000	0.000
SPC__002407.LAB	11/17/23	06:55:33.240	-0.087	0.005	-0.050
SPC__002408BKG.LAB	11/17/23	06:58:48.184	0.000	0.000	0.000
SPC__002409.LAB	11/17/23	06:59:58.189	-0.005	-0.002	0.033
SPC__002410BKG.LAB	11/17/23	07:02:26.457	0.000	0.000	0.000
SPC__002411.LAB	11/17/23	07:03:37.037	-0.048	0.001	0.032
SPC__002412BKG.LAB	11/17/23	07:06:06.105	0.000	0.000	0.000
SPC__002413.LAB	11/17/23	07:07:16.611	0.203	-0.003	0.018
SPC__002414.LAB	11/17/23	07:08:20.376	-0.059	-0.022	48.395
SPC__002415.LAB	11/17/23	07:10:16.702	-0.071	-0.013	73.653
SPC__002416.LAB	11/17/23	07:11:21.000	0.005	-0.014	73.520
SPC__002417.LAB	11/17/23	07:12:24.842	112.705	5.072	30.795
SPC__002418.LAB	11/17/23	07:13:28.431	197.016	9.583	-0.664
SPC__002419.LAB	11/17/23	07:14:32.280	197.617	9.585	-0.730
SPC__002420.LAB	11/17/23	07:15:36.261	196.781	9.578	-0.651
SPC__002421.LAB	11/17/23	07:16:40.123	196.103	9.556	-0.663

Appendix C

Ion Chromatography Analytical Report Data

Deeco, Inc.
3404 Lake Woodard Drive
Raleigh, NC 27604

Project No: 23-3313
Holcim Midlothian, TX

Hydrogen Fluoride & Chlorine

EPA Method 26A Analysis

Analytical Report
41653



Element One, Inc.
6319-D Carolina Beach Rd., Wilmington, NC 28412
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com


The following data for Analytical Report 41653
has been reviewed for completeness, accuracy,
adherence to method protocol,
and compliance with quality assurance guidelines.

Review by:



Linda Ann Webb, M.S. Analytical Chemist
December 15, 2023

Report Reviewed and Finalized By:



Ken Smith, Laboratory Director
December 15, 2023

SUMMARY OF RESULTS

Summary of Analysis

Summary of Method 26A Analysis

Element	Line1- M26A-R1A e41653-1 Total mg	Line1- M26A-R2A e41653-2 Total mg	Line1- M26A-R3A e41653-3 Total mg
HF	< 0.126	< 0.155	< 0.139
Cl ₂	< 0.176	0.582	< 0.300

Element	Line1- M26A-R4A e41653-4 Total mg	Line1- M26A-R5A e41653-5 Total mg	Line1- M26A-R6A e41653-6 Total mg
HF	< 0.113	< 0.147	< 0.150
Cl ₂	1.24	0.533	0.945

Element	Line1- M26A-R1B e41653-7 Total mg	Line1- M26A-R2B e41653-8 Total mg	Line1- M26A-R3B e41653-9 Total mg
HF	< 0.132	< 0.149	< 0.155
Cl ₂	< 0.203	< 0.348	< 0.350

Element	Line1- M26A-R4B e41653-10 Total mg	Line1- M26A-R5B e41653-11 Total mg	Line1- M26A-R6B e41653-12 Total mg
HF	< 0.161	< 0.142	< 0.121
Cl ₂	1.59	1.05	< 0.285

Element	Line1- M26A-FBON e41653-13 Total mg	Line1- M26A-FBOFF e41653-14 Total mg
HF	< 0.182	< 0.189
Cl ₂	< 0.153	< 0.153

Summary of Analysis

Summary of Method 26A Analysis

Element	Line2- M26A-R1A e41653-15 Total mg	Line2- M26A-R2A e41653-16 Total mg	Line2- M26A-R3A e41653-17 Total mg
HF	< 0.247	< 0.168	< 0.155
Cl ₂	1.08	1.56	1.53

Element	Line2- M26A-R4A e41653-18 Total mg	Line2- M26A-R5A e41653-19 Total mg	Line2- M26A-R6A e41653-20 Total mg
HF	< 0.161	< 0.147	< 0.147
Cl ₂	0.684	0.911	0.748

Element	Line2- M26A-R1B e41653-21 Total mg	Line2- M26A-R2B e41653-22 Total mg	Line2- M26A-R3B e41653-23 Total mg
HF	< 0.161	< 0.153	< 0.155
Cl ₂	1.35	1.16	1.52

Element	Line2- M26A-R4B e41653-24 Total mg	Line2- M26A-R5B e41653-25 Total mg	Line2- M26A-R6B e41653-26 Total mg
HF	< 0.178	< 0.147	< 0.165
Cl ₂	0.586	0.825	0.804

Element	Line2- M26A-FBOFF e41653-27 Total mg	Line2- M26A-FBON e41653-28 Total mg
HF	< 0.182	< 0.189
Cl ₂	< 0.178	< 0.173

ANALYTICAL NARRATIVE

elementOne

Certification: NJ NELAP NC009
41653 Deeco M26A Report Packet
Page 6 of 45

Element One Analytical Narrative

Client:	Deeco, Inc.	Element One #:	41653
Client ID:	23-3313 Holcim Midlothian, TX	Analyst:	LAW
Method:	M26A	Dates Received:	11.21.23
Analytes:	HF, Cl ₂	Dates Analyzed:	12.06-15.23

Summary of Analysis

The samples were prepared and analyzed according to Method 26A protocol. The samples were analyzed for fluoride and chloride on Metrohm 861/788 and 881/858 ion chromatograph systems.

Detection Limits

The Metrohm reporting limit was 0.1 µg/mL for fluoride and chloride.

Analysis QA/QC

Duplicate analyses relative percent difference (RPD) and spike recovery data are summarized in the Quality Control section. All QA/QC data was within the criteria of the method.

Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. Due to the sample matrix, it was necessary to analyze all samples at a minimum five-fold dilution to reduce interferences and to preserve the anion column. The reported results relate only to the items tested or calibrated.

QUALITY CONTROL SUMMARY

elementOne

Certification: NJ NELAP NC009
41653 Deeco M26A Report Packet
Page 8 of 45

Summary of Quality Control Data

Summary of Method 26A Duplicate Analysis RPD

(Method 26A QC limits: <5% for RPD)

Element	Line1- M26A-R1A RPD	Line1- M26A-R2A RPD	Line1- M26A-R3A RPD
HF	NA	NA	NA
Cl ₂	NA	0.6%	NA

Element	Line1- M26A-R4A RPD	Line1- M26A-R5A RPD	Line1- M26A-R6A RPD
HF	NA	NA	NA
Cl ₂	2.7%	1.2%	1.9%

Element	Line1- M26A-R1B RPD	Line1- M26A-R2B RPD	Line1- M26A-R3B RPD
HF	NA	NA	NA
Cl ₂	NA	NA	NA

Element	Line1- M26A-R4B RPD	Line1- M26A-R5B RPD	Line1- M26A-R6B RPD
HF	NA	NA	NA
Cl ₂	0.5%	0.0%	NA

Element	Line 1- M26A-FBON RPD	Line 1- M26A-FBOFF RPD
HF	NA	NA
Cl ₂	NA	NA

Summary of Quality Control Data

Summary of Method 26A Duplicate Analysis RPD

(Method 26A QC limits: <5% for RPD)

Element	Line2- M26A-R1A RPD	Line2- M26A-R2A RPD	Line2- M26A-R3A RPD
HF	NA	NA	NA
Cl ₂	1.7%	1.5%	3.4%

Element	Line2- M26A-R4A RPD	Line2- M26A-R5A RPD	Line2- M26A-R6A RPD
HF	NA	NA	NA
Cl ₂	0.0%	1.6%	1.5%

Element	Line2- M26A-R1B RPD	Line2- M26A-R2B RPD	Line2- M26A-R3B RPD
HF	NA	NA	NA
Cl ₂	1.2%	0.3%	1.3%

Element	Line2- M26A-R4B RPD	Line2- M26A-R5B RPD	Line2- M26A-R6B RPD
HF	NA	NA	NA
Cl ₂	1.2%	0.9%	0.4%

Element	Line2 -M26A-FBOFF RPD	Line2- M26A-FBON RPD
HF	NA	NA
Cl ₂	NA	NA

Summary of Quality Control Data

Summary of Method 26A Spike Recoveries

(Method 26A QC limits: 90-110% for Spike Recoveries)

Element	Line1- M26A-R3A Recovery	Line1- M26A-R3B Recovery
HF	108%	106%
Cl ₂	92%	101%
Element	Line2- M26A-R3A Recovery	Line2- M26A-R3B Recovery
HF	110%	109%
Cl ₂	103%	102%

Second Source Calibration Verification

*(*Laboratory QC limits: 90-110%)*

Element	DL 0.1mg/L Recovery	*QC 5.0mg/L Recovery
HF 41653 (1-14)	104%	104%
Cl ₂ 41653 (1-14)	101%	100%
HF 41653 (15-28)	105%	103%
Cl ₂ 41653 (15-28)	110%	106%

SAMPLE CUSTODY

DEECO, Inc
 3404 Lake Woodard Dr.
 Raleigh, NC 27604
 919-250-0285

Plant Name: Holcim
 Relinquished by: (Signature)
B. Newen
 Relinquished by: (Signature)

Plant Location: Midlothian TX
 Received by: (Signature)
Lisa Burt
 Received by: (Signature)

Project Name: 3313
 23-3309
 Comments: Per Marc
 JEB 11.17.23

Date: 11/22/23
 Lab: Element One
 Train: EPA Method 26

Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time
11/21/23	11/21/23	11/15/23	11/15/23	11/15/23	11/15/23	11/15/23	11/15/23	11/15/23	11/15/23	11/15/23	11/15/23
Analysis Required	Analysis Required	Analysis Required	Analysis Required	Analysis Required	Analysis Required	Analysis Required	Analysis Required	Analysis Required	Analysis Required	Analysis Required	Analysis Required
Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride	Fluoride ion as Hydrogen Fluoride
Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)	Chloride ion as Chlorine (Cl ₂)
Final Volume 486.6 mL	Final Volume 377.2 mL	Final Volume 498.7 mL	Final Volume 384.7 mL	Final Volume 590.6 mL	Final Volume 332.4 mL	Final Volume 560.2 mL	Final Volume 346.6 mL	Final Volume 486.6 mL	Final Volume 377.2 mL	Final Volume 498.7 mL	Final Volume 384.7 mL
Element One	Element One	Element One	Element One	Element One	Element One	Element One	Element One	Element One	Element One	Element One	Element One
NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!	NOT ADDED!

Samples received in good condition in Env. Exp. containers. No empty containers.

elementOne

DEECO, Inc
 3404 Lake Woodard Dr.
 Raleigh, NC 27604
 919-250-0285

41653

Plant Name: Holcim		Plant Location: Midlothian TX		Project Name: 3313			
Relinquished by: (Signature)		Date/Time	Received by: (Signature)	Date/Time	Comments		
<i>B. Weber</i> Relinquished by: (Signature)		11/15/23	<i>Loa D...</i>	11/17/23			
		Relinquished by: (Signature)		Date/Time	Comments		
		Relinquished by: (Signature)		Date/Time	Comments		
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
Line 1-3A-H ₂ SO ₄	11/15/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 533.0 mL	Element One
Line 1-3A-NaOH	11/15/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 298.2 mL Sodium thiosulfate NOT ADDED!	Element One
Line 1-3B-H ₂ SO ₄	11/15/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 570.1 mL	Element One
Line 1-3B-NaOH	11/15/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 347.7 mL Sodium thiosulfate NOT ADDED!	Element One
Line 1-4A-H ₂ SO ₄	11/15/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 555.3 mL	Element One
Line 1-4A-NaOH	11/15/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 421.8 mL Sodium thiosulfate NOT ADDED!	Element One
Line 1-4B-H ₂ SO ₄	11/15/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 637.9 mL	Element One
Line 1-4B-NaOH	11/15/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 363.3 mL Sodium thiosulfate NOT ADDED!	Element One

41653
 DEECO, Inc
 3404 Lake Woodard Dr.
 Raleigh, NC 27604
 919-250-0285

Plant Name: Holicim		Plant Location: Midlothian TX		Project Name: 3313			
Relinquished by: (Signature)		Date/Time	Received by: (Signature)	Date/Time	Comments		
Relinquished by: (Signature)		Date/Time	Received by: (Signature)	Date/Time	Comments		
Relinquished by: (Signature)		Date/Time	Received by: (Signature)	Date/Time	Comments		
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
Line1-5A-H ₂ SO ₄	11/15/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 552.2 mL	Element One
Line1-5A-NaOH	11/15/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 314.9 mL Sodium thiosulfate NOT ADDED!	Element One
Line1-5B-H ₂ SO ₄	11/15/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 542.8 mL	Element One
Line1-5B-NaOH	11/15/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 300.9 mL Sodium thiosulfate NOT ADDED!	Element One
Line1-6A-H ₂ SO ₄	11/15/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 519.5 mL	Element One
Line1-6A-NaOH	11/15/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 298.7 mL Sodium thiosulfate NOT ADDED!	Element One
Line1-6B-H ₂ SO ₄	11/15/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 570.1 mL	Element One
Line1-6B-NaOH	11/15/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 285.0 mL Sodium thiosulfate NOT ADDED!	Element One

elementOne

DEECO, Inc
 3404 Lake Woodard Dr.
 Raleigh, NC 27604
 919-250-0285

41653

Plant Name: Holcim		Plant Location: Midlothian TX		Project Name: 3313			
Relinquished by: (Signature)		Date/Time	Received by: (Signature)	Date/Time	Comments		
Relinquished by: (Signature)		Date/Time	Received by: (Signature)	Date/Time	Comments		
Relinquished by: (Signature)		Date/Time	Received by: (Signature)	Date/Time	Comments		
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
Line2-1A-H ₂ SO ₄	11/16/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 471.8 mL	Element One
Line2-1A-NaOH	11/16/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 363.5 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-1B-H ₂ SO ₄	11/16/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 458.3 mL	Element One
Line2-1B-NaOH	11/16/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 335.7 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-2A-H ₂ SO ₄	11/16/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 599.1 mL	Element One
Line2-2A-NaOH	11/16/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 323.0 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-2B-H ₂ SO ₄	11/16/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 607.5 mL	Element One
Line2-2B-NaOH	11/16/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 382.6 mL Sodium thiosulfate NOT ADDED!	Element One

DEECO, Inc

3404 Lake Woodard Dr.
Raleigh, NC 27604
919-250-0285

41563

Date:	11/06/23
Lab:	Element One
Train:	EPA Method 26A

Plant Name: Hoidim		Plant Location: Ste. Genevieve MO		Project Name: 23-3309			
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time	Comments	Comments		
<i>B. Newman</i>	11/4/23	<i>Loa B. B. B.</i>	11.6.23				
	Date/Time	Received by: (Signature)	Date/Time	Comments	Comments		
	Date/Time	Received by: (Signature)	Date/Time	Comments	Comments		
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
Cond1-FB-H ₂ SO ₄	11/01/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses		Element One
Cond1-FB-NaOH	11/01/23	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A	0.1N NaOH and DI Rinses	Sodium thiosulfate not added	Element One
Cond1-RB-H ₂ SO ₄	11/01/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄	Archive pending FB analysis	Element One
Cond1-RB-NaOH	11/01/23	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A	0.1N NaOH	Archive pending FB analysis	Element One
Cond1-RB-DI	11/01/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	DI Water	Archive pending FB analysis	Element One

DEECO, Inc
 3404 Lake Woodard Dr.
 Raleigh, NC 27604
 919-250-0285

41653

Plant Name: Holcim		Plant Location: Midlothian TX		Project Name: 3313			
Relinquished by: (Signature) <i>B. DeWitt</i>		Received by: (Signature) <i>Don Butler</i>		Comments: 220 11.21.23			
Relinquished by: (Signature)		Received by: (Signature)		Comments			
Relinquished by: (Signature)		Received by: (Signature)		Comments			
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
Line2-3A-H ₂ SO ₄	11/16/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 647.4 mL	Element One
Line2-3A-NaOH	11/16/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 339.8 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-3B-H ₂ SO ₄	11/16/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 551.1 mL	Element One
Line2-3B-NaOH	11/16/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 332.3 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-4A-H ₂ SO ₄	11/17/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 577.6 mL	Element One
Line2-4A-NaOH	11/17/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 358.9 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-4B-H ₂ SO ₄	11/17/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 569.0 mL	Element One
Line2-4B-NaOH	11/17/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 352.9 mL Sodium thiosulfate NOT ADDED!	Element One

41653

Date: 11/22/23
 Lab: Element One
 Train: EPA Method 26

DEECO, Inc
 3404 Lake Woodard Dr.
 Raleigh, NC 27604
 919-250-0285

Plant Name: Holcim		Plant Location: Midlothian TX		Project Name: 3313	
Relinquished by: (Signature)	Date	Received by: (Signature)	Analysis Required	Sampling Train	Sample Description
<i>B. Newell</i>	11/17/23	<i>Lon Smith</i>	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses
	11/17/23		Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses
	11/17/23		Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses
	11/17/23		Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses
	11/17/23		Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses
	11/17/23		Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses
	11/17/23		Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses
	11/17/23		Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses
	11/17/23		Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses
	11/17/23		Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses

Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
Line2-5A-H ₂ SO ₄	11/17/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 675.0 mL	Element One
Line2-5A-NaOH	11/17/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 366.0 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-5B-H ₂ SO ₄	11/17/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 673.8 mL	Element One
Line2-5B-NaOH	11/17/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 371.3 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-6A-H ₂ SO ₄	11/17/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 547.4 mL	Element One
Line2-6A-NaOH	11/17/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 359.3 mL Sodium thiosulfate NOT ADDED!	Element One
Line2-6B-H ₂ SO ₄	11/17/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 628.9 mL	Element One
Line2-6B-NaOH	11/17/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 344.8 mL Sodium thiosulfate NOT ADDED!	Element One

Relinquished by: (Signature) _____ Date _____
 Relinquished by: (Signature) _____ Date _____
 Relinquished by: (Signature) _____ Date _____

ANALYTICAL DATA

Analytical Calculations

HF -

$$\text{Total HX (mg)} = \frac{[\text{X Results } (\mu\text{g/mL}) * \text{Dilution} * \text{Beginning Vol (mL)}] * \text{Correction Factor}}{1000}$$

Where-

X Results= Raw sample concentration (ppm) — *IC Data Sheet*

Dilution= $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ — *IC Run Sheet*

Beginning Volume--*Sample Submission*

1.053= Correction factor for hydrogen fluoride

Cl₂ -

$$\text{Total X}_2 \text{ (mg)} = \frac{\text{X Results } (\mu\text{g/mL}) * \text{Dilution} * \text{Beginning Volume (mL)}}{1000}$$

Where-

X Results= Raw sample concentration (ppm)—*Cl₂ IC Data Sheet*

Dilution= $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ — *IC Run Sheet*

Beginning Volume--*Sample Submission*

Analytical Calculations

Spike Recovery-

$$\text{Spike (\%)} = \frac{(\text{Spiked Result } (\mu\text{g/mL}) - \text{Sample Result } (\mu\text{g/mL}))}{\text{Spike Amount } (\mu\text{g/mL})} \times 100$$

Where-

Spike Result = Raw sample concentration (ppm)--*IC-Data Sheet*

Sample Result = Raw sample concentration (ppm)--*IC-Data Sheet*

Spike Amount—*IC-Data Sheet*

Duplicate Analysis RPD-

$$\text{RPD (\%)} = \frac{(\text{Duplicate Result } (\mu\text{g/mL}) - \text{Sample Result } (\mu\text{g/mL}))}{\text{Average } (\mu\text{g/mL})} \times 100$$

Where-

Sample Result and Duplicate Results=Raw sample concentration (ppm)--*IC-Data Sheet*

$$\text{Average} = \frac{(\text{Duplicate} + \text{Sample Results})}{2}$$

Analysis Due Date 12.05.23
 QA/QC/Report Due Date 12.07.23

Client: Deeco, Inc.
Project No 23-3313

Date Rec 11.21.23
Time Rec 1100

Volume Marked	Volume Loss	FH pH < 2		BH pH > 8		Ref. Method: 26A
Y	N	Y	N	Y	N	

Sample Identification

1	Line1-M26A-R1A	7	Line1-M26A-R1B	13	Line1-M26A-FBON
2	Line1-M26A-R2A	8	Line1-M26A-R2B	14	Line1-M26A-FBOFF
3	Line1-M26A-R3A	9	Line1-M26A-R3B		
	Line1-M26A-R3A Spike		Line1-M26A-R3B Spike		
4	Line1-M26A-R4A	10	Line1-M26A-R4B		
5	Line1-M26A-R5A	11	Line1-M26A-R5B		
6	Line1-M26A-R6A	12	Line1-M26A-R6B		
Analyses Requested		Samples 1-14	HF		
		Samples 1-14	Cl ₂		

Runs/FB

Lab ID	FH Impinger 1 (or Combined Imp)		FH Impinger 2		FH Impinger 3		BH Impinger 4 (or Combined Imp)		BH Impinger 5	
	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
1	240						176			
2	245						335			
3.S	265						300			
4	215						425			
5	280						315			
6	285						300			
7	250						203			
8	283						348			
9.S	295						350			
10	305						365			
11	270						302			
12	230						285			
13	345						305			
14	360						305			

Lab Communications

See volumes on sample bottles. -run

Rec Runs/FB: H2SO4; NaOH; No RB received---11.27.23 LLB

SS Page 1 of 2
 11/28/2023 9:44:26 AM
 SS By LLB

Fit M26A Prep By / Date KH 12.5.23 Line 4 HF
 Labeled By / Date LLB 11.28.23
 ID Verification By/Date KH 11.28.23
 Bit M26A Prep By / Date LAW 12.07.23 1-14



Analysis Due Date 12.05.23
QA/QC/Report Due Date 12.07.23

Client: Deeco, Inc.
Project No 23-3313

Date Rec 11.21.23
Time Rec 1100

Volume Marked	Volume Loss	FH pH < 2	BH pH > 8	Ref. Method: 26A
Y N	Y N ?	Y N	Y N	

Sample Identification

15	Line2-M26A-R1A	21	Line2-M26A-R1B	27	Line2-M26A-FBOFF
16	Line2-M26A-R2A	22	Line2-M26A-R2B	28	Line2-M26A-FBON
17	Line2-M26A-R3A	23	Line2-M26A-R3B		
	Line2-M26A-R3A Spike		Line2-M26A-R3B Spike		
18	Line2-M26A-R4A	24	Line2-M26A-R4B		
19	Line2-M26A-R5A	25	Line2-M26A-R5B		
20	Line2-M26A-R6A	26	Line2-M26A-R6B		

Analyses Requested	Samples 15-28	HF
	Samples 15-28	Cl ₂

Runs/FB

Lab ID	FH Impinger 1 (or Combined Imp)		FH Impinger 2		FH Impinger 3		BH Impinger 4 (or Combined Imp)		BH Impinger 5	
	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
15	470						300			
16	320						325			
17.S	295						340			
18	305						360			
19	280						370			
20	280						362			
21	305						335			
22	290						385			
23.S	295						335			
24	338						355			
25	280						375			
26	313						350			
27	285						355			
28	292						345			

Reagent Blanks

Lab ID	Fractions	BV, ml	FV, ml	Notes
	0.1 N H ₂ SO ₄			
	0.1 N NaOH			
	DI H ₂ O			

SS Page 2 of 2
11/28/2023 9:44:26 AM
SS By 225

M26A Prep By / Date WJ 12/13/23
Labeled By / Date PPF 11.28.23
ID Verification By/Date WJ 11.28.23

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41653 (1-14)

Client: Deeco

Column: IonPac AS14A

Date: 12.08.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

F⁻ to HF factor: 1.053

Sample ID	F ⁻ µg/ml	Dilution	Final Vol, ml	HF, Total mg	Spike, µg/ml	% Recovery/ RPD	File Name	Date Time
LRB	0.000	1	10	< 0.001			_2023-12-06_	12/6/2023 19:19
LRB	0.000	1	10	< 0.001		NA	_2023-12-06_	12/6/2023 19:38
LRB SPK	5.140	1	10	0.054	5.00	103%	_2023-12-06_	12/6/2023 19:56
LRB SPK	5.094	1	10	0.054	5.00	102%	_2023-12-06_	12/6/2023 20:15
41653-1	0.022	5	240	< 0.126			_2023-12-06_	12/6/2023 20:34
41653-1 DUP	0.022	5	240	< 0.126		NA	_2023-12-06_	12/6/2023 20:52
41653-2	0.000	5	295	< 0.155			_2023-12-06_	12/6/2023 21:11
41653-2 DUP	0.024	5	295	< 0.155		NA	_2023-12-06_	12/6/2023 21:30
41653-3	0.026	5	265	< 0.139			_2023-12-06_	12/6/2023 23:41
41653-3 DUP	0.028	5	265	< 0.139		NA	_2023-12-07_	12/7/2023 0:00
41653-3 SPK	5.423	5	265	7.56	5.00	108%	_2023-12-07_	12/7/2023 0:19
41653-3 SPK DUP	5.368	5	265	7.49	5.00	107%	_2023-12-07_	12/7/2023 0:37
41653-4	0.025	5	215	< 0.113			_2023-12-06_	12/6/2023 21:49
41653-4 DUP	0.024	5	215	< 0.113		NA	_2023-12-06_	12/6/2023 22:07
41653-5	0.030	5	280	< 0.147			_2023-12-07_	12/7/2023 0:56
41653-5 DUP	0.024	5	280	< 0.147		NA	_2023-12-07_	12/7/2023 1:15
41653-6	0.024	5	285	< 0.15			_2023-12-07_	12/7/2023 1:34
41653-6 DUP	0.024	5	285	< 0.15		NA	_2023-12-07_	12/7/2023 1:52
41653-7	0.027	5	250	< 0.132			_2023-12-07_	12/7/2023 2:11
41653-7 DUP	0.027	5	250	< 0.132		NA	_2023-12-07_	12/7/2023 2:30
41658-8	0.000	5	283	< 0.149			_2023-12-07_	12/7/2023 10:07
41658-8 DUP	0.000	5	283	< 0.149		NA	_2023-12-07_	12/7/2023 10:26
41658-9	0.000	5	295	< 0.155			_2023-12-07_	12/7/2023 10:45
41658-9 DUP	0.000	5	295	< 0.155		NA	_2023-12-07_	12/7/2023 11:04
41658-9 SPK	5.265	5	295	8.17	5.00	105%	_2023-12-07_	12/7/2023 11:22
41658-9 SPK DUP	5.370	5	295	8.34	5.00	107%	_2023-12-07_	12/7/2023 11:41
41658-10	0.000	5	305	< 0.161			_2023-12-07_	12/7/2023 12:00
41658-10 DUP	0.000	5	305	< 0.161		NA	_2023-12-07_	12/7/2023 12:19
41658-11	0.067	5	270	< 0.142			_2023-12-07_	12/7/2023 12:37
41658-11 DUP	0.072	5	270	< 0.142		NA	_2023-12-07_	12/7/2023 12:56
41653-12	0.000	5	230	< 0.121			_2023-12-07_	12/7/2023 14:30
41653-12 DUP	0.000	5	230	< 0.121		NA	_2023-12-07_	12/7/2023 14:49
41653-13 FB	0.000	5	345	< 0.182			_2023-12-07_	12/7/2023 15:07
41653-13 FB DUP	0.000	5	345	< 0.182		NA	_2023-12-07_	12/7/2023 15:26
41653-14	0.000	5	360	< 0.189			_2023-12-07_	12/7/2023 15:45
41653-14 DUP	0.000	5	360	< 0.189		NA	_2023-12-07_	12/7/2023 16:03

Lucy Ann White

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41653 (1-14)

Client: Deeco

Column: IonPac AS14A

Date: 12.08.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

F⁻ to HF factor: 1.053

Standards	F ⁻ µg/ml	Dilution	QC, µg/ml	% Relative Error	% Recovery	File Name	Date Time
0	0.000					_2023-12-06_	12/6/2023 15:34
0.1	0.104			4.0%	104%	_2023-12-06_	12/6/2023 15:53
1	0.949			-5.1%	95%	_2023-12-06_	12/6/2023 16:11
3	2.992			-0.3%	100%	_2023-12-06_	12/6/2023 16:30
5	5.102			2.0%	102%	_2023-12-06_	12/6/2023 16:49
10	9.953			-0.5%	100%	_2023-12-06_	12/6/2023 17:08
0.1	0.106			6.0%	106%	_2023-12-07_	12/7/2023 17:18
1	0.976			-2.4%	98%	_2023-12-07_	12/7/2023 17:37
3	2.995			-0.2%	100%	_2023-12-07_	12/7/2023 17:56
5	4.808			-3.8%	96%	_2023-12-07_	12/7/2023 18:15
10	10.701			7.0%	107%	_2023-12-07_	12/7/2023 18:33
Correlation-	0.9999						
QC	5.181		5.00		104%	_2023-12-06_	12/6/2023 17:26
QC	5.126		5.00		103%	_2023-12-06_	12/6/2023 17:45
QC	5.178		5.00		104%	_2023-12-06_	12/6/2023 22:26
QC	5.146		5.00		103%	_2023-12-06_	12/6/2023 22:45
QC	5.243		5.00		105%	_2023-12-07_	12/7/2023 2:48
QC	5.187		5.00		104%	_2023-12-07_	12/7/2023 3:07
QC	4.732		5.00		95%	_2023-12-07_	12/7/2023 9:30
QC	5.124		5.00		102%	_2023-12-07_	12/7/2023 13:15
QC	5.001		5.00		100%	_2023-12-07_	12/7/2023 13:34
QC	5.257		5.00		105%	_2023-12-07_	12/7/2023 16:22
QC	5.282		5.00		106%	_2023-12-07_	12/7/2023 18:52
DL	0.104		0.10		104%	_2023-12-06_	12/6/2023 18:41
DL	0.105		0.10		105%	_2023-12-06_	12/6/2023 19:00
DL	0.102		0.10		102%	_2023-12-07_	12/7/2023 16:41
DL	0.098		0.10		98%	_2023-12-07_	12/7/2023 19:11
35165-13 QC	7.872	1	7.63		109%	_2023-12-07_	12/7/2023 19:48
BLK	0.000					_2023-12-06_	12/6/2023 18:04
BLK	0.000					_2023-12-06_	12/6/2023 18:23
BLK	0.000					_2023-12-06_	12/6/2023 23:04
BLK	0.000					_2023-12-06_	12/6/2023 23:22
BLK	0.000					_2023-12-07_	12/7/2023 3:26
BLK	0.000					_2023-12-07_	12/7/2023 3:45
BLK	0.000					_2023-12-07_	12/7/2023 9:49
BLK	0.000					_2023-12-07_	12/7/2023 13:52
BLK	0.000					_2023-12-07_	12/7/2023 14:11
BLK	0.000					_2023-12-07_	12/7/2023 17:00
BLK	0.000					_2023-12-07_	12/7/2023 19:30

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41653 Line 1

Date: 12/8/23

Column: IonPac AS14A

Instrument: 861788

Analyst: KLG

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Lot# 1C11-70-4

Batch name: 120823-41653 HF

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Lot# 1C11-96-3

Regenerant: 100 mM H₃PO₄

Flow Rate: 1.0 mL/min.

Method: 30026A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0.0		RZ	AC lot #			
2	0.1	F	9999	BBC0574	Sigma		
3	1.0		12/8/23 9999	1208			
4	3.0						
5	5.0						
6	10.0						
7	AC						
8	AC						
9	BIK						
10	BIK						
11	DL						
12	DL						
13	URB						
14	URB						
15	URB+						
16	URB+						
17	41653-1	Deeco	HF			5x	
18	-1dup						
19	-2						
20	-2dup						
21	-4						
22	-4dup						
23	AC						
24	AC						
25	BIK						

Manual integrations noted by M

Curve IC Lot # ~~1C11-97-3~~ 12/11/23

Curve lot: 1C11-98-4 p. 1 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution HPS 2303029-250 IC NO2 Solution HPS 2308942-250

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.

QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: 12/08/23 Time: 4:00 By: [signature] QC Review- Date: [signature] Time: By:

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41653 Line 1

Date: 12/8/23

Analyst: KCT (4421653)

Batch name: 20823-41653 HF

Column: IonPac AS14A

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100 mM H₃PO₄

Flow Rate: 1.0 mL/min.

Instrument: 8611788

Lot# 1C11-70-4

Lot# 1C11-96-3

Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	BLK						
27	41653-3	Deeco	HF			5X	
28	-3dup						
29	-3spk				5.423		
30	-3spk dup				5.368		
31	-5						
32	-5dup						
33	-6						
34	-6dup						
35	-7						
36	-7dup						
37	QC						
38	QC						
39	BLK						
40	BLK						
41	41653-8	Deeco	HF			5X	
42	-8dup						
43	-9						
44	-9dup						
45	-9spk				5.265		
46	-9spk dup				5.370		
47	-10						
48	-10dup						
49	-11						
50	-11dup						

recheck all extracted at end of this 10 IC BLK in 124, 125

5.265 5.370

Manual integrations noted by M

Curve IC Lot #

Comments: p. 20F3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

IC NO2 Solution

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.

QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date:

Time:

By:

QC Review- Date:

Time:

By:

elementOne

Certification: NJ NELAP NC009

41653 Deeco M26A Report Packet

Page 28 of 45

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41653 Line 7

Date: 12/15/23

Analyst: KUN ^{KUN} 12/15/23

Batch name: 20823-41653

Column: IonPac AS14A

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100 mM H₃PO₄

Flow Rate: 1.0 mL/min.

Instrument: 801 1788

Lot# 1011-70-4

Lot # 1011-96-3

Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
S1	QC						
S2	QC						
S3	BLK						
S4	BLK						
S5	41653-13FB	Deeco	HF		—	5X	
S6	-13FB dup	↓	↓		—	↓	
S7	-14FB				—		
S8	-14FB dup	↓	↓		—	↓	
S9	QC						
60	DL						
61	BLK						
62	0.1						
63	1.0						
64	3.0						
65	5.0						
66	10.0						
67	QC						
68	DL						
69	BLK						
70	35165-13QC		HF		2872	1X	TV=7.63
71	41653-12	Deeco	↓		—	5X	
72	-12 dup	↓	↓		—	↓	

Manual integrations noted by M

Curve IC Lot # _____ Comments: p. 30F3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution _____ IC NO2 Solution _____

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.

QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC Date: _____ Time: _____ By: _____ QC Review Date: _____ Time: _____ By: _____

elementOne

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41653(15-28)

Client: Deeco

Column: IonPac AS14A

Date: 12.15.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

F to HF factor: 1.053

Sample ID	F µg/ml	Dilution	Final Vol, ml	HF, Total mg	Spike, µg/ml	% Recovery/ RPD	File Name	Date Time
LRB	0.000	1	10	< 0.001			-5f5369ab:18c639c13f0:-78e3	12/13/2023 16:40
LRB	0.000	1	10	< 0.001		NA	-5f5369ab:18c639c13f0:-78e1	12/13/2023 16:59
LRB SPK	5.170	1	10	0.054	5.00	103%	-5f5369ab:18c639c13f0:-78df	12/13/2023 17:17
LRB SPK	5.263	1	10	0.055	5.00	105%	-5f5369ab:18c639c13f0:-78dd	12/13/2023 17:36
41653-15	0.000	5	470	< 0.247			-5f5369ab:18c639c13f0:-78db	12/13/2023 17:54
41653-15 DUP	0.000	5	470	< 0.247		NA	-5f5369ab:18c639c13f0:-78d9	12/13/2023 18:13
41653-16	0.000	5	320	< 0.168			-5f5369ab:18c639c13f0:-78d7	12/13/2023 18:31
41653-16 DUP	0.000	5	320	< 0.168		NA	-5f5369ab:18c639c13f0:-78d5	12/13/2023 18:50
41653-17	0.000	5	295	< 0.155			-5f5369ab:18c639c13f0:-78c7	12/13/2023 20:59
41653-17 DUP	0.000	5	295	< 0.155		NA	-5f5369ab:18c639c13f0:-78c5	12/13/2023 21:17
41653-17 SPK	5.446	5	295	8.46	5.00	109%	-5f5369ab:18c639c13f0:-7846	12/13/2023 21:36
41653-17 SPK DUP	5.489	5	295	8.52	5.00	110%	-5f5369ab:18c639c13f0:-7844	12/13/2023 21:54
41653-18	0.000	5	305	< 0.161			-5f5369ab:18c639c13f0:-78d3	12/13/2023 19:08
41653-18 DUP	0.000	5	305	< 0.161		NA	-5f5369ab:18c639c13f0:-78d1	12/13/2023 19:26
41653-19	0.043	5	280	< 0.147			-5f5369ab:18c639c13f0:-78bf	12/13/2023 22:13
41653-19 DUP	0.041	5	280	< 0.147		NA	-5f5369ab:18c639c13f0:-78bd	12/13/2023 22:31
41653-20	0.038	5	280	< 0.147			-5f5369ab:18c639c13f0:-78bb	12/13/2023 22:50
41653-20 DUP	0.035	5	280	< 0.147		NA	-5f5369ab:18c639c13f0:-78b9	12/13/2023 23:08
41653-21	0.028	5	305	< 0.161			-5f5369ab:18c639c13f0:-78b7	12/13/2023 23:27
41653-21 DUP	0.028	5	305	< 0.161		NA	-5f5369ab:18c639c13f0:-78b5	12/13/2023 23:45
41653-22	0.031	5	290	< 0.153			-5f5369ab:18c639c13f0:-78ab	12/14/2023 1:18
41653-22 DUP	0.031	5	290	< 0.153		NA	-5f5369ab:18c639c13f0:-78a9	12/14/2023 1:36
41653-23	0.035	5	295	< 0.155			-5f5369ab:18c639c13f0:-78a7	12/14/2023 1:55
41653-23 DUP	0.030	5	295	< 0.155		NA	-5f5369ab:18c639c13f0:-78a5	12/14/2023 2:13
41653-23 SPK	5.478	5	295	8.51	5.00	109%	-5f5369ab:18c639c13f0:-7842	12/14/2023 2:32
41653-23 SPK DUP	5.490	5	295	8.52	5.00	109%	-5f5369ab:18c639c13f0:-7840	12/14/2023 2:50
41653-24	0.042	5	338	< 0.178			-5f5369ab:18c639c13f0:-789f	12/14/2023 3:09
41653-24 DUP	0.037	5	338	< 0.178		NA	-5f5369ab:18c639c13f0:-789d	12/14/2023 3:27
41653-25	0.044	5	280	< 0.147			-5f5369ab:18c639c13f0:-789b	12/14/2023 3:46
41653-25 DUP	0.043	5	280	< 0.147		NA	-5f5369ab:18c639c13f0:-7899	12/14/2023 4:04
41653-26	0.040	5	313	< 0.165			-5f5369ab:18c639c13f0:-76ce	12/14/2023 5:37
41653-26 DUP	0.038	5	313	< 0.165		NA	-5f5369ab:18c639c13f0:-76cc	12/14/2023 5:55
41653-27	0.000	5	285	< 0.15			-5f5369ab:18c639c13f0:-788b	12/14/2023 6:13
41653-27 DUP	0.000	5	285	< 0.15		NA	-5f5369ab:18c639c13f0:-7889	12/14/2023 6:32
41653-28	0.000	5	292	< 0.154			-5f5369ab:18c639c13f0:-7887	12/14/2023 6:50
41653-28 DUP	0.000	5	292	< 0.154		NA	-5f5369ab:18c639c13f0:-7885	12/14/2023 7:09

HF Data 1 of 2

elementOne
e 41653 (15-28)-HF

elementOne

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41653(15-28)

Client: Deeco

Date: 12.15.23

Analyst: LAW

Detection Limit, (µg/ml): 0.10

Column: IonPac AS14A

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Flow Rate: 1.0 mL/min.

F⁻ to HF factor: 1.053

Standards	F ⁻ µg/ml	Dilution	QC, µg/ml	% Relative Error	% Recovery	File Name	Date Time
0	0.000					-5f5369ab:18c639c13f0:-75df	12/13/2023 12:58
0.1	0.100			0.0%	100%	-5f5369ab:18c639c13f0:-75dd	12/13/2023 13:17
1	0.987			-1.3%	99%	-5f5369ab:18c639c13f0:-75db	12/13/2023 13:35
3	3.097			3.2%	103%	-5f5369ab:18c639c13f0:-75d9	12/13/2023 13:54
5	4.885			-2.3%	98%	-5f5369ab:18c639c13f0:-75d7	12/13/2023 14:12
10	10.031			0.3%	100%	-5f5369ab:18c639c13f0:-75d5	12/13/2023 14:31
0.1	0.108			8.0%	108%	-5f5369ab:18c639c13f0:-778f	12/14/2023 8:23
1	1.009			0.9%	101%	-5f5369ab:18c639c13f0:-778d	12/14/2023 8:41
3	3.150			5.0%	105%	-5f5369ab:18c639c13f0:-778b	12/14/2023 9:00
5	5.273			5.5%	105%	-5f5369ab:18c639c13f0:-7789	12/14/2023 9:18
10	10.489			4.9%	105%	-5f5369ab:18c639c13f0:-7787	12/14/2023 9:37
Correlation-	0.9999						
QC	5.129		5.00		103%	-5f5369ab:18c639c13f0:-78ef	12/13/2023 14:49
QC	5.063		5.00		101%	-5f5369ab:18c639c13f0:-78ed	12/13/2023 15:08
QC	5.255		5.00		105%	-5f5369ab:18c639c13f0:-78cf	12/13/2023 19:45
QC	5.181		5.00		104%	-5f5369ab:18c639c13f0:-78cd	12/13/2023 20:03
QC	5.145		5.00		103%	-5f5369ab:18c639c13f0:-78b3	12/14/2023 0:04
QC	5.166		5.00		103%	-5f5369ab:18c639c13f0:-78b1	12/14/2023 0:22
QC	5.265		5.00		105%	-5f5369ab:18c639c13f0:-7897	12/14/2023 4:23
QC	5.183		5.00		104%	-5f5369ab:18c639c13f0:-7895	12/14/2023 4:41
QC	5.319		5.00		106%	-5f5369ab:18c639c13f0:-7795	12/14/2023 7:27
QC	5.340		5.00		107%	-5f5369ab:18c639c13f0:-774d	12/14/2023 9:55
DL	0.105		0.10		105%	-5f5369ab:18c639c13f0:-78e7	12/13/2023 16:03
DL	0.102		0.10		102%	-5f5369ab:18c639c13f0:-78e5	12/13/2023 16:22
DL	0.107		0.10		107%	-5f5369ab:18c639c13f0:-7793	12/14/2023 7:46
DL	0.107		0.10		107%	-5f5369ab:18c639c13f0:-774b	12/14/2023 10:14
36738-5QC	6.951	10	78.0		94%	-5f5369ab:18c639c13f0:-7704	12/14/2023 10:51
BLK	0.000					-5f5369ab:18c639c13f0:-78eb	12/13/2023 15:26
BLK	0.000					-5f5369ab:18c639c13f0:-78e9	12/13/2023 15:45
BLK	0.000					-5f5369ab:18c639c13f0:-78cb	12/13/2023 20:22
BLK	0.000					-5f5369ab:18c639c13f0:-78c9	12/13/2023 20:40
BLK	0.000					-5f5369ab:18c639c13f0:-78af	12/14/2023 0:41
BLK	0.000					-5f5369ab:18c639c13f0:-78ed	12/14/2023 0:59
BLK	0.000					-5f5369ab:18c639c13f0:-7893	12/14/2023 5:00
BLK	0.000					-5f5369ab:18c639c13f0:-7891	12/14/2023 5:18
BLK	0.000					-5f5369ab:18c639c13f0:-7791	12/14/2023 8:04
BLK	0.000					-5f5369ab:18c639c13f0:-7749	12/14/2023 10:32

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #:

(15-28)
41653

Date: 12/13/23

Column: IonPac AS14A

Instrument: 881/858

Analyst: KLG

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Lot# 1C11-87-1

Batch name: 121323-41653 HF

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Lot # 1C11-98-2

Regenerant: 100 mM H₃PO₄

Flow Rate: 1.0 mL/min.

Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0.0		P2	ac lot#			
2	0.1	F	9998 06	BBCV0574	Sigma		
3	1.0						
4	3.0						
5	5.0						
6	10.0						
7	ac						
8	ac						
9	Blk						
10	Blk						
11	DL						
12	DL						
13	URB						
14	URB						
15	URB+						
16	URB+						
17	41653-15	Deeco	HF			5V	
18	-15dup	↓	↓			↓	
19	-16	↓	↓			↓	
20	-16dup	↓	↓			↓	
21	-18	↓	↓			↓	
22	-18dup	↓	↓			↓	
23	ac						
24	ac						
25	Blk						

Manual integrations noted by M

Curve IC Lot # 1C11-101-1

Comments: p. 1 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution HP 2303027-250 IC NO2 Solution HP 2308942-250

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.

QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: 12/14/23 Time: 1:48 By: [Signature] QC Review- Date: [Signature] Time: [Signature] By: [Signature]

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #:

(15-28)
41653

Date: 12/13/23

Column: IonPac AS14A

Instrument: 881/858

Analyst: *WV*

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Lot# 1C11-87-1

Batch name: 121323-41653 HF 10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100 mM H₃PO₄

Lot # 1C11-98-2

Flow Rate: 1.0 mL/min.

Method: 300(26A)

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	BLK						
27	41653-17	Deeco	HF		—	5X	
28	-17dup				—		
29	-17spk			<i>5.446</i>	5.122		<i>peak joined w/ indistinct to identify peak</i>
30	-17spk dup			<i>5.484</i>	5.191		
31	-19				—		
32	-19dup				—		
33	-20				—		
34	-20dup				—		
35	-21				—		
36	-21dup	↓	↓		—	↓	
37	ac						
38	ac						
39	BLK						
40	BLK						
41	41653-22	Deeco	HF		—	5X	
42	-22dup				—		
43	-23				—		
44	-23dup				—		
45	-23spk			<i>5.478</i>	5.198		<i>peak co-eluting w/ indistinct next to E-</i>
46	-23spk dup			<i>5.490</i>	5.298		
47	-24				—		
48	-24dup				—		
49	-25				—		
50	-25dup	↓	↓		—	↓	

Manual integrations noted by M

Curve IC Lot#

Comments: *p. 2 of 3*

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution _____ IC NO2 Solution _____

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.

QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41653 (15-28)

Date: 12/13/23

Column: IonPac AS14A

Instrument: 8811858

Analyst: YUH

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Lot# 1C11-87-1

Batch name: 121323-41653 HF

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Lot # 1C11-98-2

Regenerant: 100 mM H₃PO₄

Flow Rate: 1.0 mL/min.

Method: 300(26A)

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
51	QC						
52	QC						
53	B/K						
54	B/K						
55	41653-26	Deeco	HF			5X	
56	-26dup						
57	-27						
58	-27dup						
59	-28						
60	-28dup						
61	QC						
62	DL						
63	B/K						
64	0.1						
65	1.0						
66	3.0						
67	5.0						
68	10.0						
69	QC						
70	DL						
71	B/K						
72	36738-SAC		HF	6.951		1X	TV=6.96

Manual integrations noted by M

Curve IC Lot # _____ Comments: p. 3 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: _____ IC ME Solution _____ IC NO2 Solution _____

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SQ Std. to 10mL sample; lot #'s listed above.

QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41653 (1-14)

Client: Deeco

Column: IonPac AS14A

Date: 12.12.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

Sample ID	Cl ⁻ µg/ml	Dilution	Final Vol, ml	Cl ₂ , Total mg	Spike, µg/ml	% RPD/ Recovery	File Name	Date Time
LRB	-0.047	1	10	< 0.001			-4101620d:18c44c79eeb:-79d1	12/7/2023 20:50
LRB	-0.037	1	10	< 0.001		NA	-4101620d:18c44c79eeb:-79cf	12/7/2023 21:14
LRB SPK	5.167	1	10	0.052	5.00	104%	-4101620d:18c44c79eeb:-79cd	12/7/2023 21:37
LRB SPK	5.249	1	10	0.052	5.00	108%	-4101620d:18c44c79eeb:-79cb	12/7/2023 22:01
41653-1	0.077	10	176	< 0.176			-4101620d:18c44c79eeb:-79c9	12/7/2023 22:24
41653-1 DUP	0.079	10	176	< 0.176		NA	-4101620d:18c44c79eeb:-79c7	12/7/2023 22:48
41653-2	0.174	10	335	0.583			-4101620d:18c44c79eeb:-731b	12/8/2023 14:41
41653-2 DUP	0.173	10	335	0.580		0.6%	-4101620d:18c44c79eeb:-7319	12/8/2023 15:05
41653-3	0.075	10	300	< 0.3			-4101620d:18c44c79eeb:-732b	12/8/2023 11:33
41653-3 DUP	0.024	10	300	< 0.3		NA	-4101620d:18c44c79eeb:-7329	12/8/2023 11:57
41653-3 SPK	4.750	10	300	14.3	5.00	94%	-4101620d:18c44c79eeb:-7327	12/8/2023 12:20
41653-3 SPK DUP	4.543	10	300	13.6	5.00	90%	-4101620d:18c44c79eeb:-7325	12/8/2023 12:44
41653-4	0.288	10	425	1.22			-4101620d:18c44c79eeb:-7317	12/8/2023 15:28
41653-4 DUP	0.296	10	425	1.26		2.7%	-4101620d:18c44c79eeb:-7315	12/8/2023 15:52
41653-5	0.170	10	315	0.536			-4101620d:18c44c79eeb:-7313	12/8/2023 16:15
41653-5 DUP	0.168	10	315	0.529		1.2%	-4101620d:18c44c79eeb:-7311	12/8/2023 16:39
41653-6	0.312	10	300	0.936			-4101620d:18c44c79eeb:-730f	12/8/2023 17:02
41653-6 DUP	0.318	10	300	0.954		1.9%	-4101620d:18c44c79eeb:-730d	12/8/2023 17:26
41653-7	-0.019	10	203	< 0.203			-4101620d:18c44c79eeb:-730b	12/8/2023 17:49
41653-7 DUP	-0.164	10	203	< 0.203		NA	-4101620d:18c44c79eeb:-7309	12/8/2023 18:13
41653-8	0.057	10	348	< 0.348			-4101620d:18c44c79eeb:-6f10	12/11/2023 13:15
41653-8 DUP	0.009	10	348	< 0.348		NA	-4101620d:18c44c79eeb:-6f0e	12/11/2023 13:38
41653-9	0.040	10	350	< 0.35			-4101620d:18c44c79eeb:-6cf0	12/11/2023 16:42
41653-9 DUP	0.039	10	350	< 0.35		NA	-4101620d:18c44c79eeb:-6cee	12/11/2023 17:06
41653-9 SPK	5.037	10	350	17.6	5.00	100%	-4101620d:18c44c79eeb:-6cec	12/11/2023 17:29
41653-9 SPK DUP	5.070	10	350	17.7	5.00	101%	-4101620d:18c44c79eeb:-6cea	12/11/2023 17:53
41653-10	0.436	10	365	1.59			-4101620d:18c44c79eeb:-6ce8	12/11/2023 18:16
41653-10 DUP	0.434	10	365	1.58		0.5%	-4101620d:18c44c79eeb:-6ce6	12/11/2023 18:40
41653-11	0.347	10	302	1.05			-4101620d:18c44c79eeb:-6ce4	12/11/2023 19:03
41653-11 DUP	0.347	10	302	1.05		0.0%	-4101620d:18c44c79eeb:-6ce2	12/11/2023 19:27
41653-12	0.065	10	285	< 0.285			-4101620d:18c44c79eeb:-7013	12/9/2023 1:16
41653-12 DUP	-0.153	10	285	< 0.285		NA	-4101620d:18c44c79eeb:-7011	12/9/2023 1:39
41653-13 FB ON	0.072	5	305	< 0.153			-4101620d:18c44c79eeb:-700f	12/9/2023 2:03
41653-13 FB ON DUP	-0.148	5	305	< 0.153		NA	-4101620d:18c44c79eeb:-700d	12/9/2023 2:26
41653-14 FB OFF	0.000	5	305	< 0.153			-4101620d:18c44c79eeb:-700b	12/9/2023 2:50
41653-14 FB OFF DU	0.063	5	305	< 0.153		NA	-4101620d:18c44c79eeb:-7009	12/9/2023 3:13

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41653 (1-14)

Client: Deeco

Column: IonPac AS14A

Date: 12.12.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

Standards	Cl ⁻ µg/ml	Dilution	QC µg/ml	%Relative Error	% Recovery	File Name	Date Time
0	0.000					-4101620d:18c44c79eeb:-6d00	12/7/2023 16:08
0.1	0.102			2.0%	102%	-4101620d:18c44c79eeb:-6cfe	12/7/2023 16:32
1	0.979			-2.1%	98%	-4101620d:18c44c79eeb:-6cfc	12/7/2023 16:55
3	2.956			-1.5%	99%	-4101620d:18c44c79eeb:-6cfa	12/7/2023 17:19
5	5.089			1.8%	102%	-4101620d:18c44c79eeb:-6cf8	12/7/2023 17:42
10	9.973			-0.3%	100%	-4101620d:18c44c79eeb:-6cf6	12/7/2023 18:06
0.1	0.098			-2.0%	98%	-4101620d:18c44c79eeb:-7001	12/9/2023 4:47
1	0.990			-1.0%	99%	-4101620d:18c44c79eeb:-6ffb	12/9/2023 5:58
3	3.034			1.1%	101%	-4101620d:18c44c79eeb:-6ff9	12/9/2023 6:21
5	5.012			0.2%	100%	-4101620d:18c44c79eeb:-6ff7	12/9/2023 6:45
10	10.178			1.8%	102%	-4101620d:18c44c79eeb:-6cda	12/11/2023 21:01
Correlation-	0.999804						
QC	5.090		5.00		102%	-4101620d:18c44c79eeb:-79dd	12/7/2023 18:29
QC	4.724		5.00		94%	-4101620d:18c44c79eeb:-79db	12/7/2023 18:53
QC	4.667		5.00		93%	-4101620d:18c44c79eeb:-732d	12/8/2023 11:10
QC	4.869		5.00		97%	-4101620d:18c44c79eeb:-7323	12/8/2023 13:07
QC	4.911		5.00		98%	-4101620d:18c44c79eeb:-7321	12/8/2023 13:31
QC	4.981		5.00		100%	-4101620d:18c44c79eeb:-7033	12/8/2023 19:00
QC	4.589		5.00		92%	-4101620d:18c44c79eeb:-7019	12/9/2023 0:05
QC	5.273		5.00		105%	-4101620d:18c44c79eeb:-7003	12/9/2023 4:24
QC	4.991		5.00		100%	-4101620d:18c44c79eeb:-6fe5	12/9/2023 10:16
QC	4.689		5.00		94%	-4101620d:18c44c79eeb:-6f12	12/11/2023 12:51
QC	4.549		5.00		91%	-4101620d:18c44c79eeb:-6cf2	12/11/2023 16:19
QC	5.042		5.00		101%	-4101620d:18c44c79eeb:-6ce0	12/11/23 19:50
DL	0.101		0.10		101%	-4101620d:18c44c79eeb:-79d5	12/7/2023 20:03
DL	0.090		0.10		90%	-4101620d:18c44c79eeb:-6cde	12/11/2023 20:14
40034-7 QC	3.930	20	78.0		101%	-4101620d:18c44c79eeb:-7007	12/9/2023 3:37
40034-7 QC DUP	3.894	20	78.0		100%	-4101620d:18c44c79eeb:-7005	12/9/2023 4:00
BLK	0.000					-4101620d:18c44c79eeb:-79d9	12/7/2023 19:16
BLK	0.000					-4101620d:18c44c79eeb:-79d7	12/7/2023 19:40
BLK	0.000					-4101620d:18c44c79eeb:-731f	12/8/2023 13:54
BLK	0.000					-4101620d:18c44c79eeb:-731c	12/8/2023 14:18
BLK	0.000					-4101620d:18c44c79eeb:-702f	12/8/2023 19:47
BLK	0.000					-4101620d:18c44c79eeb:-7015	12/9/2023 0:52
BLK	0.000					-4101620d:18c44c79eeb:-6fff	12/9/2023 5:11
BLK	0.000					-4101620d:18c44c79eeb:-6fef	12/9/2023 8:19
BLK	0.000					-4101620d:18c44c79eeb:-6fef	12/9/2023 8:19
BLK	0.000					-4101620d:18c44c79eeb:-6cdc	12/11/2023 20:37

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 4165

Date: 12.07.23
Analyst: LW

Column: IonPac AS14A
Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃
10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
Regenerant: 100mM H₃PO₄
Flow Rate: 1.0 mL/min.

Instrument: 8811858
Lot# 1011-70-4
Lot # 1011-98-2
Method: 26A NaOH

Batch name: # 120723-41653

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0.0			QC	main	10	
2	0.1		Cl ⁻	4308759	12104	.999804	
3	1.0						
4	3.0						
5	5.0						
6	10.0						
7	GC						
8	GC						
9	BLK						
10	BLK						
11	DL						
12	DL						
13	W3						
14	W3						
15	W3T						
16	W3T						
17	41653-1	Deeco	Cl ₂			10x	
18	-1D	→ GC in	→ retest here	Remun			
19	-3			3-9			
20	-3D			1208			
21	-3+			4750	2580		
22	-3+D			4543	4428		
23	GC				#		
24	GC						
25	BLK						

Instrument
retest clay
retest
MIS
of state

Manual integrations noted by M

Curve IC Lot # 1011-99-2 Sodium Thiosulfate Lot # 1011-73-4 Comments: pg 10 F

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution 2303024 250 HRD

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: 12.12.23 Time: 8:30 By: LW QC Review- Date: [check] Time: [] By: []

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #:

(1-14)
411653

Date: 120723
Analyst: W

Column: IonPac AS14A
Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Instrument: 881/858
Lot# 1C11-70-4

Batch name: 120723-411653

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
Regenerant: 100mM H₃PO₄
Flow Rate: 1.0 mL/min.

Lot # 1C11-98-2
Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	Blk						
27	411653-2	Deeco	Cl ₂		0.124	10X	
28	-2D				0.173		
29	-4				0.288		
30	-4D				0.296		
31	-5			0.168g			
32	-5D			0.170g			
33	-6			0.317	0.195		
34	-6D			0.318	0.192		
35	-7				0.428		
36	-7D				0.425		
37	QC	✓					
38	QC	✓					
39	Blk	✓					
40	Blk	✓					
41	411653-8	Deeco	Cl ₂			10X	Did not run
42	(9) -8D	SKIPPED	SD Sample				DUP
43	42 (9) D						
44	43 (9) D						
45	44 (9) D						
46	45 (9) D						
47	46 (9) D						
48	47 (9) D						
49	48 (9) D						
50	49 (9) D						

Manual integr:

Curve IC Lot # _____ Sodium Thiosulfate Lot # _____ Comments: pg 2 of

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution _____

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: (1-14) 41653

Date: 12-07-23
Analyst: LWO

Column: IonPac AS14A
Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Instrument: 881/858
Lot# 101-70-4

Batch name: 120723-41653

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
Regenerant: 100mM H₃PO₄
Flow Rate: 1.0 mL/min.

Lot # 1011-98-2
Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
51	GC						
52	GC / BK						
53	BK / BK						
54	BK / BK						
55	12-12 / 12-D	Deeco	Cl ₂			10X	
56	12D-12D / BK						
57	13FB13 / FB on					5X	
58	13FB-13 / FB on						
59	14FB-14 / FB off						
60	14FB-14 / FB off						
61	10034-72 / GC				3.894	20X	TV=78.00
62	7 / GC				3930		
63	GC						
64	DL use w/ 0.1						
65	BK						
66	0.1						
67	1.0						
68	30						
69	50						
70	100 run 1000 ug/ml						
71	GC Budget						
72	DL						
73	BK						
74	41653-3	Deeco	Cl ₂			10X	
75	-3D						

Manual integr:

Curve IC Lot # _____ Sodium Thiosulfate Lot # _____ Comments: pg 3 of 7

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution _____

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41653

Date: 120723
Analyst: LW

Column: IonPac AS14A
Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Instrument: 8811858
Lot# 1C11-70-4

Batch name: 120723-41653

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
Regenerant: 100mM H₃PO₄
Flow Rate: 1.0 mL/min.

Lot # 1C11-98-2
Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
76	41653-37	Deeco	Cl₂			10x	
77	31D		↓			↓	
1	B1C	after Peruskathic Pix					
2	QC						
3	41653-8		Cl ₂			10x	
4	-8D		↓				
5	-9		↓				
6	-9D		↓				Standard solution sample replaced
7	-9F		↓		5037		
8	-9FD		↓		5070		
9	-10		↓		0436		
10	-10D		↓		0434		
11	-11		↓		0342		
12	-11D		↓		0.347		
13	QC						
14	DEBI						
15	BLK						
16	10.0						

Manual integr
 Curve IC Lot # _____ Sodium Thiosulfate Lot # _____ Comments: pg 4 of 4
 Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution _____
 QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.
 Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41653 (15-28)

Client: Deeco

Column: Metrosep IonPac AS14A

Date: 12.15.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

Sample ID	Cl ⁻ µg/ml	Dilution	Final Vol, ml	Cl ₂ , Total mg	Spike, µg/ml	% RPD/ Recovery	File Name	Date Time
LRB	0.000	1	10	< 0.001			_2023-12-13_	12/13/2023 23:35
LRB	0.000	1	10	< 0.001		NA	_2023-12-14_	12/14/2023 0:05
LRB SPK	4.568	1	10	0.046	5.00	91%	_2023-12-14_	12/14/2023 0:35
LRB SPK	5.334	1	10	0.053	5.00	107%	_2023-12-14_	12/14/2023 1:05
41653-15	0.363	10	300	1.09			_2023-12-14_	12/14/2023 1:34
41653-15 DUP	0.357	10	300	1.07		1.7%	_2023-12-14_	12/14/2023 2:04
41653-16	0.476	10	325	1.55			_2023-12-14_	12/14/2023 2:34
41653-16 DUP	0.483	10	325	1.57		1.5%	_2023-12-14_	12/14/2023 3:03
41653-17	0.440	10	340	1.50			_2023-12-14_	12/14/2023 6:31
41653-17 DUP	0.455	10	340	1.55		3.4%	_2023-12-14_	12/14/2023 7:01
41653-17 SPK	5.766	10	340	19.6	5.00	107%	_2023-12-14_	12/14/2023 7:31
41653-17 SPK DUP	5.392	10	340	18.3	5.00	99%	_2023-12-14_	12/14/2023 8:00
41653-18	0.190	10	360	0.684			_2023-12-14_	12/14/2023 3:33
41653-18 DUP	0.190	10	360	0.684		0.0%	_2023-12-14_	12/14/2023 4:03
41653-19	0.248	10	370	0.918			_2023-12-14_	12/14/2023 8:30
41653-19 DUP	0.244	10	370	0.903		1.6%	_2023-12-14_	12/14/2023 9:00
41653-20	0.205	10	362	0.742			_2023-12-14_	12/14/2023 9:29
41653-20 DUP	0.208	10	362	0.753		1.5%	_2023-12-14_	12/14/2023 9:59
41653-21	0.404	10	335	1.35			_2023-12-14_	12/14/2023 10:29
41653-21 DUP	0.399	10	335	1.34		1.2%	_2023-12-14_	12/14/2023 10:59
41653-22	0.300	10	385	1.16			_2023-12-14_	12/14/2023 13:27
41653-22 DUP	0.301	10	385	1.16		0.3%	_2023-12-14_	12/14/2023 13:57
41653-23	0.456	10	335	1.53			_2023-12-14_	12/14/2023 14:27
41653-23 DUP	0.450	10	335	1.51		1.3%	_2023-12-14_	12/14/2023 14:56
41653-23 SPK	5.284	10	335	17.7	5.00	97%	_2023-12-14_	12/14/2023 15:26
41653-23 SPK DUP	5.749	10	335	19.3	5.00	106%	_2023-12-14_	12/14/2023 15:56
41653-24	0.164	10	355	0.582			_2023-12-14_	12/14/2023 16:25
41653-24 DUP	0.166	10	355	0.589		1.2%	_2023-12-14_	12/14/2023 16:55
41653-25	0.219	10	375	0.821			_2023-12-14_	12/14/2023 17:25
41653-25 DUP	0.221	10	375	0.829		0.9%	_2023-12-14_	12/14/2023 17:54
41653-26	0.230	10	350	0.805			_2023-12-14_	12/14/2023 20:23
41653-26 DUP	0.229	10	350	0.802		0.4%	_2023-12-14_	12/14/2023 20:53
41653-27 FB	0.000	5	355	< 0.178			_2023-12-14_	12/14/2023 21:22
41653-27 FB DUP	0.000	5	355	< 0.178		NA	_2023-12-14_	12/14/2023 21:52
41653-28 FB	0.000	5	345	< 0.173			_2023-12-14_	12/14/2023 22:22
41653-28 FB DUP	0.000	5	345	< 0.173		NA	_2023-12-14_	12/14/2023 22:51

Cl₂-Data 1 of 2

elementOne
e 36275-Cl₂



elementOne

Certification: NJ NELAP NC009
41653 Deeco M26A Report Packet
Page 41 of 45

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41653 (15-28)

Client: Deeco

Date: 12.15.23

Analyst: LAW

Detection Limit, (µg/ml): 0.10

Column: Metrosep IonPac AS14A

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Flow Rate: 1.0 mL/min.

Standards	Cl ⁻ µg/ml	Dilution	QC µg/ml	%Relative Error	% Recovery	File Name	Date Time
0	0.000					_2023-12-13_	12/13/2023 17:39
0.1	0.104			4.0%	104%	_2023-12-13_	12/13/2023 18:09
1	0.924			-7.6%	92%	_2023-12-13_	12/13/2023 18:38
3	2.902			-3.3%	97%	_2023-12-13_	12/13/2023 19:08
5	5.304			6.1%	106%	_2023-12-13_	12/13/2023 19:38
10	9.866			-1.3%	99%	_2023-12-13_	12/13/2023 20:08
0.1	0.108			8.0%	108%	_2023-12-15_	12/15/2023 0:50
1	0.999			-0.1%	100%	_2023-12-15_	12/15/2023 1:20
3	2.986			-0.5%	100%	_2023-12-15_	12/15/2023 1:50
5	5.264			5.3%	105%	_2023-12-15_	12/15/2023 2:19
10	10.940			9.4%	109%	_2023-12-15_	12/15/2023 2:49

Correlation- 0.9999

QC	5.318		5.00		106%	_2023-12-13_	12/13/2023 20:37
QC	5.424		5.00		108%	_2023-12-13_	12/13/2023 21:07
QC	5.466		5.00		109%	_2023-12-14_	12/14/2023 4:32
QC	4.861		5.00		97%	_2023-12-14_	12/14/2023 5:02
QC	5.195		5.00		104%	_2023-12-14_	12/14/2023 11:28
QC	5.293		5.00		106%	_2023-12-14_	12/14/2023 11:58
QC	4.148		5.00		83%	_2023-12-14_	12/14/2023 18:24
QC	5.142		5.00		103%	_2023-12-14_	12/14/2023 18:54
QC	5.231		5.00		105%	_2023-12-14_	12/14/2023 23:21
QC	4.746		5.00		95%	_2023-12-15_	12/15/2023 3:19
DL	0.110		0.10		110%	_2023-12-13_	12/13/2023 22:36
DL	0.104		0.1		104%	_2023-12-13_	12/13/23 23:06
DL	0.110		0.1		110%	_2023-12-14_	12/14/2023 23:51
DL	0.110		0.10		110%	_2023-12-15_	12/15/2023 3:48
40034-7QC	3.720	20	78.0		95%	_2023-12-15_	12/15/2023 4:48
BLK	0.000					_2023-12-13_	12/13/2023 21:37
BLK	0.000					_2023-12-13_	12/13/2023 22:06
BLK	0.000					_2023-12-14_	12/14/2023 5:32
BLK	0.000					_2023-12-14_	12/14/2023 6:02
BLK	0.000					_2023-12-14_	12/14/2023 12:28
BLK	0.000					_2023-12-14_	12/14/2023 12:57
BLK	0.000					_2023-12-14_	12/14/2023 19:23
BLK	0.000					_2023-12-14_	12/14/2023 19:53
BLK	0.000					_2023-12-15_	12/15/2023 0:20
BLK	0.000					_2023-12-15_	12/15/2023 4:18

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41653 (15-28)

Date: 12/13/23
Analyst: KCG

Column: Metrosep A Supp 5
Conc. Eluent: 3.2 mM Na₂CO₃ / 10mM NaHCO₃
10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
Regenerant: 100mM H₂SO₄
Flow Rate: .7 mL/min.

Instrument: 8611788
Lot# 1C11-87-1
Lot # 1C11-98-2
Method: 26A NaOH

Batch name: 121323-41653 C12

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0.0		R ²	AC lot #			
2	0.1	CI	.9999	4308059 Ricca			
3	1.0						
4	3.0						
5	5.0						
6	10.0						
7	ac						
8	ac						
9	BLK						
10	BLK						
11	DL						
12	DL						
13	UPB						
14	UPB						
15	UPB+						
16	UPB+						
17	41653-15	Deeco	Cl ₂		0.357	10X	
18	-15dup	↓	↓		0.363	↓	
19	-16	↓	↓		0.476	↓	
20	-16dup	↓	↓		0.483	↓	
21	-18	↓	↓		0.190	↓	
22	-18dup	↓	↓		0.190	↓	
23	ac						
24	ac						
25	BLK						

Manual integrate

Curve IC Lot # 1C11-101-4 Sodium Thiosulfate Lot # ~~11-73-4~~ 11-73-4 Comments: p. 1 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s IC ME Solution HP 2303029-250

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41653 (15-25)

Date: 12/13/23
Analyst: KUN

Column: IonPac AS14A
Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Instrument: 8611788
Lot# 1C11-87-1

Batch name: 121323-41653 C12

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
Regenerant: 100mM H₃PO₄
Flow Rate: 1.0 mL/min.

Lot # 1C11-98-2
Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	BIK						
27	41653-17	Deeco	C12		0.440	10X	
28	-17 dup				0.455		
29	-17 spk				5.766		
30	-17 spk dup				5.392		
31	-19				0.248		
32	-19 dup				0.244		
33	-20				0.205		
34	-20 dup				0.208		
35	-21				0.404		
36	-21 dup	↓	↓		0.399	↓	
37	QC						
38	QC						
39	BIK						
40	BIK						
41	41653-22	Deeco	C12	0.300	0.32X	10X	
42	-22 dup			0.301	0.317		
43	-23				0.456		
44	-23 dup				0.450		
45	-23 spk				5.284		
46	-23 spk dup				5.749		
47	-24				0.164		
48	-24 dup				0.166		
49	-25				0.219		
50	-25 dup	↓	↓		0.221	↓	

Manual integrations noted by M

Curve IC Lot # Sodium Thiosulfate Lot # Comments: p. 2 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC/ Date: / Time: / By: / QC Review- Date: / Time: / By: /

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41653 (15-28)

Date: 12/13/23

Column: IonPac AS14A

Instrument: 8611788

Analyst: YUN

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Lot# 1C11-87-1

Batch name: 121323-41653 C12

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Lot # 1C11-98-2

Regenerant: 100mM H₃PO₄

Flow Rate: 1.0 mL/min.

Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
51	AC						
52	AC						
53	BLK						
54	BLK						
55	41653-26	Duio	C12		0.230	10X	
56	-26dup	↓	↓		0.229	↓	
57	-27FB	↓	↓		---	5X	
58	-27FBdup	↓	↓		---	↓	
59	-28FB	↓	↓		---	↓	
60	-28FBdup	↓	↓		---	↓	
61	AC						
62	DL						
63	BLK						
64	0.1						
65	1.0						
66	3.0						
67	5.0						
68	10.0						
69	AC						
70	DL						
71	BLK						
72	40034-7AC		C12		3.220	10X	TV=78.0

Manual integr:

Curve IC Lot # _____ Sodium Thiosulfate Lot # _____ Comments: p. 3 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution _____

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC Date: _____ Time: _____ By: _____ QC Review Date: _____ Time: _____ By: _____

elementOne

Appendix D
Plant Process Data

Holdcm	Midlothian TX	
Line 1 Main Stack		Clinker
Mill On Run 1		mtph
Date/Time		
11/15/2023 9:00		131.0
11/15/2023 9:01		131.0
11/15/2023 9:02		130.9
11/15/2023 9:03		131.0
11/15/2023 9:04		131.0
11/15/2023 9:05		131.0
11/15/2023 9:06		130.9
11/15/2023 9:07		131.0
11/15/2023 9:08		130.9
11/15/2023 9:09		131.0
11/15/2023 9:10		131.0
11/15/2023 9:11		131.0
11/15/2023 9:12		131.0
11/15/2023 9:13		130.9
11/15/2023 9:14		131.0
11/15/2023 9:15		131.0
11/15/2023 9:16		130.9
11/15/2023 9:17		131.0
11/15/2023 9:18		131.0
11/15/2023 9:19		131.0
11/15/2023 9:20		130.9
11/15/2023 9:21		130.9
11/15/2023 9:22		131.0
11/15/2023 9:23		131.0
11/15/2023 9:24		131.0
11/15/2023 9:25		131.0
11/15/2023 9:26		130.9
11/15/2023 9:27		131.0
11/15/2023 9:28		130.9
11/15/2023 9:29		130.9
11/15/2023 9:30		131.0
11/15/2023 9:31		130.9
11/15/2023 9:32		130.9
11/15/2023 9:33		131.0
11/15/2023 9:34		130.9
11/15/2023 9:35		130.9
11/15/2023 9:36		130.9
11/15/2023 9:37		131.0
11/15/2023 9:38		131.0
11/15/2023 9:39		130.9
11/15/2023 9:40		130.9
11/15/2023 9:41		131.0
11/15/2023 9:42		130.9

Holcim Midlothian TX	
Line 1 Main Stack	
Mill On Run 1	Clinker
Date/Time	mtph
11/15/2023 9:43	131.0
11/15/2023 9:44	130.9
11/15/2023 9:45	131.0
11/15/2023 9:46	131.0
11/15/2023 9:47	130.9
11/15/2023 9:48	130.9
11/15/2023 9:49	130.9
11/15/2023 9:50	131.0
11/15/2023 9:51	131.0
11/15/2023 9:52	130.9
11/15/2023 9:53	131.0
11/15/2023 9:54	130.9
11/15/2023 9:55	130.9
11/15/2023 9:56	130.9
11/15/2023 9:57	131.0
11/15/2023 9:58	131.0
11/15/2023 9:59	130.9
11/15/2023 10:00	131.0
11/15/2023 10:01	130.9
11/15/2023 10:02	131.0
11/15/2023 10:03	130.9
11/15/2023 10:04	131.0
11/15/2023 10:05	131.0
11/15/2023 10:06	130.9
11/15/2023 10:07	130.9
11/15/2023 10:08	131.0
11/15/2023 10:09	131.0
Averages	131.0

Holcim Midlothian TX	Clinker
Line 1 Main Stack	mtph
Mill On Run 2	
Date/Time	
11/15/2023 10:37	130.9
11/15/2023 10:38	131.0
11/15/2023 10:39	131.0
11/15/2023 10:40	130.9
11/15/2023 10:41	131.0
11/15/2023 10:42	130.9
11/15/2023 10:43	131.0
11/15/2023 10:44	130.9
11/15/2023 10:45	131.0
11/15/2023 10:46	130.9
11/15/2023 10:47	131.0
11/15/2023 10:48	131.0
11/15/2023 10:49	131.0
11/15/2023 10:50	130.9
11/15/2023 10:51	130.9
11/15/2023 10:52	131.0
11/15/2023 10:53	131.0
11/15/2023 10:54	131.0
11/15/2023 10:55	130.9
11/15/2023 10:56	130.9
11/15/2023 10:57	131.0
11/15/2023 10:58	131.0
11/15/2023 10:59	131.0
11/15/2023 11:00	130.9
11/15/2023 11:01	131.0
11/15/2023 11:02	131.0
11/15/2023 11:03	130.9
11/15/2023 11:04	131.0
11/15/2023 11:05	130.9
11/15/2023 11:06	130.9
11/15/2023 11:07	131.0
11/15/2023 11:08	131.0
11/15/2023 11:09	130.9
11/15/2023 11:10	130.9
11/15/2023 11:11	131.0
11/15/2023 11:12	130.9
11/15/2023 11:13	131.0
11/15/2023 11:14	130.9
11/15/2023 11:15	130.9
11/15/2023 11:16	131.0
11/15/2023 11:17	131.0
11/15/2023 11:18	131.0
11/15/2023 11:19	130.9

Holcim Midlothian TX	
Line 1 Main Stack	
Mill On Run 2	Clinker
Date/Time	mtph
11/15/2023 11:20	130.9
11/15/2023 11:21	131.0
11/15/2023 11:22	130.9
11/15/2023 11:23	131.0
11/15/2023 11:24	131.0
11/15/2023 11:25	131.0
11/15/2023 11:26	131.0
11/15/2023 11:27	131.0
11/15/2023 11:28	131.0
11/15/2023 11:29	130.9
11/15/2023 11:30	131.0
11/15/2023 11:31	130.9
11/15/2023 11:32	130.9
11/15/2023 11:33	131.0
11/15/2023 11:34	130.9
11/15/2023 11:35	130.9
11/15/2023 11:36	131.0
11/15/2023 11:37	130.9
11/15/2023 11:38	131.0
11/15/2023 11:39	130.9
11/15/2023 11:40	130.9
11/15/2023 11:41	131.0
Averages	131.0

Holcim Midlothian TX Line 1 Main Stack Mill On Run 3 Date/Time	Clinker mtph
11/15/2023 12:02	131.0
11/15/2023 12:03	130.9
11/15/2023 12:04	130.9
11/15/2023 12:05	130.9
11/15/2023 12:06	130.9
11/15/2023 12:07	131.0
11/15/2023 12:08	131.0
11/15/2023 12:09	130.9
11/15/2023 12:10	130.9
11/15/2023 12:11	131.0
11/15/2023 12:12	130.9
11/15/2023 12:13	131.0
11/15/2023 12:14	131.0
11/15/2023 12:15	131.0
11/15/2023 12:16	131.0
11/15/2023 12:17	131.0
11/15/2023 12:18	131.0
11/15/2023 12:19	131.0
11/15/2023 12:20	131.0
11/15/2023 12:21	130.9
11/15/2023 12:22	130.9
11/15/2023 12:23	130.9
11/15/2023 12:24	130.9
11/15/2023 12:25	131.0
11/15/2023 12:26	131.0
11/15/2023 12:27	130.9
11/15/2023 12:28	131.0
11/15/2023 12:29	131.0
11/15/2023 12:30	130.9
11/15/2023 12:31	130.9
11/15/2023 12:32	131.0
11/15/2023 12:33	131.0
11/15/2023 12:34	131.0
11/15/2023 12:35	131.0
11/15/2023 12:36	131.0
11/15/2023 12:37	131.0
11/15/2023 12:38	130.9
11/15/2023 12:39	131.0
11/15/2023 12:40	131.0
11/15/2023 12:41	130.9
11/15/2023 12:42	131.0
11/15/2023 12:43	130.9
11/15/2023 12:44	130.9

Holcim Midlothian TX Line 1 Main Stack Mill On Run 3 Date/Time	Clinker mtph
11/15/2023 12:45	130.9
11/15/2023 12:46	131.0
11/15/2023 12:47	130.9
11/15/2023 12:48	130.9
11/15/2023 12:49	131.0
11/15/2023 12:50	130.9
11/15/2023 12:51	131.0
11/15/2023 12:52	131.0
11/15/2023 12:53	131.0
11/15/2023 12:54	130.9
11/15/2023 12:55	131.0
11/15/2023 12:56	131.0
11/15/2023 12:57	131.0
11/15/2023 12:58	131.0
11/15/2023 12:59	131.0
11/15/2023 13:00	131.0
11/15/2023 13:01	130.9
11/15/2023 13:02	130.9
11/15/2023 13:03	130.9
11/15/2023 13:04	131.0
11/15/2023 13:05	130.9
11/15/2023 13:06	131.0
11/15/2023 13:07	130.9
11/15/2023 13:08	131.0
11/15/2023 13:09	130.9
11/15/2023 13:10	131.0
11/15/2023 13:11	131.0
Averages	131.0

Holcim Midlothian TX	Clinker
Line 1 Main Stack	mtph
Mill Off Run 1	
Date/Time	
11/15/2023 12:02	131.0
11/15/2023 12:03	130.9
11/15/2023 12:04	130.9
11/15/2023 12:05	130.9
11/15/2023 12:06	130.9
11/15/2023 12:07	131.0
11/15/2023 12:08	131.0
11/15/2023 12:09	130.9
11/15/2023 12:10	130.9
11/15/2023 12:11	131.0
11/15/2023 12:12	130.9
11/15/2023 12:13	131.0
11/15/2023 12:14	131.0
11/15/2023 12:15	131.0
11/15/2023 12:16	131.0
11/15/2023 12:17	131.0
11/15/2023 12:18	131.0
11/15/2023 12:19	131.0
11/15/2023 12:20	131.0
11/15/2023 12:21	130.9
11/15/2023 12:22	130.9
11/15/2023 12:23	130.9
11/15/2023 12:24	130.9
11/15/2023 12:25	131.0
11/15/2023 12:26	131.0
11/15/2023 12:27	130.9
11/15/2023 12:28	131.0
11/15/2023 12:29	131.0
11/15/2023 12:30	130.9
11/15/2023 12:31	130.9
11/15/2023 12:32	131.0
11/15/2023 12:33	131.0
11/15/2023 12:34	131.0
11/15/2023 12:35	131.0
11/15/2023 12:36	131.0
11/15/2023 12:37	131.0
11/15/2023 12:38	130.9
11/15/2023 12:39	131.0
11/15/2023 12:40	131.0
11/15/2023 12:41	130.9
11/15/2023 12:42	131.0
11/15/2023 12:43	130.9
11/15/2023 12:44	130.9

Holcim Midlothian TX	
Line 1 Main Stack	
Mill Off Run 1	Clinker
Date/Time	mtph
11/15/2023 12:45	130.9
11/15/2023 12:46	131.0
11/15/2023 12:47	130.9
11/15/2023 12:48	130.9
11/15/2023 12:49	131.0
11/15/2023 12:50	130.9
11/15/2023 12:51	131.0
11/15/2023 12:52	131.0
11/15/2023 12:53	131.0
11/15/2023 12:54	130.9
11/15/2023 12:55	131.0
11/15/2023 12:56	131.0
11/15/2023 12:57	131.0
11/15/2023 12:58	131.0
11/15/2023 12:59	131.0
11/15/2023 13:00	131.0
11/15/2023 13:01	130.9
11/15/2023 13:02	130.9
11/15/2023 13:03	130.9
11/15/2023 13:04	131.0
11/15/2023 13:05	130.9
11/15/2023 13:06	131.0
11/15/2023 13:07	130.9
11/15/2023 13:08	131.0
11/15/2023 13:09	130.9
11/15/2023 13:10	131.0
11/15/2023 13:11	131.0
Averages	131.0

Hotcim	Midlothian TX	
Line 1 Main Stack		Clinker
Mill Off Run 2		mtph
Date/Time		
11/15/2023 15:55		131.0
11/15/2023 15:56		130.9
11/15/2023 15:57		131.0
11/15/2023 15:58		130.9
11/15/2023 15:59		131.0
11/15/2023 16:00		131.0
11/15/2023 16:01		130.9
11/15/2023 16:02		131.0
11/15/2023 16:03		131.0
11/15/2023 16:04		130.9
11/15/2023 16:05		131.0
11/15/2023 16:06		130.9
11/15/2023 16:07		131.0
11/15/2023 16:08		131.0
11/15/2023 16:09		130.9
11/15/2023 16:10		131.0
11/15/2023 16:11		131.0
11/15/2023 16:12		131.0
11/15/2023 16:13		131.0
11/15/2023 16:14		130.9
11/15/2023 16:15		130.9
11/15/2023 16:16		131.0
11/15/2023 16:17		131.0
11/15/2023 16:18		131.0
11/15/2023 16:19		131.0
11/15/2023 16:20		131.0
11/15/2023 16:21		131.0
11/15/2023 16:22		131.0
11/15/2023 16:23		131.0
11/15/2023 16:24		130.9
11/15/2023 16:25		131.0
11/15/2023 16:26		131.0
11/15/2023 16:27		130.9
11/15/2023 16:28		131.0
11/15/2023 16:29		130.9
11/15/2023 16:30		130.9
11/15/2023 16:31		130.9
11/15/2023 16:32		130.9
11/15/2023 16:33		131.0
11/15/2023 16:34		130.9
11/15/2023 16:35		131.0
11/15/2023 16:36		130.9
11/15/2023 16:37		130.9

Holcim Midlothian TX	
Line 1 Main Stack	
Mill Off Run 2	Clinker
Date/Time	mtph
11/15/2023 16:38	131.0
11/15/2023 16:39	131.0
11/15/2023 16:40	131.0
11/15/2023 16:41	131.0
11/15/2023 16:42	131.0
11/15/2023 16:43	130.9
11/15/2023 16:44	130.9
11/15/2023 16:45	131.0
11/15/2023 16:46	130.9
11/15/2023 16:47	130.9
11/15/2023 16:48	131.0
11/15/2023 16:49	130.9
11/15/2023 16:50	131.0
11/15/2023 16:51	131.0
11/15/2023 16:52	131.0
11/15/2023 16:53	130.9
11/15/2023 16:54	130.9
11/15/2023 16:55	131.0
11/15/2023 16:56	131.0
11/15/2023 16:57	131.0
11/15/2023 16:58	131.0
11/15/2023 16:59	130.9
11/15/2023 17:00	130.9
11/15/2023 17:01	130.9
11/15/2023 17:02	130.9
11/15/2023 17:03	130.9
11/15/2023 17:04	131.0
11/15/2023 17:05	131.0
Averages	131.0

Holcim Midlothian TX	
Line 1 Main Stack	
Mill Off Run 3	Clinker
Date/Time	mtph
11/15/2023 17:19	131.0
11/15/2023 17:20	130.9
11/15/2023 17:21	131.0
11/15/2023 17:22	130.9
11/15/2023 17:23	131.0
11/15/2023 17:24	131.0
11/15/2023 17:25	130.9
11/15/2023 17:26	130.9
11/15/2023 17:27	131.0
11/15/2023 17:28	131.0
11/15/2023 17:29	131.0
11/15/2023 17:30	130.9
11/15/2023 17:31	130.9
11/15/2023 17:32	130.9
11/15/2023 17:33	130.9
11/15/2023 17:34	131.0
11/15/2023 17:35	130.9
11/15/2023 17:36	130.9
11/15/2023 17:37	130.9
11/15/2023 17:38	131.0
11/15/2023 17:39	131.0
11/15/2023 17:40	130.9
11/15/2023 17:41	131.0
11/15/2023 17:42	131.0
11/15/2023 17:43	130.9
11/15/2023 17:44	130.9
11/15/2023 17:45	131.0
11/15/2023 17:46	131.0
11/15/2023 17:47	131.0
11/15/2023 17:48	131.0
11/15/2023 17:49	131.0
11/15/2023 17:50	131.0
11/15/2023 17:51	131.0
11/15/2023 17:52	131.0
11/15/2023 17:53	131.0
11/15/2023 17:54	131.0
11/15/2023 17:55	130.9
11/15/2023 17:56	131.0
11/15/2023 17:57	130.9
11/15/2023 17:58	131.0
11/15/2023 17:59	131.0
11/15/2023 18:00	131.0
11/15/2023 18:01	130.9

Holcim Midlothian TX		Clinker mtph
Line 1 Main Stack Mill Off Run 3		
Date/Time		
11/15/2023 18:02		131.0
11/15/2023 18:03		131.0
11/15/2023 18:04		130.9
11/15/2023 18:05		131.0
11/15/2023 18:06		131.0
11/15/2023 18:07		130.9
11/15/2023 18:08		131.0
11/15/2023 18:09		131.0
11/15/2023 18:10		131.0
11/15/2023 18:11		131.0
11/15/2023 18:12		131.0
11/15/2023 18:13		131.0
11/15/2023 18:14		130.9
11/15/2023 18:15		131.0
11/15/2023 18:16		130.9
11/15/2023 18:17		131.0
11/15/2023 18:18		131.0
11/15/2023 18:19		131.0
11/15/2023 18:20		131.0
11/15/2023 18:21		130.9
11/15/2023 18:22		131.0
11/15/2023 18:23		130.9
11/15/2023 18:24		131.0
11/15/2023 18:25		130.9
11/15/2023 18:26		131.0
11/15/2023 18:27		131.0
11/15/2023 18:28		130.9
Averages		131.0

Holcim Midlothian TX
Line 2 Main Stack
Mill Off Run 1
Date/Time

Clinker
mtph

11/16/2023 14:20	123.8
11/16/2023 14:21	123.8
11/16/2023 14:22	123.7
11/16/2023 14:23	123.8
11/16/2023 14:24	123.8
11/16/2023 14:25	123.7
11/16/2023 14:27	123.7
11/16/2023 14:28	123.8
11/16/2023 14:29	123.8
11/16/2023 14:30	123.7
11/16/2023 14:31	123.8
11/16/2023 14:32	123.8
11/16/2023 14:33	123.7
11/16/2023 14:34	123.8
11/16/2023 14:35	123.8
11/16/2023 14:36	123.7
11/16/2023 14:37	123.7
11/16/2023 14:38	123.7
11/16/2023 14:39	123.7
11/16/2023 14:40	123.8
11/16/2023 14:41	123.8
11/16/2023 14:42	123.7
11/16/2023 14:43	123.8
11/16/2023 14:44	123.8
11/16/2023 14:45	123.8
11/16/2023 14:46	123.8
11/16/2023 14:47	123.8
11/16/2023 14:48	123.7
11/16/2023 14:49	123.8
11/16/2023 14:50	123.8
11/16/2023 14:51	123.8
11/16/2023 14:52	123.7
11/16/2023 14:53	123.8
11/16/2023 14:54	123.8
11/16/2023 14:55	123.8
11/16/2023 14:56	123.7
11/16/2023 14:57	123.8
11/16/2023 14:58	123.7
11/16/2023 14:59	123.8
11/16/2023 15:00	123.8
11/16/2023 15:01	123.7
11/16/2023 15:02	123.7
11/16/2023 15:03	123.7

Holcim Midlothian TX
Line 2 Main Stack
Mill Off Run 1
Date/Time

Clinker
mtph

11/16/2023 15:04	123.7
11/16/2023 15:05	123.8
11/16/2023 15:06	123.7
11/16/2023 15:07	123.7
11/16/2023 15:08	123.7
11/16/2023 15:09	123.7
11/16/2023 15:10	123.8
11/16/2023 15:11	123.7
11/16/2023 15:12	123.7
11/16/2023 15:13	123.7
11/16/2023 15:14	123.8
11/16/2023 15:15	123.7
11/16/2023 15:16	123.7
11/16/2023 15:17	123.8
11/16/2023 15:18	123.8
11/16/2023 15:19	123.8
11/16/2023 15:20	123.7
11/16/2023 15:21	123.8
11/16/2023 15:22	123.8
11/16/2023 15:23	123.7
11/16/2023 15:24	123.7
11/16/2023 15:25	123.8
11/16/2023 15:26	123.7
11/16/2023 15:27	123.7
11/16/2023 15:28	123.7
11/16/2023 15:29	123.8
11/16/2023 15:30	123.8
11/16/2023 15:31	123.8
11/16/2023 15:32	123.8
11/16/2023 15:33	123.7
11/16/2023 15:34	123.8
11/16/2023 15:35	123.8
11/16/2023 15:36	123.8
11/16/2023 15:37	123.8
11/16/2023 15:38	123.7
11/16/2023 15:39	123.7
11/16/2023 15:40	123.8
11/16/2023 15:41	123.7
11/16/2023 15:42	123.8
11/16/2023 15:43	123.7
11/16/2023 15:44	123.7
11/16/2023 15:45	123.7
11/16/2023 15:46	123.8

Holcim Midlothian TX
Line 2 Main Stack
Mill Off Run 1
Date/Time

Clinker
mtpH

11/16/2023 15:47	123.8
11/16/2023 15:48	123.8
11/16/2023 15:49	123.7
11/16/2023 15:50	123.8
11/16/2023 15:51	123.8
11/16/2023 15:52	123.7
11/16/2023 15:53	123.8
11/16/2023 15:54	123.8
11/16/2023 15:55	123.8
11/16/2023 15:56	123.7
11/16/2023 15:57	123.8

Average **123.7551**

Holcim Midlothian TX
Line 2 Main Stack
Mill Off Run 2
Date/Time

Clinker
mtpH

11/16/2023 16:20	123.7
11/16/2023 16:21	123.7
11/16/2023 16:22	123.7
11/16/2023 16:23	123.8
11/16/2023 16:24	123.8
11/16/2023 16:25	123.7
11/16/2023 16:26	123.7
11/16/2023 16:27	123.7
11/16/2023 16:28	123.8
11/16/2023 16:29	123.8
11/16/2023 16:30	123.8
11/16/2023 16:31	123.8
11/16/2023 16:32	123.7
11/16/2023 16:33	123.8
11/16/2023 16:34	123.7
11/16/2023 16:35	123.8
11/16/2023 16:36	123.7
11/16/2023 16:37	123.8
11/16/2023 16:38	123.8
11/16/2023 16:39	123.8
11/16/2023 16:40	123.7
11/16/2023 16:41	123.8
11/16/2023 16:42	123.8
11/16/2023 16:43	123.7
11/16/2023 16:44	123.7
11/16/2023 16:45	123.8
11/16/2023 16:46	123.8
11/16/2023 16:47	123.7
11/16/2023 16:48	123.8
11/16/2023 16:49	123.7
11/16/2023 16:50	123.7
11/16/2023 16:51	123.8
11/16/2023 16:52	123.8
11/16/2023 16:53	123.7
11/16/2023 16:54	123.7
11/16/2023 16:55	123.8
11/16/2023 16:56	123.8
11/16/2023 16:57	123.8
11/16/2023 16:58	123.7
11/16/2023 16:59	123.7
11/16/2023 17:00	123.8
11/16/2023 17:01	123.7
11/16/2023 17:02	123.8

Holcim Midlothian TX
Line 2 Main Stack
Mill Off Run 2
Date/Time

Clinker
mtpg

11/16/2023 17:03	123.7
11/16/2023 17:04	123.7
11/16/2023 17:05	123.8
11/16/2023 17:06	123.7
11/16/2023 17:07	123.7
11/16/2023 17:08	123.7
11/16/2023 17:09	123.8
11/16/2023 17:10	123.8
11/16/2023 17:11	123.8
11/16/2023 17:12	123.8
11/16/2023 17:13	123.7
11/16/2023 17:14	123.8
11/16/2023 17:15	123.8
11/16/2023 17:16	123.8
11/16/2023 17:17	123.8
11/16/2023 17:18	123.8
11/16/2023 17:19	123.8
11/16/2023 17:20	123.7
11/16/2023 17:21	123.8
11/16/2023 17:22	123.7
11/16/2023 17:23	123.7
11/16/2023 17:24	123.7
11/16/2023 17:25	123.8

Average

123.7545

Holcim Midlothian TX
Line 2 Main Stack
Mill Off Run 3
Date/Time

Clinker
mtph

11/16/2023 17:41	123.8
11/16/2023 17:42	123.7
11/16/2023 17:43	123.8
11/16/2023 17:44	123.7
11/16/2023 17:45	123.7
11/16/2023 17:46	123.8
11/16/2023 17:47	123.8
11/16/2023 17:48	123.7
11/16/2023 17:49	123.7
11/16/2023 17:50	123.8
11/16/2023 17:51	123.8
11/16/2023 17:52	123.8
11/16/2023 17:53	123.8
11/16/2023 17:54	123.7
11/16/2023 17:55	123.7
11/16/2023 17:56	123.7
11/16/2023 17:57	123.7
11/16/2023 17:58	123.7
11/16/2023 17:59	123.7
11/16/2023 18:00	123.7
11/16/2023 18:01	123.8
11/16/2023 18:02	123.7
11/16/2023 18:03	123.7
11/16/2023 18:04	123.7
11/16/2023 18:05	123.7
11/16/2023 18:06	123.7
11/16/2023 18:07	123.7
11/16/2023 18:08	123.7
11/16/2023 18:09	123.8
11/16/2023 18:10	123.8
11/16/2023 18:11	123.7
11/16/2023 18:12	123.7
11/16/2023 18:13	123.7
11/16/2023 18:14	123.7
11/16/2023 18:15	123.7
11/16/2023 18:16	123.7
11/16/2023 18:17	123.7
11/16/2023 18:18	123.7
11/16/2023 18:19	123.8
11/16/2023 18:20	123.7
11/16/2023 18:21	123.7
11/16/2023 18:22	123.7
11/16/2023 18:23	123.8

Holcim Midlothian TX
Line 2 Main Stack
Mill Off Run 3
Date/Time

Clinker
mtpH

11/16/2023 18:24	123.7
11/16/2023 18:25	123.7
11/16/2023 18:26	123.7
11/16/2023 18:27	123.7
11/16/2023 18:28	123.7
11/16/2023 18:29	123.8
11/16/2023 18:30	123.7
11/16/2023 18:31	123.7
11/16/2023 18:32	123.7
11/16/2023 18:33	123.7
11/16/2023 18:34	123.7
11/16/2023 18:35	123.7
11/16/2023 18:36	123.7
11/16/2023 18:37	123.7
11/16/2023 18:38	123.7
11/16/2023 18:39	123.7
11/16/2023 18:40	123.7
11/16/2023 18:41	123.7
11/16/2023 18:42	123.7
11/16/2023 18:43	123.7
11/16/2023 18:44	123.7
11/16/2023 18:45	123.7
11/16/2023 18:46	123.7
11/16/2023 18:47	123.7

Average

123.7209

Holcim Midlothian TX
Line 2 Main Stack
Mill On Run 1
Date/Time

Clinker
mtph

11/17/2023 8:06	123.8
11/17/2023 8:07	123.7
11/17/2023 8:08	123.7
11/17/2023 8:09	123.8
11/17/2023 8:10	123.8
11/17/2023 8:11	123.8
11/17/2023 8:12	123.7
11/17/2023 8:13	123.8
11/17/2023 8:14	123.8
11/17/2023 8:15	123.8
11/17/2023 8:16	123.8
11/17/2023 8:17	123.8
11/17/2023 8:18	123.8
11/17/2023 8:19	123.7
11/17/2023 8:20	123.8
11/17/2023 8:21	123.7
11/17/2023 8:22	123.8
11/17/2023 8:23	123.8
11/17/2023 8:24	123.8
11/17/2023 8:25	123.8
11/17/2023 8:26	123.8
11/17/2023 8:27	123.8
11/17/2023 8:28	123.8
11/17/2023 8:29	123.8
11/17/2023 8:30	123.8
11/17/2023 8:31	123.8
11/17/2023 8:32	123.7
11/17/2023 8:33	123.8
11/17/2023 8:34	123.7
11/17/2023 8:35	123.8
11/17/2023 8:36	123.8
11/17/2023 8:37	123.8
11/17/2023 8:38	123.8
11/17/2023 8:39	123.7
11/17/2023 8:40	123.8
11/17/2023 8:41	123.8
11/17/2023 8:42	123.8
11/17/2023 8:43	123.8
11/17/2023 8:44	123.7
11/17/2023 8:45	123.7
11/17/2023 8:46	123.8
11/17/2023 8:47	123.8
11/17/2023 8:48	123.8

Holcim Midlothian TX
Line 2 Main Stack
Mill On Run 1
Date/Time

Clinker
mtph

11/17/2023 8:49	123.7
11/17/2023 8:50	123.8
11/17/2023 8:51	123.7
11/17/2023 8:52	123.8
11/17/2023 8:53	123.8
11/17/2023 8:54	123.7
11/17/2023 8:55	123.8
11/17/2023 8:56	123.8
11/17/2023 8:57	123.8
11/17/2023 8:58	123.8
11/17/2023 8:59	123.7
11/17/2023 9:00	123.8
11/17/2023 9:01	123.8
11/17/2023 9:02	123.8
11/17/2023 9:03	123.8
11/17/2023 9:04	123.8
11/17/2023 9:05	123.7
11/17/2023 9:06	123.8
11/17/2023 9:07	123.8
11/17/2023 9:08	123.7
11/17/2023 9:09	123.8
11/17/2023 9:10	123.8
11/17/2023 9:11	123.8
11/17/2023 9:12	123.7

Average

123.7746

Holcim Midlothian TX
Line 2 Main Stack
Mill On Run 2
Date/Time

Clinker
mtph

11/17/2023 9:30	123.8
11/17/2023 9:31	123.8
11/17/2023 9:32	123.8
11/17/2023 9:33	123.8
11/17/2023 9:34	123.8
11/17/2023 9:35	123.8
11/17/2023 9:36	123.8
11/17/2023 9:37	123.8
11/17/2023 9:38	123.8
11/17/2023 9:39	123.8
11/17/2023 9:40	123.8
11/17/2023 9:41	123.8
11/17/2023 9:42	123.8
11/17/2023 9:43	123.7
11/17/2023 9:44	123.8
11/17/2023 9:45	123.8
11/17/2023 9:46	123.8
11/17/2023 9:47	123.8
11/17/2023 9:48	123.8
11/17/2023 9:49	123.7
11/17/2023 9:50	123.7
11/17/2023 9:51	123.8
11/17/2023 9:52	123.7
11/17/2023 9:53	123.8
11/17/2023 9:54	123.8
11/17/2023 9:55	123.8
11/17/2023 9:56	123.8
11/17/2023 9:57	123.8
11/17/2023 9:58	123.7
11/17/2023 9:59	123.7
11/17/2023 10:00	123.8
11/17/2023 10:01	123.8
11/17/2023 10:02	123.8
11/17/2023 10:03	123.8
11/17/2023 10:04	123.8
11/17/2023 10:05	123.8
11/17/2023 10:06	123.8
11/17/2023 10:07	123.7
11/17/2023 10:08	123.8
11/17/2023 10:09	123.8
11/17/2023 10:10	123.8
11/17/2023 10:11	123.8
11/17/2023 10:12	123.8

Holcim Midlothian TX
Line 2 Main Stack
Mill On Run 2
Date/Time

Clinker
mtpg

11/17/2023 10:13	123.7
11/17/2023 10:14	123.8
11/17/2023 10:15	123.8
11/17/2023 10:16	123.8
11/17/2023 10:17	123.8
11/17/2023 10:18	123.8
11/17/2023 10:19	123.8
11/17/2023 10:20	123.8
11/17/2023 10:21	123.8
11/17/2023 10:22	123.8
11/17/2023 10:23	123.8
11/17/2023 10:24	123.8
11/17/2023 10:25	123.8
11/17/2023 10:26	123.8
11/17/2023 10:27	123.7
11/17/2023 10:28	123.8
11/17/2023 10:29	123.7
11/17/2023 10:30	123.8
11/17/2023 10:31	123.7
11/17/2023 10:32	123.8
11/17/2023 10:33	123.8
11/17/2023 10:34	123.8
11/17/2023 10:35	123.8
11/17/2023 10:36	123.7

Average

123.7821

Holcim Midlothian TX
Line 2 Main Stack
Mill On Run 3
Date/Time

Clinker
mtph

11/17/2023 10:58	123.8
11/17/2023 10:59	123.8
11/17/2023 11:00	123.8
11/17/2023 11:01	123.8
11/17/2023 11:02	123.8
11/17/2023 11:03	123.8
11/17/2023 11:04	123.8
11/17/2023 11:05	123.8
11/17/2023 11:06	123.8
11/17/2023 11:07	123.7
11/17/2023 11:08	123.8
11/17/2023 11:09	123.7
11/17/2023 11:10	123.7
11/17/2023 11:11	123.8
11/17/2023 11:12	123.7
11/17/2023 11:13	123.8
11/17/2023 11:14	123.8
11/17/2023 11:15	123.7
11/17/2023 11:16	123.8
11/17/2023 11:17	123.7
11/17/2023 11:18	123.7
11/17/2023 11:19	123.7
11/17/2023 11:20	123.7
11/17/2023 11:21	123.7
11/17/2023 11:22	123.8
11/17/2023 11:23	123.8
11/17/2023 11:24	123.8
11/17/2023 11:25	123.7
11/17/2023 11:26	123.8
11/17/2023 11:27	123.8
11/17/2023 11:28	123.7
11/17/2023 11:29	123.8
11/17/2023 11:30	123.7
11/17/2023 11:31	123.8
11/17/2023 11:32	123.8
11/17/2023 11:33	123.8
11/17/2023 11:34	123.7
11/17/2023 11:35	123.8
11/17/2023 11:36	123.7
11/17/2023 11:37	123.7
11/17/2023 11:38	123.8
11/17/2023 11:39	123.8
11/17/2023 11:40	123.8

Holcim Midlothian TX
Line 2 Main Stack
Mill On Run 3
Date/Time







Clinker
mtp/h

11/17/2023 11:41	123.8
11/17/2023 11:42	123.7
11/17/2023 11:43	123.7
11/17/2023 11:44	123.7
11/17/2023 11:45	123.7
11/17/2023 11:46	123.8
11/17/2023 11:47	123.8
11/17/2023 11:48	123.8
11/17/2023 11:49	123.8
11/17/2023 11:50	123.8
11/17/2023 11:51	123.7
11/17/2023 11:52	123.8
11/17/2023 11:53	123.8
11/17/2023 11:54	123.8
11/17/2023 11:55	123.8
11/17/2023 11:56	123.8
11/17/2023 11:57	123.7
11/17/2023 11:58	123.8
11/17/2023 11:59	123.8
11/17/2023 12:00	123.8
11/17/2023 12:01	123.8
11/17/2023 12:02	123.7
11/17/2023 12:03	123.7
11/17/2023 12:04	123.7

Average 123.7627

Appendix E
Calibration Documents

Pitot Tube Inspection Sheet



Date	01/03/23
Tube Assembly Level?	Yes
Ports Damaged?	No
-10 deg < a1 < +10 deg	2
-10 deg < a2 < +10 deg	1
-5 deg < B1 < +5 deg	1
-5 deg < B2 < +5 deg	1
Y (gamma)	1
θ (theta)	1
A (alpha)	0.951
Z = A (sin γ) < 0.125"?	yes
W = A (sin θ) < 0.031"?	yes
Pa =	0.475
Pb =	0.476
Tube Diameter (Dt) =	0.376
Pa = Pb +/- 0.063"?	yes
(1.05 x Dt)?	0.3948
(1.50 x Dt)?	0.564
(1.05 x Dt) < P < (1.50 x Dt)?	yes
Eligible for Default Pitot Calibration Factor (Cp = 0.84)?	Yes

Thermocouple Calibration

Type of Reference Thermometer?	Mercury	Date	01/03/23
Barometric Pressure?	29.52	Ambient Temperature?	68

Source	Reference Temp, F	Thermocouple Temp, F	Absolute Temp Difference
cold air	37	38	-0.20%
medium air	215	215	0.00%
hot air	325	325	0.00%


Windtunnel Calibration

Pitot Reading	Reference (0.99)	5A S-Type Pitot	Cp
ΔP ₁	0.31	0.44	0.84
ΔP ₂	0.31	0.43	0.85
ΔP ₃	0.31	0.43	0.85
Average Pitot Tube Calibration Factor-->			0.85

Thermocouple Calibration Check (EPA ALT-011 Procedure), performed on 1/3/23

Source	Ref. Temp. F	Thermocouple Temp. F	± 2 deg F?
Ambient	68	66.9	Yes

Pitot Tube Inspection Sheet



Date	12/19/22
Tube Assembly Level?	Yes
Ports Damaged?	No
-10 deg < a1 < +10 deg	1
-10 deg < a2 < +10 deg	1
-5 deg < B1 < +5 deg	2
-5 deg < B2 < +5 deg	1
Y (gamma)	1
0 (theta)	1
A (alpha)	0.997
Z = A (sin y) < 0.125"?	yes
W = A (sin 0) < 0.031"?	yes
Pa =	0.499
Pb =	0.498
Tube Diameter (Dt) =	0.377
Pa = Pb +/- 0.063"?	yes
(1.05 x Dt)?	0.39585
(1.50 x Dt)?	0.5655
(1.05 x Dt) < P < (1.50 x Dt)?	yes
Eligible for Default Pitot Calibration Factor (Cp = 0.84)?	Yes

Thermocouple Calibration

Type of Reference Thermometer?	Mercury	Date	12/19/22
Barometric Pressure?	30.19	Ambient Temperature?	68.3

Source	Reference Temp, F	Thermocouple Temp, F	Absolute Temp Difference
Ice Bath	36	37	-0.20%
Hot Water	215	215	0.00%
Hot Oil	325	324	0.13%


Windtunnel Calibration

Pitot Reading	Reference (0.99)	8H S-Type Pitot	Cp
ΔP1	0.54	0.81	0.82
ΔP2	0.54	0.8	0.82
ΔP3	0.55	0.79	0.83
Average Pitot Tube Calibration Factor-->			0.82

Thermocouple Calibration Check (EPA ALT-011 Procedure), performed on 12/19/22

Source	Ref. Temp. F	Thermocouple Temp. F	± 2 deg F?
Ambient	68.3	68.9	Yes

Pitot Tube Inspection Sheet



Date	12/19/22
Tube Assembly Level?	Yes
Ports Damaged?	No
-10 deg < a1 < +10 deg	1
-10 deg < a2 < +10 deg	1
-5 deg < B1 < +5 deg	1
-5 deg < B2 < +5 deg	1
Y (gamma)	1
0 (theta)	1
A (alpha)	0.932
Z = A (sin y) < 0.125"?	yes
W = A (sin 0) < 0.031"?	yes
Pa =	0.466
Pb =	0.466
Tube Diameter (Dt) =	0.377
Pa = Pb +/- 0.063"?	yes
(1.05 x Dt)?	0.39585
(1.50 x Dt)?	0.5655
(1.05 x Dt) < P < (1.50 x Dt)?	yes
Eligible for Default Pitot Calibration Factor (Cp = 0.84)?	Yes

Thermocouple Calibration

Type of Reference Thermometer?	Mercury	Date	12/19/22
Barometric Pressure?	30.18	Ambient Temperature?	69

Source	Reference Temp, F	Thermocouple Temp, F	Absolute Temp Difference
cold air	37	38	-0.20%
medium air	215	214	0.15%
hot air	325	323	0.25%

Windtunnel Calibration

Pitot Reading	Reference (0.99)	8M S-Type Pitot	Cp
ΔP ₁	0.31	0.44	0.84
ΔP ₂	0.32	0.43	0.86
ΔP ₃	0.31	0.44	0.84
Average Pitot Tube Calibration Factor-->			0.85

Thermocouple Calibration Check (EPA ALT-011 Procedure), performed on 12/19/22

Source	Ref. Temp. F	Thermocouple Temp. F	± 2 deg F?
Ambient	69	68.1	Yes



METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)		NET (V _m)	TEMPERATURES °F						ELAPSED TIME (MIN)	DGM ΔH (in H ₂ O)	V _m (STD)	V _c (STD)	Y (%)	VARIATION (%)	ΔH _g
				INITIAL	FINAL		AMBIENT	DGM INLET INITIAL	DGM INLET FINAL	DGM OUTLET INITIAL	DGM OUTLET FINAL	DGM AVG							
12	1	0.3283				0.000													
	2					0.000													
	3					0.000													
15	1	0.4094	18	353.924	359.213	5.289	75	62	65	62	62	62	10.00	0.8	5.3733	5.3168	0.989		1.62
	2	0.4094	18	359.213	364.553	5.340	76	65	66	62	63	63	10.00	0.8	5.4122	5.3119	0.981		1.62
	3					0.000													
19	1	0.5047	18	364.553	371.213	6.660	76	66	70	63	65	65	10.00	1.3	6.7325	6.5483	0.973		1.72
	2	0.5047	18	371.213	377.910	6.697	76	70	72	65	66	66	10.00	1.3	6.7411	6.5483	0.971		1.72
	3					0.000													
23	1	0.6426	18	377.910	386.465	8.555	77	70	74	66	68	68	10.00	2.1	8.6078	8.3298	0.968		1.71
	2	0.6426	18	386.465	395.066	8.601	77	74	75	68	69	69	10.00	2.1	8.6215	8.3298	0.966		1.71
	3					0.000													
32	1	0.8587				0.000													
	2					0.000													
	3					0.000													

DATE: 12/28/21
METER PART #: M5-15
METER SERIAL #: M5-15
CRITICAL ORIFICE SET SERIAL #: 14315

INITIAL: 30.03
FINAL: 30.03
AVG (P_{bar}): 30.03

BAROMETRIC PRESSURE (in Hg):
INITIAL: 30.03
FINAL: 30.03
AVG (P_{bar}): 30.03

IF Y VARIATION EXCEEDS 2.00%,
ORIFICE SHOULD BE RECALIBRATED

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_c (std), and the DGM calibration factor, Y. These equations are automatically calculated in the

$$(1) V_{m, std} = K_1 * V_m * \frac{P_{bar} + (\Delta H / 13.6)}{T_m}$$

$$(2) V_{c, std} = K' * \frac{P_{bar} * \theta}{\sqrt{T_{amb}}}$$

$$(3) Y = \frac{V_{c, std}}{V_{m, std}} = \text{DGM calibration factor}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions

K₁ = 17.64 °F/(in. Hg (English), 0.3858 °K/(mm Hg (Metric))

T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

= Volume of gas sample passed through the critical orifice, corrected to standard conditions

T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)

K' = Average K' factor from Critical Orifice Calibration

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **0.975**

AVERAGE ΔH_g = **1.68**

Potentiometer Check, °F
(per manufacturer procedure)
@ 0 F: 0
@ 500 F: 496
@ 1000 F: 1000

Avg Absolute Difference = **0.1%**

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

DATE:	12/09/22	METER SERIAL #:	m5-22	INITIAL BAROMETRIC PRESSURE (in Hg):	30.01	FINAL BAROMETRIC PRESSURE (in Hg):	29.99	AVG (P _{bar}):	30
METER PART #:	m5-22	CRITICAL ORIFICE SET SERIAL #:	1431S	IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED					

ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)		TEMPERATURES °F						ELAPSED TIME (MIN)	DGM ΔH (in H ₂ O)	V _m (STD)	V _{cr} (STD)	(3) Y	VARIATION (%)	ΔH ₀	
				INITIAL	FINAL	AMBIENT	DGM INLET	DGM INLET	DGM INLET	DGM OUTLET	DGM OUTLET								DGM OUTLET
12	1	0.3283																	
	2																		
	3																		
15	1	0.4094	18	944.228	949.609	67	66	68	66	66	66	66	10.00	0.9	5.4237	5.3517	0.987	1.78	
	2	0.4094	18	949.609	954.959	67	68	71	66	67	67	10.00	0.9	5.4073	5.3517	0.990	1.78		
	3																		
19	1	0.5047	18	955.204	961.820	67	71	73	73	68	68	10.00	1.3	6.6153	6.5975	0.997	1.68		
	2	0.5047	18	961.820	968.443	67	72	74	68	69	70.75	10.00	1.3	6.6286	6.5975	0.995	1.68		
	3	0.5047									0								
23	1	0.6426	17	969.005	977.347	67	72	75	69	70	71.5	10.00	2.2	8.3556	8.4001	1.005	1.76		
	2	0.6426	17	978.606	986.992	67	69	70	69	69	69.25	10.00	2.2	8.4354	8.4001	0.996	1.76		
	3										0								
32	1	0.8587																	
	2																		
	3																		

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:
 The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated

(1)
$$V_{m, std} = K' * V_m * \frac{P_{bar} + (\Delta H / 13.6)}{T_m}$$

(2)
$$V_{cr, std} = K' * \frac{P_{bar} * \theta}{\sqrt{T_{amb}}}$$

(3)
$$Y = \frac{V_{cr, std}}{V_{m, std}}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions
 K₁ = 17.64 °F/in. Hg (English), 0.3858 °K/mm Hg (Metric)
 T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

= Volume of gas sample passed through the critical orifice, corrected to standard conditions
 T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)
 K' = Average K' factor from Critical Orifice Calibration

= DGM calibration factor

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **0.995**

AVERAGE ΔH₀ = **1.74**

Potentiometer Check, °F
 @ 0 F
 @ 500 F
 @ 1000 F

Avg Absolute Difference = **0.1%**

Company: Holcim; Midlothian TX
 Source: Line 2 Main Stack; Raw Mill On
 Job ID: 23-3313
 Train Type: EPA Method 26A

Alt-009 Alternate Post Test Calibration Data	M5-15 4A	M5-22 4B	M5-15 5A	M5-22 5B	M5-15 6A	M5-22 6B	M5-15 Average	M5-22 Average
	11/17/23 806-912	11/17/23 806-912	11/17/23 930-1036	11/17/23 930-1036	11/17/23 1058-1204	11/17/23 1058-1204		

Vm	50.384	46.071	51.721	47.29	50.81	47.846		
Tm	524.3	521.9	526.2	523.5	528	527.3		
Pb	28.7	28.7	28.7	28.7	28.7	28.7		
Havg	2.21	2.15	2.28	2.22	2.23	2.16		
H@	1.68	1.72	1.68	1.72	1.68	1.72		
Md	30.368	30.368	30.38	30.38	30.396	30.396		
(Havg)*0.5	1.4856936	1.46605629	1.51095943	1.48873171	1.49118973	1.46883424		
Run Time, Min	60	60	60	60	60	60		

Calculated Gamma (Yqa)	1.015	1.081	1.008	1.070	1.014	1.047	1.012	1.066
Meter Gamma	0.975	1.014	0.975	1.014	0.975	1.014	0.975	1.014
% difference from Actual Y	4.1%	6.6%	3.3%	5.6%	4.0%	3.3%	3.8%	5.1%

Company: Holcim; Midlothian TX
 Source: Line 2 Main Stack; Raw Mill On
 Job ID: 23-3313
 Train Type: EPA Method 26A

Alt-009 Alternate Post Test Calibration Data	M5-15 4A 11/17/23 806-912	M5-22 4B 11/17/23 806-912	M5-15 5A 11/17/23 930-1036	M5-22 5B 11/17/23 930-1036	M5-15 6A 11/17/23 1058-1204	M5-22 6B 11/17/23 1058-1204	M5-15 Average	M5-22 Average
Vm	50.384	46.071	51.721	47.29	50.81	47.846		
Tm	524.3	521.9	526.2	523.5	528	527.3		
Pb	28.7	28.7	28.7	28.7	28.7	28.7		
Havg	2.21	2.15	2.28	2.22	2.23	2.16		
H@	1.68	1.72	1.68	1.72	1.68	1.72		
Md	30.368	30.368	30.38	30.38	30.396	30.396		
(Havg)*0.5	1.4856936	1.46605629	1.51095943	1.48873171	1.49118973	1.46883424		
Run Time, Min	60	60	60	60	60	60		
Calculated Gamma (Yqa)	1.015	1.081	1.008	1.070	1.014	1.047	1.012	1.066
Meter Gamma	0.975	1.014	0.975	1.014	0.975	1.014	0.975	1.014
% difference from Actual Y	4.1%	6.6%	3.3%	5.6%	4.0%	3.3%	3.8%	5.1%

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E04NI77E15A3796	Reference Number:	122-402389886-1A
Cylinder Number:	CC194988	Cylinder Volume:	151.0 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22022	Valve Outlet:	590
Gas Code:	CO,CO2,O2,BALN	Certification Date:	Mar 30, 2022

Expiration Date: Mar 30, 2030

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.


Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	65.00 PPM	63.33 PPM	G1	+/- 0.7% NIST Traceable	03/30/2022
CARBON DIOXIDE	10.00 %	10.16 %	G1	+/- 0.8% NIST Traceable	03/29/2022
OXYGEN	12.00 %	11.95 %	G1	+/- 0.4% NIST Traceable	03/29/2022
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	09010213	KAL004779	98.48 PPM CARBON MONOXIDE/NITROGEN	+/- 0.5%	Oct 16, 2024
NTRM	19060402	6162642Y	11.105 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Dec 04, 2025
NTRM	10010616	K014963	9.967 % OXYGEN/NITROGEN	+/- 0.3%	Apr 19, 2022

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VA-5001 CO2 BF89GV17	Nondispersive Infrared (NDIR)	Mar 01, 2022
Horiba VIA510 CO 1G46EA07	Nondispersive Infrared (NDIR)	Mar 09, 2022
Siemens Oxymat 61 M3299 O2	Paramagnetic	Mar 01, 2022

Triad Data Available Upon Request



Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E04NI59E15A38X3 Reference Number: 122-124583867-1
 Cylinder Number: CC427971 Cylinder Volume: 158.2 CF
 Laboratory: 124 - Durham - NC Cylinder Pressure: 2015 PSIG
 PGVP Number: B22016 Valve Outlet: 590
 Gas Code: CO,CO2,O2,BALN Certification Date: Oct 25, 2016

Expiration Date: Oct 25, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	120.0 PPM	119.3 PPM	G1	+/- 0.6% NIST Traceable	10/25/2016
CARBON DIOXIDE	18.00 %	18.18 %	G1	+/- 0.6% NIST Traceable	10/25/2016
OXYGEN	22.00 %	22.06 %	G1	+/- 0.3% NIST Traceable	10/25/2016
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	14060333	CC432495	252.5 PPM CARBON MONOXIDE/NITROGEN	+/- 0.3%	Feb 21, 2020
NTRM	12061551	CC354889	19.87 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 27, 2018
NTRM	12062003	CC367399	22.883 % OXYGEN/NITROGEN	+/- 0.2%	Apr 24, 2018

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA510 CO2 2L6YXWY0	Nondispersive infrared (NDIR)	Oct 13, 2016
Horiba VIA510 CO RS2EGL6K	Nondispersive infrared (NDIR)	Oct 13, 2016
Horiba MPA510 O2 41499150042	Paramagnetic	Oct 13, 2016

Triad Data Available Upon Request



[Signature]
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: CERTIFIED STANDARD-SPEC

Part Number:	X02NI99C15A54F5	Reference Number:	122-402705571-1
Cylinder Number:	CC426155	Cylinder Volume:	144.0 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
Analysis Date:	Mar 28, 2023	Valve Outlet:	350
Lot Number:	122-402705571-1		

Expiration Date: Mar 28, 2031

Product composition verified by direct comparison to calibration standards traceable to N.I.S.T. weights and/or N.I.S.T. Gas Mixture reference materials.

ANALYTICAL RESULTS

Component	Req Conc	Actual Concentration (Mole %)	Analytical Uncertainty
ETHYLENE	75.00 PPM	75.47 PPM	+/- 2%
NITROGEN	Balance		



J. K. [Signature]
Approved for Release



an Air Liquide company

TESAY LABORATORY

CERTIFICATE OF ACCURACY: GMACS-c Calibration Standard

CUSTOMER INFORMATION

AIRGAS SPECIALTY GASES
Exploratory Products Group
6141 Easton Road
Plumsteadville, PA 18949

Work Order #: 160-402845895-1
Sales Order #: 1123601913
PO #: 7100179560

Customer: DEECO Inc.
Address 1: 3404 Lake Woodard Road
Address 2:
City / State / Zip: Raleigh, NC 27604

PRODUCT INFORMATION

Table with 4 columns: COMPOSITION, CONCENTRATION, UNCERTAINTY (Abs), UNCERTAINTY (Rel). Rows include Hydrogen Cyanide, Sulfur Hexafluoride, and Nitrogen.

CYLINDER #: CC768233
CYLINDER TYPE: 150A Aluminum
CGA: 350 SS
CYLINDER PRESSURE: 2000 psig
AIRGAS PART #: X03N199C15AC0Y6
CERTIFICATION DATE: 8-Sep-2023
EXPIRATION DATE: 8-Mar-2024
MIXTURE DEW POINT: N/A

CERTIFICATION DATA

BLENDING PROCESS: GravStat™ Gravimetry

Table with 4 columns: COMPONENT, CONCENTRATION, UNCERTAINTY (Abs), UNCERTAINTY (Rel). Rows include Hydrogen Cyanide and Sulfur Hexafluoride.

CONFIRMING ANALYSIS: FTIR Spectroscopy
INSTRUMENT / MODEL: CAI Model 700 FTIR

Table with 4 columns: COMPONENT, CONCENTRATION, UNCERTAINTY (Abs), UNCERTAINTY (Rel). Row includes Hydrogen Cyanide.

REFERENCE STANDARD: GMPS-c 200 PPM Hydrogen Cyanide
CYLINDER NUMBER: CC768217
EXPIRATION DATE: 2/27/2024

Table with 4 columns: COMPONENT, CONCENTRATION, UNCERTAINTY (Abs), UNCERTAINTY (Rel). Row includes Hydrogen Cyanide.

Table with 6 columns: CALIBRATION CURVE DATA, Curve Order, Correlation, Slope (X2), Slope (X), Intercept. Row includes Point-to-Point Matching Std.

INTERLOCK STATISTICS

Table with 4 columns: CONCENTRATION, UNCERTAINTY (Abs), UNCERTAINTY (Rel). Rows include BLEND RESULT, ANALYSIS RESULT, INTERLOCK RESULT.

COMMENTS / SPECIAL INSTRUCTIONS

- 1. A GMACS-c ("Candidate GMACS") is made and certified according to the EPA GMACS Procedure (Alt-114) found at: https://cfpub.epa.gov
2. Do not use this standard if pressure is less than 200 psig.
3. Do not use or store this product at or below the stated dew point.

APPROVED BY: [Signature]

BOB GRASMEDER



an Air Liquide company

ANALYSIS LABORATORY

CERTIFICATE OF ACCURACY: *GMACS-c Calibration Standard*

CUSTOMER INFORMATION

AIRGAS SPECIALTY GASES
Exploratory Products Group
6141 Easton Road
Plumsteadville, PA 18949

Work Order #: 160-402845897-1
Sales Order #: 1123601913
PO #: 7100179560

Customer: DEECO Inc.
Address 1: 3404 Lake Woodard Road
Address 2:
City / State / Zip: Raleigh, NC 27604

PRODUCT INFORMATION

COMPOSITION	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	49.9 PPM	2.3 PPM	4.6 %
Sulfur Hexafluoride	5.0 PPM	0.07 PPM	1.3 %
Nitrogen	Balance		

<u>CYLINDER #:</u>	CC768222	<u>AIRGAS PART #:</u>	X03NI99C15AC0W8
<u>CYLINDER TYPE:</u>	150A Aluminum	<u>CERTIFICATION DATE:</u>	7-Sep-2023
<u>CGA:</u>	350 SS	<u>EXPIRATION DATE:</u>	7-Mar-2024
<u>CYLINDER PRESSURE:</u>	2000 psig	<u>MIXTURE DEW POINT:</u>	N/A

CERTIFICATION DATA

BLENDED PROCESS: GravStat™ Gravimetry

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	50.02 PPM	0.9 PPM	1.8 %
Sulfur Hexafluoride	5.02 PPM	0.07 PPM	1.3 %

CONFIRMING ANALYSIS: FTIR Spectroscopy

INSTRUMENT / MODEL: CAI Model 700 FTIR

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	49.8 PPM	2.1 PPM	4.2 %

REFERENCE STANDARD: GMPS-c 50 PPM Hydrogen Cyanide

CYLINDER NUMBER: CC768196

EXPIRATION DATE: 2/29/2024

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	48.9 PPM	1.7 PPM	3.4 %

CALIBRATION CURVE DATA

	Curve Order	Correlation	Slope (X2)	Slope (X)	Intercept
Point-to-Point Matching Std	Linear / Direct Ratio	N/A	N/A	N/A	N/A

INTERLOCK STATISTICS

	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
<u>BLEND RESULT:</u>	50.02 PPM	0.9 PPM	1.8 %
<u>ANALYSIS RESULT:</u>	49.8 PPM	2.1 PPM	4.2 %
<u>INTERLOCK RESULT:</u>	49.9 PPM	2.3 PPM	4.6 %

COMMENTS / SPECIAL INSTRUCTIONS

1. A GMACS-c ("Candidate GMACS") is made and certified according to the EPA GMACS Procedure (Alt-114) found at: <https://cfpub.epa.gov>

2. Do not use this standard if pressure is less than 200 psig.
3. Do not use or store this product at or below the stated dew point.

APPROVED BY: _____

BOB GRASMEDER

Client: Holcim Midlothian

Test Location: Line 1 Main Stack Stratification Check

Date: Nov 15 23 Start Time: 09:00:18

Run number 1

One Minute Averages

	Reference Out O2 %,wet	Plant Out O2 %,wet
9:01:16 AM	12.6	11.6
9:02:16 AM	12.7	11.6
9:03:16 AM	12.7	11.6
9:04:16 AM	12.6	11.6
9:05:16 AM	12.7	11.6
9:06:16 AM	12.7	11.6
Point 1	12.7	11.6
9:07:16 AM	12.6	11.6
9:08:16 AM	12.7	11.5
9:09:16 AM	12.6	11.5
9:10:16 AM	12.7	11.4
9:11:16 AM	12.7	11.5
9:12:16 AM	12.6	11.5
Point 2	12.6	11.5
9:13:16 AM	12.6	11.4
9:14:16 AM	12.6	11.4
9:15:16 AM	12.6	11.5
9:16:16 AM	12.6	11.5
9:17:16 AM	12.6	11.4
9:18:16 AM	12.7	11.5
Point 3	12.6	11.4
All Points	12.6	11.5

Run #	Date/Time	O2_RAW (PCT)
RM On 1	11/15/2023 9:00	11.60
	11/15/2023 9:01	11.60
	11/15/2023 9:02	11.60
	11/15/2023 9:03	11.60
	11/15/2023 9:04	11.60
	11/15/2023 9:05	11.60
		11.60
	11/15/2023 9:06	11.55
	11/15/2023 9:07	11.50
	11/15/2023 9:08	11.47
	11/15/2023 9:09	11.40
	11/15/2023 9:10	11.50
	11/15/2023 9:11	11.45
		11.48
	11/15/2023 9:12	11.40
	11/15/2023 9:13	11.40
	11/15/2023 9:14	11.47
	11/15/2023 9:15	11.50
	11/15/2023 9:16	11.40
	11/15/2023 9:17	11.48
		11.44

Client: Holcim Midlothian
Test Location: Line 2 Main Stack Stratification Check
Date: Nov 16 23 Start Time: 14:20:22
Run number 1

One Minute Averages

	Reference Out O2 %,wet	Plant Out O2 %,wet
2:21:20 PM	11.0	9.9
2:22:20 PM	11.0	9.9
2:23:20 PM	10.9	9.8
2:24:20 PM	10.9	9.8
2:25:20 PM	10.9	9.8
2:26:20 PM	10.8	9.7
Point 1	10.9	9.8
2:27:20 PM	10.9	9.7
2:28:20 PM	10.9	9.8
2:29:20 PM	10.9	9.8
2:30:20 PM	10.9	9.8
2:31:20 PM	10.9	9.8
2:32:20 PM	10.9	9.8
Point 2	10.9	9.8
2:33:20 PM	10.9	9.8
2:34:20 PM	10.9	9.8
2:35:20 PM	10.8	9.7
2:36:20 PM	10.8	9.6
2:37:20 PM	10.8	9.6
2:38:20 PM	10.8	9.7
Point 3	10.8	9.7
All Points	10.9	9.8

Run #	Date/Time	O2_RAW (PCT)
RM Off 1	11/16/2023 14:20	9.9
	11/16/2023 14:21	9.9
	11/16/2023 14:22	9.8
	11/16/2023 14:23	9.8
	11/16/2023 14:24	9.8
	11/16/2023 14:25	9.7
		9.8
	11/16/2023 14:26	9.7
	11/16/2023 14:27	9.8
	11/16/2023 14:28	9.8
	11/16/2023 14:29	9.8
	11/16/2023 14:30	9.8
	11/16/2023 14:31	9.8
		9.8
	11/16/2023 14:32	9.8
	11/16/2023 14:33	9.8
	11/16/2023 14:34	9.7
	11/16/2023 14:35	9.6
	11/16/2023 14:36	9.6
	11/16/2023 14:37	9.7
		9.7

Holcim Midlothian TX
Line 1 Main Stack
Pretest

Spectrum	Date	Time	HCN PCA 191c R1 191c	SF6 (10) 191C	Ethylene (100,3000) 191C	HF ppm (10) 191C	SNR 2500	sBeam @ 2500
SPC_000830BKGLAB	11/14/23	06:57:22.688	0.000	0.000	0.000	0.000	NaN	1.41
SPC_000831.LAB	11/14/23	06:58:33.020	-0.004	-0.001	-0.037	0.011	6779.16	1.42
SPC_000832BKGLAB	11/14/23	07:01:13.650	0.000	0.000	0.000	0.000	5363.34	1.42
SPC_000833.LAB	11/14/23	07:02:24.028	-0.064	0.003	-0.062	0.018	5553.53	1.42
SPC_000834.LAB	11/14/23	07:03:28.036	-0.154	-0.000	0.013	0.007	4837.84	1.42
SPC_000835.LAB	11/14/23	07:04:32.104	0.035	0.000	-0.014	0.003	5479.59	1.42
SPC_000836BKGLAB	11/14/23	07:07:39.052	0.000	0.000	0.000	0.000	5734.58	1.42
SPC_000837.LAB	11/14/23	07:08:49.639	-0.051	-0.001	-0.019	-0.002	6223.51	1.42
SPC_000838.LAB	11/14/23	07:09:53.338	-0.032	-0.003	0.027	-0.000	5809.30	1.42
SPC_000839.LAB	11/14/23	07:10:57.234	0.046	-0.000	-0.014	-0.017	3759.60	1.42
SPC_000840.LAB	11/14/23	07:12:01.138	-0.011	-0.001	-0.102	0.016	4373.66	1.42
SPC_000841.LAB	11/14/23	07:13:05.164	0.080	-0.001	-0.068	0.002	5347.95	1.42
SPC_000842.LAB	11/14/23	07:14:08.941	0.059	-0.001	-0.051	-0.012	5012.46	1.42
SPC_000843.LAB	11/14/23	07:15:12.843	-0.029	-0.002	-0.084	-0.006	4706.13	1.42
Standard Deviation x 3			0.156			0.032	5033.23	1.42
Averages								
SPC_000844.LAB	11/14/23	07:16:16.794	-0.021	-0.000	-0.077	-0.004	6290.82	1.42
SPC_000845.LAB	11/14/23	07:17:20.692	-0.021	-0.003	-0.037	-0.004	5389.04	1.42
SPC_000846.LAB	11/14/23	07:18:24.552	0.032	-0.002	-0.038	0.008	4608.29	1.42
SPC_000847.LAB	11/14/23	07:19:28.498	-0.103	-0.000	-0.020	0.146	2080.90	1.43
SPC_000848.LAB	11/14/23	07:20:32.403	0.008	-0.001	-0.030	0.183	4977.24	1.43
SPC_000849.LAB	11/14/23	07:21:36.307	0.024	-0.000	-0.049	0.176	5158.81	1.43
SPC_000850.LAB	11/14/23	07:22:40.172	0.035	-0.000	0.044	0.166	4584.91	1.43
SPC_000851.LAB	11/14/23	07:23:44.070	0.009	-0.002	-0.013	0.168	5909.94	1.43
SPC_000852.LAB	11/14/23	07:24:47.972	-0.067	-0.001	-0.038	0.134	5322.62	1.43
SPC_000853.LAB	11/14/23	07:25:51.884	-0.076	-0.001	0.026	0.133	5540.25	1.43
SPC_000854.LAB	11/14/23	07:26:55.782	-0.001	-0.001	-0.091	0.131	4881.68	1.44
SPC_000855.LAB	11/14/23	07:27:59.687	-0.132	-0.005	7.468	0.085	4631.16	1.44
SPC_000856.LAB	11/14/23	07:29:03.632	-0.142	-0.015	73.818	-0.003	2487.00	1.43
SPC_000857.LAB	11/14/23	07:30:07.496	-0.062	-0.018	74.279	0.001	5889.41	1.44
SPC_000858.LAB	11/14/23	07:31:11.532	0.002	-0.015	74.370	-0.008	4902.75	1.44
SPC_000859.LAB	11/14/23	07:32:15.429	-0.091	-0.016	74.324	-0.009	4849.05	1.44
Ethylene Calibration Transfer Standard (CC426155; 75.47 ppm)					74.347			
SPC_000860.LAB	11/14/23	07:33:19.559	31.836	1.437	60.617	-0.009	4168.31	1.44
SPC_000861.LAB	11/14/23	07:34:23.304	195.710	9.574	-0.380	-0.007	5189.57	1.44
SPC_000862.LAB	11/14/23	07:35:27.022	197.438	9.591	-0.600	-0.007	5751.27	1.44
SPC_000863.LAB	11/14/23	07:36:30.920	198.229	9.604	-0.593	-0.017	4465.20	1.44
SPC_000864.LAB	11/14/23	07:37:34.823	198.420	9.612	-0.633	-0.015	4680.81	1.44
SPC_000865.LAB	11/14/23	07:38:38.735	198.660	9.607	-0.858	-0.014	5762.01	1.44
SPC_000866.LAB	11/14/23	07:39:42.746	197.517	9.607	-0.716	-0.009	6188.63	1.44
HCN Standard (CC768233; 199.1 ppm HCN/10.0 ppm SF6)			198.206	9.607				
SPC_000867.LAB	11/14/23	07:40:46.540	196.505	9.583	-0.770	-0.010	6366.58	1.45
SPC_000868.LAB	11/14/23	07:41:50.451	195.447	9.568	-0.702	-0.017	5378.22	1.45
SPC_000869.LAB	11/14/23	07:42:54.353	194.795	9.553	-0.591	-0.019	4306.69	1.45
SPC_000870.LAB	11/14/23	07:43:58.396	94.284	6.180	0.480	-0.011	4883.53	1.45
SPC_000871.LAB	11/14/23	07:45:02.215	49.766	4.874	-0.443	-0.009	4772.89	1.45
SPC_000872.LAB	11/14/23	07:46:06.113	49.731	4.868	-0.442	-0.014	5065.20	1.46
SPC_000873.LAB	11/14/23	07:47:09.981	49.829	4.863	-0.380	-0.005	6907.94	1.46
SPC_000874.LAB	11/14/23	07:48:13.893	49.908	4.862	-0.391	-0.016	5781.74	1.46
SPC_000875.LAB	11/14/23	07:49:18.003	49.854	4.858	-0.423	-0.020	5412.05	1.46
SPC_000876.LAB	11/14/23	07:50:21.705	49.896	4.862	-0.380	-0.004	6539.68	1.46
HCN Standard (CC768222; 49.9 ppm HCN/5.0 ppm SF6)			49.872	4.861				

Analysis Validation Report

Sample Filename: F:\Midlothian on Rental\November 15\SPC_001501.LAB

Filename for noise: F:\Midlothian on Rental\November 14\SPC_000837.LAB
 Interferences Filenames: C:\Midlothian on Rental\November 15\SPC_001464.LAB
 C:\Midlothian on Rental\November 15\SPC_001465.LAB
 C:\Midlothian on Rental\November 15\SPC_001466.LAB
 C:\Midlothian on Rental\November 15\SPC_001467.LAB
 C:\Midlothian on Rental\November 15\SPC_001468.LAB
 C:\Midlothian on Rental\November 15\SPC_001469.LAB
 C:\Midlothian on Rental\November 15\SPC_001470.LAB

Recipe path: C:\OLT\recipes\Cement Testing R3.MGRCP

Gas calibration Name	Conc	MDC3	MDC2	MDC1	MAU	FMU*R	OCU	~DL	~CL	~Bias	Sigma	Range	Span	Comment
HCN (200) PCA 191C 191C	22.26	0.52	-	0.28	0.34	0.62	0.62	-	0.45	-	-	0-200	-	Good
SF6 (10) 191C	-0.01	0.01	-	0	0	0.02	0.02	-	0.01	-	-	0-10	-	Close to DL
HCL PPM (100) 191C	1.24	0.4	0.05	0.15	0.28	0.72	0.72	0.06	0.23	0.01	0.02	0-100	-	Check it!
SO2 (1000) 191C	40.76	0.88	0.37	0.14	0.27	1.67	1.67	0.79	1.13	0.42	0.12	0-1000	-	Good
NO (350,3000) 191C	57.62	4.92	0.22	0.26	0.35	6.69	6.69	0.45	3.19	0.23	0.07	0-3000	-	Good
NO2 (150) 191C (10F2)	-0.64	0.42	0.04	0.02	0.03	0.45	0.45	0.05	0.38	0.01	0.01	0-150	-	Check it!
NO2 (2000) 191C (20F2)	-0.41	4.22	2.03	0.88	1.12	5.37	5.37	3.81	3.81	1.78	0.68	0-2000	-	Close to DL
N2O (100,200,300) 191C	1.59	0.2	0.05	0.04	0.05	0.23	0.23	0.07	0.12	0.02	0.02	0-300	-	Good
NH3 (300) 191C (10F2)	0.38	1.02	0.03	0.12	0.2	1.73	1.73	0.15	0.9	0.11	0.01	0-300	-	Check it!
NH3 (3000) 191C (20F2)	3.13	14.22	0.35	1.19	2.25	26.82	26.82	0.44	13.16	0.09	0.12	0-3000	-	Close to DL
CO (500) 191C (10F2)	492.07	15.9	-	0.2	0.43	30.18	30.18	-	9.89	-	-	0-500	-	Good
CO% (1) 191C (20F2)	0.04	0	0	0	0	0	0	0	0	0	0	0-1	-	Good
H2O% (40) 191C	14.99	0.13	-	0.01	0.02	0.25	0.25	-	0.3	-	-	0-40	-	Good
CO2% (40) 191C	7.22	0.21	-	0.01	0.02	0.29	0.29	-	0.14	-	-	0-40	-	Good
CH4 (250) 191C (10F2)	7.81	1.09	0.05	0.26	0.7	2.88	2.88	0.06	0.62	0.01	0.02	0-250	-	Good
CH4 (3000) 191C (20F2)	8.5	6.62	0.34	1.1	1.81	10.91	10.91	0.61	5.32	0.27	0.11	0-3000	-	Check it!
FORMALDEHYDE (70) 191C	3.5	0.58	0.28	0.2	0.24	0.7	0.7	0.33	0.33	0.04	0.09	0-70	-	Good
ACETALDEHYDE (1000) 191C	2.81	1.41	0.23	0.35	0.38	1.53	1.53	0.59	0.98	0.35	0.08	0-1000	-	Check it!
ACETYLENE (1000) 191C	0.89	2.14	0.15	0.31	0.37	2.59	2.59	0.21	1.83	0.06	0.05	0-1000	-	Close to DL
PROPANE (100) 191C	2.84	0.82	0.42	0.12	0.14	0.98	0.98	0.72	0.72	0.3	0.14	0-100	-	Close to DL
PROPYLENE (200,1000) 191C	1.74	3.32	0.19	0.43	0.5	3.9	3.9	0.49	2.86	0.3	0.06	0-1000	-	Close to DL
ETHYLENE (100,3000) 191C	6.19	1.39	0.33	0.17	0.29	2.43	2.43	1.08	1.08	0.75	0.11	0-3000	-	Check it!
HF PPM (10) 191C	0.21	0.19	0.05	0.04	0.07	0.34	0.34	0.07	0.15	0.02	0.02	0-10	-	Close to DL
COS (100) 150C	2.21	0.19	0.02	0.02	0.02	0.26	0.26	0.02	0.12	0	0.01	0-100	-	Good
ETHANE (500) 191C	1.51	1.32	0.32	0.2	0.22	1.48	1.48	0.54	1.09	0.22	0.11	0-500	-	Close to DL
H2SO4 (50) 150C	-0.11	0.13	0.04	0.05	0.05	0.15	0.15	0.29	0.29	0.25	0.01	0-50	-	Close to DL
HBR (100) 180C	-0.33	3.96	0.17	0.68	1.39	8.05	8.05	0.19	3.3	0.02	0.06	0-100	-	Close to DL
MEOH (10) 191C	1.18	0.39	0.14	0.14	0.16	0.44	0.44	0.17	0.23	0.03	0.05	0-10	-	Close to DL
SO3 (150) 191C	2.18	0.31	0.7	0.03	0.04	0.34	0.34	1.14	1.14	0.44	0.23	0-150	-	Close to DL

Analysis Validation Report

Sample Filename: F:\Midlothian on Rental\November 15\SPC__001502.LAB

Filename for noise: F:\Midlothian on Rental\November 14\SPC__000837.LAB

Interferences Filenames: C:\Midlothian on Rental\November 15\SPC__001463.LAB

C:\Midlothian on Rental\November 15\SPC__001464.LAB

C:\Midlothian on Rental\November 15\SPC__001465.LAB

C:\Midlothian on Rental\November 15\SPC__001466.LAB

C:\Midlothian on Rental\November 15\SPC__001467.LAB

C:\Midlothian on Rental\November 15\SPC__001468.LAB



C:\Midlothian on Rental\November 15\SPC__001469.LAB

C:\Midlothian on Rental\November 15\SPC__001470.LAB

Recipe path: C:\OL\Recipes\Cement Testing R3.MGRCP

Gas calibration Name	Conc	MDC3	MDC2	MDC1	MAU	FMU*R	OCU	~DL	~CL	~Bias	Sigma	Range	Span	Comment
HCN (200) PCA 191C 191C	21.12	0.45	-	0.28	0.34	0.54	0.54	-	0.42	-	-	0-200	-	Good
SF6 (10) 191C	0	0.01	-	0	0	0.02	0.02	-	0.01	-	-	0-10	-	Close to DL
HCL PPM (100) 191C	1.23	0.38	0.05	0.15	0.28	0.68	0.68	0.06	0.21	0.01	0.02	0-100	-	Check it!
SO2 (1000) 191C	39.23	0.88	0.37	0.14	0.27	1.68	1.68	0.79	1.11	0.42	0.12	0-1000	-	Good
NO (350,3000) 191C	54.66	5.45	0.22	0.26	0.35	7.41	7.41	0.45	3.76	0.23	0.07	0-3000	-	Good
NO2 (150) 191C (10F2)	-0.76	0.46	0.04	0.02	0.03	0.49	0.49	0.05	0.42	0.01	0.01	0-150	-	Check it!
NO2 (2000) 191C (20F2)	-0.89	4.25	2.03	0.88	1.12	5.41	5.41	3.81	3.81	1.78	0.68	0-2000	-	Close to DL
N2O (100,200,300) 191C	1.54	0.21	0.05	0.04	0.05	0.25	0.25	0.07	0.14	0.02	0.02	0-300	-	Good
NH3 (300) 191C (10F2)	0.42	1.07	0.03	0.12	0.2	1.81	1.81	0.15	0.95	0.11	0.01	0-300	-	Check it!
NH3 (3000) 191C (20F2)	3.83	15.77	0.35	1.19	2.25	29.74	29.74	0.44	14.68	0.09	0.12	0-3000	-	Check it!
CO (500) 191C (10F2)	481.28	16.49	-	0.2	0.43	31.3	31.3	-	9.81	-	-	0-500	-	Good
CO% (1) 191C (20F2)	0.04	0	0	0	0	0	0	0	0	0	0	0-1	-	Good
H2O% (40) 191C	16.95	0.15	-	0.01	0.02	0.28	0.28	-	0.34	-	-	0-40	-	Good
CO2% (40) 191C	7.16	0.2	-	0.01	0.02	0.28	0.28	-	0.14	-	-	0-40	-	Good
CH4 (250) 191C (10F2)	7.83	1.13	0.05	0.26	0.7	3	3	0.06	0.67	0.01	0.02	0-250	-	Good
CH4 (3000) 191C (20F2)	8.61	7.11	0.34	1.1	1.81	11.71	11.71	0.61	5.8	0.27	0.11	0-3000	-	Check it!
FORMALDEHYDE (70) 191C	3.32	0.59	0.28	0.2	0.24	0.72	0.72	0.33	0.33	0.04	0.09	0-70	-	Good
ACETALDEHYDE (1000) 191C	2.77	1.35	0.23	0.35	0.38	1.47	1.47	0.59	0.92	0.35	0.08	0-1000	-	Check it!
ACETYLENE (1000) 191C	0.85	2.21	0.15	0.31	0.37	2.67	2.67	0.21	1.89	0.06	0.05	0-1000	-	Close to DL
PROPANE (100) 191C	2.94	0.84	0.42	0.12	0.14	1.01	1.01	0.72	0.72	0.3	0.14	0-100	-	Close to DL
PROPYLENE (200,1000) 191C	1.67	3.48	0.19	0.43	0.5	4.08	4.08	0.49	3.02	0.3	0.06	0-1000	-	Close to DL
ETHYLENE (100,3000) 191C	6.05	1.49	0.33	0.17	0.29	2.59	2.59	1.08	1.16	0.75	0.11	0-3000	-	Check it!
HF PPM (10) 191C	0.23	0.17	0.05	0.04	0.07	0.31	0.31	0.07	0.14	0.02	0.02	0-10	-	Close to DL
COS (100) 150C	2.15	0.19	0.02	0.02	0.02	0.26	0.26	0.02	0.12	0	0.01	0-100	-	Good
ETHANE (500) 191C	1.57	1.37	0.32	0.2	0.22	1.53	1.53	0.54	1.13	0.22	0.11	0-500	-	Close to DL
H2SO4 (50) 150C	-0.11	0.13	0.04	0.05	0.05	0.14	0.14	0.29	0.29	0.25	0.01	0-50	-	Close to DL
HBR (100) 180C	-0.17	3.83	0.17	0.68	1.39	7.79	7.79	0.19	3.17	0.02	0.06	0-100	-	Close to DL
MEOH (10) 191C	1.24	0.41	0.14	0.14	0.16	0.47	0.47	0.17	0.25	0.03	0.05	0-10	-	Close to DL
SO3 (150) 191C	2.82	0.36	0.7	0.03	0.04	0.39	0.39	1.14	1.14	0.44	0.23	0-150	-	Close to DL



Calibration Generated: 3:08 PM 12/29/2023
 Gas ID: HCN (200) PCA 191C 191c
 LRF Path: C:\OLTIMethods\R3\Cement-coal-EGU method 191C\HCN (200) PCA 191C 191c_18.lrf
 Lo Alarm: NaN Hi Alarm: NaN
 Span Mutations: FALSE
 Offse: ,00000
 Mutations: FALSE



Cal Spectra	Temp (C)	Pres (atm)	Conc (ppm-m)	Actual	Calc'd
HCN (200) PCA 191C (9.86ppm, 5.11)	191.209	0.977	50.385	50.338	58.224
HCN (200) PCA 191C (14.79ppm, 5.11)	191.194	0.977	75.577	75.505	82.698
HCN (200) PCA 191C (19.72ppm, 5.11)	191.202	0.977	100.769	100.670	109.924
HCN (200) PCA 191C (19.87ppm, 5.11)	191.196	0.978	101.536	101.566	110.865
HCN (200) PCA 191C (24.85ppm, 5.11)	191.204	0.977	125.962	125.832	138.998
HCN (200) PCA 191C (29.58ppm, 5.11)	191.209	0.977	151.154	150.999	165.056
HCN (200) PCA 191C (34.51ppm, 5.11)	191.225	0.977	176.346	176.168	193.807
HCN (200) PCA 191C (39.44ppm, 5.11)	191.217	0.977	201.538	201.349	218.561
HCN (200) PCA 191C (39.74ppm, 5.11)	191.194	0.978	203.071	203.055	221.567
HCN (200) PCA 191C (44.37ppm, 5.11)	191.203	0.977	226.731	226.500	246.999
HCN (200) PCA 191C (49.30ppm, 5.11)	191.199	0.977	251.923	251.691	274.819
HCN (200) PCA 191C (59.61ppm, 5.11)	191.221	0.978	304.607	304.577	328.275
HCN (200) PCA 191C (79.48ppm, 5.11)	191.195	0.977	406.143	405.954	437.656
HCN (200) PCA 191C (99.35ppm, 5.11)	191.258	0.977	507.679	507.181	537.974
HCN (200) PCA 191C (119.22ppm, 5.11)	191.209	0.977	609.214	608.643	634.405
HCN (200) PCA 191C (139.09ppm, 5.11)	191.246	0.977	710.750	709.953	733.320
HCN (200) PCA 191C (158.96ppm, 5.11)	191.263	0.977	812.286	811.364	836.755
HCN (200) PCA 191C (178.83ppm, 5.11)	191.221	0.977	913.821	913.339	928.309
HCN (200) PCA 191C (198.70ppm, 5.11)	191.202	0.978	1015.357	1015.357	1015.357

Interpolation: Quadratic
 Min % Residuals: Excl. Zero Quant w/ Highest
 Force Through Zero:
 Spectral Regions:
 Region 00 - 3250.25 to 3411.52 cm-1
 Region 01 - 593.01 to 840.34 cm-1
 Region 02 - 1295.95 to 1518.21 cm-1
 Region 03 - 2496.93 to 2901.43 cm-1
 Region 04 - 3172.38 to 3250.01 cm-1
 Region 05 - 3881.35 to 4113.97 cm-1

Calibration Generated 11/30/2012 2:50 AM
 Gas ID Ethylene (100,3000) 191C
 LRF Path C:\OLT\Methods R3\Cement-coal-EGU method 191C\Ethylene (100,3000) 191C_19.lrf
 Lo Alarm Hi Alarm Mutations Span Offse. J000000
 NaN NaN Mutations FALSE



Cal Spectra	Temp (C)	Pres (atm)	Conc (ppm-m)	Actual	Calc'd
Ethylene (9.74ppm, 5.11m, 190C).lab	190.014	0.994	49.792	49.542	54.522
Ethylene (19.49ppm, 5.11m, 190C).lab	189.989	0.994	99.594	99.135	107.070
Ethylene (29.23ppm, 5.11m, 190C).lab	189.985	0.994	149.365	148.729	162.298
Ethylene (38.98ppm, 5.11m, 190C).lab	189.998	0.995	199.188	198.392	217.388
Ethylene (48.72ppm, 5.11m, 190C).lab	189.971	0.995	248.959	247.990	272.190
Ethylene (58.46ppm, 5.11m, 190C).lab	189.964	0.995	298.731	297.587	327.537
Ethylene (68.21ppm, 5.11m, 190C).lab	189.977	0.995	348.553	347.251	383.508
Ethylene (77.95ppm, 5.11m, 190C).lab	189.933	0.995	398.325	396.868	439.409
Ethylene (87.70ppm, 5.11m, 190C).lab	189.964	0.995	448.127	446.506	495.696
Ethylene (97.44ppm, 5.11m, 190C).lab	189.934	0.995	497.918	496.089	551.021
Ethylene (300.00ppm, 5.11m, 190C).lab	189.942	0.997	1533.000	1531.357	1654.977
Ethylene (600.00ppm, 5.11m, 190C).lab	189.991	0.998	3066.000	3063.066	3290.420
Ethylene (900.00ppm, 5.11m, 190C).lab	189.934	0.998	4599.000	4597.015	4885.213
Ethylene (1200.00ppm, 5.11m, 190C).lab	189.933	0.998	6132.000	6130.754	6446.341
Ethylene (1500.00ppm, 5.11m, 190C).lab	189.960	0.998	7664.999	7658.046	7940.995
Ethylene (1800.00ppm, 5.11m, 190C).lab	189.922	0.998	9197.999	9195.039	9445.204
Ethylene (2100.00ppm, 5.11m, 190C).lab	189.971	0.998	10730.999	10728.462	10942.161
Ethylene (2400.00ppm, 5.11m, 190C).lab	189.936	0.998	12263.999	12262.913	12444.229
Ethylene (2700.00ppm, 5.11m, 190C).lab	189.914	0.998	13796.999	13797.629	13888.468

Interpolation: Quartic
 Min % Residuals Excl. Zero Quant w/ Highest
 Force Through Zero
 Spectral Regions
 Region 00 - 900.12 to 1000.16 cm-1
 Region 01 - 615.91 to 899.88 cm-1
 Region 02 - 1000.40 to 1211.33 cm-1
 Region 03 - 1341.75 to 2117.96 cm-1
 Region 04 - 2901.41 to 3286.87 cm-1

Appendix F

Test Participants

Scott Steinsberger	Project Manager and FTIR Operator
Lee Harris	Sample Recovery Technician
Gage Mayer	Sampling Technician
Michael Powell	Sampling Technician
Dan Carnes	Holcim Plant Contact

Appendix G

RTR Sampling and Analytical Protocol



DEECO Inc.
3404 Lake Woodard Road
Raleigh, NC 27604
(919) 250-0285 (ph); (919) 250-1835 (Fax)

www.deeco.com

**PROTOCOL TO PERFORM A SAMPLING
AND ANALYTICAL TESTING PROGRAM
AS PART OF THE US EPA RISK AND TECHNOLOGY REVIEW
at
Holcim Inc.
Midlothian Facility
1800 Dove Lane
Midlothian, TX 76065**

**Submitted By:
DEECO, INC.
3404 Lake Woodard Road
Raleigh, NC 27604**

September 29, 2023

Copy # 1

TABLE OF CONTENTS

<u>Figure</u>		<u>Page</u>
1.0	INTRODUCTION	1-1
1.1	SUMMARY OF TEST PROGRAM.....	1-1
1.2	PLANT NAME, ADDRESS, AND CONTACT.....	1-1
1.3	PROCESS OF INTEREST.	1-1
1.4	AIR POLLUTION CONTROL EQUIPMENT.	1-1
1.5	EMISSION POINTS AND SAMPLING LOCATIONS.....	1-2
1.6	POLLUTANTS TO BE MEASURED.....	1-2
1.7	EXPECTED TEST DATES.....	1-2
1.8	TEST PROGRAM ORGANIZATION.	1-2
2.0	SOURCE DESCRIPTION	2-1
2.1	PROCESS DESCRIPTION.....	2-1
2.2	CONTROL EQUIPMENT DESCRIPTION.	2-2
3.0	TEST PROGRAM.....	3-1
3.1	OBJECTIVES.	3-1
3.2	TEST MATRIX.....	3-1
3.3	TEST COORDINATION.....	3-2
4.0	SAMPLING LOCATION DESCRIPTIONS.....	4-1
4.1	SAMPLING LOCATION DESCRIPTION.....	4-1
5.0	SAMPLING AND ANALYTICAL PROCEDURES.	5-1
5.1	TEST METHODS.	5-1
5.1.1	SAMPLING POINT DETERMINATION - EPA METHOD 1.....	5-1
5.1.2	FLUE GAS VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2.....	5-1
5.1.3	OUTLET FLUE GAS COMPOSITION - EPA METHOD 3A.	5-1
5.1.3.1	Calibration Gases.	5-2
5.1.3.2	Sampling Procedures.	5-2
5.1.4	FLUE GAS MOISTURE CONTENT - EPA METHOD 4.	5-3
5.1.5	HYDROGEN FLUORIDE AND DIATOMIC CHLORINE - EPA METHOD 26A.....	5-3
5.1.6	HYDROGEN CYANIDE AND HYDROGEN FLUORIDE - EPA METHOD 320.....	5-5
5.1.6.1	Laboratory QA/QC Activities Before Field Test Program.	5-5
5.1.6.2	QA/QC Activities During Field Test Program.	5-6
6.0	QUALITY ASSURANCE/QUALITY CONTROL ACTIVITIES	6-1
6.1	QA/QC PROCEDURES.	6-1
6.2	SAMPLE IDENTIFICATION AND CUSTODY.....	6-2

TABLE OF CONTENTS (Continued)

7.0	SAMPLE CUSTODY.	7-1
7.1	FIELD SAMPLING OPERATIONS.	7-1
7.2	ANALYTICAL OPERATIONS.	7-1
8.0	INTERNAL QUALITY CONTROL CHECKS.	8-1
8.1	EQUIPMENT INSPECTION AND MAINTENANCE.	8-1
8.2	EQUIPMENT CALIBRATION.	8-1
8.3	SAMPLING QUALITY CONTROL PROCEDURES.	8-3
8.4	ANALYTICAL QUALITY CONTROL PROCEDURES.	8-5
9.0	REPORTING AND DATA REDUCTION REQUIREMENTS.	9-1
9.1	DATA REPORTING.	9-1
9.2	REPORT CONTENTS.	9-1
9.3	DATA REDUCTION.	9-1
9.4	DATA VALIDATION.	9-1
10.0	PLANT ENTRY AND SAFETY.	10-1
10.1	SAFETY RESPONSIBILITIES.	10-1
10.2	SAFETY PROGRAM.	10-1
10.3	SAFETY REQUIREMENTS.	10-1

LIST OF TABLES

<u>Table</u>	<u>Page</u>
TABLE 3-1 PROGRAM OUTLINE AND TENTATIVE TEST SCHEDULE.	7
TABLE 6-1 QA/QC PROCEDURES AND REQUIREMENTS.	18

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
Figure 1.1 Organizational Chart.	1-3
Figure 2.1 Midlothian Line 1 Detailed Process Schematic.	2-2
Figure 2.2 Midlothian Line 2 Detailed Process Schematic.	2-3
Figure 4.1 Schematic of Line 1 Stack Sampling Location.	4-2
Figure 4.2 Schematic of Line 2 Stack Sampling Location.	4-3

APPENDICES

Appendix A - Sampling and Analytical Methods

1.0 INTRODUCTION

1.1 SUMMARY OF TEST PROGRAM

The United States Environmental Protection Agency (US EPA) has directed the portland cement industry (SIC 3241) to conduct emissions testing as part of the US EPA Risk and Technology Review (RTR). This document provides the overall test program approach and specifies minimum sample collection procedures, data quality objectives, and quality assurance/quality control measures to be used by the source testing firms selected by the cement companies performing tests. The test program is designed to be a comprehensive and robust test of each facility. The quality assurance and quality control (QA/QC) measures are designed to produce standardized data having known precision and accuracy. Collection of accurate, representative, and standardized data for facilities with low emissions is necessary especially in view of MACT standard setting procedures.

Cement kiln pyro-processing systems located throughout the US will be included in this request. Individual facilities have a wide range of kiln system configurations and air pollution control (APC) trains. Site-specific considerations will be required to capture emissions profiles for the target analytes that represent the extent of control or possible emissions increases from these controls.

1.2 PLANT NAME, ADDRESS, AND CONTACT

Holcim (US) Inc.
1800 Dove Lane
Midlothian, TX 76065

Mr. Dan Carnes
TEL (972) 923-5830
FAX (972) 923-5923
dan.carnes@holcim.com

1.3 PROCESS OF INTEREST

The processes to be tested at the Midlothian facility are two preheater/precalciner pyro-processing system, each with an inline raw mill, producing portland cement, referred to as Line 1 and Line 2.

1.4 AIR POLLUTION CONTROL EQUIPMENT

The air pollution control equipment for Line 1 consists of three control devices. A dry sorbent injection system utilizing lime is used to control acid gas emissions. Combined emissions from the clinker cooler and the kiln/raw mill and alkali bypass directed through respective fabric filters for particulate removal. The kiln/raw mill exiting the fabric filter is sent to a selective catalytic reduction (SCR) system for reducing organic emissions. Exhaust from the SCR and the alkali bypass are combined and sent to scrubber for final particulate removal and acid gas control before exhausting through the Line 1 Main Stack.

The air pollution control equipment for Line 2 consists of three control devices. A dry sorbent injection system utilizing lime is used to control acid gas emissions. Combined emissions from the clinker cooler and the kiln/raw mill and alkali bypass directed through respective fabric filters for

particulate removal. The kiln/raw mill exiting the fabric filter is sent to a regenerative thermal oxidizer (RTO) system for reducing organic emissions. Exhaust from the RTO and the alkali bypass are combined and sent to scrubber for final particulate removal and acid gas control before exhausting through the Line 2 Main Stack.

1.5 EMISSION POINTS AND SAMPLING LOCATIONS

Sampling will be conducted on the Line 1 Main Stack and Line 2 Main Stack.

1.6 POLLUTANTS TO BE MEASURED

Emission testing will be conducted for hydrogen cyanide (HCN), hydrogen fluoride (HF), and diatomic chlorine (Cl₂). Concurrent measurements to determine volumetric flow rate will be made. The sampling and analytical procedures to be followed are discussed in detail in Section 4.

1.7 EXPECTED TEST DATES

Test dates are to be determined.

1.8 TEST PROGRAM ORGANIZATION

The test program organizational chart is presented in Figure 1.1.




Figure 1.1 Organizational Chart

2.0 SOURCE DESCRIPTION

2.1 PROCESS DESCRIPTION

The Midlothian Plant's Portland cement manufacturing process involves raw materials acquisition and handling, kiln feed preparation, pyro-processing, and finished cement grinding and loading. The Midlothian Plant acquires calcareous raw material (i.e., limestone) by drilling and blasting in the quarry. The blasted material is fed to the primary and secondary crushers where it is processed down to three-inch or smaller product. Crushed raw materials are deposited into piles in the Raw Material Storage (RMS) building by an overhead multi-position tripper belt conveyor before entering the Raw Mill Feed Bins.

The Midlothian Plant processes shale brought on-site by delivery truck. The shale is unloaded and then moved to a stockpile inside the existing shale storage building. The shale is crushed, stored in the shale Storage Building No. 1 or 2, and then conveyed to the raw mill feed bins.

The roller mills (i.e., Line 1 and Line 2 Raw Mills) receive the crushed raw material and process it for the Midlothian Plant's pyro-processing systems. The raw mill product is carried by airstream into cyclones where over 90 percent of the material is separated from the airstream. The exhaust gases are vented through the main baghouse where the remainder of the product is captured. The product stream from the cyclones is transported to the blending silos. The product from the main baghouse may be sent to the blending silos or directly to a bin and metered to the kiln feed.

The blending silos, which operate in a continuous flow, serve both a mixing and storage function. The silos are discharged normally through flow control gates. The ground raw feed enters a calibration bin and discharged to the preheater feed or re-circulated back to the top of the silos.

Each of the Midlothian Plant's Line 1 and Line 2 pyro-processing systems consist of a four-stage preheated precalciner system (Emission Point Numbers [EPNs] 7 and 65). Both lines have a bypass system to control the quantity of alkali and sulfur since the nature of the raw materials requires that alkali and sulfur be removed to control the quality of the clinker. Water spray conditioning towers designed to cool gases are located in the duct between the presenters and the raw mills. When the mill systems are not operational, the spray towers protect the main bathhouses from high temperatures. The spray towers are not used when the mill systems are operational.

The presenters consist of four "stages" (or cyclones) and a precalciner. The first three stages, or the preheating stage, heat the feed by mixing the cold feed with the hot kiln and precalciner exit gases. From the preheating stage, the preheated feed enters the precalciner where the calcium carbonate (limestone) is converted to lime and carbon dioxide gas. The calcined raw feed enters the kiln where raw materials are sintered and clinker produced. The clinker is cooled in reciprocating grate coolers (i.e. clinker coolers) by induced airflow. The air used to quench the clinker is hot and is reused in the kilns, precalciners, coal mills, raw mills, and partially re-circulated to various fans.

The Midlothian Plant receives coal by railcar. The coal is piled, sized, and then placed in silos. The coal then enters the coal mills where heat for drying is supplied by the hot vent air from the clinker cooler. From the coal mill, the coal is conveyed to the kilns for combustion.

Clinker from the clinker silos and acquired gypsum are fed to three finish mill systems. The finish mill systems grind the clinker and additive to produce finish cement. The mills cool the finish cement by mill venting and water spraying. The finish cement is discharged to O-Sepa separators

where properly sized product is transported by air stream to a dust collector. The tailings from the separator are reintroduced into the mills for further grinding. The dust collector product is conveyed to the cement silos. The cement is transported from the silos to various loading stations for transportation from the plant.

2.2 CONTROL EQUIPMENT DESCRIPTION

The air pollution control equipment for Line 1 consists of three control devices. A dry sorbent injection system utilizing lime is used to control acid gas emissions. Combined emissions from the clinker cooler and the kiln/raw mill and alkali bypass directed through respective fabric filters for particulate removal. The kiln/raw mill exiting the fabric filter is sent to a selective catalytic reduction (SCR) system for reducing organic emissions. Exhaust from the SCR and the alkali bypass are combined and sent to scrubber for final particulate removal and acid gas control before exhausting through the Line 1 Main Stack.

A schematic of the Line 1 process, including control equipment is shown below in Figure 2.1.




Figure 2.1 Midlothian Line 1 Detailed Process Schematic

The air pollution control equipment for Line 2 consists of three control devices. A dry sorbent injection system utilizing lime is used to control acid gas emissions. Combined emissions from the clinker cooler and the kiln/raw mill and alkali bypass directed through respective fabric filters for particulate removal. The kiln/raw mill exiting the fabric filter is sent to a regenerative thermal oxidizer (RTO) system for reducing organic emissions. Exhaust from the RTO and the alkali bypass are combined and sent to scrubber for final particulate removal and acid gas control before exhausting through the Line 2 Main Stack.

A schematic of the Line 2 process, including control equipment is shown below in Figure 2.2.




Figure 2.2 Midlothian Line 2 Detailed Process Schematic

3.0 TEST PROGRAM

3.1 OBJECTIVES

An air emissions sampling and analytical program will be conducted on the Line 1 Main stack and the Line 2 Main stack Midlothian cement facility located in Midlothian, TX. All testing will be performed following accepted EPA methodology. The test program is to provide a standardized data set to the EPA and the cement industry so that reliable facility inter-comparisons of emissions can be made.

All testing will be performed in strict accordance with "DRAFT GENERAL TEST PLAN Testing To Determine HCN, HF, and Cl₂ Emissions From Cement Kilns" dated March 2, 2023" and the specifications stipulated in 40 CFR 60, Appendix A for flow rate following EPA Method 1, 2, 3A, and 4) and hydrogen fluoride (HF) and diatomic chlorine (Cl₂) following EPA Method 26A and in 40 CFR 63, Appendix A for hydrogen cyanide (HCN) and (HF) following EPA Method 320. All sampling runs will be one hour long.

The source emission test will be performed on a date to be determined. Testing will be conducted under representative process and control system operating conditions. For facilities with inline raw mills, testing will be performed while operating in the "Mill On" and "Mill Off" conditions.

3.2 TEST MATRIX

Table 3-1 presents the sampling and analytical matrix and proposed test schedule.

TABLE 3-1 PROGRAM OUTLINE AND TENTATIVE TEST SCHEDULE

Sampling Location	No. of runs	Sample/Type Pollutant	Sampling Method	Sample Run Times (min)	Analytical Method	Analytical Laboratory
Day 1						
Line 1	Arrive on-site and set up test equipment on Line 1 Stack					
Day 2						
Line 1 Stack; Raw Mill On	3	O ₂ /CO ₂	EPA Method 3A	60	Paramagnetic (O ₂) NDIR (CO ₂)	DEECO
	3	HF and Cl ₂	EPA Method 26A ¹	60	Ion Chromatograph	Element One
	3	HCN and HF	EPA Method 320	60	FTIR (Method 320)	DEECO
Day 3						
Line 1 Stack; Raw Mill Off	3	O ₂ /CO ₂	EPA Method 3A	60	Paramagnetic (O ₂) NDIR (CO ₂)	DEECO
	3	HF and Cl ₂	EPA Method 26A ¹	60	Ion Chromatograph	Element One
	3	HCN and HF	EPA Method 320	60	FTIR (Method 320)	DEECO
Day 4						
Line 2	Move and set up test equipment on Line 2					

TABLE 3-1 (Continued)

Sampling Location	No. of runs	Sample/Type Pollutant	Sampling Method	Sample Run Times (min)	Analytical Method	Analytical Laboratory
Day 5						
Line 2 Stack; Raw Mill On	3	O ₂ /CO ₂	EPA Method 3A	60	Paramagnetic (O ₂) NDIR (CO ₂)	DEECO
	3	HF and Cl ₂	EPA Method 26A ¹	60	Ion Chromatograph	Element One
	3	HCN and HF	EPA Method 320	60	FTIR (Method 320)	DEECO
Day 6						
Line 2 Stack; Raw Mill Off	3	O ₂ /CO ₂	EPA Method 3A	60	Paramagnetic (O ₂) NDIR (CO ₂)	DEECO
	3	HF and Cl ₂	EPA Method 26A ¹	60	Ion Chromatograph	Element One
	3	HCN and HF	EPA Method 320	60	FTIR (Method 320)	DEECO

¹ Stack gas flow rate and moisture measurement may be taken from concurrent Method 26A sampling trains.

3.3 TEST COORDINATION

Mr. Dan Carnes, the Midlothian facility contact, will serve as the test coordinator and will be responsible for:

1. Scheduling the start of all testing
2. Principal contact with the agency officials concerning the tests
3. Principal contact with DEECO concerning the tests
4. Recording the process data during the testing
5. Providing copies of any field test data to the agency

If there is a temporary equipment malfunction in the middle of a test, radio contact will be made with the test crew in order to delay the test. When problems have been corrected, the test will continue from the point where it was delayed. If the malfunction or upset condition results in an extended test delay, then the affected test run(s) may be aborted and a new run(s) conducted when the malfunction has been corrected or process upset cleared. Any samples or field data from aborted runs may be discarded.

4.0 SAMPLING LOCATION DESCRIPTIONS

4.1 SAMPLING LOCATION DESCRIPTION

The Line 1 Main stack is a vertically-oriented circular stack with an inside diameter of 161.5" inside diameter. The stack gas sampling ports are located approximately 101' 7" (approximately 7.55 duct diameters) above the ID fan breaching and approximately 38' 6" (approximately 2.86 duct diameters) from the stack outlet.

The Line 2 Main stack is a vertically-oriented circular stack with an inside diameter of 164.063" inside diameter. The stack gas sampling ports are located approximately 102' 9" (approximately 7.52 duct diameters) above the ID fan breaching and approximately 83' 6" (approximately 6.11 duct diameters) from the stack outlet.

Both sampling locations meet the minimum specifications for selection of a measurement site as outlined in EPA Method 1. Cyclonic flow checks, as described in EPA Method 1 Section 2.4, using the Type-S pitot null procedure and angle measurements at the Common stack test location will be conducted.

A twelve (12) point sampling traverse will be made using 3 points in each of 4 sampling ports at the Line 1 Main stack and Line 2 Main stack. Each traverse will be made at each sampling location using a type-S pitot tube in accordance with EPA Methods 2 procedures. Gas temperatures are to be measured using calibrated Type K thermocouples and digital readout devices. All measurements are to be performed in accordance with the procedures in EPA Methods 2, and 26A.

Schematics of the Line 1 Main stack and Line 2 Main stack are provided in Figures 4-1 and 4-2, respectively.




Figure 4.1 Schematic of the Line 1 Stack Sampling Location (not) Placeholder




Figure 4.2 Schematic of the Line 2 Stack Sampling Location

5.0 SAMPLING AND ANALYTICAL PROCEDURES

This section contains a brief description of the sampling and analytical procedures for each method that will be employed during the test program. All equipment, procedures, and quality assurance measures necessary for completion of the test program will meet or exceed the specifications of the appropriate methods. Any deviations from the methods to ensure quality representativeness of the results are also discussed.

5.1 TEST METHODS

The methods for the test program are described below, and apply to all process operating conditions (e.g. where there is an inline raw mill, testing will be performed while operating in the "Mill On" and "Mill Off" conditions). Table 3-1 outlines expected operating conditions for this test.

5.1.1 SAMPLING POINT DETERMINATION - EPA METHOD 1

The number and location of the sampling or traverse points will be determined according to the procedures outlined in EPA Method 1. The sample location will be inspected to insure EPA Method 1 criteria is met. All points will be at least 1.0 inches from the stack wall, per Method 1.

5.1.2 FLUE GAS VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2

The flue gas velocity and volumetric flow rate will be determined according to the procedures outlined in EPA Method 2. Velocity measurements will be made using type S pitot tubes conforming to the calibration specifications outlined in EPA Method 2, Section 10.1. Each Type-S pitot tube, calibrated according to these standards, will have an assigned coefficient. Differential pressures will be measured with Magnehelic gauges of appropriate range or with fluid manometers. Effluent gas temperatures will be measured with chromel-alumel thermocouples equipped with digital readouts.

5.1.3 OUTLET FLUE GAS COMPOSITION - EPA METHOD 3A

Outlet flue gas analysis for oxygen (O₂) and carbon dioxide (CO₂) concentrations, and the calculation of percent excess air and flue gas dry molecular weight will be performed in accordance with EPA Method 3A.

To evaluate the sampling location and points for FTIR and O₂ sampling, a three-point O₂ concentration stratification test on a line passing through the centroidal area at 16.7, 50.0 and 83.3 percent of the measurement line (or for stacks is greater than 2.4 meters (7.8 ft) at 0.4, 1.2 and 2.0 meters from the stack or duct wall). The procedures in Section 8.1.2 of Method 7E will be followed, but oxygen will be used as parameter as allowed by fourth sentence in Section 8.1.2. The plant O₂ CEMS as a control. A criteria of <5% variation from combined mean for each point will be used as indication of non-stratification and allowing single point sampling at the point closest to the mean. Otherwise, sampling for equal periods at the three test points during test run will be conducted.

Per EPA Method 3A for determining molecular weight, integrated sampling will be obtain using the Method 320 sampling system described in Section 5.1.6.

A portion of the hot, wet gas sample will be sent through a condensing system to remove the stack moisture, A portion of the moisture-free gas sample will be sent to a CAI Model 200 O₂ (or

equivalent) analyzer measures using the paramagnetic technique. An oxygen molecule, because of its sp³ electron orbital distribution, has an unpaired electron and hence displays a magnetic orientation. Since other elements that display this magnetic phenomenon are not common gasses at normal temperatures, the paramagnetic measurement technique is virtually specific for oxygen. The sample gas flows through a detection cell located in a very strong magnetic field. The concentration of O₂ gas present induces a pressure differential in the detector cell. The amount of differential pressure is proportional to the concentration of O₂ gas present.

Calibration procedures will be performed in accordance with EPA methodology. Analyzers will be calibrated before and after each test and a calibration check between each test run.

The pretest calibrations will consist of the following steps:

- Internal (direct) calibration of each analyzer to adjust calibration and check linearity.
- External (through the entire sampling system) calibration to check the system bias on zero and span gases.

The post test calibration will consist of an external system bias calibration check.

The analyzer will be as calibrated using a certified zero and span (mid or high range) gas. Zero and span gases were directed to each analyzer through the appropriate plumbing, the calibration gas flow rates will be adjusted to the correct flow rate and the analyzer will be adjusted with the appropriate span pot.

After the analyzer is properly adjusted the linearity will be checked using a low and high range calibration gas. The maximum allowable limit for linearity is 2% of the analyzer range. All analyzers will be shown to be linear within these limits before proceeding.

The external calibration bias check will be performed by placing the CEM system in sampling mode and injecting a zero and span gas into the sample line at the probe exit. This check shows if there is any sampling system related bias, and also checks the integrity of the sample line.

5.1.3.1 Calibration Gases-DEECO will use EPA Protocol and/or ±2% NIST Traceable gases for calibration as required by the various reference methods employed in this test program. Calibration gases will be selected from previous experience with similar sources and/or from information obtained from the facility engineer prior to sampling. In some cases if the gases that are selected are out of the optimum range of operation then no significant impact of data quality is expected due to the linear nature of the analyzers that were used.

Audit gases, if available from a federal or a state agency, will be analyzed.

5.1.3.2 Sampling Procedures-At the completion of the pretest calibration routine, the CEM system will be ready for operation. No further adjustments of sample flow rates, analyzer zero or span adjustments, or other critical CEM operating parameters will be made until testing and post test calibration were complete.

Each sampling run will be one hour. At the completion for each test run, calibration gases will be used to check between test runs. A zero and the upscale calibration gas closest to the actual emission concentrations will be used for the pretest and post test calibrations.

5.1.4 FLUE GAS MOISTURE CONTENT - EPA METHOD 4

The flue gas moisture content will be determined in conjunction with the EPA Method 26A trains according to the sampling and analytical procedures outlined in EPA Method 4. (**NOTE:** In order to maintain isokinetic sampling, the sampling rate used may be required to temporarily exceed the EPA Method 4-specified maximum sampling rate of 0.75 CFM, based on observed stack gas pitot readings.) The impingers will be connected in series and will contain reagents as described below. The impingers will be contained in an ice bath in order to assure condensation of the moisture in the flue gas stream. Any moisture that is not condensed in the impingers is captured in the silica gel, therefore all moisture can be weighed and entered into moisture content calculations.

5.1.5 HYDROGEN FLUORIDE AND DIATOMIC CHLORINE - EPA METHOD 26A

Sampling and analytical procedures will be similar to those outlined in EPA Method 26A to determine primarily diatomic chlorine (Cl_2) emissions and hydrogen fluoride (HF) emissions at main stack outlet sampling locations. Duplicate simultaneous trains (a.k.a “paired trains”) for each test run will be used to determine precision.

Sample is collected through a heated glass probe, followed by a heated quartz fiber filter, where stack gas HF and Cl_2 are collected in a series of chilled impingers. The sampling train impingers will contain 50 ml of 0.1N sulfuric acid in the first impinger (optional should high moisture warrant a modified short stem), 100 ml of 0.1N sulfuric acid in the second and third, an optional fourth empty impinger, 100 ml of 0.1N NaOH in the fifth and sixth and 200 grams of silica gel in the last impinger. (**NOTE:** For plants with scrubbers, the optional cyclone may be used since the gas stream may be saturated with moisture.)

Sampling will be conducted isokinetically ($\pm 10\%$) with readings of flue gas parameters recorded at traverse points selected according to EPA Method 1. Leak-checks on the Method 26A sampling train will be performed before and after each sampling run and optionally for any port change. In the event that any portion of the train needed to be disassembled and reassembled (i.e., due to filter or resin changes), leak-checks are performed. The sampling train leak-checks and leakage rate (where applicable) are documented on the field test data sheet for each respective run. All leak checks will be acceptable.

The glass button hook nozzle and probe liner will be constructed of borosilicate glass or quartz. The filter holder will be constructed of borosilicate glass with a Teflon frit filter support and a sealing gasket. A heated quartz fiber filter, for sources above 210°C , or PTFE-bonded glass fiber filter will be used. The probe and filter housing will be heated to above 248°F and not exceed an upper boundary of 273°F . Probe liners and filter holders will be cleaned thoroughly prior to testing.

The Method 26A trains will be operated isokinetically for a minimum of 60 minutes and collect a minimum of 1 dry, standard cubic meter (DSCM). Pretest preparations, preliminary determinations, and leak check procedures will be those outlined in EPA Method 5.

After completion of sampling the train will be leak checked and transferred to the sample recovery trailer. All leak checks will be acceptable. The impingers will be weighed to determine moisture gain in accordance with EPA Method 4.

Sample recovery will involve quantitative recovery of the sulfuric acid impinger contents and the NaOH impinger contents into separate tare-weighed, precleaned polyethylene sample containers.

The nozzle, probe, filter and filter housing will not be recovered.

The contents of sulfuric acid impingers, including the contents if any of the empty (2nd knockout or fourth) impinger will be quantitatively transferred to the tare-weighed, precleaned polyethylene sample container, followed by three rinses with deionized (DI) water of the impingers and all connecting glassware (including the connecting glassware to the first impinger) placed in the same H₂SO₄ container. The container will be labeled and weighed to determine the final sample volume. The liquid level will be marked on the sample container.

The contents NaOH impingers will be quantitatively transferred to a second tare-weighed, precleaned polyethylene sample container, followed by three rinses with DI water of the impingers and all connecting glassware placed in the same NaOH container. The container will be labeled and weighed to determine the final sample volume. The liquid level will be marked on the sample container

Sample recovery from each train will include:

1. Container No. 1 - Contents 1st knockout, H₂SO₄ impingers, and 2nd knockout and, and DI rinse of impingers and connecting glassware; and
2. Container No. 2 - Contents NaOH impingers, and DI rinse of impingers and connecting glassware.

Additional quality control consists of collecting and analyzing a field blank train for every three test runs. The blank train is to be assembled from a used train, leak checked and sit for a period equal to the sampling time (i.e, 1-hr). The blank train data will be used to determine the method detection limit for the test program target analytes (ie. The lowest number that could be detected), and compared to stack emissions.

Reagent blanks of 0.1 N H₂SO₄, 0.1N NaOH, and DI water will be collected and archived for later analysis should there be any issues with the field blank train samples

The H₂SO₄ impinger solutions will be analyzed using ion chromatography techniques for fluoride ions (F⁻) (EPA SW-9057). Duplicate analyses will be performed on the samples and a reagent blank. Precision will be demonstrated by duplicate injection of each sample, the results of each individual analysis must be within 5% of their mean to be acceptable. If the precision criteria is not met, analysis of the sample is repeated until consecutive injections meet the criteria.

The NaOH impinger solutions will be treated with sodium thiosulfate to ensure complete conversion of hypochlorous acid (HClO) to chloride ions (Cl⁻). The resulting solution will be analyzed using ion chromatography techniques for chloride ions (EPA SW-9057). Duplicate analyses will be performed on the samples and a reagent blank. Precision will be demonstrated by duplicate injection of each sample, the results of each individual analysis must be within 5% of their mean to be acceptable. If the precision criteria is not met, analysis of the sample is repeated until consecutive injections meet the criteria.

All EPA Method 26A HF/Cl₂ samples will be analyzed by Element One of Wilmington NC. Refer to Section 1, Figure 1.1 for contact information.

The relative deviation (RD) will be calculated as described in EPA Method 30B between the Cl₂ concentrations measured with the paired trains.

5.1.6 HYDROGEN CYANIDE AND HYDROGEN FLUORIDE - EPA METHOD 320

EPA Method 320 will be performed to determine emissions of concentrations of HCN and HF. Three, 1-hour sampling runs will be conducted under representative process and control system operating conditions.

The gas sample will be extracted from the stack through a glass-lined probe and filter heated to 375° F. For external calibration checks and analyte spikes, the gases will be introduced in front of the heated filter. Any excess calibration gas will be diverted through the sample probes into the source. Outflow of gas from the heated filter enclosure was transported through a Teflon sample line heated to 375° F. For this source approximately 100' of sample line will be required. The heated sample line will be connected directly to the FTIR sample cell. Using heat-traced Teflon tubing the exit of the FTIR cell will be connected to a sample pump with a heated stainless steel pump head. The pump discharge will be directed to a proprietary chiller-type gas conditioner to remove moisture prior to delivery sample gas to the O₂/CO₂ monitors.

The distribution of the gas sample to the monitors will be accomplished using a panel equipped with valves and rotometers. The gas sample was then divided and directed to the analyzers.

FTIR sample cell will be maintained at 191° C and connected to a MKS Instruments Multigas 2030 Fourier Transform Infrared Spectrometer and Detector.

The FTIR spectrometer will measure vapor phase organic or inorganic compounds which absorb energy in the mid-infrared spectral region, about 400 to 4000 cm⁻¹ (25 to 2.5 μm). Continuous measurement will be made by matching sample absorbance bands with bands in reference spectra, and comparing sample band intensities with reference band intensities.

The principle limitation to FTIR spectroscopy are the presence of interfering compounds that also absorb energy in the mid-infrared spectral region. In a cement kiln stack gas matrix, water vapor (H₂O) and carbon dioxide (CO₂) are the primary interferents that must be incorporated into the identification and quantitation method.

The FTIR software performs the computation for a single compound by subtracting all the other compounds (interferants and target) from the absorbance spectra and quantifies the single compound based on the remain absorbance. The FTIR software provides a Standard Error Calculation (SEC) value that is an indication of how well the identification and quantitation has been performed. A high SEC indicates that other interferants have not been accounted for in the analysis method, and a low SEC is indicative of greater confidence measurement.

The instrument is operated with a resolution of 0.5 cm⁻¹ with 4x zero filling. Beer-Norton Medium apodization is used with amplitude phase correction.

For this RTR test program, following specific QA/QC activities for EPA Method 320 will be performed and criterium met.

5.1.6.1 Laboratory QA/QC Activities Before Field Test Program- Before field testing occurs, the following QA/QC activities will be conducted;

- 1) Seven consecutive samples of dry nitrogen through the sampling system will be acquired and used to calculate the standard deviation for each of the test program target analytes multiplied

- by a factor of 3. These data will be considered representative of detection limits for this test program and are to be compared to the 0.5 ppm required DL;
- 2) From these seven dry nitrogen samples, the results for the Signal-to-Noise Ratio (SNR) @ 2500 cm^{-1} should be >2500 , at 64 scans and the results for single beam intensity @ 2500 cm^{-1} should be >0.9 ; and
 - 3) Upon receipt of HCN calibration gases a direct analysis will be performed to verify FTIR response agrees with tag value within 5%. Analysis results will be reported to PCA to assess need for modified reference spectra and/or change to direct analysis criterion:

5.1.6.2 QA/QC Activities During Field Test Program- During the field test program, following QA/QC activities will be performed and criterium met;

- 1) On each test day prior to any testing, an instrument background will be collected using dry nitrogen directed to the gas cell. The background will be collected with at least 128 scans;
- 2) The probe, filter, sample line and all sample system components in contact with effluent will be maintained at or above 375°F or 191°C (consistent with FTIR calibration temperature) to avoid any possible “cold spots;”
- 3) Heated sample lines will be ≤ 100 feet wherever possible, and not longer than 200 feet, without prior approval for unusual test circumstances;
- 4) A system zero with all sampling system components at operating temperature will be performed by injecting nitrogen at the sample probe and through sample filter and entire measurement system. After zero equilibration has been achieved, all measurement components will be quantified for at least 128 scans;
- 5) Ambient air will be sampled until equilibration of the measurement system has been achieved and all measurement components will be quantify for at least 128 scans;
- 6) The sample probe will be position at effluent measurement point and sampling will continue until equilibration of the measurement system has been achieved. At this point, the effluent concentrations will be quantified with two consecutive 64-scan samples as the initial native concentration for the dynamic spike;
- 7) Analyte spiking will be conducted for HCN before the first test run, and after each successive test run for a minimum of 4 spikes per test condition. (Additional spikes would be required before and after corrective action for the sampling or analysis system and/or before and after removing the sampling system from the stack.) These results will determine accuracy;
- 8) The spike gas injections will be maintained at 10% or less of total sample volume. The spike gas concentration and flow rate will be selected to approximately double the native effluent concentration, or the spike will be conducted to add 3-4 ppm to native concentration, whichever results in greater spiked concentration. Spike recovery results will be within $\pm 20\%$ of the expected value or ± 0.5 ppm, whichever is least restrictive. (Specific HCN gases will be manufactured for this test program in the range of 50-100 ppm to provide spikes in the 5-10 ppm range, or lower. An SF_6 or appropriate tracer will be used to calculate the exact spike gas dilution ratio of 10% or less;)
- 9) After the dynamic spike, nitrogen will be sent through the sampling system until all traces of spike gas are removed and lines are proven below DL for target analytes;
- 10) The nitrogen purge will be discontinued and the sampling system will be allowed to equilibrate with stack gas before starting a test run. The first two consecutive 64-scan samples of a sample run will be used for the final native concentration. Residual results for HCN and HF will be verified to be less than 0.2-0.3 ppm for data acceptance, or less than 5% of the measured value, whichever is least restrictive. Calculate the standard deviation for each of the test program target analytes for seven consecutive sample spectra from Run 1,

- multiplied by a factor of 3. These data will be compared to the pre-test system nitrogen standard deviation results and also included in the facility test report;
- 11) The SNR @ 2500 cm^{-1} , at 64 scans, and the results for single beam intensity @ 2500 cm^{-1} will be verified to meet the >2500 and >0.9 criterium; respectively. The analyte spiking for HCN and subsequent system nitrogen injection will be conducted after each test run. Continue sequence until at least three valid runs per test condition are completed.

6.0 QUALITY ASSURANCE/QUALITY CONTROL ACTIVITIES

6.1 QA/QC PROCEDURES

The QA/QC procedures for this RTR test program are summarized in Table 6-1.

TABLE 6-1 QA/QC PROCEDURES AND REQUIREMENTS

Target Analyte	Test Method	Detection Limit	QA/QC
HCN	EPA Method 320	0.5 ppm	<p>Increase scans if needed to achieve detection limits. Increasing to 400 from relative 64 (gives a 2.5 S/N advantage).</p> <p>HCN spiking before and after each run by adding 10% or less spike to approximately double the native effluent concentration, or conduct spike to add 3-4 ppm to native concentration, whichever results in greater spiked concentration.</p> <p>Spike recovery results shall be within $\pm 20\%$ of the expected value or ± 0.5 ppm, whichever is least restrictive</p> <p>5% pre-to-post run calibration transfer standard (CTS) requirement</p>
HF		0.2-0.3 ppm	Rely on CTS (5%), HCN and tracer gas responses to validate HF FTIR data
Cl ₂	EPA Method 26A	~ 0.07 mg/m ³ (~0.2 ppm)	<p>Duplicate Simultaneous Trains; Collect minimum of 1 dscm for each sample train. Acceptance criteria for paired samples: 10% Relative Deviation or 0.2 ppm absolute difference, whichever is least restrictive. Insert dry impinger between acid and base impingers</p>
Effluent Flow Rate	EPA Methods 1-4	Not Applicable	<p>As per M26A isokinetic testing or separately by Methods 1-3. FTIR measurements for H₂O.</p> <p>Wind Tunnel calibrated pitot tube having a Cp of 0.84 or less is required for all flow measurements.</p> <p>Compare preliminary velocity traverse measurements and sample run flow rate measurements to installed certified flow rate monitor. Investigate and resolve differences greater than 10% of average flow rate.</p>
O ₂	EPA Method 3A	Not Applicable	<p>Analyte concentrations corrected @ 7% O₂</p> <p>Span is 10%, 15%, or 20% (for co-mingled stacks only)</p> <p>Acceptance criteria are 0.2% O₂ difference for analyzer calibration error, and 0.3% O₂ for system bias checks, and zero and upscale drift checks.</p>

6.2 SAMPLE IDENTIFICATION AND CUSTODY

Sample custody procedures for this program are based on EPA recommended procedures. Since samples will be analyzed by one or more laboratories as well as in the field, the custody procedures emphasize careful documentation of sample collection and field analytical data and the use of chain of custody records for samples being transported. The procedures which will be used are discussed below.

The project manager will be responsible for ensuring that proper custody and documentation procedures are followed for the field sampling and field analytical efforts. He will be assisted in this effort by key sampling personnel involved in sampling recovery.

Samples will be collected, transported, and stored in clean containers which are constructed of materials inert to the analytical matrix such as glass jars. Only containers which allow air tight seals will be used. Amber glass jars will be employed when containers are needed to inhibit photochemical reactions.

All sampling data, including information regarding sampling times, locations, and any specific considerations associated with sample acquisition will be recorded on preformatted data sheets. All samples will be given unique, identifying alphanumeric sample codes which will serve to track samples from the field to the laboratory.

Samples will be stored for transport from the lab to the field to the lab in storage boxes constructed in a fashion which minimizes movement and thus prevents breakage of containers. For example, boxes used for transporting glass containers will have foam inserts with form-fitting cutouts. Sample transport boxes will be locked except when in use. Vans containing equipment and samples will be locked whenever they are left unattended.

A daily activity log will be maintained by the project supervisor. This will be an informal log used to record various types of information, such as minor problems which arise, sketches of sampling locations, names and phone numbers of plant contacts, daily activity summaries, etc.

This section provides information regarding the organization of the sampling and analytical program. The following details the key positions and their responsibilities. Once personnel have been assigned to these positions, their qualifications will be provided as an addendum.

The organization of the project team, including QA functions, is shown in the project organization chart (see Figure 1.1).

7.0 SAMPLE CUSTODY

Sample custody procedures for this program are based on EPA recommended procedures. Since samples will be analyzed by one or more laboratories as well as in the field, the custody procedures emphasize careful documentation of sample collection and field analytical data and the use of chain of custody records for samples being transported. The procedures which will be used are discussed below.

7.1 FIELD SAMPLING OPERATIONS

The project manager will be responsible for ensuring that proper custody and documentation procedures are followed for the field sampling and field analytical efforts. He will be assisted in this effort by key sampling personnel involved in sampling recovery.

Samples will be collected, transported, and stored in clean containers which are constructed of materials inert to the analytical matrix such as glass jars. Only containers which allow air tight seals will be used. Amber glass jars will be employed when containers are needed to inhibit photochemical reactions.

All sampling data, including information regarding sampling times, locations, and any specific considerations associated with sample acquisition will be recorded on preformatted data sheets. All samples will be given unique, identifying alphanumeric sample codes which will serve to track samples from the field to the laboratory.

Samples will be stored for transport from the lab to the field to the lab in storage boxes constructed in a fashion which minimizes movement and thus prevents breakage of containers. For example, boxes used for transporting glass containers will have foam inserts with form-fitting cutouts. Sample transport boxes will be locked except when in use. Vans containing equipment and samples will be locked whenever they are left unattended.

A daily activity log will be maintained by the project supervisor. This will be an informal log used to record various types of information, such as minor problems which arise, sketches of sampling locations, names and phone numbers of plant contacts, daily activity summaries, etc.

7.2 ANALYTICAL OPERATIONS

Analytical operations will be performed on-site in the laboratory as well as in the remote laboratories. Samples analyzed by outside laboratories are transported with a Change of Custody form. This form will list sample identifications, analytical parameters, sample matrices, anticipated date of results, and other relevant information necessary to ensure the appropriate analyses are performed and to document the progress of the samples.

8.0 INTERNAL QUALITY CONTROL CHECKS

Specific quality control (QC) procedures will be followed to ensure the continuous production of useful and valid data throughout the course of this test program. The QC checks and procedures described in this section represent an integral part of the overall sampling and analytical scheme. Strict adherence to prescribed procedures is quite often the most applicable QC check. A discussion of both the sampling and analytical QC checks that will be utilized during this program is presented below.

8.1 EQUIPMENT INSPECTION AND MAINTENANCE

Each item of field test equipment will be assigned a unique, permanent identification number. An effective preventative maintenance program is necessary to ensure data quality. Each item of equipment returning from the field will be inspected before it is returned to storage. During the course of these inspections, items are cleaned, repaired, reconditioned, and recalibrated where necessary.

Each item of equipment transported to the field for this test program will be inspected again before being packed to detect equipment problems which may originate during periods of storage. This minimizes lost time on the job site due to equipment failure.

Occasional equipment failure in the field is unavoidable despite the most rigorous inspection and maintenance procedures. For this reason, replacement equipment for all critical sampling train components will be transported to the job site.

8.2 EQUIPMENT CALIBRATION

New items for which calibration is required will be calibrated before initial field use. Equipment whose calibration status may change with use or time will be inspected in the field before testing begins and again upon return from each field use. When an item of equipment is found to be out of calibration, it will be repaired and recalibrated or retired from service. All equipment will be periodically recalibrated in full, regardless of the outcome of these regular inspections.

Calibrations will be conducted in a manner, and at a frequency, which meets or exceeds U.S. EPA specifications. The calibration procedures outlined in the EPA Methods will be followed. When these methods are inapplicable, methods such as those prescribed by the American Society for Testing Materials (ASTM) will be used.

Data obtained during calibrations will be recorded on standardized forms, which will be checked for completeness and accuracy by the quality assurance manager. Data reduction and subsequent calculations will be performed using computer facilities. Calculations will be checked at least twice for accuracy. Copies of calibration forms will be included in the test or projects reports.

Emissions sampling equipment requiring calibration includes pitot tubes, pressure gauges, thermometers, dry gas meters and barometers. The following sections elaborate on the calibration procedures to be followed for these items of equipment.

- A: Pitot Tubes.** All Type S pitot tubes used, whether separate or attached to a sampling probe, will be constructed in-house or by a third-party vendor. Each new pitot will

be calibrated in accordance with Section 10.1 of EPA Method 2. Each Type-S pitot tube, calibrated according to these standards, will have an assigned coefficient. This coefficient should not change as long as the pitot tube is not damaged.

Each pitot tube will be inspected visually upon return from the field. If a cursory inspection indicates damage or raises doubt that the pitot remains in accordance with the EPA geometry standards, the pitot tube will be refurbished as needed and recalibrated.

- B: Differential Pressure Gauge.** All meter consoles used are equipped with 10-inch water column (W.C.) inclined-vertical manometers. Fluid manometers do not require calibration other than leak checks. Manometers will be leak checked in the field prior to each test series, and again upon return from the field.
- C: Impinger Thermometer.** Prior to the start of testing, the thermometer used to monitor the temperature of the gas leaving the last impinger will be compared with a mercury-in-glass thermometer which meets ASTM E-1 No. 63F specifications. The impinger thermometer is adjusted if necessary until it agrees within 2°F of the reference thermometer. If the thermometer is not adjustable, it is labeled with a correction factor.
- D: Dry Gas Meter Thermometer.** The thermometer used to measure the temperature of the metered gas sample will be checked prior to each field trip against an ASTM mercury-in-glass thermometer. The dry gas meter thermometer is acceptable if the values agree within $\pm 5.4^\circ\text{F}$. Thermometers not meeting this requirements will be adjusted or labeled with a correction factor.
- E: Flue Gas Temperature Sensor.** All thermocouples employed for the measurement of flue gas temperature are calibrated upon receipt. Initial calibrations will be performed at three points (ice bath, boiling water, and hot oil). An ASTM mercury-in-glass thermometer will be used as a reference. The thermocouple is acceptable if the agreement is within 1.5 percent (absolute) at each of the three calibration points.

Before and after each field use, the reading from the flue gas thermocouple-potentiometer combination will be compared with an ASTM mercury-in-glass reference thermometer at ambient conditions. If the two agree within ± 1.5 percent (absolute), the thermocouple and potentiometer are considered to be in proper working order.

- F: Dry Gas Meter and Orifice.** Two procedures will be used to calibrate the dry gas meter and orifice simultaneously. The full calibration will be a complete laboratory procedure used to obtain the calibration factor of the dry gas meter. Full calibrations will be performed over a wide range of orifice settings. A simpler procedure, the post-test calibration, will be designed to check whether the calibration factor has changed.

A dry gas meter that is calibrated annually against a spirometer or a set of calibrated critical orifices will be used as a transfer standard. During the annual calibration, triplicate calibration runs will be performed at seven flow rates ranging from 0.25 to 1.40 cfm.

G: Dry Gas Meter. Each metering system receives a full calibration at the time of purchase and a post-test calibration after each field use. If the calibration factor, γ , deviates by less than five percent from the initial value, the test data are acceptable. If γ deviates by more than 5 percent, the meter is recalibrated and the meter coefficient (initial or recalibrated) that yields the lowest sample volume for the test runs is used.

EPA Method 5 requires another full calibration anytime the post-test calibration check indicates that γ changed by more than 5 percent. Standard practice is to adjust and recalibrate the dry gas meter anytime γ is found to be outside the range of 0.96 to 1.04. Post-test calibrations will be performed after each field test series per EPA Method 5, section 16.3 procedures.

H: Orifice. An orifice calibration factor will be calculated for each flow setting during a full calibration. If the range of values does not vary by more than 0.20 in H₂O over a range of 0.4 to 4.0 in H₂O, the arithmetic average of the values obtained during the calibration is used.

I: Barometer. Each field barometer will be adjusted before each test series to agree within ± 0.1 inches of a reference aneroid barometer. The reference barometer will be checked against the station pressure value (corrected for elevation difference) reported by the National Weather Service.

8.3 SAMPLING QUALITY CONTROL PROCEDURES

The following pretest QC checks will be conducted:

- All sampling equipment will be thoroughly checked to ensure clean and operable components.
- Equipment will be inspected for possible damage from shipment.
- The oil manometer or Magnehelic gauge used to measure pressure across the Type S pitot tube will be leveled and zeroed.
- The number and location of the sampling traverse points will be checked before taking measurements.
- The temperature measurement system will be visually checked for damage and operability by measuring the ambient temperature prior to each traverse.

In addition to the general QC procedures listed above, QC procedures specific to each sampling method will also be incorporated into the sampling scheme. These methods and specific procedures are discussed below.

A: Sampling Train QC checks. The following QC procedures will be emphasized:

Prior to Start of Tests

- Keep all cleaned glassware and sample train components sealed until train assembly.
- Assemble the sampling trains in an environment free from uncontrolled dust.
- Visually inspect each sampling train for proper assembly.
- Perform pretest calculations to determine the proper sampling nozzle size.

Prior to Each Test Run

- Visually inspect the sampling nozzle.
- Visually inspect the Type S pitot tube.
- Leak check each leg of the Type S pitot tube.
- Leak check the entire sampling train.

During Each Test Run

- Readings of temperature and differential pressure will be taken at each transverse point.
- All sampling data and calculations will be recorded on preformatted data sheets.
- All calibration data forms will be reviewed for completeness and accuracy.
- Any unusual occurrences will be noted during each run on the appropriate data form.
- The project supervisor will review sampling data sheets daily during testing.
- Properly maintain the roll and pitch axis of the Type S pitot tube and the sampling nozzle.
- Leak check the train before and after any move from one sampling port to another during a run (at DEECO's option) or if a filter change takes place.
- Conduct additional leak checks if the sampling time exceeds 4 hours.
- Maintain the probe, filter, and impingers at the proper temperatures.
- Maintain ice in the ice bath at all times.
- Make proper readings of the dry gas meter, delta P and delta H, temperature, and pump vacuum during sampling at each traverse point.
- Maintain isokinetic sampling within $\pm 10\%$ of 100%.

After Each Test Run

- Visually inspect the sampling nozzle.
- Visually inspect the Type S pitot tube.
- Leak check each leg of the Type S pitot tube.
- Leak check the entire sampling train.

B: QC for Volumetric air flow rate determinations

Flue Gas Velocity. Data required to determine the flue gas velocity will be collected using the methodology specified in EPA Method 2. Quality control procedures are as follows.

- Visually inspect the Type S pitot tube before and after sampling.
- Leak check both legs of the pitot tube before and after sampling.
- Check the number and location of the sampling traverse points before taking measurements.

Flue Gas Molecular Weight. In the event that that integrated bag samples are to be used for determination of flue gas molecular weight, EPA Method 3 will be the sampling technique specified. Quality control will focus on the following procedures:

- The sampling train will be leak checked before and after each run.
- A constant sampling rate will be used in withdrawing a sample.
- The sampling train will be purged prior to sample collection.
- The sampling port will be properly sealed to prevent air in-leakage.

Moisture Content. The moisture content of the gas stream will be determined using the technique specified in EPA Method 4. The following QC checks will be performed:

- The sampling train will be leak checked before and after each run.
- Ice will be maintained in the ice bath throughout each run to insure an exit temperature (after the silica gel impinger) of $\leq 67^{\circ}\text{F}$.

8.4 ANALYTICAL QUALITY CONTROL PROCEDURES

All analyses for this program will be performed using accepted laboratory procedures in accordance with the specified analytical protocols. Adherence to prescribed QC procedures will ensure data of consistent and measurable quality. Analytical QC will focus upon the use of control standards to provide a measure of analytical precision and accuracy. Also, specific acceptance criteria are defined for various analytical operations including calibrations, control standard analyses, drift checks, blanks, etc. The following general QC procedures will be incorporated into the analytical effort:

- The on-site project manager will review all analytical data and QC data on a daily basis for completeness and acceptability.
- Analytical QC data will be tabulated using the appropriate charts and forms on a daily basis
- Copies of the QC data tabulation will be submitted to the quality assurance manager following the completion of the test program.
- All hard copy raw data (i.e., chromatograms, computer printouts, etc.) will be maintained in organized files.

Specific analytical QC procedures for the Orsat analyzer (if used) are listed below.

- The analyzer will be leveled and the fluid levels zeroed prior to use.
- The analyzer will be leak checked prior to use.
- The analyzer will be thoroughly purged with sample prior to use.
- The analyzer will be checked by analyzing an ambient air sample.

EPA Method 26A Sample Analysis QC Checks are listed below.

- Calibration curve consisting of 4 calibration levels that bracket the expected sample range. Dilute samples as necessary to reach the calibration range;
- Duplicate analysis of calibration standards, before and after sample analysis, with duplicate injections being within 5% of their mean;
- Duplicate analysis of reagent blanks, quality control samples and field samples with duplicate injections being within 5% of their mean;
- Matrix spike samples may be prepared and analyzed. Matrix spike recoveries should be 90-110%
- A field blank will be carried through the procedure and analyzed with the field samples.
- An audit sample will be analyzed for if available from two or more independent, Approved Audit Sample Providers no less than 60 days prior to the test effort.

9.0 REPORTING AND DATA REDUCTION REQUIREMENTS

9.1 DATA REPORTING

The reporting units for HCN, HF, and Cl₂ will be in parts-per-million by volume, wet basis (ppm_{v,d}), parts-per-million by volume, dry corrected to 7% oxygen (ppm_{v,d}@7%O₂), pounds-per-hour (lbs/hr), and pounds-per-ton of clinker (lbs/ton). Additional supporting data for CO₂, O₂, and H₂O concentrations and volumetric flow rates (actual cubic feet-per-minute, wet, standard cubic feet-per-minute, and dry, standard cubic feet-per-minute) will be reported. The clinker production, in short tons-per-hour (TPH) will be reported.

Any data that is not acceptable because of technical difficulties will be indicated, and an explanation of the technical problem will be given. All related QC and calibration data will be in the final report.

9.2 REPORT CONTENTS

Copies of the test report will be submitted after the test series has been completed. Results reported will include, but not be limited to emission rates and concentrations of gaseous pollutants, and process sample determinations, any liquid stream constituents determinations, and any other type of data requested. This report will also include a list of all personnel present during testing, summary results, descriptions of test procedures used, a description of the source and its operation during testing, test locations drawings, example calculations, raw field data, and equipment calibrations.

9.3 DATA REDUCTION

Care will be exercised to ensure hand recorded data is written accurately and legibly. Additionally, the use of prepared data recording forms, conveniently formatted, is an important aid to verify that all necessary data items are recorded. The collected field and laboratory data will be reviewed by the analyst and the Project Manager.

The Project Manager will reduce and validate all of the sampling and analytical data that is collected. The sampling data will include flow measurements, calibrations, etc. Each laboratory will reduce all analytical results prior to their submission to the Project Manager. The analytical data will be used to determine concentrations and emission rates of the compounds of interest.

Data reduction follows guidelines published in EPA Reference Methods, where applicable, and by guideline documents where EPA Reference Methods are not available. Validated computer programs will be used to calculate all reported values.

9.4 DATA VALIDATION

A second technical review of the data will be performed and documented by a qualified scientist other than the one who performed the actual analyses. The second reviewer will include evidence (e.g., check marks, recalculations, etc.) that show which data points were checked. Finally, the second reviewer will sign and date the cover page of the data packet or the record that was reviewed.

In-situ measurements will be validated by demonstrated acceptable post-test leak checks and calibration verifications according to the referenced method used.

Analysis data may be validated according to defined criteria by a secondary reviewer or by the analyst. At a minimum and if applicable, analysis data will be validated according to the following criteria (additional method-specific criteria or project requirements may apply):

- Sampling records complete and traceable
- All appropriate QC samples included with the analytical batch and reported with the sample results
- Routine tuning, calibration and inspection of analytical instrumentation documented and performed prior to analyses
- Initial and continuing calibration criteria met
- Method/reagent blanks confirm no background contamination
- Surrogate recoveries within criteria
- Qualitative sample results (e.g., retention times, mass spectra, isotopic ratios) consistent with standard data
- Sample data within the calibrated range of the instrument
- Chromatograms or other raw data consistent with computer-generated quantitation reports
- Accuracy of intermediate data manipulations, transcribed numbers and/or final reported results verified
- Reference standards, instrumentation, sample identification, analysts, methodology, and sequence of processing clearly identified and traceable in the project records
- Lost data or corrective actions documented (e.g., loss of sample, reanalysis, redilutions, additional cleanup steps, alternative calculations etc.)
- Data that does not meet the validation requirements flagged accordingly
- Data reported in the correct units (e.g., "ppm" should not be used without specifying volume or mass units; "ug/g" are preferred units for data reporting)

10.0 PLANT ENTRY AND SAFETY

10.1 SAFETY RESPONSIBILITIES

The Project Manager is responsible for ensuring compliance with plant entry, health, and safety requirements. The Facility Contact (refer to Section 1.2) as the authority to impose or waive facility restrictions. The Project Manager has the authority to negotiate with facility person any deviations from the facility restrictions.

10.2 SAFETY PROGRAM

DEECO has a comprehensive health and safety program that satisfies Federal OSHA and MSHA requirements. The basic elements include: (1) written policies and procedures, (2) routine training of employees and supervisors, (3) medical monitoring, (4) use of personal protection equipment, (5) hazard communication, (6) pre-mobilization meetings with Holcim personnel and DEECO test team personnel, and (7) routine surveillance of the on-going test work.

10.3 SAFETY REQUIREMENTS

All test personnel will adhere to the following standard safety and precautionary measures as follows:

- 1) Confine activities to test area only;
- 2) Wear hard hats at all times on-site, except inside sample recovery trailers and mobile CEM laboratory;
- 3) Wear protective shoes or boots in test area;
- 4) Wear protective glasses or goggles at the outlet test sites, and other areas as designated;
- 5) Have readily available first aid equipment and fire extinguishers.

Before or on the first day on-site, the Project Manager will fill out the Emergency Response Procedure form and provide copies to be posted at each test site.

Appendix A

Sampling and Analytical Methods

The sampling and analytical methods for this sampling effort can be found at the following website:

Promulgated EPA test methods, 40 CFR 60 (Methods 1-4, 26A, and 320)

<https://www.epa.gov/emc/emc-promulgated-test-methods>