

Permit Information

Report Year: 2019NPDES ID: IDR053248

Facility Information

Facility Name: COOPER PIT

Facility Point of Contact

First Name Middle Initial Last Name: Patrick ClarkPhone: 801-430-3116 Ext.: Email: pclark@stakeperson.com

Facility Mailing Address

Address Line 1: HIGHWAY 26 AND WAGNER ROADAddress Line 2: SUITE 100City: CALDWELLZIP/Postal Code: 83606State: IDCounty or Similar Division: CANYON

General Findings

Provide a summary of your past year's routine facility inspection documentation (see Part 3.1.2 of the permit). In addition, if you are an operator of an airport facility (Sector S) that is subject to the airport effluent limitations guidelines, and are complying with the MSGP Part 8.S.8.1 effluent limitation through the use of non-urea-containing deicers, provide a statement certifying that you do not use pavement deicers containing urea (e.g., "Urea was not used at [name of airport] for pavement deicing in the past year and will also not be used in 2015." (Note: Operators of airport facilities that are complying with Part 8.S.8.1 by meeting the numeric effluent limitation for ammonia do not need to include this statement.)

BMP's maintained as needed.

Provide a summary of your past year's quarterly visual assessment documentation (see Part 3.2.2 of the permit).

No visible indicators of significant pollution. Turbidity within State water quality parameters

For any four-sample (minimum) average benchmark monitoring exceedance, if after reviewing the selection, design, installation, and implementation of your control measures and considering whether any modifications are necessary to meet the effluent limits in the permit, you determine that no further pollutant reductions are technologically available and economically practicable and achievable in light of best industry practice, provide your rationale for why you believe no further reductions are achievable (see Part 6.2.1.2 of the permit). Enter "NA" if not applicable.

Exceeded nitrate / nitrite benchmark for Q1, 3, 4. No qualifying storm event during Q2. Site is former cattle grazing pasture. Boise area is know for high nitrate / nitrite levels in shallow groundwater. TSS met Boise River impaired water limitations. No additional BMP's available.

Provide a summary of your past year's corrective action documentation (See Part 4.4 of the permit). (Note: If corrective action is not yet completed at the time of submission of this annual report, you must describe the status of any outstanding corrective action(s).) Also describe any incidents of noncompliance in the past year or currently ongoing, or if none, provide a statement that you are in compliance with the permit.

Documented exceedances of nitrate nitrite benchmark. TSS and turbidity meets MSGP benchmark, Boise River impaired water and Idaho water quality standards. Will continue to monitor

Certification Information

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel

properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I have no personal knowledge that the information submitted is other than true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Certified By: Patrick L. Clark

Certifier Title:

Certifier Email: pclark@stakerperson.com

Certified On: 01/18/2020 10:24 AMET