



DEECO Inc.
3404 Lake Woodard Road
Raleigh, NC 27604
(919) 250-0285 (ph); (919) 250-1835 (Fax)

www.deeco.com

REPORT NO: 022224-3313

PROJECT: 23-3313

DATE: February 22, 2024

TYPE: **Emission Test Report**

**Hydrogen Cyanide, Hydrogen Fluoride
and Diatomic Chlorine
from
a Portland Cement Plant**

**Buzzi Unicem USA, Inc.
Maryneal Cement Plant
Maryneal, TX**

AUTHOR: Scott Steinsberger, Ph.D.

TEST DATES: November 29-30, 2023

FIELD TEAM: Lee Harris, Gage Mayer, and Scott Steinsberger

PREPARED FOR: Buzzi Unicem USA, Inc.
Maryneal Cement Plant
202 CR 306
Maryneal, TX 79535

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1. INTRODUCTION.....	1
2. SUMMARY OF RESULTS.....	5
3. SAMPLING AND ANALYTICAL PROCEDURES.....	8
3.1 Sampling Point Determination - EPA Method 1.....	8
3.2 Flue Gas Velocity and Volumetric Flow Rate - EPA Method 2.....	10
3.3 Outlet Flue Gas Composition - EPA Method 3A.....	10
3.3.1 Calibration Gases.....	11
3.3.2 Sampling Procedures.....	11
3.4 Flue Gas Moisture Content - EPA Method 4.....	11
3.5 Hydrogen Fluoride and Diatomic Chlorine - EPA Method 26A.....	12
3.6 Hydrogen Cyanide and Hydrogen Fluoride - EPA Method 320.....	15
3.6.1 Laboratory QA/QC Activities Before Field Test Program.....	16
3.6.2 QA/QC Activities During Field Test Program.....	16
4. QA/QC PROCEDURES AND RESULTS.....	20
4.1 Sampling Equipment.....	20
4.1.1 Manual Sampling Equipment Calibrations.....	20
4.2 Analytical QA/QC Results.....	21
Appendix A - Emission Summary Tables	
Appendix B - Field Data and CEM/FTIR Data	
Appendix C - Ion Chromatography Analytical Report Data	
Appendix D - Plant Process Data	
Appendix E - Calibration Documents	
Appendix F - Test Participants	
Appendix G - RTR Sampling and Analytical Protocol	

LIST OF TABLES

<u>Table No.</u>		<u>Page</u>
TABLE 1.1	SUMMARY OF HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; BUZZI UNICEM USA, INC. MARYNEAL, TX FACILITY; NOVEMBER 29-30, 2023.	2
TABLE 1.2	SUMMARY OF SAMPLING AND ANALYTICAL PROTOCOLS FOR BUZZI UNICEM USA, INC. MARYNEAL, TX FACILITY	4
TABLE 2.1	BUZZI UNICEM USA, INC. MARYNEAL, TX FACILITY; KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL ON; NOVEMBER 29-30, 2023.....	6
TABLE 2.2	BUZZI UNICEM USA, INC. MARYNEAL, TX FACILITY; KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL OFF; NOVEMBER 30, 2023.....	7
TABLE 3.1	PAIRED METHOD 26A SAMPLING TRAIN DIATOMIC CHLORINE CONCENTRATION COMPARISON RESULTS FOR THE KILN MAIN STACK; NOVEMBER 29-30, 2023.	14
TABLE 3.2	FTIR PRETEST AND FIELD TEST QA/QC SUMMARY.....	17
TABLE 3.3	ETHYLENE CALIBRATION TRANSFER STANDARD (CTS) AND HYDROGEN CYANIDE ANALYTE SPIKING TEST RESULTS FOR THE KILN MAIN STACK ; NOVEMBER 29-30, 2023.....	19

LIST OF FIGURES

<u>Figure No.</u>		<u>Page</u>
Figure 3.1	Schematic of the Main Stack Sampling Location.	9

1. INTRODUCTION

The United States Environmental Protection Agency (US EPA) has directed the portland cement industry (SIC 3241) to conduct emissions testing as part of the US EPA Risk and Technology Review (RTR). This document provides the emission test results and supporting quality assurance/quality control (QA/QC) measures used to produce standardized data having known precision and accuracy. Collection of accurate, representative, and standardized data for facilities with low emissions is necessary especially in view of MACT standard setting procedures.

The Buzzi Unicem USA, Inc (Buzzi) facility in Maryneal, TX is a 1.1 million ton per year rated cement pyro-processing system. The plant operates one dry-process rotary kiln (Kiln #4) that has a preheater/precalciner (PH/PC). It consists of a ThyssenKrupp Industrial Solution PREPOL AS Calciner. An in-line raw mill provides kiln feed to the system.

The Maryneal facility kiln has a Selective Non-Catalytic Reduction System (SNCR) for NO_x control, a Dry Sorbent Injection (DSI) system for acid gas control, and a baghouse to control particulate matter (PM). The gases from the kiln process exhaust out of a main kiln stack.

A more detailed description of the processes is provided in Section 2 of the RTR Sampling and Analytical Protocol reproduced in Appendix

The Buzzi retained DEECO Inc. (DEECO) to conduct emission tests for for hydrogen cyanide (HCN), hydrogen fluoride (HF), and diatomic chlorine (Cl₂). All sampling runs were be one hour long. Concurrent measurements to determine volumetric flow rate were made.

A summary of the test results is shown in Table 1.1.

TABLE 1.1 SUMMARY OF HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; BUZZI UNICEM USA, INC. MARYNEAL, TX FACILITY; NOVEMBER 29-30, 2023

Test Parameters	Main Stack Raw Mill On	Main Stack Raw Mill Off
Hydrogen Cyanide (FTIR) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	13.1 9.6 0.070	15.4 10.6 0.082
Hydrogen Fluoride (FTIR) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.053 <0.029 <0.0002	<0.047 <0.024 <0.0002
Hydrogen Fluoride (Method 26A) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.31 <0.170 <0.0012	<0.34 <0.175 <0.0014
Diatomic Chlorine (Method 26A) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.06 <0.114 <0.0008	0.20 0.40 0.0031

The sampling and analytical procedures followed are summarized in Table 1.2 and discussed in detail in Section 3.

Testing was performed on the main stack under two conditions, Raw Mill On and Raw Mill Off. One Raw Mill On run was conducted on November 29, 2023. The remaining two Raw Mill On runs and three Raw Mill Off runs were conducted on November 30, 2023.

Sampling was conducted by personnel from DEECO, Inc. of Raleigh, North Carolina. All questions regarding sampling and analytical data should be directed to Dr. Scott Steinsberger of DEECO at (800) 733-3261. The field sampling was completed by Lee Harris, Gage Mayer, and Scott Steinsberger of DEECO.

The remainder of this document summarizes the results, procedures and quality control measures followed for this program. Section 2 contains tabulated air emission results for each parameter of interest. Section 3 summarizes the air emission sampling and analytical procedures performed by DEECO, with a brief description and/or reference to the applicable methodologies. Section 4 discusses the basic quality control elements in place for this program to assure the collection of representative, accurate air emission data.

The appendices provided in this document contain all of the necessary information to verify the reported results. Included as Appendices are: Appendix A - Emission Summary Tables; Appendix B - Field Data and CEM/FTIR Data; Appendix C - Ion Chromatography Analytical Report Data; Appendix D - Plant Process Data; Appendix E - Calibration Documents; Appendix F - Test Participants; Appendix G - RTR Sampling and Analytical Protocol

TABLE 1.2 SUMMARY OF SAMPLING AND ANALYTICAL PROTOCOLS FOR BUZZI UNICEM USA, INC. MARYNEAL, TX FACILITY

Location and Frequency	Test Parameter	Sampling Method	Sampling Procedure	Analysis Method	Analysis Procedure
Kiln Main Stack	Volumetric Flow Rate and cyclonic check	EPA Methods 1 and 2	Velocity and temperature traverses	EPA Methods 1 and 2	Manometer for differential pressure and thermocouple for temperature
	Oxygen and Carbon Dioxide and Stratification Check	EPA Method 3A	Continuous; extractive sample	EPA Method 3A	Paramagnetic for O ₂ and NDIR for CO ₂
	Moisture	EPA Method 4	Condensation	EPA Method 4	Gravimetric
	Hydrogen Fluoride and Diatomic Chlorine (Cl ₂)	EPA Method 26A	Isokinetic integrated sample	EPA Method 26A	Ion chromatography
	Hydrogen Fluoride and Hydrogen Cyanide	EPA Method 320	Continuous; extractive sample	EPA Method 320	Fourier Transform Infrared (FTIR) Spectroscopy

2. SUMMARY OF RESULTS

Emissions sampling was conducted at the Buzzi facility located in Maryneal, TX Sampling was conducted for stack gas flow rate (EPA Methods 1 and 2), stack gas oxygen and carbon dioxide (EPA Method 3A), stack gas moisture (EPA Method 4), stack gas hydrogen fluoride and diatomic chlorine (EPA Method 26A) and stack gas hydrogen cyanide and hydrogen fluoride (EPA Method 320).

Testing was conducted on the main stack under two conditions; Raw Mill On and Raw Mill Off and the results are summarized in Tables 2.1 and 2.2, respectively.

TABLE 2.1 BUZZI UNICEM USA, INC. MARYNEAL, TX FACILITY; KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL ON; NOVEMBER 29-30, 2023

Test Parameter	Main Stack Raw Mill On Run 1	Main Stack Raw Mill On Run 2	Main Stack Raw Mill On Run 3	Main Stack Raw Mill On Average
Time	14:50-15:56	09:20-10:26	10:45-11:51	November 29-30, 2023
Flow Rate (dscfm)	256,850	244,700	251,600	251,050
Oxygen	10.7%	11.4%	11.7%	11.3%
Carbon Dioxide	16.9%	15.2%	14.9%	15.7%
Moisture	13.3%	14.0%	11.1%	12.8%
Hydrogen Cyanide (FTIR)				
ppm _{dry} at 7% O ₂	13.8	13.1	12.4	13.1
pounds-per-hour	10.9	9.2	8.7	9.6
pounds-per-ton of clinker	0.073	0.069	0.067	0.070
Hydrogen Fluoride (FTIR)				
ppm _{dry} at 7% O ₂	<0.050	<0.054	<0.054	<0.053
pounds-per-hour	<0.030	<0.028	<0.028	<0.029
pounds-per-ton of clinker	<0.0002	<0.0002	<0.0002	<0.0002
Hydrogen Fluoride (Method 26A)				
ppm _{dry} at 7% O ₂	<0.29	<0.34	<0.32	<0.31
pounds-per-hour	<0.168	<0.178	<0.163	<0.170
pounds-per-ton of clinker	<0.0011	<0.0013	<0.0013	<0.0012
Diatomic Chlorine (Method 26A)				
ppm _{dry} at 7% O ₂	<0.05	<0.07	<0.06	<0.06
pounds-per-hour	<0.105	<0.123	<0.114	<0.114
pounds-per-ton of clinker	<0.0007	<0.0009	<0.0009	<0.0008

TABLE 2.2 BUZZI UNICEM USA, INC. MARYNEAL, TX FACILITY; KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; RAW MILL OFF; NOVEMBER 30, 2023

Test Parameter	Main Stack Raw Mill Off Run 1	Main Stack Raw Mill Off Run 2	Main Stack Raw Mill Off Run 3	Main Stack Raw Mill Off Average
Time	14:05-15:11	15:39-16:45	17:25-18:31	November 30, 2023
Flow Rate (dscfm)	202,100	208,800	207,350	206,083
Oxygen	9.7%	9.9%	10.0%	9.9%
Carbon Dioxide	18.2%	17.9%	17.8%	18.0%
Moisture	14.7%	13.8%	14.2%	14.2%
Hydrogen Cyanide (FTIR)				
ppm _{dry} at 7% O ₂	15.1	15.7	15.5	15.4
pounds-per-hour	10.4	10.9	10.6	10.6
pounds-per-ton of clinker	0.080	0.085	0.082	0.082
Hydrogen Fluoride (FTIR)				
ppm _{dry} at 7% O ₂	<0.047	<0.047	<0.048	<0.047
pounds-per-hour	<0.024	<0.024	<0.024	<0.024
pounds-per-ton of clinker	<0.0002	<0.0002	<0.0002	<0.0002
Hydrogen Fluoride (Method 26A)				
ppm _{dry} at 7% O ₂	<0.34	<0.34	<0.35	<0.34
pounds-per-hour	<0.174	<0.174	<0.177	<0.175
pounds-per-ton of clinker	<0.0014	<0.0014	<0.0014	<0.0014
Diatomic Chlorine (Method 26A)				
ppm _{dry} at 7% O ₂	0.25	0.11	0.23	0.20
pounds-per-hour	0.49	0.23	0.47	0.40
pounds-per-ton of clinker	0.0038	0.0018	0.0036	0.0031

3. SAMPLING AND ANALYTICAL PROCEDURES

Table 1.2 presents a summary of the overall sampling and analytical protocols used for the test program for the main stack at Buzzi's Maryneal, TX facility. All sampling and analytical methods employed for this test program were performed in accordance with the procedures outlined in the Reference Test Methods contained in the Code of Federal Regulations, Title 40, Part 60, Appendix A (40 CFR 60, Appendix A) and 40 CFR 63, Appendix A.


3.1 Sampling Point Determination - EPA Method 1

The main stack is a vertically-oriented circular stack with an inside diameter of 140.0" inside diameter. The stack gas sampling ports are located approximately 157' 9" (approximately 13.4 duct diameters) above the ID fan breaching and approximately 48' 3" (approximately 4.1 duct diameters) from the stack outlet.

The sampling location met the minimum specifications for selection of a measurement site as outlined in EPA Method 1. Cyclonic flow checks, as described in EPA Method 1 Section 2.4, using the Type-S pitot null procedure and angle measurements at the stack test location were conducted.

A twelve (12) point sampling traverse were made using 3 points in each of 4 sampling ports at the main stack. Each traverse was made at each sampling location using a type-S pitot tube in accordance with EPA Methods 2 procedures. The traverse point locations are provided in Appendix B. Gas temperatures were measured using calibrated Type K thermocouples and digital readout devices. All measurements were performed in accordance with the procedures in EPA Methods 2, and 26A.

A schematic of the main stack is provided in Figure 3-1.



Stack Diameter (D) = 140.0"

Distance to nearest upstream disturbance (A) = 579", 4.1 Duct Diameters

Distance to nearest downstream disturbance (B) = 1893", 13.4 Duct Diameters

Sampling Ports Available = 4

Ports Diameter = 6"

Length of ports L_n = 6.25"

Figure 3.1 Schematic of the Main Stack Sampling Location

The number and location of the sampling or traverse points were determined according to the procedures outlined in EPA Method 1. The traverse point locations are provided in Appendix B. All points were at least 1.0 inches from the stack wall, per Method 1.

3.2 Flue Gas Velocity and Volumetric Flow Rate - EPA Method 2

The flue gas velocity and volumetric flow rate were determined according to the procedures outlined in EPA Method 2. Velocity measurements were using type S pitot tubes conforming to the calibration specifications outlined in EPA Method 2, Section 10.1. Each Type-S pitot tube, calibrated according to these standards, had an assigned coefficient. Differential pressures were measured with fluid manometers. Effluent gas temperatures were measured with chromel-alumel thermocouples equipped with digital readouts.

3.3 Outlet Flue Gas Composition - EPA Method 3A

Outlet flue gas analysis for oxygen (O₂) and carbon dioxide (CO₂) concentrations, and the calculation of percent excess air and flue gas dry molecular weight was performed in accordance with EPA Method 3A.

To evaluate the sampling location and points for FTIR and O₂ sampling, a three-point O₂ concentration stratification test on a line passing through the centroidal area at (for stacks is greater than 2.4 meters) at 0.4, 1.2 and 2.0 meters from the stack or duct wall. The procedures in Section 8.1.2 of Method 7E were followed, but oxygen will be used as parameter as allowed by fourth sentence in Section 8.1.2. The plant O₂ CEMS was used as a control. A criteria of <5% variation from combined mean for each point was used as indication of non-stratification to allow single point sampling at the point closest to the mean.

Per EPA Method 3A for determining molecular weight, continuous extractive sampling will be obtain using the Method 320 sampling system described in Section 3.6.

A portion of the hot , wet gas sample was sent through a condensing system to remove the stack moisture. A portion of the moisture-free gas sample was sent to an O₂/CO₂ analyzer.

Calibration procedures were be performed in accordance with EPA methodology. Analyzers were calibrated before and after each test and a calibration check between each test run.

The pretest calibrations consisted of the following steps:

- Internal (direct) calibration of each analyzer to adjust calibration and check linearity.
- External (through the entire sampling system) calibration to check the system bias on zero and span gases.

The post test calibration consisted of an external system bias calibration check.

The analyzer calibrated using a certified zero and span (mid or high range) gas. Zero and span

gases were directed to each analyzer through the appropriate plumbing, the calibration gas flow rates were adjusted to the correct flow rate and the analyzer was adjusted with the appropriate span pot.

After the analyzer was properly adjusted the linearity was checked using a low and high range calibration gas. The maximum allowable limit for linearity is 2% of the analyzer range and all analyzers were shown to be linear within these limits before proceeding.

The external calibration bias check were performed by placing the CEM system in sampling mode and injecting a zero and span gas into the sample line at the probe exit. This check showed if there is any sampling system related bias, and also checks the integrity of the sample line.

3.3.1 Calibration Gases

DEECO used EPA Protocol and/or $\pm 2\%$ NIST Traceable gases for calibration as required by the various reference methods employed in this test program. Calibration gases were selected from previous experience with similar sources and/or from information obtained from the facility engineer prior to sampling. In some cases if the gases that are selected are out of the optimum range of operation then no significant impact of data quality is expected due to the linear nature of the analyzers that were used.

Specific HCN gases were manufactured for this test program in the range of 50-100 ppm to provide spikes in the 5-10 ppm range, or lower; with an SF₆ or appropriate tracer used to calculate the exact spike gas dilution ratio of 10% or less.

No audit gases from a federal or a state agency were provided.

3.3.2 Sampling Procedures

At the completion of the pretest calibration routine, the CEM system was ready for operation. No further adjustments of sample flow rates, analyzer zero or span adjustments, or other critical CEM operating parameters were made until testing and post test calibration were complete.

Each sampling run was one hour. At the completion for each test run, calibration gases were used to check between test runs. A zero and the upscale calibration gas closest to the actual emission concentrations were used for the pretest and post test calibrations.

3.4 Flue Gas Moisture Content - EPA Method 4

The flue gas moisture content was determined in conjunction with the EPA Method 26A trains according to the sampling and analytical procedures outlined in EPA Method 4. (**NOTE:** In order to maintain isokinetic sampling, the sampling rate used may have been required to temporarily exceed the EPA Method 4-specified maximum sampling rate of 0.75 CFM, based on observed stack gas pitot readings.) The impingers were connected in series and contained reagents as described below. The impingers were contained in an ice bath in order to assure condensation of the moisture in the flue gas stream. Any moisture that is not condensed in the impingers was captured in the silica gel, therefore all moisture was weighed and entered into moisture content calculations.

3.5 Hydrogen Fluoride and Diatomic Chlorine - EPA Method 26A

Sampling and analytical procedures were those outlined in EPA Method 26A to determine primarily diatomic chlorine (Cl_2) emissions and hydrogen fluoride (HF) emissions at main stack outlet sampling locations. Duplicate simultaneous trains (a.k.a “paired trains”) for each test run were used to determine precision.

Sample was collected through a heated glass probe, followed by a heated Teflon filter, where stack gas HF and Cl_2 were collected in a series of chilled impingers. The sampling train impingers contained 100 ml of 0.1N sulfuric acid in the first and second, an empty third impinger, 100 ml of 0.1N NaOH in the fourth and fifth and 200 grams of silica gel in the last impinger

Sampling was conducted isokinetically ($\pm 10\%$) with readings of flue gas parameters recorded at traverse points selected according to EPA Method 1. Leak-checks on the Method 26A sampling train were performed before and after each sampling run and optionally for any port change. The sampling train leak-checks and leakage rate (where applicable) were documented on the field test data sheet for each respective run. All leak checks were acceptable.

The glass button hook nozzle and probe liner was constructed of borosilicate glass. The filter holder will be constructed of borosilicate glass with a Teflon frit filter support and a sealing gasket. A PTFE-bonded glass fiber filter was used. The probe and filter housing were heated to above 248°F and not exceed an upper boundary of 273°F . Probe liners and filter holders were cleaned thoroughly prior to testing.

The Method 26A trains was operated isokinetically for a minimum of 60 minutes and collected a minimum of 1 dry, standard cubic meter (DSCM). Pretest preparations, preliminary determinations, and leak check procedures were those outlined in EPA Method 5.

After completion of sampling the train was leak checked and transferred to the sample recovery trailer. All leak checks were acceptable. The impingers were weighed to determine moisture gain in accordance with EPA Method 4.

Sample recovery involved quantitative recovery of the sulfuric acid impinger contents and the NaOH impinger contents into separate tare-weighted, precleaned polyethylene sample containers.

The nozzle, probe, filter and filter housing were not recovered.

The contents of sulfuric acid impingers, including the contents if any of the empty (2nd knockout or third) impinger were quantitatively transferred to the tare-weighted, precleaned polyethylene sample container, followed by three rinses with deionized (DI) water of the impingers and all connecting glassware (including the connecting glassware to the first impinger) placed in the same H_2SO_4 container. The container was labeled and weighed to determine the final sample volume.

The contents NaOH impingers were quantitatively transferred to a second tare-weighed, precleaned polyethylene sample container, followed by three rinses with DI water of the impingers and all connecting glassware placed in the same NaOH container. The container was labeled and weighed to determine the final sample volume.

Sample recovery from each train included:

1. Container No. 1 - Contents of H_2SO_4 impingers and knockout impinger and, and DI rinse of impingers and connecting glassware; and
2. Container No. 2 - Contents NaOH impingers, and DI rinse of impingers and connecting glassware.

Additional quality control consisted of collecting and analyzing a field blank train for every three test runs. The blank train was assembled from a used train, leak checked and sat for a period equal to the sampling time (i.e, 1-hr). The blank train data was to be used to determine the method detection limit for the test program target analytes (ie. The lowest number that could be detected), and compared to stack emissions.

Reagent blanks of 0.1 N H_2SO_4 , 0.1N NaOH, and DI water were collected and archived for later analysis should there be any issues with the field blank train samples

The H_2SO_4 impinger solutions were analyzed using ion chromatography techniques for fluoride ions (F^-) (EPA SW-9057). Duplicate analyses performed on the samples and field blanks. Precision was demonstrated by duplicate injection of each sample, the results of each individual analysis being within 5% of their mean to be acceptable.

The NaOH impinger solutions was treated with sodium thiosulfate to ensure complete conversion of hypochlorous acid (HClO) to chloride ions (Cl^-). The resulting solution was analyzed using ion chromatography techniques for chloride ions (EPA SW-9057). Duplicate analyses was performed on the samples and field blanks. Precision was demonstrated by duplicate injection of each sample, the results of each individual analysis being within 5% of their mean to be acceptable

All EPA Method 26A HF/Cl_2 samples were analyzed by Element One of Wilmington NC. Refer to Section 1, Figure 1.1 of the RTR Sampling and Analytical Protocol for contact information.

For this test program, the relative deviation (RD) was to be calculated as described in EPA Method 30B between the Cl_2 concentrations measured with the paired trains. A criteria of a less than 10% relative deviation or 0.2 ppm absolute difference was required.

The absolute differences between the Cl_2 concentrations measured with the paired trains is summarized in Table 3.1. For each paired run, Cl_2 concentrations met the 0.2 ppm absolute difference criteria.

TABLE 3.1 PAIRED METHOD 26A SAMPLING TRAIN DIATOMIC CHLORINE CONCENTRATION COMPARISON RESULTS FOR THE KILN MAIN STACK; NOVEMBER 29-30, 2023

Run	Time	Train A Diatomic Chlorine Concentration (ppm,dry)	Train B Diatomic Chlorine Concentration (ppm,dry)	Absolute Difference (ppm,dry)
November 29-30, 2023; Main Stack; Raw Mill On				
Run 1	14:50-15:56	<0.037	<0.037	0.000
Run 2	09:20-10:26	<0.042	<0.049	0.006
Run 3	10:45-11:51	<0.043	<0.040	0.003
November 30, 2023; Main Stack; Raw Mill Off				
Run 1	14:05-15:11	0.192	0.206	0.015
Run 2	15:39-16:45	0.085	0.093	0.008
Run 3	17:25-18:31	0.173	0.185	0.012

3.6 Hydrogen Cyanide and Hydrogen Fluoride - EPA Method 320

EPA Method 320 was performed to determine emissions of concentrations of HCN and HF. Three, 1-hour sampling runs were conducted under each representative process and control system operating conditions.

The gas sample was extracted from the stack through a glass-lined probe and filter heated to 375° F. For external calibration checks and analyte spikes, the gases were introduced in front of the heated filter. Any excess calibration gas was diverted through the sample probes into the source. Outflow of gas from the heated filter enclosure was transported through a Teflon sample line heated to 375° F. For these sources approximately 300' of sample line was required. The heated sample line was connected directly to the FTIR sample cell. Using heat-traced Teflon tubing the exit of the FTIR cell was connected to a sample pump with a heated stainless steel pump head. The pump discharge was directed to a proprietary chiller-type gas conditioner to remove moisture prior to delivery sample gas to the O₂/CO₂ monitor.

The distribution of the gas sample to the monitors was accomplished using a panel equipped with valves and rotometers. The gas sample was then divided and directed to the O₂/CO₂ analyzer.

FTIR sample cell was maintained at 191° C and connected to a MKS Instruments Multigas 2030 Fourier Transform Infrared Spectrometer and Detector.

The FTIR spectrometer measured vapor phase organic or inorganic compounds which absorb energy in the mid-infrared spectral region, about 400 to 4000 cm⁻¹ (25 to 2.5 μm). Continuous measurement were made by matching sample absorbance bands with bands in reference spectra, and comparing sample band intensities with reference band intensities.

The principle limitation to FTIR spectroscopy are the presence of interfering compounds that also absorb energy in the mid-infrared spectral region. In a cement kiln stack gas matrix, water vapor (H₂O) and carbon dioxide (CO₂) are the primary interferents that must be incorporated into the identification and quantitation method.

The FTIR software performs the computation for a single compound by subtracting all the other compounds (interferants and target) from the absorbance spectra and quantifies the single compound based on the remain absorbance. The FTIR software provides a Standard Error Calculation (SEC) value that is an indication of how well the identification and quantitation has been performed. A high SEC indicates that other interferants have not been accounted for in the analysis method, and a low SEC is indicative of greater confidence measurement.

The instrument is operated with a resolution of 0.5 cm⁻¹ with 4x zero filling. Beer-Norton Medium apodization is used with amplitude phase correction.

For this RTR test program, following specific QA/QC activities for EPA Method 320 were performed and are summarized in Table 3.2

3.6.1 Laboratory QA/QC Activities Before Field Test Program

Before field testing occurs, the following QA/QC activities were conducted;

- 1) Seven consecutive samples of dry nitrogen through the sampling system was acquired and used to calculate the standard deviation for each of the test program target analytes multiplied by a factor of 3. These data were considered representative of detection limits (DL) for this test program and were below the 0.5 ppm required DL for both HCN and HF;
- 2) From these seven dry nitrogen samples, the results for the Signal-to-Noise Ratio (SNR) @ 2500 cm^{-1} was >2500, at 64 scans and the results for single beam intensity @ 2500 cm^{-1} was >0.9; and
- 3) The HCN calibration gases was analyzed directly and the FTIR responses agreed with tag value within 5%

3.6.2 QA/QC Activities During Field Test Program

During the field test program, following QA/QC activities were be performed and criterium met;

- 1) On each test day prior to any testing, an instrument background was collected using dry nitrogen directed to the gas cell. The background was collected with at least 128 scans;
- 2) The probe, filter, sample line and all sample system components in contact with effluent were be maintained at or above 375°F or 191°C (consistent with FTIR calibration temperature) to avoid any possible “cold spots;”
- 3) A system zero with all sampling system components at operating temperature was performed by injecting nitrogen at the sample probe and through sample filter and entire measurement system. After zero equilibration was been achieved, all measurement components will be quantified for at least 128 scans;
- 4) The sample probe was position at effluent measurement point and sampling was continue until equilibration of the measurement system has been achieved. At this point, the effluent concentrations was quantified with two consecutive 64-scan samples as the initial native concentration for the dynamic spike;
- 5) Analyte spiking was conducted for HCN before the first test run, and after each successive test run for a minimum of 4 spikes per test condition. These results will be used to determine accuracy and are summarized in Table 3.3;
- 6) The spike gas injections was maintained at 10% or less of total sample volume. The spike gas concentration and flow rate was be selected to approximately double the native effluent concentration. Spike recovery results were within $\pm 20\%$ of the expected value. An SF_6 tracer was used to calculate the exact spike gas dilution ratio of 10% or less;
- 7) After the dynamic spike, nitrogen was sent through the sampling system until all traces of spike gas are removed and lines are proven below DL for target analytes;

TABLE 3.2 FTIR PRETEST AND FIELD TEST QA/QC SUMMARY

Spectrum	HCN	SF6	HF	SNR 2500	sBeam @2500
Seven consecutive samples of dry nitrogen for detection limit					
SPC_000837.LAB	-0.051		-0.002	6223.51	1.42
SPC_000838.LAB	-0.032		-0.000	5809.30	1.42
SPC_000839.LAB	0.046		-0.017	3759.60	1.42
SPC_000840.LAB	-0.011		0.016	4373.66	1.42
SPC_000841.LAB	0.080		0.002	5347.95	1.42
SPC_000842.LAB	0.059		-0.012	5012.46	1.42
SPC_000843.LAB	-0.029		-0.006	4706.13	1.42
Standard Deviation X 3	0.156		0.032		
Averages				5033.23	1.42
HCN Standard (CC768233; 199.1 ppm HCN/10.0 ppm SF6)					
SPC_003164.LAB	196.3	9.6			
SPC_003165.LAB	197.0	9.6			
SPC_003166.LAB	197.0	9.6			
SPC_003167.LAB	197.3	9.6			
Averages	196.9	9.6			
HCN Standard (CC768222; 49.9 ppm HCN/5.0 ppm SF6)					
SPC_003173.LAB	49.91	4.85			
SPC_003174.LAB	49.93	4.85			
SPC_003175.LAB	49.82	4.85			
SPC_003176.LAB	49.90	4.85			
Averages	49.89	4.85			
Residuals for Post HCN analyte spike native scans					
SPC_003269.LAB					
Concentration	8.65		-0.06		
MDC3	0.38		0.25		
MDC3%	4.4%		NA		
SPC_003270.LAB					
Concentration	8.64		-0.02		
MDC3	0.47		0.24		
MDC3%	5.4%		NA		
Final SNR @ 2500 cm⁻¹ and single beam intensity @ 2500 cm⁻¹					
SPC_004198.LAB				3828.6	1.30

- 8) The nitrogen purge was discontinued and the sampling system was allowed to equilibrate with stack gas before starting a test run. The first two consecutive 64-scan samples of a sample run was used for the final native concentration. Residual results for HCN and HF were verified to be less than 0.2-0.3 ppm for data acceptance, or less than 5% of the measured value, whichever was least restrictive.
- 9) The final SNR @ 2500 cm^{-1} , at 64 scans, and the results for single beam intensity @ 2500 cm^{-1} were verified to meet the >2500 and >0.9 criterium; respectively.

TABLE 3.3 ETHYLENE CALIBRATION TRANSFER STANDARD (CTS) AND HYDROGEN CYANIDE ANALYTE SPIKING TEST RESULTS FOR THE KILN MAIN STACK; NOVEMBER 29-30, 2023

Run	Time	Average Native Hydrogen Cyanide Concentration (ppm,wet)	Spike plus Average Hydrogen Cyanide Native Concentration (ppm,wet)	Hydrogen Cyanide Spike Recovery	CTS Error
November 29, 2023; Main Stack Raw Mill On					
Pre Run 1	12:15-12:33	8.72	19.97	95.9%	-1.3%
Post Run 1	13:16-13:56	9.15	17.74	91.4%	-2.6%
November 30, 2023; Main Stack Raw Mill On					
Pre Run 2	09:08-09:24	7.66	10.95	92.3%	-2.1%
Post Run 2	10:27-10:39	7.56	11.36	91.7%	
Post Run 3	11:42-11:56	7.40	10.90	89.7%	-2.1%
November 30, 2023; Main Stack Raw Mill Off					
Pre Run 1	13:39-13:57	9.73	13.50	99.5%	-2.1%
Post Run 1	15:12-15:23	10.69	14.05	91.5%	
Post Run 2	16:46-16:58	10.87	14.40	94.2%	
Post Run 3	18:31-18:51	10.26	13.50	93.0%	-2.2%

4. QA/QC PROCEDURES AND RESULTS

The objective of a quality assurance/quality control (QA/QC) program is to assure that the precision and accuracy of all environmental data generated by DEECO for clients are commensurate with data quality objectives (DQO's). DQO's are based on a common understanding of the intended end use(s) of the data, the measurement process, and the availability of resources. Once DQO's are established, formally or informally, QC protocol can be defined for the measurements.

In this project, the final data user will be Holcim. The data quality objectives in this project are to generate scientifically sound data to be used for compliance purposes.

4.1 Sampling Equipment

All of the sampling equipment used was calibrated according to the procedures outlined in the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III, EPA-600/4-77-027b.

4.1.1 Manual Sampling Equipment Calibrations

For sampling Methods 1, 2, and 4 the procedures and equipment used to measure stack gas velocity and temperature measurements and the metering system used to maintain constant rate sampling conditions and to determine the sample gas volume were subjected to pretest and posttest calibrations and/or inspections as required by the appropriate EPA methods.

Barometer - Barometric pressure values were obtained from a calibrated barometer, verified by phone call to a local airport, and corrected for elevation to sample port level (0.01 inches Hg per 10 ft. elevation).

Pitot Tubes - Each pitot tube used in sampling meets the design specifications for type-S pitot tubes in EPA Method 2. Therefore, a maximum value baseline coefficient (C_p) of 0.84 is assigned to each pitot tube. Calibration by the manufacturer for pitot face-opening alignment included measuring the external tubing diameter (dimension D_t), the base-to-opening plane distance (dimensions P_a and P_b), and the face opening misalignment angles, with all terms as described in EPA Method 2. Pitot tubes were visually inspected for structural integrity at the completion of each test. Inspection sheets for pitot tubes are included in Appendix E.

Calibration Meter and Metering System - The secondary reference meter equipment arrangement for calibration is shown in Figure 5.7 of EPA Method 5. The prescribed procedures were followed. A wet test meter with a 1 ft³/rev capacity and ± 1 percent accuracy is used as the primary calibrant. The dry gas meter's pump is run for a minimum of 5 minutes at a flow rate of 0.35 cfm to condition the interior surface of the wet test meter. Leak checks are performed and if satisfactory, triplicate runs at each of no less than five different flow rates are done. A calibration curve is prepared and the meter is recalibrated after 200 hours of operation or annually, whichever comes first.

The calibration set-up for the dry gas metering system using the secondary reference meter in lieu of the wet test meter is given in Figure 5.5 of EPA Method 5. A leak check of the metering system before calibration was performed as shown in Figure 5.4 of EPA Method 5. The metering system's pump is operated for 5 minutes at an orifice manometer setting of 0.5 inches H₂O to heat up the pump and system to stabilize the meter inlet and outlet temperatures. Values for the orifice setting (ΔH), wet test meter volume (V_w), corresponding dry test meter volume (V_d), dry test meter inlet and outlet gas temperatures (t_{di} and t_{dn}), and time are recorded for the initial calibration. Then the ratio of the wet test meter to the dry test meter (γ) and the orifice pressure differential that equates to 0.75 cfm at standard conditions ($\Delta H@$) are calculated.

A post-test meter calibration was made on the dry gas meter used during the test to check its accuracy against the pre-test calibration. This was performed following EPA Method 5, Section 16.3 or a post-test calibration check was made using the average orifice setting obtained during each test run and setting the vacuum at the maximum value obtained during each test run. These test runs were made against DEECO's secondary reference dry gas meter which was calibrated against a wet test meter. The calibration data sheets for the dry gas meters are included in Appendix E.

Thermocouples and Digital Indicators - Thermocouples were calibrated by comparing them against an ASTM-3F mercury-in-glass thermometer at approximately 32 °F (ice water), ambient temperature, and at approximately 220 °F. Each thermocouple was calibrated against temperature ranges to which it is typically exposed during test conditions, and they agreed within 1.5 percent (expressed in °R) of the reference thermometer throughout the entire calibration range. Also, thermocouples were checked at ambient temperature at the test site to verify calibration. The calibration data sheets for the thermocouples are included in Appendix E.

Pretest and Posttest Leak Checks of Sampling Trains - Each Method 4 sampling train was subjected to pretest leak checks and posttest leak checks. For all sampling runs the posttest leak checks were acceptable (less than 4% of the sampling rate at the highest vacuum recorded during the test run).

4.2 Analytical QA/QC Results

Analytical measurements of precision and accuracy were made on stack gas samples, and are summarized in a separate report.

Appendix A

Emission Summary Tables

Company: Buzzi Unicem; Maryneal TX
Source: Main Stack; Raw Mill On
Job ID: 23-3315
Train Type: EPA Method 26A

	1A 11/29/23 1450-1556	1B 11/29/23 1450-1556	3A 11/30/23 920-1026	3B 11/30/23 920-1026	4A 11/30/23 1045-1151	4B 11/30/23 1045-1151	Average
Initial Meter Volume, ft ³	861.672	971.583	936.456	43.246	988.879	95.369	
Final Meter Volume, ft ³	917.275	1025.334	988.745	95.115	1040.834	147.364	
Intra-Port Volume and/or Leak Check Correction, ft ³	0.000	0.000	0.000	0.000	0.000	0.000	
Total Sample Volume, cf	55.603	53.751	52.289	51.869	51.955	51.995	52.910
DGM Calibration Factor	0.975	0.985	0.975	0.985	0.975	0.985	0.980
Average DGM Temp, F	69.6	72.3	61.3	61.6	66.1	68.1	66.5
Average DGM delta H, "H ₂ O	2.33	2.34	2.18	2.19	2.17	2.18	2.23
Barometric Pressure, "Hg	27.32	27.32	27.43	27.43	27.43	27.43	27.39
Corrected Sample Vol, dscf	49.631	48.225	47.586	47.662	46.850	47.189	47.857
Corrected Sample Vol, dscmm	1.405	1.366	1.347	1.350	1.327	1.336	1.355
Sample Volume (at Stack Conditions), acf	83.169	81.562	82.682	82.814	78.949	78.996	81.362
Sample Volume (at Stack Conditions), acmm	2.355	2.310	2.341	2.345	2.236	2.237	2.304
Oxygen, %	10.7	10.7	11.4	11.4	11.7	11.7	11.3
Carbon Dioxide, %	16.9	16.9	15.2	15.2	14.9	14.9	15.7
Nitrogen, %	72.4	72.4	73.4	73.4	73.4	73.4	73.1
Stack Gas Excess Air, %	127.2	127.2	142.9	142.9	152.4	152.4	140.8
Total Moisture Catch Weight, grams	155.3	162.7	164.1	164.6	128.4	120.7	137.9
Stack Gas Moisture, %	12.9	13.7	14.0	14.0	11.4	10.8	12.8
Stack Gas Dry Molecular Weight, lb/lbmole	31.13	31.13	30.89	30.89	30.85	30.85	30.96
Stack Gas Wet Molecular Weight, lb/lbmole	29.44	29.33	29.08	29.08	29.39	29.46	29.30
Average Stack Temp, F	242.4	242.4	262.0	262.0	261.4	261.5	255.3
Stack Static (Gauge) Pressure, "H ₂ O	-0.67	-0.67	-0.67	-0.67	-0.67	-0.67	-0.67
Stack Gas Actual Pressure, "Hg	27.27	27.27	27.38	27.38	27.38	27.38	27.34
Average Sqrt delta P *	0.991	0.991	0.958	0.958	0.958	0.958	0.969
Pitot Tube Coefficient	0.85	0.85	0.85	0.85	0.85	0.85	0.85
Stack Gas Velocity, ft/second	67.36	67.48	66.29	66.29	65.91	65.84	66.53
Nozzle Inside Diameter, inches	0.250	0.250	0.250	0.250	0.250	0.250	
Total Sample Time, min	60	60	60	60	60	60	60
Isokinetic Rate, %	100.7	98.6	101.7	101.9	97.7	97.8	99.7
Stack Dimensions	140 in. ID	140 in. ID	140 in. ID	140 in. ID	140 in. ID	140 in. ID	
Stack Area, sq ft	106.90	106.90	106.90	106.90	106.90	106.90	106.90
Actual Stack Gas Flow Rate, acfm	432,000	432,800	425,200	425,200	422,700	422,300	426,700
Actual Stack Gas Flow Rate, acmm	12,233	12,256	12,040	12,040	11,970	11,958	12,083
Stack Gas Flow Rate, dscfm	257,800	255,900	244,700	244,700	250,900	252,300	251,100
Stack Gas Flow Rate, dscmm	7,300	7,246	6,929	6,929	7,105	7,144	7,109

Company: Buzzi Unicem; Maryneal TX
Source: Main Stack; Raw Mill On
Job ID: 23-3315
Train Type: EPA Method 26A

NOTE: Average INCLUDES Non-detect runs' results

"ND()" denotes values below detection limits

		1450-1556		1450-1556		920-1026		920-1026		1045-1151		1045-1151		Average
Hydrogen Fluoride	Catch Wt, mg	ND(0.228)	ND(0.254)	ND(0.254)	ND(0.265)	ND(0.259)	ND(0.237)	ND(0.224)	ND(0.224)	ND(0.237)	ND(0.224)	ND(0.224)	ND(0.2445)	
	Conc., mg/dscm	ND(0.162)	ND(0.186)	ND(0.186)	ND(0.197)	ND(0.192)	ND(0.179)	ND(0.168)	ND(0.168)	ND(0.179)	ND(0.168)	ND(0.168)	ND(0.181)	
	Conc., mg/dscm @ 7% O2	ND(0.221)	ND(0.253)	ND(0.253)	ND(0.288)	ND(0.281)	ND(0.270)	ND(0.253)	ND(0.253)	ND(0.270)	ND(0.253)	ND(0.253)	ND(0.261)	
	Conc., mg/dscm @ 12% CO2	ND(0.115)	ND(0.132)	ND(0.132)	ND(0.155)	ND(0.151)	ND(0.144)	ND(0.135)	ND(0.135)	ND(0.144)	ND(0.135)	ND(0.135)	ND(0.139)	
	Conc., ppmvd	ND(0.195)	ND(0.224)	ND(0.224)	ND(0.237)	ND(0.231)	ND(0.215)	ND(0.202)	ND(0.202)	ND(0.215)	ND(0.202)	ND(0.202)	ND(0.217)	
	Conc., ppmvd @ 7% O2	ND(0.266)	ND(0.305)	ND(0.305)	ND(0.346)	ND(0.338)	ND(0.324)	ND(0.305)	ND(0.305)	ND(0.324)	ND(0.305)	ND(0.305)	ND(0.314)	
	Conc., ppmvd @ 12% CO2	ND(0.139)	ND(0.159)	ND(0.159)	ND(0.187)	ND(0.182)	ND(0.173)	ND(0.162)	ND(0.162)	ND(0.173)	ND(0.162)	ND(0.162)	ND(0.167)	
	Emission Rate, lb/hr	ND(0.157)	ND(0.178)	ND(0.178)	ND(0.180)	ND(0.176)	ND(0.168)	ND(0.158)	ND(0.170)	ND(0.168)	ND(0.158)	ND(0.170)	ND(0.170)	
	Clinker Rates (tph and lbs/ton)	150.90	ND(0.0011)	ND(0.0011)	133.10	ND(0.0013)	130.40	ND(0.0013)	ND(0.0012)	ND(0.0013)	ND(0.0012)	ND(0.0012)	ND(0.0012)	
Chlorine	Catch Wt, mg	ND(0.154)	ND(0.148)	ND(0.148)	ND(0.167)	ND(0.193)	ND(0.167)	ND(0.156)	ND(0.156)	ND(0.167)	ND(0.156)	ND(0.156)	ND(0.16416667)	
	Conc., mg/dscm	ND(0.110)	ND(0.108)	ND(0.108)	ND(0.124)	ND(0.143)	ND(0.126)	ND(0.117)	ND(0.121)	ND(0.126)	ND(0.117)	ND(0.117)	ND(0.121)	
	Conc., mg/dscm @ 7% O2	ND(0.149)	ND(0.148)	ND(0.148)	ND(0.181)	ND(0.209)	ND(0.190)	ND(0.176)	ND(0.176)	ND(0.190)	ND(0.176)	ND(0.176)	ND(0.176)	
	Conc., mg/dscm @ 12% CO2	ND(0.078)	ND(0.077)	ND(0.077)	ND(0.098)	ND(0.113)	ND(0.101)	ND(0.094)	ND(0.093)	ND(0.101)	ND(0.094)	ND(0.094)	ND(0.093)	
	Conc., ppmvd	ND(0.037)	ND(0.037)	ND(0.037)	ND(0.042)	ND(0.049)	ND(0.043)	ND(0.040)	ND(0.041)	ND(0.043)	ND(0.040)	ND(0.040)	ND(0.041)	
	Absolute Difference, ppmvd (<0.2 required)					0.006		0.003			0.003			
	Conc., ppmvd @ 7% O2	ND(0.051)	ND(0.050)	ND(0.050)	ND(0.062)	ND(0.071)	ND(0.065)	ND(0.060)	ND(0.060)	ND(0.065)	ND(0.060)	ND(0.060)	ND(0.060)	
	Conc., ppmvd @ 12% CO2	ND(0.026)	ND(0.026)	ND(0.026)	ND(0.033)	ND(0.038)	ND(0.034)	ND(0.032)	ND(0.032)	ND(0.034)	ND(0.032)	ND(0.032)	ND(0.032)	
	Emission Rate, lb/hr	ND(0.106)	ND(0.104)	ND(0.104)	ND(0.114)	ND(0.131)	ND(0.118)	ND(0.110)	ND(0.114)	ND(0.118)	ND(0.110)	ND(0.110)	ND(0.114)	
Clinker Rates (tph and lbs/ton)	150.90	ND(0.0007)	ND(0.0007)	133.10	ND(0.0009)	130.40	ND(0.0009)	0.0008	130.40	ND(0.0009)	0.0008	0.0008		

Buzzi Unicem: Mayrneal TX
Main Stack, Raw Mill On

Run 1		Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100.3000) 191C	H2O% (40) 191C	CO2% (40) 191C
Spectrum									
SPC_003397.LAB	11/29/23	14:50:36.250	8.594	-0.149	-0.016	3.326	13.327	14.169	
SPC_003398.LAB	11/29/23	14:51:40.100	8.630	-0.138	-0.013	3.302	13.899	14.010	
SPC_003399.LAB	11/29/23	14:52:44.007	8.670	-0.150	-0.015	3.328	13.465	14.167	
SPC_003400.LAB	11/29/23	14:53:49.000	8.962	-0.138	-0.011	3.250	13.380	14.157	
SPC_003401.LAB	11/29/23	14:54:51.854	8.965	-0.150	-0.010	3.209	14.220	13.875	
SPC_003402.LAB	11/29/23	14:55:56.817	8.866	-0.187	-0.012	3.044	13.464	14.046	
SPC_003403.LAB	11/29/23	14:56:59.807	8.389	-0.195	-0.010	2.948	13.550	14.321	
SPC_003404.LAB	11/29/23	14:58:03.879	8.753	-0.194	-0.011	3.046	13.854	14.172	
SPC_003405.LAB	11/29/23	14:59:07.449	8.843	-0.156	-0.012	3.120	13.626	14.101	
SPC_003406.LAB	11/29/23	15:00:11.350	8.751	-0.146	-0.015	2.936	13.871	14.005	
SPC_003407.LAB	11/29/23	15:01:15.337	8.807	-0.159	-0.009	3.134	13.760	14.114	
SPC_003408.LAB	11/29/23	15:02:19.536	8.946	-0.148	-0.013	3.264	13.382	13.844	
SPC_003409.LAB	11/29/23	15:03:23.083	8.897	-0.156	-0.012	3.167	13.871	13.937	
SPC_003410.LAB	11/29/23	15:04:27.039	9.062	-0.164	-0.011	3.282	13.680	13.979	
SPC_003411.LAB	11/29/23	15:05:30.949	8.680	-0.151	-0.013	3.200	14.052	13.914	
SPC_003412.LAB	11/29/23	15:06:34.933	8.627	-0.131	-0.012	3.054	13.739	14.007	
SPC_003413.LAB	11/29/23	15:07:38.726	8.533	-0.182	-0.012	3.069	13.359	14.256	
SPC_003414.LAB	11/29/23	15:08:42.898	8.470	-0.142	-0.012	3.118	13.837	13.902	
SPC_003415.LAB	11/29/23	15:09:46.594	8.473	-0.144	-0.015	3.089	13.311	13.992	
SPC_003416.LAB	11/29/23	15:10:50.461	8.599	-0.198	-0.014	3.007	13.696	14.039	
SPC_003417.LAB	11/29/23	15:11:54.373	8.754	-0.194	-0.008	3.035	13.674	14.073	
SPC_003418.LAB	11/29/23	15:12:58.276	8.789	-0.199	-0.013	3.012	13.394	14.081	
SPC_003419.LAB	11/29/23	15:14:02.467	8.619	-0.180	-0.015	2.986	13.748	14.105	
SPC_003420.LAB	11/29/23	15:15:06.094	8.805	-0.177	-0.014	3.265	13.303	14.033	
SPC_003421.LAB	11/29/23	15:16:10.001	8.895	-0.180	-0.010	3.172	13.315	14.007	
SPC_003422.LAB	11/29/23	15:17:13.949	8.865	-0.160	-0.011	3.170	13.694	14.023	
SPC_003423.LAB	11/29/23	15:18:17.859	8.820	-0.199	-0.012	3.219	13.027	14.179	
SPC_003424.LAB	11/29/23	15:19:21.776	8.523	-0.125	-0.013	3.290	14.545	13.961	
SPC_003425.LAB	11/29/23	15:20:25.788	8.835	-0.156	-0.012	3.324	13.315	14.144	
SPC_003426.LAB	11/29/23	15:21:29.591	8.452	-0.143	-0.011	3.360	13.843	14.074	
SPC_003427.LAB	11/29/23	15:22:33.598	8.550	-0.155	-0.013	3.264	13.644	14.104	
SPC_003428.LAB	11/29/23	15:23:37.672	8.504	-0.199	-0.012	3.429	13.509	14.260	
SPC_003429.LAB	11/29/23	15:24:41.527	8.507	-0.149	-0.013	3.474	14.010	14.046	
SPC_003430.LAB	11/29/23	15:25:45.219	8.603	-0.145	-0.012	3.473	13.791	14.131	
SPC_003431.LAB	11/29/23	15:26:49.142	8.822	-0.197	-0.013	3.342	13.709	14.163	
SPC_003432.LAB	11/29/23	15:27:53.032	8.682	-0.191	-0.013	3.426	13.489	14.257	
SPC_003433.LAB	11/29/23	15:28:56.947	8.756	-0.185	-0.015	3.487	13.562	14.083	
SPC_003434.LAB	11/29/23	15:30:00.919	8.752	-0.203	-0.013	3.317	13.585	14.113	
SPC_003435.LAB	11/29/23	15:31:04.736	8.747	-0.206	-0.012	3.234	13.616	14.251	
SPC_003436.LAB	11/29/23	15:32:08.631	8.864	-0.202	-0.015	3.251	13.704	14.223	
SPC_003437.LAB	11/29/23	15:33:12.655	8.947	-0.192	-0.014	3.253	13.955	14.169	
SPC_003438.LAB	11/29/23	15:34:16.546	9.119	-0.208	-0.013	3.288	13.753	14.143	
SPC_003439.LAB	11/29/23	15:35:20.365	8.815	-0.194	-0.014	3.359	13.818	14.182	
SPC_003440.LAB	11/29/23	15:36:24.271	8.963	-0.176	-0.010	3.340	13.654	14.132	
SPC_003441.LAB	11/29/23	15:37:28.220	8.788	-0.200	-0.013	3.345	13.721	14.181	
SPC_003442.LAB	11/29/23	15:38:32.281	8.877	-0.218	-0.013	3.398	13.361	14.216	
SPC_003443.LAB	11/29/23	15:39:35.994	8.680	-0.145	-0.011	3.316	13.892	14.028	
SPC_003444.LAB	11/29/23	15:40:39.909	8.703	-0.147	-0.009	3.393	13.798	14.041	
SPC_003445.LAB	11/29/23	15:41:44.131	8.798	-0.159	-0.011	3.256	13.976	13.983	
SPC_003446.LAB	11/29/23	15:42:47.980	8.725	-0.157	-0.013	3.386	13.684	14.014	
SPC_003447.LAB	11/29/23	15:43:51.673	8.969	-0.208	-0.012	3.320	13.670	14.152	
SPC_003448.LAB	11/29/23	15:44:55.544	8.724	-0.201	-0.015	3.096	14.167	14.050	
SPC_003449.LAB	11/29/23	15:45:59.447	8.729	-0.223	-0.014	3.087	13.426	14.337	
SPC_003450.LAB	11/29/23	15:47:03.359	8.927	-0.201	-0.012	3.229	13.935	14.097	
SPC_003451.LAB	11/29/23	15:48:07.270	8.949	-0.190	-0.014	3.202	14.110	13.961	
SPC_003452.LAB	11/29/23	15:49:11.454	8.994	-0.204	-0.012	3.050	13.865	14.076	
SPC_003453.LAB	11/29/23	15:50:15.091	9.203	-0.209	-0.015	3.036	13.801	13.982	
SPC_003454.LAB	11/29/23	15:51:19.387	9.197	-0.220	-0.014	3.165	13.373	14.174	
SPC_003455.LAB	11/29/23	15:52:23.149	9.098	-0.192	-0.010	3.224	14.096	13.950	
SPC_003456.LAB	11/29/23	15:53:26.812	9.169	-0.214	-0.015	3.211	13.158	14.174	
SPC_003457.LAB	11/29/23	15:54:30.763	8.867	-0.200	-0.013	3.169	14.139	14.091	
SPC_003458.LAB	11/29/23	15:55:34.858	9.099	-0.227	-0.014	3.221	13.489	14.119	
Mill On Run 1			8.783	<	0.032	3.217	13.687	14.091	
Oxygen	10.7%	(actual)	13.805	<	0.050	5.057			M26A Moisture
DSCFM	256.850	(ppm dry @7% O2)	10.949	<	0.030	4.163			
Clinker (tons/hr)	150.90	(lbs/hr)	0.073	<	0.0002				

Buzzi Unicem, Maryneal TX
Main Stack, Raw Mill On

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C
SPC_003666.LAB	11/30/23	09:20:40.086	7.235	-0.039	-0.007	2.556	8.689	11.445
SPC_003667.LAB	11/30/23	09:21:43.959	8.068	-0.205	-0.008	2.878	12.316	12.870
SPC_003668.LAB	11/30/23	09:22:47.875	7.488	-0.185	-0.007	2.838	15.213	12.874
SPC_003669.LAB	11/30/23	09:23:51.774	7.647	-0.201	-0.007	2.849	14.042	12.954
SPC_003670.LAB	11/30/23	09:24:55.773	7.706	-0.213	-0.007	2.971	13.808	12.994
SPC_003671.LAB	11/30/23	09:25:59.590	7.681	-0.197	-0.004	2.883	14.617	13.017
SPC_003672.LAB	11/30/23	09:27:03.490	7.752	-0.218	-0.004	2.938	14.076	13.045
SPC_003673.LAB	11/30/23	09:28:07.607	7.788	-0.218	-0.004	2.894	14.450	12.991
SPC_003674.LAB	11/30/23	09:29:11.312	7.752	-0.215	-0.008	2.957	13.815	13.103
SPC_003675.LAB	11/30/23	09:30:15.404	7.645	-0.174	-0.006	2.946	14.263	13.015
SPC_003676.LAB	11/30/23	09:31:19.114	7.922	-0.180	-0.004	2.917	13.924	13.058
SPC_003677.LAB	11/30/23	09:32:23.360	7.719	-0.199	-0.007	2.855	14.720	12.887
SPC_003678.LAB	11/30/23	09:33:26.926	7.822	-0.189	-0.008	2.912	13.811	13.025
SPC_003679.LAB	11/30/23	09:34:30.839	7.571	-0.171	-0.007	2.886	14.210	12.796
SPC_003680.LAB	11/30/23	09:35:35.113	7.774	-0.192	-0.006	2.942	13.783	12.876
SPC_003681.LAB	11/30/23	09:36:38.846	7.809	-0.189	-0.007	2.846	13.926	12.855
SPC_003682.LAB	11/30/23	09:37:42.545	7.673	-0.195	-0.006	2.916	14.459	12.805
SPC_003683.LAB	11/30/23	09:38:46.449	7.792	-0.206	-0.007	2.954	13.585	12.855
SPC_003684.LAB	11/30/23	09:39:50.342	7.632	-0.179	-0.007	2.892	14.343	12.672
SPC_003685.LAB	11/30/23	09:40:54.247	7.700	-0.192	-0.006	2.994	14.064	12.760
SPC_003686.LAB	11/30/23	09:41:58.157	7.732	-0.197	-0.004	2.934	14.511	12.733
SPC_003687.LAB	11/30/23	09:43:02.055	7.793	-0.226	-0.007	3.024	13.787	12.853
SPC_003688.LAB	11/30/23	09:44:06.219	7.639	-0.214	-0.005	2.976	14.280	12.754
SPC_003689.LAB	11/30/23	09:45:10.246	7.694	-0.209	-0.008	2.940	14.105	12.778
SPC_003690.LAB	11/30/23	09:46:13.767	7.781	-0.223	-0.006	2.978	13.664	12.847
SPC_003691.LAB	11/30/23	09:47:17.716	7.475	-0.217	-0.008	3.008	14.258	12.814
SPC_003692.LAB	11/30/23	09:48:21.583	7.568	-0.189	-0.006	3.002	14.387	12.702
SPC_003693.LAB	11/30/23	09:49:25.486	7.622	-0.209	-0.008	3.018	14.519	12.762
SPC_003694.LAB	11/30/23	09:50:29.583	7.626	-0.228	-0.007	3.018	13.801	12.863
SPC_003695.LAB	11/30/23	09:51:33.336	7.624	-0.214	-0.005	2.954	13.729	12.840
SPC_003696.LAB	11/30/23	09:52:37.249	7.317	-0.191	-0.006	3.010	14.524	12.777
SPC_003697.LAB	11/30/23	09:53:41.109	7.594	-0.227	-0.007	2.983	13.891	12.877
SPC_003698.LAB	11/30/23	09:54:45.146	7.627	-0.171	-0.004	3.002	13.884	12.844
SPC_003699.LAB	11/30/23	09:55:49.264	7.532	-0.195	-0.008	3.020	14.255	12.770
SPC_003700.LAB	11/30/23	09:56:52.826	7.811	-0.195	-0.007	3.073	14.249	12.729
SPC_003701.LAB	11/30/23	09:57:56.739	8.000	-0.191	-0.004	3.221	13.629	12.938
SPC_003702.LAB	11/30/23	09:59:00.637	7.940	-0.191	-0.007	3.323	13.947	12.856
SPC_003703.LAB	11/30/23	10:00:04.543	7.778	-0.194	-0.004	3.301	14.475	12.709
SPC_003704.LAB	11/30/23	10:01:08.462	8.019	-0.194	-0.006	3.350	13.778	12.770
SPC_003705.LAB	11/30/23	10:02:12.349	8.179	-0.194	-0.007	3.365	13.986	12.820
SPC_003706.LAB	11/30/23	10:03:16.256	7.908	-0.177	-0.007	3.330	14.086	12.576
SPC_003707.LAB	11/30/23	10:04:20.159	8.265	-0.203	-0.004	3.396	13.489	12.726
SPC_003708.LAB	11/30/23	10:05:24.056	7.864	-0.186	-0.007	3.344	14.068	12.679
SPC_003709.LAB	11/30/23	10:06:27.958	7.626	-0.188	-0.006	3.297	14.189	12.528
SPC_003710.LAB	11/30/23	10:07:31.909	7.519	-0.216	-0.004	3.349	13.550	12.470
SPC_003711.LAB	11/30/23	10:08:35.819	7.584	-0.209	-0.004	3.314	13.551	12.353
SPC_003712.LAB	11/30/23	10:09:39.675	7.370	-0.210	-0.010	3.330	14.309	12.149
SPC_003713.LAB	11/30/23	10:10:43.586	7.440	-0.216	-0.009	3.252	13.573	12.296
SPC_003714.LAB	11/30/23	10:11:47.486	7.380	-0.202	-0.010	3.262	13.962	12.257
SPC_003715.LAB	11/30/23	10:12:51.519	7.498	-0.214	-0.008	3.271	14.386	12.264
SPC_003716.LAB	11/30/23	10:13:55.386	7.614	-0.212	-0.008	3.273	13.616	12.236
SPC_003717.LAB	11/30/23	10:14:59.247	7.447	-0.230	-0.008	3.200	13.504	12.152
SPC_003718.LAB	11/30/23	10:16:03.103	7.740	-0.234	-0.009	3.200	13.468	12.219
SPC_003719.LAB	11/30/23	10:17:07.046	7.555	-0.216	-0.007	3.136	13.991	12.218
SPC_003720.LAB	11/30/23	10:18:11.112	7.577	-0.217	-0.011	3.151	13.966	12.179
SPC_003721.LAB	11/30/23	10:19:14.808	7.667	-0.225	-0.010	3.217	13.257	12.267
SPC_003722.LAB	11/30/23	10:20:18.718	7.526	-0.216	-0.009	3.155	14.378	12.054
SPC_003723.LAB	11/30/23	10:21:22.875	7.490	-0.228	-0.007	3.120	13.516	12.151
SPC_003724.LAB	11/30/23	10:22:26.533	7.611	-0.221	-0.007	3.219	13.547	12.219
SPC_003725.LAB	11/30/23	10:23:30.466	7.412	-0.206	-0.008	3.172	14.020	12.116
SPC_003726.LAB	11/30/23	10:24:34.366	7.539	-0.212	-0.005	3.172	13.463	12.146
SPC_003727.LAB	11/30/23	10:25:38.231	7.704	-0.206	-0.009	3.176	13.501	12.198
Mill On Run 2		(actual)		< 0.032	-0.007	3.076	13.896	12.642
Oxygen	11.4%	(ppm,dry @7% O2)	13.058	< 0.054	-0.012			
DSCFM	244,700	(lbs/hr)	9,190	< 0.028	-0.044			
Clinker (tons/hr)	133.10	(lbs/ton clinker)	0,069	< 0.0002			14.0	M26A Moisture

Buzzi Unicem: Maryneal TX
Main Slack, Raw Mill On

Spectrum		Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C
Run 3									
SPC_003745.LAB		11/30/23	10:46:06.396	7.396	-0.199	-0.005	3.062	14.339	12.339
SPC_003746.LAB		11/30/23	10:47:10.302	7.584	-0.213	-0.005	3.094	13.350	12.549
SPC_003747.LAB		11/30/23	10:48:14.289	7.548	-0.218	-0.005	3.105	13.350	12.545
SPC_003748.LAB		11/30/23	10:49:18.063	7.513	-0.198	-0.008	3.092	14.511	12.440
SPC_003749.LAB		11/30/23	10:50:21.963	7.559	-0.217	-0.004	3.091	13.550	12.480
SPC_003750.LAB		11/30/23	10:51:25.877	7.558	-0.168	-0.005	3.032	13.550	12.350
SPC_003751.LAB		11/30/23	10:52:29.768	7.846	-0.226	-0.005	3.102	13.285	12.496
SPC_003752.LAB		11/30/23	10:53:33.702	7.574	-0.213	-0.009	2.955	14.588	12.454
SPC_003753.LAB		11/30/23	10:54:37.561	7.629	-0.201	-0.006	3.012	13.256	12.213
SPC_003754.LAB		11/30/23	10:55:41.465	7.359	-0.225	-0.008	3.034	13.534	12.325
SPC_003755.LAB		11/30/23	10:56:45.407	7.483	-0.200	-0.006	2.953	13.574	12.319
SPC_003756.LAB		11/30/23	10:57:49.305	7.432	-0.216	-0.009	2.897	14.480	12.175
SPC_003757.LAB		11/30/23	10:58:53.170	7.595	-0.215	-0.003	2.956	13.565	12.372
SPC_003758.LAB		11/30/23	10:59:57.064	7.636	-0.211	-0.004	2.997	13.306	12.432
SPC_003759.LAB		11/30/23	11:01:01.161	7.383	-0.213	-0.007	2.896	14.606	12.360
SPC_003760.LAB		11/30/23	11:02:05.067	7.133	-0.172	-0.006	2.993	13.192	12.434
SPC_003761.LAB		11/30/23	11:03:08.775	7.121	-0.166	-0.006	3.047	13.972	12.320
SPC_003762.LAB		11/30/23	11:04:12.675	7.157	-0.185	-0.007	3.007	13.668	12.398
SPC_003763.LAB		11/30/23	11:05:16.699	6.954	-0.192	-0.009	3.063	13.718	12.282
SPC_003764.LAB		11/30/23	11:06:20.473	7.168	-0.175	-0.008	2.948	14.311	12.188
SPC_003765.LAB		11/30/23	11:07:24.377	7.034	-0.164	-0.004	2.940	13.469	12.380
SPC_003766.LAB		11/30/23	11:08:28.335	6.937	-0.170	-0.009	3.010	13.949	12.260
SPC_003767.LAB		11/30/23	11:09:32.225	7.235	-0.159	-0.006	2.966	13.411	12.402
SPC_003768.LAB		11/30/23	11:10:36.133	7.053	-0.172	-0.006	3.058	13.344	12.400
SPC_003769.LAB		11/30/23	11:11:40.265	6.866	-0.186	-0.006	2.989	13.248	12.274
SPC_003770.LAB		11/30/23	11:12:43.883	6.919	-0.154	-0.008	2.867	14.398	12.035
SPC_003771.LAB		11/30/23	11:13:47.987	7.167	-0.194	-0.008	2.932	12.894	12.249
SPC_003772.LAB		11/30/23	11:14:51.692	7.118	-0.167	-0.005	2.855	13.268	12.179
SPC_003773.LAB		11/30/23	11:15:55.709	7.003	-0.164	-0.005	2.853	13.898	12.062
SPC_003774.LAB		11/30/23	11:16:59.489	7.183	-0.177	-0.007	2.858	13.145	12.123
SPC_003775.LAB		11/30/23	11:18:03.514	7.256	-0.168	-0.006	2.929	12.866	12.176
SPC_003776.LAB		11/30/23	11:19:07.443	7.138	-0.203	-0.006	2.793	14.153	12.201
SPC_003777.LAB		11/30/23	11:20:11.196	7.158	-0.222	-0.009	2.799	12.927	12.264
SPC_003778.LAB		11/30/23	11:21:15.186	7.280	-0.206	-0.005	2.767	13.067	12.269
SPC_003779.LAB		11/30/23	11:22:19.101	7.191	-0.220	-0.002	2.877	13.055	12.393
SPC_003780.LAB		11/30/23	11:23:23.281	6.902	-0.216	-0.011	2.881	14.123	12.220
SPC_003781.LAB		11/30/23	11:24:26.809	7.455	-0.217	-0.005	2.896	12.892	12.509
SPC_003782.LAB		11/30/23	11:25:30.744	7.639	-0.220	-0.005	2.898	13.007	12.622
SPC_003783.LAB		11/30/23	11:26:34.599	7.334	-0.203	-0.007	2.826	14.319	12.448
SPC_003784.LAB		11/30/23	11:27:38.507	7.558	-0.212	-0.006	2.871	13.156	12.732
SPC_003785.LAB		11/30/23	11:28:42.406	7.503	-0.215	-0.006	2.768	13.713	12.669
SPC_003786.LAB		11/30/23	11:29:46.645	7.657	-0.232	-0.006	2.877	12.964	12.782
SPC_003787.LAB		11/30/23	11:30:50.210	7.560	-0.226	-0.007	2.898	13.310	12.716
SPC_003788.LAB		11/30/23	11:31:54.104	7.385	-0.203	-0.009	2.908	13.978	12.653
SPC_003789.LAB		11/30/23	11:32:58.006	7.764	-0.241	-0.008	2.913	13.261	12.852
SPC_003790.LAB		11/30/23	11:34:02.030	7.447	-0.207	-0.005	2.960	13.953	12.772
SPC_003791.LAB		11/30/23	11:35:05.819	7.450	-0.229	-0.004	2.854	13.626	12.719
SPC_003792.LAB		11/30/23	11:36:10.081	7.467	-0.237	-0.007	2.897	13.302	12.819
SPC_003793.LAB		11/30/23	11:37:13.665	7.421	-0.215	-0.006	2.943	13.886	12.708
SPC_003794.LAB		11/30/23	11:38:17.860	7.515	-0.231	-0.007	3.012	13.274	12.840
SPC_003795.LAB		11/30/23	11:39:21.418	7.280	-0.167	-0.003	2.916	13.463	12.764
SPC_003796.LAB		11/30/23	11:40:25.446	7.099	-0.166	-0.008	2.915	13.410	12.686
SPC_003797.LAB		11/30/23	11:41:29.223	7.118	-0.171	-0.009	2.811	14.606	12.507
SPC_003798.LAB		11/30/23	11:42:33.378	7.424	-0.195	-0.008	2.839	13.173	12.740
SPC_003799.LAB		11/30/23	11:43:37.025	7.136	-0.166	-0.006	2.792	14.555	12.543
SPC_003800.LAB		11/30/23	11:44:41.107	7.167	-0.192	-0.003	2.823	13.340	12.684
SPC_003801.LAB		11/30/23	11:45:44.866	7.048	-0.166	-0.006	2.831	13.534	12.736
SPC_003802.LAB		11/30/23	11:46:49.116	7.173	-0.166	-0.008	2.761	14.227	12.527
SPC_003803.LAB		11/30/23	11:47:53.006	7.110	-0.193	-0.005	2.749	13.729	12.697
SPC_003804.LAB		11/30/23	11:48:56.618	7.212	-0.196	-0.002	2.730	13.438	12.719
SPC_003805.LAB		11/30/23	11:50:00.436	6.988	-0.185	-0.004	2.719	13.440	12.666
SPC_003806.LAB		11/30/23	11:51:04.476	6.925	-0.189	-0.006	2.649	14.510	12.460
Mill On Run 3			(actual)		<	0.032	2.915	13.626	12.463
Oxygen		11.7%	(ppm.dry @7% O2)	7.308	<	0.054	4.954	11.1	M26A Moisture
DSCFM		251.600	(lbs/hr)	8.703	<	0.028	3.603		
Clinker (tons/hr)		130.40	(lbs/ton clinker)	0.067	<	0.0002			

Company: Buzzi Unicem; Maryneal TX
Source: Main Stack; Raw Mill Off
Job ID: 23-3315
Train Type: EPA Method 26A

	5A 11/30/23 1405-1511	5B 11/30/23 1405-1511	6A 11/30/23 1539-1645	6B 11/30/23 1539-1645	7A 11/30/23 1725-1831	7B 11/30/23 1725-1831	Average
Initial Meter Volume, ft ³	42.388	148.366	87.361	192.402	133.245	237.196	
Final Meter Volume, ft ³	87.059	192.303	133.165	236.989	178.981	282.538	
Intra-Port Volume and/or Leak Check Correction, ft ³	0.000	0.000	0.000	0.000	0.000	0.000	
Total Sample Volume, cf	44.671	43.937	45.804	44.587	45.736	45.342	45.013
DGM Calibration Factor	0.975	0.985	0.975	0.985	0.975	0.985	0.980
Average DGM Temp, F	78.0	82.3	78.1	81.3	78.1	82.3	80.0
Average DGM delta H, "H ₂ O	1.48	1.46	1.51	1.51	1.52	1.54	1.50
Barometric Pressure, "Hg	27.43	27.43	27.43	27.43	27.43	27.43	27.43
Corrected Sample Vol, dscf	39.318	38.757	40.311	39.408	40.252	40.005	39.675
Corrected Sample Vol, dscm	1.113	1.097	1.141	1.116	1.140	1.133	1.123
Sample Volume (at Stack Conditions), acf	72.248	71.720	72.656	71.524	72.766	73.081	72.333
Sample Volume (at Stack Conditions), acm	2.046	2.031	2.057	2.025	2.061	2.069	2.048
Oxygen, %	9.7	9.7	9.9	9.9	10.0	10.0	9.9
Carbon Dioxide, %	18.2	18.2	17.9	17.9	17.8	17.8	18.0
Nitrogen, %	72.1	72.1	72.2	72.2	72.2	72.2	72.2
Stack Gas Excess Air, %	103.9	103.9	108.1	108.1	110.4	110.4	107.5
Total Moisture Catch Weight, grams	140.1	144.8	133.2	137.5	135.2	145.3	139.3
Stack Gas Moisture, %	14.4	15.0	13.5	14.1	13.7	14.6	14.2
Stack Gas Dry Molecular Weight, lb/lbmole	31.30	31.30	31.26	31.26	31.25	31.25	31.27
Stack Gas Wet Molecular Weight, lb/lbmole	29.38	29.31	29.47	29.39	29.43	29.31	29.38
Average Stack Temp, F	300.0	300.0	293.3	293.3	293.8	293.8	295.7
Stack Static (Gauge) Pressure, "H ₂ O	-0.67	-0.67	-0.67	-0.67	-0.67	-0.67	-0.67
Stack Gas Actual Pressure, "Hg	27.38	27.38	27.38	27.38	27.38	27.38	27.38
Average Sqrt delta P *	0.822	0.822	0.838	0.838	0.835	0.835	0.832
Pitot Tube Coefficient	0.85	0.85	0.85	0.85	0.85	0.85	0.85
Stack Gas Velocity, ft/second	58.06	58.13	58.84	58.92	58.69	58.81	58.58
Nozzle Inside Diameter, inches	0.250	0.250	0.250	0.250	0.250	0.250	
Total Sample Time, min	60	60	60	60	60	60	60
Isokinetic Rate, %	101.5	100.6	100.7	99.0	101.1	101.3	100.7
Stack Dimensions	140 in. ID	140 in. ID	140 in. ID	140 in. ID	140 in. ID	140 in. ID	
Stack Area, sq ft	106.90	106.90	106.90	106.90	106.90	106.90	106.90
Actual Stack Gas Flow Rate, acfm	372,400	372,800	377,400	377,900	376,400	377,200	375,700
Actual Stack Gas Flow Rate, acmm	10,545	10,557	10,687	10,701	10,659	10,681	10,638
Stack Gas Flow Rate, dscfm	202,700	201,500	209,400	208,200	208,200	206,500	206,100
Stack Gas Flow Rate, dscmm	5,740	5,706	5,930	5,896	5,896	5,847	5,836

NOTE: Average INCLUDES Non-detect runs' results

"ND()" denotes values below detection limits									
Hydrogen Fluoride	5A 11/30/23 1405-1511	5B 11/30/23 1405-1511	6A 30-Nov-23 1539-1645	6B 30-Nov-23 1539-1645	7A 30-Nov-23 1725-1831	7B 30-Nov-23 1725-1831	Average		
Catch Wt, mg	ND(0.243)	ND(0.265)	ND(0.253)	ND(0.251)	ND(0.251)	ND(0.267)	ND(0.255)		
Conc., mg/dscm	ND(0.218)	ND(0.242)	ND(0.222)	ND(0.225)	ND(0.220)	ND(0.236)	ND(0.227)		
Conc., mg/dscm @ 7% O2	ND(0.271)	ND(0.300)	ND(0.280)	ND(0.284)	ND(0.281)	ND(0.301)	ND(0.286)		
Conc., mg/dscm @ 12% CO2	ND(0.144)	ND(0.159)	ND(0.149)	ND(0.151)	ND(0.148)	ND(0.159)	ND(0.152)		
Conc., ppmvd	ND(0.263)	ND(0.290)	ND(0.267)	ND(0.270)	ND(0.265)	ND(0.283)	ND(0.273)		
Conc., ppmvd @ 7% O2	ND(0.326)	ND(0.360)	ND(0.337)	ND(0.342)	ND(0.338)	ND(0.361)	ND(0.344)		
Conc., ppmvd @ 12% CO2	ND(0.173)	ND(0.192)	ND(0.179)	ND(0.181)	ND(0.178)	ND(0.191)	ND(0.182)		
Emission Rate, lb/hr	ND(0.166)	ND(0.182)	ND(0.174)	ND(0.175)	ND(0.172)	ND(0.182)	ND(0.175)		
Clinker Rates (tph and lbs/ton)	128.90	ND(0.0014)	128.90	ND(0.0014)	128.90	ND(0.0014)	ND(0.0014)		

Hydrogen Fluoride	Catch Wt, mg	ND(0.243)	ND(0.265)	ND(0.253)	ND(0.251)	ND(0.251)	ND(0.267)	ND(0.255)
	Conc., mg/dscm	ND(0.218)	ND(0.242)	ND(0.222)	ND(0.225)	ND(0.220)	ND(0.236)	ND(0.227)
	Conc., mg/dscm @ 7% O2	ND(0.271)	ND(0.300)	ND(0.280)	ND(0.284)	ND(0.281)	ND(0.301)	ND(0.286)
	Conc., mg/dscm @ 12% CO2	ND(0.144)	ND(0.159)	ND(0.149)	ND(0.151)	ND(0.148)	ND(0.159)	ND(0.152)
	Conc., ppmvd	ND(0.263)	ND(0.290)	ND(0.267)	ND(0.270)	ND(0.265)	ND(0.283)	ND(0.273)
	Conc., ppmvd @ 7% O2	ND(0.326)	ND(0.360)	ND(0.337)	ND(0.342)	ND(0.338)	ND(0.361)	ND(0.344)
	Conc., ppmvd @ 12% CO2	ND(0.173)	ND(0.192)	ND(0.179)	ND(0.181)	ND(0.178)	ND(0.191)	ND(0.182)
	Emission Rate, lb/hr	ND(0.166)	ND(0.182)	ND(0.174)	ND(0.175)	ND(0.172)	ND(0.182)	ND(0.175)
	Clinker Rates (tph and lbs/ton)	128.90	ND(0.0014)	128.90	ND(0.0014)	128.90	ND(0.0014)	ND(0.0014)
	Chlorine	Catch Wt, mg	0.631	0.672	0.286	0.306	0.580	0.617
Conc., mg/dscm		0.567	0.613	0.251	0.274	0.509	0.545	0.460
Conc., mg/dscm @ 7% O2		0.704	0.760	0.317	0.346	0.649	0.694	0.578
Conc., mg/dscm @ 12% CO2		0.374	0.404	0.168	0.184	0.343	0.367	0.307
Conc., ppmvd		0.192	0.208	0.085	0.093	0.173	0.185	0.156
Absolute Difference, ppmvd (<0.2 required)			0.015	0.085	0.008		0.012	
Conc., ppmvd @ 7% O2		0.239	0.258	0.107	0.118	0.220	0.236	0.196
Conc., ppmvd @ 12% CO2		0.127	0.137	0.057	0.062	0.116	0.125	0.104
Emission Rate, lb/hr		0.479	0.507	0.224	0.239	0.452	0.477	0.396
Clinker Rates (tph and lbs/ton)		128.90	0.0038	128.90	0.0018	128.90	0.0036	0.0031

Company: Buzz! Unicem; Maryneal TX
Source: Main Stack; Raw Mill Off
Job ID: 23-3315
Train Type: EPA Method 26A

NOTE: Average INCLUDES Non-detect runs' results

"ND()" denotes values below detection limits

		5A		5B		6A		6B		7A		7B		Average
		11/30/23	1405-1511	11/30/23	1405-1511	30-Nov-23	1539-1645	30-Nov-23	1539-1645	30-Nov-23	1725-1831	30-Nov-23	1725-1831	
Hydrogen Fluoride	Catch Wt, mg	ND(	0.243	ND(	0.265	ND(	0.253	ND(	0.251	ND(	0.251	ND(	0.267	ND(
	Conc., mg/dscm	ND(	0.218	ND(	0.242	ND(	0.222	ND(	0.225	ND(	0.220	ND(	0.236	ND(
	Conc., mg/dscm @ 7% O2	ND(	0.271	ND(	0.300	ND(	0.280	ND(	0.284	ND(	0.281	ND(	0.301	ND(
	Conc., mg/dscm @ 12% CO2	ND(	0.144	ND(	0.159	ND(	0.149	ND(	0.151	ND(	0.148	ND(	0.159	ND(
	Conc., ppmvd	ND(	0.263	ND(	0.290	ND(	0.267	ND(	0.270	ND(	0.265	ND(	0.283	ND(
	Conc., ppmvd @ 7% O2	ND(	0.326	ND(	0.360	ND(	0.337	ND(	0.342	ND(	0.338	ND(	0.361	ND(
	Conc., ppmvd @ 12% CO2	ND(	0.173	ND(	0.192	ND(	0.179	ND(	0.181	ND(	0.178	ND(	0.191	ND(
	Emission Rate, lb/hr	ND(	0.166	ND(	0.182	ND(	0.174	ND(	0.175	ND(	0.172	ND(	0.182	ND(
	Clinker Rates (mtp and lbs/ton)	128.90		ND(	0.0012	128.90		ND(	0.0012	128.90		ND(	0.0012	ND(
														0.255
														0.227
Chlorine	Catch Wt, mg	0.631		0.672		0.286		0.306		0.580		0.617		0.515
	Conc., mg/dscm	0.567		0.613		0.251		0.274		0.509		0.545		0.460
	Conc., mg/dscm @ 7% O2	0.704		0.760		0.317		0.346		0.649		0.694		0.578
	Conc., mg/dscm @ 12% CO2	0.374		0.404		0.168		0.184		0.343		0.367		0.307
	Conc., ppmvd	0.195		0.210		0.086		0.094		0.175		0.187		0.158
	Absolute Difference, ppmvd (<0.2 required)			0.016				0.008				0.012		
	Conc., ppmvd @ 7% O2	0.241		0.261		0.109		0.119		0.223		0.238		0.199
	Conc., ppmvd @ 12% CO2	0.128		0.139		0.058		0.063		0.118		0.126		0.105
	Emission Rate, lb/hr	0.479		0.507		0.224		0.239		0.452		0.477		0.396
	Clinker Rates (mtp and lbs/ton)	128.90		0.0035		128.90		0.0016		128.90		0.0033		0.0028

Buzzi Unicem, Maryneal TX
Main Stack, Raw Mill Off

Run 1

Spectrum	Date	Time	HCl PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C
SPC_003932.LAB	11/30/23	14:06:08.642	10.570	-0.218	-0.013	3.152	15.198	14.762
SPC_003933.LAB	11/30/23	14:07:10.538	10.511	-0.176	-0.008	3.101	15.046	14.788
SPC_003934.LAB	11/30/23	14:08:14.400	10.391	-0.183	-0.008	3.066	15.083	14.882
SPC_003935.LAB	11/30/23	14:09:18.347	10.589	-0.235	-0.009	3.078	15.003	15.079
SPC_003936.LAB	11/30/23	14:10:22.556	10.494	-0.226	-0.012	3.169	14.960	14.866
SPC_003937.LAB	11/30/23	14:11:26.114	10.419	-0.186	-0.009	3.393	14.971	14.791
SPC_003938.LAB	11/30/23	14:12:30.024	10.333	-0.185	-0.009	3.335	15.192	14.902
SPC_003939.LAB	11/30/23	14:13:33.930	10.158	-0.182	-0.011	3.487	15.281	14.914
SPC_003940.LAB	11/30/23	14:14:38.121	10.201	-0.181	-0.010	3.521	15.436	14.824
SPC_003941.LAB	11/30/23	14:15:41.810	10.293	-0.174	-0.008	3.485	15.044	14.936
SPC_003942.LAB	11/30/23	14:16:45.633	10.328	-0.185	-0.010	3.401	15.260	14.875
SPC_003943.LAB	11/30/23	14:17:49.577	10.330	-0.187	-0.009	3.257	15.165	15.010
SPC_003944.LAB	11/30/23	14:18:53.483	10.515	-0.178	-0.009	3.239	15.112	15.024
SPC_003945.LAB	11/30/23	14:19:57.457	10.322	-0.167	-0.010	3.284	15.647	14.932
SPC_003946.LAB	11/30/23	14:21:01.245	10.202	-0.192	-0.008	3.332	15.279	14.787
SPC_003947.LAB	11/30/23	14:22:05.536	10.446	-0.192	-0.003	3.355	15.270	15.000
SPC_003948.LAB	11/30/23	14:23:09.059	10.126	-0.173	-0.010	3.239	15.526	14.803
SPC_003949.LAB	11/30/23	14:24:12.997	10.281	-0.179	-0.006	3.243	15.466	14.773
SPC_003950.LAB	11/30/23	14:25:16.972	10.354	-0.178	-0.010	3.132	14.991	14.932
SPC_003951.LAB	11/30/23	14:26:21.106	10.401	-0.183	-0.009	3.162	15.189	14.972
SPC_003952.LAB	11/30/23	14:27:24.661	10.564	-0.184	-0.011	3.041	15.351	14.923
SPC_003953.LAB	11/30/23	14:28:28.819	10.630	-0.239	-0.009	3.036	15.002	15.135
SPC_003954.LAB	11/30/23	14:29:32.581	10.388	-0.177	-0.010	3.145	15.058	14.940
SPC_003955.LAB	11/30/23	14:30:36.465	10.320	-0.184	-0.009	3.061	15.512	14.742
SPC_003956.LAB	11/30/23	14:31:40.282	10.449	-0.184	-0.008	3.116	14.955	14.950
SPC_003957.LAB	11/30/23	14:32:44.180	10.478	-0.193	-0.013	3.102	15.110	14.866
SPC_003958.LAB	11/30/23	14:33:48.124	10.380	-0.186	-0.011	3.094	15.562	14.819
SPC_003959.LAB	11/30/23	14:34:51.999	10.313	-0.184	-0.009	3.015	15.515	14.940
SPC_003960.LAB	11/30/23	14:35:55.990	10.396	-0.173	-0.009	3.089	15.250	14.603
SPC_003961.LAB	11/30/23	14:36:59.796	10.166	-0.194	-0.007	3.107	15.190	14.835
SPC_003962.LAB	11/30/23	14:38:03.707	10.313	-0.175	-0.009	3.130	15.240	14.897
SPC_003963.LAB	11/30/23	14:39:07.600	10.326	-0.181	-0.006	3.097	15.247	14.830
SPC_003964.LAB	11/30/23	14:40:11.655	10.298	-0.193	-0.009	3.081	15.281	14.815
SPC_003965.LAB	11/30/23	14:41:15.482	10.188	-0.180	-0.009	3.124	15.678	14.811
SPC_003966.LAB	11/30/23	14:42:19.679	10.453	-0.186	-0.010	3.154	15.269	14.783
SPC_003967.LAB	11/30/23	14:43:23.209	10.245	-0.174	-0.008	3.124	14.990	14.855
SPC_003968.LAB	11/30/23	14:44:27.506	10.243	-0.183	-0.006	3.091	15.417	14.732
SPC_003969.LAB	11/30/23	14:45:31.061	10.282	-0.186	-0.010	3.012	15.105	14.831
SPC_003970.LAB	11/30/23	14:46:34.916	10.230	-0.189	-0.009	3.029	15.001	14.947
SPC_003971.LAB	11/30/23	14:47:38.824	10.360	-0.190	-0.008	3.070	14.807	14.807
SPC_003972.LAB	11/30/23	14:48:42.718	10.319	-0.189	-0.008	2.996	15.236	14.868
SPC_003973.LAB	11/30/23	14:49:46.618	10.282	-0.190	-0.010	3.001	14.946	14.878
SPC_003974.LAB	11/30/23	14:50:50.570	10.318	-0.186	-0.010	3.148	15.152	14.861
SPC_003975.LAB	11/30/23	14:51:54.426	10.298	-0.197	-0.009	3.143	15.217	14.768
SPC_003976.LAB	11/30/23	14:52:58.382	10.527	-0.180	-0.014	3.214	15.235	14.809
SPC_003977.LAB	11/30/23	14:54:02.241	10.475	-0.189	-0.008	3.167	15.011	14.947
SPC_003978.LAB	11/30/23	14:55:06.281	10.632	-0.185	-0.008	3.100	14.942	14.973
SPC_003979.LAB	11/30/23	14:56:10.104	10.525	-0.205	-0.011	3.208	14.899	15.101
SPC_003980.LAB	11/30/23	14:57:14.298	10.446	-0.177	-0.012	3.128	15.196	14.880
SPC_003981.LAB	11/30/23	14:58:17.848	10.250	-0.200	-0.009	3.225	15.114	14.842
SPC_003982.LAB	11/30/23	14:59:21.816	9.997	-0.203	-0.011	3.049	15.263	14.736
SPC_003983.LAB	11/30/23	15:00:25.653	10.134	-0.195	-0.008	3.084	15.148	14.752
SPC_003984.LAB	11/30/23	15:01:29.668	10.441	-0.173	-0.010	2.954	14.943	14.860
SPC_003985.LAB	11/30/23	15:02:33.505	10.531	-0.182	-0.010	3.058	14.827	14.799
SPC_003986.LAB	11/30/23	15:03:37.361	10.589	-0.187	-0.008	3.041	15.016	14.820
SPC_003987.LAB	11/30/23	15:04:41.368	10.463	-0.184	-0.012	2.991	15.069	14.709
SPC_003988.LAB	11/30/23	15:05:45.202	10.697	-0.231	-0.012	2.966	15.176	14.973
SPC_003989.LAB	11/30/23	15:06:49.416	10.516	-0.229	-0.010	3.043	15.223	14.910
SPC_003990.LAB	11/30/23	15:08:07.985	10.424	-0.187	-0.008	3.062	14.959	14.830
SPC_003991.LAB	11/30/23	15:09:11.851	10.606	-0.195	-0.010	3.034	14.878	14.793
SPC_003992.LAB	11/30/23	15:10:15.789	10.483	-0.230	-0.010	3.052	14.823	14.823
SPC_003993.LAB	11/30/23	15:11:19.695	10.536	-0.182	-0.009	3.149	15.146	14.853
Mill Off Run 1	9.7% (actual)		10.384	0.032	-0.004	3.145	15.165	14.866
Oxygen	202.100 (ppm.dry @7% O2)		15.108	0.047	-0.014	4.576		
DSCFM	128.90 (tbs/hr)		10.352	0.024	-0.051	3.254		
Clinker (tons/hr)			0.080	0.002			14.7	M26A Moisture

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill Off

Run 2

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191c	SF6 (10) 191c	Ethylene (100,3000) 191c	H2O% (40) 191c	CO2% (40) 191c
SPC_004019.LAB	11/30/23	15:39:46.051	10.622	-0.220	-0.008	3.275	15.467	14.836
SPC_004020.LAB	11/30/23	15:40:49.948	10.468	-0.220	-0.010	3.219	14.988	14.908
SPC_004021.LAB	11/30/23	15:41:53.859	10.538	-0.240	-0.013	3.233	14.903	14.815
SPC_004022.LAB	11/30/23	15:42:57.759	10.431	-0.237	-0.011	3.190	15.191	14.990
SPC_004023.LAB	11/30/23	15:44:01.662	10.563	-0.182	-0.010	3.194	15.081	14.850
SPC_004024.LAB	11/30/23	15:45:05.573	10.535	-0.253	-0.010	3.164	14.971	14.816
SPC_004025.LAB	11/30/23	15:46:09.529	10.387	-0.237	-0.010	3.280	15.002	14.850
SPC_004026.LAB	11/30/23	15:47:13.374	10.500	-0.247	-0.009	3.338	14.996	14.700
SPC_004027.LAB	11/30/23	15:48:17.285	10.631	-0.238	-0.010	3.364	14.754	14.803
SPC_004028.LAB	11/30/23	15:49:21.226	10.658	-0.244	-0.010	3.276	14.856	14.781
SPC_004029.LAB	11/30/23	15:50:25.479	10.477	-0.250	-0.009	3.268	15.256	14.733
SPC_004030.LAB	11/30/23	15:51:29.040	10.623	-0.239	-0.007	3.316	14.982	14.679
SPC_004031.LAB	11/30/23	15:52:32.943	10.664	-0.238	-0.010	3.143	14.834	14.729
SPC_004032.LAB	11/30/23	15:53:36.840	10.701	-0.247	-0.010	3.038	14.601	14.785
SPC_004033.LAB	11/30/23	15:54:41.129	10.721	-0.244	-0.011	3.115	15.011	14.541
SPC_004034.LAB	11/30/23	15:55:44.645	10.601	-0.245	-0.009	3.088	14.806	14.561
SPC_004035.LAB	11/30/23	15:56:48.598	10.546	-0.241	-0.008	3.186	14.513	14.563
SPC_004036.LAB	11/30/23	15:57:52.416	10.623	-0.239	-0.007	3.130	14.525	14.754
SPC_004037.LAB	11/30/23	15:58:56.315	10.683	-0.241	-0.007	3.204	14.911	14.543
SPC_004038.LAB	11/30/23	16:00:00.269	10.553	-0.251	-0.007	3.182	15.004	14.648
SPC_004039.LAB	11/30/23	16:01:04.131	10.643	-0.250	-0.011	3.158	14.591	14.674
SPC_004040.LAB	11/30/23	16:02:08.072	10.605	-0.244	-0.008	3.111	14.865	14.762
SPC_004041.LAB	11/30/23	16:03:11.977	10.737	-0.240	-0.008	3.161	14.845	14.637
SPC_004042.LAB	11/30/23	16:04:15.847	10.513	-0.250	-0.009	3.140	15.018	14.562
SPC_004043.LAB	11/30/23	16:05:20.159	10.615	-0.242	-0.006	3.179	14.787	14.843
SPC_004044.LAB	11/30/23	16:06:23.661	10.571	-0.235	-0.007	3.126	14.748	14.589
SPC_004045.LAB	11/30/23	16:07:27.548	10.479	-0.236	-0.007	3.212	14.562	14.588
SPC_004046.LAB	11/30/23	16:08:31.831	10.364	-0.222	-0.008	3.195	14.956	14.632
SPC_004047.LAB	11/30/23	16:09:35.397	10.652	-0.239	-0.011	3.247	14.745	14.505
SPC_004048.LAB	11/30/23	16:10:39.261	10.555	-0.258	-0.007	3.139	14.697	14.697
SPC_004049.LAB	11/30/23	16:11:43.295	10.746	-0.243	-0.010	3.198	14.873	14.841
SPC_004050.LAB	11/30/23	16:12:47.061	10.608	-0.239	-0.009	3.183	15.088	14.563
SPC_004051.LAB	11/30/23	16:13:50.987	10.772	-0.243	-0.010	3.078	14.569	14.713
SPC_004052.LAB	11/30/23	16:14:54.863	10.551	-0.243	-0.011	3.162	14.934	14.585
SPC_004053.LAB	11/30/23	16:15:58.770	10.793	-0.231	-0.011	3.157	14.444	14.681
SPC_004054.LAB	11/30/23	16:17:02.677	10.556	-0.254	-0.008	3.222	15.074	14.494
SPC_004055.LAB	11/30/23	16:18:06.574	10.782	-0.242	-0.008	3.217	14.724	14.573
SPC_004056.LAB	11/30/23	16:19:10.527	10.843	-0.232	-0.007	3.215	15.064	14.675
SPC_004057.LAB	11/30/23	16:20:14.391	10.739	-0.260	-0.009	3.201	14.851	14.869
SPC_004058.LAB	11/30/23	16:21:18.288	10.771	-0.260	-0.011	3.276	14.626	14.737
SPC_004059.LAB	11/30/23	16:22:22.543	10.759	-0.236	-0.009	3.264	14.830	14.550
SPC_004060.LAB	11/30/23	16:23:26.385	10.863	-0.245	-0.009	3.244	14.565	14.682
SPC_004061.LAB	11/30/23	16:24:30.138	10.868	-0.240	-0.008	3.340	15.076	14.507
SPC_004062.LAB	11/30/23	16:25:33.905	10.860	-0.232	-0.006	3.212	14.649	14.745
SPC_004063.LAB	11/30/23	16:26:38.204	10.756	-0.244	-0.009	3.259	14.703	14.725
SPC_004064.LAB	11/30/23	16:27:41.735	10.918	-0.234	-0.010	3.147	14.750	14.696
SPC_004065.LAB	11/30/23	16:28:45.615	10.864	-0.234	-0.011	3.088	14.718	14.768
SPC_004066.LAB	11/30/23	16:29:49.525	10.852	-0.231	-0.008	3.185	14.903	14.583
SPC_004067.LAB	11/30/23	16:30:53.421	10.886	-0.262	-0.008	3.198	14.701	14.806
SPC_004068.LAB	11/30/23	16:31:57.322	10.971	-0.244	-0.006	3.123	14.603	14.628
SPC_004069.LAB	11/30/23	16:33:01.232	10.925	-0.253	-0.008	3.253	14.722	14.689
SPC_004070.LAB	11/30/23	16:34:05.474	10.825	-0.247	-0.009	3.307	14.841	14.637
SPC_004071.LAB	11/30/23	16:35:09.032	10.722	-0.248	-0.009	3.324	14.820	14.746
SPC_004072.LAB	11/30/23	16:36:12.943	10.768	-0.239	-0.008	3.298	15.010	14.722
SPC_004073.LAB	11/30/23	16:37:16.837	10.858	-0.238	-0.006	3.313	14.735	14.793
SPC_004074.LAB	11/30/23	16:38:20.733	10.921	-0.256	-0.009	3.202	15.039	14.629
SPC_004075.LAB	11/30/23	16:39:24.642	10.836	-0.241	-0.010	3.225	14.708	14.837
SPC_004076.LAB	11/30/23	16:40:28.543	11.054	-0.244	-0.008	3.141	14.565	14.758
SPC_004077.LAB	11/30/23	16:41:32.449	10.957	-0.243	-0.010	3.365	14.859	14.669
SPC_004078.LAB	11/30/23	16:42:36.357	10.862	-0.247	-0.008	3.296	14.751	14.743
SPC_004079.LAB	11/30/23	16:43:40.252	10.947	-0.247	-0.008	3.298	14.730	14.693
SPC_004080.LAB	11/30/23	16:44:44.156	11.000	-0.247	-0.008	3.242	14.694	14.789
Mill Off Run 2		(actual)	10.705	<	-0.009	3.211	14.832	14.698
Oxygen	9.9%	(ppm,dry @7% O2)	15.693	<			13.8	M26A Moisture
DSCFM	208,800	(lbsh/hr)	10.912	<				
Clinker (tons/hr)	128.90	(lbstons clinker)	0.085	<				

Buzzi Unicem: Maryneal TX
Main Stack, Raw Mill Off

Run 3


Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C
SPC_004118.LAB	11/30/23	17:26:09.022	10.517	-0.246	-0.010	3.276	14.933	14.473
SPC_004119.LAB	11/30/23	17:27:12.780	10.549	-0.230	-0.008	3.210	14.588	14.725
SPC_004120.LAB	11/30/23	17:28:16.755	10.754	-0.241	-0.009	3.220	14.704	14.674
SPC_004121.LAB	11/30/23	17:29:20.541	10.674	-0.231	-0.008	3.364	14.451	14.612
SPC_004122.LAB	11/30/23	17:30:24.453	10.611	-0.237	-0.009	3.293	14.866	14.580
SPC_004123.LAB	11/30/23	17:31:28.458	10.873	-0.257	-0.008	3.229	14.558	14.705
SPC_004124.LAB	11/30/23	17:32:32.248	10.763	-0.246	-0.008	3.185	14.530	14.732
SPC_004125.LAB	11/30/23	17:33:36.161	10.527	-0.240	-0.009	3.263	14.555	14.614
SPC_004126.LAB	11/30/23	17:34:40.063	10.569	-0.242	-0.010	3.219	14.748	14.657
SPC_004127.LAB	11/30/23	17:35:44.006	10.628	-0.252	-0.011	3.182	14.733	14.733
SPC_004128.LAB	11/30/23	17:36:47.866	10.788	-0.241	-0.009	3.167	14.765	14.818
SPC_004129.LAB	11/30/23	17:37:51.777	10.678	-0.241	-0.009	3.236	14.712	14.901
SPC_004130.LAB	11/30/23	17:38:55.678	10.358	-0.231	-0.009	3.378	14.988	14.579
SPC_004131.LAB	11/30/23	17:39:59.580	10.293	-0.193	-0.009	3.368	14.906	14.539
SPC_004132.LAB	11/30/23	17:41:03.605	10.447	-0.240	-0.007	3.291	14.294	14.644
SPC_004133.LAB	11/30/23	17:42:07.595	10.584	-0.237	-0.008	3.274	15.011	14.540
SPC_004134.LAB	11/30/23	17:43:11.290	10.699	-0.248	-0.007	3.262	14.491	14.691
SPC_004135.LAB	11/30/23	17:44:15.287	10.431	-0.255	-0.008	3.233	14.868	14.636
SPC_004136.LAB	11/30/23	17:45:19.096	10.514	-0.201	-0.008	3.209	14.493	14.676
SPC_004137.LAB	11/30/23	17:46:23.001	10.322	-0.184	-0.009	3.136	14.907	14.527
SPC_004138.LAB	11/30/23	17:47:26.909	10.585	-0.204	-0.008	3.172	14.302	14.578
SPC_004139.LAB	11/30/23	17:48:31.017	10.564	-0.207	-0.009	3.051	15.012	14.525
SPC_004140.LAB	11/30/23	17:49:34.713	10.548	-0.202	-0.010	3.075	14.573	14.678
SPC_004141.LAB	11/30/23	17:50:38.626	10.244	-0.244	-0.008	3.229	14.941	14.579
SPC_004142.LAB	11/30/23	17:51:42.523	10.179	-0.255	-0.007	3.251	15.102	14.365
SPC_004143.LAB	11/30/23	17:52:46.426	10.116	-0.245	-0.010	3.280	14.821	14.468
SPC_004144.LAB	11/30/23	17:53:50.521	10.485	-0.235	-0.009	3.269	14.548	14.579
SPC_004145.LAB	11/30/23	17:54:54.231	10.541	-0.239	-0.006	3.245	14.697	14.593
SPC_004146.LAB	11/30/23	17:55:58.190	10.558	-0.241	-0.009	3.203	14.838	14.593
SPC_004147.LAB	11/30/23	17:57:02.225	10.404	-0.251	-0.008	3.266	14.986	14.414
SPC_004148.LAB	11/30/23	17:58:06.149	10.307	-0.244	-0.009	3.384	14.964	14.473
SPC_004149.LAB	11/30/23	17:59:09.886	10.405	-0.256	-0.009	3.293	14.832	14.572
SPC_004150.LAB	11/30/23	18:00:14.088	10.384	-0.251	-0.008	3.275	14.569	14.662
SPC_004151.LAB	11/30/23	18:01:17.651	10.186	-0.239	-0.008	3.350	15.102	14.622
SPC_004152.LAB	11/30/23	18:02:21.552	10.296	-0.231	-0.009	3.332	14.519	14.642
SPC_004153.LAB	11/30/23	18:03:25.852	10.298	-0.246	-0.009	3.359	14.754	14.684
SPC_004154.LAB	11/30/23	18:04:29.368	10.112	-0.249	-0.010	3.253	15.734	14.523
SPC_004155.LAB	11/30/23	18:05:33.469	10.248	-0.237	-0.010	3.307	14.929	14.713
SPC_004156.LAB	11/30/23	18:06:37.169	10.432	-0.235	-0.008	3.397	14.654	14.673
SPC_004157.LAB	11/30/23	18:07:41.071	10.205	-0.237	-0.010	3.351	15.142	14.510
SPC_004158.LAB	11/30/23	18:08:45.346	10.194	-0.244	-0.007	3.340	14.776	14.645
SPC_004159.LAB	11/30/23	18:09:49.016	10.140	-0.242	-0.007	3.313	14.675	14.656
SPC_004160.LAB	11/30/23	18:10:52.779	10.399	-0.250	-0.009	3.182	15.002	14.582
SPC_004161.LAB	11/30/23	18:11:56.684	10.378	-0.229	-0.009	3.197	14.720	14.603
SPC_004162.LAB	11/30/23	18:13:00.599	10.363	-0.197	-0.007	3.161	14.598	14.612
SPC_004163.LAB	11/30/23	18:14:04.490	10.297	-0.215	-0.008	3.103	14.831	14.747
SPC_004164.LAB	11/30/23	18:15:08.392	10.250	-0.240	-0.011	3.229	14.724	14.676
SPC_004165.LAB	11/30/23	18:16:12.302	10.429	-0.247	-0.010	3.109	15.036	14.472
SPC_004166.LAB	11/30/23	18:17:16.308	10.520	-0.246	-0.006	3.239	15.098	14.439
SPC_004167.LAB	11/30/23	18:18:20.148	10.653	-0.248	-0.009	3.133	14.508	14.546
SPC_004168.LAB	11/30/23	18:19:24.007	10.351	-0.247	-0.008	3.095	15.108	14.556
SPC_004169.LAB	11/30/23	18:20:27.917	10.274	-0.249	-0.009	3.054	14.813	14.565
SPC_004170.LAB	11/30/23	18:21:31.896	10.264	-0.244	-0.007	3.210	14.584	14.620
SPC_004171.LAB	11/30/23	18:22:35.720	9.999	-0.234	-0.011	3.087	15.059	14.415
SPC_004172.LAB	11/30/23	18:23:39.629	10.145	-0.256	-0.005	3.122	14.533	14.763
SPC_004173.LAB	11/30/23	18:24:43.869	10.289	-0.246	-0.009	3.040	14.854	14.625
SPC_004174.LAB	11/30/23	18:25:47.772	10.239	-0.251	-0.008	3.073	14.524	14.590
SPC_004175.LAB	11/30/23	18:26:51.580	9.994	-0.235	-0.011	3.168	14.955	14.550
SPC_004176.LAB	11/30/23	18:27:55.226	10.296	-0.215	-0.006	3.001	14.670	14.523
SPC_004177.LAB	11/30/23	18:28:59.136	10.222	-0.209	-0.010	3.093	15.168	14.477
SPC_004178.LAB	11/30/23	18:30:03.292	10.323	-0.245	-0.007	3.046	14.659	14.748
SPC_004179.LAB	11/30/23	18:31:07.393	10.394	-0.189	-0.008	3.109	14.757	14.556
Mill Off Run 3		(actual)	10.403	0.032	-0.009	3.217	14.788	14.604
Oxygen	10.0%	(ppm, dry @7% O2)	15.453	< 0.048	-0.013	4.779		
DSCFM	207.350	(lbs/hr)	10.573	< 0.024		3.394		
Clinker (tons/hr)	128.90	(lbs/ton clinker)	0.082	< 0.0002	-0.047		14.2	M26A Moisture

Appendix B

Field Data
and
CEM/FTIR Data

Traverse Point Location for Circular Ducts

Plant	Lone Star Industries		
City	Maryneal	State	TX
Location	Main Kiln Stack		
Stack ID (inches)	140		
Nipple Length	6.25		
Nearest Upstream Disturbance (Bend, ID FAN, etc)			
Distance (inches)	1893	Type of Disturbance	
Nearest Downstream Disturbance (Bend, or Stack Outlet)			
Distance (inches)	579	Type of Disturbance	
Sampler	SCS	Date	11/28/23



Particulate Traverse?

x	Yes		No
----------	------------	--	-----------

Stack Schematic (Draw by hand after printing)

Number of Traverse Points Required

6

[illegible]

Cyclonic Flow Check Data Sheet

PLANT AND CITY <i>Buzzi Marginal TX</i>		DATE <i>11/24/22</i>	SAMPLING LOCATION <i>Main Stack</i>		SAMPLE TYPE <i>Cyclonic Flow Check</i>		RUN NUMBER		
OPERATOR <i>WV/GM</i>	Barometric Pressure (Pb) (in. Hg) <i>27.32</i>	STATIC PRESS (in. H2O) <i>-20.67</i>	AMBIENT TEMP (deg. F) <i>50</i>	STACK ID (in.) <i>140</i>	PITOT Cp <i>0.84</i>	DGM BOX No. <i>MJ-15</i>	DGM delta H@ <i>NA</i>	DGM CAL FACTOR (gamma) <i>NA</i>	PROBE ID NO <i>5B</i>

EPA Method 2 Data

Run Time (24 hr)	Traverse Port ID	Point	Pitot Delta P READING " H2O	STACK TEMP deg F	Absolute Angle at null (0) Delta P READING " H2O
	<i>A</i>	<i>1</i>	<i>0.90</i>	<i>241</i>	<i>5</i>
		<i>2</i>	<i>0.90</i>	<i>244</i>	<i>3</i>
		<i>3</i>	<i>0.95</i>	<i>240</i>	<i>3</i>
	<i>B</i>	<i>1</i>	<i>1.1</i>	<i>243</i>	<i>4</i>
		<i>2</i>	<i>1.0</i>	<i>247</i>	<i>4</i>
		<i>3</i>	<i>0.95</i>	<i>244</i>	<i>4</i>
	<i>C</i>	<i>1</i>	<i>1.0</i>	<i>242</i>	<i>3</i>
		<i>2</i>	<i>0.96</i>	<i>243</i>	<i>4</i>
		<i>3</i>	<i>0.90</i>	<i>240</i>	<i>3</i>
	<i>D</i>	<i>1</i>	<i>0.98</i>	<i>240</i>	<i>5</i>
		<i>2</i>	<i>1.0</i>	<i>241</i>	<i>3</i>
		<i>3</i>	<i>1.0</i>	<i>244</i>	<i>3</i>
Pitot Leak Check			<i>✓</i>		
Averages					

Average of Absolute Angle Readings must be < 20 degrees

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE	SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER 1	
Burlington, Vermont		12/29/2013	M26A		1A		0N	
OPERATOR		AMBIENT PRESS (in. Hg)	STATIC PRESSURE (in. Water)	AMBIENT TEMP (deg. F)	FILTER NUMBERS	STACK ID (in.)	PITOT Cp	PROBE LENGTH AND LINER TYPE
122 Harts		207.32	-0.67	50	AK	140.00	0.85	14 Class effective
ASSUMED DGM MOISTURE BOX No. (%)		DGM H@	DGM CAL FACTOR (Y)	STACK THERM NO.	STACK PITOT NO.	ORSAT NO.	LEAK CHECK (INITIAL)	LEAK CHECK (FINAL)
15		103	0.975	5A	5A	2521	0.01	0.01
PITOT LEAK CHECK		PASSED						
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	delta P VELOCITY HEAD (in. H2O)	delta H ORIFICE (in. H2O)	PROBE TEMP (deg. F)	STACK TEMP (deg. F)	DGM IN / OUT TEMP (deg. F)
A-1		0	1450	0.90	2.1	253	243	68
2		5	866.17	0.92	2.2	254	244	70
3		10	870.61	0.93	2.2	256	239	70
15		1505	875.079	End of Port				
INTRA-PORT LEAK CHECK?		LEAK RATE: /						
DGM VOLUME (CU. FT)		INITIAL	FINAL					
B-1		15	875.079	1.2	2.3	255	245	69
2		20	880.19	0.95	2.3	255	245	70
3		25	884.98	0.90	2.1	256	245	71
30		1522	887.319	End of Port				
INTRA-PORT LEAK CHECK?		LEAK RATE: /						
DGM VOLUME (CU. FT)		INITIAL	FINAL					
C-1		30	889.319	0.94	2.2	254	243	69
2		35	893.34	0.96	2.3	255	242	70
3		40	898.19	0.92	2.2	253	238	69
45		1539	902.719	End of Port				
INTRA-PORT LEAK CHECK?		LEAK RATE: /						
DGM VOLUME (CU. FT)		INITIAL	FINAL					
D-1		45	902.719	1.0	2.4	256	238	68
2		50	907.44	1.1	2.6	257	242	70
3		55	912.34	1.1	2.6	255	245	71
60		1556	917.275	End of Port				
TOTAL TIME		DGM VOLUME		AVE SQRT delta P	AVE. TEMP.		AVE. TEMP.	
60 Min.								
NOZZLE DIAMETER		CO2 CONTENT %		K FACTOR				
.250		.250		1.57				
SAMPLE TRAIN VAC (in. Hg)		FILTR OVEN TEMP (deg. F)		SIL GEL EXIT TEMP (deg. F)				
5		246		61				
5		248		57				
6		255		55				

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Buzzi Maryland TX
 Sample Location Main Stack
 Run No. 1A ON -M26A- TA
 Filter Number(s) Not Applicable

Sample Date 11 / 29 / 23
 Recovery Date 11 / 29 / 23
 Recovered by gcs

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		842.4	784.5	648.9	751.4	742.9	920.6	g
Initial weight		737.5	758.1	643.2	747.9	741.0	907.7	g
Net weight		104.9	26.4	5.7	3.5	1.9	12.9	g

Description of impinger water clean 25 % spent
B/W Sil gel color
 Total moisture = 155.3 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MAN ON-M26A-H2SO4- 1A

Liquid level marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MAN ON-M26A-NaOH 1B

Liquid level marked/sealed ☒

Samples stored and locked _____
 Remarks _____

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION			SAMPLE TYPE		RUN NUMBER /		
Burlington, MA		11 / 24 / 23		Main Stack			M26A		13		
OPERATOR		AMBIENT PRESS (In. Hg)		STATIC PRESSURE (in. Water)		AMBIENT TEMP (deg. F)		PITOT Cp		PROBE LENGTH AND LINER TYPE	
100%		24.32		-50		40		0.85 0.84		250	
DGM H@		DGM CAL FACTOR (Y)		DGM		DGM		LEAK CHECK (INITIAL)		O2 CONTENT %	
1.69		.185		5.5		5.5		.001 CU. FT @ 12 "Hg		11	
PITOT LEAK CHECK		delta P		delta H		delta P		DGM IN / OUT TEMP (deg. F)		SAMPLE TRAIN VAC (in. Hg)	
13		1.69		.185		5.5		71		2	
TRaverse		ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		PROBE TEMP (deg. F)		FILTER OVEN TEMP (deg. F)	
A-1		0		14:50		941.583		256		246	
2		5		15:05		974.33		256		249	
3		10		15:15		978.51		256		249	
15		15:05		15:15		982.935		256		249	
INTRA-PORT LEAK CHECK?		DGM VOLUME (CU. FT)		INITIAL		FINAL		LEAK RATE: CU. FT @ CU. FT @		INCHES Hg INCHES Hg	
B-1		15		15:07		982.935		1.2		245	
2		20		15:10		985.91		1.5		245	
3		25		15:15		990.68		2.0		245	
30		15:22		15:22		995.641		2.2		245	
INTRA-PORT LEAK CHECK?		DGM VOLUME (CU. FT)		INITIAL		FINAL		LEAK RATE: CU. FT @ CU. FT @		INCHES Hg INCHES Hg	
C-1		30		15:24		995.641		1.4		243	
2		35		15:27		999.41		1.6		242	
3		40		15:30		1005.52		1.8		239	
45		15:37		15:37		1009.182		2.0		238	
INTRA-PORT LEAK CHECK?		DGM VOLUME (CU. FT)		INITIAL		FINAL		LEAK RATE: CU. FT @ CU. FT @		INCHES Hg INCHES Hg	
D-1		45		15:41		1009.182		1.0		238	
2		50		15:44		1014.73		1.1		238	
3		55		15:47		1020.08		1.1		238	
60		15:56		15:56		1025.34		1.1		238	
TOTAL TIME		60 Min.		60 Min.		1025.34		1.1		238	
Ave. Temp.		Ave. Temp.		Ave. Temp.		Ave. Temp.		Ave. Temp.		Ave. Temp.	

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Buzzi Maryneal TX
 Sample Location Main Stalk
 Run No. 1B 0N -M26A- 1B
 Filter Number(s) Not Applicable

Sample Date 11/29/23
 Recovery Date 11/29/23
 Recovered by SS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		845.7	789.8	615.1	740.0	740.8	912.3	g
Initial weight		749.9	747.1	611.9	734.9	738.1	899.1	g
Net weight		95.8	42.7	3.2	5.1	2.7	13.2	g

Description of impinger water clean 25 % spent
13N Sil gel color
 Total moisture = 162.7 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. 1N 0N -M26A-H2SO4- 1B

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. 1N 0A -M26A-NaOH 1B

Liquid level
 marked/sealed ☒

Samples stored and locked _____

Remarks _____

Run 2
Aborted
Process Problem

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION			SAMPLE TYPE		RUN NUMBER		
Brazos, Unruh, Maryland, TX		11 / 29 / 23		Main Stack			M26A		2A 0N		
OPERATOR	AMBIENT PRESS (in. Hg)	STATIC PRESSURE (in. Water)	AMBIENT TEMP (deg. F)	FILTER NUMBERS	STACK ID (In.)	PITOT Cp	PROBE LENGTH AND LINER TYPE	NOZZLE NUMBER	NOZZLE DIAMETER		
Lee Harris	27.32	0.67	50		140	0.84		250.258	250		
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (Y)	STACK THERM NO.	STACK PITOT NO.	ORSAT NO.	LEAK CHECK (INITIAL)	LEAK CHECK (FINAL)	O2 CONTENT %	CO2 CONTENT %		
13	1.63	0.975				3.06 / 14	@ 14 "Hg	11	16.5		
PITOT LEAK CHECK ----> PASSED											
TRAVERSE PORT/NO.	ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	VELOCITY HEAD (In. H2O)	delta H ORIFICE (In. H2O)	PROBE TEMP (deg. F)	STACK TEMP (deg. F)	DGM IN / OUT TEMP (deg. F)	FILTER OVEN TEMP (deg. F)	Sil Gel EXIT TEMP (deg. F)	SAMPLE TRAIN VAC (in. Hg)
A-1	0	1620	917.865	1.7	2.3	254	243	66	259	57	4
2	5		923.29	1.1	2.6	254	248	65	256	56	4
3	10		928.33	1.0	2.4	258	263	67	258	57	4
End of Port											
INTRA-PORT LEAK CHECK?											
DGM VOLUME (CU. FT)		INITIAL		FINAL		LEAK RATE:		CU. FT @		INCHES Hg	
B-1		15		1641		933.085		2.1		252	
2		20						22		240	
3		25									
30											
End of Port											
INTRA-PORT LEAK CHECK?											
DGM VOLUME (CU. FT)		INITIAL		FINAL		LEAK RATE:		CU. FT @		INCHES Hg	
C-1		30									
2		35									
3		40									
45											
End of Port											
INTRA-PORT LEAK CHECK?											
DGM VOLUME (CU. FT)		INITIAL		FINAL		LEAK RATE:		CU. FT @		INCHES Hg	
D-1		45									
2		50									
3		55									
60											
End of Port											
TOTAL TIME		60 Min.		DGM VOLUME		AVE SQRT delta P		AVE. TEMP.		AVE. TEMP.	

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION			SAMPLE TYPE		RUN NUMBER		
Burr's Wagon, Wagon, TX		11/30/23		Main Stack 6N			M26A		54 0N		
OPERATOR		AMBIENT PRESS (in. Hg)		STATIC PRESSURE (in. Water)		AMBIENT TEMP (deg. F)		PITOT Cp		PROBE LENGTH AND LINER TYPE	
Lee Harris		27.43		-0.67		50		0.85 0.84		5 ft glass	
ASSUMED DGM BOX No.		DGM H@		DGM CAL		STACK THERM NO.		LEAK CHECK (INITIAL)		O2 CONTENT %	
13 MS-15		1.68		0.975		5A		0.001 CU. FT @ 12 "Hg		16.5	
				PITOT LEAK CHECK		delta P		DGM IN / OUT TEMP (deg. F)		SAMPLE TRAIN VAC (in. Hg)	
				PASS		delta P		58		5	
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		VELOCITY HEAD (in. H2O)		delta H ORIFICE (in. H2O)		PROBE TEMP (deg. F)	
A-1 0		0810		936.456		0.86		2.0		253	
2 5				940.72		0.84		2.0		256	
3 10				944.95		0.76		1.8		255	
15 0855				948.941		End of Port					
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU. FT @ CU. FT @		INCHES Hg INCHES Hg					
B-1 15 0937		948.941		0.95		2.3		254		254	
2 20		953.45		0.93		2.2		254		253	
3 25		957.91		0.89		2.1		253		258	
30 0952		962.175		End of Port							
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU. FT @ CU. FT @		INCHES Hg INCHES Hg					
C-1 30 0954		962.175		1.0		2.4		253		253	
2 35		966.64		0.98		2.3		254		253	
3 40		971.07		0.96		2.3		257		254	
45 1009		975.464		End of Port							
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU. FT @ CU. FT @		INCHES Hg INCHES Hg					
D-1 45 1011		975.464		0.96		2.3		255		254	
2 50		980.61		0.95		2.3		255		258	
3 55		984.33		0.94		2.2		257		255	
60 1026		989.745		End of Port							
TOTAL TIME		DGM VOLUME		AVE SQRT delta P		AVE delta H		AVE. TEMP.		AVE. TEMP.	
60 Min.											

**EPA METHOD 26A RECOVERY
AND INTEGRITY DATA SHEET**

Plant Buzzi Maryneal Tx
 Sample Location Main Stack
 Run No. MN On -M26A-3A
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/30/23
 Recovered by SCJ

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		831.8	812.3	652.5	759.7	731.0	934.1	g
Initial weight		749.2	750.2	648.8	758.1	730.4	920.6	g
Net weight								g

Description of impinger water clean 50 % spent
B/W Sil gel color
 Total moisture = 164.1 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN On -M26A-H2SO4-3A

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN On -M26A-NaOH 3A

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks _____

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION			SAMPLE TYPE		RUN NUMBER	
Bussell Creek		11/30/23		M26A			26		26	
OPERATOR		MAYNARD		AMBIENT PRESS (in. Hg)			PITOT Cp		PROBE LENGTH AND LINER TYPE	
ASSUMED DGM MOISTURE BOX No. (%)		13%		STATIC PRESSURE (in. Water)			LEAK CHECK (INITIAL)		NOZZLE DIAMETER	
		13%		DGM CAL FACTOR (Y)			LEAK CHECK (FINAL)		250	
		1.6%		DGM CAL FACTOR (Y)			LEAK CHECK (INITIAL)		250	
		1.6%		DGM CAL FACTOR (Y)			LEAK CHECK (FINAL)		250	
TRAVERSE ELAPSED TEST TIME (MIN)		0		DGM READING Vm (cu. ft.)			DGM IN / OUT TEMP (deg. F)		SAMPLE TRAIN VAC (in. Hg)	
A-1		9:20		43.746			58		3	
2		5		47.32			59		3	
3		10		51.34			60		3	
15		9:25		55.33			60		3	
INTRA-PORT LEAK CHECK?				LEAK RATE: CU.FT @ CU.FT @			INCHES Hg INCHES Hg			
DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @			INCHES Hg INCHES Hg			
B-1		15		55.33			2.3		253	
2		20		59.46			2.2		253	
3		25		63.86			2.1		253	
30		9:52		68.186			2.1		253	
INTRA-PORT LEAK CHECK?				LEAK RATE: CU.FT @ CU.FT @			INCHES Hg INCHES Hg			
DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @			INCHES Hg INCHES Hg			
C-1		30		68.186			2.4		253	
2		35		72.15			2.4		253	
3		40		76.84			2.3		253	
45		10:09		81.240			2.3		253	
INTRA-PORT LEAK CHECK?				LEAK RATE: CU.FT @ CU.FT @			INCHES Hg INCHES Hg			
DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @			INCHES Hg INCHES Hg			
D-1		45		81.240			2.3		253	
2		50		85.108			2.3		253	
3		55		90.20			2.2		253	
60		10:26		95.115			2.2		253	
TOTAL TIME				DGM VOLUME			AVE. SQRT delta P		AVE. TEMP.	
60 Min.				95.115			2.2		253	

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Buzzi Maryneal TX
 Sample Location Main Stack
 Run No. MN ON -M26A- 3B
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/30/23
 Recovered by SES

782.9 MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		865.3	755.0	615.4	748.9	747.0	925.1	g
Initial weight		753.0	747.7	613.1	745.9	746.0	912.1	g
Net weight		110.3	25.2	2.3	2.9	1.0	13.0	g

Description of impinger water clear 60 % spent
B/W Sil gel color
 Total moisture = 164.6 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN ON -M26A-H2SO4- 3B

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN ON -M26A-NaOH 3B

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks _____

PAGE 1 of 1

Attorney Client Privileged and Confidential

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Buzzi Macmillan TX
 Sample Location Main Stack Mill ~~2~~
 Run No. 41 ON -M26A- 4A
 Filter Number(s) 929 Not Applicable

Sample Date 11/30/23
 Recovery Date 11/30/23
 Recovered by SCJ

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		841.8	761.7	615.9	751.5	751.5	932.5	g
Initial weight		747.2	747.6	614.4	751.1	751.5	921.7	g
Net weight	✓	94.6	14.1	1.5	0.4	0.0	17.8	g

Description of impinger water clean 50 % spent
13/w Sil gel color
 Total moisture = 128.4 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN ~~26A~~ -M26A-H2SO4- 4A

Liquid level marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN ~~26A~~ -M26A-NaOH 4A

Liquid level marked/sealed ☒

Samples stored and locked _____
 Remarks _____

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Bayer Unicom Marquette		11/30/23		Main Stack Mill 01		M26A		43 ON	
OPERATOR		STATIONARY PRESS (in. Hg)		AMBIENT TEMP (deg. F)		PITOT Cp		NOZZLE DIAMETER	
13		-0.67		~75		0.59034		.250	
ASSUMED DGM MOISTURE BOX No. (%)		DGM CAL FACTOR (Y)		STACK THERM NO.		LEAK CHECK (INITIAL)		LEAK CHECK (FINAL)	
13		.985		5 F		.001 CU. FT @ 10 "Hg		.001 CU. FT @ 10 "Hg	
PITOT LEAK CHECK		PITOT LEAK CHECK		PITOT LEAK CHECK		PITOT LEAK CHECK		PITOT LEAK CHECK	
13		16.1		5 F		5 F		5 F	
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		delta P VELOCITY HEAD (in. H2O)		delta H ORIFICE (in. H2O)	
A-1 10:45		10:45		95.369		.65		2.0	
2 5				74.24		.88		2.1	
3 10				103.56		.79		1.9	
15		11:00		107.634		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		INITIAL FINAL		LEAK RATE:		CU. FT @ CU. FT @		INCHES Hg INCHES Hg	
B-1 15		11:02		107.634		.94		2.3	
2 20				12.14		.92		2.2	
3 25				16.56		.87		2.1	
30		11:17		121.091		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		INITIAL FINAL		LEAK RATE:		CU. FT @ CU. FT @		INCHES Hg INCHES Hg	
C-1 30		11:19		161.091		.98		2.4	
2 35				125.06		.99		2.4	
3 40				129.86		.94		2.2	
45		11:34		134.57		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		INITIAL FINAL		LEAK RATE:		CU. FT @ CU. FT @		INCHES Hg INCHES Hg	
D-1 45		11:36		134.57		.96		2.3	
2 50				137.58		.94		2.2	
3 55				139.58		.94		2.2	
60		11:51		143.26		End of Port		End of Port	
TOTAL TIME				DGM VOLUME		AVE SQRT delta P		AVE. TEMP.	
60 Min.				187.364				AVE. TEMP.	

**EPA METHOD 26A RECOVERY
AND INTEGRITY DATA SHEET**

Plant Buzzi Mayne TX
 Sample Location _____
 Run No. 40N -M26A- 4B
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/30/23
 Recovered by SCS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		<u>839.4</u>	<u>741.8</u>	<u>665.7</u>	<u>753.1</u>	<u>742.7</u>	<u>936.2</u>	g
Initial weight		<u>742.6</u>	<u>733.8</u>	<u>665.3</u>	<u>753.2</u>	<u>742.7</u>	<u>920.1</u>	g
Net weight		<u>95.8</u>	<u>8.0</u>	<u>0.4</u>	<u>-0.1</u>	<u>0.0</u>	<u>16.6</u>	g

Description of impinger water clear 50 % spent
B/W Sil gel color
 Total moisture = 120.2 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN 01 -M26A-H2SO4- 4B

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN 01 -M26A-NaOH 4B

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks _____

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Burlington, VT		11/30/23		Main Stack Off		M26A		5A	
OPERATOR		STATIC PRESSURE (in. Water)		FILTER NUMBERS		PITOT Cp		PROBE LENGTH AND LINER TYPE	
Lee Harris		-0.06		11A		0.84		21 g/c 55	
ASSUMED DGM MOISTURE BOX No. (%)		DGM CAL FACTOR (Y)		STACK PITOT NO.		LEAK CHECK (INITIAL)		LEAK CHECK (FINAL)	
14		1.06		5A		0.01		0.01	
PILOT LEAK CHECK		PILOT LEAK CHECK		PASSED		@ 12		@ 10	
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		VELOCITY HEAD (in. H2O)		delta P	
A-1		0 1405		42.256		0.65		1.4	
2		5		46.02		0.60		1.3	
3		10		49.44		0.58		1.3	
15		1470		52.766		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		INITIAL		FINAL		LEAK RATE:		CU.FT @ CU.FT @	
DGM VOLUME (CU. FT)		15 1422		52.766		0.69		1.5	
B-1		20		56.41		0.64		1.4	
3		25		60.01		0.62		1.4	
30		1437		63.606		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		INITIAL		FINAL		LEAK RATE:		CU.FT @ CU.FT @	
DGM VOLUME (CU. FT)		30 1439		63.606		0.76		1.6	
C-1		35		67.53		0.71		1.5	
3		40		71.37		0.70		1.5	
45		1454		75.149		End of Port		End of Port	
INTRA-PORT LEAK CHECK?		INITIAL		FINAL		LEAK RATE:		CU.FT @ CU.FT @	
DGM VOLUME (CU. FT)		45 1456		75.149		0.79		1.7	
D-1		50		79.18		0.72		1.6	
3		55		83.21		0.68		1.5	
60		1511		87.059		End of Port		End of Port	
TOTAL TIME		DGM VOLUME		AVE SQR delta P		AVE		delta H	
60 Min.		1511		87.059		80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	
						80		255	
						81		254	
						83		249	

**EPA METHOD 26A RECOVERY
AND INTEGRITY DATA SHEET**

Plant Buzzi Margreal TX
 Sample Location Main
 Run No. MN Off -M26A- 5A
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/30/23
 Recovered by SCS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		859.6	768.9	646.8	742.4	762.7	946.5	g
Initial weight		750.3	753.6	643.9	746.6	763.2	934.2	g
Net weight		109.3	115.3	2.9	0.8	-0.5	12.3	g

Description of impinger water clear 60 % spent
Blw Sil gel color
 Total moisture = 140.1 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN Off-M26A-H2SO4- 5A

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN Off -M26A-NaOH 5A

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks _____

PAGE 1 of 1

Attorney Client Priveliged and Confidential

**EPA METHOD 26A RECOVERY
AND INTEGRITY DATA SHEET**

Plant Burzti Maryneal TX
 Sample Location Main Street
 Run No. MN Off-M26A-5B
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/30/23
 Recovered by ACS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		868.9	768.1	614.1	757.7	737.2	937.0	g
Initial weight		760.9	747.0	612.5	755.7	737.1	925.0	g
Net weight		108.0	21.1	1.6	2.0	0.1	12.0	g

Description of impinger water clean 80 % spent
B/W Sil gel color
 Total moisture = 144.8 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN Off-M26A-H2SO4- 5B

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN Off-M26A-NaOH 5B

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks _____

PAGE 1 of 1

Attorney Client Privileged and Confidential

**EPA METHOD 26A RECOVERY
AND INTEGRITY DATA SHEET**

Plant Buzzi Margreal TX
 Sample Location Main Stack
 Run No. MN Off-M26A-6A
 Filter Number(s) Not Applicable

Sample Date 11 / 30 / 23
 Recovery Date 11 / 31 / 23
 Recovered by SLS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		860.3	767.0	619.3	750.1	748.7	950.7	g
Initial weight		751.7	757.7	616.7	749.7	747.7	939.4	g
Net weight		108.6	9.3	2.6	0.4	1.0	11.3	g

Description of impinger water clean 75 % spent
13/w Sil gel color
 Total moisture = 133.2 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN Off-M26A-H2SO4-6A

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN Off-M26A-NaOH 6A

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks _____

PAGE 1 of 1

Attorney Client Priveliged and Confidential

**EPA METHOD 26A RECOVERY
AND INTEGRITY DATA SHEET**

Plant Burgess Marineal TX
 Sample Location MN Off -M26A- 6B
 Run No. MN Off -M26A- 6B
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/31/23
 Recovered by SCZ

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		877.8	770.9	671.1	745.6	744.3	950.4	g
Initial weight		771.2	756.7	668.2	745.6	744.2	936.7	g
Net weight		106.6	114.2	2.9	0.0	0.1	13.7	g

Description of impinger water clear 80 % spent
B/W Sil gel color
 Total moisture = 137.5 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN Off -M26A-H2SO4- 6B

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN Off -M26A-NaOH 6B

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks _____

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE	SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER		
Buzzi Unicem, Mary New TX		11/30/23	Man Stack	DEF	M26A		7A	05F	
OPERATOR		AMBIENT PRESS (In. Hg)	STATIC PRESSURE (In. Water)	AMBIENT TEMP (deg. F)	FILTER NUMBERS	STACK ID (In.)	PITOT Cp	PROBE LENGTH AND LINER TYPE	
Lee Harris		27.43	0.67	60	NA	140.0	0.85084	51 g 655	
ASSUMED DGM MOISTURE BOX No. (%)		DGM H@	DGM CAL FACTOR (Y)	STACK THERM NO.	STACK PITOT NO.	ORSAT NO.	LEAK CHECK (INITIAL)	LEAK CHECK (FINAL)	
14		1.68	0.975	6A	5A	CEM	0.001 CU. FT @ 10 "Hg	0.001 CU. FT @ 10 "Hg	
PITOT LEAK CHECK		PITOT LEAK CHECK		PITOT LEAK CHECK		PITOT LEAK CHECK		PITOT LEAK CHECK	
PASS		PASS		PASS		PASS		PASS	
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	delta P VELOCITY HEAD (In. H2O)	delta H ORIFICE (In. H2O)	PROBE TEMP (deg. F)	STACK TEMP (deg. F)	DGM IN / OUT TEMP (deg. F)	FILTER OVEN TEMP (deg. F)
A-1		0 1725	133.245	0.67	1.5	255	293	75	257
2		5	137.01	0.64	1.4	253	294	77	257
3		10	140.54	0.69	1.3	256	294	77	256
15		1740	143.915	0.67	1.3	256	294	77	256
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL	FINAL	LEAK RATE: CU. FT @ CU. FT @	INCHES Hg INCHES Hg				
B-1		15	1742	143.915	0.70	1.5	295	76	256
2		20	147.46	0.65	1.4	255	295	77	254
3		25	151.07	0.60	1.3	255	293	78	251
30		1757	154.811	0.60	1.3	255	293	78	251
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL	FINAL	LEAK RATE: CU. FT @ CU. FT @	INCHES Hg INCHES Hg				
C-1		30	1759	154.811	0.77	1.7	294	77	254
2		35	158.89	0.75	1.6	256	293	79	255
3		40	162.95	0.70	1.5	254	293	80	256
45		1814	166.699	0.69	1.5	254	293	80	256
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL	FINAL	LEAK RATE: CU. FT @ CU. FT @	INCHES Hg INCHES Hg				
D-1		45	1816	166.699	0.81	1.8	293	80	255
2		50	171.02	0.79	1.7	253	294	81	255
3		55	174.98	0.72	1.6	256	294	80	255
60		1831	178.981	0.72	1.6	256	294	80	255
TOTAL TIME 60 Min.		DGM VOLUME		AVE SQRT delta P	AVE	AVE. TEMP.		AVE. TEMP.	

**EPA METHOD 26A RECOVERY
AND INTEGRITY DATA SHEET**

Plant Buzzi Maryneal
 Sample Location Main stack
 Run No. MN Off-M26A-7A
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/31/23
 Recovered by SCS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		845.5	778.8	645.4	747.4	757.0	1642.8	g
Initial weight		742.9	761.4	643.4	747.0	751.4	1029.1	g
Net weight		102.6	17.4	2.0	0.4	-0.4	13.2	g

Description of impinger water clean 25 % spent
B/W Sil gel color
 Total moisture = 135.2 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN Off-M26A-H2SO4-7A

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN Off-M26A-NaOH 7A

Liquid level
 marked/sealed ☒

Samples stored and locked _____

Remarks _____

PAGE 1 of 1

Attorney Client Privileged and Confidential

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Buzzi Maru Neal TX
 Sample Location Main Stack
 Run No. MN Off-M26A-7AB
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 12/1/23
 Recovered by SCS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		853.6	789.3	612.9	748.4	733.0	982.1	g
Initial weight		761.1	754.2	611.3	744.6	732.8	967.0	g
Net weight		92.5	34.1	1.6	1.8	0.2	15.1	g

Description of impinger water Clear 20 % spent
13/w Sil gel color
 Total moisture = 145.3 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN Off-M26A-H2SO4-7B

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN Off-M26A-NaOH 7B

Liquid level
 marked/sealed ☒

Samples stored and locked _____

Remarks _____

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Buzzi Maryneal TX
 Sample Location Main Stack
 Run No. Off-M26A-FB
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/31/23
 Recovered by SCS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		766.0	760.4	618.0	749.9	752.7	951.3	g
Initial weight		766.2	760.4	618.1	760.0	752.8	950.2	g
Net weight								g

Description of impinger water clean % spent _____
 _____ Sil gel color _____
 Total moisture = _____ grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN Off-M26A-H2SO4-FB

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. MN Off-M26A-NaOH FB

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks From train 6A

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Buzzi Marneal TX
 Sample Location Main Stack
 Run No. MN ON -M26A- FB
 Filter Number(s) Not Applicable

Sample Date 11/30/23
 Recovery Date 11/30/23
 Recovered by SLG

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		750.9	752.6	613.0	741.7	744.7	932.3	g
Initial weight		757.3	752.5	612.9	749.5	741.7	932.2	g
Net weight								g

Description of impinger water Clear 50 % spent
B/W Sil gel color
 Total moisture = grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. MN ON -M26A-H2SO4- FB

Liquid level ☒
 marked/sealed

NaOH Impingers contents and water rinse
 container no. MN ON -M26A-NaOH FB

Liquid level ☒
 marked/sealed

Samples stored and locked
 Remarks From train 3A

Client: Buzzi Maryneal TX
 Test Location: Main Stack; Raw Mill On
 Date: Nov 29, 2023 Start Time: 14:50:05
 Run number 1
 One Minute Averages

	O2 %,dry	CO2 %,dry
2:51:03 PM	10.8	16.7
2:52:03 PM	10.7	16.8
2:53:03 PM	10.8	16.6
2:54:03 PM	10.8	16.6
2:55:03 PM	10.8	16.7
2:56:03 PM	10.7	17.0
2:57:03 PM	10.8	16.8
2:58:03 PM	10.8	16.7
2:59:03 PM	10.8	16.7
3:00:03 PM	10.8	16.8
3:01:03 PM	10.8	16.3
3:02:03 PM	10.8	16.5
3:03:03 PM	10.8	16.6
3:04:03 PM	10.8	16.5
3:05:03 PM	10.8	16.7
3:06:03 PM	10.8	16.8
3:07:03 PM	10.8	16.7
3:08:03 PM	10.8	16.5
3:09:03 PM	10.8	16.6
3:10:03 PM	10.8	16.7
3:11:03 PM	10.8	16.6
3:12:03 PM	10.8	16.7
3:13:03 PM	10.8	16.8
3:14:03 PM	10.9	16.5
3:15:03 PM	10.9	16.5
3:16:03 PM	10.8	16.6
3:17:03 PM	10.8	16.7
3:18:03 PM	10.8	16.8
3:19:03 PM	10.8	16.7
3:20:03 PM	10.8	16.8
3:21:03 PM	10.7	16.7
3:22:03 PM	10.7	16.9
3:23:03 PM	10.7	16.9
3:24:03 PM	10.7	16.7
3:25:03 PM	10.7	16.9
3:26:03 PM	10.7	16.9
3:27:03 PM	10.7	16.8
3:28:03 PM	10.7	16.7
3:29:03 PM	10.7	16.7
3:30:03 PM	10.7	17.0
3:31:03 PM	10.7	16.9
3:32:03 PM	10.7	16.9
3:33:03 PM	10.7	16.8
3:34:03 PM	10.7	16.9
3:35:03 PM	10.8	16.8
3:36:03 PM	10.8	16.8
3:37:03 PM	10.7	16.8
3:38:03 PM	10.7	16.7
3:39:03 PM	10.7	16.8
3:40:03 PM	10.7	16.6
3:41:03 PM	10.7	16.7
3:42:03 PM	10.7	16.6
3:43:03 PM	10.7	16.8
3:44:03 PM	10.7	16.8
3:45:03 PM	10.7	17.0
3:46:03 PM	10.7	16.7
3:47:03 PM	10.8	16.7
3:48:03 PM	10.8	16.7
3:49:03 PM	10.8	16.6
3:50:03 PM	10.8	16.8
3:51:03 PM	10.8	16.8
3:52:03 PM	10.8	16.6
3:53:03 PM	10.8	16.9
3:54:03 PM	10.8	16.7
3:55:03 PM	10.8	16.8
3:56:03 PM	10.8	16.7
Run Avgs	10.8	16.7
Cal Gas	11.8	10.0
Initial Zero	0.0	0.2
Final Zero	0.2	0.3
Initial cal.	11.8	10.0
Final Cal.	11.9	10.0
Corrected Average	10.7	16.9

Client: Buzzi Maryneal TX
 Test Location: Main Stack; Raw Mill On
 Date: Nov 30, 2023 Start Time: 09:20:23
 Run number 2
 One Minute Averages

	O2 %,dry	CO2 %,dry
9:21:21 AM	11.2	15.4
9:22:21 AM	11.2	15.3
9:23:21 AM	11.2	15.2
9:24:21 AM	11.2	15.4
9:25:21 AM	11.3	15.4
9:26:21 AM	11.3	15.4
9:27:21 AM	11.3	15.4
9:28:21 AM	11.3	15.4
9:29:21 AM	11.3	15.4
9:30:21 AM	11.3	15.4
9:31:21 AM	11.4	15.3
9:32:21 AM	11.4	15.3
9:33:21 AM	11.4	15.1
9:34:21 AM	11.4	15.1
9:35:21 AM	11.4	15.1
9:36:21 AM	11.4	15.2
9:37:21 AM	11.4	15.1
9:38:21 AM	11.4	15.0
9:39:21 AM	11.5	15.0
9:40:21 AM	11.5	15.1
9:41:21 AM	11.5	15.1
9:42:21 AM	11.5	15.1
9:43:21 AM	11.4	15.1
9:44:21 AM	11.5	15.1
9:45:21 AM	11.5	15.1
9:46:21 AM	11.5	15.1
9:47:21 AM	11.5	15.0
9:48:21 AM	11.5	15.2
9:49:21 AM	11.5	15.1
9:50:21 AM	11.5	15.1
9:51:21 AM	11.5	15.2
9:52:21 AM	11.5	15.2
9:53:21 AM	11.5	15.1
9:54:21 AM	11.5	15.1
9:55:21 AM	11.5	15.1
9:56:21 AM	11.5	15.1
9:57:21 AM	11.5	15.1
9:58:21 AM	11.5	15.2
9:59:21 AM	11.5	15.0
10:00:21 AM	11.5	15.1
10:01:21 AM	11.5	15.1
10:02:21 AM	11.6	14.8
10:03:21 AM	11.6	14.9
10:04:21 AM	11.6	15.0
10:05:21 AM	11.7	14.8
10:06:21 AM	11.7	14.6
10:07:21 AM	11.8	14.4
10:08:21 AM	11.8	14.4
10:09:21 AM	11.8	14.4
10:10:21 AM	11.8	14.5
10:11:21 AM	11.8	14.5
10:12:21 AM	11.8	14.4
10:13:21 AM	11.9	14.3
10:14:21 AM	11.9	14.3
10:15:21 AM	11.9	14.3
10:16:21 AM	11.9	14.4
10:17:21 AM	11.9	14.3
10:18:21 AM	11.9	14.3
10:19:21 AM	12.0	14.3
10:20:21 AM	12.0	14.2
10:21:21 AM	12.0	14.3
10:22:21 AM	12.0	14.3
10:23:21 AM	12.0	14.2
10:24:21 AM	12.0	14.2
10:25:21 AM	11.9	14.3
10:26:21 AM	12.0	14.2
10:27:21 AM	12.0	14.2
Run Avgs	11.6	14.9
Cal Gas	11.8	10.0
Initial Zero	0.0	0.0
Final Zero	0.1	0.1
Initial cal.	11.9	9.8
Final Cal.	12.0	9.8
Corrected Average	11.4	15.2

Client: Buzzi Maryneal TX
 Test Location: Main Stack; Raw Mill On
 Date: Nov 30, 2023 Start Time: 10:39:23
 Run number 3
 One Minute Averages

	O2 %,dry	CO2 %,dry
10:46:21 AM	11.9	14.5
10:47:21 AM	11.9	14.5
10:48:21 AM	11.9	14.4
10:49:21 AM	11.9	14.5
10:50:21 AM	11.9	14.3
10:51:21 AM	11.9	14.5
10:52:21 AM	11.9	14.4
10:53:21 AM	11.9	14.4
10:54:21 AM	12.0	14.3
10:55:21 AM	12.0	14.3
10:56:21 AM	12.0	14.3
10:57:21 AM	11.9	14.4
10:58:21 AM	12.0	14.3
10:59:21 AM	11.9	14.6
11:00:21 AM	11.9	14.4
11:01:21 AM	11.9	14.4
11:02:21 AM	11.9	14.4
11:03:21 AM	11.9	14.4
11:04:21 AM	11.9	14.3
11:05:21 AM	11.9	14.3
11:06:21 AM	12.0	14.4
11:07:21 AM	12.0	14.3
11:08:21 AM	12.0	14.4
11:09:21 AM	12.0	14.4
11:10:21 AM	12.0	14.2
11:11:21 AM	12.1	14.2
11:12:21 AM	12.1	14.1
11:13:21 AM	12.1	14.0
11:14:21 AM	12.1	14.1
11:15:21 AM	12.1	14.0
11:16:21 AM	12.2	14.0
11:17:21 AM	12.2	14.2
11:18:21 AM	12.2	14.2
11:19:21 AM	12.2	14.1
11:20:21 AM	12.2	14.2
11:21:21 AM	12.1	14.3
11:22:21 AM	12.1	14.3
11:23:21 AM	12.0	14.4
11:24:21 AM	12.0	14.6
11:25:21 AM	11.9	14.6
11:26:21 AM	11.9	14.7
11:27:21 AM	11.8	14.8
11:28:21 AM	11.8	14.8
11:29:21 AM	11.8	14.8
11:30:21 AM	11.8	14.8
11:31:21 AM	11.8	14.8
11:32:21 AM	11.7	15.0
11:33:21 AM	11.7	14.9
11:34:21 AM	11.7	14.9
11:35:21 AM	11.7	14.9
11:36:21 AM	11.7	14.9
11:37:21 AM	11.7	14.9
11:38:21 AM	11.7	14.8
11:39:21 AM	11.7	14.8
11:40:21 AM	11.7	14.8
11:41:21 AM	11.7	14.8
11:42:21 AM	11.7	14.8
11:43:21 AM	11.7	14.8
11:44:21 AM	11.7	14.8
11:45:21 AM	11.7	14.8
11:46:21 AM	11.7	14.8
11:47:21 AM	11.7	14.8
11:48:21 AM	11.7	14.8
11:49:21 AM	11.7	14.7
11:50:21 AM	11.7	14.7
11:51:21 AM	11.7	14.7
Run Avgs	11.9	14.5
Cal Gas	11.8	10.0
Initial Zero	0.1	0.1
Final Zero	0.0	0.1
Initial cal.	12.0	9.8
Final Cal.	11.9	9.8
Corrected Average	11.7	14.9

Operator

[illegible]

Client: Buzzi Maryneal TX
 Test Location: Main Stack Mill Off
 Date: Nov 30, 2023 Start Time: 13:58:53
 Run number 4
 One Minute Averages

	O2 %,dry	CO2 %,dry
2:05:51 PM	9.9	17.6
2:06:51 PM	9.9	17.6
2:07:51 PM	9.8	17.9
2:08:51 PM	9.8	17.8
2:09:51 PM	9.8	17.5
2:10:51 PM	9.7	17.7
2:11:51 PM	9.7	17.8
2:12:51 PM	9.6	17.8
2:13:51 PM	9.7	17.8
2:14:51 PM	9.6	17.8
2:15:51 PM	9.7	17.7
2:16:51 PM	9.6	18.0
2:17:51 PM	9.6	17.9
2:18:51 PM	9.6	18.0
2:19:51 PM	9.7	17.6
2:20:51 PM	9.6	17.9
2:21:51 PM	9.6	17.8
2:22:51 PM	9.6	17.7
2:23:51 PM	9.7	17.7
2:24:51 PM	9.6	17.9
2:25:51 PM	9.7	17.7
2:26:51 PM	9.7	18.0
2:27:51 PM	9.6	18.1
2:28:51 PM	9.7	17.7
2:29:51 PM	9.8	17.7
2:30:51 PM	9.7	17.8
2:31:51 PM	9.8	17.7
2:32:51 PM	9.8	17.8
2:33:51 PM	9.7	17.9
2:34:51 PM	9.9	17.4
2:35:51 PM	9.8	17.7
2:36:51 PM	9.8	17.8
2:37:51 PM	9.7	17.8
2:38:51 PM	9.8	17.6
2:39:51 PM	9.7	17.8
2:40:51 PM	9.8	17.6
2:41:51 PM	9.8	17.8
2:42:51 PM	9.8	17.6
2:43:51 PM	9.8	17.7
2:44:51 PM	9.8	17.7
2:45:51 PM	9.7	17.7
2:46:51 PM	9.7	17.7
2:47:51 PM	9.7	17.7
2:48:51 PM	9.8	17.7
2:49:51 PM	9.8	17.7
2:50:51 PM	9.8	17.7
2:51:51 PM	9.8	17.7
2:52:51 PM	9.7	17.8
2:53:51 PM	9.7	17.8
2:54:51 PM	9.7	18.0
2:55:51 PM	9.8	17.8
2:56:51 PM	9.8	17.7
2:57:51 PM	9.8	17.6
2:58:51 PM	9.9	17.5
2:59:51 PM	9.9	17.7
3:00:51 PM	9.9	17.6
3:01:51 PM	9.9	17.7
3:02:51 PM	9.9	17.5
3:03:51 PM	9.8	17.7
3:04:51 PM	9.8	17.8
3:05:51 PM	9.8	17.9
3:06:51 PM	9.8	17.7
3:07:51 PM	9.9	17.6
3:08:51 PM	9.8	17.6
3:09:51 PM	9.8	17.7
3:10:51 PM	9.9	17.6
Run Avgs	9.8	17.7
Cal Gas	11.8	10.0
Initial Zero	0.1	0.1
Final Zero	0.1	0.1
Initial cal.	11.9	9.8
Final Cal.	11.9	9.8
Corrected Average	9.7	18.2

Client: Buzzi Maryneal TX
 Test Location: Main Stack Mill Off
 Date: Nov 30, 2023 Start Time: 15:22:49
 Run number 5
 One Minute Averages

	O2 %,dry	CO2 %,dry
3:39:47 PM	9.8	17.8
3:40:47 PM	9.9	17.6
3:41:47 PM	9.8	17.9
3:42:47 PM	9.9	17.8
3:43:47 PM	9.9	17.7
3:44:47 PM	9.9	17.7
3:45:47 PM	9.9	17.6
3:46:47 PM	9.9	17.6
3:47:47 PM	9.9	17.6
3:48:47 PM	10.0	17.5
3:49:47 PM	10.0	17.6
3:50:47 PM	10.0	17.4
3:51:47 PM	10.1	17.6
3:52:47 PM	10.1	17.5
3:53:47 PM	10.2	17.2
3:54:47 PM	10.2	17.3
3:55:47 PM	10.2	17.2
3:56:47 PM	10.1	17.5
3:57:47 PM	10.1	17.3
3:58:47 PM	10.1	17.4
3:59:47 PM	10.1	17.4
4:00:47 PM	10.1	17.5
4:01:47 PM	10.1	17.5
4:02:47 PM	10.1	17.3
4:03:47 PM	10.2	17.3
4:04:47 PM	10.1	17.5
4:05:47 PM	10.2	17.1
4:06:47 PM	10.1	17.5
4:07:47 PM	10.1	17.3
4:08:47 PM	10.2	17.3
4:09:47 PM	10.1	17.5
4:10:47 PM	10.0	17.6
4:11:47 PM	10.1	17.4
4:12:47 PM	10.1	17.4
4:13:47 PM	10.1	17.3
4:14:47 PM	10.1	17.4
4:15:47 PM	10.1	17.3
4:16:47 PM	10.1	17.3
4:17:47 PM	10.1	17.4
4:18:47 PM	10.1	17.4
4:19:47 PM	10.0	17.7
4:20:47 PM	10.1	17.3
4:21:47 PM	10.1	17.2
4:22:47 PM	10.0	17.5
4:23:47 PM	10.1	17.5
4:24:47 PM	10.1	17.5
4:25:47 PM	10.1	17.5
4:26:47 PM	10.1	17.5
4:27:47 PM	10.1	17.5
4:28:47 PM	10.2	17.4
4:29:47 PM	10.1	17.6
4:30:47 PM	10.1	17.4
4:31:47 PM	10.1	17.5
4:32:47 PM	10.1	17.5
4:33:47 PM	10.0	17.6
4:34:47 PM	10.0	17.6
4:35:47 PM	10.0	17.6
4:36:47 PM	10.0	17.5
4:37:47 PM	10.1	17.4
4:38:47 PM	10.0	17.8
4:39:47 PM	10.1	17.4
4:40:47 PM	10.0	17.6
4:41:47 PM	10.0	17.4
4:42:47 PM	10.0	17.6
4:43:47 PM	10.0	17.6
4:44:47 PM	10.1	17.5
4:45:47 PM	10.1	17.5
Run Avgs	10.1	17.5
Cal Gas	11.8	10.0
Initial Zero	0.1	0.1
Final Zero	0.1	0.1
Initial cal.	11.9	9.8
Final Cal.	12.0	9.8
Corrected Average	9.9	17.9

Client: Buzzi Maryneal TX
 Test Location: Main Stack Mill Off
 Date: Nov 30, 2023 Start Time: 16:57:03
 Run number 6
 One Minute Averages

	O2 %,dry	CO2 %,dry
5:26:01 PM	10.1	17.5
5:27:01 PM	10.1	17.5
5:28:01 PM	10.2	17.3
5:29:01 PM	10.1	17.3
5:30:01 PM	10.1	17.5
5:31:01 PM	10.1	17.5
5:32:01 PM	10.1	17.4
5:33:01 PM	10.1	17.4
5:34:01 PM	10.1	17.4
5:35:01 PM	10.0	17.6
5:36:01 PM	10.0	17.7
5:37:01 PM	10.0	17.6
5:38:01 PM	10.0	17.4
5:39:01 PM	10.1	17.3
5:40:01 PM	10.1	17.3
5:41:01 PM	10.1	17.4
5:42:01 PM	10.1	17.4
5:43:01 PM	10.0	17.5
5:44:01 PM	10.1	17.4
5:45:01 PM	10.1	17.4
5:46:01 PM	10.2	17.2
5:47:01 PM	10.1	17.3
5:48:01 PM	10.2	17.4
5:49:01 PM	10.2	17.4
5:50:01 PM	10.2	17.3
5:51:01 PM	10.3	17.0
5:52:01 PM	10.2	17.3
5:53:01 PM	10.2	17.3
5:54:01 PM	10.3	17.4
5:55:01 PM	10.2	17.4
5:56:01 PM	10.3	17.2
5:57:01 PM	10.2	17.2
5:58:01 PM	10.2	17.3
5:59:01 PM	10.2	17.4
6:00:01 PM	10.1	17.5
6:01:01 PM	10.2	17.3
6:02:01 PM	10.1	17.5
6:03:01 PM	10.1	17.7
6:04:01 PM	10.2	17.4
6:05:01 PM	10.1	17.6
6:06:01 PM	10.1	17.4
6:07:01 PM	10.1	17.4
6:08:01 PM	10.1	17.5
6:09:01 PM	10.1	17.5
6:10:01 PM	10.2	17.3
6:11:01 PM	10.2	17.4
6:12:01 PM	10.2	17.4
6:13:01 PM	10.1	17.6
6:14:01 PM	10.1	17.5
6:15:01 PM	10.2	17.3
6:16:01 PM	10.2	17.3
6:17:01 PM	10.2	17.3
6:18:01 PM	10.2	17.4
6:19:01 PM	10.2	17.4
6:20:01 PM	10.2	17.4
6:21:01 PM	10.2	17.3
6:22:01 PM	10.2	17.4
6:23:01 PM	10.2	17.5
6:24:01 PM	10.2	17.3
6:25:01 PM	10.2	17.3
6:26:01 PM	10.2	17.4
6:27:01 PM	10.2	17.3
6:28:01 PM	10.2	17.3
6:29:01 PM	10.2	17.6
6:30:01 PM	10.2	17.3
6:31:01 PM	10.2	17.4
Run Avgs	10.2	17.4
Cal Gas	11.8	10.0
Initial Zero	0.1	0.1
Final Zero	0.1	0.1
Initial cal.	12.0	9.8
Final Cal.	12.0	9.8
Corrected Average	10.0	17.8

**Buzzi Unicem
Maryneal TX
Main Stack; Mill On
HCN Analyte Spikes**

Date		11/29/23	11/29/23
Time		12:15-12:33	15:57-16:15
		Main Pre 1	Main Post 1
		HCN	HCN
Cs	Spike Direct, ppm	197.19	197.19
	SF6 Tracer Direct, ppm	9.58	9.58
SF6	Diluted SF6 Tracer, ppm	0.616	0.533
	Diluted SF6 Tracer, ppm	0.579	0.429
	Average Diluted SF6 Tracer, ppm	0.598	0.481
DF	Dilution Ratio	16.03	19.92
Ct	Total, ppm	20.211	18.671
	Total, ppm	19.721	16.802
	Average Total, ppm	19.966	17.737
Cn	Pre Spike Native , ppm	8.868	9.151
	Pre Spike Native , ppm	8.704	8.908
	Post Spike Native , ppm	8.650	9.353
	Post Spike Native , ppm	8.642	9.180
	Average Native , ppm	8.716	9.148
Spike Recovery		95.9%	91.4%
CTS Direct (CC426155)			
Ethylene Expected (ppm)		75.47	75.47
Ethylene Measured (ppm)		74.48	73.48
CTS Error		-1.3%	-2.6%

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill On
Pre Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC_003252.LAB	11/29/23	12:13:49.127	10.097	-0.043	0.032
SPC_003253.LAB	11/29/23	12:14:53.023	8.868	-0.052	-0.006
SPC_003254.LAB	11/29/23	12:15:56.935	8.704	-0.075	-0.010
SPC_003255.LAB	11/29/23	12:17:00.851	13.783	-0.080	0.306
SPC_003256.LAB	11/29/23	12:18:04.795	24.690	-0.072	0.868
SPC_003257.LAB	11/29/23	12:19:08.664	22.206	-0.093	0.730
SPC_003258.LAB	11/29/23	12:20:12.632	20.211	-0.063	0.616
SPC_003259.LAB	11/29/23	12:21:16.495	19.721	-0.071	0.579
SPC_003260.LAB	11/29/23	12:22:20.410	21.800	-0.062	0.711
SPC_003261.LAB	11/29/23	12:23:24.329	44.831	-0.084	1.916
SPC_003262.LAB	11/29/23	12:24:28.549	10.093	-0.090	0.193
SPC_003263.LAB	11/29/23	12:25:32.136	0.235	-0.025	0.001
SPC_003264.LAB	11/29/23	12:26:36.375	0.237	-0.000	-0.004
SPC_003265.LAB	11/29/23	12:27:40.087	0.081	-0.012	-0.009
SPC_003266.LAB	11/29/23	12:28:44.166	0.794	-0.016	-0.007
SPC_003267.LAB	11/29/23	12:29:47.797	9.255	0.058	-0.010
SPC_003268.LAB	11/29/23	12:30:52.098	9.025	-0.036	-0.010
SPC_003269.LAB	11/29/23	12:31:55.611	8.650	-0.059	-0.013
SPC_003270.LAB	11/29/23	12:32:59.572	8.642	-0.018	-0.010

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill On
Post Run 1 HCN Analyte Spike
Spectrum Date Time

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__003459.LAB	11/29/23	15:56:38.579	9.151	-0.186	-0.008
SPC__003460.LAB	11/29/23	15:57:42.450	8.908	-0.195	-0.013
SPC__003461.LAB	11/29/23	15:58:46.356	15.433	-0.158	0.483
SPC__003462.LAB	11/29/23	15:59:50.268	24.154	-0.154	0.848
SPC__003463.LAB	11/29/23	16:00:54.215	12.849	-0.186	0.211
SPC__003464.LAB	11/29/23	16:01:58.082	24.883	-0.194	0.880
SPC__003465.LAB	11/29/23	16:03:01.992	21.645	-0.195	0.688
SPC__003466.LAB	11/29/23	16:04:05.903	18.671	-0.215	0.533
SPC__003467.LAB	11/29/23	16:05:09.802	16.802	-0.214	0.429
SPC__003468.LAB	11/29/23	16:06:13.717	15.668	-0.214	0.359
SPC__003469.LAB	11/29/23	16:07:17.877	13.151	-0.097	0.345
SPC__003470.LAB	11/29/23	16:08:21.640	0.315	-0.036	0.005
SPC__003471.LAB	11/29/23	16:09:25.432	0.084	-0.025	-0.000
SPC__003472.LAB	11/29/23	16:10:29.343	-0.008	-0.036	-0.009
SPC__003473.LAB	11/29/23	16:11:33.434	3.554	-0.031	-0.011
SPC__003474.LAB	11/29/23	16:12:37.253	9.649	-0.103	-0.011
SPC__003475.LAB	11/29/23	16:13:41.122	9.353	-0.191	-0.013
SPC__003476.LAB	11/29/23	16:14:45.034	9.180	-0.213	-0.013

Buzzi Unicem: Maryneal TX
 Main Slack, Raw Mill On
 Post Run 1 CTS

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC___003560.LAB	11/29/23	18:45:53.586	0.053	-0.013	-0.010	16.286
SPC___003561.LAB	11/29/23	18:46:57.614	-0.226	-0.005	-0.013	73.543
SPC___003562.LAB	11/29/23	18:48:01.393	-0.128	-0.007	-0.014	73.411
SPC___003563.LAB	11/29/23	18:49:05.439	-0.316	-0.013	-0.020	53.814

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill On
CTS and HCN Direct

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__003128.LAB	11/29/23	09:48:23.996	0.020	0.006	0.001	-0.072
SPC__003129.LAB	11/29/23	09:49:27.908	0.134	-0.005	-0.001	-0.058
SPC__003130.LAB	11/29/23	09:50:31.936	0.044	-0.008	0.003	-0.116
SPC__003131BKG.LAB	11/29/23	09:53:26.078	0.000	0.000	0.000	0.000
SPC__003132.LAB	11/29/23	09:54:36.458	0.000	0.000	0.001	-0.015
SPC__003133.LAB	11/29/23	09:55:40.374	0.109	0.009	0.000	0.002
SPC__003134.LAB	11/29/23	09:56:44.401	-0.042	-0.006	0.001	-0.051
SPC__003135.LAB	11/29/23	09:57:48.181	-0.080	-0.006	0.000	-0.006
SPC__003136.LAB	11/29/23	09:58:52.214	-0.022	0.049	-0.001	-0.033
SPC__003137.LAB	11/29/23	09:59:56.406	0.006	0.033	0.001	-0.047
SPC__003138.LAB	11/29/23	10:00:59.901	-0.032	0.047	0.002	-0.051
SPC__003139.LAB	11/29/23	10:02:03.848	-0.090	0.127	-0.001	0.015
SPC__003140.LAB	11/29/23	10:03:07.759	-0.001	0.125	-0.011	22.400
SPC__003141.LAB	11/29/23	10:04:11.624	-0.293	0.061	-0.005	61.988
SPC__003142.LAB	11/29/23	10:05:15.938	-0.165	0.060	-0.011	58.433
SPC__003143.LAB	11/29/23	10:06:19.438	-0.142	0.062	-0.009	54.454
SPC__003144.LAB	11/29/23	10:07:23.437	-0.070	0.009	-0.009	74.299
SPC__003145.LAB	11/29/23	10:08:27.783	-0.180	0.010	-0.008	74.579
SPC__003146.LAB	11/29/23	10:09:31.168	-0.255	0.004	-0.011	74.391
SPC__003147.LAB	11/29/23	10:10:35.067	-0.286	-0.005	-0.008	74.456
SPC__003148.LAB	11/29/23	10:11:39.102	-0.083	-0.001	-0.006	9.761
SPC__003149.LAB	11/29/23	10:12:42.891	-0.151	-0.001	-0.005	0.481
SPC__003150.LAB	11/29/23	10:13:46.799	-0.048	-0.009	-0.005	0.478
SPC__003151.LAB	11/29/23	10:14:50.845	-0.038	0.011	-0.007	0.442
SPC__003152.LAB	11/29/23	10:15:54.666	-0.180	0.006	-0.004	0.467
SPC__003153.LAB	11/29/23	10:16:58.915	-0.100	-0.004	-0.006	0.497
SPC__003154.LAB	11/29/23	10:18:02.445	-0.007	0.002	-0.002	0.472
SPC__003155.LAB	11/29/23	10:19:06.462	10.754	0.013	1.172	0.663
SPC__003156.LAB	11/29/23	10:20:10.264	41.711	0.028	4.607	-0.076
SPC__003157.LAB	11/29/23	10:21:14.292	45.886	0.017	4.849	-0.279
SPC__003158.LAB	11/29/23	10:22:18.085	46.590	-0.006	4.851	-0.135
SPC__003159.LAB	11/29/23	10:23:21.995	46.739	0.016	4.856	-0.264
SPC__003160.LAB	11/29/23	10:24:25.960	47.320	0.003	4.860	-0.268
SPC__003161.LAB	11/29/23	10:25:29.819	37.078	0.008	4.848	-0.184
SPC__003162.LAB	11/29/23	10:26:33.849	28.421	0.018	4.624	-0.228
SPC__003163.LAB	11/29/23	10:32:14.551	195.980	0.011	9.583	-0.647
SPC__003164.LAB	11/29/23	10:33:18.264	196.278	-0.026	9.585	-0.465
SPC__003165.LAB	11/29/23	10:34:22.223	196.975	0.012	9.583	-0.523
SPC__003166.LAB	11/29/23	10:35:26.094	197.038	0.007	9.580	-0.445
SPC__003167.LAB	11/29/23	10:36:30.150	197.342	-0.007	9.580	-0.500
SPC__003168.LAB	11/29/23	10:37:34.119	170.976	-0.020	9.590	-0.601
SPC__003169.LAB	11/29/23	10:38:37.830	157.143	-0.019	9.064	-0.470
SPC__003170.LAB	11/29/23	10:39:41.948	138.047	0.025	7.225	-0.339
SPC__003171.LAB	11/29/23	10:40:45.858	67.542	0.029	5.083	-0.220
SPC__003172.LAB	11/29/23	10:41:49.573	49.888	-0.000	4.852	-0.250
SPC__003173.LAB	11/29/23	10:42:53.522	49.909	0.003	4.847	-0.339
SPC__003174.LAB	11/29/23	10:43:57.490	49.927	0.006	4.851	-0.271
SPC__003175.LAB	11/29/23	10:45:01.307	49.815	0.013	4.849	-0.321
SPC__003176.LAB	11/29/23	10:46:05.212	49.899	0.005	4.848	-0.292
SPC__003177.LAB	11/29/23	10:47:09.125	23.829	0.025	2.379	0.742

[illegible]

Raw Mill Status	On	On	On	Off	Off	Off	Off
Date	11/30/23	11/30/23	11/30/23	11/30/23	11/30/23	11/30/23	11/30/23
Time	09:08-09:24	10:27-10:39	11:42-11:56	13:39-13:57	15:12-15:23	16:46-16:58	18:31-18:51
	Main Pre 2	Main Post 2	Main Post 3	Main Pre 4	Main Post 4	Main Post 5	Main Post 6
	HCN	HCN	HCN	HCN	HCN	HCN	HCN
Spike Direct, ppm	49.92	49.92	49.92	49.92	49.92	49.92	49.92
SF6 Tracer Direct, ppm	4.84	4.84	4.84	4.84	4.84	4.84	4.84
Diluted SF6 Tracer, ppm	0.420	0.499	0.476	0.466	0.474	0.482	0.450
Diluted SF6 Tracer, ppm	0.407	0.462	0.427	0.445	0.454	0.461	0.417
Average Diluted SF6 Tracer, ppm	0.414	0.481	0.452	0.456	0.464	0.472	0.434
Dilution Ratio	11.69	10.06	10.71	10.61	10.42	10.25	11.15
Total, ppm	10.955	11.425	11.060	13.559	14.073	14.432	13.608
Total, ppm	10.938	11.290	10.732	13.438	14.019	14.364	13.398
Average Total, ppm	10.947	11.358	10.896	13.499	14.046	14.398	13.503
Pre Spike Native , ppm	7.915	7.571	7.147	9.645	10.596	11.052	10.394
Pre Spike Native , ppm	7.597	7.503	6.992	9.597	10.474	11.064	10.121
Post Spike Native , ppm	7.488	7.750	7.687	9.886	10.950	10.615	10.319
Post Spike Native , ppm	7.647	7.425	7.789	9.809	10.725	10.762	10.213
Average Native , ppm	7.662	7.562	7.404	9.734	10.686	10.873	10.262
Spike Recovery	92.3%	91.7%	89.7%	99.5%	91.5%	94.2%	93.0%
CTS Direct (CC426155)							
Ethylene Expected (ppm)	75.47		75.47				75.47
Ethylene Measured (ppm)	73.85		73.86				73.81
CTS Error	-2.1%		-2.1%				-2.2%

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill On
Pre Run 2 HCN Analyte Spike

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__003653.LAB	11/30/23	09:06:49.691	8.614	-0.076	-0.009
SPC__003654.LAB	11/30/23	09:07:53.558	7.915	-0.159	-0.010
SPC__003655.LAB	11/30/23	09:08:57.221	7.597	-0.165	-0.007
SPC__003656.LAB	11/30/23	09:10:01.009	8.417	-0.179	0.165
SPC__003657.LAB	11/30/23	09:11:05.018	12.389	-0.183	0.589
SPC__003658.LAB	11/30/23	09:12:08.818	11.962	-0.164	0.535
SPC__003659.LAB	11/30/23	09:13:12.721	10.955	-0.175	0.420
SPC__003660.LAB	11/30/23	09:14:16.770	10.938	-0.154	0.407
SPC__003661.LAB	11/30/23	09:15:20.779	9.460	-0.170	0.190
SPC__003662.LAB	11/30/23	09:16:24.617	7.698	-0.166	-0.004
SPC__003663.LAB	11/30/23	09:17:28.327	4.351	-0.088	0.147
SPC__003664.LAB	11/30/23	09:18:32.432	0.178	-0.039	0.005
SPC__003665.LAB	11/30/23	09:19:36.136	0.177	-0.020	0.003
SPC__003666.LAB	11/30/23	09:20:40.096	7.235	-0.059	-0.007
SPC__003667.LAB	11/30/23	09:21:43.959	8.068	-0.205	-0.008
SPC__003668.LAB	11/30/23	09:22:47.875	7.488	-0.185	-0.007
SPC__003669.LAB	11/30/23	09:23:51.774	7.647	-0.201	-0.007
SPC__003670.LAB	11/30/23	09:24:55.773	7.706	-0.213	-0.007

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill On
Post Run 2 HCN Analyte Spike

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__003727.LAB	11/30/23	10:25:38.231	7.704	-0.206	-0.009
SPC__003728.LAB	11/30/23	10:26:42.135	7.571	-0.229	-0.008
SPC__003729.LAB	11/30/23	10:27:46.073	7.503	-0.192	-0.008
SPC__003730.LAB	11/30/23	10:28:49.930	7.766	-0.208	-0.003
SPC__003731.LAB	11/30/23	10:29:54.024	10.988	-0.187	0.441
SPC__003732.LAB	11/30/23	10:30:57.740	11.425	-0.212	0.499
SPC__003733.LAB	11/30/23	10:32:01.639	11.290	-0.218	0.462
SPC__003734.LAB	11/30/23	10:33:05.541	9.417	-0.144	0.311
SPC__003735.LAB	11/30/23	10:34:09.433	0.594	-0.077	0.010
SPC__003736.LAB	11/30/23	10:35:13.378	0.077	-0.038	-0.002
SPC__003737.LAB	11/30/23	10:36:17.244	0.564	-0.027	-0.003
SPC__003738.LAB	11/30/23	10:37:21.148	7.939	-0.091	-0.006
SPC__003739.LAB	11/30/23	10:38:25.052	7.750	-0.195	-0.004
SPC__003740.LAB	11/30/23	10:39:28.962	7.425	-0.209	-0.004

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill On
Post Run 3 CTS and HCN Analyte Spike
Spectrum Date Time

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__003807.LAB	11/30/23	11:52:08.233	7.147	-0.192	-0.003	2.744
SPC__003808.LAB	11/30/23	11:53:12.140	6.992	-0.175	-0.007	2.751
SPC__003809.LAB	11/30/23	11:54:16.171	7.978	-0.196	0.131	2.587
SPC__003810.LAB	11/30/23	11:55:19.933	11.513	-0.200	0.545	2.416
SPC__003811.LAB	11/30/23	11:56:24.218	11.060	-0.205	0.476	2.486
SPC__003812.LAB	11/30/23	11:57:27.780	10.732	-0.194	0.427	2.562
SPC__003813.LAB	11/30/23	11:58:31.979	8.274	-0.084	0.399	1.592
SPC__003814.LAB	11/30/23	11:59:35.886	0.416	-0.038	0.008	0.033
SPC__003815.LAB	11/30/23	12:00:39.432	0.172	-0.022	-0.008	-0.011
SPC__003816.LAB	11/30/23	12:01:43.471	2.855	-0.046	-0.003	0.932
SPC__003817.LAB	11/30/23	12:02:47.325	7.615	-0.093	-0.004	3.027
SPC__003818.LAB	11/30/23	12:03:51.154	7.687	-0.165	-0.004	2.978
SPC__003819.LAB	11/30/23	12:04:55.061	7.789	-0.215	-0.004	3.018
SPC__003820.LAB	11/30/23	12:05:58.994	7.597	-0.216	-0.004	2.851
SPC__003821.LAB	11/30/23	12:07:02.894	5.943	-0.114	-0.009	10.770
SPC__003822.LAB	11/30/23	12:08:06.790	-0.016	-0.041	-0.005	72.292
SPC__003823.LAB	11/30/23	12:09:11.005	-0.148	-0.026	-0.009	73.536
SPC__003824.LAB	11/30/23	12:10:14.655	-0.142	-0.014	-0.011	73.864
SPC__003825.LAB	11/30/23	12:11:18.662	-0.048	-0.005	-0.010	73.846
SPC__003826.LAB	11/30/23	12:12:22.480	-0.065	-0.023	-0.007	74.133
SPC__003827.LAB	11/30/23	12:13:26.274	0.736	-0.027	-0.010	67.215
SPC__003828.LAB	11/30/23	12:14:30.179	8.806	-0.096	-0.005	4.047

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill Off
Pre Run 4 HCN Analyte Spike

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__003907.LAB	11/30/23	13:39:29.055	9.645	-0.175	-0.010
SPC__003908.LAB	11/30/23	13:40:32.962	9.598	-0.216	-0.009
SPC__003909.LAB	11/30/23	13:41:36.858	10.329	-0.164	0.088
SPC__003910.LAB	11/30/23	13:42:40.721	15.836	-0.196	0.847
SPC__003911.LAB	11/30/23	13:43:44.629	11.759	-0.169	0.243
SPC__003912.LAB	11/30/23	13:44:48.877	13.673	-0.167	0.493
SPC__003913.LAB	11/30/23	13:45:52.430	13.559	-0.176	0.466
SPC__003914.LAB	11/30/23	13:46:56.342	13.438	-0.193	0.445
SPC__003915.LAB	11/30/23	13:48:00.291	13.321	-0.192	0.406
SPC__003916.LAB	11/30/23	13:49:04.257	7.370	-0.110	0.130
SPC__003917.LAB	11/30/23	13:50:08.144	0.968	-0.036	0.004
SPC__003918.LAB	11/30/23	13:51:11.932	0.227	-0.020	-0.006
SPC__003919.LAB	11/30/23	13:52:15.850	2.280	-0.026	-0.003
SPC__003920.LAB	11/30/23	13:53:19.760	10.340	-0.137	-0.013
SPC__003921.LAB	11/30/23	13:54:23.690	9.954	-0.172	-0.011
SPC__003922.LAB	11/30/23	13:55:27.604	9.886	-0.165	-0.011
SPC__003923.LAB	11/30/23	13:56:31.515	9.809	-0.171	-0.010
SPC__003924.LAB	11/30/23	13:57:35.413	10.067	-0.166	-0.012

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill Off
Post Run 4 HCN Analyte Spike

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__003994.LAB	11/30/23	15:12:23.934	10.596	-0.196	-0.010
SPC__003995.LAB	11/30/23	15:13:27.573	10.474	-0.205	-0.008
SPC__003996.LAB	11/30/23	15:14:31.355	12.848	-0.185	0.347
SPC__003997.LAB	11/30/23	15:15:35.688	14.073	-0.194	0.474
SPC__003998.LAB	11/30/23	15:16:39.508	14.019	-0.182	0.454
SPC__003999.LAB	11/30/23	15:17:43.316	13.169	-0.191	0.342
SPC__004000.LAB	11/30/23	15:18:47.034	0.815	-0.059	0.025
SPC__004001.LAB	11/30/23	15:19:50.928	0.148	-0.034	-0.000
SPC__004002.LAB	11/30/23	15:20:54.773	7.417	-0.092	-0.005
SPC__004003.LAB	11/30/23	15:21:58.704	10.950	-0.225	-0.011
SPC__004004.LAB	11/30/23	15:23:02.963	10.725	-0.230	-0.011

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill Off
Post Run 5 HCN Analyte Spike

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__004081.LAB	11/30/23	16:45:48.064	11.052	-0.239	-0.011
SPC__004082.LAB	11/30/23	16:46:52.004	11.064	-0.251	-0.008
SPC__004083.LAB	11/30/23	16:47:56.216	11.960	-0.257	0.165
SPC__004084.LAB	11/30/23	16:49:00.137	14.432	-0.201	0.482
SPC__004085.LAB	11/30/23	16:50:03.716	14.364	-0.200	0.461
SPC__004086.LAB	11/30/23	16:51:07.575	13.612	-0.204	0.349
SPC__004087.LAB	11/30/23	16:52:11.596	3.280	-0.064	0.138
SPC__004088.LAB	11/30/23	16:53:15.366	0.246	-0.015	0.002
SPC__004089.LAB	11/30/23	16:54:19.328	4.999	-0.048	-0.006
SPC__004090.LAB	11/30/23	16:55:23.562	11.376	-0.224	-0.010
SPC__004091.LAB	11/30/23	16:56:27.199	10.615	-0.241	-0.009
SPC__004092.LAB	11/30/23	16:57:31.081	10.762	-0.245	-0.008

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill Off
Post Run 6 HCN Analyte Spike

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC___004179.LAB	11/30/23	18:31:07.393	10.394	-0.189	-0.008	3.109
SPC___004180.LAB	11/30/23	18:32:10.845	10.121	-0.219	-0.007	3.041
SPC___004181.LAB	11/30/23	18:33:14.862	11.066	-0.203	0.143	2.692
SPC___004182.LAB	11/30/23	18:34:18.678	13.774	-0.203	0.502	2.703
SPC___004183.LAB	11/30/23	18:35:22.859	13.608	-0.194	0.450	2.738
SPC___004184.LAB	11/30/23	18:36:26.454	13.398	-0.200	0.417	2.852
SPC___004185.LAB	11/30/23	18:37:30.468	4.400	-0.049	0.209	0.626
SPC___004186.LAB	11/30/23	18:38:34.287	0.228	-0.027	0.008	-0.050
SPC___004187.LAB	11/30/23	18:39:38.147	0.090	-0.014	-0.003	0.064
SPC___004188.LAB	11/30/23	18:40:42.431	0.075	-0.004	-0.000	0.005
SPC___004189.LAB	11/30/23	18:41:45.973	2.211	-0.016	-0.003	0.510
SPC___004190.LAB	11/30/23	18:42:49.916	10.542	-0.224	-0.009	3.214
SPC___004191.LAB	11/30/23	18:43:53.770	10.319	-0.202	-0.009	3.049
SPC___004192.LAB	11/30/23	18:44:57.717	10.213	-0.199	-0.015	3.073
SPC___004193.LAB	11/30/23	18:46:01.566	2.584	-0.098	-0.002	0.856
SPC___004194.LAB	11/30/23	18:47:05.662	0.139	-0.030	0.003	-0.055
SPC___004195.LAB	11/30/23	18:48:09.361	0.137	-0.015	0.005	-0.086
SPC___004196.LAB	11/30/23	18:49:13.258	0.122	-0.028	-0.003	10.430
SPC___004197.LAB	11/30/23	18:50:17.158	0.005	-0.013	-0.009	73.788
SPC___004198.LAB	11/30/23	18:51:21.066	0.082	-0.004	-0.008	73.840

Buzzi Unicem; Maryneal TX
Main Stack, Raw Mill On
CTS and HCN Direct

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__003645.LAB	11/30/23	08:58:18.068	29.847	-0.013	2.882	-0.025
SPC__003646.LAB	11/30/23	08:59:21.972	49.867	-0.030	4.835	-0.504
SPC__003647.LAB	11/30/23	09:00:25.885	49.970	-0.015	4.835	-0.460
SPC__003648.LAB	11/30/23	09:01:30.186	30.292	0.002	2.696	0.702

Buzzi Unicem; Maryneal TX

Main Stack, Raw Mill On

CTS and HCN Direct

Spectrum	Date	Time	HCN PCA 191c R1 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__003564BKG.LAB	11/30/23	07:24:27.085	0.000	0.000	0.000	0.000
SPC__003565.LAB	11/30/23	07:25:37.733	0.014	-0.006	-0.001	-0.061
SPC__003566.LAB	11/30/23	07:26:41.371	-0.080	0.006	-0.020	43.985
SPC__003567.LAB	11/30/23	07:27:45.267	-0.228	0.009	-0.010	73.655
SPC__003568.LAB	11/30/23	07:28:49.515	-0.229	-0.022	-0.011	73.784
SPC__003569.LAB	11/30/23	07:29:53.185	0.009	-0.015	-0.012	73.918
SPC__003570.LAB	11/30/23	07:30:56.969	77.472	0.004	3.499	38.467
SPC__003571.LAB	11/30/23	07:32:00.868	193.908	-0.014	9.564	-0.537
SPC__003572.LAB	11/30/23	07:33:04.768	195.330	-0.015	9.546	-0.325
SPC__003573.LAB	11/30/23	07:34:08.677	196.749	0.007	9.535	-0.349
SPC__003574.LAB	11/30/23	07:35:12.623	197.175	-0.016	9.567	-0.452
SPC__003575.LAB	11/30/23	07:36:16.530	198.323	-0.017	9.561	-0.435
SPC__003576.LAB	11/30/23	07:37:20.478	198.512	-0.012	9.541	-0.516
SPC__003577.LAB	11/30/23	07:38:24.409	109.918	-0.035	4.944	4.122
SPC__003578.LAB	11/30/23	07:39:28.420	0.306	-0.009	-0.005	0.478
SPC__003579.LAB	11/30/23	07:40:32.184	0.162	-0.014	-0.002	0.488

Appendix C

Ion Chromatography Analytical Report Data


Deeco, Inc.
3404 Lake Woodard Drive
Raleigh, NC 27604

Project No: 23-3315
Buzzi Unicem

Hydrogen Fluoride & Chlorine

EPA Method 26A Analysis

Analytical Report
41721



Element One, Inc.
6319-D Carolina Beach Rd., Wilmington, NC 28412
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 41721
has been reviewed for completeness, accuracy,
adherence to method protocol,
and compliance with quality assurance guidelines.

Review by:

A handwritten signature in black ink, appearing to read 'Katie Gattis', with a large, stylized loop at the end.

Katie Gattis, Quality Assurance Officer
December 27, 2023

Report Reviewed and Finalized by:

A handwritten signature in black ink, appearing to read 'Ken Smith', with a checkmark at the end.

Ken Smith, Laboratory Director
December 27, 2023

SUMMARY OF RESULTS

Summary of Analysis

Summary of Method 26A Analysis

Element	MN- M26A-R1A e41721-1 Total mg	MN- M26A-R3A e41721-2 Total mg	MN- M26A-R4A e41721-3 Total mg
HF	< 0.228	< 0.265	< 0.237
Cl ₂	< 0.154	< 0.167	< 0.167
Element	MN- M26A-R5A e41721-4 Total mg	MN- M26A-R6A e41721-5 Total mg	MN- M26A-R7A e41721-6 Total mg
HF	< 0.243	< 0.253	< 0.251
Cl ₂	0.631	0.286	0.580
Element	MN- M26A-R1B e41721-7 Total mg	MN- M26A-R3B e41721-8 Total mg	MN- M26A-R4B e41721-9 Total mg
HF	< 0.254	< 0.259	< 0.224
Cl ₂	< 0.148	< 0.193	< 0.156
Element	MN- M26A-R5B e41721-10 Total mg	MN- M26A-R6B e41721-11 Total mg	MN- M26A-R7B e41721-12 Total mg
HF	< 0.265	< 0.251	< 0.267
Cl ₂	0.672	0.306	0.617
Element	MN- M26A-FBON e41721-13 Total mg	MN- M26A-FBOFF e41721-14 Total mg	
HF	< 0.202	< 0.21	
Cl ₂	< 0.157	< 0.178	

elementOne

ANALYTICAL NARRATIVE

Element One Analytical Narrative

Client:	Deeco, Inc.	Element One #:	41721
Client ID:	23-3315 Buzzi Unicem	Analyst:	LAW
Method:	M26A	Dates Received:	12.11.23
Analytes:	HF, Cl ₂	Dates Analyzed:	12.18-21.23

Summary of Analysis

The samples were prepared and analyzed according to Method 26A protocol. The samples were analyzed for fluoride and chloride on Metrohm 861/788 and 881/858 ion chromatograph systems.

Detection Limits

The Metrohm reporting limit was 0.1 µg/mL for fluoride and chloride.

Analysis QA/QC

Duplicate analyses relative percent difference (RPD), spike recovery and second source verification data are summarized in the Quality Control section. All QA/QC data was within the criteria of the method.

Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. Due to the sample matrix, it was necessary to analyze all samples at a minimum five-fold dilution to reduce interferences and to preserve the anion column. The reported results relate only to the items tested or calibrated.

QUALITY CONTROL SUMMARY

Summary of Quality Control Data

Summary of Method 26A Duplicate Analysis RPD

(Method 26A QC limits: <5% for RPD)

Element	MN- M26A-R1A RPD	MN- M26A-R3A RPD	MN- M26A-R4A RPD
HF	NA	NA	NA
Cl ₂	NA	NA	NA

Element	MN- M26A-R5A RPD	MN- M26A-R6A RPD	MN- M26A-R7A RPD
HF	NA	NA	NA
Cl ₂	2.1%	0.0%	3.6%

Element	MN- M26A-R1B RPD	MN- M26A-R3B RPD	MN- M26A-R4B RPD
HF	NA	NA	NA
Cl ₂	NA	NA	NA

Element	MN- M26A-R5B RPD	MN- M26A-R6B RPD	MN- M26A-R7B RPD
HF	NA	NA	NA
Cl ₂	1.9%	1.0%	4.1%

Element	MN- M26A-FBON RPD	MN- M26A-FBOFF RPD
HF	NA	NA
Cl ₂	NA	NA

elementOne

Summary of Quality Control Data

Summary of Method 26A Spike Recoveries

(Method 26A QC limits: 90-110% for Spike Recoveries)

Element	MN- M26A-R4A Recovery	MN- M26A-R4B Recovery
HF	108%	108%
Cl ₂	105%	100%

Element	RC- M26A-R3A Recovery	RC- M26A-R3B Recovery
HF	106%	106%
Cl ₂	101%	101%

Second Source Calibration Verification

(*Laboratory QC limits: 90-110%)

Element	DL 0.1mg/L Recovery	*QC 5.0mg/L Recovery
HF e41721 (1-14)	97%	101%
HF e41721 (15-28)	105%	100%
Cl ₂ e41721 (1-14)	94%	107%
Cl ₂ e41721 (15-28)	109%	102%

SAMPLE CUSTODY

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285		Date: 12/10/23 Lab: Element One Train: EPA Method 26					
Plant Name: Buzzl Unicem Relinquished by: (Signature) <i>[Signature]</i>		Project Name: 23-3315 Comments					
Relinquished by: (Signature) <i>[Signature]</i>		Date/Time: 12.11.23 Comments					
Relinquished by: (Signature)		Date/Time:					
Relinquished by: (Signature)		Date/Time:					
Relinquished by: (Signature)		Date/Time:					
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
MN-1A-H ₂ SO ₄	11/29/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume: 434.0 mL	Element One
MN-1A-NaOH	11/29/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume: 308.5 mL Sodium thiosulfate NOT ADDED!	Element One
MN-1B-H ₂ SO ₄	11/29/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume: 483.5 mL	Element One
MN-1B-NaOH	11/29/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume: 296.1 mL Sodium thiosulfate NOT ADDED!	Element One
MN-3A-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume: 504.1 mL	Element One
MN-3A-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume: 333.1 mL Sodium thiosulfate NOT ADDED!	Element One
MN-3B-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume: 492.8 mL	Element One
MN-3B-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume: 325.2 mL Sodium thiosulfate NOT ADDED!	Element One

Samples received in good condition in Env Express containers, No empty containers.

elementOne

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285		41721					
		Date: 12/10/23	Element One				
		Lab: EPA Method 26					
Plant Name: Buzzi Unicem Relinquished by: (Signature) <i>[Signature]</i> Date/Time: 12/11		Project Name: 23-3315 Comments					
Relinquished by: (Signature) Date/Time:		Comments					
Relinquished by: (Signature) Date/Time:		Comments					
Plant Location: Maryneal TX Received by: (Signature) <i>[Signature]</i> Date/Time:		Date/Time: 12-11-23					
Received by: (Signature) Date/Time:		Comments					
Received by: (Signature) Date/Time:		Comments					
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
MN-4A-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 447.4 mL	Element One
MN-4A-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 333.6 mL Sodium thiosulfate NOT ADDED!	Element One
MN-4B-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 425.8 mL	Element One
MN-4B-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 312.2 mL Sodium thiosulfate NOT ADDED!	Element One
MN-5A-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 461.7 mL	Element One
MN-5A-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 333.8 mL Sodium thiosulfate NOT ADDED!	Element One
MN-5B-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 503.1 mL	Element One
MN-5B-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 358.9 mL Sodium thiosulfate NOT ADDED!	Element One

elementOne

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285		41721 Date: 12/10/23 Lab: Element One Train: EPA Method 26					
Plant Name: Buzzi Unicem Relinquished by: (Signature) <i>[Signature]</i> Relinquished by: (Signature) <i>[Signature]</i> Relinquished by: (Signature)		Plant Location: Maryneal TX Received by: (Signature) <i>[Signature]</i> Received by: (Signature) Received by: (Signature)					
Date/Time 12/11/23 Date/Time Date/Time Date/Time		Date/Time 12-11-23 Date/Time Date/Time Date/Time					
Project Name: 23-3315 Comments Comments Comments		Project Name: 23-3315 Comments Comments Comments					
Field Sample No.	Date	Composited or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
MIN-6A-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume= 479.8 mL	Element One
MIN-6A-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume= 338.3 mL Sodium thiosulfate NOT ADDED!	Element One
MIN-6B-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume= 477.4 mL	Element One
MIN-6B-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume= 311.5 mL Sodium thiosulfate NOT ADDED!	Element One
MIN-7A-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume= 476.5 mL	Element One
MIN-7A-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume= 352.3 mL Sodium thiosulfate NOT ADDED!	Element One
MIN-7B-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume= 507.1 mL	Element One
MIN-7B-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume= 337.5 mL Sodium thiosulfate NOT ADDED!	Element One

elementOne

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285		41721 Date: 12/10/23 Lab: Element One Train: EPA Method 26					
		Project Name: 23-3315 Comments					
		Date/Time: 12/10/23 Comments					
Plant Name: Buzzl Unicem Relinquished by: (Signature) <i>[Signature]</i> Relinquished by: (Signature) <i>[Signature]</i>		Plant Location: Maryneal TX Received by: (Signature) <i>[Signature]</i> Received by: (Signature) <i>[Signature]</i>					
Relinquished by: (Signature)		Date/Time					
Relinquished by: (Signature)		Date/Time					
Relinquished by: (Signature)		Date/Time					
Field Sample No.	Date	Composited or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
MIN-FBON-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ Rinses	Final Volume 384.3 mL	Element One
MIN-FBON-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 313.8 mL Sodium thiosulfate NOT ADDED!	Element One
MIN-FBOFF-H ₂ SO ₄	11/30/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 399.1 mL	Element One
MIN-FBOFF-NaOH	11/30/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 355.9 mL Sodium thiosulfate NOT ADDED!	Element One

DEECO, Inc. 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285		41721 Date: 12/10/23 Lab: Element One Train: EPA Method 26					
Plant Name: Buzzl Unicem							
Plant Location: Festus MO							
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time				
<i>[Signature]</i>	12/11	<i>[Signature]</i>	12/11-21				
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time				
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time				
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
RC-1A-H ₂ SO ₄	12/05/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 422.6 mL	Element One
RC-1A-NaOH	12/05/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 296.6 mL Sodium thiosulfate NOT ADDED!	Element One
RC-1B-H ₂ SO ₄	12/05/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 498.6 mL	Element One
RC-1B-NaOH	12/05/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 297.1 mL Sodium thiosulfate NOT ADDED!	Element One
RC-2A-H ₂ SO ₄	12/05/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 436.5 mL	Element One
RC-2A-NaOH	12/05/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 339.0 mL Sodium thiosulfate NOT ADDED!	Element One
RC-2B-H ₂ SO ₄	12/05/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 436.0 mL	Element One
RC-2B-NaOH	12/05/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 324.8 mL Sodium thiosulfate NOT ADDED!	Element One

elementOne

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285				Date: 12/10/23 Lab: Element One Train: EPA Method 26		41721	
				Project Name: 23-3317			
				Plant Location: Festus MO			
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time	Comments			
Relinquished by: (Signature)	12/11	Received by: (Signature)	12-11-23	Comments			
Relinquished by: (Signature)		Received by: (Signature)		Comments			
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
RC-3A-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 482.2 mL	Element One
RC-3A-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 349.4 mL Sodium thiosulfate NOT ADDED!	Element One
RC-3B-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 469.8 mL	Element One
RC-3B-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 3343.6 mL Sodium thiosulfate NOT ADDED!	Element One
RC-4A-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 432.0 mL	Element One
RC-4A-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 347.0 mL Sodium thiosulfate NOT ADDED!	Element One
RC-4B-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 461.3 mL	Element One
RC-4B-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 341.0 mL Sodium thiosulfate NOT ADDED!	Element One

elementOne

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285		41721		
		Date:	12/10/23	
		Lab:	Element One	
		Train:		EPA Method 26

Plant Name: Buzzl Unicem		Plant Location: Festus MO		Project Name: 23-3317	
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time	Comments	
<i>[Signature]</i>	12/11/23	<i>[Signature]</i>	12/11/23		
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time	Comments	
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time	Comments	

Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
RC-5A-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 433.1 mL	Element One
RC-5A-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 282.2 mL Sodium thiosulfate NOT ADDED!	Element One
RC-5B-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 463.3 mL	Element One
RC-5B-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 329.1 mL Sodium thiosulfate NOT ADDED!	Element One
RC-6A-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 437.9 mL	Element One
RC-6A-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 328.5 mL Sodium thiosulfate NOT ADDED!	Element One
RC-6B-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 464.0 mL	Element One
RC-6B-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 346.4 mL Sodium thiosulfate NOT ADDED!	Element One

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285		41721 Date: 12/10/23 Lab: Element One Train: EPA Method 26					
		Project Name: 23-3317					
Plant Name: Buzzl Unicam		Plant Location: Festus MO					
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time				
<i>[Signature]</i>	12/11	<i>[Signature]</i>	12/11/23				
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time				
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time				
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
RC-FBON-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 419.0 mL	Element One
RC-FBON-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 341.0 mL Sodium thiosulfate NOT ADDED!	Element One
RC-FBOFF-H ₂ SO ₄	12/06/23	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 420.7 mL	Element One
RC-FBOFF-NaOH	12/06/23	Comp.	Chloride ion as Chlorine (Cl ₂)	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 334.7 mL Sodium thiosulfate NOT ADDED!	Element One
	12/06/23						
	12/06/23						

ANALYTICAL DATA

Analytical Calculations

HF -

$$\text{Total HX (mg)} = \frac{[\text{X Results } (\mu\text{g/mL}) * \text{Dilution} * \text{Beginning Vol (mL)}] * \text{Correction Factor}}{1000}$$

Where-

X Results= Raw sample concentration (ppm) — *IC Data Sheet*

Dilution= $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ — *IC Run Sheet*

Beginning Volume--*Sample Submission*

1.053= Correction factor for hydrogen fluoride

Cl₂ -

$$\text{Total X}_2 \text{ (mg)} = \frac{\text{X Results } (\mu\text{g/mL}) * \text{Dilution} * \text{Beginning Volume (mL)}}{1000}$$

Where-

X Results= Raw sample concentration (ppm)—*Cl₂ IC Data Sheet*

Dilution= $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ — *IC Run Sheet*

Beginning Volume--*Sample Submission*

Analytical Calculations

Spike Recovery-

$$\text{Spike (\%)} = \frac{(\text{Spiked Result } (\mu\text{g/mL}) - \text{Sample Result } (\mu\text{g/mL}))}{\text{Spike Amount } (\mu\text{g/mL})} \times 100$$

Where-

Spike Result = Raw sample concentration (ppm)--*IC-Data Sheet*

Sample Result = Raw sample concentration (ppm)--*IC-Data Sheet*

Spike Amount—*IC-Data Sheet*

Duplicate Analysis RPD-

$$\text{RPD (\%)} = \frac{(\text{Duplicate Result } (\mu\text{g/mL}) - \text{Sample Result } (\mu\text{g/mL}))}{\text{Average } (\mu\text{g/mL})} \times 100$$

Where-

Sample Result and Duplicate Results=Raw sample concentration (ppm)--*IC-Data Sheet*

$$\text{Average} = \frac{(\text{Duplicate} + \text{Sample Results})}{2}$$

elementOne

AIR TESTING SAMPLE SUBMISSION FORM

Lab ID 41721

Analysis Due Date 12.20.23
QA/QC/Report Due Date 12.22.23

Client: Deeco, Inc.
Project No 23-3315

Date Rec 12.11.23
Time Rec 1100

Volume Marked	Volume Loss	FH pH < 2	BH pH > 8	Ref. Method:
Y (N)	Y (N) ?	(Y) N	(Y) N	26A

Sample Identification

1	MN-M26A-R1A	7	MN-M26A-R1B	13	MN-M26A-FBON
2	MN-M26A-R3A	8	MN-M26A-R3B	14	MN-M26A-FBOFF
3	MN-M26A-R4A	9	MN-M26A-R4B		
	MN-M26A-R4A Spike		MN-M26A-R4B Spike		
4	MN-M26A-R5A	10	MN-M26A-R5B		
5	MN-M26A-R6A	11	MN-M26A-R6B		
6	MN-M26A-R7A	12	MN-M26A-R7B		
Analyses Requested		Samples 1-14	HF		
		Samples 1-14	Cl ₂		

Runs/FB

Lab ID	FH Impinger 1 (or Combined Imp)		FH Impinger 2		FH Impinger 3		BH Impinger 4 (or Combined Imp)		BH Impinger 5	
	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
1		438.0						308.5		
2		504.1						333.1		
3.S		449.4						333.6		
4		461.7						333.8		
5		479.8						336.3		
6		476.5						352.3		
7		483.5						296.1		
8		492.8						325.2		
9.S		425.8						312.2		
10		503.1						358.9		
11		477.9						311.5		
12		507.1						337.5		
13		364.3						313.8		
14		399.1						355.9		

Lab Communications

Rec Runs/FB: H₂SO₄; NaOH; No RB received---12.11.23 LLB

SS Page 1 of 2
SS by LLB
12/19/2023 11:40:15 AM

HF 15-28 12/19/23 LLB
HF Imp 1, 2, & 3 Prep By / Date LLB 12/18/23 1-14
Imp 4 & 5 Prep By / Date LLB 12/19/23 1-14
Labeled By/Date LLB 12/12/23
ID Verification By/Date LLB 12/12/23
012 K.28 LLB 12/20/23

elementOne

Certification: NJ NELAP NC009
41721 Deeco M26A Report Packet
Page 24 of 46

elementOne AIR TESTING SAMPLE SUBMISSION FORM Lab ID 41721

Analysis Due Date 12.20.23

QA/QC/Report Due Date 12.22.23

Client: Deeco, Inc.
Project No 23-3315

Date Rec 12.11.23
Time Rec 1100

Volume Marked	Volume Loss	FH pH < 2	BH pH > 8	Ref. Method:
Y <u>N</u>	Y <u>N</u> ?	<u>Y</u> N	<u>Y</u> N	26A

Sample Identification

15	RC-M26A-R1A	21	RC-M26A-R1B	27	RC-M26A-FBON
16	RC-M26A-R2A	22	RC-M26A-R2B	28	RC-M26A-FBOFF
17	RC-M26A-R3A	23	RC-M26A-R3B		
	RC-M26A-R3A Spike		RC-M26A-R3B Spike		
18	RC-M26A-R4A	24	RC-M26A-R4B		
19	RC-M26A-R5A	25	RC-M26A-R5B		
20	RC-M26A-R6A	26	RC-M26A-R6B		

Analyses Requested

Samples 15-28 HF

Samples 15-28 Cl₂

Runs/FB

Lab ID	FH Impinger 1 (or Combined Imp)		FH Impinger 2		FH Impinger 3		BH Impinger 4 (or Combined Imp)		BH Impinger 5	
	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
15		412.6						296.6		
16		436.5						339.0		
17.S		482.2						349.4		
18		432.0						347.0		
19		433.1						282.2		
20		437.9						328.5		
21		498.6						297.1		
22		436.0						324.8		
23.S		469.8						343.6		
24		461.3						341.0		
25		463.3						329.1		
26		464.0						346.4		
27		419.0						341.0		
28		410.7						334.7		

Reagent Blanks

Lab ID	Fractions	BV, ml	FV, ml	Notes
	0.1 N H ₂ SO ₄			
	0.1 N NaOH			
	DI H ₂ O			

SS Page 2 of 2
SS by LLB
12/19/2023 11:40:15 AM

HF Imp 1, 2, & 3 Prep By / Date LLB 12-18-23 1-14
Imp 4 & 5 Prep By / Date _____
Labeled By/Date LLB 12/12/23
ID Verification By/Date LLB 12/12/23

elementOne

Certification: NJ NELAP NC009
41721 Deeco M26A Report Packet
Page 25 of 46

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41721 (1-14)

Client: Deeco

Date: 12.20.23

Analyst: LAW

Detection Limit, (µg/ml): 0.10

Column: IonPac AS14A

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Flow Rate: 1.0 mL/min.

F⁻ to HF factor: 1.053

Sample ID	F ⁻ µg/ml	Dilution	Final Vol, ml	HF, Total mg	Spike, µg/ml	% Recovery/ RPD	File Name	Date Time
LRB	0.000	1	10	< 0.001			_2023-12-18_	12/18/2023 14:57
LRB	0.000	1	10	< 0.001		NA	_2023-12-18_	12/18/2023 15:16
LRB SPK	5.100	1	10	0.054	5.00	102%	_2023-12-18_	12/18/2023 15:34
LRB SPK	4.942	1	10	0.052	5.00	99%	_2023-12-18_	12/18/2023 15:53
41721-1	0.000	5	434.0	< 0.228			_2023-12-18_	12/18/2023 17:27
41721-1 DUP	0.000	5	434.0	< 0.228		NA	_2023-12-18_	12/18/2023 17:46
41721-2	0.000	5	504.1	< 0.265			_2023-12-18_	12/18/2023 20:34
41721-2 DUP	0.082	5	504.1	< 0.265		NA	_2023-12-18_	12/18/2023 20:53
41721-3	0.000	5	449.4	< 0.237			_2023-12-18_	12/18/2023 18:04
41721-3 DUP	0.000	5	449.4	< 0.237		NA	_2023-12-18_	12/18/2023 18:23
41731-3 SPK	5.429	5	449.4	12.84	5.00	109%	_2023-12-18_	12/18/2023 18:42
41721-3 SPK DUP	5.318	5	449.4	12.58	5.00	106%	_2023-12-18_	12/18/2023 19:00
41721-4	0.000	5	461.0	< 0.243			_2023-12-18_	12/18/2023 21:12
41721-4 DUP	0.000	5	461.7	< 0.243		NA	_2023-12-18_	12/18/2023 21:30
41721-5	0.000	5	479.8	< 0.253			_2023-12-18_	12/18/2023 21:49
41721-5 DUP	0.000	5	479.8	< 0.253		NA	_2023-12-18_	12/18/2023 22:08
41721-6	0.000	5	476.5	< 0.251			_2023-12-18_	12/18/2023 22:26
41721-6 DUP	0.000	5	476.5	< 0.251		NA	_2023-12-18_	12/18/2023 22:45
41721-7	0.000	5	483.5	< 0.254			_2023-12-18_	12/18/2023 23:04
41721-7 DUP	0.081	5	483.5	< 0.254		NA	_2023-12-18_	12/18/2023 23:23
41721-8	0.000	5	492.8	< 0.259			_2023-12-19_	12/19/2023 0:56
41721-8 DUP	0.079	5	492.8	< 0.259		NA	_2023-12-19_	12/19/2023 1:15
41721-9	0.073	5	425.8	< 0.224			_2023-12-19_	12/19/2023 1:34
41721-9 DUP	0.066	5	425.8	< 0.224		NA	_2023-12-19_	12/19/2023 1:53
41721-9 SPK	5.466	5	425.8	12.2	5.00	108%	_2023-12-19_	12/19/2023 2:11
41721-9 SPK DUP	5.459	5	425.8	12.2	5.00	108%	_2023-12-19_	12/19/2023 2:30
41721-10	0.097	5	503.1	< 0.265			_2023-12-19_	12/19/2023 2:49
41721-10 DUP	0.047	5	503.1	< 0.265		NA	_2023-12-19_	12/19/2023 3:07
41721-11	0.076	5	477.4	< 0.251			_2023-12-19_	12/19/2023 3:26
41721-11 DUP	0.073	5	477.4	< 0.251		NA	_2023-12-19_	12/19/2023 3:45
41721-12	0.094	5	507.1	< 0.267			_2023-12-19_	12/19/2023 5:19
41721-12 DUP	0.081	5	507.1	< 0.267		NA	_2023-12-19_	12/19/2023 5:37
41721-13 FB ON	0.000	5	384.3	< 0.202			_2023-12-19_	12/19/2023 5:56
41721-13 FB ON DUP	0.000	5	384.3	< 0.202		NA	_2023-12-19_	12/19/2023 6:15
41721-14 FB OFF	0.000	5	399.1	< 0.21			_2023-12-19_	12/19/2023 6:34
41721-14 FB OFF DUP	0.000	5	399.1	< 0.21		NA	_2023-12-19_	12/19/2023 6:52

HF Data 1 of 2

elementOne

e 41721-HF

elementOne

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41721 (1-14)

Client: Deeco

Date: 12.20.23

Analyst: LAW

Detection Limit, (µg/ml): 0.10

Column: IonPac AS14A

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Flow Rate: 1.0 mL/min.

F to HF factor: 1.053

Standards	F µg/ml	Dilution	QC, µg/ml	% Relative Error	% Recovery	File Name	Date Time
0	0.000					_2023-12-18_	12/18/2023 11:12
0.1	0.102			2.0%	102%	_2023-12-18_	12/18/2023 11:31
1	0.962			-3.8%	96%	_2023-12-18_	12/18/2023 11:50
3	3.041			1.4%	101%	_2023-12-18_	12/18/2023 12:08
5	5.008			0.2%	100%	_2023-12-18_	12/18/2023 12:27
10	9.987			-0.1%	100%	_2023-12-18_	12/18/2023 12:46
0.1	0.110			10.0%	110%	_2023-12-19_	12/19/2023 8:45
1	0.932			-6.8%	93%	_2023-12-19_	12/19/2023 9:03
3	3.071			2.4%	102%	_2023-12-19_	12/19/2023 9:22
5	5.126			2.5%	103%	_2023-12-19_	12/19/2023 9:41
10	10.109			1.1%	101%	_2023-12-19_	12/19/2023 10:00
Correlation-	0.999788						
QC	5.028		5.00		101%	_2023-12-18_	12/18/2023 13:05
QC	4.832		5.00		97%	_2023-12-18_	12/18/2023 13:23
QC	4.819		5.00		96%	_2023-12-18_	12/18/2023 17:08
QC	5.178		5.00		104%	_2023-12-18_	12/18/2023 19:19
QC	4.933		5.00		99%	_2023-12-18_	12/18/2023 19:38
QC	5.176		5.00		104%	_2023-12-18_	12/18/2023 23:41
QC	5.199		5.00		104%	_2023-12-19_	12/19/2023 0:00
QC	10.104		5.00		202%	_2023-12-19_	12/19/2023 4:04
QC	5.117		5.00		102%	_2023-12-19_	12/19/2023 4:22
QC	5.089		5.00		102%	_2023-12-19_	12/19/2023 7:48
QC	5.084		5.00		102%	_2023-12-19_	12/19/2023 10:18
DL	0.097		0.10		97%	_2023-12-18_	12/18/2023 14:19
DL	0.110		0.10		110%	_2023-12-18_	12/18/2023 14:38
DL	0.105		0.10		105%	_2023-12-19_	12/19/2023 8:07
DL	0.110		0.10		110%	_2023-12-19_	12/19/2023 10:37
36738-5 QC DUP	6.651	1	6.96		101%	_2023-12-19_	12/19/2023 7:30
BLK	0.000					_2023-12-18_	12/18/2023 13:42
BLK	0.000					_2023-12-18_	12/18/2023 14:01
BLK	0.144					_2023-12-18_	12/18/2023 19:57
BLK	0.000					_2023-12-18_	12/18/2023 20:15
BLK	0.000					_2023-12-19_	12/19/2023 0:19
BLK	0.000					_2023-12-19_	12/19/2023 0:38
BLK	0.000					_2023-12-19_	12/19/2023 4:41
BLK	0.000					_2023-12-19_	12/19/2023 5:00
BLK	0.000					_2023-12-19_	12/19/2023 8:26
BLK	0.000					_2023-12-19_	12/19/2023 10:56

HF Data 2 of 2

elementOne

e 41721-HF

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #:

HF
41721 (1-4)

Date: 12/8/23
 Analyst: LMO
 Batch name: 12/8/23-41721

Column: IonPac AS14A
 Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃
 10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
 Regenerant: 100 mM H₃PO₄
 Flow Rate: 1.0 mL/min.

Instrument: 861 1784
 Lot# 1C11-87-1
 Lot # 1C11-103-2
 Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	00			GC	max	R ²	
2	01		F ⁻	BBEJUS74	Summation	0.998	
3	10						
4	30						
5	50						
6	100						
7	GC						
8	GC						
9	BK						
10	BK						
11	DL						
12	DL						
13	LRB						
14	LRB						
15	LRBT						
16	LRBT						
17	41721-1	Deeco	HF		—	5X	
18	-10	↓	↓		—	↓	
19	-3	↓	↓		—	↓	
20	-3D	↓	↓		—	↓	
21	-34	↓	↓		5.429	↓	
22	-34D	↓	↓		5.318	↓	
23	GC						
24	GC						
25	BK						

Manual integrations noted by M

Curve IC Lot # 1C11-103-4

Comments:

pg 10F3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution 2303024-250 44 IC NO2 Solution 2308942-250 (40)

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

Certification: NJ NELAP NC009
 41721 Deeco M26A Report Packet
 Page 28 of 46

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: ^{HF} 41721 (1-14)

Date: 121823
 Analyst: LW
 Batch name: 121823-41721

Column: IonPac AS14A
 Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃
 10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
 Regenerant: 100 mM H₃PO₄
 Flow Rate: 1.0 mL/min.

Instrument: 861788
 Lot# 1C11-821
 Lot # 1C11-103-2
 Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	Blk						
27	41721-2	Deeco	HF		—	SX	
28	-2D				—		
29	-4				—		
30	-4D				—		
31	-5				—		
32	-5D				—		
33	-6				—		
34	-6D				—		
35	-7				—		
36	-7D				—		
37	GC						
38	GC						
39	Plk						
40	Blk						
41	41721-8	Deeco	HF		—	SX	
42	-8D				—		
43	-9				—		
44	-9D				—		
45	-9+				5466		
46	-9+D				5459		
47	-10				—		
48	-10D				—		
49	-11				—		
50	-11D				—		

Manual integrations noted by M

Curve IC Lot #

Comments:

pg 20F3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

IC NO₂ SolutionQC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date:

Time:

By:

QC Review- Date:

Time:

By:

elementOne

Certification: NJ NELAP NC009
 41721 Deeco M26A Report Packet
 Page 29 of 46

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #:

HF
41721 (1-14)

Date: 12.18.23

Column: IonPac AS14A

Instrument: 861 1288

Analyst: LW

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Lot# 1C11-827

Batch name: 121823-41721

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100 mM H₃PO₄

Lot # 1C11-1032

Flow Rate: 1.0 mL/min.

Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
51	GE 10ppm						
52	GE 5ppm						
53	BLK						
54	BLK						
55	41721-12	Deeco	HF		—	5X	
56	-12D				—		
57	-13 FBow				—		
58	-13 FBowD				—		
59	-14 FBowF				—		
60	-14 FBowFD				—		
61	36738-5-GE				5.228	1X	TV=6.96
62	5-GE				6.651		
63	GE						
64	DL						
65	BLK						
66	0.1						
67	1.0						
68	3.0						
69	5.0						
70	100						
71	GE						
72	DL						
73	BLK						
74							
75							

Manual integrations noted by M

Curve IC Lot #

Comments:

pg 3083

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

IC NO2 Solution

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date:

Time:

By:

QC Review- Date:

Time:

By:

elementOne

Certification: NJ NELAP NC009

41721 Deeco M26A Report Packet

Page 30 of 46

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41721 (15-28)

Client: Deeco

Column: IonPac AS14A

Date: 12.22.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

F⁻ to HF factor: 1.053

Sample ID	F ⁻ µg/ml	Dilution	Final Vol, ml	HF, Total mg	Spike, µg/ml	% Recovery/ RPD	File Name	Date Time
LRB	0.000	1	10	< 0.001			_2023-12-19_	12/19/2023 21:14
LRB	0.000	1	10	< 0.001		NA	_2023-12-19_	12/19/2023 21:33
LRB SPK	5.044	1	10	0.053	5.00	101%	_2023-12-19_	12/19/2023 21:52
LRB SPK	5.013	1	10	0.053	5.00	100%	_2023-12-19_	12/19/2023 22:10
41721-15	0.036	5	422.6	< 0.222			_2023-12-19_	12/19/2023 22:29
41721-15 DUP	0.036	5	422.6	< 0.222		NA	_2023-12-19_	12/19/2023 22:48
41721-16	0.036	5	436.5	< 0.23			_2023-12-20_	12/20/2023 1:36
41721-16 DUP	0.035	5	436.5	< 0.23		NA	_2023-12-20_	12/20/2023 1:55
41721-17	0.032	5	482.2	< 0.254			_2023-12-19_	12/19/2023 23:07
41721-17 DUP	0.032	5	482.2	< 0.254		NA	_2023-12-19_	12/19/2023 23:25
41721-17 SPK	5.388	5	482.2	13.67	5.00	107%	_2023-12-19_	12/19/2023 23:44
41721-17 SPK DUP	5.234	5	482.2	13.28	5.00	104%	_2023-12-20_	12/20/2023 0:03
41721-18	0.033	5	432.0	< 0.227			_2023-12-20_	12/20/2023 2:14
41721-18 DUP	0.056	5	432.0	< 0.227		NA	_2023-12-20_	12/20/2023 2:33
41721-19	0.058	5	433.1	< 0.228			_2023-12-20_	12/20/2023 2:51
41721-19 DUP	0.066	5	433.1	< 0.228		NA	_2023-12-20_	12/20/2023 3:10
41721-20	0.050	5	437.9	< 0.23			_2023-12-20_	12/20/2023 3:29
41721-20 DUP	0.043	5	437.9	< 0.23		NA	_2023-12-20_	12/20/2023 3:48
41721-21	0.040	5	498.6	< 0.262			_2023-12-20_	12/20/2023 4:06
41721-21 DUP	0.048	5	498.6	< 0.262		NA	_2023-12-20_	12/20/2023 4:25
41721-22	0.094	5	436.0	< 0.229			_2023-12-20_	12/20/2023 5:59
41721-22 DUP	0.065	5	436.0	< 0.229		NA	_2023-12-20_	12/20/2023 6:17
41721-23	0.040	5	469.8	< 0.247			_2023-12-20_	12/20/2023 6:36
41721-23 DUP	0.039	5	469.8	< 0.247		NA	_2023-12-20_	12/20/2023 6:55
41721-23 SPK	5.355	5	469.8	13.24	5.00	106%	_2023-12-20_	12/20/2023 7:14
41721-23 SPK DUP	5.347	5	469.8	13.22	5.00	106%	_2023-12-20_	12/20/2023 7:32
41721-24	0.083	5	461.3	< 0.243			_2023-12-20_	12/20/2023 7:51
41721-24 DUP	0.037	5	461.3	< 0.243		NA	_2023-12-20_	12/20/2023 8:10
41721-25	0.077	5	463.3	< 0.244			_2023-12-20_	12/20/2023 8:29
41721-25 DUP	0.048	5	463.3	< 0.244		NA	_2023-12-20_	12/20/2023 8:47
41721-26	0.042	5	464.0	< 0.244			_2023-12-20_	12/20/2023 10:22
41721-26 DUP	0.000	5	464.0	< 0.244		NA	_2023-12-20_	12/20/2023 10:40
41721-27 FB ON	0.000	5	419.0	< 0.221			_2023-12-20_	12/20/2023 10:59
41721-27 FB ON DUP	0.000	5	419.0	< 0.221		NA	_2023-12-20_	12/20/2023 11:18
41721-28 FB OFF	0.000	5	420.7	< 0.221			_2023-12-20_	12/20/2023 11:36
41721-28 FB OFF DUP	0.000	5	420.7	< 0.221		NA	_2023-12-20_	12/20/2023 11:55

HF Data 1 of 2

elementOne
e 41721-HF

elementOne

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41721 (15-28)

Client: Deeco

Column: IonPac AS14A

Date: 12.22.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

F⁻ to HF factor: 1.053

Standards	F ⁻ µg/ml	Dilution	QC, µg/ml	% Relative Error	% Recovery	File Name	Date Time
0	0.000					_2023-12-19_	12/19/2023 17:29
0.1	0.104			4.0%	104%	_2023-12-19_	12/19/2023 17:48
1	0.934			-8.6%	93%	_2023-12-19_	12/19/2023 18:07
3	3.059			2.0%	102%	_2023-12-19_	12/19/2023 18:26
5	5.032			0.6%	101%	_2023-12-19_	12/19/2023 18:44
10	9.971			-0.3%	100%	_2023-12-19_	12/19/2023 19:03
0.1	0.105			5.0%	105%	_2023-12-20_	12/20/2023 13:48
1	0.927			-7.3%	93%	_2023-12-20_	12/20/2023 14:06
3	2.717			-9.4%	91%	_2023-12-20_	12/20/2023 14:25
5	5.119			2.4%	102%	_2023-12-20_	12/20/2023 14:44
10	10.251			2.5%	103%	_2023-12-20_	12/20/2023 15:03
Correlation-	0.999798						
QC	5.009		5.00		100%	_2023-12-19_	12/19/2023 19:22
QC	4.742		5.00		95%	_2023-12-19_	12/19/2023 19:41
QC	4.659		5.00		93%	_2023-12-20_	12/20/2023 0:22
QC	5.008		5.00		100%	_2023-12-20_	12/20/2023 0:40
QC	5.129		5.00		103%	_2023-12-20_	12/20/2023 4:44
QC	4.685		5.00		94%	_2023-12-20_	12/20/2023 5:03
QC	5.057		5.00		101%	_2023-12-20_	12/20/2023 9:06
QC	5.033		5.00		101%	_2023-12-20_	12/20/2023 9:25
QC	5.063		5.00		101%	_2023-12-20_	12/20/2023 12:51
QC	5.028		5.00		101%	_2023-12-20_	12/20/2023 15:21
DL	0.105		0.10		105%	_2023-12-19_	12/19/2023 20:37
DL	0.095		0.10		95%	_2023-12-19_	12/19/2023 20:55
DL	0.103		0.10		103%	_2023-12-20_	12/20/2023 13:10
DL	0.108		0.10		108%	_2023-12-20_	12/20/2023 15:40
36738-5 QC	6.720	1	6.96		102%	_2023-12-20_	12/20/2023 12:14
36738-5 QC DUP	6.765	1	6.96		102%	_2023-12-20_	12/20/2023 12:33
BLK	0.000					_2023-12-19_	12/19/2023 19:59
BLK	0.000					_2023-12-19_	12/19/2023 20:18
BLK	0.000					_2023-12-20_	12/20/2023 0:59
BLK	0.000					_2023-12-20_	12/20/2023 1:18
BLK	0.000					_2023-12-20_	12/20/2023 5:21
BLK	0.000					_2023-12-20_	12/20/2023 5:40
BLK	0.000					_2023-12-20_	12/20/2023 9:44
BLK	0.000					_2023-12-20_	12/20/2023 10:03
BLK	0.000					_2023-12-20_	12/20/2023 13:29
BLK	0.000					_2023-12-20_	12/20/2023 15:59

HF Data 2 of 2

elementOne
e 41721-HF

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #:

41721 (15-28)

Date: 12-19-23

Column: IonPac AS14A

Instrument: 861788

Analyst: *W*Conc. Eluent: 8.0 mM Na₂CO₃ / 1.0mM NaHCO₃

Lot# 1C11-871

Batch name: 121923-41721

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Lot # 1C11-871 104-2

Regenerant: 100 mM H₃PO₄

Flow Rate: 1.0 mL/min.

Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0.0			<i>OK</i>	<i>MAF</i>	<i>R1</i>	
2	01		F-	<i>RBC JOSTY</i>	<i>Sigmadetrol</i>	<i>0.9996</i>	
3	1.0						
4	5.0						
5	5.0						
6	100						
7	<i>OK</i>						
8	<i>OK</i>						
9	<i>OK</i>						
10	<i>OK</i>						
11	<i>OK</i>						
12	<i>OK</i>						
13	<i>OK</i>						
14	<i>OK</i>						
15	<i>OK</i>						
16	<i>OK</i>						
17	41721-15	Deeco	HF		—	5X	
18	-15D				—		
19	-17				—		
20	-17D				—		
21	-17+				5.388		
22	-17+D				5.234		
23	<i>OK</i>						
24	<i>OK</i>						
25	<i>OK</i>						

Manual integrations noted by M

Curve IC Lot # 1C11-104-4

Comments:

pyloF3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution 2303029-290 H⁺ IC NO2 Solution 2308942-290 W⁺QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.Submitted for QC- Date: 12/20/23 Time: 4:37 By: *W* QC Review- Date: / Time: By: /

elementOne

Certification: NJ NELAP NC009
 41721 Deeco M26A Report Packet
 Page 33 of 46

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41724

Date: 12-19-23

Column: IonPac AS14A

Instrument: 861 H88

Analyst: LND

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Lot# 1C11-87-1

Batch name: 1242241721

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Lot # 1C11-104-2

Regenerant: 100 mM H₃PO₄

Flow Rate: 1.0 mL/min.

Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	Blk						
27	41721-16	Deeco	HF		—	5X	
28	-16D	↓	↓		—	↓	
29	-18	↓	↓		—	↓	
30	-18D	↓	↓		—	↓	
31	-19	↓	↓		—	↓	
32	-19D	↓	↓		—	↓	
33	-20	↓	↓		—	↓	
34	-20D	↓	↓		—	↓	
35	-21	↓	↓		—	↓	
36	-21D	↓	↓		—	↓	
37	GC						
38	GC						
39	Blk						
40	Blk						
41	41721-22	Deeco	HF		—	5X	
42	-22D	↓	↓		—	↓	
43	-23	↓	↓		—	↓	
44	-23D	↓	↓		—	↓	
45	-23+	↓	↓		5355	↓	
46	-23+D	↓	↓		5342	↓	
47	-24	↓	↓		—	↓	
48	-24D	↓	↓		—	↓	
49	-25	↓	↓		—	↓	
50	-25D	↓	↓		—	↓	

Manual integrations noted by M

Curve IC Lot #

Comments: pg 2 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution IC/NO2 Solution

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: Time: By: QC Review- Date: Time: By:

elementOne

Certification: NJ NELAP NC009

41721 Deeco M26A Report Packet

Page 34 of 46

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41724

Date: 12/19/23
 Analyst: WJ
 Batch name: 121923-41721

Column: IonPac AS14A
 Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃
 10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
 Regenerant: 100 mM H₃PO₄
 Flow Rate: 1.0 mL/min.

Instrument: 861 1783
 Lot# 1C11-871
 Lot # 1C11-104-2
 Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
51	GL						
52	GL						
53	BL						
54	BL						
55	41721-26	DECO	HF		---	5X	
56	-26D				---		
57	-27FBOW				---		
58	-27FBOWD				---		
59	-28FBOW				---		
60	-28FBOWD				---		
61	36738-S-GL				6.720	1X	TV=6.96
62	S-GL				6.965	↓	
63	GL						
64	DL						
65	BL						
66	DL						
67	LO						
68	30						
69	50						
70	LO						
71	GL						
72	DL						
73	BL						
74							
75							

Manual integrations noted by M

Curve IC Lot # _____ Comments: pg 30 F3
 Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution _____ IC/NO2 Solution _____
 QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.
 QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.
 Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

Certification: NJ NELAP NC009
 41721 Deeco M26A Report Packet
 Page 35 of 46

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41721 (1-14)

Client: Deeco

Column: IonPac AS14A

Date: 12.20.23

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

Sample ID	Cl ⁻ µg/ml	Dilution	Final Vol, ml	Cl ₂ , Total mg	Spike, µg/ml	% RPD/ Recovery	File Name	Date Time
LRB	-0.013	1	10	< 0.001			-2dc57c8e:18c7d19aefa:-7919	12/18/2023 20:14
LRB	-0.026	1	10	< 0.001		NA	-2dc57c8e:18c7d19aefa:-7917	12/18/2023 20:38
LRB SPK	10.086	1	10	0.101	5.00	202%	-2dc57c8e:18c7d19aefa:-7915	12/18/2023 21:01
LRB SPK	10.090	1	10	0.101	5.00	202%	-2dc57c8e:18c7d19aefa:-7913	12/18/2023 21:25
41721-1	0.013	5	308.5	< 0.154			-2dc57c8e:18c7d19aefa:-78f9	12/19/2023 2:30
41721-1 DUP	0.010	5	308.5	< 0.154		NA	-2dc57c8e:18c7d19aefa:-78f7	12/19/2023 2:54
41721-2	0.006	5	333.1	< 0.167			-2dc57c8e:18c7d19aefa:-78f5	12/19/2023 3:17
41721-2 DUP	-0.045	5	333.1	< 0.167		NA	-2dc57c8e:18c7d19aefa:-78f3	12/19/2023 3:41
41721-3	-0.010	5	333.6	< 0.167			-2dc57c8e:18c7d19aefa:-78f1	12/19/2023 4:04
41721-3 DUP	-0.028	5	333.6	< 0.167		NA	-2dc57c8e:18c7d19aefa:-78ef	12/19/2023 4:28
41721-3 SPK	5.285	5	333.6	8.8	5.00	106%	-2dc57c8e:18c7d19aefa:-78ed	12/19/2023 4:51
41721-3 SPK DUP	5.221	5	333.6	8.71	5.00	104%	-2dc57c8e:18c7d19aefa:-78eb	12/19/2023 5:15
41721-4	0.374	5	333.8	0.624			-2dc57c8e:18c7d19aefa:-78e1	12/19/2023 7:12
41721-4 DUP	0.382	5	333.8	0.638		2.1%	-2dc57c8e:18c7d19aefa:-78df	12/19/2023 7:36
41721-5	0.169	5	338.3	0.286			-2dc57c8e:18c7d19aefa:-784c	12/19/2023 7:59
41721-5 DUP	0.169	5	338.3	0.286		0.0%	-2dc57c8e:18c7d19aefa:-784a	12/19/2023 8:23
41721-6	0.323	5	352.3	0.569			-2dc57c8e:18c7d19aefa:-7848	12/19/2023 8:46
41721-6 DUP	0.335	5	352.3	0.590		3.6%	-2dc57c8e:18c7d19aefa:-7846	12/19/2023 9:10
41721-7	0.021	5	296.1	< 0.148			-2dc57c8e:18c7d19aefa:-7844	12/19/2023 9:33
41721-7 DUP	0.012	5	296.1	< 0.148		NA	-2dc57c8e:18c7d19aefa:-7842	12/19/2023 9:57
41721-8	-0.026	5	385.2	< 0.193			-2dc57c8e:18c7d19aefa:-77d9	12/19/2023 10:20
41721-8 DUP	-0.029	5	385.2	< 0.193		NA	-2dc57c8e:18c7d19aefa:-77d7	12/19/2023 10:44
41721-9	-0.035	5	312.2	< 0.156			-2dc57c8e:18c7d19aefa:-7704	12/19/2023 12:41
41721-9 DUP	-0.034	5	312.2	< 0.156		NA	-2dc57c8e:18c7d19aefa:-7702	12/19/2023 13:04
41721-9 SPK	4.953	5	312.2	7.73	5.00	99%	-2dc57c8e:18c7d19aefa:-7700	12/19/2023 13:28
41721-9 SPK DUP	5.064	5	312.2	7.90	5.00	101%	-2dc57c8e:18c7d19aefa:-76fe	12/19/2023 13:51
41721-10	0.371	5	358.9	0.666			-2dc57c8e:18c7d19aefa:-74f7	12/19/2023 14:15
41721-10 DUP	0.378	5	358.9	0.678		1.9%	-2dc57c8e:18c7d19aefa:-74f5	12/19/2023 14:38
41721-11	0.197	5	311.5	0.307			-2dc57c8e:18c7d19aefa:-74f3	12/19/2023 15:02
41721-11 DUP	0.195	5	311.5	0.304		1.0%	-2dc57c8e:18c7d19aefa:-74f1	12/19/2023 15:25
41721-12	0.358	5	337.5	0.604			-2dc57c8e:18c7d19aefa:-74ef	12/19/2023 15:49
41721-12 DUP	0.373	5	337.5	0.629		4.1%	-2dc57c8e:18c7d19aefa:-74ed	12/19/2023 16:12
41721-13 FBON	0.008	5	313.8	< 0.157			-2dc57c8e:18c7d19aefa:-74e3	12/19/2023 18:10
41721-13 FBON DUP	0.039	5	313.8	< 0.157		NA	-2dc57c8e:18c7d19aefa:-74e1	12/19/2023 18:34
41721-14 FB OFF	0.070	5	355.9	< 0.178			-2dc57c8e:18c7d19aefa:-74df	12/19/2023 18:57
41721-14 FB OFF DUI	0.084	5	355.9	< 0.178		NA	-2dc57c8e:18c7d19aefa:-74dd	12/19/2023 19:21

Cl₂ Data 1 of 2

elementOne

● 41721-Cl₂

elementOne

Certification: NJ NELAP NC009
 41721 Deeco M26A Report Packet
 Page 36 of 46

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41721 (1-14)

Client: Deeco

Date: 12.20.23

Analyst: LAW

Detection Limit, (µg/ml): 0.10

Column: IonPac AS14A

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Flow Rate: 1.0 mL/min.

Standards	Cl ⁻ µg/ml	Dilution	QC	µg/ml	%Relative Error	% Recovery	File Name	Date Time
0	0.000						-2dc57c8e:18c7d19aefa:-7503	12/18/2023 15:32
0.1	0.107				7.0%	107%	-2dc57c8e:18c7d19aefa:-7501	12/18/2023 15:56
1	0.912				-8.6%	91%	-2dc57c8e:18c7d19aefa:-74ff	12/18/2023 16:19
3	2.980				-0.7%	99%	-2dc57c8e:18c7d19aefa:-74fd	12/18/2023 16:43
5	5.149				3.0%	103%	-2dc57c8e:18c7d19aefa:-74fb	12/18/2023 17:06
10	9.948				-0.5%	99%	-2dc57c8e:18c7d19aefa:-74f9	12/18/2023 17:30
0.1	0.107				7.0%	107%	-2dc57c8e:18c7d19aefa:-74d1	12/19/2023 21:42
1	1.014				1.4%	101%	-2dc57c8e:18c7d19aefa:-74cf	12/19/2023 22:05
3	3.097				3.2%	103%	-2dc57c8e:18c7d19aefa:-74cd	12/19/2023 22:29
5	5.162				3.2%	103%	-2dc57c8e:18c7d19aefa:-74cb	12/19/2023 22:52
10	9.782				-2.2%	98%	-2dc57c8e:18c7d19aefa:-74c9	12/19/2023 23:16
Correlation-	0.999771							
QC	5.336			5.00		107%	-2dc57c8e:18c7d19aefa:-7925	12/18/2023 17:53
QC	5.264			5.00		105%	-2dc57c8e:18c7d19aefa:-7923	12/18/2023 18:17
QC	5.208			5.00		104%	-2dc57c8e:18c7d19aefa:-7905	12/19/2023 0:09
QC	5.205			5.00		104%	-2dc57c8e:18c7d19aefa:-7903	12/19/2023 0:33
QC	5.256			5.00		105%	-2dc57c8e:18c7d19aefa:-78e9	12/19/2023 5:36
QC	5.322			5.00		106%	-2dc57c8e:18c7d19aefa:-78e7	12/19/2023 6:02
QC	5.319			5.00		106%	-2dc57c8e:18c7d19aefa:-770c	12/19/2023 11:07
QC	5.020			5.00		100%	-2dc57c8e:18c7d19aefa:-770a	12/19/2023 11:31
QC	5.365			5.00		107%	-2dc57c8e:18c7d19aefa:-74eb	12/19/2023 16:36
QC	5.406			5.00		108%	-2dc57c8e:18c7d19aefa:-74e9	12/19/2023 17:00
QC	5.310			5.00		106%	-2dc57c8e:18c7d19aefa:-74d7	12/19/2023 20:31
QC	5.366			5.00		107%	-2dc57c8e:18c7d19aefa:-74c7	12/19/23 23:39
DL	0.094			0.10		94%	-2dc57c8e:18c7d19aefa:-791d	12/18/2023 19:27
DL	0.090			0.10		90%	-2dc57c8e:18c7d19aefa:-791b	12/18/2023 19:51
DL	0.095			0.10		95%	-2dc57c8e:18c7d19aefa:-74d5	12/19/2023 20:55
DL	0.106			0.10		106%	-2dc57c8e:18c7d19aefa:-74c5	12/20/2023 0:03
40034-7 QC	3.938	20		78.0		101%	-2dc57c8e:18c7d19aefa:-74db	12/19/2023 19:44
40034-7 QC DUP	3.919	20		78.0		100%	-2dc57c8e:18c7d19aefa:-74d9	12/19/2023 20:08
BLK	0.000						-2dc57c8e:18c7d19aefa:-7921	12/18/2023 18:40
BLK	0.000						-2dc57c8e:18c7d19aefa:-791f	12/18/2023 19:04
BLK	0.000						-2dc57c8e:18c7d19aefa:-7901	12/19/2023 0:56
BLK	0.000						-2dc57c8e:18c7d19aefa:-78ff	12/19/2023 1:20
BLK	0.020						-2dc57c8e:18c7d19aefa:-78e5	12/19/2023 6:25
BLK	0.000						-2dc57c8e:18c7d19aefa:-78e3	12/19/2023 6:49
BLK	0.000						-2dc57c8e:18c7d19aefa:-7708	12/19/2023 11:54
BLK	0.000						-2dc57c8e:18c7d19aefa:-7706	12/19/2023 12:18
BLK	0.000						-2dc57c8e:18c7d19aefa:-74e7	12/19/2023 17:23
BLK	0.000						-2dc57c8e:18c7d19aefa:-74e5	12/19/2023 17:47
BLK	0.000						-2dc57c8e:18c7d19aefa:-74d3	12/19/2023 21:18
BLK	0.000						-2dc57c8e:18c7d19aefa:-74c3	12/20/2023 0:26

Cl₂-Data 2 of 2elementOne
e 41721-Cl₂

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #:

41707
41721Date: 12/8/23
Analyst: CWColumn: IonPac AS14A
Conc. Eluent: 8.0 mM Na₂CO₃ / 1.0mM NaHCO₃
10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
Regenerant: 100mM H₃PO₄
Flow Rate: 1.0 mL/min.Instrument: 881/88
Lot# 1C11-87-1
Lot # 1C11-103-2
Method: 26A NaOH

Batch name: 121823-41707

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0.0			QC	main	R2	
2	0.1		Cl-	438959	200A	99971	
3	1.0						
4	3.0						
5	5.0						
6	10.0						
7	QC						
8	QC						
9	Blk						
10	Blk						
11	Bl						
12	Bl						
13	LEB						
14	LEB						
15	LEB+) 10000 SPK						
16	LEB+)						
17	41707-1		Cl-		3.191	10X	
18	-1D				3.192		
19	-3				0.162		
20	-3D				0.159		
21	-3+) 10000 SPK				10.212		
22	-3+)				10.153		
23	QC						
24	QC						
25	Blk						

Manual integrations noted by M

Curve IC Lot # 1C11-104-1 Sodium Thiosulfate Lot # 1C11-73-4 Comments: pg 1 of 4

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution 2383024-250 WPS

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: 12/20/23 Time: 8:30 By: CW QC Review- Date: Time: By:

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41707

Date: 12.18.23

Analyst: LWS

Column: IonPac AS14A

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Instrument: 881/858

Lot# 1C11-87-1

Batch name: 121823-41707

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100mM H₃PO₄

Lot# 1C11-83-2

Flow Rate: 1.0 mL/min.

Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	BLK						
27	41707-2		Cl ₂		1.417	10X	
28	-2D				1.472	↓	
29	41721-1				—	SX	
30	-1D				—		
31	-2				—		
32	-2D				—		
33	-3				—		
34	-3D				—		
35	-3+				5.285		
36	-3+D		↓		5221	↓	
37	BLK						
38	BLK						
39	BLK						
40	BLK						
41	41721-4		Cl ₂		0.374	SX	
42	-4D				0.382		
43	-5				0.169		
44	-5D				0.169		
45	-6				0.323		
46	-6D				0.335		
47	-7				—		
48	-7D				—		
49	-8				—		
50	-8D		✓		—	✓	

Manual Integre

Curve IC Lot #

Sodium Thiosulfate Lot #

Comments: pg 2 of 4

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #s: IC ME Solution

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #s listed above.

Submitted for QC- Date:

Time:

By:

QC Review- Date:

Time:

By:

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #:

41707
41721

Date: 12-18-23

Column: IonPac AS14A

Instrument: 881858

Analyst: LW

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Lot# 1C11-871

Batch name: 121823-41707

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100mM H₃PO₄

Lot # 1C11-103-2

Flow Rate: 1.0 mL/min.

Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
51	BL						
52	BL						
53	BL						
54	BL						
55	41721-9				—	5X	
56	-9D				—	↓	
57	-9+				4953		
58	-9+D				3064		
59	-10				0.371		
60	-10D				0.378		
61	-11				0.192		
62	-11D				0.195		
63	-12				0.358		
64	-12D				0.373	↓	
65	BL						
66	GL						
67	BL						
68	BL						
69	41721-13FB FBW				—	5X	
70	-13FB FBW				—	↓	
71	-14FB FBW				—	↓	
72	-14FB FBW				—	↓	
73	70034-7 - GL				3.938	20X	TV=78.0
74	-7 - GL				3.919	↓	
75	GL						

Manual Integr:

Curve IC Lot #

Sodium Thiosulfate Lot #

Comments:

pg 30F4

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date:

Time:

By:

QC Review- Date:

Time:

By:

elementOne

Certification: NJ NELAP NC009

41721 Deeco M26A Report Packet

Page 40 of 46

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41721 (15-28)

Client: Deeco

Date: 12.22.23

Analyst: LAW

Detection Limit, (µg/ml): 0.10

Column: IonPac AS14A

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Flow Rate: 1.0 mL/min.

1.000

Sample ID	Cl ⁻ µg/ml	Dilution	Final Vol, ml	Cl ₂ Total mg	Spike, µg/ml	% RPD/ Recovery	File Name	Date Time
LRB	-0.003	1	10	< 0.001			-2dc57c8e:18c7d19aefa:-6f6d	12/20/2023 14:26
LRB	0.004	1	10	< 0.001		NA	-2dc57c8e:18c7d19aefa:-6f6b	12/20/2023 14:50
LRB SPK	5.137	1	10	0.051	5.00	103%	-2dc57c8e:18c7d19aefa:-6f69	12/20/2023 15:13
LRB SPK	5.242	1	10	0.052	5.00	105%	-2dc57c8e:18c7d19aefa:-6f67	12/20/2023 15:37
41721-15	-0.021	5	296.6	< 0.148			-2dc57c8e:18c7d19aefa:-6f65	12/20/2023 16:00
41721-15 DUP	0.020	5	296.6	< 0.148		NA	-2dc57c8e:18c7d19aefa:-6f63	12/20/2023 16:24
41721-16	0.008	5	339.0	< 0.17			-2dc57c8e:18c7d19aefa:-6f51	12/20/2023 19:55
41721-16 DUP	-0.013	5	339.0	< 0.17		NA	-2dc57c8e:18c7d19aefa:-6f4f	12/20/2023 20:19
41721-17	0.034	5	349.4	< 0.175			-2dc57c8e:18c7d19aefa:-6f61	12/20/2023 16:47
41721-17 DUP	0.016	5	349.4	< 0.175		NA	-2dc57c8e:18c7d19aefa:-6f5f	12/20/2023 17:11
41721-17 SPK	5.057	5	349.4	8.83	5.00	100%	-2dc57c8e:18c7d19aefa:-6f5d	12/20/2023 17:34
41721-17 SPK DUP	5.065	5	349.4	8.85	5.00	101%	-2dc57c8e:18c7d19aefa:-6f5b	12/20/2023 17:58
41721-18	0.023	5	347.0	< 0.174			-2dc57c8e:18c7d19aefa:-6f4d	12/20/2023 20:42
41721-18 DUP	0.037	5	347.0	< 0.174		NA	-2dc57c8e:18c7d19aefa:-6f4b	12/20/2023 21:06
41721-19	0.092	5	282.2	< 0.141			-2dc57c8e:18c7d19aefa:-6f49	12/20/2023 21:29
41721-19 DUP	0.090	5	282.2	< 0.141		NA	-2dc57c8e:18c7d19aefa:-6f47	12/20/2023 21:53
41721-20	0.058	5	328.5	< 0.164			-2dc57c8e:18c7d19aefa:-6f45	12/20/2023 22:16
41721-20 DUP	0.077	5	328.5	< 0.164		NA	-2dc57c8e:18c7d19aefa:-6f43	12/20/2023 22:40
41721-21	-0.029	5	297.1	< 0.149			-2dc57c8e:18c7d19aefa:-6dfe	12/20/2023 23:03
41721-21 DUP	-0.052	5	297.1	< 0.149		NA	-2dc57c8e:18c7d19aefa:-6dfc	12/20/2023 23:27
41721-22	-0.016	5	324.8	< 0.162			-2dc57c8e:18c7d19aefa:-6dfd	12/21/2023 1:24
41721-22 DUP	-0.016	5	324.8	< 0.162		NA	-2dc57c8e:18c7d19aefa:-6df0	12/21/2023 1:48
41721-23	-0.016	5	343.6	< 0.172			-2dc57c8e:18c7d19aefa:-6dee	12/21/2023 2:11
41721-23 DUP	-0.019	5	343.6	< 0.172		NA	-2dc57c8e:18c7d19aefa:-6dec	12/21/2023 2:35
41721-23 SPK	4.922	5	343.6	8.46	5.00	99%	-2dc57c8e:18c7d19aefa:-6dea	12/21/2023 2:58
41721-23 SPK DUP	5.125	5	343.6	8.80	5.00	103%	-2dc57c8e:18c7d19aefa:-6de8	12/21/2023 3:22
41721-24	-0.053	5	341.0	< 0.171			-2dc57c8e:18c7d19aefa:-6de6	12/21/2023 3:45
41721-24 DUP	0.011	5	341.0	< 0.171		NA	-2dc57c8e:18c7d19aefa:-6de4	12/21/2023 4:09
41721-25	-0.029	5	329.1	< 0.165			-2dc57c8e:18c7d19aefa:-6de2	12/21/2023 4:32
41721-25 DUP	-0.014	5	329.1	< 0.165		NA	-2dc57c8e:18c7d19aefa:-6de0	12/21/2023 4:56
41721-26	0.005	5	346.4	< 0.173			-2dc57c8e:18c7d19aefa:-6dd6	12/21/2023 6:53
41721-26 DUP	-0.011	5	346.4	< 0.173		NA	-2dc57c8e:18c7d19aefa:-6dd4	12/21/2023 7:17
41721-27 FB ON	-0.029	5	341.0	< 0.171			-2dc57c8e:18c7d19aefa:-6dd2	12/21/2023 7:40
41721-27 FB ON DUP	0.014	5	341.0	< 0.171		NA	-2dc57c8e:18c7d19aefa:-6dd0	12/21/2023 8:04
41721-28 FB OFF	0.055	5	334.7	< 0.167			-2dc57c8e:18c7d19aefa:-6dce	12/21/2023 8:27
41721-28 FB OFF DUP	0.019	5	334.7	< 0.167		NA	-2dc57c8e:18c7d19aefa:-6dcc	12/21/2023 8:50

Cl₂-Data 1 of 2

elementOne
e 41721-Cl₂

elementOne

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41721 (15-28)

Client: Deeco

Date: 12.22.23

Analyst: LAW

Detection Limit, (µg/ml): 0.10

Column: IonPac AS14A

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Flow Rate: 1.0 mL/min.

1.000

Standards	Cl ⁻ µg/ml	Dilution	QC µg/ml	%Relative Error	% Recovery	File Name	Date Time
0	0.000					-2dc57c8e:18c7d19aefa:-6d07	12/20/2023 9:44
0.1	0.106			6.0%	106%	-2dc57c8e:18c7d19aefa:-6d05	12/20/2023 10:08
1	0.924			-7.6%	92%	-2dc57c8e:18c7d19aefa:-6d03	12/20/2023 10:32
3	2.989			-0.4%	100%	-2dc57c8e:18c7d19aefa:-6d01	12/20/2023 10:55
5	5.131			2.6%	103%	-2dc57c8e:18c7d19aefa:-6cff	12/20/2023 11:19
10	9.949			-0.5%	99%	-2dc57c8e:18c7d19aefa:-6cfd	12/20/2023 11:42
0.1	0.109			9.0%	109%	-2dc57c8e:18c7d19aefa:-6cf5	12/21/2023 11:11
1	0.969			-3.1%	97%	-2dc57c8e:18c7d19aefa:-6cf3	12/21/2023 11:35
3	2.949			-1.7%	98%	-2dc57c8e:18c7d19aefa:-6cf1	12/21/2023 11:58
5	5.140			2.8%	103%	-2dc57c8e:18c7d19aefa:-6cef	12/21/2023 12:22
10	10.294			2.9%	103%	-2dc57c8e:18c7d19aefa:-6ced	12/21/2023 12:45
Correlation-	0.999798						
QC	5.110		5.00		102%	-2dc57c8e:18c7d19aefa:-6f79	12/20/2023 12:06
QC	5.181		5.00		104%	-2dc57c8e:18c7d19aefa:-6f77	12/20/2023 12:29
QC	5.149		5.00		103%	-2dc57c8e:18c7d19aefa:-6f59	12/20/2023 18:21
QC	5.114		5.00		102%	-2dc57c8e:18c7d19aefa:-6f57	12/20/2023 18:45
QC	5.105		5.00		102%	-2dc57c8e:18c7d19aefa:-6dfa	12/20/2023 23:50
QC	5.208		5.00		104%	-2dc57c8e:18c7d19aefa:-6df8	12/21/2023 0:14
QC	5.092		5.00		102%	-2dc57c8e:18c7d19aefa:-6dde	12/21/2023 5:19
QC	5.149		5.00		103%	-2dc57c8e:18c7d19aefa:-6ddc	12/21/2023 5:43
QC	5.157		5.00		103%	-2dc57c8e:18c7d19aefa:-6cfe	12/21/2023 10:01
QC	5.230		5.00		105%	-2dc57c8e:18c7d19aefa:-6ceb	12/21/2023 13:09
DL	0.109		0.10		109%	-2dc57c8e:18c7d19aefa:-6f71	12/20/2023 13:39
DL	0.100		0.10		100%	-2dc57c8e:18c7d19aefa:-6f6f	12/20/2023 14:03
DL	0.094		0.10		94%	-2dc57c8e:18c7d19aefa:-6cf9	12/21/2023 10:24
40034-7 QC	3.801	20	78.0		97%	-2dc57c8e:18c7d19aefa:-6dca	12/21/2023 9:14
40034-7 QC DUP	3.844	20	78.0		99%	-2dc57c8e:18c7d19aefa:-6dc8	12/21/2023 9:37
BLK	0.000					-2dc57c8e:18c7d19aefa:-6f75	12/20/2023 12:53
BLK	0.000					-2dc57c8e:18c7d19aefa:-6f73	12/20/2023 13:16
BLK	0.000					-2dc57c8e:18c7d19aefa:-6f55	12/20/2023 19:08
BLK	0.000					-2dc57c8e:18c7d19aefa:-6f53	12/20/2023 19:32
BLK	0.000					-2dc57c8e:18c7d19aefa:-6df6	12/21/2023 0:37
BLK	0.000					-2dc57c8e:18c7d19aefa:-6df4	12/21/2023 1:01
BLK	-0.039					-2dc57c8e:18c7d19aefa:-6dda	12/21/2023 6:06
BLK	0.000					-2dc57c8e:18c7d19aefa:-6dd8	12/21/2023 6:30
BLK	0.000					-2dc57c8e:18c7d19aefa:-6cf7	12/21/2023 10:48
BLK	0.000					-2dc57c8e:18c7d19aefa:-6cef	12/21/2023 13:56

Cl₂-Data 2 of 2

elementOne
e 41721-Cl₂

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41721 (15-28)

Date: 12/29/23
Analyst: WJColumn: IonPac AS14A
Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃Instrument: 8811858
Lot# 1C11-871

Batch name: 12/29/23-41721

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
Regenerant: 100mM H₃PO₄

Lot # 1C11-101-2

Flow Rate: 1.0 mL/min.

Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0.0			GC	MANR	R2	
2	0.1		Cl ⁻	4308.339	12.166	4992.98	
3	1.0						
4	3.0						
5	5.0						
6	10.0						
7	GC						
8	GC						
9	BLK						
10	BLK						
11	DL						
12	DL						
13	LEB						
14	LEB						
15	LEB+						
16	LEB+						
17	41721-15	Deeco	Cl ₂		—	SX	
18	-15	↓	↓		—	↓	
19	-17	↓	↓		—	↓	
20	-17D	↓	↓		—	↓	
21	-17+	↓	↓		5.057	↓	
22	-17+D	↓	↓		5.065	↓	
23	GC						
24	GC						
25	BLK						

Manual integrations noted by M

Curve IC Lot # 1C11-105-1 Sodium Thiosulfate Lot # 1C11-73-4 Comments: pg 1 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #s: IC ME Solution 230907.9-250 10/1

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: 12/29/23 Time: 3:28 By: WJ QC Review- Date: _____ Time: _____ By: _____

elementOne

Certification: NJ NELAP NC009
41721 Deeco M26A Report Packet
Page 44 of 46

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41721 (15-28)

Date: 12/19/23

Analyst: WJ

Column: IonPac AS14A

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Instrument: 881/858

Lot# 1C11-87-1

Batch name: 12/19/23-41721

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100mM H₃PO₄

Lot # 1C11-104-2

Flow Rate: 1.0 mL/min.

Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	BLK						
27	41721-16	Deeco	Cl ₂			5X	
28	-16D						
29	-18						
30	-19D						
31	-19						
32	-19D						
33	-20						
34	-20D						
35	-21						
36	-21D						
37	GC						
38	GC						
39	BLK						
40	BLK						
41	41721-22	Deeco	Cl ₂			5X	
42	-22D						
43	-23						
44	-23D						
45	-23+				4.922		
46	-23+D				5.125		
47	-24						
48	-24D						
49	-25						
50	-25D						

Manual Integr:

Curve IC Lot #

Sodium Thiosulfate Lot #

Comments:

pg 2 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: _____ Time: _____ By: _____ QC Review- Date: _____ Time: _____ By: _____

elementOne

Certification: NJ NELAP NC009

41721 Deeco M26A Report Packet

Page 45 of 46

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41721 (15-28)

Date: 12.19.23

Analyst: W

Column: IonPac AS14A

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Instrument: 8811658

Lot# 1C11-871

Batch name: 12.23-41721

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100mM H₃PO₄

Lot # 1C11-104-2

Flow Rate: 1.0 mL/min.

Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
51	GC						
52	GC						
53	PLK						
54	PLK						
55	41721-26	Deeco	Cl ₂			5X	
56	-26D						
57	-27 FBON						
58	-27 FBOND						
59	-28 FB OFF						
60	-28 FB OFFD						
61	100347 - GC				3.801	20X	TV=78.0
62	7 - GC				3844	↓	
63	GC						
64	DL						
65	BLK						
66	DI						
67	LO						
68	30						
69	50						
70	10.0						
71	GC						
72	DL						
73	BLK						

Manual integr

Curve IC Lot #

Sodium Thiosulfate Lot #

Comments: pg 30FB

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date:

Time:

By:

QC Review- Date:

Time:

By:

elementOne

Appendix D

Plant Process Data

Buzzi Unicem Maryneal TX Kiln 4 Main Stack Mill On Run 1 Date/Time	Kiln4: CLINKER_PR OD (TNHR) Expression Value
11/29/2023 14:50	150.9
11/29/2023 14:51	150.9
11/29/2023 14:52	151.0
11/29/2023 14:53	150.9
11/29/2023 14:54	150.9
11/29/2023 14:55	150.9
11/29/2023 14:56	151.0
11/29/2023 14:57	150.9
11/29/2023 14:58	150.9
11/29/2023 14:59	150.9
11/29/2023 15:00	150.9
11/29/2023 15:01	150.9
11/29/2023 15:02	150.9
11/29/2023 15:03	150.9
11/29/2023 15:04	151.0
11/29/2023 15:05	150.9
11/29/2023 15:06	150.9
11/29/2023 15:07	150.9
11/29/2023 15:08	150.9
11/29/2023 15:09	150.9
11/29/2023 15:10	150.9
11/29/2023 15:11	151.0
11/29/2023 15:12	150.9
11/29/2023 15:13	150.9
11/29/2023 15:14	150.9
11/29/2023 15:15	150.9
11/29/2023 15:16	150.9
11/29/2023 15:17	150.8
11/29/2023 15:18	150.9
11/29/2023 15:19	150.9
11/29/2023 15:20	151.0
11/29/2023 15:21	150.9
11/29/2023 15:22	150.9
11/29/2023 15:23	150.9
11/29/2023 15:24	150.9
11/29/2023 15:25	150.9
11/29/2023 15:26	150.9
11/29/2023 15:27	150.9
11/29/2023 15:28	150.9
11/29/2023 15:29	150.9
11/29/2023 15:30	150.9
11/29/2023 15:31	150.9
11/29/2023 15:32	150.9
11/29/2023 15:33	150.9
11/29/2023 15:34	150.9
11/29/2023 15:35	150.9
11/29/2023 15:36	150.9
11/29/2023 15:37	151.0
11/29/2023 15:38	150.9
11/29/2023 15:39	150.9
11/29/2023 15:40	150.9
11/29/2023 15:41	150.9
11/29/2023 15:42	151.0
11/29/2023 15:43	150.9
11/29/2023 15:44	150.9
11/29/2023 15:45	150.9
11/29/2023 15:46	151.0
11/29/2023 15:47	150.9
11/29/2023 15:48	151.0
11/29/2023 15:49	150.9
11/29/2023 15:50	151.0
11/29/2023 15:51	150.9
11/29/2023 15:52	150.9
11/29/2023 15:53	150.9
11/29/2023 15:54	150.9
11/29/2023 15:55	150.9
11/29/2023 15:56	150.9
Average	150.9

Buzzi Unicem Maryneal TX Kiln 4 Main Stack Mill On Run 2	Kiln4: CLINKER_PR OD (TNHR) Expression Value
11/30/2023 09:20	138.3
11/30/2023 09:21	138.4
11/30/2023 09:22	138.3
11/30/2023 09:23	138.2
11/30/2023 09:24	138.2
11/30/2023 09:25	138.3
11/30/2023 09:26	138.3
11/30/2023 09:27	138.2
11/30/2023 09:28	135.7
11/30/2023 09:29	135.0
11/30/2023 09:30	135.1
11/30/2023 09:31	135.2
11/30/2023 09:32	135.1
11/30/2023 09:33	135.2
11/30/2023 09:34	135.1
11/30/2023 09:35	135.2
11/30/2023 09:36	135.1
11/30/2023 09:37	135.0
11/30/2023 09:38	135.1
11/30/2023 09:39	135.2
11/30/2023 09:40	135.1
11/30/2023 09:41	135.1
11/30/2023 09:42	135.1
11/30/2023 09:43	135.1
11/30/2023 09:44	135.1
11/30/2023 09:45	135.1
11/30/2023 09:46	135.1
11/30/2023 09:47	135.1
11/30/2023 09:48	135.1
11/30/2023 09:49	135.1
11/30/2023 09:50	135.0
11/30/2023 09:51	135.1
11/30/2023 09:52	135.1
11/30/2023 09:53	135.1
11/30/2023 09:54	135.1
11/30/2023 09:55	135.2
11/30/2023 09:56	135.2
11/30/2023 09:57	135.0
11/30/2023 09:58	135.1
11/30/2023 09:59	135.1
11/30/2023 10:00	133.0
11/30/2023 10:01	128.9
11/30/2023 10:02	129.0
11/30/2023 10:03	128.9
11/30/2023 10:04	128.9
11/30/2023 10:05	128.9
11/30/2023 10:06	128.9
11/30/2023 10:07	128.9
11/30/2023 10:08	128.9
11/30/2023 10:09	128.9
11/30/2023 10:10	128.9
11/30/2023 10:11	129.0
11/30/2023 10:12	128.9
11/30/2023 10:13	128.9
11/30/2023 10:14	128.9
11/30/2023 10:15	128.9
11/30/2023 10:16	128.9
11/30/2023 10:17	128.9
11/30/2023 10:18	128.9
11/30/2023 10:19	128.9
11/30/2023 10:20	128.9
11/30/2023 10:21	128.9
11/30/2023 10:22	128.9
11/30/2023 10:23	128.9
11/30/2023 10:24	128.9
11/30/2023 10:25	128.9
11/30/2023 10:26	128.9
Average	133.1

Date/Time	Klin4: CLINKER_PR OD (TNHR) Expression Value
11/30/2023 10:45	129.0
11/30/2023 10:46	128.9
11/30/2023 10:47	128.9
11/30/2023 10:48	129.0
11/30/2023 10:49	128.9
11/30/2023 10:50	128.9
11/30/2023 10:51	128.9
11/30/2023 10:52	129.0
11/30/2023 10:53	128.9
11/30/2023 10:54	128.9
11/30/2023 10:55	129.0
11/30/2023 10:56	128.9
11/30/2023 10:57	128.9
11/30/2023 10:58	128.9
11/30/2023 10:59	128.9
11/30/2023 11:00	128.9
11/30/2023 11:01	128.9
11/30/2023 11:02	128.9
11/30/2023 11:03	128.9
11/30/2023 11:04	128.9
11/30/2023 11:05	128.9
11/30/2023 11:06	128.9
11/30/2023 11:07	128.9
11/30/2023 11:08	128.9
11/30/2023 11:09	128.9
11/30/2023 11:10	128.9
11/30/2023 11:11	129.0
11/30/2023 11:12	128.9
11/30/2023 11:13	128.9
11/30/2023 11:14	128.9
11/30/2023 11:15	128.9
11/30/2023 11:16	128.9
11/30/2023 11:17	129.0
11/30/2023 11:18	128.9
11/30/2023 11:19	132.0
11/30/2023 11:20	132.1
11/30/2023 11:21	132.0
11/30/2023 11:22	132.0
11/30/2023 11:23	131.9
11/30/2023 11:24	132.0
11/30/2023 11:25	132.0
11/30/2023 11:26	132.0
11/30/2023 11:27	132.0
11/30/2023 11:28	131.9
11/30/2023 11:29	131.9
11/30/2023 11:30	131.9
11/30/2023 11:31	132.1
11/30/2023 11:32	132.0
11/30/2023 11:33	131.9
11/30/2023 11:34	132.0
11/30/2023 11:35	132.1
11/30/2023 11:36	132.0
11/30/2023 11:37	132.0
11/30/2023 11:38	132.1
11/30/2023 11:39	132.0
11/30/2023 11:40	132.1
11/30/2023 11:41	131.9
11/30/2023 11:42	132.1
11/30/2023 11:43	131.9
11/30/2023 11:44	131.9
11/30/2023 11:45	132.1
11/30/2023 11:46	132.1
11/30/2023 11:47	131.9
11/30/2023 11:48	132.1
11/30/2023 11:49	132.0
11/30/2023 11:50	131.9
11/30/2023 11:51	132.0
Average	130.4

Buzzi Unicem Maryneal TX Kiln 4 Main Stack Mill On Run 3 Date/Time	Kiln4: CLINKER_PR OD (TNHR) Expression Value
11/30/2023 10:45	129.0
11/30/2023 10:46	128.9
11/30/2023 10:47	128.9
11/30/2023 10:48	129.0
11/30/2023 10:49	128.9
11/30/2023 10:50	128.9
11/30/2023 10:51	128.9
11/30/2023 10:52	129.0
11/30/2023 10:53	128.9
11/30/2023 10:54	128.9
11/30/2023 10:55	129.0
11/30/2023 10:56	128.9
11/30/2023 10:57	128.9
11/30/2023 10:58	128.9
11/30/2023 10:59	128.9
11/30/2023 11:00	128.9
11/30/2023 11:01	128.9
11/30/2023 11:02	128.9
11/30/2023 11:03	128.9
11/30/2023 11:04	128.9
11/30/2023 11:05	128.9
11/30/2023 11:06	128.9
11/30/2023 11:07	128.9
11/30/2023 11:08	128.9
11/30/2023 11:09	128.9
11/30/2023 11:10	128.9
11/30/2023 11:11	129.0
11/30/2023 11:12	128.9
11/30/2023 11:13	128.9
11/30/2023 11:14	128.9
11/30/2023 11:15	128.9
11/30/2023 11:16	128.9
11/30/2023 11:17	129.0
11/30/2023 11:18	128.9
11/30/2023 11:19	132.0
11/30/2023 11:20	132.1
11/30/2023 11:21	132.0
11/30/2023 11:22	132.0
11/30/2023 11:23	131.9
11/30/2023 11:24	132.0
11/30/2023 11:25	132.0
11/30/2023 11:26	132.0
11/30/2023 11:27	132.0
11/30/2023 11:28	131.9
11/30/2023 11:29	131.9
11/30/2023 11:30	131.9
11/30/2023 11:31	132.1
11/30/2023 11:32	132.0
11/30/2023 11:33	131.9
11/30/2023 11:34	132.0
11/30/2023 11:35	132.1
11/30/2023 11:36	132.0
11/30/2023 11:37	132.0
11/30/2023 11:38	132.1
11/30/2023 11:39	132.0
11/30/2023 11:40	132.1
11/30/2023 11:41	131.9
11/30/2023 11:42	132.1
11/30/2023 11:43	131.9
11/30/2023 11:44	131.9
11/30/2023 11:45	132.1
11/30/2023 11:46	132.1
11/30/2023 11:47	131.9
11/30/2023 11:48	132.1
11/30/2023 11:49	132.0
11/30/2023 11:50	131.9
11/30/2023 11:51	132.0
Average	130.4

Buzzi Unicem Maryneal TX Kiln 4 Main Stack Mill Off Run 1 Date/Time	Kiln4: CLINKER_PR OD (TNHR) Expression Value
11/30/2023 14:05	128.9
11/30/2023 14:06	129.0
11/30/2023 14:07	128.9
11/30/2023 14:08	128.9
11/30/2023 14:09	128.9
11/30/2023 14:10	128.9
11/30/2023 14:11	129.0
11/30/2023 14:12	128.8
11/30/2023 14:13	128.9
11/30/2023 14:14	128.9
11/30/2023 14:15	128.8
11/30/2023 14:16	128.9
11/30/2023 14:17	128.9
11/30/2023 14:18	128.9
11/30/2023 14:19	128.9
11/30/2023 14:20	128.9
11/30/2023 14:21	128.9
11/30/2023 14:22	129.0
11/30/2023 14:23	128.9
11/30/2023 14:24	128.9
11/30/2023 14:25	128.9
11/30/2023 14:26	128.9
11/30/2023 14:27	128.9
11/30/2023 14:28	128.9
11/30/2023 14:29	128.9
11/30/2023 14:30	128.9
11/30/2023 14:31	129.0
11/30/2023 14:32	129.0
11/30/2023 14:33	129.0
11/30/2023 14:34	128.9
11/30/2023 14:35	128.9
11/30/2023 14:36	129.0
11/30/2023 14:37	128.9
11/30/2023 14:38	129.0
11/30/2023 14:39	128.9
11/30/2023 14:40	128.9
11/30/2023 14:41	128.9
11/30/2023 14:42	128.9
11/30/2023 14:43	128.9
11/30/2023 14:44	128.9
11/30/2023 14:45	128.9
11/30/2023 14:46	129.0
11/30/2023 14:47	128.9
11/30/2023 14:48	128.9
11/30/2023 14:49	128.9
11/30/2023 14:50	129.0
11/30/2023 14:51	128.9
11/30/2023 14:52	129.0
11/30/2023 14:53	129.0
11/30/2023 14:54	128.9
11/30/2023 14:55	128.9
11/30/2023 14:56	128.9
11/30/2023 14:57	128.9
11/30/2023 14:58	128.9
11/30/2023 14:59	129.0
11/30/2023 15:00	128.9
11/30/2023 15:01	128.9
11/30/2023 15:02	128.9
11/30/2023 15:03	128.9
11/30/2023 15:04	128.9
11/30/2023 15:05	128.9
11/30/2023 15:06	128.9
11/30/2023 15:07	128.9
11/30/2023 15:08	129.0
11/30/2023 15:09	128.9
11/30/2023 15:10	128.9
11/30/2023 15:11	128.9
Average	128.9







Buzzi Unicem Maryneal TX Kiln 4 Main Stack Mill Off Run 2 Date/Time	Kiln4: CLINKER_PR OD (TNHR) Expression Value
11/30/2023 15:39	129.0
11/30/2023 15:40	128.9
11/30/2023 15:41	128.9
11/30/2023 15:42	128.9
11/30/2023 15:43	128.9
11/30/2023 15:44	128.9
11/30/2023 15:45	128.9
11/30/2023 15:46	128.9
11/30/2023 15:47	128.9
11/30/2023 15:48	129.0
11/30/2023 15:49	128.9
11/30/2023 15:50	129.0
11/30/2023 15:51	128.9
11/30/2023 15:52	128.9
11/30/2023 15:53	128.9
11/30/2023 15:54	128.9
11/30/2023 15:55	128.9
11/30/2023 15:56	128.9
11/30/2023 15:57	128.9
11/30/2023 15:58	128.9
11/30/2023 15:59	129.0
11/30/2023 16:00	128.9
11/30/2023 16:01	128.9
11/30/2023 16:02	129.0
11/30/2023 16:03	128.9
11/30/2023 16:04	128.9
11/30/2023 16:05	128.9
11/30/2023 16:06	129.0
11/30/2023 16:07	128.9
11/30/2023 16:08	129.0
11/30/2023 16:09	128.9
11/30/2023 16:10	128.9
11/30/2023 16:11	129.0
11/30/2023 16:12	128.9
11/30/2023 16:13	128.9
11/30/2023 16:14	128.9
11/30/2023 16:15	128.9
11/30/2023 16:16	128.9
11/30/2023 16:17	129.0
11/30/2023 16:18	128.9
11/30/2023 16:19	129.0
11/30/2023 16:20	128.9
11/30/2023 16:21	128.9
11/30/2023 16:22	128.9
11/30/2023 16:23	128.9
11/30/2023 16:24	129.0
11/30/2023 16:25	128.9
11/30/2023 16:26	128.9
11/30/2023 16:27	128.9
11/30/2023 16:28	128.9
11/30/2023 16:29	128.9
11/30/2023 16:30	129.0
11/30/2023 16:31	128.9
11/30/2023 16:32	129.0
11/30/2023 16:33	129.0
11/30/2023 16:34	128.9
11/30/2023 16:35	129.0
11/30/2023 16:36	128.9
11/30/2023 16:37	128.9
11/30/2023 16:38	128.9
11/30/2023 16:39	129.0
11/30/2023 16:40	129.0
11/30/2023 16:41	128.9
11/30/2023 16:42	128.9
11/30/2023 16:43	128.9
11/30/2023 16:44	128.9
11/30/2023 16:45	128.9
Average	128.9

Buzzi Unicem Maryneal TX Kiln 4 Main Stack Mill Off Run 3 Date/Time	Kiln4: CLINKER_PR OD (TNHR) Expression Value
11/30/2023 17:25	128.9
11/30/2023 17:26	128.9
11/30/2023 17:27	128.9
11/30/2023 17:28	128.9
11/30/2023 17:29	128.9
11/30/2023 17:30	128.9
11/30/2023 17:31	128.9
11/30/2023 17:32	128.9
11/30/2023 17:33	128.9
11/30/2023 17:34	128.9
11/30/2023 17:35	129.0
11/30/2023 17:36	128.9
11/30/2023 17:37	128.9
11/30/2023 17:38	128.9
11/30/2023 17:39	129.0
11/30/2023 17:40	128.9
11/30/2023 17:41	128.9
11/30/2023 17:42	129.0
11/30/2023 17:43	128.9
11/30/2023 17:44	128.9
11/30/2023 17:45	128.9
11/30/2023 17:46	129.0
11/30/2023 17:47	128.9
11/30/2023 17:48	129.0
11/30/2023 17:49	129.0
11/30/2023 17:50	129.0
11/30/2023 17:51	129.0
11/30/2023 17:52	128.9
11/30/2023 17:53	128.9
11/30/2023 17:54	129.0
11/30/2023 17:55	128.9
11/30/2023 17:56	128.9
11/30/2023 17:57	128.9
11/30/2023 17:58	128.9
11/30/2023 17:59	128.9
11/30/2023 18:00	128.9
11/30/2023 18:01	129.0
11/30/2023 18:02	128.9
11/30/2023 18:03	128.9
11/30/2023 18:04	128.9
11/30/2023 18:05	128.9
11/30/2023 18:06	129.0
11/30/2023 18:07	128.9
11/30/2023 18:08	128.9
11/30/2023 18:09	129.0
11/30/2023 18:10	128.9
11/30/2023 18:11	128.9
11/30/2023 18:12	128.9
11/30/2023 18:13	128.9
11/30/2023 18:14	128.9
11/30/2023 18:15	128.9
11/30/2023 18:16	128.9
11/30/2023 18:17	128.9
11/30/2023 18:18	128.9
11/30/2023 18:19	129.0
11/30/2023 18:20	128.9
11/30/2023 18:21	128.9
11/30/2023 18:22	128.9
11/30/2023 18:23	129.0
11/30/2023 18:24	128.9
11/30/2023 18:25	128.9
11/30/2023 18:26	128.9
11/30/2023 18:27	129.0
11/30/2023 18:28	128.9
11/30/2023 18:29	128.9
11/30/2023 18:30	128.9
11/30/2023 18:31	128.9
Average	128.9

Appendix E

Calibration Documents

Pitot Tube Inspection Sheet



Date	01/03/23
Tube Assembly Level?	Yes
Ports Damaged?	No
-10 deg < a1 < +10 deg	2
-10 deg < a2 < +10 deg	1
-5 deg < B1 < +5 deg	1
-5 deg < B2 < +5 deg	1
Y (gamma)	1
0 (theta)	1
A (alpha)	0.951
Z = A (sin y) < 0.125"	yes
W = A (sin 0) < 0.031"	yes
Pa =	0.475
Pb =	0.476
Tube Diameter (Dt) =	0.376
Pa = Pb +/- 0.063"	yes
(1.05 x Dt)?	0.3948
(1.50 x Dt)?	0.564
(1.05 x Dt) < P < (1.50 x Dt)?	yes
Eligible for Default Pitot Calibration Factor (Cp = 0.84)?	Yes

Thermocouple Calibration

Type of Reference Thermometer?	Mercury	Date	01/03/23
Barometric Pressure?	29.52	Ambient Temperature?	68

Source	Reference Temp, F	Thermocouple Temp, F	Absolute Temp Difference
cold air	37	38	-0.20%
medium air	215	215	0.00%
hot air	325	325	0.00%

Windtunnel Calibration

Pitot Reading	Reference (0.99)	5A S-Type Pitot	Cp
ΔP_1	0.31	0.44	0.84
ΔP_2	0.31	0.43	0.85
ΔP_3	0.31	0.43	0.85
Average Pitot Tube Calibration Factor---->			0.85

Thermocouple Calibration Check (EPA ALT-011 Procedure), performed on 1/3/23

Source	Ref. Temp. F	Thermocouple Temp. F	± 2 deg F?
Ambient	68	66.9	Yes

Pitot Tube Inspection Sheet

	Date	01/03/23
	Tube Assembly Level?	Yes
	Ports Damaged?	No
	-10 deg < a1 < +10 deg	1
	-10 deg < a2 < +10 deg	2
	-5 deg < B1 < +5 deg	1
	-5 deg < B2 < +5 deg	2
	Y (gamma)	1
	0 (theta)	1
	A (alpha)	0.94
	Z = A (sin y) < 0.125"?	yes
	W = A (sin 0) < 0.031"?	yes
	Pa =	0.47
	Pb =	0.47
	Tube Diameter (Dt) =	0.376
Pa = Pb +/- 0.063"?	yes	
(1.05 x Dt)?	0.3948	
(1.50 x Dt)?	0.564	
(1.05 x Dt) < P < (1.50 x Dt)?	yes	
Eligible for Default Pitot Calibration Factor (Cp = 0.84)?		Yes

Thermocouple Calibration

Type of Reference Thermometer?	Mercury	Date	01/03/23
Barometric Pressure?	29.52	Ambient Temperature?	69.9

Source	Reference Temp. F	Thermocouple Temp. F	Absolute Temp Difference
cold air	37	38	-0.20%
medium air	215	215	0.00%
hot air	325	324	0.13%


Windtunnel Calibration

Pitot Reading	Reference (0.99)	5B S-Type Pitot	Cp
ΔP_1	0.31	0.44	0.84
ΔP_2	0.31	0.43	0.85
ΔP_3	0.31	0.44	0.84
Average Pitot Tube Calibration Factor-->			0.84

Thermocouple Calibration Check (EPA ALT-011 Procedure), performed on 1/3/23

Source	Ref. Temp. F	Thermocouple Temp. F	± 2 deg F?
Ambient	69.9	69.4	Yes

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

DATE: 12/28/21		METER SERIAL #: M5-15		CRITICAL ORIFICE SET SERIAL #: 14315		BAROMETRIC PRESSURE (in Hg):		INITIAL: 30.03		FINAL: 30.03		AVG (P _{bar}): 30.03						
METER PART #: M5-15		METER SERIAL #: M5-15		CRITICAL ORIFICE SET SERIAL #: 14315		BAROMETRIC PRESSURE (in Hg):		INITIAL: 30.03		FINAL: 30.03		AVG (P _{bar}): 30.03						
ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)				TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H ₂ O)	V _{cr} (STD)	(3) Y	VARIATION (%)	ΔH _g	
				INITIAL	FINAL	NET (V _m)	AMBIENT	DGM INLET	DGM OUTLET	DGM INLET	DGM OUTLET							DGM INLET
12	1	0.3283																
	2																	
	3																	
15	1	0.4094	18	353.924	359.213	5.289	75	62	65	62	62	62.75	10.00	0.8	5.3733	5.3168	0.989	
	2	0.4094	18	359.213	364.553	5.340	76	65	66	62	63	64	10.00	0.8	5.4122	5.3119	0.981	1.62
	3						0.000					0						1.62
19	1	0.5047	18	364.553	371.213	6.660	76	66	70	63	65	66	10.00	1.3	6.7325	6.5483	0.973	1.72
	2	0.5047	18	371.213	377.910	6.697	76	70	72	65	66	68.25	10.00	1.3	6.7411	6.5483	0.971	1.72
	3						0.000					0						
23	1	0.6426	18	377.910	386.465	8.555	77	70	74	66	68	69.5	10.00	2.1	8.6078	8.3298	0.968	1.71
	2	0.6426	18	386.465	395.066	8.601	77	74	75	68	69	71.5	10.00	2.1	8.6215	8.3298	0.966	1.71
	3						0.000					0						
32	1	0.8587																
	2																	
	3																	

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:
The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **0.975**

$$(1) \quad V'_{m(air)} = K' \cdot V_m \cdot \frac{P_{bar} + (\Delta H \cdot 13.6)}{T_m}$$


$$(2) \quad V'_{cr(air)} = K' \cdot \frac{P_{bar} \cdot \Phi}{\sqrt{T_{amb}}}$$

$$(3) \quad Y = \frac{V'_{cr(air)}}{V'_{m(air)}} = \frac{P_{bar} \cdot \Phi}{\sqrt{T_{amb}} \cdot V_m \cdot \frac{P_{bar} + (\Delta H \cdot 13.6)}{T_m}}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions
K₁ = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)
T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)
= Volume of gas sample passed through the critical orifice, corrected to standard conditions
T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)
K' = Average K' factor from Critical Orifice Calibration
= DGM calibration factor

AVERAGE ΔH_g = **1.68**
Potentiometer Check, °F
@ 0 F
@ 496
@ 500 F
@ 1000 F
Avg Absolute Difference = **0.1%**

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

DATE: 12.8.22
METER PART #: M5-21

METER SERIAL #: M5-21
CRITICAL ORIFICE SET SERIAL #: 14315

INITIAL: 29.99
FINAL: 29.99
AVG (P_{bar}): 29.99

IF Y VARIATION EXCEEDS 2.00%,
ORIFICE SHOULD BE RECALIBRATED

ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)				TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H ₂ O)	V _m (STD)	(2) V _c (STD)	(3) Y	VARIATION (%)	ΔH ₂
				INITIAL	FINAL	NET (V _m)	AMBIENT	DGM INLET INITIAL	DGM INLET FINAL	DGM OUTLET INITIAL	DGM OUTLET FINAL							
12	1	0.3283				0.000												
	2					0.000												
	3					0.000												
15	1	0.4094	18	58.501	63.745	5.244	67	69	69	69	69	69	10.00	0.86	5.2584	5.3499	1.017	1.69
	2	0.4094	18	63.811	69.109	5.298	67	69	70	69	69	69	10.00	0.86	5.3100	5.3499	1.008	1.69
	3					0.000												
19	1	0.5047	18	69.109	75.825	6.716	68	70	71	69	70	70	10.00	1.3	6.7289	6.5890	0.979	1.69
	2	0.5047	18	75.825	82.595	6.770	67	70	72	69	70	70	10.00	1.3	6.7798	6.5953	0.973	1.68
	3					0.000												
23	1	0.6426	18	82.595	91.263	8.668	67	70	74	69	70	70	10.00	2.1	8.6894	8.3973	0.966	1.68
	2	0.6426	18	91.263	99.971	8.708	67	72	76	70	70	72	10.00	2.1	8.7089	8.3973	0.964	1.68
	3					0.000												
32	1	0.8587				0.000												
	2					0.000												
	3					0.000												

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:
The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the

$$(1) V_{m_{std}} = K' \cdot V_m \cdot \frac{P_{bar} + (\Delta H \cdot 13.6)}{T_m}$$

$$(2) V_{cr_{std}} = K' \cdot \frac{P_{bar} \cdot \Theta}{\sqrt{T_{amb}}}$$

$$(3) Y = \frac{V_{cr_{std}}}{V_{m_{std}}}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions

K₁ = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)

T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

= Volume of gas sample passed through the critical orifice, corrected to standard conditions

T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)

K' = Average K' factor from Critical Orifice Calibration

= DGM calibration factor

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 0.985

AVERAGE ΔH₂ = 1.69

Potentiometer Check, °F
(per manufacturer procedure)
0 @ 0 F
496 @ 500 F
1000 @ 1000 F

Avg Absolute Difference = 0.1%

Company: Buzzi Unicem; Maryneal TX
Source: Main Stack; Raw Mill Off
Job ID: 23-3315
Train Type: EPA Method 26A

Alt-009 Alternate Post Test Calibration Data

	5A 11/30/23 1405-1511	5B 11/30/23 1405-1511	6A 30-Nov-23 1539-1645	6B 30-Nov-23 1539-1645	7A 30-Nov-23 1725-1831	7B 30-Nov-23 1725-1831	M5-15 Averages	M5-21 Averages
Vm	44.671	43.937	45.804	44.587	45.736	45.342		
Tm	538	542.3	538.1	541.3	538.1	542.3		
Pb	27.43	27.43	27.43	27.43	27.43	27.43		
Havg	1.48	1.46	1.51	1.51	1.52	1.54		
H@	1.68	1.69	1.68	1.69	1.68	1.69		
Md	31.3	31.3	31.26	31.26	31.248	31.248		
(Havg)*0.5	1.2135534	1.20637998	1.22591897	1.22591897	1.22999959	1.23974091		
Run Time, Min	60	60	60	60	60	60		
Calculated Gamma (Yqa)	0.956	0.967	0.942	0.968	0.947	0.963	0.948	0.966
Meter Gamma	0.975	0.985	0.975	0.985	0.975	0.985	0.975	0.985
% difference from Actual Y	1.99%	1.85%	3.37%	1.75%	2.89%	2.19%	2.75%	1.93%

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E04NI77E15A3796	Reference Number:	122-401833216-1
Cylinder Number:	EB0066680	Cylinder Volume:	151.1 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22020	Valve Outlet:	590
Gas Code:	CO,CO2,O2,BALN	Certification Date:	Jun 23, 2020

Expiration Date: Jun 23, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	65.00 PPM	63.68 PPM	G1	+/- 0.5% NIST Traceable	06/23/2020
CARBON DIOXIDE	10.00 %	10.01 %	G1	+/- 0.6% NIST Traceable	06/22/2020
OXYGEN	12.00 %	11.82 %	G1	+/- 0.9% NIST Traceable	06/22/2020
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	09010213	KAL004779	98.48 PPM CARBON MONOXIDE/NITROGEN	+/- 0.5%	Oct 16, 2024
NTRM	13060638	CC414571	13.359 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 14, 2025
NTRM	98051109	SG9168283BAL	9.507 % OXYGEN/NITROGEN	+/- 0.7%	Oct 06, 2021

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA510 CO2 2L6YXWY0	Nondispersive Infrared (NDIR)	May 28, 2020
Horiba VIA510 CO 1G48EA07	Nondispersive Infrared (NDIR)	Jun 18, 2020
Horiba MPA510 O2 41499150042	Paramagnetic	May 28, 2020

Triad Data Available Upon Request




Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E04NI59E15A38X3	Reference Number:	122-402389885-1A
Cylinder Number:	ALM-056015	Cylinder Volume:	143.7 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2016 PSIG
PGVP Number:	B22022	Valve Outlet:	590
Gas Code:	CO,CO2,O2,BALN	Certification Date:	Mar 28, 2022

Expiration Date: Mar 28, 2030

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	120.0 PPM	116.5 PPM	G1	+/- 0.3% NIST Traceable	03/28/2022
CARBON DIOXIDE	18.00 %	18.17 %	G1	+/- 0.7% NIST Traceable	03/28/2022
OXYGEN	22.00 %	21.90 %	G1	+/- 0.5% NIST Traceable	03/28/2022
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010207	KAL003102	246.9 PPM CARBON MONOXIDE/NITROGEN	+/- 0.2%	Oct 16, 2024
NTRM	12061508	CC354696	19.87 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 11, 2024
NTRM	08010220	K013155	23.20 % OXYGEN/NITROGEN	+/- 0.4%	Jun 01, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VA-5001 CO2 BF89GV17	Nondispersive Infrared (NDIR)	Mar 01, 2022
Horiba VIA510 CO RS2EGL6K	Nondispersive Infrared (NDIR)	Mar 01, 2022
Siemens Oxymat 61 M3299 O2	Paramagnetic	Mar 01, 2022

Triad Data Available Upon Request




Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: CERTIFIED STANDARD-SPEC

Part Number:	X02NI99C15A54F5	Reference Number:	122-402705571-1
Cylinder Number:	CC426155	Cylinder Volume:	144.0 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
Analysis Date:	Mar 28, 2023	Valve Outlet:	350
Lot Number:	122-402705571-1		


Expiration Date: Mar 28, 2031

Product composition verified by direct comparison to calibration standards traceable to N.I.S.T. weights and/or N.I.S.T. Gas Mixture reference materials.

ANALYTICAL RESULTS

Component	Req Conc	Actual Concentration (Mole %)	Analytical Uncertainty
ETHYLENE	75.00 PPM	75.47 PPM	+/- 2%
NITROGEN	Balance		




Approved for Release



an Air Liquide company

SAY LABORATORY

CERTIFICATE OF ACCURACY: GMACS-c Calibration Standard

CUSTOMER INFORMATION

AIRGAS SPECIALTY GASES
Exploratory Products Group
6141 Easton Road
Plumsteadville, PA 18949

Work Order #: 160-402845895-1
Sales Order #: 1123601913
PO #: 7100179560

Customer: DEECO Inc.
Address 1: 3404 Lake Woodard Road
Address 2:
City / State / Zip: Raleigh, NC 27604

PRODUCT INFORMATION

COMPOSITION	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	199.1 PPM	5.7 PPM	2.9 %
Sulfur Hexafluoride	10.0 PPM	0.07 PPM	0.7 %
Nitrogen	Balance		

CYLINDER #: CC768233
CYLINDER TYPE: 150A Aluminum
CGA: 350 SS
CYLINDER PRESSURE: 2000 psig

AIRGAS PART #: X03NI99C15AC0Y6
CERTIFICATION DATE: 8-Sep-2023
EXPIRATION DATE: 8-Mar-2024
MIXTURE DEW POINT: N/A

CERTIFICATION DATA

BLENDING PROCESS: GravStat™ Gravimetry

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	200.40 PPM	3.0 PPM	1.5 %
Sulfur Hexafluoride	10.01 PPM	0.07 PPM	0.7 %

CONFIRMING ANALYSIS: FTIR Spectroscopy

INSTRUMENT / MODEL: CAI Model 700 FTIR

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	197.9 PPM	4.9 PPM	2.5 %

REFERENCE STANDARD: GMPS-c 200 PPM Hydrogen Cyanide

CYLINDER NUMBER: CC768217

EXPIRATION DATE: 2/27/2024

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	197.1 PPM	4.8 PPM	2.4 %

CALIBRATION CURVE DATA	Curve Order	Correlation	Slope (X2)	Slope (X)	Intercept
Point-to-Point Matching Std	Linear / Direct Ratio	N/A	N/A	N/A	N/A

INTERLOCK STATISTICS

	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
BLEND RESULT:	200.40 PPM	3.0 PPM	1.5 %
ANALYSIS RESULT:	197.9 PPM	4.9 PPM	2.5 %
INTERLOCK RESULT:	199.1 PPM	5.7 PPM	2.9 %

COMMENTS / SPECIAL INSTRUCTIONS

1. A GMACS-c ("Candidate GMACS") is made and certified according to the EPA GMACS Procedure (Alt-114) found at: <https://cfpub.epa.gov>

2. Do not use this standard if pressure is less than 200 psig.
3. Do not use or store this product at or below the stated dew point.

APPROVED BY:

BOB GRASMEDER



an Air Liquide company

AIRGAS LABORATORY

CERTIFICATE OF ACCURACY: GMACS-c Calibration Standard

CUSTOMER INFORMATION

AIRGAS SPECIALTY GASES
Exploratory Products Group
6141 Easton Road
Plumsteadville, PA 18949

Work Order #: 160-402845897-1
Sales Order #: 1123601913
PO #: 7100179560

Customer: DEECO Inc.
Address 1: 3404 Lake Woodard Road
Address 2:
City / State / Zip: Raleigh, NC 27604

PRODUCT INFORMATION

COMPOSITION	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	49.9 PPM	2.3 PPM	4.6 %
Sulfur Hexafluoride	5.0 PPM	0.07 PPM	1.3 %
Nitrogen	Balance		

CYLINDER #: CC768222
CYLINDER TYPE: 150A Aluminum
CGA: 350 SS
CYLINDER PRESSURE: 2000 psig

AIRGAS PART #: X03NI99C15AC0W8
CERTIFICATION DATE: 7-Sep-2023
EXPIRATION DATE: 7-Mar-2024
MIXTURE DEW POINT: N/A

CERTIFICATION DATA

BLENDING PROCESS: GravStat™ Gravimetry

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	50.02 PPM	0.9 PPM	1.8 %
Sulfur Hexafluoride	5.02 PPM	0.07 PPM	1.3 %

CONFIRMING ANALYSIS: FTIR Spectroscopy
INSTRUMENT / MODEL: CAI Model 700 FTIR

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	49.8 PPM	2.1 PPM	4.2 %

REFERENCE STANDARD: GMPS-c 50 PPM Hydrogen Cyanide

CYLINDER NUMBER: CC768196

EXPIRATION DATE: 2/29/2024

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	48.9 PPM	1.7 PPM	3.4 %

CALIBRATION CURVE DATA	Curve Order	Correlation	Slope (X2)	Slope (X)	Intercept
Point-to-Point Matching Std	Linear / Direct Ratio	N/A	N/A	N/A	N/A

INTERLOCK STATISTICS

	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
BLEND RESULT:	50.02 PPM	0.9 PPM	1.8 %
ANALYSIS RESULT:	49.8 PPM	2.1 PPM	4.2 %
INTERLOCK RESULT:	49.9 PPM	2.3 PPM	4.6 %

COMMENTS / SPECIAL INSTRUCTIONS

1. A GMACS-c ("Candidate GMACS") is made and certified according to the EPA GMACS Procedure (Alt-114) found at: <https://cfpub.epa.gov>

2. Do not use this standard if pressure is less than 200 psig.

3. Do not use or store this product at or below the stated dew point.

APPROVED BY: _____

BOB GRASMEDER

Client: Buzzi Maryneal TX

Test Location: Main Stack; Stratification Check

Date: Nov 29, 2023 Start Time: 14:50:05

Run number 1

One Minute Averages

	Reference O2 %,dry	Plant O2 %,dry
2:51:03 PM	10.8	11.5
2:52:03 PM	10.7	11.4
2:53:03 PM	10.8	11.4
2:54:03 PM	10.8	11.4
2:55:03 PM	10.8	11.5
2:56:03 PM	10.7	11.5
Point A	10.8	11.4
2:57:03 PM	10.8	11.5
2:58:03 PM	10.8	11.5
2:59:03 PM	10.8	11.4
3:00:03 PM	10.8	11.5
3:01:03 PM	10.8	11.4
3:02:03 PM	10.8	11.5
Point B	10.8	11.5
3:03:03 PM	10.8	11.5
3:04:03 PM	10.8	11.4
3:05:03 PM	10.8	11.4
3:06:03 PM	10.8	11.5
3:07:03 PM	10.8	11.3
3:08:03 PM	10.8	11.4
Point C	10.8	11.4
Average	10.8	11.4

Date/Time	Kiln4: O2 (PCT) Raw Value
11/29/2023 14:50	11.45
11/29/2023 14:51	11.43
11/29/2023 14:52	11.42
11/29/2023 14:53	11.40
11/29/2023 14:54	11.45
11/29/2023 14:55	11.45
11/29/2023 14:56	11.47
11/29/2023 14:57	11.50
11/29/2023 14:58	11.36
11/29/2023 14:59	11.45
11/29/2023 15:00	11.40
11/29/2023 15:01	11.53
11/29/2023 15:02	11.48
11/29/2023 15:03	11.40
11/29/2023 15:04	11.43
11/29/2023 15:05	11.50
11/29/2023 15:06	11.31
11/29/2023 15:07	11.42

Buzzi Unicem, Maryneal TX

Main Stack

Pretest

Spectrum	Date	Time	HCN PCA 191c R1 191c	SF6 (10) 191C	Ethylene (100,3000) 191C	HF ppm (10) 191C	SNR 2500	sBeam @ 2500
SPC_000830BKG.LAB	11/14/23	06:57:22.888	0.000	0.000	0.000	0.000	NaN	1.41
SPC_000831.LAB	11/14/23	06:58:33.020	-0.004	-0.001	-0.037	0.011	6779.16	1.42
SPC_000832BKG.LAB	11/14/23	07:01:13.650	0.000	0.000	0.000	0.000	5353.34	1.42
SPC_000833.LAB	11/14/23	07:02:24.028	-0.064	0.003	-0.062	0.018	5553.53	1.42
SPC_000834.LAB	11/14/23	07:03:28.036	-0.154	-0.000	0.013	0.007	4837.84	1.42
SPC_000835.LAB	11/14/23	07:04:32.104	0.035	0.001	-0.014	0.003	5479.59	1.42
SPC_000836BKG.LAB	11/14/23	07:07:39.052	0.000	0.000	0.000	0.000	5734.58	1.42
SPC_000837.LAB	11/14/23	07:08:49.639	-0.051	-0.001	-0.019	-0.002	6223.51	1.42
SPC_000838.LAB	11/14/23	07:09:53.338	-0.032	-0.003	0.027	-0.000	5809.30	1.42
SPC_000839.LAB	11/14/23	07:10:57.234	0.046	-0.000	-0.014	-0.017	3759.60	1.42
SPC_000840.LAB	11/14/23	07:12:01.138	-0.011	-0.001	-0.102	0.016	4373.66	1.42
SPC_000841.LAB	11/14/23	07:13:05.164	0.080	-0.001	-0.068	0.002	5347.95	1.42
SPC_000842.LAB	11/14/23	07:14:08.941	0.059	-0.001	-0.051	-0.012	5012.46	1.42
SPC_000843.LAB	11/14/23	07:15:12.843	-0.029	-0.002	-0.084	-0.006	4706.13	1.42
Standard Deviation x 3			0.156	0.002		0.032		
Averages							5033.23	1.42

SPC_003144.LAB

11/29/23 10:07:23.437

SPC_003145.LAB

11/29/23 10:08:27.783

SPC_003146.LAB

11/29/23 10:09:31.168

SPC_003147.LAB

11/29/23 10:10:35.067

Ethylene Calibration Transfer Standard (CC426155; 75.47 ppm)

73.818
74.579
74.391
74.456
74.475

0.009
0.010
0.004
-0.005

3771.37
4602.22
3362.83
3721.81

1.25
1.25
1.25
1.25

SPC_003163.LAB

11/29/23 10:32:14.551

SPC_003164.LAB

11/29/23 10:33:18.264

SPC_003165.LAB

11/29/23 10:34:22.223

SPC_003166.LAB

11/29/23 10:35:26.094

SPC_003167.LAB

11/29/23 10:36:30.150

HCN Standard (CC768233; 199.1 ppm HCN/10.0 ppm SF6)

195.980
196.278
196.975
197.038
197.342
196.908

-0.647
-0.465
-0.523
-0.445
-0.500

9.583
9.585
9.583
9.580
9.580

NaN
4782.81
5254.76
5634.48
5809.63

1.25
1.25
1.25
1.25
1.25

SPC_003172.LAB

11/29/23 10:41:49.573

SPC_003173.LAB

11/29/23 10:42:53.522

SPC_003174.LAB

11/29/23 10:43:57.490

SPC_003175.LAB

11/29/23 10:45:01.307

SPC_003176.LAB

11/29/23 10:46:05.212

HCN Standard (CC768222; 49.9 ppm HCN/5.0 ppm SF6)

49.888
49.909
49.927
49.815
49.899
49.887

-0.442
-0.380
-0.391
-0.423
-0.380

4.852
4.847
4.851
4.849
4.848

4728.10
4092.51
3563.85
4533.18
3854.17

1.25
1.25
1.25
1.25
1.25

Analysis Validation Report

Sample Filename: F:\Maryneal\November 29\SPC_003269.LAB

Filename for noise: F:\Midlothian on Rental\November 14\SPC_000837.LAB

Interferences Filenames: C:\Midlothian on Rental\November 15\SPC_001463.LAB

C:\Midlothian on Rental\November 15\SPC_001464.LAB

C:\Midlothian on Rental\November 15\SPC_001465.LAB

C:\Midlothian on Rental\November 15\SPC_001466.LAB

C:\Midlothian on Rental\November 15\SPC_001467.LAB

C:\Midlothian on Rental\November 15\SPC_001468.LAB

C:\Midlothian on Rental\November 15\SPC_001469.LAB

C:\Midlothian on Rental\November 15\SPC_001470.LAB

Recipe path: C:\OL\Trecipes\Cement Testing R3.MGRCP

Gas calibration Name	Conc	MDC3	MDC2	MDC1	MAU	FMU*R	OCU	~DL	~CL	~Bias	Sigma	Range	Span	Comment
HCN (200) PCA 191C 191C	8.65	0.38	-	0.28	0.34	0.46	0.46	-	0.17	-	-	0-200	-	Good
HF PPM (10) 191C	-0.06	0.25	0.05	0.04	0.07	0.45	0.45	0.07	0.22	0.02	0.02	0-10	-	Close to DL
SF6 (10) 191C	-0.01	0.02	-	0	0	0.02	0.02	-	0.01	-	-	0-10	-	Check it!
ETHYLENE (100,3000) 191C	2.92	1.79	0.33	0.17	0.29	3.11	3.11	1.08	1.55	0.75	0.11	0-3000	-	Close to DL
H2O% (40) 191C	13.76	0.17	-	0.01	0.02	0.33	0.33	-	0.28	-	-	0-40	-	Good
CO2% (40) 191C	13.46	0.18	-	0.01	0.02	0.25	0.25	-	0.27	-	-	0-40	-	Good
HCL PPM (100) 191C	1.23	0.58	0.05	0.15	0.28	1.05	1.05	0.06	0.41	0.01	0.02	0-100	-	Check it!
SO2 (1000) 191C	12.1	1.13	0.37	0.14	0.27	2.17	2.17	0.79	0.82	0.42	0.12	0-1000	-	Good
NO (350,3000) 191C	129.08	4.15	0.22	0.26	0.35	5.69	5.69	0.45	2.62	0.23	0.07	0-3000	-	Good
NH3 (300) 191C (10F2)	1.04	1.33	0.03	0.12	0.2	2.25	2.25	0.15	1.19	0.11	0.01	0-300	-	Check it!
CO (500) 191C (10F2)	161.72	4.99	-	0.2	0.43	10.18	10.18	-	3.23	-	-	0-500	-	Good
CO% (1) 191C (20F2)	0.02	0	0	0	0	0	0	0	0	0	0	0-1	-	Good
FORMALDEHYDE (70) 191C	5.44	1.09	0.28	0.2	0.24	1.32	1.32	0.33	0.75	0.04	0.09	0-70	-	Good
ACETALDEHYDE (1000) 191C	2.22	2.41	0.23	0.35	0.38	2.63	2.63	0.59	2	0.35	0.08	0-1000	-	Close to DL
CH4 (250) 191C (10F2)	4.96	1.19	0.05	0.26	0.7	3.15	3.15	0.06	0.8	0.01	0.02	0-250	-	Good
PROPANE (100) 191C	1.17	0.75	0.42	0.12	0.14	0.89	0.89	0.72	0.72	0.3	0.14	0-100	-	Close to DL
HBR (100) 180C	-0.19	4.9	0.17	0.68	1.39	9.96	9.96	0.19	4.24	0.02	0.06	0-100	-	Close to DL
NO2 (150) 191C (10F2)	-0.1	0.34	0.04	0.02	0.03	0.35	0.35	0.05	0.31	0.01	0.01	0-150	-	Close to DL
NO2 (2000) 191C (20F2)	-0.16	5	2.03	0.88	1.12	6.36	6.36	3.81	4.15	1.78	0.68	0-2000	-	Close to DL
N2O (100,200,300) 191C	0.31	0.17	0.05	0.04	0.05	0.19	0.19	0.07	0.12	0.02	0.02	0-300	-	Close to DL
NH3 (3000) 191C (20F2)	2.21	12.94	0.35	1.19	2.25	24.41	24.41	0.44	11.91	0.09	0.12	0-3000	-	Close to DL
CH4 (3000) 191C (20F2)	4.45	7.43	0.34	1.1	1.81	12.24	12.24	0.61	6.25	0.27	0.11	0-3000	-	Check it!
ACETYLENE (1000) 191C	0.62	1.89	0.15	0.31	0.37	2.29	2.29	0.21	1.58	0.06	0.05	0-1000	-	Close to DL
PROPYLENE (200,1000) 191C	1.78	4.28	0.19	0.43	0.5	5.01	5.01	0.49	3.81	0.3	0.06	0-1000	-	Close to DL
COS (100) 150C	0.61	0.17	0.02	0.02	0.02	0.23	0.23	0.02	0.14	0	0.01	0-100	-	Check it!
ETHANE (500) 191C	1.17	1.22	0.32	0.2	0.22	1.36	1.36	0.54	1	0.22	0.11	0-500	-	Close to DL
H2SO4 (50) 150C	0.02	0.15	0.04	0.05	0.05	0.16	0.16	0.29	0.29	0.25	0.01	0-50	-	Close to DL
MEOH (10) 191C	0.8	0.48	0.14	0.14	0.16	0.55	0.55	0.17	0.33	0.03	0.05	0-10	-	Close to DL
SO3 (150) 191C	-3.51	0.38	0.7	0.03	0.04	0.41	0.41	1.14	1.14	0.44	0.23	0-150	-	Close to DL

Analysis Validation Report

Sample Filename: F:\Maryneal\November 29\SPC__003270.LAB

Filename for noise: F:\Midlothian on Rental\November 14\SPC__000837.LAB

Interferences Filenames: C:\Midlothian on Rental\November 15\SPC__001463.LAB

C:\Midlothian on Rental\November 15\SPC__001464.LAB

C:\Midlothian on Rental\November 15\SPC__001465.LAB

C:\Midlothian on Rental\November 15\SPC__001466.LAB

C:\Midlothian on Rental\November 15\SPC__001467.LAB


C:\Midlothian on Rental\November 15\SPC__001468.LAB

C:\Midlothian on Rental\November 15\SPC__001469.LAB

C:\Midlothian on Rental\November 15\SPC__001470.LAB

Recipe path: C:\OL\Trecipes\Cement Testing R3.MGRCP

Gas calibration Name	Conc	MDC3	MDC2	MDC1	MAU	FMU*R	OCU	~DL	~CL	~Bias	Sigma	Range	Span	Comment
HCN (200) PCA 191C 191C	8.64	0.47	-	0.28	0.34	0.57	0.57	-	0.18	-	-	0-200	-	Good
HF PPM (10) 191C	-0.02	0.24	0.05	0.04	0.07	0.43	0.43	0.07	0.21	0.02	0.02	0-10	-	Close to DL
SF6 (10) 191C	-0.01	0.02	-	0	0	0.02	0.02	-	0.02	-	-	0-10	-	Check it!
ETHYLENE (100,3000) 191C	2.89	1.8	0.33	0.17	0.29	3.14	3.14	1.08	1.57	0.75	0.11	0-3000	-	Close to DL
H2O% (40) 191C	13.67	0.17	-	0.01	0.02	0.33	0.33	-	0.27	-	-	0-40	-	Good
CO2% (40) 191C	13.62	0.19	-	0.01	0.02	0.26	0.26	-	0.27	-	-	0-40	-	Good
HCL PPM (100) 191C	1.13	0.52	0.05	0.15	0.28	0.96	0.96	0.06	0.36	0.01	0.02	0-100	-	Check it!
SO2 (1000) 191C	10.37	1.13	0.37	0.14	0.27	2.18	2.18	0.79	0.81	0.42	0.12	0-1000	-	Good
NO (350,3000) 191C	135.44	4.2	0.22	0.26	0.35	5.76	5.76	0.45	2.75	0.23	0.07	0-3000	-	Good
NH3 (300) 191C (10F2)	1.07	1.36	0.03	0.12	0.2	2.3	2.3	0.15	1.21	0.11	0.01	0-300	-	Check it!
CO (500) 191C (10F2)	168.94	5.15	-	0.2	0.43	10.49	10.49	-	3.38	-	-	0-500	-	Good
CO% (1) 191C (20F2)	0.02	0	0	0	0	0	0	0	0	0	0	0-1	-	Good
FORMALDEHYDE (70) 191C	5.24	1.09	0.28	0.2	0.24	1.32	1.32	0.33	0.76	0.04	0.09	0-70	-	Good
ACETALDEHYDE (1000) 191C	2.21	2.41	0.23	0.35	0.38	2.62	2.62	0.59	2	0.35	0.08	0-1000	-	Close to DL
CH4 (250) 191C (10F2)	4.83	1.19	0.05	0.26	0.7	3.14	3.14	0.06	0.8	0.01	0.02	0-250	-	Good
PROPANE (100) 191C	1.2	0.74	0.42	0.12	0.14	0.88	0.88	0.72	0.72	0.3	0.14	0-100	-	Close to DL
HBR (100) 180C	-0.02	4.99	0.17	0.68	1.39	10.15	10.15	0.19	4.34	0.02	0.06	0-100	-	Close to DL
NO2 (150) 191C (10F2)	-0.09	0.34	0.04	0.02	0.03	0.35	0.35	0.05	0.31	0.01	0.01	0-150	-	Close to DL
NO2 (2000) 191C (20F2)	-0.1	4.94	2.03	0.88	1.12	6.29	6.29	3.81	4.09	1.78	0.68	0-2000	-	Close to DL
N2O (100,200,300) 191C	0.33	0.17	0.05	0.04	0.05	0.2	0.2	0.07	0.13	0.02	0.02	0-300	-	Close to DL
NH3 (3000) 191C (20F2)	1.62	12.96	0.35	1.19	2.25	24.45	24.45	0.44	11.94	0.09	0.12	0-3000	-	Close to DL
CH4 (3000) 191C (20F2)	4.36	7.55	0.34	1.1	1.81	12.43	12.43	0.61	6.36	0.27	0.11	0-3000	-	Check it!
ACETYLENE (1000) 191C	0.54	1.9	0.15	0.31	0.37	2.3	2.3	0.21	1.6	0.06	0.05	0-1000	-	Close to DL
PROPYLENE (200,1000) 191C	1.51	4.33	0.19	0.43	0.5	5.08	5.08	0.49	3.87	0.3	0.06	0-1000	-	Close to DL
COS (100) 150C	0.61	0.17	0.02	0.02	0.02	0.23	0.23	0.02	0.14	0	0.01	0-100	-	Check it!
ETHANE (500) 191C	1.24	1.21	0.32	0.2	0.22	1.36	1.36	0.54	0.99	0.22	0.11	0-500	-	Close to DL
H2SO4 (50) 150C	0.02	0.15	0.04	0.05	0.05	0.17	0.17	0.29	0.29	0.25	0.01	0-50	-	Close to DL
MEOH (10) 191C	0.78	0.47	0.14	0.14	0.16	0.54	0.54	0.17	0.33	0.03	0.05	0-10	-	Close to DL
SO3 (150) 191C	-3.51	0.38	0.7	0.03	0.04	0.41	0.41	1.14	1.14	0.44	0.23	0-150	-	Close to DL



Cal Spectra	Temp (C)	Pres (atm)	Conc (ppm-m)	Actual	Calc'd
HCN (200) PCA 191C (9.86ppm, 5.11	191.209	0.977	50.385	50.338	58.224
HCN (200) PCA 191C (14.79ppm, 5.11	191.194	0.977	75.577	75.505	82.698
HCN (200) PCA 191C (19.72ppm, 5.11	191.202	0.977	100.769	100.670	109.924
HCN (200) PCA 191C (19.87ppm, 5.11	191.196	0.978	101.536	101.566	110.865
HCN (200) PCA 191C (24.65ppm, 5.11	191.204	0.977	125.962	125.832	138.998
HCN (200) PCA 191C (29.58ppm, 5.11	191.209	0.977	151.154	150.999	165.056
HCN (200) PCA 191C (34.51ppm, 5.11	191.225	0.977	176.346	176.168	193.807
HCN (200) PCA 191C (39.44ppm, 5.11	191.217	0.977	201.538	201.349	218.561
HCN (200) PCA 191C (39.74ppm, 5.11	191.194	0.978	203.071	203.055	221.567
HCN (200) PCA 191C (44.37ppm, 5.11	191.203	0.977	226.731	226.500	246.999
HCN (200) PCA 191C (49.30ppm, 5.11	191.199	0.977	251.923	251.691	274.819
HCN (200) PCA 191C (59.61ppm, 5.11	191.221	0.978	304.607	304.577	328.275
HCN (200) PCA 191C (79.48ppm, 5.11	191.195	0.977	406.143	405.954	437.656
HCN (200) PCA 191C (99.35ppm, 5.11	191.258	0.977	507.679	507.181	537.974
HCN (200) PCA 191C (119.22ppm, 5.11	191.209	0.977	609.214	608.643	634.405
HCN (200) PCA 191C (139.09ppm, 5.11	191.246	0.977	710.750	709.953	733.320
HCN (200) PCA 191C (158.96ppm, 5.11	191.263	0.977	812.286	811.364	836.755
HCN (200) PCA 191C (178.83ppm, 5.11	191.221	0.977	913.821	913.339	928.309
HCN (200) PCA 191C (198.70ppm, 5.11	191.202	0.978	1015.357	1015.357	1015.357


Interpolation Quadratic

☒ Force Through Zero


Min % Residuals ☐ Excl. Zero ☐ Quant w/ Highest

Spectral Regions
Region 00 - 3250.25 to 3411.52 cm-1
Region 01 - 593.01 to 840.34 cm-1
Region 02 - 1295.95 to 1518.21 cm-1
Region 03 - 2496.93 to 2901.43 cm-1
Region 04 - 3172.38 to 3250.01 cm-1
Region 05 - 3881.35 to 4113.97 cm-1


NAME	SPAN	MUTATIONS	OFFICE	JO0000
Lo Alarm	NaN	NaN	Span	Office
Hi Alarm	NaN	NaN	Mutations	FALSE

[illegible]

```
Span : Offs. : J00000
Mutations : FALSE
```

[illegible]

00000

[illegible]

Appendix F

Test Participants

Scott Steinsberger

Project Manager and FTIR Operator

Lee Harris

Sample Recovery Technician

Gage Mayer

Sampling Technician

Antonio Pineda

Buzzi Plant Contact

Appendix G

RTR Sampling and Analytical Protocol



DEECO Inc.
3404 Lake Woodard Road
Raleigh, NC 27604
(919) 250-0285 (ph); (919) 250-1835 (Fax)

www.deeco.com

**PROTOCOL TO PERFORM A SAMPLING
AND ANALYTICAL TESTING PROGRAM
AS PART OF
THE US EPA RISK AND TECHNOLOGY REVIEW
at
Buzzi Unicem USA, Inc.
Maryneal Cement Plant
202 CR 306
Maryneal, TX 79535**

**Submitted By:
DEECO, INC.
3404 Lake Woodard Road
Raleigh, NC 27604**

October 10, 2023

Copy # 1

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION	1-1
1.1 SUMMARY OF TEST PROGRAM.....	1-1
1.2 PLANT NAME, ADDRESS, AND CONTACT.....	1-1
1.3 PROCESS OF INTEREST.	1-1
1.4 AIR POLLUTION CONTROL EQUIPMENT.	1-1
1.5 EMISSION POINTS AND SAMPLING LOCATIONS.....	1-2
1.6 POLLUTANTS TO BE MEASURED.....	1-2
1.7 EXPECTED TEST DATES.....	1-2
1.8 TEST PROGRAM ORGANIZATION.	1-2
2.0 SOURCE DESCRIPTION	2-1
2.1 PROCESS DESCRIPTION.....	2-1
2.2 CONTROL EQUIPMENT DESCRIPTION.	2-1
3.0 TEST PROGRAM.	3-1
3.1 OBJECTIVES.	3-1
3.2 TEST MATRIX.....	3-1
3.3 TEST COORDINATION.....	3-2
4.0 SAMPLING LOCATION DESCRIPTIONS.	4-1
4.1 SAMPLING LOCATION DESCRIPTION.....	4-1
5.0 SAMPLING AND ANALYTICAL PROCEDURES.....	5-1
5.1 TEST METHODS.	5-1
5.1.1 SAMPLING POINT DETERMINATION - EPA METHOD 1.....	5-1
5.1.2 FLUE GAS VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2.....	5-1
5.1.3 OUTLET FLUE GAS COMPOSITION - EPA METHOD 3A.....	5-1
5.1.3.1 Calibration Gases.	5-2
5.1.3.2 Sampling Procedures.	5-2
5.1.4 FLUE GAS MOISTURE CONTENT - EPA METHOD 4.	5-3
5.1.5 HYDROGEN FLUORIDE AND DIATOMIC CHLORINE - EPA METHOD 26A.....	5-3
5.1.6 HYDROGEN CYANIDE AND HYDROGEN FLUORIDE - EPA METHOD 320.	5-5
5.1.6.1 Laboratory QA/QC Activities Before Field Test Program.	5-6
5.1.6.2 QA/QC Activities During Field Test Program.	5-6

TABLE OF CONTENTS (continued)

6.0	QUALITY ASSURANCE/QUALITY CONTROL ACTIVITIES	6-1
6.1	QA/QC PROCEDURES.	6-1
6.2	SAMPLE IDENTIFICATION AND CUSTODY.	6-2
7.0	SAMPLE CUSTODY.	7-1
7.1	FIELD SAMPLING OPERATIONS.	7-1
7.2	ANALYTICAL OPERATIONS.	7-1
8.0	INTERNAL QUALITY CONTROL CHECKS.	8-1
8.1	EQUIPMENT INSPECTION AND MAINTENANCE.	8-1
8.2	EQUIPMENT CALIBRATION.	8-1
8.3	SAMPLING QUALITY CONTROL PROCEDURES.	8-3
8.4	ANALYTICAL QUALITY CONTROL PROCEDURES.	8-5
9.0	REPORTING AND DATA REDUCTION REQUIREMENTS	9-1
9.1	DATA REPORTING.	9-1
9.2	REPORT CONTENTS.	9-1
9.3	DATA REDUCTION.	9-1
9.4	DATA VALIDATION.	9-1
10.0	PLANT ENTRY AND SAFETY.	10-1
10.1	SAFETY RESPONSIBILITIES.	10-1
10.2	SAFETY PROGRAM.	10-1
10.3	SAFETY REQUIREMENTS.	10-1

LIST OF TABLES

<u>Table</u>	<u>Page</u>
TABLE 3-1	PROGRAM OUTLINE AND TENTATIVE TEST SCHEDULE FOR BUZZI UNICEM USA, INC, MARYNEAL TX
TABLE 6-1	QA/QC PROCEDURES AND REQUIREMENTS.

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
Figure 1.1	Organizational Chart.
Figure 2.1	Maryneal Process Schematic.
Figure 4.1	Schematic of Kiln Stack Sampling Location.

1.0 INTRODUCTION

1.1 SUMMARY OF TEST PROGRAM

The United States Environmental Protection Agency (US EPA) has directed the portland cement industry (SIC 3241) to conduct emissions testing as part of the US EPA Risk and Technology Review (RTR). This document provides the overall test program approach and specifies minimum sample collection procedures, data quality objectives, and quality assurance/quality control measures to be used by the source testing firms selected by the cement companies performing tests. The test program is designed to be a comprehensive and robust test of each facility. The quality assurance and quality control (QA/QC) measures are designed to produce standardized data having known precision and accuracy. Collection of accurate, representative, and standardized data for facilities with low emissions is necessary especially in view of MACT standard setting procedures.

Cement kiln pyro-processing systems located throughout the US are included in the RTR request. Individual facilities have a wide range of kiln system configurations and air pollution control (APC) trains. Site-specific considerations will be required to capture emissions profiles for the target analytes that represent the extent of control or possible emissions increases from these controls.

1.2 PLANT NAME, ADDRESS, AND CONTACT

Buzzi Unicem USA, Inc.
Maryneal Cement Plant
202 CR 306
Maryneal, TX 79535

Antonio Pineda
Office: 610-882-5038
Mobile: 610-704-3592
E-Mail Antonio.Pineda@buzziunicemusa.com

1.3 PROCESS OF INTEREST

Maryneal is a 1.1 million ton per year rated cement pyro-processing system. The plant operates one dry-process rotary kiln (Kiln #4) that has a preheater/precalciner (PH/PC). It consists of a ThyssenKrupp Industrial Solution PREPOL AS Calciner. An in-line raw mill provides kiln feed to the system. The gases from the kiln process exhaust out of a main kiln stack.

1.4 AIR POLLUTION CONTROL EQUIPMENT

The Maryneal facility kiln has a Selective Non-Catalytic Reduction System (SNCR) for NO_x control, a Dry Sorbent Injection (DSI) system for acid gas control, and a baghouse to control particulate matter (PM).

1.5 EMISSION POINTS AND SAMPLING LOCATIONS

The Kiln Stack will be the only location sampled for the RTR program. Details of this sampling location are provided in Section 4.

1.6 POLLUTANTS TO BE MEASURED

Emission testing will be conducted for hydrogen cyanide (HCN), hydrogen fluoride (HF), and diatomic chlorine (Cl₂). Concurrent measurements to determine volumetric flow rate will be made. The sampling and analytical procedures to be followed are discussed in detail in Section 5.

1.7 EXPECTED TEST DATES

The test is currently scheduled for the week of November 27, 2023. A detailed test schedule is provided in Table 3-1.

1.8 TEST PROGRAM ORGANIZATION

The test program organizational chart is presented in Figure 1.1.




Figure 1.1 Organizational Chart

2.0 SOURCE DESCRIPTION

2.1 PROCESS DESCRIPTION

Buzzi Unicem's Maryneal plant operates one dry-process, rotary kiln with a preheater/precalciner (PH/PC) to produce portland cement at their facility in Maryneal, TX.

Kiln feed is introduced at the top of the kiln's preheater tower, while fuel is introduced at the burning zone or discharge end of the rotary kiln. Fuel is also introduced at the calciner burner located toward the bottom of the preheater tower. Natural gas and petroleum coke are used as the fuels in the production process. Exhaust gases from the kiln are drafted into a common duct with an induced-draft fan and ultimately vent to a baghouse.

The raw mill at the facility is an in-line mill (as defined in 40 CFR 63.1341) since a portion of the exhaust gases from the kiln system is used for processing raw materials in the mill. In the mill, raw materials are combined and ground. Kiln exhaust gas is used to dry the materials during grinding, which provides for greater fuel efficiency in the kiln system. Prepared feed is can either be stored in silos or directly fed to the kiln system.

In addition to the main baghouse and stack, exhaust gases from the clinker cooling process vent to three clinker cooler baghouses. Two of the clinker cooler baghouses vent to a combined common stack and the other to a single exhaust stack.

Stack gases from the kiln system are mainly composed of combustion products, carbon dioxide from calcination, excess air, and particulate matter. To remove the PM, exhaust gases from the kiln are routed through a fabric filter dust collector (i.e., the main baghouse. Once cleaned, the exhaust gases from the baghouse discharge to the atmosphere through a single exhaust stack.

2.2 CONTROL EQUIPMENT DESCRIPTION

Airflows from the kiln are routed through a fabric filter dust collection (i.e., the main baghouse). Once cleaned, the exhaust gases from the baghouse discharge to the atmosphere through a single exhaust stack. The system uses lime injection and SNCR for additional emissions control.

A schematic of the Maryneal process, including control equipment is shown below in Figure 2.1.




Figure 2.1 Maryneal Process Schematic

3.0 TEST PROGRAM

3.1 OBJECTIVES

An air emissions sampling and analytical program will be conducted on the Kiln Stack at the Buzzi Unicem USA Inc. cement facility located in Maryneal TX. All testing will be performed following accepted EPA methodology. The test program is to provide a standardized data set to the EPA and the cement industry so that reliable facility inter-comparisons of emissions can be made.

All testing will be performed in strict accordance with specifications stipulated in 40 CFR 60, Appendix A for flow rate following EPA Method 1, 2, 3A, and 4 and hydrogen fluoride (HF) and diatomic chlorine (Cl₂) following EPA Method 26A and in 40 CFR 63, Appendix A for hydrogen cyanide (HCN) and (HF) following EPA Method 320. All sampling runs will be one hour long.

Testing will be conducted under representative process and control system operating conditions. This facility has an inline raw mill and testing will be performed while operating in the "Mill On" and "Mill Off" conditions.

3.2 TEST MATRIX

Table 3-1 presents the sampling and analytical matrix and proposed test schedule.

TABLE 3-1 PROGRAM OUTLINE AND TENTATIVE TEST SCHEDULE FOR BUZZI UNICEM USA, INC, MARYNEAL TX

Sampling Location	No. of runs	Sample/Type Pollutant	Sampling Method	Sample Run Times (min)	Analytical Method	Analytical Laboratory
Day 1						
Stack	Arrive on-site and set up test equipment					
Day 2 (Raw Mill On or Off, depending on production)						
Stack	3	O ₂ /CO ₂	EPA Method 3A	60	Paramagnetic (O ₂) NDIR (CO ₂)	DEECO
	3	HF and Cl ₂	EPA Method 26A ¹	60	Ion Chromatograph	Element One
	3	HCN and HF	EPA Method 320	60	FTIR (Method 320)	DEECO
Day 3 (Raw Mill On or Off, depending on production)						
Stack	3	O ₂ /CO ₂	EPA Method 3A	60	Paramagnetic (O ₂) NDIR (CO ₂)	DEECO
	3	HF and Cl ₂	EPA Method 26A ¹	60	Ion Chromatograph	Element One
	3	HCN and HF	EPA Method 320	60	FTIR (Method 320)	DEECO
Day 4 Contingency Day/Demobilization						

¹ Stack gas flow rate and moisture measurement may be taken from concurrent Method 26A isokinetic sampling trains.

3.3 TEST COORDINATION

Mr. Antonio Pineda, Corporate Environmental Engineer, will serve as the test coordinator and will be responsible for:

1. Scheduling the start of all testing
2. Principal contact with the agency officials concerning the tests
3. Principal contact with DEECO concerning the tests
4. Recording the process data during the testing
5. Providing copies of any field test data to the agency

If there is a temporary equipment malfunction in the middle of a test, radio contact will be made with the test crew in order to delay the test. When problems have been corrected, the test will continue from the point where it was delayed. If the malfunction or upset condition results in an extended test delay, then the affected test run(s) may be aborted and a new run(s) conducted when the malfunction has been corrected or process upset cleared. Any samples or field data from aborted runs may be discarded.


4.0 SAMPLING LOCATION DESCRIPTIONS

4.1 SAMPLING LOCATION DESCRIPTION

The measurement site for the Kiln Stack is located in a vertically-oriented round duct. The duct has an inside diameter of 141.25". The nearest upstream disturbance is a duct breaching (from the ID fan) located about 579 inches (~4.1 diameters) from the sampling ports. The nearest downstream disturbance is the stack outlet at about 1893 inches (~13.4 diameters) from the sampling ports.

This sampling location meets the minimum specifications for selection of a measurement site as outlined in EPA Method 1. Four (4) test ports are located at equidistant positions (every 90°) around the duct. A schematic of the stack sampling location is shown in Figure 4.1. Cyclonic flow checks, as described in EPA Method 1 Section 2.4, using the Type-S pitot null procedure and angle measurements will be conducted at the Kiln Stack test location.

For the Kiln Stack, a total of 24 velocity/isokinetic traverse points will be used, with six points on each of the four ports. An S-type pitot tube is used in accordance with EPA Method 2 to measure the flue gas velocity. Gas temperatures are measured using calibrated Type K thermocouples and digital readout devices. These measurements are performed in accordance with the procedures in EPA Methods 2, 5, and 26A .



Stack Diameter (D) = 141.25"

Distance to nearest upstream disturbance (A) = 579", 4.1 Duct Diameters

Distance to nearest downstream disturbance (B) = 1893", 13.4 Duct Diameters

Sampling Ports Available = 4

Ports Diameter = 6"

Length of ports L_n = 6.25"

Figure 4.1 Schematic of Kiln Stack Sampling Location

5.0 SAMPLING AND ANALYTICAL PROCEDURES

This section contains a brief description of the sampling and analytical procedures for each method that will be employed during the test program. All equipment, procedures, and quality assurance measures necessary for completion of the test program will meet or exceed the specifications of the appropriate methods. Any deviations from the methods to ensure quality representativeness of the results are also discussed.

5.1 TEST METHODS

The methods for the test program are described below, and apply to all process operating conditions (e.g. where there is an inline raw mill, testing will be performed while operating in the "Mill On" and "Mill Off" conditions). Table 3-1 outlines expected operating conditions for this test.

5.1.1 SAMPLING POINT DETERMINATION - EPA METHOD 1

The number and location of the sampling or traverse points will be determined according to the procedures outlined in EPA Method 1. The sample location will be inspected to insure EPA Method 1 criteria is met. All points will be at least 1.0 inches from the stack wall, per Method 1.

5.1.2 FLUE GAS VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2

The flue gas velocity and volumetric flow rate will be determined according to the procedures outlined in EPA Method 2. Velocity measurements will be made using type S pitot tubes conforming to the calibration specifications outlined in EPA Method 2, Section 10.1. Each Type-S pitot tube, calibrated according to these standards, will have an assigned coefficient. Differential pressures will be measured with Magnehelic gauges of appropriate range or with fluid manometers. Effluent gas temperatures will be measured with chromel-alumel thermocouples equipped with digital readouts.

5.1.3 OUTLET FLUE GAS COMPOSITION - EPA METHOD 3A

Outlet flue gas analysis for oxygen (O₂) and carbon dioxide (CO₂) concentrations, and the calculation of percent excess air and flue gas dry molecular weight will be performed in accordance with EPA Method 3A.

To evaluate the sampling location and points for FTIR and O₂ sampling, a three-point O₂ concentration stratification test on a line passing through the centroidal area at 16.7, 50.0 and 83.3 percent of the measurement line (or for stacks is greater than 2.4 meters (7.8 ft) at 0.4, 1.2 and 2.0 meters from the stack or duct wall). The procedures in Section 8.1.2 of Method 7E will be followed, but oxygen will be used as parameter as allowed by fourth sentence in Section 8.1.2. The plant O₂ CEMS as a control. A criteria of <5% variation from combined mean for each point will be used as indication of non-stratification and allowing single point sampling at the point closest to the mean. Otherwise, sampling for equal periods at the three test points during test run will be conducted.

Per EPA Method 3A for determining molecular weight, integrated sampling will be obtain using the Method 320 sampling system described in Section 5.1.6.

A portion of the hot, wet gas sample will be sent through a condensing system to remove the stack moisture. A portion of the moisture-free gas sample will be sent to a CAI Model 200 O₂ (or equivalent) analyzer measures using the paramagnetic technique. An oxygen molecule, because of its

sp³ electron orbital distribution, has an unpaired electron and hence displays a magnetic orientation. Since other elements that display this magnetic phenomenon are not common gasses at normal temperatures, the paramagnetic measurement technique is virtually specific for oxygen. The sample gas flows through a detection cell located in a very strong magnetic field. The concentration of O₂ gas present induces a pressure differential in the detector cell. The amount of differential pressure is proportional to the concentration of O₂ gas present.

Calibration procedures will be performed in accordance with EPA methodology. Analyzers will be calibrated before and after each test and a calibration check between each test run.

The pretest calibrations will consist of the following steps:

- Internal (direct) calibration of each analyzer to adjust calibration and check linearity.
- External (through the entire sampling system) calibration to check the system bias on zero and span gases.

The post test calibration will consist of an external system bias calibration check.

The analyzer will be as calibrated using a certified zero and span (mid or high range) gas. Zero and span gases were directed to each analyzer through the appropriate plumbing, the calibration gas flow rates will be adjusted to the correct flow rate and the analyzer will be adjusted with the appropriate span pot.

After the analyzer is properly adjusted the linearity will be checked using a low and high range calibration gas. The maximum allowable limit for linearity is 2% of the analyzer range. All analyzers will be shown to be linear within these limits before proceeding..

The external calibration bias check will be performed by placing the CEM system in sampling mode and injecting a zero and span gas into the sample line at the probe exit. This check shows if there is any sampling system related bias, and also checks the integrity of the sample line.

5.1.3.1 Calibration Gases-DEECO will use EPA Protocol and/or $\pm 2\%$ NIST Traceable gases for calibration as required by the various reference methods employed in this test program. Calibration gases will be selected from previous experience with similar sources and/or from information obtained from the facility engineer prior to sampling. In some cases if the gases that are selected are out of the optimum range of operation then no significant impact of data quality is expected due to the linear nature of the analyzers that were used.

Audit gases, if available from a federal or a state agency, will be analyzed.

5.1.3.2 Sampling Procedures-At the completion of the pretest calibration routine, the CEM system will be ready for operation. No further adjustments of sample flow rates, analyzer zero or span adjustments, or other critical CEM operating parameters will be made until testing and post test calibration were complete.

Each sampling run will be one hour. At the completion for each test run, calibration gases will be used to check between test runs. A zero and the upscale calibration gas closest to the actual emission concentrations will be used for the pretest and post test calibrations.

5.1.4 FLUE GAS MOISTURE CONTENT - EPA METHOD 4

The flue gas moisture content will be determined in conjunction with the EPA Method 26A trains according to the sampling and analytical procedures outlined in EPA Method 4. (**NOTE:** In order to maintain isokinetic sampling, the sampling rate used may be required to temporarily exceed the EPA Method 4-specified maximum sampling rate of 0.75 CFM, based on observed stack gas pitot readings.) The impingers will be connected in series and will contain reagents as described below. The impingers will be contained in an ice bath in order to assure condensation of the moisture in the flue gas stream. Any moisture that is not condensed in the impingers is captured in the silica gel, therefore all moisture can be weighed and entered into moisture content calculations.

5.1.5 HYDROGEN FLUORIDE AND DIATOMIC CHLORINE - EPA METHOD 26A

Sampling and analytical procedures will be similar to those outlined in EPA Method 26A to determine primarily diatomic chlorine (Cl_2) emissions and hydrogen fluoride (HF) emissions at main stack outlet sampling locations. Duplicate simultaneous trains (a.k.a “paired trains”) for each test run will be used to determine precision.

Sample is collected through a heated glass probe, followed by a heated quartz fiber filter, where stack gas HF and Cl_2 are collected in a series of chilled impingers. The sampling train impingers will contain 50 ml of 0.1N sulfuric acid in the first impinger (optional should high moisture warrant a modified short stem), 100 ml of 0.1N sulfuric acid in the second and third, a fourth empty impinger, 100 ml of 0.1N NaOH in the fifth and sixth and 200 grams of silica gel in the last impinger. (**NOTE:** For plants with scrubbers, the optional cyclone may be used since the gas stream may be saturated with moisture.)

Sampling will be conducted isokinetically ($\pm 10\%$) with readings of flue gas parameters recorded at traverse points selected according to EPA Method 1. Leak-checks on the Method 26A sampling train will be performed before and after each sampling run and optionally for any port change. In the event that any portion of the train needed to be disassembled and reassembled (i.e., due to filter or resin changes), leak-checks are performed. The sampling train leak-checks and leakage rate (where applicable) are documented on the field test data sheet for each respective run. All leak checks will be acceptable.

The glass button hook nozzle and probe liner will be constructed of borosilicate glass or quartz. The filter holder will be constructed of borosilicate glass with a Teflon frit filter support and a sealing gasket. A heated quartz fiber filter, for sources above 210°C , or PTFE-bonded glass fiber filter will be used. The probe and filter housing will be heated to above 248°F and not exceed an upper boundary of 273°F . Probe liners and filter holders will be cleaned thoroughly prior to testing.

The Method 26A trains will be operated isokinetically for a minimum of 60 minutes and collect a minimum of 1 dry, standard cubic meter (DSCM). Pretest preparations, preliminary determinations, and leak check procedures will be those outlined in EPA Method 5.

After completion of sampling the train will be leak checked and transferred to the sample recovery trailer. All leak checks will be acceptable. The impingers will be weighed to determine moisture gain in accordance with EPA Method 4.

Sample recovery will involve quantitative recovery of the sulfuric acid impinger contents and the NaOH impinger contents into separate tare-weighted, precleaned polyethylene sample containers. The nozzle, probe, filter and filter housing will not be recovered.

The contents of sulfuric acid impingers, including the contents if any of the empty (2nd knockout or fourth) impinger will be quantitatively transferred to the tare-weighted, precleaned polyethylene sample container, followed by three rinses with deionized (DI) water of the impingers and all connecting glassware (including the connecting glassware to the first impinger) placed in the same H₂SO₄ container. The container will be labeled and weighed to determine the final sample volume. The liquid level will be marked on the sample container.

The contents NaOH impingers will be quantitatively transferred to a second tare-weighted, precleaned polyethylene sample container, followed by three rinses with DI water of the impingers and all connecting glassware placed in the same NaOH container. The container will be labeled and weighed to determine the final sample volume. The liquid level will be marked on the sample container

Sample recovery from each train will include:

1. Container No. 1 - Contents 1st knockout, H₂SO₄ impingers, and 2nd knockout and, and DI rinse of impingers and connecting glassware; and
2. Container No. 2 - Contents NaOH impingers, and DI rinse of impingers and connecting glassware.

Additional quality control consists of collecting and analyzing a field blank train for every three test runs. The blank train is to be assembled from a used train, leak checked and sit for a period equal to the sampling time (i.e, 1-hr). The blank train data will be used to determine the method detection limit for the test program target analytes (ie. The lowest number that could be detected), and compared to stack emissions.

Reagent blanks of 0.1 N H₂SO₄, 0.1N NaOH, and DI water will be collected and archived for later analysis should there be any issues with the field blank train samples

The H₂SO₄ impinger solutions will be analyzed using ion chromatography techniques for fluoride ions (F⁻) (EPA SW-9057). Duplicate analyses will be performed on the samples and a reagent blank. Precision will be demonstrated by duplicate injection of each sample, the results of each individual analysis must be within 5% of their mean to be acceptable. If the precision criteria is not met, analysis of the sample is repeated until consecutive injections meet the criteria.

The NaOH impinger solutions will be treated with sodium thiosulfate to ensure complete conversion of hypochlorous acid (HClO) to chloride ions (Cl⁻). The resulting solution will be analyzed using ion chromatography techniques for chloride ions (EPA SW-9057). Duplicate analyses will be performed on the samples and a reagent blank. Precision will be demonstrated by duplicate injection of each sample, the results of each individual analysis must be within 5% of their mean to be acceptable. If the precision criteria is not met, analysis of the sample is repeated until consecutive injections meet the criteria.

All EPA Method 26A HF/Cl₂ samples will be analyzed by Element One of Wilmington NC. Refer to Section 1, Figure 1.1 for contact information.

The relative deviation (RD) will be calculated as described in EPA Method 30B between the Cl_2 concentrations measured with the paired trains.

5.1.6 HYDROGEN CYANIDE AND HYDROGEN FLUORIDE - EPA METHOD 320

EPA Method 320 will be performed to determine emissions of concentrations of HCN and HF. Three, 1-hour sampling runs will be conducted under representative process and control system operating conditions.

The gas sample will be extracted from the stack through a glass-lined probe and filter heated to 375° F. For external calibration checks and analyte spikes, the gases will be introduced in front of the heated filter. Any excess calibration gas will be diverted through the sample probes into the source. Outflow of gas from the heated filter enclosure was transported through a Teflon sample line heated to 375° F. For this source approximately 100' of sample line will be required. The heated sample line will be connected directly to the FTIR sample cell. Using heat-traced Teflon tubing the exit of the FTIR cell will be connected to a sample pump with a heated stainless steel pump head. The pump discharge will be directed to a proprietary chiller-type gas conditioner to remove moisture prior to delivery sample gas to the O_2/CO_2 monitors.

The distribution of the gas sample to the monitors will be accomplished using a panel equipped with valves and rotometers. The gas sample was then divided and directed to the analyzers.

FTIR sample cell will be maintained at 191° C and connected to a MKS Instruments Multigas 2030 Fourier Transform Infrared Spectrometer and Detector.

The FTIR spectrometer will measure vapor phase organic or inorganic compounds which absorb energy in the mid-infrared spectral region, about 400 to 4000 cm^{-1} (25 to 2.5 μm). Continuous measurement will be made by matching sample absorbance bands with bands in reference spectra, and comparing sample band intensities with reference band intensities.

The principle limitation to FTIR spectroscopy are the presence of interfering compounds that also absorb energy in the mid-infrared spectral region. In a cement kiln stack gas matrix, water vapor (H_2O) and carbon dioxide (CO_2) are the primary interferents that must be incorporated into the identification and quantitation method.

The FTIR software performs the computation for a single compound by subtracting all the other compounds (interferants and target) from the absorbance spectra and quantifies the single compound based on the remain absorbance. The FTIR software provides a Standard Error Calculation (SEC) value that is an indication of how well the identification and quantitation has been performed. A high SEC indicates that other interferants have not been accounted for in the analysis method, and a low SEC is indicative of greater confidence measurement.

The instrument is operated with a resolution of 0.5 cm^{-1} with 4x zero filling. Beer-Norton Medium apodization is used with amplitude phase correction.

For this RTR test program, following specific QA/QC activities for EPA Method 320 will be performed and criterium met.

5.1.6.1 Laboratory QA/QC Activities Before Field Test Program- Before field testing occurs, the following QA/QC activities will be conducted;

- 1) Seven consecutive samples of dry nitrogen through the sampling system will be acquired and used to calculate the standard deviation for each of the test program target analytes multiplied by a factor of 3. These data will be considered representative of detection limits for this test program and are to be compared to the 0.5 ppm required DL;
- 2) From these seven dry nitrogen samples, the results for the Signal-to-Noise Ratio (SNR) @ 2500 cm^{-1} should be >2500, at 64 scans and the results for single beam intensity @ 2500 cm^{-1} should be >0.9; and
- 3) Upon receipt of HCN calibration gases a direct analysis will be performed to verify FTIR response agrees with tag value within 5%. Analysis results will be reported to PCA to assess need for modified reference spectra and/or change to direct analysis criterion:

5.1.6.2 QA/QC Activities During Field Test Program- During the field test program, following QA/QC activities will be performed and criterion met;

- 1) On each test day prior to any testing, an instrument background will be collected using dry nitrogen directed to the gas cell. The background will be collected with at least 128 scans;
- 2) The probe, filter, sample line and all sample system components in contact with effluent will be maintained at or above 375°F or 191°C (consistent with FTIR calibration temperature) to avoid any possible “cold spots;”
- 3) Heated sample lines will be ≤ 100 feet wherever possible, and not longer than 200 feet, without prior approval for unusual test circumstances;
- 4) A system zero with all sampling system components at operating temperature will be performed by injecting nitrogen at the sample probe and through sample filter and entire measurement system. After zero equilibration has been achieved, all measurement components will be quantified for at least 128 scans;
- 5) Ambient air will be sampled until equilibration of the measurement system has been achieved and all measurement components will be quantify for at least 128 scans;
- 6) The sample probe will be position at effluent measurement point and sampling will continue until equilibration of the measurement system has been achieved. At this point, the effluent concentrations will be quantified with two consecutive 64-scan samples as the initial native concentration for the dynamic spike;
- 7) Analyte spiking will be conducted for HCN before the first test run, and after each successive test run for a minimum of 4 spikes per test condition. (Additional spikes would be required before and after corrective action for the sampling or analysis system and/or before and after removing the sampling system from the stack.) These results will determine accuracy;
- 8) The spike gas injections will be maintained at 10% or less of total sample volume. The spike gas concentration and flow rate will be selected to approximately double the native effluent concentration, or the spike will be conducted to add 3-4 ppm to native concentration, whichever results in greater spiked concentration. Spike recovery results will be within $\pm 20\%$ of the expected value or ± 0.5 ppm, whichever is least restrictive. (Specific HCN gases will be manufactured for this test program in the range of 50-100 ppm to provide spikes in the 5-10 ppm range, or lower. An SF_6 or appropriate tracer will be used to calculate the exact spike gas dilution ratio of 10% or less;)
- 9) After the dynamic spike, nitrogen will be sent through the sampling system until all traces of spike gas are removed and lines are proven below DL for target analytes;

- 10) The nitrogen purge will be discontinued and the sampling system will be allowed to equilibrate with stack gas before starting a test run. The first two consecutive 64-scan samples of a sample run will be used for the final native concentration. Residual results for HCN and HF will be verified to be less than 0.2-0.3 ppm for data acceptance, or less than 5% of the measured value, whichever is least restrictive. Calculate the standard deviation for each of the test program target analytes for seven consecutive sample spectra from Run 1, multiplied by a factor of 3. These data will be compared to the pre-test system nitrogen standard deviation results and also included in the facility test report;
- 11) The SNR @ 2500 cm^{-1} , at 64 scans, and the results for single beam intensity @ 2500 cm^{-1} will be verified to meet the >2500 and >0.9 criterium; respectively. The analyte spiking for HCN and subsequent system nitrogen injection will be conducted after each test run. Continue sequence until at least three valid runs per test condition are completed.

6.0 QUALITY ASSURANCE/QUALITY CONTROL ACTIVITIES

6.1 QA/QC PROCEDURES

The QA/QC procedures for this RTR test program are summarized in Table 6-1.

TABLE 6-1 QA/QC PROCEDURES AND REQUIREMENTS

Target Analyte	Test Method	Detection Limit	QA/QC
HCN	EPA Method 320	0.5 ppm	Increase scans if needed to achieve detection limits. Increasing to 400 from relative 64 (gives a 2.5 S/N advantage). HCN spiking before and after each run by adding 10% or less spike to approximately double the native effluent concentration, or conduct spike to add 3-4 ppm to native concentration, whichever results in greater spiked concentration. Spike recovery results shall be within $\pm 20\%$ of the expected value or ± 0.5 ppm, whichever is least restrictive 5% pre-to-post run calibration transfer standard (CTS) requirement
HF		0.2-0.3 ppm	Rely on CTS (5%), HCN and tracer gas responses to validate HF FTIR data
Cl ₂	EPA Method 26A	~ 0.07 mg/m ³ (~0.2 ppm)	Duplicate Simultaneous Trains; Collect minimum of 1 dscm for each sample train. Acceptance criteria for paired samples: 10% Relative Deviation or 0.2 ppm absolute difference, whichever is least restrictive. Insert dry impinger between acid and base impingers
Effluent Flow Rate	EPA Methods 1-4	Not Applicable	As per M26A isokinetic testing or separately by Methods 1-3. FTIR measurements for H₂O. Wind Tunnel calibrated pitot tube having a Cp of 0.84 or less is required for all flow measurements. Compare preliminary velocity traverse measurements and sample run flow rate measurements to installed certified flow rate monitor. Investigate and resolve differences greater than 10% of average flow rate.
O ₂	EPA Method 3A	Not Applicable	Analyte concentrations corrected @ 7% O₂ Span is 10%, 15%, or 20% (for co-mingled stacks only) Acceptance criteria are 0.2% O₂ difference for analyzer calibration error, and 0.3% O₂ for system bias checks, and zero and upscale drift checks.

6.2 SAMPLE IDENTIFICATION AND CUSTODY

Sample custody procedures for this program are based on EPA recommended procedures. Since samples will be analyzed by one or more laboratories as well as in the field, the custody procedures emphasize careful documentation of sample collection and field analytical data and the use of chain of custody records for samples being transported. The procedures which will be used are discussed below.

The project manager will be responsible for ensuring that proper custody and documentation procedures are followed for the field sampling and field analytical efforts. He will be assisted in this effort by key sampling personnel involved in sampling recovery.

Samples will be collected, transported, and stored in clean containers which are constructed of materials inert to the analytical matrix such as glass jars. Only containers which allow air tight seals will be used. Amber glass jars will be employed when containers are needed to inhibit photochemical reactions.

All sampling data, including information regarding sampling times, locations, and any specific considerations associated with sample acquisition will be recorded on preformatted data sheets. All samples will be given unique, identifying alphanumeric sample codes which will serve to track samples from the field to the laboratory.

Samples will be stored for transport from the lab to the field to the lab in storage boxes constructed in a fashion which minimizes movement and thus prevents breakage of containers. For example, boxes used for transporting glass containers will have foam inserts with form-fitting cutouts. Sample transport boxes will be locked except when in use. Vans containing equipment and samples will be locked whenever they are left unattended.

A daily activity log will be maintained by the project supervisor. This will be an informal log used to record various types of information, such as minor problems which arise, sketches of sampling locations, names and phone numbers of plant contacts, daily activity summaries, etc.

This section provides information regarding the organization of the sampling and analytical program. The following details the key positions and their responsibilities. Once personnel have been assigned to these positions, their qualifications will be provided as an addendum.

The organization of the project team, including QA functions, is shown in the project organization chart (see Figure 1.1).

7.0 SAMPLE CUSTODY

Sample custody procedures for this program are based on EPA recommended procedures. Since samples will be analyzed by one or more laboratories as well as in the field, the custody procedures emphasize careful documentation of sample collection and field analytical data and the use of chain of custody records for samples being transported. The procedures which will be used are discussed below.

7.1 FIELD SAMPLING OPERATIONS

The project manager will be responsible for ensuring that proper custody and documentation procedures are followed for the field sampling and field analytical efforts. He will be assisted in this effort by key sampling personnel involved in sampling recovery.

Samples will be collected, transported, and stored in clean containers which are constructed of materials inert to the analytical matrix such as glass jars. Only containers which allow air tight seals will be used. Amber glass jars will be employed when containers are needed to inhibit photochemical reactions.

All sampling data, including information regarding sampling times, locations, and any specific considerations associated with sample acquisition will be recorded on preformatted data sheets. All samples will be given unique, identifying alphanumeric sample codes which will serve to track samples from the field to the laboratory.

Samples will be stored for transport from the lab to the field to the lab in storage boxes constructed in a fashion which minimizes movement and thus prevents breakage of containers. For example, boxes used for transporting glass containers will have foam inserts with form-fitting cutouts. Sample transport boxes will be locked except when in use. Vans containing equipment and samples will be locked whenever they are left unattended.

A daily activity log will be maintained by the project supervisor. This will be an informal log used to record various types of information, such as minor problems which arise, sketches of sampling locations, names and phone numbers of plant contacts. daily activity summaries, etc.

7.2 ANALYTICAL OPERATIONS

Analytical operations will be performed on-site in the laboratory as well as in the remote laboratories. Samples analyzed by outside laboratories are transported with a Change of Custody form. This form will list sample identifications, analytical parameters, sample matrices, anticipated date of results, and other relevant information necessary to ensure the appropriate analyses are performed and to document the progress of the samples.

8.0 INTERNAL QUALITY CONTROL CHECKS

Specific quality control (QC) procedures will be followed to ensure the continuous production of useful and valid data throughout the course of this test program. The QC checks and procedures described in this section represent an integral part of the overall sampling and analytical scheme. Strict adherence to prescribed procedures is quite often the most applicable QC check. A discussion of both the sampling and analytical QC checks that will be utilized during this program is presented below.

8.1 EQUIPMENT INSPECTION AND MAINTENANCE

Each item of field test equipment will be assigned a unique, permanent identification number. An effective preventative maintenance program is necessary to ensure data quality. Each item of equipment returning from the field will be inspected before it is returned to storage. During the course of these inspections, items are cleaned, repaired, reconditioned, and recalibrated where necessary.

Each item of equipment transported to the field for this test program will be inspected again before being packed to detect equipment problems which may originate during periods of storage. This minimizes lost time on the job site due to equipment failure.

Occasional equipment failure in the field is unavoidable despite the most rigorous inspection and maintenance procedures. For this reason, replacement equipment for all critical sampling train components will be transported to the job site.

8.2 EQUIPMENT CALIBRATION

New items for which calibration is required will be calibrated before initial field use. Equipment whose calibration status may change with use or time will be inspected in the field before testing begins and again upon return from each field use. When an item of equipment is found to be out of calibration, it will be repaired and recalibrated or retired from service. All equipment will be periodically recalibrated in full, regardless of the outcome of these regular inspections.

Calibrations will be conducted in a manner, and at a frequency, which meets or exceeds U.S. EPA specifications. The calibration procedures outlined in the EPA Methods will be followed. When these methods are inapplicable, methods such as those prescribed by the American Society for Testing Materials (ASTM) will be used.

Data obtained during calibrations will be recorded on standardized forms, which will be checked for completeness and accuracy by the quality assurance manager. Data reduction and subsequent calculations will be performed using computer facilities. Calculations will be checked at least twice for accuracy. Copies of calibration forms will be included in the test or projects reports.

Emissions sampling equipment requiring calibration includes pitot tubes, pressure gauges, thermometers, dry gas meters and barometers. The following sections elaborate on the calibration procedures to be followed for these items of equipment.

- A: Pitot Tubes.** All Type S pitot tubes used, whether separate or attached to a sampling probe, will be constructed in-house or by a third-party vendor. Each new pitot will be calibrated in accordance with Section 10.1 of EPA Method 2. Each Type-S pitot tube, calibrated according to these standards, will have an assigned coefficient. This coefficient should not change as long as the pitot tube is not damaged.

Each pitot tube will be inspected visually upon return from the field. If a cursory inspection indicates damage or raises doubt that the pitot remains in accordance with the EPA geometry standards, the pitot tube will be refurbished as needed and recalibrated.

- B: Differential Pressure Gauge.** All meter consoles used are equipped with 10-inch water column (W.C.) inclined-vertical manometers. Fluid manometers do not require calibration other than leak checks. Manometers will be leak checked in the field prior to each test series, and again upon return from the field.
- C: Impinger Thermometer.** Prior to the start of testing, the thermometer used to monitor the temperature of the gas leaving the last impinger will be compared with a mercury-in-glass thermometer which meets ASTM E-1 No. 63F specifications. The impinger thermometer is adjusted if necessary until it agrees within 2°F of the reference thermometer. If the thermometer is not adjustable, it is labeled with a correction factor.
- D: Dry Gas Meter Thermometer.** The thermometer used to measure the temperature of the metered gas sample will be checked prior to each field trip against an ASTM mercury-in-glass thermometer. The dry gas meter thermometer is acceptable if the values agree within $\pm 5.4^{\circ}\text{F}$. Thermometers not meeting this requirements will be adjusted or labeled with a correction factor.
- E: Flue Gas Temperature Sensor.** All thermocouples employed for the measurement of flue gas temperature are calibrated upon receipt. Initial calibrations will be performed at three points (ice bath, boiling water, and hot oil). An ASTM mercury-in-glass thermometer will be used as a reference. The thermocouple is acceptable if the agreement is within 1.5 percent (absolute) at each of the three calibration points.

Before and after each field use, the reading from the flue gas thermocouple-potentiometer combination will be compared with an ASTM mercury-in-glass reference thermometer at ambient conditions. If the two agree within ± 1.5 percent (absolute), the thermocouple and potentiometer are considered to be in proper working order.

- F: Dry Gas Meter and Orifice.** Two procedures will be used to calibrate the dry gas meter and orifice simultaneously. The full calibration will be a complete laboratory procedure used to obtain the calibration factor of the dry gas meter. Full calibrations will be performed over a wide range of orifice settings. A simpler procedure, the post-test calibration, will be designed to check whether the calibration factor has changed.

A dry gas meter that is calibrated annually against a spirometer or a set of calibrated critical orifices will be used as a transfer standard. During the annual calibration, triplicate calibration runs will be performed at seven flow rates ranging from 0.25 to 1.40 cfm.

- G: Dry Gas Meter.** Each metering system receives a full calibration at the time of purchase and a post-test calibration after each field use. If the calibration factor, γ , deviates by less than five percent from the initial value, the test data are acceptable.

If γ deviates by more than 5 percent, the meter is recalibrated and the meter coefficient (initial or recalibrated) that yields the lowest sample volume for the test runs is used.

EPA Method 5 requires another full calibration anytime the post-test calibration check indicates that γ changed by more than 5 percent. Standard practice is to adjust and recalibrate the dry gas meter anytime γ is found to be outside the range of 0.96 to 1.04. Post-test calibrations will be performed after each field test series per EPA Method 5, section 16.3 procedures.

- H: Orifice.** An orifice calibration factor will be calculated for each flow setting during a full calibration. If the range of values does not vary by more than 0.20 in H_2O over a range of 0.4 to 4.0 in H_2O , the arithmetic average of the values obtained during the calibration is used.
- I: Barometer.** Each field barometer will be adjusted before each test series to agree within ± 0.1 inches of a reference aneroid barometer. The reference barometer will be checked against the station pressure value (corrected for elevation difference) reported by the National Weather Service.

8.3 SAMPLING QUALITY CONTROL PROCEDURES

The following pretest QC checks will be conducted:

- All sampling equipment will be thoroughly checked to ensure clean and operable components.
- Equipment will be inspected for possible damage from shipment.
- The oil manometer or Magnehelic gauge used to measure pressure across the Type S pitot tube will be leveled and zeroed.
- The number and location of the sampling traverse points will be checked before taking measurements.
- The temperature measurement system will be visually checked for damage and operability by measuring the ambient temperature prior to each traverse.

In addition to the general QC procedures listed above, QC procedures specific to each sampling method will also be incorporated into the sampling scheme. These methods and specific procedures are discussed below.

A: Sampling Train QC checks. The following QC procedures will be emphasized:

Prior to Start of Tests

- Keep all cleaned glassware and sample train components sealed until train assembly.
- Assemble the sampling trains in an environment free from uncontrolled dust.
- Visually inspect each sampling train for proper assembly.
- Perform pretest calculations to determine the proper sampling nozzle size.

Prior to Each Test Run

- Visually inspect the sampling nozzle.
- Visually inspect the Type S pitot tube.
- Leak check each leg of the Type S pitot tube.
- Leak check the entire sampling train.

During Each Test Run

- Readings of temperature and differential pressure will be taken at each transverse point.
- All sampling data and calculations will be recorded on preformatted data sheets.
- All calibration data forms will be reviewed for completeness and accuracy.
- Any unusual occurrences will be noted during each run on the appropriate data form.
- The project supervisor will review sampling data sheets daily during testing.
- Properly maintain the roll and pitch axis of the Type S pitot tube and the sampling nozzle.
- Leak check the train before and after any move from one sampling port to another during a run (at DEECO's option) or if a filter change takes place.
- Conduct additional leak checks if the sampling time exceeds 4 hours.
- Maintain the probe, filter, and impingers at the proper temperatures.
- Maintain ice in the ice bath at all times.
- Make proper readings of the dry gas meter, delta P and delta H, temperature, and pump vacuum during sampling at each traverse point.
- Maintain isokinetic sampling within $\pm 10\%$ of 100%.

After Each Test Run

- Visually inspect the sampling nozzle.
- Visually inspect the Type S pitot tube.
- Leak check each leg of the Type S pitot tube.
- Leak check the entire sampling train.

B: QC for Volumetric air flow rate determinations

Flue Gas Velocity. Data required to determine the flue gas velocity will be collected using the methodology specified in EPA Method 2. Quality control procedures are as follows.

- Visually inspect the Type S pitot tube before and after sampling.
- Leak check both legs of the pitot tube before and after sampling.
- Check the number and location of the sampling traverse points before taking measurements.

Flue Gas Molecular Weight. In the event that that integrated bag samples are to be used for determination of flue gas molecular weight, EPA Method 3 will be the sampling technique specified. Quality control will focus on the following procedures:

- The sampling train will be leak checked before and after each run.
- A constant sampling rate will be used in withdrawing a sample.
- The sampling train will be purged prior to sample collection.
- The sampling port will be properly sealed to prevent air in-leakage.

Moisture Content. The moisture content of the gas stream will be determined using the technique specified in EPA Method 4. The following QC checks will be performed:

- The sampling train will be leak checked before and after each run.
- Ice will be maintained in the ice bath throughout each run to insure an exit temperature (after the silica gel impinger) of $\leq 67^{\circ}\text{F}$.

8.4 ANALYTICAL QUALITY CONTROL PROCEDURES

All analyses for this program will be performed using accepted laboratory procedures in accordance with the specified analytical protocols. Adherence to prescribed QC procedures will ensure data of consistent and measurable quality. Analytical QC will focus upon the use of control standards to provide a measure of analytical precision and accuracy. Also, specific acceptance criteria are defined for various analytical operations including calibrations, control standard analyses, drift checks, blanks, etc. The following general QC procedures will be incorporated into the analytical effort:

- The on-site project manager will review all analytical data and QC data on a daily basis for completeness and acceptability.
- Analytical QC data will be tabulated using the appropriate charts and forms on a daily basis
- Copies of the QC data tabulation will be submitted to the quality assurance manager following the completion of the test program.
- All hard copy raw data (i.e., chromatograms, computer printouts, etc.) will be maintained in organized files.

Specific analytical QC procedures for the Orsat analyzer (if used) are listed below.

- The analyzer will be leveled and the fluid levels zeroed prior to use.
- The analyzer will be leak checked prior to use.
- The analyzer will be thoroughly purged with sample prior to use.
- The analyzer will be checked by analyzing an ambient air sample.

EPA Method 26A Sample Analysis QC Checks are listed below.

- Calibration curve consisting of 4 calibration levels that bracket the expected sample range. Dilute samples as necessary to reach the calibration range;
- Duplicate analysis of calibration standards, before and after sample analysis, with duplicate injections being within 5% of their mean;
- Duplicate analysis of reagent blanks, quality control samples and field samples with duplicate injections being within 5% of their mean;
- Matrix spike samples may be prepared and analyzed. Matrix spike recoveries should be 90-110%
- A field blank will be carried through the procedure and analyzed with the field samples.
- An audit sample will be analyzed for if available from two or more independent, Approved Audit Sample Providers no less than 60 days prior to the test effort.

9.0 REPORTING AND DATA REDUCTION REQUIREMENTS

9.1 DATA REPORTING

The reporting units for HCN, HF, and Cl₂ will be in parts-per-million by volume, wet basis (ppm_{v,d}), parts-per-million by volume, dry corrected to 7% oxygen (ppm_{v,d}@7%O₂), pounds-per-hour (lbs/hr), and pounds-per-ton of clinker (lbs/ton). Additional supporting data for CO₂, O₂, and H₂O concentrations and volumetric flow rates (actual cubic feet-per-minute, wet, standard cubic feet-per-minute, and dry, standard cubic feet-per-minute) will be reported. The clinker production, in short tons-per-hour (TPH) will be reported.

Any data that is not acceptable because of technical difficulties will be indicated, and an explanation of the technical problem will be given. All related QC and calibration data will be in the final report.

9.2 REPORT CONTENTS

Copies of the test report will be submitted after the test series has been completed. Results reported will include, but not be limited to emission rates and concentrations of gaseous pollutants, and process sample determinations, any liquid stream constituents determinations, and any other type of data requested. This report will also include a list of all personnel present during testing, summary results, descriptions of test procedures used, a description of the source and its operation during testing, test locations drawings, example calculations, raw field data, and equipment calibrations.

9.3 DATA REDUCTION

Care will be exercised to ensure hand recorded data is written accurately and legibly. Additionally, the use of prepared data recording forms, conveniently formatted, is an important aid to verify that all necessary data items are recorded. The collected field and laboratory data will be reviewed by the analyst and the Project Manager.

The Project Manager will reduce and validate all of the sampling and analytical data that is collected. The sampling data will include flow measurements, calibrations, etc. Each laboratory will reduce all analytical results prior to their submission to the Project Manager. The analytical data will be used to determine concentrations and emission rates of the compounds of interest.

Data reduction follows guidelines published in EPA Reference Methods, where applicable, and by guideline documents where EPA Reference Methods are not available. Validated computer programs will be used to calculate all reported values.

9.4 DATA VALIDATION

A second technical review of the data will be performed and documented by a qualified scientist other than the one who performed the actual analyses. The second reviewer will include evidence (e.g., check marks, recalculations, etc.) that show which data points were checked. Finally, the second reviewer will sign and date the cover page of the data packet or the record that was reviewed.

In-situ measurements will be validated by demonstrated acceptable post-test leak checks and calibration verifications according to the referenced method used.

Analysis data may be validated according to defined criteria by a secondary reviewer or by the analyst. At a minimum and if applicable, analysis data will be validated according to the following criteria (additional method-specific criteria or project requirements may apply):

- Sampling records complete and traceable
- All appropriate QC samples included with the analytical batch and reported with the sample results
- Routine tuning, calibration and inspection of analytical instrumentation documented and performed prior to analyses
- Initial and continuing calibration criteria met
- Method/reagent blanks confirm no background contamination
- Surrogate recoveries within criteria
- Qualitative sample results (e.g., retention times, mass spectra, isotopic ratios) consistent with standard data
- Sample data within the calibrated range of the instrument
- Chromatograms or other raw data consistent with computer-generated quantitation reports
- Accuracy of intermediate data manipulations, transcribed numbers and/or final reported results verified
- Reference standards, instrumentation, sample identification, analysts, methodology, and sequence of processing clearly identified and traceable in the project records
- Lost data or corrective actions documented (e.g., loss of sample, reanalysis, redilutions, additional cleanup steps, alternative calculations etc.)
- Data that does not meet the validation requirements flagged accordingly
- Data reported in the correct units (e.g., "ppm" should not be used without specifying volume or mass units; "ug/g" are preferred units for data reporting)

10.0 PLANT ENTRY AND SAFETY

10.1 SAFETY RESPONSIBILITIES

The Project Manager is responsible for ensuring compliance with plant entry, health, and safety requirements. The Facility Contact (refer to Section 1.2) as the authority to impose or waive facility restrictions. The Project Manager has the authority to negotiate with facility person any deviations from the facility restrictions.

10.2 SAFETY PROGRAM

DEECO has a comprehensive health and safety program that satisfies Federal OSHA and MSHA requirements. The basic elements include: (1) written policies and procedures, (2) routine training of employees and supervisors, (3) medical monitoring, (4) use of personal protection equipment, (5) hazard communication, (6) pre-mobilization meetings with Holcim personnel and DEECO test team personnel, and (7) routine surveillance of the on-going test work.

10.3 SAFETY REQUIREMENTS

All test personnel will adhere to the following standard safety and precautionary measures as follows:

- 1) Confine activities to test area only;
- 2) Wear hard hats at all times on-site, except inside sample recovery trailers and mobile CEM laboratory;
- 3) Wear protective shoes or boots in test area;
- 4) Wear protective glasses or goggles at the outlet test sites, and other areas as designated;
- 5) Have readily available first aid equipment and fire extinguishers.

Before or on the first day on-site, the Project Manager will fill out the Emergency Response Procedure form and provide copies to be posted at each test site.