



DEECO Inc.
3404 Lake Woodard Road
Raleigh, NC 27604
(919) 250-0285 (ph); (919) 250-1835 (Fax)

www.deeco.com

REPORT NO: 021824-3328

PROJECT: 24-3328

DATE: February 20, 2024

TYPE: **Emission Test Report**

**Hydrogen Cyanide, Hydrogen Fluoride
and Diatomic Chlorine
from
a Portland Cement Plant**

**Holcim (US) Inc.
Theodore Facility
3051 Hamilton Blvd
Theodore, AL 36582**

AUTHOR: Scott Steinsberger, Ph.D.

TEST DATE: February 1, 2024

FIELD TEAM: Lee Harris, Michael Powell, Jeremy Rothenberg, and Scott Steinsberger

PREPARED FOR: Holcim (US) Inc.
Theodore Facility
3051 Hamilton Blvd
Theodore, AL 36582

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1. INTRODUCTION.....	1
2. SUMMARY OF RESULTS.....	5
3. SAMPLING AND ANALYTICAL PROCEDURES.....	7
3.1 Sampling Point Determination - EPA Method 1.....	7
3.2 Flue Gas Velocity and Volumetric Flow Rate - EPA Method 2.....	9
3.3 Outlet Flue Gas Composition - EPA Method 3A.....	9
3.3.1 Calibration Gases.....	10
3.3.2 Sampling Procedures.....	10
3.4 Flue Gas Moisture Content - EPA Method 4.....	10
3.5 Hydrogen Fluoride and Diatomic Chlorine - EPA Method 26A.....	11
3.6 Hydrogen Cyanide and Hydrogen Fluoride - EPA Method 320	
.....	14
3.6.1 Laboratory QA/QC Activities Before Field Test Program.....	15
3.6.2 QA/QC Activities During Field Test Program.....	15
4. QA/QC PROCEDURES AND RESULTS.....	19
4.1 Sampling Equipment.....	19
4.1.1 Manual Sampling Equipment Calibrations.....	19
4.2 Analytical QA/QC Results.....	20
Appendix A - Emission Summary Tables	
Appendix B - Field Data and CEM/FTIR Data	
Appendix C - Ion Chromatography Analytical Report Data	
Appendix D - Plant Process Data	
Appendix E - Calibration Documents	
Appendix F - Test Participants	
Appendix G - RTR Sampling and Analytical Protocol	

LIST OF TABLES

<u>Table No.</u>		<u>Page</u>
TABLE 1.1	SUMMARY OF HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; HOLCIM INC., THEODORE, AL FACILITY; MAIN KILN STACK; FEBRUARY 1, 2024.	2
TABLE 1.2	SUMMARY OF SAMPLING AND ANALYTICAL PROTOCOLS HOLCIM INC., THEODORE , AL FACILITY.....	4
TABLE 2.1	HOLCIM INC., THEODORE, AL FACILITY; KILN MAIN STACK HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; FEBRUARY 1, 2024.....	6
TABLE 3.1	PAIRED METHOD 26A SAMPLING TRAIN DIATOMIC CHLORINE CONCENTRATION COMPARISON RESULTS FOR THE KILN MAIN STACK; FEBRUARY 1, 2024.	13
TABLE 3.2	FTIR PRETEST AND FIELD TEST QA/QC SUMMARY.....	16
TABLE 3.3	ETHYLENE CALIBRATION TRANSFER STANDARD (CTS) AND HYDROGEN CYANIDE ANALYTE SPIKING TEST RESULTS FOR THE KILN MAIN STACK; FEBRUARY 1, 2024.	18

LIST OF FIGURES

<u>Figure No.</u>		<u>Page</u>
Figure 3.1	Schematic of the Kiln Main Stack Sampling Location.	8

1. INTRODUCTION

The United States Environmental Protection Agency (US EPA) has directed the portland cement industry (SIC 3241) to conduct emissions testing as part of the US EPA Risk and Technology Review (RTR). This document provides the emission test results and supporting quality assurance/quality control (QA/QC) measures used to produce standardized data having known precision and accuracy. Collection of accurate, representative, and standardized data for facilities with low emissions is necessary especially in view of MACT standard setting procedures.

The process tested at the Theodore facility operates one dry cement kiln, equipped with a preheater and a 4-stage inline precalciner. It is equipped with two, inline dryers. The kiln is fed a variety of fuels including, but not limited to, coal, pet coke, natural gas, tire-derived fuel (TDF), wood waste, non-hazardous waste solids, fuel oil and non-hazardous waste liquids. It is capable of producing up to 250 tons of clinker per hour (TPH), when operating both dryers.

The Holcim Theodore kiln uses two reverse air baghouses for air pollution control. Each reverse air baghouse has sixteen compartments with an air-to-cloth ratio of 1.35. They are rated for 800,000 actual cubic feet per minute (acfm). A selective non-catalytic reduction (SNCR) post combustion emissions control technology reduces NO_x by injecting ammonia into the process at a properly determined location. Raw materials fed to the dryers, in conjunction with a water spray system, protects the baghouses from high temperature preheater tower exhaust.

A more detailed description of the processes is provided in Section 2 of the RTR Sampling and Analytical Protocol reproduced in Appendix G.

The Holcim Inc. retained DEECO Inc. (DEECO) to conduct emission tests for for hydrogen cyanide (HCN), hydrogen fluoride (HF), and diatomic chlorine (Cl_2). All sampling runs were be one hour long. Concurrent measurements to determine volumetric flow rate were made. The Whitehall facility does not have an inline raw mill so testing was conducted under a single condition.

A summary of the test results is shown in Table 1.1.

TABLE 1.1 SUMMARY OF HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC CHLORINE EMISSIONS; HOLCIM INC., THEODORE, AL FACILITY; MAIN KILN STACK; FEBRUARY 1, 2024

Test Parameters	Main Stack
Hydrogen Cyanide (FTIR) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	2.3 1.58 0.010
Hydrogen Fluoride (FTIR) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.11 <0.059 <0.0004
Hydrogen Fluoride (Method 26A) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.56 <0.291 <0.0018
Diatomic Chlorine (Method 26A) parts-per-million, dry basis corrected to 7% O ₂ pounds-per-hour pounds-per-ton of clinker	<0.14 <0.257 <0.0016

The sampling and analytical procedures followed are summarized in Table 1.2 and discussed in detail in Section 3.

Testing was performed on the Kiln Main Stack under one condition on February 1, 2024.

Sampling was conducted by personnel from DEECO, Inc. of Raleigh, North Carolina. All questions regarding sampling and analytical data should be directed to Dr. Scott Steinsberger of DEECO at (800) 733-3261. The field sampling was completed by Lee Harris, Michael Powell, Jeremy Rothenberg, and Scott Steinsberger of DEECO.

The remainder of this document summarizes the results, procedures and quality control measures followed for this program. Section 2 contains tabulated air emission results for each parameter of interest. Section 3 summarizes the air emission sampling and analytical procedures performed by DEECO, with a brief description and/or reference to the applicable methodologies. Section 4 discusses the basic quality control elements in place for this program to assure the collection of representative, accurate air emission data.

The appendices provided in this document contain all of the necessary information to verify the reported results. Included as Appendices are: Appendix A - Emission Summary Tables; Appendix B - Field Data and CEM/FTIR Data; Appendix C - Ion Chromatography Analytical Report Data; Appendix D - Plant Process Data; Appendix E - Calibration Documents; Appendix F - Test Participants; Appendix G - RTR Sampling and Analytical Protocol

TABLE 1.2 SUMMARY OF SAMPLING AND ANALYTICAL PROTOCOLS HOLCIM INC., THEODORE, AL FACILITY

Location and Frequency	Test Parameter	Sampling Method	Sampling Procedure	Analysis Method	Analysis Procedure
Kiln Main Stack	Volumetric Flow Rate and cyclonic check	EPA Methods 1 and 2	Velocity and temperature traverses	EPA Methods 1 and 2	Manometer for differential pressure and thermocouple for temperature
	Oxygen and Carbon Dioxide and Stratification Check	EPA Method 3A	Continuous; extractive sample	EPA Method 3A	Paramagnetic for O ₂ and NDIR for CO ₂
	Moisture	EPA Method 4	Condensation	EPA Method 4	Gravimetric
	Hydrogen Fluoride and Diatomic Chlorine (Cl ₂)	EPA Method 26A	Isokinetic integrated sample	EPA Method 26A	Ion chromatography
	Hydrogen Fluoride and Hydrogen Cyanide	EPA Method 320	Continuous; extractive sample	EPA Method 320	Fourier Transform Infrared (FTIR) Spectroscopy

2. SUMMARY OF RESULTS

Emissions sampling was conducted at the Holcim Theodore AL facility. Sampling was conducted for stack gas flow rate (EPA Methods 1 and 2), stack gas oxygen and carbon dioxide (EPA Method 3A), stack gas moisture (EPA Method 4), stack gas hydrogen fluoride and diatomic chlorine (EPA Method 26A) and stack gas hydrogen cyanide and hydrogen fluoride (EPA Method 320).

Testing was conducted on the Kiln Main Stack under one condition and the results are summarized in Table 2.1.

**TABLE 2.1 HOLCIM INC., THEODORE, AL FACILITY; KILN MAIN STACK
HYDROGEN CYANIDE, HYDROGEN FLUORIDE, AND DIATOMIC
CHLORINE EMISSIONS; FEBRUARY 1, 2024**

Test Parameter	Kiln Main Stack Run 1	Kiln Main Stack Run 2	Kiln Main Stack Run 3	Kiln Main Stack Average
Time	10:26-11:35	11:56-13:05	13:18-14:27	February 1, 2024
Flow Rate (dscfm)	539,100	539,200	536,700	538,300
Oxygen	16.6%	16.7%	16.4%	16.6%
Carbon Dioxide	7.3%	7.2%	7.4%	7.3%
Moisture	7.0%	6.4%	7.2%	6.8%
Hydrogen Cyanide (FTIR)				
ppm _{dry} at 7% O ₂	2.0	2.7	2.1	2.3
pounds-per-hour	1.41	1.82	1.50	1.58
pounds-per-ton of clinker	0.009	0.011	0.009	0.010
Hydrogen Fluoride (FTIR)				
ppm _{dry} at 7% O ₂	0.11	<0.11	<0.11	<0.11
pounds-per-hour	0.061	<0.057	<0.058	<0.059
pounds-per-ton of clinker	0.0004	<0.0004	<0.0004	<0.0004
Hydrogen Fluoride (Method 26A)				
ppm _{dry} at 7% O ₂	<0.58	<0.58	<0.52	<0.30
pounds-per-hour	<0.297	<0.292	<0.279	<0.291
pounds-per-ton of clinker	<0.0019	<0.0018	<0.0017	<0.0018
Diatomic Chlorine (Method 26A)				
ppm _{dry} at 7% O ₂	0.16	<0.13	0.13	<0.14
pounds-per-hour	0.299	<0.233	0.239	<0.257
pounds-per-ton of clinker	0.0018	<0.0014	<0.0015	<0.0016

3. SAMPLING AND ANALYTICAL PROCEDURES

Table 1.2 presents a summary of the overall sampling and analytical protocols used for the test program for the Kiln Main Stack at Holcim's Theodore, AL facility. All sampling and analytical methods employed for this test program were performed in accordance with the procedures outlined in the Reference Test Methods contained in the Code of Federal Regulations, Title 40, Part 60, Appendix A (40 CFR 60, Appendix A) and 40 CFR 63, Appendix A.

3.1 Sampling Point Determination - EPA Method 1

The Kiln Main Stack is a vertically-oriented circular stack with an inside diameter of 204". The stack gas sampling ports are located 1680 inches (8.2 duct diameters) above the duct breaching and 1380 inches (6.8 duct diameters) below the stack outlet.

This sampling location meets the minimum specifications for selection of a measurement site as outlined in EPA Method 1. The number and location of the sampling or traverse points were determined according to the procedures outlined in EPA Method 1. All points were at least 1.0 inches from the stack wall, per Method 1. A twelve (12) point sampling traverse was made using three (3) point traverses in each of 4 sampling ports on two perpendicular directions. Each traverse was made at each sampling location using a type-S pitot tube in accordance with EPA Methods 2 procedures. Gas temperatures were measured using calibrated Type K thermocouples and digital readout devices. All measurements were performed in accordance with the procedures in EPA Methods 2, and 26A.

Cyclonic flow checks, as described in EPA Method 1 Section 2.4, using the Type-S pitot null procedure and angle measurements were conducted at the Kiln Main Stack test location.

A schematic of the Kiln Main Stack is provided in Figure 3.1.





Figure 3.1 Schematic of the Kiln Main Stack Sampling Location

3.2 Flue Gas Velocity and Volumetric Flow Rate - EPA Method 2

The flue gas velocity and volumetric flow rate were determined according to the procedures outlined in EPA Method 2. Velocity measurements were using type S pitot tubes conforming to the calibration specifications outlined in EPA Method 2, Section 10.1. Each Type-S pitot tube, calibrated according to these standards, had an assigned coefficient. Differential pressures were measured with fluid manometers. Effluent gas temperatures were measured with chromel-alumel thermocouples equipped with digital readouts.

3.3 Outlet Flue Gas Composition - EPA Method 3A

Outlet flue gas analysis for oxygen (O₂) and carbon dioxide (CO₂) concentrations, and the calculation of percent excess air and flue gas dry molecular weight was performed in accordance with EPA Method 3A.

To evaluate the sampling location and points for FTIR and O₂ sampling, a three-point O₂ concentration stratification test on a line passing through the centroidal area at (for stacks is greater than 2.4 meters) at 0.4, 1.2 and 2.0 meters from the stack or duct wall. The procedures in Section 8.1.2 of Method 7E were followed, using oxygen as allowed by fourth sentence in Section 8.1.2. The plant O₂ CEMS was used as a control. A criteria of <5% variation from combined mean for each point was used as indication of non-stratification to allow single point sampling at the point closest to the mean.

Per EPA Method 3A for determining molecular weight, continuous extractive sampling was obtained using the same Method 320 sampling system described in Section 3.6.

A portion of the hot, wet gas sample was sent through a condensing system to remove the stack moisture. A portion of the moisture-free gas sample was sent to an O₂/CO₂ analyzer.

Calibration procedures were performed in accordance with EPA methodology. Analyzers were calibrated before and after each test and a calibration check between each test run.

The pretest calibrations consisted of the following steps:

- Internal (direct) calibration of each analyzer to adjust calibration and check linearity.
- External (through the entire sampling system) calibration to check the system bias on zero and span gases.

The post test calibration consisted of an external system bias calibration check.

The analyzer calibrated using a certified zero and span (mid or high range) gas. Zero and span gases were directed to each analyzer through the appropriate plumbing, the calibration gas flow rates were adjusted to the correct flow rate and the analyzer was adjusted with the appropriate span pot.

After the analyzer was properly adjusted the linearity was checked using a low and high range

calibration gas. The maximum allowable limit for linearity is 2% of the analyzer range and all analyzers were shown to be linear within these limits before proceeding.

The external calibration bias check were performed by placing the CEM system in sampling mode and injecting a zero and span gas into the sample line at the probe exit. This check showed if there is any sampling system related bias, and also checks the integrity of the sample line.

3.3.1 Calibration Gases

DEECO used EPA Protocol and/or $\pm 2\%$ NIST Traceable gases for calibration as required by the various reference methods employed in this test program. Calibration gases were selected from previous experience with similar sources and/or from information obtained from the facility engineer prior to sampling. In some cases if the gases that are selected are out of the optimum range of operation then no significant impact of data quality is expected due to the linear nature of the analyzers that were used.

Specific HCN gases were manufactured for this test program in the range of 50-100 ppm to provide spikes in the 5-10 ppm range, or lower; with an SF₆ or appropriate tracer used to calculate the exact spike gas dilution ratio of 10% or less.

No audit gases from a federal or a state agency were provided.

3.3.2 Sampling Procedures

At the completion of the pretest calibration routine, the CEM system was ready for operation. No further adjustments of sample flow rates, analyzer zero or span adjustments, or other critical CEM operating parameters were made until testing and post test calibration were complete.

Each sampling run was one hour. At the completion for each test run, calibration gases were used to check between test runs. A zero and the upscale calibration gas closest to the actual emission concentrations were used for the pretest and post test calibrations.

3.4 Flue Gas Moisture Content - EPA Method 4

The flue gas moisture content was determined in conjunction with the EPA Method 26A trains according to the sampling and analytical procedures outlined in EPA Method 4. (**NOTE:** In order to maintain isokinetic sampling, the sampling rate used may have been required to temporarily exceed the EPA Method 4-specified maximum sampling rate of 0.75 CFM, based on observed stack gas pitot readings.) The impingers were connected in series and contained reagents as described below. The impingers were contained in an ice bath in order to assure condensation of the moisture in the flue gas stream. Any moisture that is not condensed in the impingers was captured in the silica gel, therefore all moisture was weighed and entered into moisture content calculations.

3.5 Hydrogen Fluoride and Diatomic Chlorine - EPA Method 26A

Sampling and analytical procedures were those outlined in EPA Method 26A to determine primarily diatomic chlorine (Cl_2) emissions and hydrogen fluoride (HF) emissions at main stack outlet sampling locations. Duplicate simultaneous trains (a.k.a “paired trains”) for each test run were used to determine precision.

Sample was collected through a heated glass probe, followed by a heated Teflon filter, where stack gas HF and Cl_2 were collected in a series of chilled impingers. The sampling train impingers contained 100 ml of 0.1N sulfuric acid in the first and second, an empty third impinger, 100 ml of 0.1N NaOH in the fourth and fifth and 200 grams of silica gel in the last impinger

Sampling was conducted isokinetically ($\pm 10\%$) with readings of flue gas parameters recorded at traverse points selected according to EPA Method 1. Leak-checks on the Method 26A sampling train were performed before and after each sampling run and optionally for any port change. The sampling train leak-checks and leakage rate (where applicable) were documented on the field test data sheet for each respective run. All leak checks were acceptable.

The glass button hook nozzle and probe liner was constructed of borosilicate glass. The filter holder was constructed of borosilicate glass with a Teflon frit filter support and a sealing gasket. A PTFE-bonded glass fiber filter was used. The probe and filter housing were heated to above 248°F and not exceed an upper boundary of 273°F . Probe liners and filter holders were cleaned thoroughly prior to testing.

The Method 26A trains was operated isokinetically for a minimum of 60 minutes and collected a minimum of 1 dry, standard cubic meter (DSCM). Pretest preparations, preliminary determinations, and leak check procedures were those outlined in EPA Method 5.

After completion of sampling the train was leak checked and transferred to the sample recovery trailer. All leak checks were acceptable. The impingers were weighed to determine moisture gain in accordance with EPA Method 4.

Sample recovery involved quantitative recovery of the sulfuric acid impinger contents and the NaOH impinger contents into separate tare-weighted, precleaned polyethylene sample containers.

The nozzle, probe, filter and filter housing were not recovered.

The contents of sulfuric acid impingers, including the contents if any of the empty (2nd knockout or third) impinger were quantitatively transferred to the tare-weighted, precleaned polyethylene sample container, followed by three rinses with deionized (DI) water of the impingers and all connecting glassware (including the connecting glassware to the first impinger) placed in the same H_2SO_4 container. The container was labeled and weighed to determine the final sample volume.

The contents NaOH impingers were quantitatively transferred to a second tare-weighted, precleaned polyethylene sample container, followed by three rinses with DI water of the impingers

and all connecting glassware placed in the same NaOH container. The container was labeled and weighed to determine the final sample volume.

Sample recovery from each train included:

1. Container No. 1 - Contents of H₂SO₄ impingers and knockout impinger and, and DI rinse of impingers and connecting glassware; and
2. Container No. 2 - Contents NaOH impingers, and DI rinse of impingers and connecting glassware.

Additional quality control consisted of collecting and analyzing a field blank train for every three test runs. The blank train was assembled from a used train, leak checked and sat for a period equal to the sampling time (i.e, 1-hr). The blank train data was to be used to determine the method detection limit for the test program target analytes (ie. The lowest number that could be detected), and compared to stack emissions.

Reagent blanks of 0.1 N H₂SO₄, 0.1N NaOH, and DI water were collected and archived for later analysis should there be any issues with the field blank train samples

The H₂SO₄ impinger solutions were analyzed using ion chromatography techniques for fluoride ions (F⁻) (EPA SW-9057). Duplicate analyses performed on the samples and field blanks. Precision was demonstrated by duplicate injection of each sample, the results of each individual analysis being within 5% of their mean to be acceptable.

The NaOH impinger solutions was treated with sodium thiosulfate to ensure complete conversion of hypochlorous acid (HClO) to chloride ions (Cl⁻). The resulting solution was analyzed using ion chromatography techniques for chloride ions (EPA SW-9057). Duplicate analyses was performed on the samples and field blanks. Precision was demonstrated by duplicate injection of each sample, the results of each individual analysis being within 5% of their mean to be acceptable

All EPA Method 26A HF/Cl₂ samples were analyzed by Element One of Wilmington NC. Refer to Section 1, Figure 1.1 of the RTR Sampling and Analytical Protocol for contact information.

For this test program, the relative deviation (RD) was to be calculated as described in EPA Method 30B between the Cl₂ concentrations measured with the paired trains. A criteria of a less than 10% relative deviation or 0.2 ppm absolute difference was required.

The absolute differences between the Cl₂ concentrations measured with the paired trains is summarized in Table 3.1. For each paired run, Cl₂ concentrations met the 0.2 ppm absolute difference criteria.

TABLE 3.1 PAIRED METHOD 26A SAMPLING TRAIN DIATOMIC CHLORINE CONCENTRATION COMPARISON RESULTS FOR THE KILN MAIN STACK; FEBRUARY 1, 2024

Run	Time	Train A Diatomic Chlorine Concentration (ppm,dry)	Train B Diatomic Chlorine Concentration (ppm,dry)	Absolute Difference (ppm,dry)
Run 1	10:26-11:35	0.053	0.047	0.006
Run 2	11:56-13:05	0.040	<0.038	0.002
Run 3	13:18-14:27	0.040	0.040	0.000

3.6 Hydrogen Cyanide and Hydrogen Fluoride - EPA Method 320

EPA Method 320 was performed to determine emissions of concentrations of HCN and HF. Three, 1-hour sampling runs were conducted under each representative process and control system operating conditions.

The gas sample was extracted from the stack through a glass-lined probe and filter heated to 375° F. For external calibration checks and analyte spikes, the gases were introduced in front of the heated filter. Any excess calibration gas was diverted through the sample probes into the source. Outflow of gas from the heated filter enclosure was transported through a Teflon sample line heated to 375° F. For these sources approximately 300' of sample line was required. The heated sample line was connected directly to the FTIR sample cell. Using heat-traced Teflon tubing the exit of the FTIR cell was connected to a sample pump with a heated stainless steel pump head. The pump discharge was directed to a proprietary chiller-type gas conditioner to remove moisture prior to delivery sample gas to the O₂/CO₂ monitor.

The distribution of the gas sample to the monitors was accomplished using a panel equipped with valves and rotometers. The gas sample was then divided and directed to the O₂/CO₂ analyzer.

FTIR sample cell was maintained at 191° C and connected to a MKS Instruments Multigas 2030 Fourier Transform Infrared Spectrometer and Detector.

The FTIR spectrometer measured vapor phase organic or inorganic compounds which absorb energy in the mid-infrared spectral region, about 400 to 4000 cm⁻¹ (25 to 2.5 μm). Continuous measurement were made by matching sample absorbance bands with bands in reference spectra, and comparing sample band intensities with reference band intensities.

The principle limitation to FTIR spectroscopy are the presence of interfering compounds that also absorb energy in the mid-infrared spectral region. In a cement kiln stack gas matrix, water vapor (H₂O) and carbon dioxide (CO₂) are the primary interferents that must be incorporated into the identification and quantitation method.

The FTIR software performs the computation for a single compound by subtracting all the other compounds (interferants and target) from the absorbance spectra and quantifies the single compound based on the remain absorbance. The FTIR software provides a Standard Error Calculation (SEC) value that is an indication of how well the identification and quantitation has been performed. A high SEC indicates that other interferants have not been accounted for in the analysis method, and a low SEC is indicative of greater confidence measurement.

The instrument is operated with a resolution of 0.5 cm⁻¹ with 4x zero filling. Beer-Norton Medium apodization is used with amplitude phase correction.

For this RTR test program, following specific QA/QC activities for EPA Method 320 were performed and are summarized in Table 3.2

3.6.1 Laboratory QA/QC Activities Before Field Test Program

Before field testing occurs, the following QA/QC activities were conducted;

- 1) Seven consecutive samples of dry nitrogen through the sampling system was acquired and used to calculate the standard deviation for each of the test program target analytes multiplied by a factor of 3. These data were considered representative of detection limits (DL) for this test program and were below the 0.5 ppm required DL for both HCN and HF;
- 2) From these seven dry nitrogen samples, the results for the Signal-to-Noise Ratio (SNR) @ 2500 cm^{-1} was >2500, at 64 scans and the results for single beam intensity @ 2500 cm^{-1} was >0.9; and
- 3) The HCN calibration gases was analyzed directly and the FTIR responses agreed with tag value within 5%

3.6.2 QA/QC Activities During Field Test Program

During the field test program, following QA/QC activities were be performed and criterium met;

- 1) On each test day prior to any testing, an instrument background was collected using dry nitrogen directed to the gas cell. The background was collected with at least 128 scans;
- 2) The probe, filter, sample line and all sample system components in contact with effluent were be maintained at or above 375°F or 191°C (consistent with FTIR calibration temperature) to avoid any possible “cold spots;”
- 3) A system zero with all sampling system components at operating temperature was performed by injecting nitrogen at the sample probe and through sample filter and entire measurement system. After zero equilibration was achieved, all measurement components were quantified for at least 128 scans;
- 4) The sample probe was position at effluent measurement point and sampling was continue until equilibration of the measurement system has been achieved. At this point, the effluent concentrations was quantified with two consecutive 64-scan samples as the initial native concentration for the dynamic spike;
- 5) Analyte spiking was conducted for HCN before the first test run, and after each successive test run for a minimum of 4 spikes per test condition. These results were used to determine accuracy and are summarized in Table 3.3;
- 6) The spike gas injections was maintained at 10% or less of total sample volume. The spike gas concentration and flow rate was be selected to approximately double the native effluent concentration. Spike recovery results were within $\pm 20\%$ of the expected value. An SF_6 tracer was used to calculate the exact spike gas dilution ratio of 10% or less;

TABLE 3.2 FTIR PRETEST AND FIELD TEST QA/QC SUMMARY

Spectrum	HCN	SF6	HF	SNR 2500	sBeam @2500
Seven consecutive samples of dry nitrogen for detection limit					
SPC__000837.LAB	-0.051		-0.002	6223.51	1.42
SPC__000838.LAB	-0.032		-0.000	5809.30	1.42
SPC__000839.LAB	0.046		-0.017	3759.60	1.42
SPC__000840.LAB	-0.011		0.016	4373.66	1.42
SPC__000841.LAB	0.080		0.002	5347.95	1.42
SPC__000842.LAB	0.059		-0.012	5012.46	1.42
SPC__000843.LAB	-0.029		-0.006	4706.13	1.42
Standard Deviation X 3	0.156			0.032	
Averages				5033.23	1.42
HCN Standard (CC768222; 49.9 ppm HCN/5.0 ppm SF6)					
SPC__156801.LAB	48.27	4.78			
SPC__156802.LAB	48.30	4.77			
SPC__156803.LAB	48.32	4.78			
SPC__156804.LAB	48.18	4.78			
Averages	48.27	4.78			
Residuals for Post HCN analyte spike native scans					
SPC_156855.LAB	0.56 0.01 NA		0.16 0.24 NA		
Concentration					
MDC3					
MDC3%	0.16 0.22 NA				
SPC_156856.LAB					
Concentration					
MDC3	0.01				
MDC3%	NA				
Final SNR @ 2500 cm ⁻¹ and single beam intensity @ 2500 cm ⁻¹					
SPC__157191.LAB				4867.1	1.05

- 7) After the dynamic spike, nitrogen was sent through the sampling system until all traces of spike gas removed and lines proven below DL for target analytes;
- 8) The nitrogen purge was discontinued and the sampling system was allowed to equilibrate with stack gas before starting a test run. The first two consecutive 64-scan samples of a sample run was used for the final native concentration. Residual results for HCN and HF were verified to be less than 0.2-0.3 ppm for data acceptance, or less than 5% of the measured value, whichever was least restrictive.
- 9) The final SNR @ 2500 cm^{-1} , at 64 scans, and the results for single beam intensity @ 2500 cm^{-1} were verified to meet the >2500 and >0.9 criterium; respectively.

TABLE 3.3 ETHYLENE CALIBRATION TRANSFER STANDARD (CTS) AND HYDROGEN CYANIDE ANALYTE SPIKING TEST RESULTS FOR THE KILN MAIN STACK; FEBRUARY 1, 2024

Run	Time	Average Native Hydrogen Cyanide Concentration (ppm,wet)	Spike plus Average Hydrogen Cyanide Native Concentration (ppm,wet)	Hydrogen Cyanide Spike Recovery	CTS Error
Pre Run 1	08:02-08:19	0.56	4.26	98.6%	-3.6%
Post Run 1	11:28-11:46	0.62	4.19	115.9%	
Post Run 2	12:59-13:18	0.75	3.68	100.3%	
Post Run 3	14:21-14:46	0.54	3.46	99.6%	-4.3%

4. QA/QC PROCEDURES AND RESULTS

The objective of a quality assurance/quality control (QA/QC) program is to assure that the precision and accuracy of all environmental data generated by DEECO for clients are commensurate with data quality objectives (DQO's). DQO's are based on a common understanding of the intended end use(s) of the data, the measurement process, and the availability of resources. Once DQO's are established, formally or informally, QC protocol can be defined for the measurements.

In this project, the final data user is Holcim. The data quality objectives in this project are to generate scientifically sound data to be used for compliance purposes.

4.1 Sampling Equipment

All of the sampling equipment used was calibrated according to the procedures outlined in the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III, EPA-600/4-77-027b.

4.1.1 Manual Sampling Equipment Calibrations

For sampling Methods 1, 2, and 4 the procedures and equipment used to measure stack gas velocity and temperature measurements and the metering system used to maintain constant rate sampling conditions and to determine the sample gas volume were subjected to pretest and posttest calibrations and/or inspections as required by the appropriate EPA methods.

Barometer - Barometric pressure values were obtained from a calibrated barometer, verified by phone call to a local airport, and corrected for elevation to sample port level (0.01 inches Hg per 10 ft. elevation).

Pitot Tubes - Each pitot tube used in sampling meets the design specifications for type-S pitot tubes in EPA Method 2. Therefore, a maximum value baseline coefficient (C_p) of 0.84 is assigned to each pitot tube. Calibration by the manufacturer for pitot face-opening alignment included measuring the external tubing diameter (dimension D_t), the base-to-opening plane distance (dimensions P_a and P_b), and the face opening misalignment angles, with all terms as described in EPA Method 2. Pitot tubes were visually inspected for structural integrity at the completion of each test. Inspection sheets for pitot tubes are included in Appendix E.

Calibration Meter and Metering System - The secondary reference meter equipment arrangement for calibration is shown in Figure 5.7 of EPA Method 5. The prescribed procedures were followed. A wet test meter with a 1 ft³/rev capacity and ± 1 percent accuracy is used as the primary calibrant. The dry gas meter's pump is run for a minimum of 5 minutes at a flow rate of 0.35 cfm to condition the interior surface of the wet test meter. Leak checks are performed and if satisfactory, triplicate runs at each of no less than five different flow rates are done. A calibration curve is prepared and the meter is recalibrated after 200 hours of operation or annually, whichever comes first.

The calibration set-up for the dry gas metering system using the secondary reference meter in lieu of the wet test meter is given in Figure 5.5 of EPA Method 5. A leak check of the metering system before calibration was performed as shown in Figure 5.4 of EPA Method 5. The metering system's pump is operated for 5 minutes at an orifice manometer setting of 0.5 inches H₂O to heat up the pump and system to stabilize the meter inlet and outlet temperatures. Values for the orifice setting (ΔH), wet test meter volume (V_w), corresponding dry test meter volume (V_d), dry test meter inlet and outlet gas temperatures (t_{di} and t_{dn}), and time are recorded for the initial calibration. Then the ratio of the wet test meter to the dry test meter (γ) and the orifice pressure differential that equates to 0.75 cfm at standard conditions ($\Delta H@$) are calculated.

A post-test meter calibration was made on the dry gas meter used during the test to check its accuracy against the pre-test calibration. This post-test calibration check was made using the average orifice setting obtained during each test run and setting the vacuum at the maximum value obtained during each test run. These test runs were made against DEECO's secondary reference dry gas meter which was calibrated against a wet test meter. The calibration data sheets for the dry gas meters are included in Appendix E.

Thermocouples and Digital Indicators - Thermocouples were calibrated by comparing them against an ASTM-3F mercury-in-glass thermometer at approximately 32°F (ice water), ambient temperature, and at approximately 220°F. Each thermocouple was calibrated against temperature ranges to which it is typically exposed during test conditions, and they agreed within 1.5 percent (expressed in °R) of the reference thermometer throughout the entire calibration range. Also, thermocouples were checked at ambient temperature at the test site to verify calibration. The calibration data sheets for the thermocouples are included in Appendix E.

Pretest and Posttest Leak Checks of Sampling Trains - Each Method 4 sampling train was subjected to pretest leak checks and posttest leak checks. For all sampling runs the posttest leak checks were acceptable (less than 4% of the sampling rate at the highest vacuum recorded during the test run).

4.2 Analytical QA/QC Results

Analytical measurements of precision and accuracy were made on stack gas samples, and are summarized in a separate report.

Appendix A

Emission Summary Tables

Company: Holcim; Theodore AL
Source: Kiln Main Stack
Job ID: 24-3328
Train Type: M26A

	1A 02/01/24 1026-1135	1B 02/01/24 1026-1135	2A 02/01/24 1156-1305	2B 02/01/24 1156-1305	3A 02/01/24 1318-1427	3B 02/01/24 1318-1427	Average
Initial Meter Volume, ft³	88.401	586.761	144.525	642.926	203.358	703.655	
Final Meter Volume, ft³	144.292	642.771	203.135	703.016	264.935	763.405	
Intra-Port Leak Check Volume, ft³	0.000	0.000	0.000	0.000	0.000	0.000	
Total Sample Volume, cf	55.891	56.010	58.610	60.090	61.577	59.750	58.655
DGM Calibration Factor	0.967	1.014	0.967	1.014	0.967	1.014	0.991
Average DGM Temp, F	57.4	69.1	69.0	78.5	67.8	82.7	70.8
Average DGM delta H, "H2O	2.97	2.83	3.39	2.88	3.63	3.23	3.16
Barometric Pressure, "Hg	29.86	29.86	29.86	29.86	29.86	29.86	29.86
Corrected Sample Vol,dscf	55.424	56.934	56.904	60.022	59.955	59.271	58.085
Corrected Sample Vol,dscm	1.569	1.612	1.611	1.700	1.698	1.678	1.645
Oxygen, %	16.6	16.6	16.7	16.7	16.4	16.4	16.6
Carbon Dioxide, %	7.3	7.3	7.2	7.2	7.4	7.4	7.3
Nitrogen, %	76.1	76.1	76.1	76.1	76.2	76.2	76.1
Stack Gas Excess Air, %	475.6	475.6	492.6	492.6	441.2	441.2	469.8
Total Moisture Catch Weight, grams	85.2	95.9	81.6	87.5	97.0	97.2	93.9
Stack Gas Moisture, %	6.7	7.3	6.3	6.4	7.1	7.2	6.8
Stack Gas Dry Molecular Weight, lb/lbmole	29.83	29.83	29.82	29.82	29.84	29.84	29.83
Stack Gas Wet Molecular Weight, lb/lbmole	29.04	28.97	29.08	29.06	29.00	28.99	29.02
Average Stack Temp, F	235.2	236.0	263.0	262.8	258.5	261.6	252.9
Stack Static (Gauge) Pressure, "H2O	-0.80	-0.80	-0.80	-0.80	-0.80	-0.80	-0.80
Stack Gas Actual Pressure, "Hg	29.80	29.80	29.80	29.80	29.80	29.80	29.80
Average Sqrt delta P	0.868	0.880	0.878	0.894	0.881	0.892	0.882
Pitot Tube Coefficient	0.84	0.84	0.84	0.84	0.84	0.84	0.84
Stack Gas Velocity, ft/second	55.87	56.74	57.59	58.65	57.69	58.54	57.51
Nozzle Inside Diameter, inches	0.278	0.278	0.278	0.278	0.278	0.278	
Total Sample Time, min	60	60	60	60	60	60	60
Isokinetic Rate, %	92.7	94.5	95.6	99.1	100.8	98.7	96.9
Stack Dimensions	204 in. ID	204 in. ID	204 in. ID	204 in. ID	204 in. ID	204 in. ID	
Stack Area, sq ft	226.98	226.98	226.98	226.98	226.98	226.98	226.98
Stack Gas Flow Rate, acfm	760,900	772,700	784,300	798,700	785,700	797,200	783,250
Stack Gas Flow Rate, acmm	21,546	21,881	22,209	22,617	22,249	22,574	22,179
Stack Gas Flow Rate, dscfm	537,000	541,200	534,500	543,900	534,200	539,200	538,333
Stack Gas Flow Rate, dscmm	15,206	15,325	15,135	15,402	15,127	15,269	15,244

Company: Holcim; Theodore AL
Source: Kiln Main Stack
Job ID: 24-3328
Train Type: M26A

"ND()" denotes values below detection limits
NOTE: Average INCLUDES Non-detect runs' results

	1A 02/01/24 1026-1135	1B 02/01/24 1026-1135	2A 02/01/24 1156-1305	2B 02/01/24 1156-1305	3A 02/01/24 1318-1427	3B 02/01/24 1318-1427	Average
Hydrogen Fluoride							
Catch Wt, mg	ND(	ND(	ND(	ND(	ND(	ND(	ND(
Conc., mg/dscm	0.232	0.245	0.236	0.243	0.225	0.243	0.237
Conc., mg/dscm @7% O2	0.148	0.152	0.146	0.143	0.133	0.145	0.144
Conc., mg/dscm @12% CO2	0.478	0.491	0.485	0.473	0.409	0.447	0.464
Conc., ppmvd	0.243	0.250	0.244	0.238	0.215	0.235	0.238
Conc., ppmvd @7% O2	0.178	0.183	0.176	0.172	0.159	0.174	0.174
Conc., ppmvd @12% CO2	0.575	0.591	0.583	0.569	0.492	0.538	0.558
Emission Rate, lb/hr	0.292	0.300	0.294	0.286	0.258	0.282	0.286
Clinker Rates (mtph and lbs/ton)	0.297	0.308	0.293	0.291	0.265	0.292	0.291
	147.75	0.0019	147.71	0.0018	147.93	0.0017	0.0018
Chlorine							
Catch Wt, mg	0.246	0.225	0.191	0.19	0.201	0.2	0.209
Conc., mg/dscm	0.157	0.140	0.119	0.112	0.118	0.119	0.127
Conc., mg/dscm @7% O2	0.507	0.451	0.392	0.370	0.366	0.368	0.409
Conc., mg/dscm @12% CO2	0.258	0.229	0.198	0.186	0.192	0.193	0.209
Conc., ppmvd	0.053	0.047	0.040	0.038	0.040	0.040	0.043
Absolute Difference, ppmvd (<0.2 required)		0.006		0.002		0.000	
Conc., ppmvd @7% O2	0.172	0.153	0.133	0.125	0.124	0.125	0.139
Conc., ppmvd @12% CO2	0.087	0.078	0.067	0.063	0.065	0.066	0.071
Emission Rate, lb/hr	0.315	0.283	0.237	0.228	0.237	0.241	0.257
Clinker Rates (tph and lbs/ton)	147.75	0.0018	147.71	<	147.93	0.0015	0.0016

Run 1

Spectrum	Date	Time	HCN (200)	PCA 191C	191c	HF ppm (10)	191C	SF6 (10)	191C	Ethylene (100,3000)	191C	H2O% (40)	191C	CO2% (40)	191C	spars
SPC___156976.LAB	02/01/24	10:26:51.555	0.630			0.015	0.006			0.692	7.724	6.657				
SPC___156977.LAB	02/01/24	10:27:55.213	0.599			-0.001	0.006			0.757	7.677	6.300				
SPC___156978.LAB	02/01/24	10:28:59.348	0.576			0.076	0.005			0.692	7.739	6.337				
SPC___156979.LAB	02/01/24	10:30:02.944	0.613			0.025	0.006			0.822	7.656	6.312				
SPC___156980.LAB	02/01/24	10:31:06.802	0.722			0.030	0.006			0.611	7.600	6.544				
SPC___156981.LAB	02/01/24	10:32:10.705	0.548			0.082	0.004			0.736	7.713	7.493				
SPC___156982.LAB	02/01/24	10:33:14.593	0.711			-0.005	-0.000			0.754	7.693	7.965				
SPC___156983.LAB	02/01/24	10:34:18.824	0.653			0.065	-0.000			0.984	7.727	8.289				
SPC___156984.LAB	02/01/24	10:35:22.394	0.657			0.000	0.003			0.727	7.496	7.714				
SPC___156985.LAB	02/01/24	10:36:26.283	0.587			-0.009	0.002			0.691	7.188	6.878				
SPC___156986.LAB	02/01/24	10:37:30.512	0.638			0.007	0.004			0.586	7.135	6.819				
SPC___156987.LAB	02/01/24	10:38:34.082	0.629			0.028	0.005			0.655	7.068	6.758				
SPC___156988.LAB	02/01/24	10:39:37.972	0.659			0.037	0.003			0.701	7.089	7.220				
SPC___156989.LAB	02/01/24	10:40:41.868	0.691			0.004	0.001			0.613	7.219	7.992				
SPC___156990.LAB	02/01/24	10:41:45.772	0.667			0.006	0.004			0.734	7.270	8.117				
SPC___156991.LAB	02/01/24	10:42:49.666	0.667			0.026	-0.000			0.680	7.287	7.917				
SPC___156992.LAB	02/01/24	10:43:53.559	0.596			0.015	0.002			0.603	7.316	7.740				
SPC___156993.LAB	02/01/24	10:44:57.464	0.531			0.006	0.004			0.538	7.131	6.970				
SPC___156994.LAB	02/01/24	10:46:01.692	0.636			-0.011	0.004			0.623	6.918	6.226				
SPC___156995.LAB	02/01/24	10:47:05.288	0.616			0.001	0.004			0.617	6.913	6.407				
SPC___156996.LAB	02/01/24	10:48:09.190	0.649			0.031	0.006			0.581	6.881	6.718				
SPC___156997.LAB	02/01/24	10:49:13.411	0.651			0.015	0.003			0.722	6.932	7.137				
SPC___156998.LAB	02/01/24	10:50:16.978	0.757			0.012	0.001			0.776	7.238	8.077				
SPC___156999.LAB	02/01/24	10:51:20.943	0.714			0.007	-0.000			0.928	7.502	8.335				
SPC___157000.LAB	02/01/24	10:52:24.771	0.831			-0.011	0.001			1.103	7.688	8.199				
SPC___157001.LAB	02/01/24	10:53:28.959	0.604			-0.014	-0.001			0.693	7.596	7.357				
SPC___157002.LAB	02/01/24	10:54:32.631	0.611			0.007	0.005			0.670	7.302	6.221				
SPC___157003.LAB	02/01/24	10:55:36.546	0.701			0.032	0.005			0.852	7.269	5.776				
SPC___157004.LAB	02/01/24	10:56:40.316	0.652			0.052	0.004			0.734	7.239	5.904				
SPC___157005.LAB	02/01/24	10:57:44.220	0.629			0.020	0.005			0.699	7.187	6.172				
SPC___157006.LAB	02/01/24	10:58:48.110	0.619			0.011	0.004			0.619	7.357	7.004				
SPC___157007.LAB	02/01/24	10:59:52.008	0.601			0.012	0.004			0.671	7.383	7.148				
SPC___157008.LAB	02/01/24	11:00:55.913	0.658			0.026	0.005			0.716	7.515	7.508				
SPC___157009.LAB	02/01/24	11:01:59.804	0.658			0.086	0.002			0.695	7.758	8.247				
SPC___157010.LAB	02/01/24	11:03:03.739	0.576			0.082	0.002			0.779	7.819	8.169				
SPC___157011.LAB	02/01/24	11:04:07.639	0.608			0.054	0.002			0.760	7.976	8.169				
SPC___157012.LAB	02/01/24	11:05:11.599	0.682			0.073	0.002			0.694	8.061	7.909				
SPC___157013.LAB	02/01/24	11:06:15.389	0.578			0.081	0.002			0.735	8.040	7.383				
SPC___157014.LAB	02/01/24	11:07:19.293	0.679			0.102	0.002			0.662	8.101	6.888				
SPC___157015.LAB	02/01/24	11:08:23.187	0.604			0.095	0.003			0.710	8.180	7.258				
SPC___157016.LAB	02/01/24	11:09:27.080	0.642			0.109	-0.000			0.751	8.145	7.634				
SPC___157017.LAB	02/01/24	11:10:30.986	0.597			0.079	0.001			0.714	7.892	7.583				
SPC___157018.LAB	02/01/24	11:11:34.913	0.550			0.036	0.002			0.616	7.733	7.966				
SPC___157019.LAB	02/01/24	11:12:38.811	0.595			-0.002	0.000			0.675	7.514	7.890				
SPC___157020.LAB	02/01/24	11:13:42.712	0.560			0.012	0.002			0.585	7.468	7.815				
SPC___157021.LAB	02/01/24	11:14:46.566	0.573			-0.001	0.001			0.695	7.362	7.221				
SPC___157022.LAB	02/01/24	11:15:50.567	0.534			-0.003	0.003			0.578	7.464	6.821				
SPC___157023.LAB	02/01/24	11:16:54.367	0.520			0.001	0.004			0.646	7.647	6.668				
SPC___157024.LAB	02/01/24	11:17:58.591	0.508			0.080	0.006			0.761	7.734	6.045				
SPC___157025.LAB	02/01/24	11:19:02.225	0.562			0.056	0.001			0.687	8.034	7.027				
SPC___157026.LAB	02/01/24	11:20:06.389	0.592			0.068	0.002			0.612	8.294	7.215				
SPC___157027.LAB	02/01/24	11:21:09.984	0.614			0.059	0.003			0.697	8.323	7.046				
SPC___157028.LAB	02/01/24	11:22:13.880	0.544			0.101	0.001			0.645	8.422	7.594				
SPC___157029.LAB	02/01/24	11:23:17.781	0.542			0.099	0.003			0.691	8.437	7.752				
SPC___157030.LAB	02/01/24	11:24:21.768	0.619			0.064	0.003			0.662	8.221	7.708				
SPC___157031.LAB	02/01/24	11:25:25.570	0.559			-0.003	0.002			0.673	7.682	7.498				
SPC___157032.LAB	02/01/24	11:26:29.436	0.631			-0.005	0.001			0.584	7.032	6.875				
Averages	16.6%	(actual)	0.622			0.034	0.003			0.700	7.579	7.238				
Dryers On Run 1	539,100	(ppm,dry @7% O2)	2,009			0.110	0.009			2,262	7.0	M26A Moisture				
Oxygen		(lbs/hr)	1.410			0.061	0.033			1,548						
Clinker (mtons/hr)	147.8	(lbs/ton clinker)	0.009			0.0004										
DSFCM																

Holcim, Theodore AL																
Kiln Main Stack, Dryers On																
Run 2																
Spectrum	Date	Time	HCN (200)	PCA 191C	191c	HF ppm (10)	191C	SF6 (10)	191C	Ethylene (100,3000)	191C	H2O% (40)	191C	CO2% (40)	191C	span
SPC_157060.LAB	02/01/24	11:56:44.521	0.351			0.003	0.003	0.003	0.733	7.175	8.142					
SPC_157061.LAB	02/01/24	11:57:48.378	0.567			-0.006	0.003	0.003	0.659	7.322	8.143					
SPC_157062.LAB	02/01/24	11:58:52.319	0.514			0.003	0.001	0.001	0.632	7.198	7.517					
SPC_157063.LAB	02/01/24	11:59:56.275	0.571			-0.012	0.003	0.003	0.664	7.154	7.158					
SPC_157064.LAB	02/01/24	12:01:00.127	0.519			-0.010	0.002	0.002	0.591	7.163	6.618					
SPC_157065.LAB	02/01/24	12:02:03.971	0.709			0.022	0.006	0.006	0.614	7.190	6.375					
SPC_157066.LAB	02/01/24	12:03:07.989	0.442			0.025	-0.000	-0.000	0.596	7.435	7.130					
SPC_157067.LAB	02/01/24	12:04:11.757	0.384			0.004	0.003	0.003	0.634	7.315	7.549					
SPC_157068.LAB	02/01/24	12:05:15.660	1.043			-0.004	-0.002	-0.002	0.558	6.719	7.988					
SPC_157069.LAB	02/01/24	12:06:19.556	0.769			-0.001	0.002	0.002	0.595	6.334	7.624					
SPC_157070.LAB	02/01/24	12:07:23.782	0.613			-0.024	-0.001	-0.001	0.528	5.541	6.971					
SPC_157071.LAB	02/01/24	12:08:27.587	0.950			-0.032	0.000	0.000	0.528	5.050	6.046					
SPC_157072.LAB	02/01/24	12:09:31.239	1.039			0.047	0.001	0.001	0.643	5.350	5.854					
SPC_157073.LAB	02/01/24	12:10:35.166	0.924			0.036	0.003	0.003	0.605	5.360	6.203					
SPC_157074.LAB	02/01/24	12:11:39.374	0.819			0.030	0.002	0.002	0.629	5.355	6.940					
SPC_157075.LAB	02/01/24	12:12:42.968	0.885			-0.026	-0.002	-0.002	0.671	5.534	8.122					
SPC_157076.LAB	02/01/24	12:13:47.162	0.759			-0.025	0.001	0.001	0.606	5.887	8.115					
SPC_157077.LAB	02/01/24	12:14:50.727	0.992			-0.029	0.002	0.002	0.609	5.878	7.602					
SPC_157078.LAB	02/01/24	12:15:54.621	1.222			-0.026	0.002	0.002	0.549	6.005	6.996					
SPC_157079.LAB	02/01/24	12:16:58.514	0.947			-0.024	0.002	0.002	0.578	5.921	6.358					
SPC_157080.LAB	02/01/24	12:18:02.418	0.667			0.029	0.004	0.004	0.626	5.771	5.645					
SPC_157081.LAB	02/01/24	12:19:06.312	0.670			0.020	0.003	0.003	0.703	5.756	5.856					
SPC_157082.LAB	02/01/24	12:20:10.265	0.641			0.023	0.002	0.002	0.589	5.758	6.370					
SPC_157083.LAB	02/01/24	12:21:14.109	0.615			0.030	0.003	0.003	0.634	5.815	6.811					
SPC_157084.LAB	02/01/24	12:22:18.092	0.985			-0.040	-0.001	-0.001	0.920	6.085	8.140					
SPC_157085.LAB	02/01/24	12:23:21.897	0.644			-0.001	-0.000	-0.000	0.646	8.243	8.278					
SPC_157086.LAB	02/01/24</															




Holcim: Theodore AL										
Kiln Main Stack; Dryers On										
Run 3										
Spectrum	Date	Time	HCN (200) PCA 191C 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C	H2O% (40) 191C	CO2% (40) 191C	span	
SPC_157136.LAB	02/01/24	13:19:02.022	0.680	0.044	-0.001	0.686	6.662	6.662	6.926	
SPC_157137.LAB	02/01/24	13:20:06.238	0.757	0.004	0.000	0.632	6.824	6.824	7.565	
SPC_157138.LAB	02/01/24	13:21:09.776	0.610	0.003	-0.002	0.692	6.888	6.888	8.006	
SPC_157139.LAB	02/01/24	13:22:13.759	0.342	-0.038	-0.003	0.721	6.898	6.898	8.438	
SPC_157140.LAB	02/01/24	13:23:17.899	1.095	-0.033	-0.007	1.495	7.019	7.019	9.084	
SPC_157141.LAB	02/01/24	13:24:21.569	0.934	0.014	-0.003	1.541	6.967	6.967	8.930	
SPC_157142.LAB	02/01/24	13:25:25.362	1.016	-0.036	0.000	0.673	6.7521	6.7521	7.521	
SPC_157143.LAB	02/01/24	13:26:29.367	1.045	-0.004	-0.002	0.666	6.647	6.647	6.466	
SPC_157144.LAB	02/01/24	13:27:33.337	0.784	-0.022	0.002	0.537	6.593	6.593	6.361	
SPC_157145.LAB	02/01/24	13:28:37.053	0.542	-0.043	0.002	0.642	6.644	6.644	6.501	
SPC_157146.LAB	02/01/24	13:29:40.952	0.411	-0.027	0.000	0.637	6.693	6.693	7.075	
SPC_157147.LAB	02/01/24	13:30:44.844	0.695	-0.004	0.003	0.643	6.712	6.712	7.355	
SPC_157148.LAB	02/01/24	13:31:48.740	0.668	0.006	0.001	0.606	6.766	6.766	7.608	
SPC_157149.LAB	02/01/24	13:32:52.743	0.665	0.002	-0.004	0.606	6.860	6.860	8.157	
SPC_157150.LAB	02/01/24	13:33:56.532	0.480	-0.034	-0.002	0.620	6.988	6.988	8.351	
SPC_157151.LAB	02/01/24	13:35:00.812	0.642	0.017	-0.000	0.683	7.030	7.030	8.128	
SPC_157152.LAB	02/01/24	13:36:04.360	0.825	-0.057	0.001	0.553	6.925	6.925	7.564	
SPC_157153.LAB	02/01/24	13:37:08.262	0.533	-0.003	-0.000	0.599	6.800	6.800	6.413	
SPC_157154.LAB	02/01/24	13:38:12.158	0.235	-0.037	0.003	0.640	6.820	6.820	6.293	
SPC_157155.LAB	02/01/24	13:39:16.375	0.714	-0.015	0.004	0.575	6.800	6.800	6.401	
SPC_157156.LAB	02/01/24	13:40:20.274	0.439	0.039	0.001	0.694	6.985	6.985	7.174	
SPC_157157.LAB	02/01/24	13:41:23.895	0.382	-0.045	-0.000	0.571	7.052	7.052	7.261	
SPC_157158.LAB	02/01/24	13:42:27.888	0.485	-0.011	0.002	0.605	7.030	7.030	7.309	
SPC_157159.LAB	02/01/24	13:43:31.596	0.506	0.021	0.002	0.607	7.108	7.108	7.748	
SPC_157160.LAB	02/01/24	13:44:35.489	0.393	-0.012	0.001	0.672	7.130	7.130	7.857	
SPC_157161.LAB	02/01/24	13:45:39.390	0.819	-0.016	-0.000	0.671	7.094	7.094	7.797	
SPC_157162.LAB	02/01/24	13:46:43.283	0.416	-0.016	0.000	0.618	7.174	7.174	7.645	
SPC_157163.LAB	02/01/24	13:47:47.181	0.671	-0.015	-0.001	0.614	7.164	7.164	7.463	
SPC_157164.LAB	02/01/24	13:48:51.264	0.515	-0.034	0.001	0.605	7.054	7.054	6.956	
SPC_157165.LAB	02/01/24	13:49:55.155	0.290	0.004	0.003	0.648	6.837	6.837	6.837	
SPC_157166.LAB	02/01/24	13:50:58.975	0.424	-0.033	0.000	0.642	6.999	6.999	7.228	
SPC_157167.LAB	02/01/24	13:52:02.768	0.862	-0.047	0.001	0.616	6.909	6.909	7.597	
SPC_157168.LAB	02/01/24	13:53:06.968	0.413	-0.017	-0.002	0.726	6.877	6.877	7.677	
SPC_157169.LAB	02/01/24	13:54:10.663	0.651	0.010	0.001	0.684	6.836	6.836	7.895	
SPC_157170.LAB	02/01/24	13:55:14.457	0.802	-0.007	-0.001	0.820	6.922	6.922	8.141	
SPC_157171.LAB	02/01/24	13:56:18.349	0.610	-0.049	-0.000	0.686	6.981	6.981	7.880	
SPC_157172.LAB	02/01/24	13:57:22.244	0.565	-0.026	0.001	0.544	6.808	6.808	7.034	
SPC_157173.LAB	02/01/24	13:58:26.146	0.660	0.007	0.004	0.711	6.711	6.711	6.325	
SPC_157174.LAB	02/01/24	13:59:30.289	0.446	-0.018	0.002	0.644	6.826	6.826	6.859	
SPC_157175.LAB	02/01/24	14:00:33.935	0.350	-0.055	-0.003	0.675	6.840	6.840	6.925	
SPC_157176.LAB	02/01/24	14:01:37.836	0.539	-0.027	0.000	0.655	6.926	6.926	7.202	
SPC_157177.LAB	02/01/24	14:02:41.727	0.891	-0.021	0.001	0.597	7.071	7.071	7.581	
SPC_157178.LAB	02/01/24	14:03:45.663	0.797	-0.027	-0.000	0.661	7.225	7.225	7.937	
SPC_157179.LAB	02/01/24	14:04:49.555	0.955	-0.039	0.001	0.794	7.319	7.319	8.160	
SPC_157180.LAB	02/01/24	14:05:53.456	0.554	-0.035	-0.001	0.834	7.313	7.313	8.246	
SPC_157181.LAB	02/01/24	14:06:57.396	0.689	-0.029	0.001	0.659	7.099	7.099	6.967	
SPC_157182.LAB	02/01/24	14:08:01.242	0.689	-0.022	0.001	0.644	7.075	7.075	6.444	
SPC_157183.LAB	02/01/24	14:09:05.103	0.562	-0.009	0.006	0.671	7.089	7.089	6.343	
SPC_157184.LAB	02/01/24	14:10:08.999	0.619	-0.024	0.004	0.881	7.226	7.226	6.515	
SPC_157185.LAB	02/01/24	14:11:12.901	0.826	-0.016	0.002	0.607	7.318	7.318	7.155	
SPC_157186.LAB	02/01/24	14:12:17.124	0.643	-0.014	0.001	0.667	7.403	7.403	7.569	
SPC_157187.LAB	02/01/24	14:13:20.797	0.585	-0.037	0.002	0.689	7.494	7.494	7.783	
SPC_157188.LAB	02/01/24	14:14:24.585	0.368	-0.026	0.001	0.637	7.436	7.436	7.448	
SPC_157189.LAB	02/01/24	14:15:28.475	0.495	-0.024	-0.002	0.736	7.330	7.330	7.050	
SPC_157190.LAB	02/01/24	14:16:32.372	0.846	-0.055	-0.001	0.614	7.403	7.403	7.337	
SPC_157191.LAB	02/01/24	14:17:36.275	0.204	-0.072	0.004	0.672	7.422	7.422	7.107	
Averages	(actual)		0.619	0.032	0.000	0.689	6.996	6.996	7.386	
Oxygen	16.4%	(ppm,dry @7% O2)	2.058	0.106	0.001	2.291	7.2			
DSCFM	536,700	(lbs/hr)	1.504	0.058	0.006	1.739				
Clinker (mt/tons/hr)	147.9	(lbs/ton clinker)	0.009	0.0004						

Appendix B

Field Data
and
CEM/FTIR Data

Traverse Point Location for Circular Ducts

Plant	Holcim (US) Theodore		
City	Theodore	State	Alabama
Location	Main Kiln		
Stack ID (inches)	204		
Nipple Length	57		
Nearest Upstream Disturbance (Bend, ID FAN, etc)			
Distance (inches)	1680	Type of Disturbance	Duct Breaching
Nearest Downstream Disturbance (Bend, or Stack Outlet)			
Distance (inches)	1380	Type of Disturbance	Stack Outlet



Stack Schematic (Draw by hand after printing)

(Mark with an "x")

Particulate Traverse?

x	Yes
---	-----

☐ No

Number of Traverse Points Required

6

[illegible]

Cyclonic Flow Check Data Sheet

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim Theodore AL		2/1/24		Main Stack		Cyclonic Flow Check			

OPERATOR	Barometric Pressure (Pb) (In. Hg)	STATIC PRESS (In. H2O)	AMBIENT TEMP (deg. F)	STACK ID (In.)	PITOT Cp	DGM BOX No.	DGM delta H@	DGM CAL FACTOR (gamma)	PROBE ID NO
MP/JR	29.86	-0.80	40	2041	0.84	12575	NA	NA	1013

EPA Method 2 Data

[illegible]

Average of Absolute Angle Readings must be < 20 degrees

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION		SAMPLE TYPE		RUN NUMBER	
Holcim: Theodore, AL		2/1/24		Theodore Main Stack		Method 26A		- ON OFF -M26A-1A	
OPERATOR		AMBIENT PRESS (In. Hg)		STATIC PRESSURE (In. Water)		PITOT Cp		PROBE LENGTH AND LINER TYPE	
J. Rothberg		29.86		-0.80		2004		10' effective glass	
ASSUMED MOISTURE BOX No. (%)		DGM H@		DGM CAL FACTOR (Y)		STACK THERM NO.		STACK PITOT NO.	
7		1.95		0.967		106		174	
TRaverse ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		VELOCITY HEAD (In. H2O)		delta P	
A-1 1026 0		1026		28.401		11.90		4.426	
2 5				93.54		.79		3.2	
3 10				98.32		.55		2.2	
15		1041		102.420		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg			
B-1 15		1044		102.420		.92		3.7	
2 20				107.41		.73		2.9	
3 25				111.93		.60		2.4	
30		1059		116.065		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg			
C-1 30		1102		116.065		.95		3.8	
2 35				121.21		.77		3.1	
3 40				125.86		.56		2.2	
45		1117		129.942		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg			
D-1 45		1120		129.942		1.0		4.0	
2 50				135.42		.77		3.1	
3 55				140.73		.60		2.4	
60		1135		144.292		End of Port			
TOTAL TIME		DGM VOLUME		AVE SQRT delta P		AVE. TEMP.		AVE. TEMP.	
60 Min.									

SAMPLE TYPE		PITOT		LEAK CHECK (INITIAL)		LEAK CHECK (FINAL)		CO2 CONTENT %		K FACTOR	
Method 26A		Cp		.001 CU.FT @ 10 "Hg		.88 "CU.FT @ 10 "Hg		%		2.78	
10' effective glass		0.84		2004		106		16		2.78	
DGM		STACK THERM NO.		DGM CAL FACTOR (Y)		VELOCITY HEAD (In. H2O)		delta P		SAMPLE TRAIN VAC	
1026 0		1026		28.401		11.90		4.426		50	
2 5				93.54		.79		3.2		56	
3 10				98.32		.55		2.2		57	
15		1041		102.420		End of Port				52	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg					
B-1 15		1044		102.420		.92		3.7		60	
2 20				107.41		.73		2.9		61	
3 25				111.93		.60		2.4		62	
30		1059		116.065		End of Port				65	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg					
C-1 30		1102		116.065		.95		3.8		64	
2 35				121.21		.77		3.1		63	
3 40				125.86		.56		2.2		63	
45		1117		129.942		End of Port				5	
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg					
D-1 45		1120		129.942		1.0		4.0		64	
2 50				135.42		.77		3.1		64	
3 55				140.73		.60		2.4		65	
60		1135		144.292		End of Port				5	
TOTAL TIME		DGM VOLUME		AVE SQRT delta P		AVE. TEMP.		AVE. TEMP.			
60 Min.											

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim Theodore AL
 Sample Location main sack
 Run No. TD -M26A-1A
 Filter Number(s) Not Applicable

Sample Date 2/1/24
 Recovery Date 2/1/24
 Recovered by GC

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		763.6	766.2	687.1	765.8	778.7	975.3	g
Initial weight		747.6	756.5	670.9	757.3	776.4	962.8	g
Net weight		16.0	29.7	16.2	8.5	2.3	12.5	g

Description of impinger water Clear 20 % spent
B/W Sil gel color
 Total moisture = 85.2 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. TD -M26A-H2SO4-1A

Liquid level FV
 marked/sealed ✓ 440.3

NaOH Impingers contents and water rinse
 container no. TD -M26A-NaOH 1B

Liquid level ✓
 marked/sealed 353.0

Samples stored and locked _____
 Remarks _____

PAGE 1 of 1

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim Theodore AL
 Sample Location Main Stack
 Run No. TD -M26A-1B
 Filter Number(s) Not Applicable

Sample Date 21 1 /24
 Recovery Date 21 1 /24
 Recovered by SCJ

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		773.2	776.6	633.4	772.6	751.6	971.7	g
Initial weight		757.3	743.7	617.2	764.4	749.5	953.1	g
Net weight		15.9	32.9	16.2	8.2	2.1	18.6	g

Description of impinger water clean 30 % spent
B/W Sil gel color
 Total moisture = 95.9 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. TD -M26A-H2SO4- 1B

Liquid level
 marked/sealed ✓ 465.3

NaOH Impingers contents and water rinse
 container no. TD -M26A-NaOH 1B

Liquid level
 marked/sealed ✓ 367.2

Samples stored and locked _____
 Remarks _____

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION			SAMPLE TYPE		RUN NUMBER		
HOLDING		2 / 1 / 24		Method 26A			PITOT		- ON OFF - M26A- Z.A		
OPERATOR		AMBIENT PRESS (In. Hg)		STATIC PRESSURE (In. Water)		AMBIENT TEMP (deg. F)		PROBE LENGTH AND LINER TYPE		NOZZLE	
J. Rothberg		298.6		-0.80		50		10' 9165		.277 .278	
ASSUMED DGM MOISTURE BOX No. (%)	DGM H@	DGM CAL FACTOR (Y)	STACK THERM NO.	STACK PITOT NO.	ORSAT NO.	LEAK CHECK (INITIAL)	LEAK CHECK (FINAL)	O2 CONTENT %	CO2 CONTENT %	K FACTOR	
7 M5-25	1.95	0.967	10.5	10.5	CEM	0.01 CU. FT @ 10 "Hg	0.01 CU. FT @ 10 "Hg	10	7	4.0 / 4.6	
TRaverse ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	delta P VELOCITY HEAD (In. H2O)	delta H ORIFICE (In. H2O)	PROBE TEMP (deg. F)	STACK TEMP (deg. F)	DGM IN / OUT TEMP (deg. F)	FILTER OVEN TEMP (deg. F)	Sil Gel EXIT TEMP (deg. F)	SAMPLE TRAIN VAC (in. Hg)	
A-1 0	1156	144.525	.95	3.8	254	260	66	258	64	6	
2 5		149.59	.77	3.1	255	257	67	258	62	5	
3 10		154.11	.53	2.1	254	256	67	259	61	5	
INTRA-PORT LEAK CHECK?											
DGM VOLUME (CU. FT)	INITIAL	FINAL	LEAK RATE:		CU. FT @	CU. FT @	INCHES Hg				
B-1 15	1214	159.050	.95	3.8	255	267	69	259	64	6	
2 20		163.45	.81	3.2	255	271	70	256	63	5	
3 25		168.03	.60	2.8	255	270	72	256	63	5	
INTRA-PORT LEAK CHECK?											
DGM VOLUME (CU. FT)	INITIAL	FINAL	LEAK RATE:		CU. FT @	CU. FT @	INCHES Hg				
C-1 30	1232	172.310	1.0	4.6	257	262	70	253	64	8	
2 35		178.30	.75	3.5	257	263	69	253	62	5	
3 40		183.25	.55	2.5	256	263	69	253	60	5	
INTRA-PORT LEAK CHECK?											
DGM VOLUME (CU. FT)	INITIAL	FINAL	LEAK RATE:		CU. FT @	CU. FT @	INCHES Hg				
D-1 45	1250	187.655	1.0	4.6	255	261	70	257	62	8	
2 50		193.17	.82	3.8	256	263	70	257	60	6	
3 55		198.72	.63	2.9	256	263	69	256	59	6	
INTRA-PORT LEAK CHECK?											
DGM VOLUME (CU. FT)	INITIAL	FINAL	LEAK RATE:		CU. FT @	CU. FT @	INCHES Hg				
60	1305	203.135	End of Port	AVE SQRT delta P		AVE. TEMP.					
TOTAL TIME	DGM VOLUME		AVE SQRT delta P		AVE. TEMP.						
60 Min.											

* Check K factor to 4.

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim Theodore AL
 Sample Location Main Stack
 Run No. TD -M26A- ~~2B~~ 2A
 Filter Number(s) Not Applicable

Sample Date 2/1/24
 Recovery Date 2/1/24
 Recovered by SCS

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		766.1	779.5	671.2	770.7	742.7	978.4	g
Initial weight		765.0	755.4	661.2	764.1	740.9	960.7	g
Net weight		21.1	24.4	10.0	6.6	1.8	17.7	g

Description of impinger water clean 30 % spent
13/14 Sil gel color
 Total moisture = 81.6 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. TD -M26A-H2SO4- 2A

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. TD -M26A-NaOH 2A

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks _____

METHOD 26A FIELD DATA SHEET

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION			SAMPLE TYPE		RUN NUMBER		
Holcim: Terebore, AL		2/5/124		Method 26A			Method 26A		- ON OFF -M26A- 2-13		
OPERATOR		AMBIENT PRESS (In. Hg)		STATIC PRESSURE (in. Water)		AMBIENT TEMP (deg. F)		PITOT Cp		PROBE LENGTH AND LINER TYPE	
M. Powell		29.84		0.80		50		0.84		10 Effective / 6.5	
ASSUMED DGM MOISTURE BOX No. (%)		DGM H@		DGM CAL FACTOR (Y)		STACK THERM NO.		STACK PITOT NO.		K FACTOR	
7 MS-22		1.72		1.014		10.5		10.5		3.6	
TRAVERSE ELAPSED TEST TIME (MIN)		CLOCK TIME (24-HR)		DGM READING Vm (cu. ft.)		VELOCITY HEAD (In. H2O)		delta H ORIFICE (In. H2O)		PROBE TEMP (deg. F)	
A-1 0		1156		642.426		.96		3.5		252	
2 5				647.88		.87		3.1		251	
3 10				552.91		.59		3.1		255	
15		1211		656.487		End of Port		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg					
B-1 15		1214		656.987		.95		3.4		252	
2 20				662.02		.88		3.2		255	
3 25				667.03		.58		2.0		254	
30		1229		671.642		End of Port		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg					
C-1 30		1232		671.642		.95		3.4		254	
2 35				677.38		.88		3.2		252	
3 40				682.49		.59		3.1		250	
45		1247		687.492		End of Port		End of Port			
INTRA-PORT LEAK CHECK? DGM VOLUME (CU. FT)		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg					
D-1 45		1250		687.492		.94		3.4		240	
2 50				693.36		.89		3.2		261	
3 55				698.53		.60		2.0		251	
60		1305		703.016		End of Port		End of Port			
TOTAL TIME				DGM VOLUME		AVE SQRT delta P		AVE delta H		AVE. TEMP.	
60 Min.											
CO2 CONTENT %		7		16		7		7		7	
SI Gel EXIT TEMP (deg. F)		418		449		50		47		48	
SAMPLE TRAIN VAC (in. Hg)		6		6		4		6		4	
NOZZLE NUMBER		278		279		278		279		278	
DGM VOLUME (CU. FT) <td colspan="2">INITIAL FINAL</td> <td colspan="2">LEAK RATE: CU.FT @ CU.FT @</td> <td colspan="2">INCHES Hg INCHES Hg</td> <td colspan="2"></td> <td colspan="2"></td>		INITIAL FINAL		LEAK RATE: CU.FT @ CU.FT @		INCHES Hg INCHES Hg					
D-1 45		1250		687.492		.94		3.4		240	
2 50				693.36		.89		3.2		261	
3 55				698.53		.60		2.0		251	
60		1305		703.016		End of Port		End of Port			
TOTAL TIME				DGM VOLUME		AVE SQRT delta P		AVE delta H		AVE. TEMP.	
60 Min.											

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim; Theodore AL
 Sample Location Main Stack
 Run No. TD -M26A- 2B
 Filter Number(s) Not Applicable

Sample Date 2/1/24
 Recovery Date 2/1/24
 Recovered by SC

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		767.5	800.4	606.4	779.1	772.4	944.7	g
Initial weight		749.5	770.3	599.3	771.5	769.3	923.1	g
Net weight		18.0	30.1	7.1	7.6	3.1	21.6	g

Description of impinger water clear 30 % spent
BC Sil gel color
 Total moisture = 87.5 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. TD -M26A-H2SO4- 2B

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. TD -M26A-NaOH- 2B

Liquid level
 marked/sealed ☒

Samples stored and locked _____

Remarks _____

PAGE 1 of 1

✓

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim; Theodore AL
 Sample Location Main Stack
 Run No. TD -M26A- 3A
 Filter Number(s) Not Applicable

Sample Date 2/1/24
 Recovery Date 2/1/24
 Recovered by SC

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight	X	795.4	804.1	616.4	766.5	746.2	921.7	g
Initial weight	X	861.0	775.8	611.8	757.1	742.9	904.8	g
Net weight	X	34.4	28.3	4.6	9.4	3.3	17.0	g

Description of impinger water clear 90 % spent
B/W Sil gel color
 Total moisture = 97.0 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. TD -M26A-H2SO4- 3A

Liquid level
 marked/sealed ✓ 428.4

NaOH Impingers contents and water rinse
 container no. TD -M26A-NaOH- 3A

Liquid level
 marked/sealed ✓ 373.2

Samples stored and locked _____
 Remarks _____

PAGE 1 of 1

PLANT AND CITY		DATE		SAMPLING LOCATION			SAMPLE TYPE		RUN NUMBER	
HOLCIM:		21 01 124		Main Stack			Method 26A		ID- ON OFF -M26A- 3 13	
OPERATOR	AMBIENT PRESS (In. Hg)	STATIC PRESSURE (in. Water)	AMBIENT TEMP (deg. F)	FILTER NUMBERS	STACK ID (In.)	PITOT Cp	PROBE LENGTH AND LINER TYPE	NOZZLE	NUMBER	DIAMETER
M. Powell	29.56	-0.50	50	NA	204	0.84	10 effective / 6/4	279	279	0.278
ASSUMED MOISTURE (%)	DGM H@	DGM CAL FACTOR (Y)	STACK THERM NO.	STACK PITOT NO.	ORSAT NO.	LEAK CHECK (INITIAL)	LEAK CHECK (FINAL)	CO2 CONTENT %	K FACTOR	
7	1522	1.72	10 F	10 F	CEM NO.	0.001 CU. FT @ 10 "Hg	0.001 CU. FT @ 10 "Hg	16	4.0	
PITOT LEAK CHECK ---> PASSED										
TRAVERSE PORT/ POINT NO.	ELAPSED TEST TIME (MIN)	CLOCK TIME (24-HR)	DGM READING Vm (cu. ft.)	delta P VELOCITY HEAD (In. H2O)	delta H ORIFICE (In. H2O)	PROBE TEMP (deg. F)	STACK TEMP (deg. F)	DGM IN / OUT TEMP (deg. F)	FILTER OVEN TEMP (deg. F)	SIL GEL EXIT TEMP (deg. F)
A-1	0	1318	703.655	.93	3.7	250	259	79	250	417
2	5		708.92	.58	3.5	251	260	80	252	47
3	10		714.37	.59	2.4	252	259	81	253	418
15		1333	718.941							
INTRA-PORT LEAK CHECK?										
DGM VOLUME (CU. FT)		INITIAL	FINAL	LEAK RATE: CU. FT @ CU. FT @						
B-1	15	1336	718.441	.95	3.8	255	262	81	253	49
2	20		724.75	.87	3.5	253	265	82	255	50
3	25		729.45	.58	2.3	254	265	83	254	51
30		1351	733.679							
INTRA-PORT LEAK CHECK?										
DGM VOLUME (CU. FT)		INITIAL	FINAL	LEAK RATE: CU. FT @ CU. FT @						
C-1	30	1354	733.679	.94	3.8	250	263	83	251	51
2	35		739.12	.88	3.5	252	263	83	250	50
3	40		744.16	.59	2.4	254	263	84	252	42
45		1409	748.575							
INTRA-PORT LEAK CHECK?										
DGM VOLUME (CU. FT)		INITIAL	FINAL	LEAK RATE: CU. FT @ CU. FT @						
D-1	45	1412	748.575	.95	3.8	253	259	85	253	47
2	50		752.81	.89	3.6	255	261	86	253	46
3	55		758.31	.59	2.4	251	260	87	259	46
60		1427	763.405							
End of Port										
TOTAL TIME		DGM VOLUME		AVE SQRT delta P		AVE. TEMP.		AVE. TEMP.		
60 Min.										

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim; Theodore AL
 Sample Location Main Stack
 Run No. TD -M26A- 313
 Filter Number(s) Not Applicable

Sample Date 2/1/24
 Recovery Date 2/1/24
 Recovered by SC

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		778.2	798.3	661.4	761.7	777.9	1022.8	g
Initial weight		755.9	766.3	648.2	755.4	775.4	1001.5	g
Net weight		22.3	32.0	13.2	6.3	2.1	21.3	g

Description of impinger water clean 35 % spent
13/4 Sil gel color
 Total moisture = 94.2 grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. TD -M26A-H2SO4- 313

Liquid level
 marked/sealed ☒ 462.3

NaOH Impingers contents and water rinse
 container no. TD -M26A-NaOH- 313

Liquid level
 marked/sealed ☒ 386.8

Samples stored and locked _____
 Remarks _____

EPA METHOD 26A RECOVERY AND INTEGRITY DATA SHEET

Plant Holcim; Theodore AL
 Sample Location Main Stack
 Run No. TD -M26A-Field Blank
 Filter Number(s) Not Applicable

Sample Date 2/1/24
 Recovery Date 2/1/24
 Recovered by SLJ

MOISTURE

Impingers	1 50 ml 0.1N H ₂ SO ₄ (knockout)	2 100 ml 0.1N H ₂ SO ₄ (tipped)	3 100 ml 0.1N H ₂ SO ₄ (tipped)	4 Optional Knockout (untipped)	5 100 ml 0.1N NaOH (untipped)	6 100 ml 0.1N NaOH (untipped)	Silica gel (untipped)	
Final weight		736.4	749.9	666.1	744.1	755.8	975.4	g
Initial weight		736.4	749.9	666.2	744.2	755.7	975.2	g
Net weight								g

Description of impinger water clear 15 % spent
B/U Sil gel color
 Total moisture = _____ grams

RECOVERED SAMPLE

H₂SO₄ Impingers and knockout contents and water rinse
 container no. TD -M26A-H2SO4- FB

Liquid level
 marked/sealed ☒

NaOH Impingers contents and water rinse
 container no. TD -M26A-NaOH- FB

Liquid level
 marked/sealed ☒

Samples stored and locked _____
 Remarks From Train 1A

Client: Holcim Theodore AL
 Test Location: Kiln Main Stack
 Date: Feb 01 24 Start Time: 10:26:30
 Run number 1
 One Minute Averages

	O2 %,dry	CO2 %,dry
10:27:28 AM	17.0	6.6
10:28:28 AM	17.1	6.3
10:29:28 AM	17.0	6.4
10:30:28 AM	17.1	6.3
10:31:28 AM	17.1	6.5
10:32:28 AM	16.7	7.4
10:33:28 AM	16.5	7.7
10:34:28 AM	16.0	8.4
10:35:28 AM	16.1	8.1
10:36:28 AM	16.6	7.3
10:37:28 AM	17.0	6.8
10:38:28 AM	17.0	6.6
10:39:28 AM	16.8	6.9
10:40:28 AM	16.6	7.3
10:41:28 AM	16.2	8.1
10:42:28 AM	16.1	8.1
10:43:28 AM	16.2	7.9
10:44:28 AM	16.3	7.7
10:45:28 AM	16.7	7.0
10:46:28 AM	17.2	6.2
10:47:28 AM	17.1	6.3
10:48:28 AM	17.0	6.6
10:49:28 AM	16.8	6.9
10:50:28 AM	16.4	7.8
10:51:28 AM	16.1	8.2
10:52:28 AM	15.9	8.5
10:53:28 AM	16.2	7.9
10:54:28 AM	16.8	6.9
10:55:28 AM	17.3	6.0
10:56:28 AM	17.3	5.8
10:57:28 AM	17.3	6.0
10:58:28 AM	17.1	6.3
10:59:28 AM	16.8	7.0
11:00:28 AM	16.8	7.1
11:01:28 AM	16.7	7.5
11:02:28 AM	16.2	8.3
11:03:28 AM	16.3	8.2
11:04:28 AM	16.2	8.4
11:05:28 AM	16.4	8.1
11:06:28 AM	16.5	7.7
11:07:28 AM	16.7	7.1
11:08:28 AM	16.7	7.0
11:09:28 AM	16.4	7.6
11:10:28 AM	16.4	7.7
11:11:28 AM	16.5	7.7
11:12:28 AM	16.2	8.1
11:13:28 AM	16.3	7.9
11:14:28 AM	16.3	7.8
11:15:28 AM	16.6	7.1
11:16:28 AM	16.9	6.8
11:17:28 AM	16.9	6.7
11:18:28 AM	17.3	6.1
11:19:28 AM	16.8	6.9
11:20:28 AM	16.6	7.4
11:21:28 AM	16.9	7.0
11:22:28 AM	16.5	7.6
11:23:28 AM	16.4	7.8
11:24:28 AM	16.3	7.9
11:25:28 AM	16.3	7.7
11:26:28 AM	16.6	7.1
Run Avgs	16.6	7.3
Cal Gas	12.1	10.1
Initial Zero	0.3	0.1
Final Zero	0.5	0.2
Initial cal.	12.1	9.9
Final Cal.	12.3	10.0
Corrected Average	16.6	7.3

Client: Holcim Theodore AL
 Test Location: Kiln Main Stack
 Date: Feb 01 24 Start Time: 11:56:04
 Run number 2
 One Minute Averages

	O2 %,dry	CO2 %,dry
11:57:02 AM	16.3	8.1
11:58:02 AM	16.2	8.1
11:59:02 AM	16.4	7.8
12:00:02 PM	16.8	7.3
12:01:02 PM	17.1	6.9
12:02:02 PM	17.3	6.3
12:03:02 PM	17.1	6.6
12:04:02 PM	16.8	7.3
12:05:02 PM	16.6	7.6
12:06:02 PM	16.3	7.9
12:07:02 PM	16.6	7.5
12:08:02 PM	17.0	6.7
12:09:02 PM	17.5	5.9
12:10:02 PM	17.5	5.7
12:11:02 PM	17.4	6.0
12:12:02 PM	17.1	6.5
12:13:02 PM	16.5	7.7
12:14:02 PM	16.3	8.0
12:15:02 PM	16.5	7.7
12:16:02 PM	16.8	7.2
12:17:02 PM	17.3	6.3
12:18:02 PM	17.4	6.0
12:19:02 PM	17.6	5.5
12:20:02 PM	17.4	5.9
12:21:02 PM	17.3	6.2
12:22:02 PM	17.0	6.8
12:23:02 PM	16.3	8.2
12:24:02 PM	16.3	8.1
12:25:02 PM	16.3	8.2
12:26:02 PM	16.4	7.9
12:27:02 PM	17.1	6.9
12:28:02 PM	17.3	6.5
12:29:02 PM	17.4	6.2
12:30:02 PM	17.2	6.3
12:31:02 PM	16.7	7.3
12:32:02 PM	16.5	7.9
12:33:02 PM	16.0	8.7
12:34:02 PM	16.0	8.5
12:35:02 PM	16.4	7.9
12:36:02 PM	17.1	6.8
12:37:02 PM	17.3	6.5
12:38:02 PM	17.4	6.0
12:39:02 PM	17.5	5.9
12:40:02 PM	17.3	6.0
12:41:02 PM	17.1	6.5
12:42:02 PM	16.7	7.4
12:43:02 PM	16.6	7.6
12:44:02 PM	16.5	7.9
12:45:02 PM	16.4	8.0
12:46:02 PM	16.5	7.9
12:47:02 PM	16.7	7.6
12:48:02 PM	16.7	7.8
12:49:02 PM	16.6	7.9
12:50:02 PM	16.5	8.0
12:51:02 PM	16.1	8.4
12:52:02 PM	16.2	8.3
12:53:02 PM	16.4	7.8
12:54:02 PM	17.1	6.6
12:55:02 PM	17.3	6.0
12:56:02 PM	17.3	6.2
Run Avgs	16.8	7.2
Cal Gas	12.1	10.1
Initial Zero	0.5	0.2
Final Zero	0.6	0.2
Initial cal.	12.3	10.0
Final Cal.	12.4	10.0
Corrected Average	16.7	7.2

Client: Holcim Theodore AL
 Test Location: Kiln Main Stack
 Date: Feb 01 24 Start Time: 13:18:04
 Run number 3
 One Minute Averages

	O2 %,dry	CO2 %,dry
1:19:02 PM	16.8	6.4
1:20:02 PM	16.5	7.0
1:21:02 PM	16.3	7.5
1:22:02 PM	16.0	8.0
1:23:02 PM	15.9	8.4
1:24:02 PM	15.5	9.1
1:25:02 PM	15.6	8.8
1:26:02 PM	16.4	7.3
1:27:02 PM	16.9	6.3
1:28:02 PM	16.9	6.2
1:29:02 PM	16.8	6.3
1:30:02 PM	16.6	6.8
1:31:02 PM	16.4	7.2
1:32:02 PM	16.4	7.3
1:33:02 PM	16.2	7.8
1:34:02 PM	15.9	8.2
1:35:02 PM	15.9	8.1
1:36:02 PM	16.0	7.8
1:37:02 PM	16.3	7.1
1:38:02 PM	16.8	6.1
1:39:02 PM	16.8	6.1
1:40:02 PM	16.7	6.4
1:41:02 PM	16.4	7.0
1:42:02 PM	16.4	7.1
1:43:02 PM	16.4	7.1
1:44:02 PM	16.2	7.6
1:45:02 PM	16.1	7.7
1:46:02 PM	16.1	7.6
1:47:02 PM	16.0	7.6
1:48:02 PM	16.1	7.4
1:49:02 PM	16.3	7.1
1:50:02 PM	16.6	6.6
1:51:02 PM	16.5	6.8
1:52:02 PM	16.2	7.4
1:53:02 PM	16.2	7.3
1:54:02 PM	16.1	7.7
1:55:02 PM	16.0	7.8
1:56:02 PM	15.8	8.0
1:57:02 PM	16.0	7.6
1:58:02 PM	16.5	6.8
1:59:02 PM	16.8	6.2
2:00:02 PM	16.6	6.6
2:01:02 PM	16.6	6.7
2:02:02 PM	16.5	7.0
2:03:02 PM	16.3	7.3
2:04:02 PM	16.0	7.8
2:05:02 PM	15.9	7.9
2:06:02 PM	15.7	8.1
2:07:02 PM	16.1	7.6
2:08:02 PM	16.7	6.5
2:09:02 PM	16.9	6.2
2:10:02 PM	16.7	6.4
2:11:02 PM	16.7	6.4
2:12:02 PM	16.3	7.2
2:13:02 PM	16.1	7.5
2:14:02 PM	16.0	7.7
2:15:02 PM	16.2	7.3
2:16:02 PM	16.5	6.9
2:17:02 PM	16.4	7.2
2:18:02 PM	16.5	7.1
Run Avgs	16.3	7.2
Cal Gas	12.1	10.1
Initial Zero	0.3	0.1
Final Zero	0.3	0.1
Initial cal.	12.1	9.8
Final Cal.	12.1	9.9
Corrected Average	16.4	7.4

Holcim
Theodore AL
Kiln Main Stack
HCN Analyte Spikes

Date		02/01/24	02/01/24	02/01/24	02/01/24
Time		08:02-08:19	11:28--11:46	12:59-13:18	14:21-14:46
		Pre Run 1	Post Run 1	Post Run 2	Post Run 3
CC768222		HCN	HCN	HCN	HCN
Cs	Spike Direct, ppm	48.31	48.31	48.31	48.31
	SF6 Tracer Direct, ppm	4.78	4.78	4.78	4.78
SF6	Diluted SF6 Tracer, ppm	0.379	0.315	0.298	0.298
	Diluted SF6 Tracer, ppm	0.371	0.302	0.289	0.288
	Average Diluted SF6 Tracer, ppm	0.375	0.309	0.294	0.293
DF	Dilution Ratio	12.73	15.48	16.27	16.30
Ct	Total, ppm	4.337	4.043	3.730	3.486
	Total, ppm	4.180	4.345	3.638	3.440
	Average Total, ppm	4.259	4.194	3.684	3.463
Cn	Pre Spike Native , ppm	0.569	0.603	0.956	0.631
	Pre Spike Native , ppm	0.565	0.631	0.867	0.663
	Post Spike Native , ppm	0.557	0.544	0.586	0.404
	Post Spike Native , ppm	0.554	0.689	0.596	0.479
	Average Native , ppm	0.561	0.617	0.751	0.544
	Spike Recovery	98.6%	115.9%	100.3%	99.6%
CTS Direct (CC426155)					
Ethylene Expected (ppm)		75.47			75.48
Ethylene Measured (ppm)		72.72			72.27
CTS Error		-3.6%			-4.3%

Holcim; Theodore AL
 Kiln Main Stack; Dryers On
 Pre Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__156840.LAB	02/01/24	08:02:01.254	0.569	0.247	0.005
SPC__156841.LAB	02/01/24	08:03:05.387	0.565	0.265	0.006
SPC__156842.LAB	02/01/24	08:04:08.985	0.173	0.249	0.007
SPC__156843.LAB	02/01/24	08:05:12.888	0.467	0.282	-0.001
SPC__156844.LAB	02/01/24	08:06:16.780	0.589	0.227	0.002
SPC__156845.LAB	02/01/24	08:07:20.641	3.961	0.243	0.218
SPC__156846.LAB	02/01/24	08:08:24.549	4.337	0.212	0.379
SPC__156847.LAB	02/01/24	08:09:28.489	4.180	0.207	0.371
SPC__156848.LAB	02/01/24	08:10:32.648	6.974	0.193	0.556
SPC__156849.LAB	02/01/24	08:11:36.226	0.363	0.014	0.006
SPC__156850.LAB	02/01/24	08:12:40.117	0.155	0.025	-0.000
SPC__156851.LAB	02/01/24	08:13:44.031	-0.042	0.095	0.001
SPC__156852.LAB	02/01/24	08:14:47.935	0.326	0.225	0.004
SPC__156853.LAB	02/01/24	08:15:51.827	0.377	0.216	0.003
SPC__156854.LAB	02/01/24	08:16:55.797	0.349	0.200	0.005
SPC__156855.LAB	02/01/24	08:17:59.633	0.557	0.205	0.005
SPC__156856.LAB	02/01/24	08:19:03.525	0.554	0.202	0.004

Holcim; Theodore AL

Kiln Main Stack; Dryers On

Post Run 1 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__157031.LAB	02/01/24	11:25:25.570	0.603	-0.005	0.001
SPC__157032.LAB	02/01/24	11:26:29.436	0.631	-0.005	0.001
SPC__157033.LAB	02/01/24	11:27:33.361	0.836	-0.010	0.005
SPC__157034.LAB	02/01/24	11:28:37.300	3.307	-0.006	0.130
SPC__157035.LAB	02/01/24	11:29:41.120	4.043	0.010	0.315
SPC__157036.LAB	02/01/24	11:30:45.348	4.345	0.003	0.302
SPC__157037.LAB	02/01/24	11:31:49.196	6.433	-0.022	0.496
SPC__157038.LAB	02/01/24	11:32:53.138	1.012	-0.032	0.002
SPC__157039.LAB	02/01/24	11:33:56.811	0.687	-0.001	0.005
SPC__157040.LAB	02/01/24	11:35:00.762	-0.205	-0.004	0.001
SPC__157041.LAB	02/01/24	11:36:04.581	0.148	-0.007	0.001
SPC__157042.LAB	02/01/24	11:37:08.382	0.133	-0.026	-0.010
SPC__157043.LAB	02/01/24	11:38:12.279	-0.187	-0.032	-0.006
SPC__157044.LAB	02/01/24	11:39:16.246	-0.198	-0.025	-0.009
SPC__157045.LAB	02/01/24	11:40:20.419	0.138	-0.034	-0.006
SPC__157046.LAB	02/01/24	11:41:24.015	1.159	-0.003	0.002
SPC__157047.LAB	02/01/24	11:42:28.212	0.671	0.058	0.002
SPC__157048.LAB	02/01/24	11:43:31.808	0.824	0.034	0.005
SPC__157049.LAB	02/01/24	11:44:36.037	0.544	0.014	0.005
SPC__157050.LAB	02/01/24	11:45:39.666	0.689	0.025	0.002

Holcim; Theodore AL

Kiln Main Stack; Dryers On

Post Run 2 HCN Analyte Spike

Spectrum	Date	Time	HCN (200) PCA 191C 191c	HF ppm (10) 191C	SF6 (10) 191C
SPC__157118.LAB	02/01/24	12:58:30.496	0.956	0.018	-0.001
SPC__157119.LAB	02/01/24	12:59:34.675	0.867	-0.007	-0.003
SPC__157120.LAB	02/01/24	13:00:38.287	0.973	0.037	0.002
SPC__157121.LAB	02/01/24	13:01:42.182	2.458	0.026	0.076
SPC__157122.LAB	02/01/24	13:02:46.086	4.012	0.023	0.307
SPC__157123.LAB	02/01/24	13:03:49.976	3.730	-0.013	0.298
SPC__157124.LAB	02/01/24	13:04:54.011	3.638	-0.008	0.289
SPC__157125.LAB	02/01/24	13:05:57.777	2.016	-0.024	0.119
SPC__157126.LAB	02/01/24	13:07:01.694	3.190	0.006	0.278
SPC__157127.LAB	02/01/24	13:08:05.581	0.156	0.003	0.003
SPC__157128.LAB	02/01/24	13:09:09.483	0.009	-0.051	-0.007
SPC__157129.LAB	02/01/24	13:10:13.344	0.049	-0.002	-0.005
SPC__157130.LAB	02/01/24	13:11:17.333	1.100	-0.045	0.001
SPC__157131.LAB	02/01/24	13:12:21.479	0.821	0.024	0.003
SPC__157132.LAB	02/01/24	13:13:25.040	0.586	0.019	0.003
SPC__157135.LAB	02/01/24	13:17:58.181	0.596	0.044	0.044

Holcim; Theodore AL
 Kiln Main Stack; Dryers On
 Post Run 3 HCN Analyte Spike and CTS

Spectrum	Date	Time	HCN (200) PCA 191C 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__157194.LAB	02/01/24	14:20:48.143	0.631	0.011	0.002	0.704
SPC__157195.LAB	02/01/24	14:21:51.852	0.663	-0.005	0.002	0.780
SPC__157196.LAB	02/01/24	14:22:55.748	0.347	-0.028	-0.004	0.790
SPC__157197.LAB	02/01/24	14:23:59.650	0.084	-0.030	0.001	0.769
SPC__157198.LAB	02/01/24	14:25:03.933	0.537	-0.020	-0.003	0.727
SPC__157199.LAB	02/01/24	14:26:07.436	2.944	-0.046	0.215	0.695
SPC__157200.LAB	02/01/24	14:27:11.338	3.486	-0.032	0.298	0.530
SPC__157201.LAB	02/01/24	14:28:15.228	3.440	-0.054	0.288	0.620
SPC__157202.LAB	02/01/24	14:29:19.292	6.269	-0.033	0.509	0.566
SPC__157203.LAB	02/01/24	14:30:23.014	0.253	0.023	0.003	0.052
SPC__157204.LAB	02/01/24	14:31:26.904	-0.017	0.012	0.004	0.041
SPC__157205.LAB	02/01/24	14:32:30.806	-0.091	-0.018	-0.009	0.097
SPC__157206.LAB	02/01/24	14:33:34.706	-0.139	-0.054	-0.008	0.142
SPC__157207.LAB	02/01/24	14:34:38.603	0.676	-0.039	0.001	0.553
SPC__157208.LAB	02/01/24	14:35:42.500	0.336	-0.028	0.001	0.723
SPC__157209.LAB	02/01/24	14:36:46.399	0.419	-0.044	-0.000	0.690
SPC__157210.LAB	02/01/24	14:37:50.324	0.404	-0.010	-0.000	0.346
SPC__157211.LAB	02/01/24	14:38:54.173	0.479	0.024	0.000	0.027
SPC__157212.LAB	02/01/24	14:39:58.073	0.096	-0.002	0.002	0.081
SPC__157213.LAB	02/01/24	14:41:01.963	0.026	0.005	-0.007	10.259
SPC__157214.LAB	02/01/24	14:42:05.983	0.005	-0.003	-0.011	72.358
SPC__157215.LAB	02/01/24	14:43:09.760	-0.025	0.004	-0.014	72.908
SPC__157216.LAB	02/01/24	14:44:13.652	-0.018	0.013	-0.010	72.281
SPC__157217.LAB	02/01/24	14:45:17.547	-0.233	-0.006	-0.009	72.379
SPC__157218.LAB	02/01/24	14:46:21.447	-0.168	0.001	-0.011	72.162

Holcim; Theodore AL

Main Stack

CTS and HCN Analyte Spike Direct

Spectrum	Date	Time	HCN (200) PCA 191C 191c	HF ppm (10) 191C	SF6 (10) 191C	Ethylene (100,3000) 191C
SPC__156787BKG.LAB	02/01/24	07:54:33.196	0.000	0.000	0.000	0.000
SPC__156788BKG.LAB	02/01/24	06:57:42.676	0.000	0.000	0.000	0.000
SPC__156789.LAB	02/01/24	06:58:52.684	0.006	-0.005	0.001	-0.043
SPC__156790BKG.LAB	02/01/24	07:01:34.489	0.000	0.000	0.000	0.000
SPC__156791.LAB	02/01/24	07:02:44.197	0.008	0.010	0.001	0.071
SPC__156792.LAB	02/01/24	07:03:48.203	0.082	0.008	-0.019	29.421
SPC__156793.LAB	02/01/24	07:04:51.998	-0.013	-0.008	-0.012	72.612
SPC__156794.LAB	02/01/24	07:05:55.897	-0.034	0.001	-0.010	72.328
SPC__156795.LAB	02/01/24	07:06:59.801	-0.003	-0.002	-0.011	72.701
SPC__156796.LAB	02/01/24	07:08:03.697	-0.080	0.001	-0.013	72.730
Ethylene CTS (CC426155)						72.716
SPC__156797.LAB	02/01/24	07:09:07.595	20.579	0.017	2.026	33.972
SPC__156798.LAB	02/01/24	07:10:11.505	47.032	0.000	4.770	-0.557
SPC__156799.LAB	02/01/24	07:11:15.434	47.503	0.001	4.759	-0.492
SPC__156800.LAB	02/01/24	07:12:19.332	47.771	0.007	4.766	-0.477
SPC__156801.LAB	02/01/24	07:13:23.202	48.271	0.005	4.776	-0.543
SPC__156802.LAB	02/01/24	07:14:27.121	48.304	0.004	4.769	-0.443
SPC__156803.LAB	02/01/24	07:15:31.029	48.324	0.000	4.781	-0.529
SPC__156804.LAB	02/01/24	07:16:34.933	48.175	-0.008	4.780	-0.534
HCN Analyte Spike (CC768222)			48.268		4.776	

Appendix C

Ion Chromatography Analytical Report Data


Deeco, Inc.
3404 Lake Woodard Drive
Raleigh, NC 27604

Project ID: 24-3328
Holcim Theodore

Hydrogen Fluoride & Chlorine

EPA Method 26A Analysis


Analytical Report
41983



Element One, Inc.
6319-D Carolina Beach Rd., Wilmington, NC 28412
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 41983
has been reviewed for completeness, accuracy,
adherence to method protocol,
and compliance with quality assurance guidelines.

Review by:



Linda Ann Webb, M.S. Analytical Chemist
February 14, 2024

Report Reviewed and Finalized by:



Ken Smith, Laboratory Director
February 14, 2024

SUMMARY OF RESULTS

Summary of Analysis

Summary of Method 26A Analysis

Element	TD- M26A-R1A e41983-1 Total mg	TD- M26A-R2A e41983-2 Total mg	TD- M26A-R3A e41983-3 Total mg
HF	< 0.232	< 0.236	< 0.225
Cl ₂	0.246	0.191	0.201

Element	TD- M26A-R1B e41983-4 Total mg	TD- M26A-R2B e41983-5 Total mg	TD- M26A-R3B e41983-6 Total mg
HF	< 0.245	< 0.243	< 0.243
Cl ₂	0.225	< 0.190	0.200

Element	TD- M26A-FB e41983-7 Total mg
HF	< 0.201
Cl ₂	< 0.171

ANALYTICAL NARRATIVE

Element One Analytical Narrative

Client:	Deeco, Inc.	Element One #:	41983
Client ID:	24-3328 Holcim Theodore, AL	Analyst:	LAW, MNB
Method:	M26A	Dates Received:	02.05.24
Analytes:	HF, Cl ₂	Dates Analyzed:	02.08-12.24

Summary of Analysis

The samples were prepared and analyzed according to Method 26A protocol. The samples were analyzed for fluoride and chloride on Metrohm 861/778 and 881/858 ion chromatograph systems respectively.

Detection Limits

The Metrohm reporting limit was 0.1 µg/mL for fluoride and chloride.

Analysis QA/QC

Duplicate analyses relative percent difference (RPD), spike recovery and second source verification data are summarized in the Quality Control section. All QA/QC data was within the criteria of the method.

Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. Due to the sample matrix, it was necessary to analyze all samples at a minimum five-fold dilution to reduce interferences and to preserve the anion column. The reported results relate only to the items tested or calibrated.

QUALITY CONTROL SUMMARY

Summary of Quality Control Data

Summary of Method 26A Duplicate Analysis RPD

(Method 26A QC limits: <5% for RPD)

Element	TD- M26A-R1A RPD	TD- M26A-R2A RPD	TD- M26A-R3A RPD
HF	NA	NA	NA
Cl ₂	0.7%	0.9%	0.9%

Element	TD- M26A-R1B RPD	TD- M26A-R2B RPD	TD- M26A-R3B RPD
HF	NA	NA	NA
Cl ₂	0.8%	NA	1.0%

Element	TD- M26A-FB RPD
HF	NA
Cl ₂	NA

Summary of Method 26A Spike Recoveries

(Method 26A QC limits: 90-110% for Spike Recoveries)

Element	TD- M26A-R3A Recovery	TD- M26A-R3B Recovery
HF	106%	108%
Cl ₂	102%	105%

Second Source Calibration Verification

(*Laboratory QC limits: 90-110%)

Element	DL 0.1mg/L Recovery	*QC 5.0mg/L Recovery
HF	109%	99%
Cl ₂	106%	103%

elementOne

Certification: NJ NELAP NC009
41983 Deeco M26A Report Packet
Page 8 of 26

SAMPLE CUSTODY

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285		Date: 02/5/24 Lab: Element One Train: EPA Method 26A		41983
Project Name: 24-3328				
Plant Location: Theodore, AL				
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time	Comments
<i>Mike Morris</i>	2/5/24	<i>Lucia B. Burt</i>	2-5-24	
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time	Comments
Relinquished by: (Signature)	Date/Time	Received by: (Signature)	Date/Time	Comments
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train
TD-1A-H ₂ SO ₄	02/01/24	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A
				0.1N H ₂ SO ₄ and DI Rinses
TD-1A-NaOH	02/01/24	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A
				0.1N NaOH and DI Rinses
TD-1B-H ₂ SO ₄	02/01/24	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A
				0.1N H ₂ SO ₄ and DI Rinses
TD-1B-NaOH	02/01/24	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A
				0.1N NaOH and DI Rinses
TD-2A-H ₂ SO ₄	02/01/24	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A
				0.1N H ₂ SO ₄ and DI Rinses
TD-2A-NaOH	02/01/24	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A
				0.1N NaOH and DI Rinses
				Final Volume 440.3 mL
				Final Volume 353.0 mL
				Sodium thiosulfate not added
				Final Volume 465.3 mL
				Final Volume 367.2 mL
				Sodium thiosulfate not added
				Final Volume 449.0 mL
				Final Volume 352.4 mL
				Sodium thiosulfate not added
				Element One
				Element One
				Element One
				Element One
				Element One
				Element One

Samples received in good condition in ENV. Express containers. No empty containers.

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285										41983 Date: 02/5/24 Lab: Element One Train: EPA Method 26A	
Plant Name: Holcim Relinquished by: (Signature) _____ Date/Time _____ Relinquished by: (Signature) _____ Date/Time _____ Relinquished by: (Signature) _____ Date/Time _____										Project Name: 24-3328 Comments	
Plant Location: Theodore, AL Received by: (Signature) _____ Date/Time 2.5.24 Received by: (Signature) _____ Date/Time _____ Received by: (Signature) _____ Date/Time _____										Comments Comments	
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab				
TD-2B-H ₂ SO ₄	02/01/24	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 461.1 mL	Element One				
TD-2B-NaOH	02/01/24	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 379.5 mL Sodium thiosulfate not added	Element One				
TD-3A-H ₂ SO ₄	02/01/24	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 428.4 mL	Element One				
TD-3A-NaOH	02/01/24	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 373.0 mL Sodium thiosulfate not added	Element One				
TD-3B-H ₂ SO ₄	02/01/24	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 462.3 mL	Element One				
TD-3B-NaOH	02/01/24	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 386.1 mL Sodium thiosulfate not added	Element One				

DEECO, Inc 3404 Lake Woodard Dr. Raleigh, NC 27604 919-250-0285				41983 Date: 02/5/24 Lab: Element One Train: EPA Method 26A			
Plant Name: Holcim Relinquished by: (Signature) <i>[Signature]</i>				Project Name: 24-3328 Comments			
Plant Location: Theodore, AL Received by: (Signature) <i>[Signature]</i>				Date/Time: 2.5.24			
Relinquished by: (Signature)				Date/Time			
Relinquished by: (Signature)				Date/Time			
Relinquished by: (Signature)				Date/Time			
Field Sample No.	Date	Composite or Grab	Analysis Required	Sampling Train	Sample Description	Special Notes	Lab
TD-FB-H ₂ SO ₄	02/01/24	Comp.	Fluoride ion as Hydrogen Fluoride	EPA Method 26A	0.1N H ₂ SO ₄ and DI Rinses	Final Volume 382.3 mL	Element One
TD-FB-NaOH	02/01/24	Comp.	Chloride ion as Diatomic Chlorine	EPA Method 26A	0.1N NaOH and DI Rinses	Final Volume 341.5 mL Sodium thiosulfate not added	Element One

ANALYTICAL DATA

Analytical Calculations

HF -

$$\text{Total HX (mg)} = \frac{[\text{X Results } (\mu\text{g/mL}) * \text{Dilution} * \text{Beginning Vol (mL)}] * \text{Correction Factor}}{1000}$$

Where-

X Results= Raw sample concentration (ppm) — *IC Data Sheet*

Dilution= $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ — *IC Run Sheet*

Beginning Volume--*Sample Submission*

1.053= Correction factor for hydrogen fluoride

Cl₂ -

$$\text{Total X}_2 \text{ (mg)} = \frac{\text{X Results } (\mu\text{g/mL}) * \text{Dilution} * \text{Beginning Volume (mL)}}{1000}$$

Where-

X Results= Raw sample concentration (ppm)—*Cl₂ IC Data Sheet*

Dilution= $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ — *IC Run Sheet*

Beginning Volume--*Sample Submission*

Analytical Calculations

Spike Recovery-

$$\text{Spike (\%)} = \frac{(\text{Spiked Result } (\mu\text{g/mL}) - \text{Sample Result } (\mu\text{g/mL}))}{\text{Spike Amount } (\mu\text{g/mL})} \times 100$$

Where-

Spike Result = Raw sample concentration (ppm)--*IC-Data Sheet*

Sample Result = Raw sample concentration (ppm)--*IC-Data Sheet*

Spike Amount—*IC-Data Sheet*

Duplicate Analysis RPD-

$$\text{RPD (\%)} = \frac{(\text{Duplicate Result } (\mu\text{g/mL}) - \text{Sample Result } (\mu\text{g/mL}))}{\text{Average } (\mu\text{g/mL})} \times 100$$

Where-

Sample Result and Duplicate Results=Raw sample concentration (ppm)--*IC-Data Sheet*

$$\text{Average} = \frac{(\text{Duplicate} + \text{Sample Results})}{2}$$

elementOne

AIR TESTING SAMPLE SUBMISSION FORM

Lab ID 41983

Analysis Due Date 02.13.24
QA/QC/Report Due Date 02.15.24Client: Deeco, Inc.
Project No 24-3328Date Rec 02.05.24
Time Rec 1100

Volume Marked	Volume Loss	FH pH < 2	BH pH > 8	Ref. Method:
Y N	Y N ?	Y N	Y N	26A

Sample Identification

1	TD-M26A-R1A	4	TD-M26A-R1B	7	TD-M26A-FB
2	TD-M26A-R2A	5	TD-M26A-R2B		
3	TD-M26A-R3A	6	TD-M26A-R3B		
	TD-M26A-R3A Spike		TD-M26A-R3B Spike		

Analyses Requested

Samples 1-7 HF
Samples 1-7 Cl₂

Runs/FB

Lab ID	FH Impinger 1 (or Combined Imp)		FH Impinger 2		FH Impinger 3		BH Impinger 4 (or Combined Imp)		BH Impinger 5	
	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
1	440.3						353.0			
2	449.0						352.4			
3.S	428.4						373.0			
4	465.3						367.2			
5	461.1						379.5			
6.S	462.3						386.1			
7	382.3						341.5			

Reagent Blanks

Lab ID	Fractions	BV, ml	FV, ml	Notes
	0.1 N H ₂ SO ₄			
	0.1 N NaOH			
	DI H ₂ O			

Lab Communications

Volumes on COC

Rec Runs/FB: H2SO4; NaOH; No RB received---02.05.24 LLB

SS Page 1 of 1
SS by XXB
2/5/2024 3:38:22 PMImp 1, 2, & 3 Prep By / Date 02.07.24 MNB
Imp 4 & 5 Prep By / Date 02.09.24 LM
Labeled By/Date LM 02.05.24
ID Verification By/Date PPC 2.6.24

elementOne

Certification: NJ NELAP NC009
41983 Deeco M26A Report Packet
Page 16 of 26

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41983

Client: Deeco

Column: IonPac AS14A

Date: 02.13.24

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

F⁻ to HF factor: 1.053

Sample ID	F ⁻ µg/ml	Dilution	Final Vol, ml	HF, Total mg	Spike, µg/ml	% Recovery/ RPD	File Name	Date Time
LRB	0.025	1	10	< 0.001			_2024-02-08_	2/8/2024 14:31
LRB	0.025	1	10	< 0.001		NA	_2024-02-08_	2/8/2024 14:51
LRB SPK	5.039	1	10	0.053	5.00	100%	_2024-02-08_	2/8/2024 15:12
LRB SPK	5.102	1	10	0.054	5.00	102%	_2024-02-08_	2/8/2024 15:33
41983-1	0.025	5	440.3	< 0.232			_2024-02-08_	2/8/2024 15:54
41983-1 DUP	0.022	5	440.3	< 0.232		NA	_2024-02-08_	2/8/2024 16:14
41983-2	0.028	5	449.0	< 0.236			_2024-02-08_	2/8/2024 16:35
41983-2 DUP	0.034	5	449.0	< 0.236		NA	_2024-02-08_	2/8/2024 16:56
41983-3	0.000	5	428.4	< 0.225			_2024-02-08_	2/8/2024 19:21
41983-3 DUP	0.020	5	428.4	< 0.225		NA	_2024-02-08_	2/8/2024 19:42
41983-3 SPK	5.253	5	428.4	11.8	5.00	105%	_2024-02-08_	2/8/2024 20:02
41983-3 SPK DUP	5.350	5	428.4	12.1	5.00	107%	_2024-02-08_	2/8/2024 20:23
41983-4	0.022	5	465.3	< 0.245			_2024-02-08_	2/8/2024 17:17
41983-4 DUP	0.021	5	465.3	< 0.245		NA	_2024-02-08_	2/8/2024 17:37
41983-5	0.030	5	461.1	< 0.243			_2024-02-08_	2/8/2024 20:44
41983-5 DUP	0.025	5	461.1	< 0.243		NA	_2024-02-08_	2/8/2024 21:05
41983-6	0.024	5	462.3	< 0.243			_2024-02-08_	2/8/2024 21:25
41983-6 DUP	0.021	5	462.3	< 0.243		NA	_2024-02-08_	2/8/2024 21:46
41983-6 SPK	5.360	5	462.3	13.0	5.00	107%	_2024-02-08_	2/8/2024 22:07
41983-6 SPK DUP	5.410	5	462.3	13.2	5.00	108%	_2024-02-08_	2/8/2024 22:28
41983-7 FB	0.000	5	382.3	< 0.201			_2024-02-12_	2/12/2024 19:34
41983-7 FB DUP	0.000	5	382.3	< 0.201		NA	_2024-02-12_	2/12/2024 19:55

HF Data 1 of 2

elementOne
e 41983-HF

elementOne

elementOne

M26A-HF IC Data Sheet

Lab ID #: 41983

Client: Deeco

Column: IonPac AS14A

Date: 02.13.24

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

F⁻ to HF factor: 1.053

Standards	F ⁻ µg/ml	Dilution	QC, µg/ml	% Relative Error	% Recovery	File Name	Date Time
0	0.000					_2024-02-07_	2/7/2024 15:26
0.1	0.103			3.0%	103%	_2024-02-07_	2/7/2024 15:47
1	0.952			-4.8%	95%	_2024-02-07_	2/7/2024 16:08
3	3.023			0.8%	101%	_2024-02-07_	2/7/2024 16:28
5	5.051			1.0%	101%	_2024-02-07_	2/7/2024 16:49
10	9.971			-0.3%	100%	_2024-02-07_	2/7/2024 17:10
0.1	0.109			9.0%	109%	_2024-02-12_	2/12/2024 21:59
1	1.042			4.2%	104%	_2024-02-12_	2/12/2024 22:20
3	3.102			3.4%	103%	_2024-02-12_	2/12/2024 22:41
5	5.236			4.7%	105%	_2024-02-12_	2/12/2024 23:02
10	10.399			4.0%	104%	_2024-02-12_	2/12/2024 23:22
Correlation-	0.9999						
QC	4.934		5.00		99%	_2024-02-08_	2/8/2024 12:26
QC	5.066		5.00		101%	_2024-02-08_	2/8/2024 12:47
QC	4.958		5.00		99%	_2024-02-08_	2/8/2024 17:58
QC	5.006		5.00		100%	_2024-02-08_	2/8/2024 18:19
QC	5.187		5.00		104%	_2024-02-08_	2/8/2024 22:48
QC	5.191		5.00		104%	_2024-02-08_	2/8/2024 23:09
QC	5.009		5.00		100%	_2024-02-12_	2/12/2024 18:53
QC	5.059		5.00		101%	_2024-02-12_	2/12/2024 20:57
QC	5.313		5.00		106%	_2024-02-12_	2/12/2024 23:43
DL	0.109		0.10		109%	_2024-02-08_	2/8/2024 13:49
DL	0.104		0.10		104%	_2024-02-08_	2/8/2024 14:10
DL	0.109		0.10		109%	_2024-02-12_	2/12/2024 21:18
DL	0.120		0.10		120%	_2024-02-13_	2/13/2024 0:04
40034-6 QC	6.820	10	71.7		100%	_2024-02-12_	2/12/2024 20:16
40034-6 QC	6.884	10	71.7		101%	_2024-02-12_	2/12/2024 20:36
BLK	0.000					_2024-02-08_	2/8/2024 13:08
BLK	0.000					_2024-02-08_	2/8/2024 13:28
BLK	0.170					_2024-02-08_	2/8/2024 18:39
BLK	0.031					_2024-02-08_	2/8/2024 19:00
BLK	0.036					_2024-02-08_	2/8/2024 23:30
BLK	0.033					_2024-02-08_	2/8/2024 23:50
BLK	0.033					_2024-02-08_	2/8/2024 23:50
BLK	0.000					_2024-02-12_	2/12/2024 19:13
BLK	0.000					_2024-02-12_	2/12/2024 21:38
BLK	0.000					_2024-02-13_	2/13/2024 0:24

HF Data 2 of 2

elementOne

e 41983-HF

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41983

Date: 020924
 Analyst: mnblaw
 Batch name: 020924-41983

Column: ~~Metrosep A Supp 10~~ ^{ICMPACAS14A}
 Conc. Eluent: 8.0 mM Na₂CO₃ / 0.25 mM NaHCO₃
 10mL Conc. Eluent Diluted to FV=1L with filtered
 Regenerant: 500 mM H₂SO₄
 Flow Rate: 0.7 mL/min. ^{1.0 mL/min} Method: 300/26A

Instrument: 2011788
 Lot# 1C11.102.1
 UPDI 1C11.124.4
 Lot #

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0.0			QC	mant	R2	
2	0.1		F	BBCJ0574	fiama	0.9999	
3	1.0				aidrich	0.9999	
4	3.0						
5	5.0						
6	10.0						
7	QC						
8	QC						
9	BKC						
10	BKC						
11	DL						
12	DL						
13	LRB						
14	LRB						
15	LRB+						
16	LRB+						
17	41983-1	deeco	HF		—	Sx	
18	-1d	↓	↓		—	↓	
19	-2	↓	↓		—	↓	
20	-2d	↓	↓		—	↓	
21	-4	↓	↓		—	↓	
22	-4d	↓	↓		—	↓	
23	QC						
24	QC						
25	BKC						

Manual integr:

Curve IC Lot # 1C11.177.4 Comments: pg1 043Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution 1303079-230 IC NO2 Solution 1309942-250QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.Submitted for QC- Date: 2-13-24 Time: 1111 By: mnbl QC Review- Date: ✓ Time: _____ By: _____

elementOne

Certification: NJ NELAP NC009
 41983 Deeco M26A Report Packet
 Page 19 of 26

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41983

Date: 2-7-24
 Analyst: mnw/law
 Batch name: 020724-41983

Column: Metrosep A Supp 19
 Conc. Eluent: 8.0 mM Na₂CO₃ / 0.25 mM NaHCO₃
 10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
 Regenerant: 500 mM H₂SO₄
 Flow Rate: 0.7 mL/min. 1.0 mL/min

Instrument: 8211788
 Lot# 1011102-1
 Lot # 1011124-4
 Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	BK ^{1000 ug/mL}	deeco					
27	41983-3	deeco	HF		—	5X	
28	-3d				—		
29	-3f				5.253		
30	-3+d				5.350		
31	-5				—		
32	-5d				—		
33	-6				—		
34	-6d				—		
35	-6f				5.3120		
36	-6+d				5.417		
37	QC						
38	QC						
39	BK						
40	BK						
41	41983-7 FB	deeco	HF	Flow rev		5X	
42	-7d FB			1000			
43	41983-12 GC					10X	TV=71.7
44	-12d GC						
45	QC						
46	DL						
47	BK						
48	0.1						
49	1.0						
50	3.0						

Manual integr:

Curve IC Lot #

Comments:

pg 2 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

IC NO2 Solution

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SO₄ Std. to 10mL sample; lot #'s listed above.QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date:

Time:

By:

QC Review- Date:

Time:

By:

elementOne

Certification: NJ NELAP NC009
 41983 Deeco M26A Report Packet
 Page 20 of 26

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41983

Date: 2.7.24
 Analyst: mnb/law
 Batch name: 020724-41983

Column: IonPac AS14A
 Conc. Eluent: 8.0 mM Na₂CO₃ / 1.0mM NaHCO₃
 10mL Conc. Eluent Diluted to FV=1L with filtered UPDI
 Regenerant: 100 mM H₃PO₄
 Flow Rate: 1.0 mL/min.

Instrument: 821/788
 Lot# 1C11-102-1
 Lot # 1C11-124.4
 Method: 300/26A

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
S1	5.0						
S2	10.0						
S3	QC						
SA	DL						
SS	BLK						
SL	UPB } insert seg						
S7	UPB }						
1	41983-7FB	deeco	HF		—	SX	
2	-7FBd	↓	↓		—	↓	
3	40034-6 QC					10x	TV=71.7
4	-6d QC					↓	↓
5	QC						
6	DL						
7	BLK						
8	0.1						
9	1.0						
10	3.0						
11	5.0						
12	10.0						
13	QC						
14	DL						
15	BLK						
16	QC						
17	QC BLK } insert seg						
18	QC BLK }						

Manual integrations noted by M

Curve IC Lot #

Comments:

pg 3 of 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution IC NO2 Solution

QC: Spike 50 uL from 1000 ug/mL F, Cl, Br, and SQ Std. to 10mL sample; lot #'s listed above.

QC: Spike 20 uL from 1000 ug/mL NO₂, NO₃, and PO₄ Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: Time: By: QC Review- Date: Time: By:

elementOne

Certification: NJ NELAP NC009
 41983 Deeco M26A Report Packet
 Page 21 of 26

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41983

Client: Deeco

Column: IonPac AS14A

Date: 02.13.24

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

Sample ID	Cl ⁻ µg/ml	Dilution	Final Vol, ml	Cl ₂ , Total mg	Spike, µg/ml	% RPD/ Recovery	File Name	Date Time
LRB	0.000	1	10	< 0.001			-17de6efb:18d8a3def01:-7538	2/9/2024 16:50
LRB	0.000	1	10	< 0.001		NA	-17de6efb:18d8a3def01:-7536	2/9/2024 17:13
LRB SPK	5.175	1	10	0.052	5.00	104%	-17de6efb:18d8a3def01:-7534	2/9/2024 17:37
LRB SPK	5.182	1	10	0.052	5.00	104%	-17de6efb:18d8a3def01:-7532	2/9/2024 18:00
41983-1	0.140	5	353.0	0.247			-17de6efb:18d8a3def01:-7530	2/9/2024 18:24
41983-1 DUP	0.139	5	353.0	0.245		0.7%	-17de6efb:18d8a3def01:-752e	2/9/2024 18:47
41983-2	0.109	5	352.4	0.192			-17de6efb:18d8a3def01:-751c	2/9/2024 22:19
41983-2 DUP	0.108	5	352.4	0.190		0.9%	-17de6efb:18d8a3def01:-751a	2/9/2024 22:42
41983-3	0.107	5	373.0	0.200			-17de6efb:18d8a3def01:-752c	2/9/2024 19:11
41983-3 DUP	0.108	5	373.0	0.201		0.9%	-17de6efb:18d8a3def01:-752a	2/9/2024 19:34
41983-3 SPK	5.189	5	373.0	9.68	5.00	102%	-17de6efb:18d8a3def01:-7528	2/9/2024 19:58
41983-3 SPK DUP	5.222	5	373.0	9.74	5.00	102%	-17de6efb:18d8a3def01:-7526	2/9/2024 20:21
41983-4	0.123	5	367.2	0.226			-17de6efb:18d8a3def01:-7518	2/9/2024 23:06
41983-4 DUP	0.122	5	367.2	0.224		0.8%	-17de6efb:18d8a3def01:-7516	2/9/2024 23:29
41983-5	0.088	5	379.5	< 0.19			-17de6efb:18d8a3def01:-7514	2/9/2024 23:53
41983-5 DUP	0.089	5	379.5	< 0.19		NA	-17de6efb:18d8a3def01:-7512	2/10/2024 0:16
41983-6	0.104	5	386.1	0.201			-17de6efb:18d8a3def01:-7510	2/10/2024 0:40
41983-6 DUP	0.103	5	386.1	0.199		1.0%	-17de6efb:18d8a3def01:-750e	2/10/2024 1:03
41983-6 SPK	5.338	5	386.1	10.3	5.00	105%	-17de6efb:18d8a3def01:-750c	2/10/2024 1:27
41983-6 SPK DUP	5.331	5	386.1	10.3	5.00	105%	-17de6efb:18d8a3def01:-750a	2/10/2024 1:50
41983-7 FB	0.037	5	341.5	< 0.171			-17de6efb:18d8a3def01:-7500	2/10/2024 3:48
41983-7 FB DUP	0.027	5	341.5	< 0.171		NA	-17de6efb:18d8a3def01:-74fe	2/10/2024 4:11

Cl₂-Data 1 of 2elementOne
e 41983-Cl₂


elementOne

elementOne

M26A-Cl₂ IC Data Sheet

Lab ID #: 41983

Client: Deeco

Column: IonPac AS14A

Date: 02.13.24

Eluent: 8.0 mM Na₂CO₃/ 1.0 mM NaHCO₃

Analyst: LAW

Flow Rate: 1.0 mL/min.

Detection Limit, (µg/ml): 0.10

Standards	Cl ⁻ µg/ml	Dilution	QC µg/ml	%Relative Error	% Recovery	File Name	Date Time
0	0.000					-17de6efb:18d8a3def01:-7550	2/9/2024 12:08
0.1	0.102			2.0%	102%	-17de6efb:18d8a3def01:-754e	2/9/2024 12:31
1	0.969			-3.1%	97%	-17de6efb:18d8a3def01:-754c	2/9/2024 12:55
3	3.001			0.0%	100%	-17de6efb:18d8a3def01:-754a	2/9/2024 13:18
5	5.046			0.9%	101%	-17de6efb:18d8a3def01:-7548	2/9/2024 13:42
10	9.981			-0.2%	100%	-17de6efb:18d8a3def01:-7546	2/9/2024 14:05
0.1	0.103			3.0%	103%	-17de6efb:18d8a3def01:-74da	2/10/2024 11:14
1	1.022			2.2%	102%	-17de6efb:18d8a3def01:-74d8	2/10/2024 11:37
3	3.093			3.1%	103%	-17de6efb:18d8a3def01:-74d6	2/10/2024 12:01
5	5.239			4.8%	105%	-17de6efb:18d8a3def01:-74d4	2/10/2024 12:24
10	10.456			4.6%	105%	-17de6efb:18d8a3def01:-74d2	2/10/2024 12:48

Correlation- 0.999911

QC	5.162		5.00		103%	-17de6efb:18d8a3def01:-7544	2/9/2024 14:29
QC	5.137		5.00		103%	-17de6efb:18d8a3def01:-7542	2/9/2024 14:52
QC	5.259		5.00		105%	-17de6efb:18d8a3def01:-7524	2/9/2024 20:45
QC	5.243		5.00		105%	-17de6efb:18d8a3def01:-7522	2/9/2024 21:08
QC	5.236		5.00		105%	-17de6efb:18d8a3def01:-7508	2/10/2024 2:14
QC	5.314		5.00		106%	-17de6efb:18d8a3def01:-7506	2/10/2024 2:37
QC	5.222		5.00		104%	-17de6efb:18d8a3def01:-74ec	2/10/2024 7:43
QC	5.246		5.00		105%	-17de6efb:18d8a3def01:-74ea	2/10/2024 8:06
QC	5.385		5.00		108%	-17de6efb:18d8a3def01:-74d0	2/10/2024 13:11
DL	0.106		0.10		106%	-17de6efb:18d8a3def01:-753c	2/9/2024 16:03
DL	0.098		0.10		98%	-17de6efb:18d8a3def01:-753a	2/9/2024 16:26
DL	0.104		0.10		104%	-17de6efb:18d8a3def01:-74de	2/10/24 10:27
DL	0.096		0.10		96%	-17de6efb:18d8a3def01:-74ce	2/10/2024 13:35
40034-7 QC	3.919	20	78.00		100%	-17de6efb:18d8a3def01:-74fc	2/10/2024 4:35
40034-7 QC DUP	3.886	20	78.00		100%	-17de6efb:18d8a3def01:-74fa	2/10/2024 4:58
BLK	0.000					-17de6efb:18d8a3def01:-7540	2/9/2024 15:16
BLK	0.000					-17de6efb:18d8a3def01:-753e	2/9/2024 15:39
BLK	0.000					-17de6efb:18d8a3def01:-7520	2/9/2024 21:32
BLK	0.000					-17de6efb:18d8a3def01:-751e	2/9/2024 21:55
BLK	0.000					-17de6efb:18d8a3def01:-7504	2/10/2024 3:01
BLK	0.000					-17de6efb:18d8a3def01:-7502	2/10/2024 3:24
BLK	0.000					-17de6efb:18d8a3def01:-74e8	2/10/2024 8:30
BLK	0.000					-17de6efb:18d8a3def01:-74e6	2/10/2024 8:53
BLK	0.000					-17de6efb:18d8a3def01:-74dc	2/10/2024 10:51
BLK	0.000					-17de6efb:18d8a3def01:-74cc	2/10/2024 13:58

elementOne

e 41983-Cl₂Cl₂-Data 2 of 2

elementOne

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 42006
41983Date: 02-09-24
Analyst: CMOColumn: IonPac AS14A
Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃Instrument: 881/858
Lot# 1C11-106-1

Batch name: 020924-41983

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100mM H₃PO₄

Lot # 1C11-124-4

Flow Rate: 1.0 mL/min.

Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
1	0-0			GC	MANF	R2	
2	0-1		Cl-	4308554	RICCA	.999911	
3	1-0						
4	3-0						
5	5-0						
6	10-0						
7	GC						
8	GC						
9	BK						
10	BK						
11	DL						
12	DL						
13	LEB						
14	LEB						
15	LEB+						
16	LEB+						
17	41983-1		Cl2		0.40	5X	
18	-1D				6.139		
19	-3				6.102		
20	-3D				6.108		
21	-3+				5.189		
22	-3+				5.222		
23	GC						
24	GC						
25	BK						

Manual Integr

Curve IC Lot # 1C11-124-1 Sodium Thiosulfate Lot # 1C11-124-3 Comments: #9 lot 3

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution 2303029-250445

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date: 02-19-24 Time: 5:30 By: JWS QC Review- Date: 02-20-24 Time: By:

elementOne

Certification: NJ NELAP NC009
41983 Deeco M26A Report Packet
Page 24 of 26

elementOne

IC Sample Sheet/Digestion Worksheet

Lab ID #: 41983

Date: 020924

Analyst: wj

Column: IonPac AS14A

Conc. Eluent: 8.0 mM Na₂CO₃/ 1.0mM NaHCO₃

Instrument: 881/858

Lot#: 1C11-106-1

Batch name: 020924-41983

10mL Conc. Eluent Diluted to FV=1L with filtered UPDI

Regenerant: 100mM H₃PO₄

Lot # 1C11-124-4

Flow Rate: 1.0 mL/min.

Method: 26A NaOH

AS LOC.	Sample ID	Client	Analyte	Results (ug/mL)	Results (ug/mL)	Dilution	Wt (g) / FV (mL)
26	BIC						
27	41983-2		Cl ₂		0.109	5X	
28	-2D				0.108	↓	
29	-4				0.123	5X	
30	-4D				0.122	↓	
31	-5				—		
32	-5D				—		
33	-6				0.104		
34	-6D				0.103		
35	-6+				5.338		
36	-6+				5.331	↓	
37	GC						
38	GC						
39	BIC						
40	ALC						
41	41983-7FB		Cl ₂		—	5X	
42	-7FB.D				—	↓	
43	40034-1 GC				3.919	20X	TV=78.0
44	-7 GC				3.886	↓	
45	GC/42006-1				—	5X	
46	DL -1D				—		
47	BIC -2				—		
48	Cl -2D				—		
49	1.0 -2+				5.070		
50	3.0 -2+				5.277	↓	

Manual integrations noted by M

Curve IC Lot #

Sodium Thiosulfate Lot #

Comments:

Spike 50 uL from 1000 ug/mL Std. to 10mL sample Lot #'s: IC ME Solution

QC: Spike 50 uL from 1000 ug/mL Br Std. to 10mL sample; lot #'s listed above.

Submitted for QC- Date:

Time:

By:

QC Review- Date:

Time:

By:

elementOne

Certification: NJ NELAP NC009

41983 Deeco M26A Report Packet

Page 25 of 26

Appendix D

Plant Process Data

Holcim

Theodore AL

Main Stack

Date/Time	CEMS: CLINKER_METRIC (TNHR) Raw Value
Run 1	
02/01/2024 10:26	147.6
02/01/2024 10:27	148.0
02/01/2024 10:28	148.6
02/01/2024 10:29	148.4
02/01/2024 10:30	147.8
02/01/2024 10:31	147.6
02/01/2024 10:32	148.5
02/01/2024 10:33	149.8
02/01/2024 10:34	150.5
02/01/2024 10:35	149.4
02/01/2024 10:36	149.4
02/01/2024 10:37	149.9
02/01/2024 10:38	148.6
02/01/2024 10:39	149.1
02/01/2024 10:40	148.6
02/01/2024 10:41	148.6
02/01/2024 10:42	146.2
02/01/2024 10:43	147.0
02/01/2024 10:44	146.7
02/01/2024 10:45	145.1
02/01/2024 10:46	144.8
02/01/2024 10:47	147.1
02/01/2024 10:48	147.4
02/01/2024 10:49	147.2
02/01/2024 10:50	146.4
02/01/2024 10:51	145.8
02/01/2024 10:52	145.8
02/01/2024 10:53	147.1
02/01/2024 10:54	147.1
02/01/2024 10:55	146.4
02/01/2024 10:56	147.5
02/01/2024 10:57	148.3
02/01/2024 10:58	148.8
02/01/2024 10:59	148.4
02/01/2024 11:00	148.2
02/01/2024 11:01	149.0
02/01/2024 11:02	150.1
02/01/2024 11:03	149.4

Holcim

Theodore AL

Main Stack

Date/Time	CEMS: CLINKER_METRIC (TNHR) Raw Value
02/01/2024 11:04	149.2
02/01/2024 11:05	149.0
02/01/2024 11:06	148.8
02/01/2024 11:07	150.2
02/01/2024 11:08	149.7
02/01/2024 11:09	148.8
02/01/2024 11:10	148.8
02/01/2024 11:11	149.2
02/01/2024 11:12	148.5
02/01/2024 11:13	147.5
02/01/2024 11:14	147.0
02/01/2024 11:15	146.7
02/01/2024 11:16	149.1
02/01/2024 11:17	147.5
02/01/2024 11:18	146.5
02/01/2024 11:19	146.8
02/01/2024 11:20	146.6
02/01/2024 11:21	146.8
02/01/2024 11:22	147.5
02/01/2024 11:23	146.2
02/01/2024 11:24	146.9
02/01/2024 11:25	146.9
02/01/2024 11:26	145.4
02/01/2024 11:27	146.0
02/01/2024 11:28	146.7
02/01/2024 11:29	146.3
02/01/2024 11:30	147.1
02/01/2024 11:31	147.2
02/01/2024 11:32	147.3
02/01/2024 11:33	146.8
02/01/2024 11:34	147.8
02/01/2024 11:35	147.5
Sum	10342.50
Average	147.75
Max	150.50
Min	144.80
Count	70

Holcim

Theodore AL

Main Stack

Date/Time	CEMS: CLINKER_METRIC (TNHR) Raw Value
Run 2	
02/01/2024 11:56	148.4
02/01/2024 11:57	148.3
02/01/2024 11:58	147.3
02/01/2024 11:59	146.8
02/01/2024 12:00	146.1
02/01/2024 12:01	146.0
02/01/2024 12:02	146.4
02/01/2024 12:03	146.6
02/01/2024 12:04	148.2
02/01/2024 12:05	146.7
02/01/2024 12:06	146.9
02/01/2024 12:07	146.3
02/01/2024 12:08	147.3
02/01/2024 12:09	147.8
02/01/2024 12:10	147.4
02/01/2024 12:11	147.4
02/01/2024 12:12	147.8
02/01/2024 12:13	148.7
02/01/2024 12:14	149.6
02/01/2024 12:15	149.0
02/01/2024 12:16	150.7
02/01/2024 12:17	149.4
02/01/2024 12:18	148.4
02/01/2024 12:19	148.6
02/01/2024 12:20	149.2
02/01/2024 12:21	147.6
02/01/2024 12:22	146.8
02/01/2024 12:23	147.5
02/01/2024 12:24	148.5
02/01/2024 12:25	147.9
02/01/2024 12:26	146.4
02/01/2024 12:27	146.4
02/01/2024 12:28	148.2
02/01/2024 12:29	147.7
02/01/2024 12:30	147.1
02/01/2024 12:31	145.7
02/01/2024 12:32	145.9
02/01/2024 12:33	145.9

Holcim

Theodore AL

Main Stack

Date/Time	CEMS: CLINKER_METRIC (TNHR) Raw Value
02/01/2024 12:34	146.2
02/01/2024 12:35	146.3
02/01/2024 12:36	146.8
02/01/2024 12:37	146.7
02/01/2024 12:38	145.9
02/01/2024 12:39	146.7
02/01/2024 12:40	147.2
02/01/2024 12:41	148.3
02/01/2024 12:42	149.3
02/01/2024 12:43	149.8
02/01/2024 12:44	149.7
02/01/2024 12:45	149.0
02/01/2024 12:46	149.0
02/01/2024 12:47	149.5
02/01/2024 12:48	149.8
02/01/2024 12:49	149.2
02/01/2024 12:50	149.1
02/01/2024 12:51	148.6
02/01/2024 12:52	148.8
02/01/2024 12:53	148.9
02/01/2024 12:54	148.1
02/01/2024 12:55	147.2
02/01/2024 12:56	148.1
02/01/2024 12:57	147.2
02/01/2024 12:58	146.7
02/01/2024 12:59	147.0
02/01/2024 13:00	146.0
02/01/2024 13:01	146.3
02/01/2024 13:02	145.9
02/01/2024 13:03	148.6
02/01/2024 13:04	148.8
02/01/2024 13:05	148.2
Sum	10339.80
Average	147.71
Max	150.70
Min	145.70
Count	70

Holcim
Theodore AL
Main Stack

Date/Time	CEMS: CLINKER_METRIC (TNHR) Raw Value
Run 3	
02/01/2024 13:18	148.9
02/01/2024 13:19	148.8
02/01/2024 13:20	149.2
02/01/2024 13:21	148.6
02/01/2024 13:22	149.2
02/01/2024 13:23	149.3
02/01/2024 13:24	147.9
02/01/2024 13:25	146.8
02/01/2024 13:26	147.1
02/01/2024 13:27	146.7
02/01/2024 13:28	146.1
02/01/2024 13:29	147.4
02/01/2024 13:30	149.0
02/01/2024 13:31	147.2
02/01/2024 13:32	146.5
02/01/2024 13:33	146.0
02/01/2024 13:34	146.4
02/01/2024 13:35	146.3
02/01/2024 13:36	146.4
02/01/2024 13:37	145.8
02/01/2024 13:38	146.2
02/01/2024 13:39	146.9
02/01/2024 13:40	147.3
02/01/2024 13:41	148.2
02/01/2024 13:42	148.6
02/01/2024 13:43	149.3
02/01/2024 13:44	148.8
02/01/2024 13:45	148.7
02/01/2024 13:46	148.6
02/01/2024 13:47	149.6
02/01/2024 13:48	149.8
02/01/2024 13:49	149.3
02/01/2024 13:50	150.0
02/01/2024 13:51	149.1
02/01/2024 13:52	148.5
02/01/2024 13:53	148.4
02/01/2024 13:54	148.5
02/01/2024 13:55	149.3







Holcim
Theodore AL
Main Stack

Date/Time	CEMS: CLINKER_METRIC (TNHR) Raw Value
02/01/2024 13:56	148.5
02/01/2024 13:57	147.3
02/01/2024 13:58	146.9
02/01/2024 13:59	148.7
02/01/2024 14:00	147.8
02/01/2024 14:01	145.4
02/01/2024 14:02	146.6
02/01/2024 14:03	146.6
02/01/2024 14:04	145.8
02/01/2024 14:05	146.2
02/01/2024 14:06	146.6
02/01/2024 14:07	146.8
02/01/2024 14:08	145.7
02/01/2024 14:09	146.0
02/01/2024 14:10	148.7
02/01/2024 14:11	147.8
02/01/2024 14:12	146.7
02/01/2024 14:13	148.0
02/01/2024 14:14	148.8
02/01/2024 14:15	148.9
02/01/2024 14:16	149.6
02/01/2024 14:17	149.3
02/01/2024 14:18	149.7
02/01/2024 14:19	149.8
02/01/2024 14:20	149.5
02/01/2024 14:21	149.0
02/01/2024 14:22	149.0
02/01/2024 14:23	148.3
02/01/2024 14:24	148.6
02/01/2024 14:25	148.0
02/01/2024 14:26	148.2
02/01/2024 14:27	147.9
Sum	10355.40
Average	147.93
Max	150.00
Min	145.40
Count	70

Appendix E

Calibration Documents

Pitot Tube Inspection Sheet



Date	01/02/24
Tube Assembly Level?	Yes
Ports Damaged?	No
-10 deg < a1 < +10 deg	1
-10 deg < a2 < +10 deg	1
-5 deg < B1 < +5 deg	2
-5 deg < B2 < +5 deg	1
Y (gamma)	1
0 (theta)	1
A (alpha)	0.939
Z = A (sin y) < 0.125"?	yes
W = A (sin 0) < 0.031"?	yes
Pa =	0.469
Pb =	0.47
Tube Diameter (Dt) =	0.376
Pa = Pb +/- 0.063"?	yes
(1.05 x Dt)?	0.3948
(1.50 x Dt)?	0.564
(1.05 x Dt) < P < (1.50 x Dt)?	yes

Eligible for Default Pitot Calibration Factor (Cp = 0.84)?

Yes

Thermocouple Calibration

Type of Reference Thermometer?	Mercury	Date	01/02/24
Barometric Pressure?	29.91	Ambient Temperature?	56

Source	Reference Temp, F	Thermocouple Temp, F	Absolute Temp Difference
cold air	38	38	0.00%
medium air	215	213	0.30%
hot air	325	325	0.00%

Windtunnel Calibration

Pitot Reading	Reference (0.99)	10B S-Type Pitot	Cp
ΔP_1	0.31	0.44	0.84
ΔP_2	0.32	0.45	0.84
ΔP_3	0.31	0.45	0.83
Average Pitot Tube Calibration Factor-->			0.84

Thermocouple Calibration Check (EPA ALT-011 Procedure), performed on 1/2/24

Source	Ref. Temp. F	Thermocouple Temp. F	± 2 deg F?
Ambient	59	59	Yes

Pitot Tube Inspection Sheet

	Date	01/02/24
	Tube Assembly Level?	Yes
	Ports Damaged?	No
	-10 deg < a1 < +10 deg	1
	-10 deg < a2 < +10 deg	1
	-5 deg < B1 < +5 deg	1
	-5 deg < B2 < +5 deg	2
	Y (gamma)	1
	0 (theta)	1
	A (alpha)	0.941
	Z = A (sin y) < 0.125"?	yes
	W = A (sin 0) < 0.031"?	yes
	Pa =	0.468
	Pb =	0.473
	Tube Diameter (Dt) =	0.376
Pa = Pb +/- 0.063"?	yes	
(1.05 x Dt)?	0.397	
(1.50 x Dt)?	0.564	
(1.05 x Dt) < P < (1.50 x Dt)?	yes	
Eligible for Default Pitot Calibration Factor (Cp = 0.84)?		Yes

Thermocouple Calibration

Type of Reference Thermometer?	Mercury	Date	01/02/24
Barometric Pressure?	29.91	Ambient Temperature?	56

Source	Reference Temp, F	Thermocouple Temp, F	Absolute Temp Difference
cold air	36	36	0.00%
medium air	215	216	-0.15%
hot air	325	324	0.13%

Windtunnel Calibration

Pitot Reading	Reference (0.99)	10E S-Type Pitot	Cp
ΔP_1	0.31	0.44	0.84
ΔP_2	0.32	0.44	0.85
ΔP_3	0.31	0.45	0.83
Average Pitot Tube Calibration Factor-->			0.84

Thermocouple Calibration Check (EPA ALT-011 Procedure), performed on 1/2/24

Source	Ref. Temp. F	Thermocouple Temp. F	± 2 deg F?
Ambient	64	65	Yes

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

DATE: 08/04/23		METER SERIAL #: m5-22		CRITICAL ORIFICE SET SERIAL #: 1431S		BAROMETRIC PRESSURE (in Hg):		INITIAL: 29.43		FINAL: 29.43		AVG (P _{bar}): 29.445		IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED			
ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)		TEMPERATURES °F				DGM ΔH (in H ₂ O)	ELAPSED TIME (MIN)	V _m (STD)	V _c (STD)	(3) Y	Y VARIATION (%)	ΔH _@	
				INITIAL	FINAL	NET (V _m)	AMBIENT	DGM INLET INITIAL	DGM INLET FINAL								DGM OUTLET INITIAL
12	1	0.3283															
	2																
	3																
15	1	0.4094	18	122.826	128.142	5.316	83	83	84	83	83	83.25	0.82	5.0960	5.1747	1.015	1.65
	2	0.4094	18	128.142	133.460	5.318	83	83	85	83	84	83.75	0.82	5.0933	5.1747	1.016	1.65
	3											0					
19	1	0.5047	18	133.864	140.425	6.561	83	85	87	84	85	85.25	1.3	6.2739	6.3792	1.017	1.72
	2	0.5047	18	140.425	147.019	6.594	83	86	88	85	85	86	1.3	6.2968	6.3792	1.013	1.72
	3	0.5047										0					
23	1	0.6426	18	147.234	155.627	8.393	83	86	88	84	85	85.75	2.2	8.0364	8.1223	1.011	1.80
	2	0.6426	18	155.627	164.026	8.399	83	87	88	85	85	86.25	2.2	8.0347	8.1223	1.011	1.79
	3											0					
32	1	0.8587															
	2																
	3																

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:
 The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_c (std), and the DGM calibration factor, Y. These equations are automatically calculated

$$(1) \quad V'_{m (std)} = K' * V_m * \frac{P_{bar} + (\Delta H / 13.6)}{T_m}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions
 K₁ = 17.64 °R/in. Hg (English), 0.3858 °K/(mm Hg (Metric))
 T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

$$(2) \quad V'_{c (std)} = K' * \frac{P_{bar} * \Theta}{\sqrt{T_{amb}}}$$

= Volume of gas sample passed through the critical orifice, corrected to standard conditions
 T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)
 K' = Average K' factor from Critical Orifice Calibration

$$(3) \quad Y = \frac{V'_{c (std)}}{V'_{m (std)}} = \text{DGM calibration factor}$$

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **1.014**

AVERAGE ΔH@ = **1.72**

Potentiometer Check, °F
 (per manufacturer procedure)
 @ 0 F
 @ 500 F
 @ 1000 F

Avg Absolute Difference = **0.1%**

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

DATE: 12/21/23		METER SERIAL #: m5-25		CRITICAL ORIFICE SET SERIAL #: 1431S		BAROMETRIC PRESSURE (in Hg):		INITIAL		FINAL		AVG (P _{avg})							
METER PART #: m5-25								30.18		30.15		30.165							
ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)				TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H ₂ O)	V _m (STD)	V _{cr} (STD)	Y	Y VARIATION (%)	ΔH _g	
				INITIAL	FINAL	NET (V _m)	AMBIENT	DGM INLET INITIAL	DGM INLET FINAL	DGM OUTLET INITIAL	DGM OUTLET FINAL								DGM AVG
12	1	0.3283				0.000													
	2					0.000													
	3					0.000													
15	1	0.4094	18	576.201	581.661	5.460	55	53	55	53	54	53.75	10.00	0.97	5.6719	5.4435	0.960		1.91
	2	0.4094	18	581.661	587.119	5.458	55	55	58	54	55	55.5	10.00	0.97	5.6506	5.4435	0.963		1.91
	3					0.000						0							
19	1	0.5047	18	587.424	594.121	6.697	55	57	61	55	56	57.25	10.00	1.5	6.9187	6.7106	0.970		1.94
	2	0.5047	18	594.121	600.831	6.710	57	59	63	56	57	58.75	10.00	1.5	6.9121	6.6976	0.969		1.94
	3					0.000						0							
23	1	0.6426	18	601.129	609.648	8.519	57	62	65	58	59	61	10.00	2.5	8.7589	8.5276	0.974		1.99
	2	0.6426	18	609.648	618.182	8.534	58	63	62	58	55	59.5	10.00	2.5	8.7997	8.5194	0.968		2.00
	3					0.000						0							
32	1	0.8587				0.000													
	2					0.000													
	3					0.000													

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the

$$(1) \quad V_{m, std} = K' \cdot V_m \cdot \frac{P_{bar} + (\Delta H / 13.6)}{T_m}$$

$$(2) \quad V_{cr, std} = K' \cdot V_{cr} \cdot \frac{P_{bar} \cdot \theta}{\sqrt{T_{amb}}}$$

$$(3) \quad Y = \frac{V_{cr, std}}{V_{m, std}} = \text{DGM calibration factor}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions

K' = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)

T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)

= Volume of gas sample passed through the critical orifice, corrected to standard conditions

T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)

K' = Average K' factor from Critical Orifice Calibration

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **0.967**

AVERAGE ΔH_g = **1.95**

Potentiometer Check, °F
(per manufacturer procedure)

0 @ 0 F
498 @ 500 F
1064 @ 1000 F

Avg Absolute Difference = **0.0%**

IF Y VARIATION EXCEEDS 2.00%,
ORIFICE SHOULD BE RECALIBRATED

Company: Holcim; Theodore AL
Source: Kiln Main Stack
Job ID: 24-3328
Train Type: M26A

Alt-009 Alternate Post Test Calibration Data

	M5-25 1A 02/01/24 1026-1135	M5-22 1B 02/01/24 1026-1135	M5-25 2A 02/01/24 1156-1305	M5-22 2B 02/01/24 1156-1305	M5-25 3A 02/01/24 1318-1427	M5-22 3B 02/01/24 1318-1427	M5-25 Average	M5-22 Average
--	--------------------------------------	--------------------------------------	--------------------------------------	--------------------------------------	--------------------------------------	--------------------------------------	------------------	------------------

Vm
Tm
Pb
Havg
H@
Md
(Havg)^0.5
Run Time, Min

Vm	55.891	56.01	58.61	60.09	61.577	59.75		
Tm	517.4	529.1	529	538.5	527.8	542.7		
Pb	29.86	29.86	29.86	29.86	29.86	29.86		
Havg	2.97	2.83	3.39	2.88	3.63	3.23		
H@	1.95	1.72	1.95	1.72	1.95	1.72		
Md	29.832	29.832	29.82	29.82	29.84	29.84		
(Havg)^0.5	1.71361427	1.67578167	1.83037489	1.68804189	1.8977963	1.78713523		
Run Time, Min	60	60	60	60	60	60		

Meter Gamma

Meter Gamma	0.967	1.014	0.967	1.014	0.967	1.014		
-------------	-------	-------	-------	-------	-------	-------	--	--

Calculated Gamma (Yqa)

Calculated Gamma (Yqa)	0.962	1.011	0.991	0.958	0.976	1.023	0.976	0.997
------------------------	-------	-------	-------	-------	-------	-------	-------	-------

% difference from Actual Y

% difference from Actual Y	0.50%	0.28%	2.45%	5.53%	0.92%	0.90%	1.3%	2.2%
----------------------------	-------	-------	-------	-------	-------	-------	------	------

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E04NI77E15A3796	Reference Number:	122-402248430-1
Cylinder Number:	EB0070787	Cylinder Volume:	151.1 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22021	Valve Outlet:	590
Gas Code:	CO,CO2,O2,BALN	Certification Date:	Oct 13, 2021

Expiration Date: Oct 13, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	85.00 PPM	84.01 PPM	G1	+/- 0.7% NIST Traceable	10/13/2021
CARBON DIOXIDE	10.00 %	10.19 %	G1	+/- 0.6% NIST Traceable	10/12/2021
OXYGEN	12.00 %	11.97 %	G1	+/- 0.4% NIST Traceable	10/12/2021
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	09010213	KAL004779	98.48 PPM CARBON MONOXIDE/NITROGEN	+/- 0.5%	Oct 16, 2024
NTRM	19080402	6162642Y	11.105 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Dec 04, 2025
NTRM	10010616	K014963	9.967 % OXYGEN/NITROGEN	+/- 0.3%	Apr 19, 2022

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VA-5001 CO2 BF89GV17	Nondispersive Infrared (NDIR)	Sep 15, 2021
Horiba VIA510 CO 1G46EA07	Nondispersive Infrared (NDIR)	Sep 22, 2021
Siemens Oxymat 61 M3299 O2	Paramagnetic	Sep 14, 2021

Triad Data Available Upon Request



Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E04NI59E15A38X3	Reference Number:	122-402389885-1A
Cylinder Number:	ALM-056015	Cylinder Volume:	143.7 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2016 PSIG
PGVP Number:	B22022	Valve Outlet:	590
Gas Code:	CO,CO2,O2,BALN	Certification Date:	Mar 28, 2022

Expiration Date: Mar 28, 2030

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	120.0 PPM	116.5 PPM	G1	+/- 0.3% NIST Traceable	03/28/2022
CARBON DIOXIDE	18.00 %	18.17 %	G1	+/- 0.7% NIST Traceable	03/28/2022
OXYGEN	22.00 %	21.90 %	G1	+/- 0.5% NIST Traceable	03/28/2022
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010207	KAL003102	246.9 PPM CARBON MONOXIDE/NITROGEN	+/- 0.2%	Oct 16, 2024
NTRM	12061508	CC354696	19.87 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 11, 2024
NTRM	08010220	K013155	23.20 % OXYGEN/NITROGEN	+/- 0.4%	Jun 01, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VA-5001 CO2 BF89GV17	Nondispersive Infrared (NDIR)	Mar 01, 2022
Horiba VIA510 CO RS2EGL6K	Nondispersive Infrared (NDIR)	Mar 01, 2022
Siemens Oxymat 61 M3299 O2	Paramagnetic	Mar 01, 2022

Triad Data Available Upon Request




Approved for Release



Air Liquide company

LABORATORY

CERTIFICATE OF ACCURACY: GMACS-c Calibration Standard

CUSTOMER INFORMATION

AIRGAS SPECIALTY GASES
Exploratory Products Group
6141 Easton Road
Plumsteadville, PA 18949

Work Order #: 160-402845897-1

Sales Order #: 1123601913

PO #: 7100179560

Customer: DEECO Inc.

Address 1: 3404 Lake Woodard Road

Address 2:

City / State / Zip: Raleigh, NC 27604

PRODUCT INFORMATION

COMPOSITION	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	49.9 PPM	2.3 PPM	4.6 %
Sulfur Hexafluoride	5.0 PPM	0.07 PPM	1.3 %
Nitrogen	Balance		

CYLINDER #: CC768222
CYLINDER TYPE: 150A Aluminum
CGA: 350 SS
CYLINDER PRESSURE: 2000 psig

AIRGAS PART #: X03NI99C15AC0W8
CERTIFICATION DATE: 7-Sep-2023
EXPIRATION DATE: 7-Mar-2024
MIXTURE DEW POINT: N/A

CERTIFICATION DATA

<u>BLENDING PROCESS:</u> GravStat™ Gravimetry			
COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	50.02 PPM	0.9 PPM	1.8 %
Sulfur Hexafluoride	5.02 PPM	0.07 PPM	1.3 %

CONFIRMING ANALYSIS: FTIR Spectroscopy
INSTRUMENT / MODEL: CAI Model 700 FTIR

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	49.8 PPM	2.1 PPM	4.2 %

REFERENCE STANDARD: GMPS-c 50 PPM Hydrogen Cyanide

CYLINDER NUMBER: CC768196

EXPIRATION DATE: 2/29/2024

COMPONENT	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
Hydrogen Cyanide	48.9 PPM	1.7 PPM	3.4 %

CALIBRATION CURVE DATA	Curve Order	Correlation	Slope (X2)	Slope (X)	Intercept
Point-to-Point Matching Std	Linear / Direct Ratio	N/A	N/A	N/A	N/A

INTERLOCK STATISTICS

	CONCENTRATION	UNCERTAINTY (Abs)	UNCERTAINTY (Rel)
<u>BLEND RESULT:</u>	50.02 PPM	0.9 PPM	1.8 %
<u>ANALYSIS RESULT:</u>	49.8 PPM	2.1 PPM	4.2 %
<u>INTERLOCK RESULT:</u>	49.9 PPM	2.3 PPM	4.6 %

COMMENTS / SPECIAL INSTRUCTIONS

1. A GMACS-c ("Candidate GMACS") is made and certified according to the EPA GMACS Procedure (Alt-114) found at: <https://cfpub.epa.gov>
2. Do not use this standard if pressure is less than 200 psig.
3. Do not use or store this product at or below the stated dew point.

APPROVED BY: _____

BOB GRASMEDER

CERTIFICATE OF ANALYSIS

Grade of Product: CERTIFIED STANDARD-SPEC

Part Number:	X02NI99C15A54F5	Reference Number:	122-402705571-1
Cylinder Number:	CC426155	Cylinder Volume:	144.0 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
Analysis Date:	Mar 28, 2023	Valve Outlet:	350
Lot Number:	122-402705571-1		

Expiration Date: Mar 28, 2031

Product composition verified by direct comparison to calibration standards traceable to N.I.S.T. weights and/or N.I.S.T. Gas Mixture reference materials.

ANALYTICAL RESULTS

Component	Req Conc	Actual Concentration (Mole %)	Analytical Uncertainty
ETHYLENE	75.00 PPM	75.47 PPM	+/- 2%
NITROGEN	Balance		




Approved for Release

Client: Holcim Theodore AL
Test Location: Kiln Main Stack
Date: Feb 01 24 Start Time: 10:26:30
Run number: Stratification Check
One Minute Averages

	Reference O2 %,dry	Plant O2 %,dry
10:27:28 AM	17.0	19.0
10:28:28 AM	17.1	19.2
10:29:28 AM	17.0	19.3
10:30:28 AM	17.1	19.2
10:31:28 AM	17.1	19.3
Point A	17.1	19.2
10:32:28 AM	16.7	19.2
10:33:28 AM	16.5	19.0
10:34:28 AM	16.0	18.9
10:35:28 AM	16.1	18.6
10:36:28 AM	16.6	18.7
Point B	16.4	18.9
10:37:28 AM	17.0	19.0
10:38:28 AM	17.0	19.2
10:39:28 AM	16.8	19.2
10:40:28 AM	16.6	19.1
10:41:28 AM	16.2	18.9
Point C	16.7	19.1

Holcim

Theodore AL

Main Stack

Date/Time	CEMS: ABB_O2_DRY (PCT) Expression Value
02/01/2024 10:26	19.02
02/01/2024 10:27	19.24
02/01/2024 10:28	19.27
02/01/2024 10:29	19.23
02/01/2024 10:30	19.27
02/01/2024 10:31	19.24
02/01/2024 10:32	19.01
02/01/2024 10:33	18.88
02/01/2024 10:34	18.60
02/01/2024 10:35	18.65
02/01/2024 10:36	19.02
02/01/2024 10:37	19.18
02/01/2024 10:38	19.18
02/01/2024 10:39	19.08
02/01/2024 10:40	18.91

Analysis Validation Report

Sample Filename: F:\Holcim Theodore October 2023\February 1\SPC__156855.LAB

Filename for noise: F:\Midlothian on Rental\November 14\SPC__000837.LAB

Interferences Filenames: C:\Midlothian on Rental\November 15\SPC__001463.LAB

C:\Midlothian on Rental\November 15\SPC__001464.LAB

C:\Midlothian on Rental\November 15\SPC__001465.LAB

C:\Midlothian on Rental\November 15\SPC__001466.LAB

C:\Midlothian on Rental\November 15\SPC__001467.LAB

C:\Midlothian on Rental\November 15\SPC__001468.LAB

C:\Midlothian on Rental\November 15\SPC__001469.LAB

C:\Midlothian on Rental\November 15\SPC__001470.LAB

Recipe path: C:\OLT\recipes\Cement Testing R3.MGRCP

Gas calibration Name	Conc	MDC3	MDC2	MDC1	MAU	FMU*R	OCU	~DL	~CL	~Bias	Sigma	Range	Span	Comment
TD HCN (200) PCA 191C 191C	0.56	0.01	-	0.29	0.34	0.02	0.34	-	0.01	-	-	0-200	-	Good
HF PPM (10) 191C	0.16	0.24	0.05	0.04	0.07	0.42	0.42	0.07	0.2	0.02	0.02	0-10	-	Close to DL
SF6 (10) 191C	0.01	0.01	-	0	0	0.02	0.02	-	0.01	-	-	0-10	-	Close to DL
ETHYLENE (100,3000) 191C	0.69	0.81	0.33	0.17	0.29	1.41	1.41	1.08	1.08	0.75	0.11	0-3000	-	Close to DL
H2O% (40) 191C	6.84	0.15	-	0.01	0.02	0.3	0.3	-	0.14	-	-	0-40	-	Good
CO2% (40) 191C	5.61	0.1	-	0.01	0.02	0.14	0.14	-	0.11	-	-	0-40	-	Good
HCL PPM (100) 191C	-0.12	0.73	0.05	0.15	0.28	1.32	1.32	0.06	0.6	0.01	0.02	0-100	-	Close to DL
SO2 (1000) 191C	0.35	1.34	0.37	0.14	0.27	2.58	2.58	0.79	1.21	0.42	0.12	0-1000	-	Close to DL
NO (350,3000) 191C	111.35	3.83	0.22	0.26	0.35	5.25	5.25	0.45	2.27	0.23	0.07	0-3000	-	Good
NH3 (300) 191C (10F2)	1.47	0.65	0.03	0.12	0.2	1.09	1.09	0.15	0.49	0.11	0.01	0-300	-	Check it!
CO (500) 191C (10F2)	122.59	3.88	-	0.2	0.43	8.01	8.01	-	2.45	-	-	0-500	-	Good
CO% (1) 191C (20F2)	0.01	0	0	0	0	0	0	0	0	0	0	0-1	-	Good
FORMALDEHYDE (70) 191C	2.07	1.23	0.28	0.2	0.24	1.49	1.49	0.33	0.99	0.04	0.09	0-70	-	Close to DL
ACETALDEHYDE (1000) 191C	0.15	2.58	0.23	0.35	0.38	2.8	2.8	0.59	2.22	0.35	0.08	0-1000	-	Close to DL
CH4 (250) 191C (10F2)	2.39	1.12	0.05	0.26	0.7	2.95	2.95	0.06	0.79	0.01	0.02	0-250	-	Check it!
PROPANE (100) 191C	-0.14	0.66	0.42	0.12	0.14	0.79	0.79	0.72	0.72	0.3	0.14	0-100	-	Close to DL
HBR (100) 180C	-0.42	4.43	0.17	0.68	1.39	9.01	9.01	0.19	3.77	0.02	0.06	0-100	-	Close to DL
NO2 (150) 191C (10F2)	0.81	0.38	0.04	0.02	0.03	0.4	0.4	0.05	0.33	0.01	0.01	0-150	-	Check it!
NO2 (2000) 191C (20F2)	-0.21	5.53	2.03	0.88	1.12	7.05	7.05	3.81	4.68	1.78	0.68	0-2000	-	Close to DL
N2O (100,200,300) 191C	0.45	0.17	0.05	0.04	0.05	0.19	0.19	0.07	0.12	0.02	0.02	0-300	-	Close to DL
NH3 (3000) 191C (20F2)	2.8	5.74	0.35	1.19	2.25	10.82	10.82	0.44	4.68	0.09	0.12	0-3000	-	Close to DL
CH4 (3000) 191C (20F2)	2.88	11.4	0.34	1.1	1.81	18.77	18.77	0.61	10.26	0.27	0.11	0-3000	-	Close to DL
ACETYLENE (1000) 191C	0.24	1.79	0.15	0.31	0.37	2.17	2.17	0.21	1.5	0.06	0.05	0-1000	-	Close to DL
PROPYLENE (200,1000) 191C	0.47	2.13	0.19	0.43	0.5	2.5	2.5	0.49	1.71	0.3	0.06	0-1000	-	Close to DL
COS (100) 150C	0.1	0.14	0.02	0.02	0.02	0.19	0.19	0.02	0.12	0	0.01	0-100	-	Close to DL
ETHANE (500) 191C	0.34	1.06	0.32	0.2	0.22	1.18	1.18	0.54	0.86	0.22	0.11	0-500	-	Close to DL
H2SO4 (50) 150C	-0.04	0.15	0.04	0.05	0.05	0.16	0.16	0.29	0.29	0.25	0.01	0-50	-	Close to DL
MEOH (10) 191C	-0.05	0.43	0.14	0.14	0.16	0.49	0.49	0.17	0.3	0.03	0.05	0-10	-	Close to DL
SO3 (150) 191C	-7.05	0.52	0.7	0.03	0.04	0.56	0.56	1.14	1.15	0.44	0.23	0-150	-	Check it!

Analysis Validation Report

Sample Filename: F:\Holcim Theodore October 2023\February 1\SPC__156856.LAB

Filename for noise: F:\Midlothian on Rental\November 14\SPC__000837.LAB

Interferences Filenames: C:\Midlothian on Rental\November 15\SPC__001463.LAB

C:\Midlothian on Rental\November 15\SPC__001464.LAB

C:\Midlothian on Rental\November 15\SPC__001465.LAB

C:\Midlothian on Rental\November 15\SPC__001466.LAB

C:\Midlothian on Rental\November 15\SPC__001467.LAB

C:\Midlothian on Rental\November 15\SPC__001468.LAB

C:\Midlothian on Rental\November 15\SPC__001469.LAB



C:\Midlothian on Rental\November 15\SPC__001470.LAB

Recipe path: C:\OLT\recipes\Cement Testing R3.MGRCP

Gas calibration Name	Conc	MDC3	MDC2	MDC1	MAU	FMU*R	OCU	~ DL	~ CL	~ Bias	Sigma	Range	Span	Comment
TD HCN (200) PCA 191C 191C	0.55	0.01	-	0.29	0.34	0.01	0.34	-	0.01	-	-	0-200	-	Good
HF PPM (10) 191C	0.16	0.22	0.05	0.04	0.07	0.39	0.39	0.07	0.18	0.02	0.02	0-10	-	Close to DL
SF6 (10) 191C	0	0.01	-	0	0	0.02	0.02	-	0.01	-	-	0-10	-	Close to DL
ETHYLENE (100,3000) 191C	0.5	0.84	0.33	0.17	0.29	1.46	1.46	1.08	1.08	0.75	0.11	0-3000	-	Close to DL
H2O% (40) 191C	6.83	0.15	-	0.01	0.02	0.29	0.29	-	0.14	-	-	0-40	-	Good
CO2% (40) 191C	5.7	0.1	-	0.01	0.02	0.14	0.14	-	0.11	-	-	0-40	-	Good
HCL PPM (100) 191C	-0.12	0.69	0.05	0.15	0.28	1.26	1.26	0.06	0.56	0.01	0.02	0-100	-	Close to DL
SO2 (1000) 191C	0.43	1.32	0.37	0.14	0.27	2.53	2.53	0.79	1.18	0.42	0.12	0-1000	-	Close to DL
NO (350,3000) 191C	120.92	3.89	0.22	0.26	0.35	5.34	5.34	0.45	2.46	0.23	0.07	0-3000	-	Good
NH3 (300) 191C (1OF2)	1.45	0.66	0.03	0.12	0.2	1.12	1.12	0.15	0.51	0.11	0.01	0-300	-	Check it!
CO (500) 191C (1OF2)	119.35	3.2	-	0.2	0.43	6.62	6.62	-	2.39	-	-	0-500	-	Good
CO% (1) 191C (2OF2)	0.01	0	0	0	0	0	0	0	0	0	0	0-1	-	Good
FORMALDEHYDE (70) 191C	1.96	1.25	0.28	0.2	0.24	1.51	1.51	0.33	1.01	0.04	0.09	0-70	-	Close to DL
ACETALDEHYDE (1000) 191C	0.03	2.58	0.23	0.35	0.38	2.8	2.8	0.59	2.23	0.35	0.08	0-1000	-	Close to DL
CH4 (250) 191C (1OF2)	2.04	1.12	0.05	0.26	0.7	2.96	2.96	0.06	0.81	0.01	0.02	0-250	-	Check it!
PROPANE (100) 191C	-0.13	0.66	0.42	0.12	0.14	0.79	0.79	0.72	0.72	0.3	0.14	0-100	-	Close to DL
HBR (100) 180C	-0.37	4.47	0.17	0.68	1.39	9.08	9.08	0.19	3.8	0.02	0.06	0-100	-	Close to DL
NO2 (150) 191C (1OF2)	0.94	0.37	0.04	0.02	0.03	0.39	0.39	0.05	0.33	0.01	0.01	0-150	-	Check it!
NO2 (2000) 191C (2OF2)	-0.06	5.41	2.03	0.88	1.12	6.89	6.89	3.81	4.56	1.78	0.68	0-2000	-	Close to DL
N2O (100,200,300) 191C	0.51	0.17	0.05	0.04	0.05	0.2	0.2	0.07	0.12	0.02	0.02	0-300	-	Close to DL
NH3 (3000) 191C (2OF2)	2.86	5.87	0.35	1.19	2.25	11.08	11.08	0.44	4.82	0.09	0.12	0-3000	-	Close to DL
CH4 (3000) 191C (2OF2)	2.44	11.14	0.34	1.1	1.81	18.36	18.36	0.61	10.02	0.27	0.11	0-3000	-	Close to DL
ACETYLENE (1000) 191C	0.14	1.78	0.15	0.31	0.37	2.16	2.16	0.21	1.49	0.06	0.05	0-1000	-	Close to DL
PROPYLENE (200,1000) 191C	0.74	2.19	0.19	0.43	0.5	2.57	2.57	0.49	1.76	0.3	0.06	0-1000	-	Close to DL
COS (100) 150C	0.11	0.14	0.02	0.02	0.02	0.19	0.19	0.02	0.12	0	0.01	0-100	-	Close to DL
ETHANE (500) 191C	0.32	1.05	0.32	0.2	0.22	1.18	1.18	0.54	0.86	0.22	0.11	0-500	-	Close to DL
H2SO4 (50) 150C	-0.05	0.14	0.04	0.05	0.05	0.15	0.15	0.29	0.29	0.25	0.01	0-50	-	Close to DL
MEOH (10) 191C	0.01	0.41	0.14	0.14	0.16	0.47	0.47	0.17	0.28	0.03	0.05	0-10	-	Close to DL
SO3 (150) 191C	-6.98	0.51	0.7	0.03	0.04	0.56	0.56	1.14	1.15	0.44	0.23	0-150	-	Close to DL

Holcim; Theodore AL
Kiln Main Stack; Dryers On
Run 3

Spectrum	Date	Time	SNR 2500	sBeam @ 2500
SPC___157191.LAB	02/01/24	14:17:36.275	4867.05	1.05



Cal Spectra		Temp (C)	Pres (atm)	Conc (ppm-m)	Actual	Calc'd
HCN (200) PCA 191C (9.86ppm, 5.11		191.209	0.977	50.385	50.338	59.055
HCN (200) PCA 191C (14.79ppm, 5.11		191.194	0.977	75.577	75.505	83.590
HCN (200) PCA 191C (19.72ppm, 5.11		191.202	0.977	100.769	100.670	111.066
HCN (200) PCA 191C (19.87ppm, 5.11		191.196	0.978	101.536	101.566	112.904
HCN (200) PCA 191C (24.65ppm, 5.11		191.204	0.977	125.962	125.832	140.114
HCN (200) PCA 191C (29.58ppm, 5.11		191.209	0.977	151.154	150.999	168.265
HCN (200) PCA 191C (34.51ppm, 5.11		191.225	0.977	176.346	176.168	197.179
HCN (200) PCA 191C (39.44ppm, 5.11		191.217	0.977	201.538	201.349	221.482
HCN (200) PCA 191C (39.74ppm, 5.11		191.194	0.978	203.071	203.055	225.817
HCN (200) PCA 191C (44.37ppm, 5.11		191.203	0.977	226.731	226.500	249.947
HCN (200) PCA 191C (49.30ppm, 5.11		191.199	0.977	251.923	251.691	278.232
HCN (200) PCA 191C (59.61ppm, 5.11		191.221	0.978	304.607	304.577	332.797
HCN (200) PCA 191C (79.48ppm, 5.11		191.195	0.977	406.143	405.954	442.717
HCN (200) PCA 191C (99.35ppm, 5.11		191.258	0.977	507.679	507.181	542.937
HCN (200) PCA 191C (119.22ppm, 5.11		191.209	0.977	609.214	608.643	639.922
HCN (200) PCA 191C (139.09ppm, 5.11		191.246	0.977	710.750	709.953	738.363
HCN (200) PCA 191C (158.96ppm, 5.11		191.263	0.977	812.286	811.364	841.793
HCN (200) PCA 191C (178.83ppm, 5.11		191.221	0.977	913.821	913.339	930.554
HCN (200) PCA 191C (198.70ppm, 5.11		191.202	0.978	1015.357	1015.357	1015.357

Interpolation Quadratic

☒ Force Through Zero


☐ Min % Residuals


☐ Excl. Zero

☐ Quant w/ Highest

Spectral Regions
Region 00 - 3250.25 to 3411.52 cm-1
Region 01 - 593.01 to 840.34 cm-1
Region 02 - 1295.95 to 1518.21 cm-1
Region 03 - 2496.93 to 2901.43 cm-1
Region 04 - 3172.38 to 3250.01 cm-1
Region 05 - 3881.35 to 4113.97 cm-1

00000

[illegible]



Cal Spectra	Temp (C)	Pres (atm)	Conc (ppm-m)	Actual	Calc'd
Ethylene (9.74ppm, 5.11m, 190C).lab	190.014	0.994	49.792	49.542	54.522
Ethylene (19.49ppm, 5.11m, 190C).lab	189.989	0.994	99.594	99.135	107.070
Ethylene (29.23ppm, 5.11m, 190C).lab	189.985	0.994	149.365	148.729	162.298
Ethylene (38.98ppm, 5.11m, 190C).lab	189.998	0.995	199.188	198.392	217.388
Ethylene (48.72ppm, 5.11m, 190C).lab	189.971	0.995	248.959	247.990	272.190
Ethylene (58.46ppm, 5.11m, 190C).lab	189.964	0.995	298.731	297.587	327.537
Ethylene (68.21ppm, 5.11m, 190C).lab	189.977	0.995	348.553	347.251	383.508
Ethylene (77.95ppm, 5.11m, 190C).lab	189.933	0.995	398.325	396.868	439.409
Ethylene (87.70ppm, 5.11m, 190C).lab	189.964	0.995	448.127	446.506	495.696
Ethylene (97.44ppm, 5.11m, 190C).lab	189.934	0.995	497.918	496.089	551.021
Ethylene (300.00ppm, 5.11m, 190C).la	189.942	0.997	1533.000	1531.357	1654.977
Ethylene (600.00ppm, 5.11m, 190C).la	189.991	0.998	3066.000	3063.066	3290.420
Ethylene (900.00ppm, 5.11m, 190C).la	189.934	0.998	4599.000	4597.015	4885.213
Ethylene (1200.00ppm, 5.11m, 190C).la	189.933	0.998	6132.000	6130.754	6446.341
Ethylene (1500.00ppm, 5.11m, 190C).la	189.960	0.998	7664.999	7658.046	7940.995
Ethylene (1800.00ppm, 5.11m, 190C).la	189.922	0.998	9197.999	9195.039	9445.204
Ethylene (2100.00ppm, 5.11m, 190C).la	189.971	0.998	10730.999	10728.462	10942.161
Ethylene (2400.00ppm, 5.11m, 190C).la	189.936	0.998	12263.999	12262.913	12444.229
Ethylene (2700.00ppm, 5.11m, 190C).la	189.914	0.998	13796.999	13797.629	13888.468

Interpolation

Quartic

Force Through Zero

Min % Residuals

Excl. Zero

Quant w/ Highest

Spectral Regions

Region 00 - 900.12 to 1000.16 cm-1

Region 01 - 615.91 to 899.88 cm-1

Region 02 - 1000.40 to 1211.33 cm-1

Region 03 - 1341.75 to 2117.96 cm-1

Region 04 - 2901.41 to 3286.87 cm-1

07/09/2012 07:34 PM

Gas ID	LRF Path
1	1
2	2
3	3
4	4
5	5
6	6
7	7
8	8
9	9
10	10
11	11
12	12
13	13
14	14
15	15
16	16
17	17
18	18
19	19
20	20
21	21
22	22
23	23
24	24
25	25
26	26
27	27
28	28
29	29
30	30
31	31
32	32
33	33
34	34
35	35
36	36
37	37
38	38
39	39
40	40
41	41
42	42
43	43
44	44
45	45
46	46
47	47
48	48
49	49
50	50
51	51
52	52
53	53
54	54
55	55
56	56
57	57
58	58
59	59
60	60
61	61
62	62
63	63
64	64
65	65
66	66
67	67
68	68
69	69
70	70
71	71
72	72
73	73
74	74
75	75
76	76
77	77
78	78
79	79
80	80
81	81
82	82
83	83
84	84
85	85
86	86
87	87
88	88
89	89
90	90
91	91
92	92
93	93
94	94
95	95
96	96
97	97
98	98
99	99
100	100

SF6 (10) 191C

.....

Lo Alarm



NaN

Span

Offset.

00000

30

[illegible][illegible]

Appendix F

Test Participants

Scott Steinsberger	Project Manager and FTIR Operator
Lee Harris	Sampling Technician
Michael Powell	Sampling Technician
Jeremy Rothenberg	Sampling Technician
Duane Cannon	Holcim Plant Contact

Appendix G

RTR Sampling and Analytical Protocol



DEECO Inc.
3404 Lake Woodard Road
Raleigh, NC 27604
(919) 250-0285 (ph); (919) 250-1835 (Fax)

www.deeco.com

**PROTOCOL TO PERFORM A SAMPLING
AND ANALYTICAL TESTING PROGRAM
AS PART OF THE US EPA RISK AND TECHNOLOGY REVIEW
at**

**Holcim (US) Inc.
Theodore Facility
3051 Hamilton Blvd
Theodore, AL 36582**

**Submitted By:
DEECO, INC.
3404 Lake Woodard Road
Raleigh, NC 27604**

September 29, 2023

Copy # 1

TABLE OF CONTENTS

<u>Figure</u>		<u>Page</u>
1.0	INTRODUCTION	1-1
1.1	SUMMARY OF TEST PROGRAM.....	1-1
1.2	PLANT NAME, ADDRESS, AND CONTACT.....	1-1
1.3	PROCESS OF INTEREST.	1-1
1.4	AIR POLLUTION CONTROL EQUIPMENT.	1-1
1.5	EMISSION POINTS AND SAMPLING LOCATIONS.....	1-1
1.6	POLLUTANTS TO BE MEASURED.....	1-2
1.7	EXPECTED TEST DATES.....	1-2
1.8	TEST PROGRAM ORGANIZATION.	1-2
2.0	SOURCE DESCRIPTION	2-1
2.1	PROCESS DESCRIPTION.....	2-1
2.2	CONTROL EQUIPMENT DESCRIPTION.	2-1
3.0	TEST PROGRAM.....	3-1
3.1	OBJECTIVES.	3-1
3.2	TEST MATRIX.....	3-1
3.3	TEST COORDINATION.....	3-2
4.0	SAMPLING LOCATION DESCRIPTIONS.....	4-1
4.1	SAMPLING LOCATION DESCRIPTION.....	4-1
5.0	SAMPLING AND ANALYTICAL PROCEDURES.	5-1
5.1	TEST METHODS.	5-1
5.1.1	SAMPLING POINT DETERMINATION - EPA METHOD 1.....	5-1
5.1.2	FLUE GAS VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2.....	5-1
5.1.3	OUTLET FLUE GAS COMPOSITION - EPA METHOD 3A.	5-1
5.1.3.1	Calibration Gases.	5-2
5.1.3.2	Sampling Procedures.	5-2
5.1.4	FLUE GAS MOISTURE CONTENT - EPA METHOD 4.	5-3
5.1.5	HYDROGEN FLUORIDE AND DIATOMIC CHLORINE - EPA METHOD 26A.....	5-3
5.1.6	HYDROGEN CYANIDE AND HYDROGEN FLUORIDE - EPA METHOD 320.	5-5
5.1.6.1	Laboratory QA/QC Activities Before Field Test Program.	5-5
5.1.6.2	QA/QC Activities During Field Test Program.	5-6
6.0	QUALITY ASSURANCE/QUALITY CONTROL ACTIVITIES	6-1
6.1	QA/QC PROCEDURES.	6-1
6.2	SAMPLE IDENTIFICATION AND CUSTODY.	6-2

TABLE OF CONTENTS (Continued)

7.0	SAMPLE CUSTODY.	7-1
7.1	FIELD SAMPLING OPERATIONS.....	7-1
7.2	ANALYTICAL OPERATIONS.	7-1
8.0	INTERNAL QUALITY CONTROL CHECKS.....	8-1
8.1	EQUIPMENT INSPECTION AND MAINTENANCE.....	8-1
8.2	EQUIPMENT CALIBRATION.....	8-1
8.3	SAMPLING QUALITY CONTROL PROCEDURES.	8-3
8.4	ANALYTICAL QUALITY CONTROL PROCEDURES.....	8-5
9.0	REPORTING AND DATA REDUCTION REQUIREMENTS.....	9-1
9.1	DATA REPORTING.....	9-1
9.2	REPORT CONTENTS.	9-1
9.3	DATA REDUCTION.	9-1
9.4	DATA VALIDATION.....	9-1
10.0	PLANT ENTRY AND SAFETY.....	10-1
10.1	SAFETY RESPONSIBILITIES.....	10-1
10.2	SAFETY PROGRAM.	10-1
10.3	SAFETY REQUIREMENTS.....	10-1

LIST OF TABLES

<u>Table</u>	<u>Page</u>
TABLE 3-1 PROGRAM OUTLINE AND TENTATIVE TEST SCHEDULE.....	3-1
TABLE 6-1 QA/QC PROCEDURES AND REQUIREMENTS.....	6-1

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
Figure 1.1 Organizational Chart.....	1-3
Figure 2.1 Theodore Detailed Process Schematic.....	2-1
Figure 4.1 Schematic of Stack Sampling Location.	4-2

APPENDICES

Appendix A - Sampling and Analytical Methods

1.0 INTRODUCTION

1.1 SUMMARY OF TEST PROGRAM

The United States Environmental Protection Agency (US EPA) has directed the portland cement industry (SIC 3241) to conduct emissions testing as part of the US EPA Risk and Technology Review (RTR). This document provides the overall test program approach and specifies minimum sample collection procedures, data quality objectives, and quality assurance/quality control measures to be used by the source testing firms selected by the cement companies performing tests. The test program is designed to be a comprehensive and robust test of each facility. The quality assurance and quality control (QA/QC) measures are designed to produce standardized data having known precision and accuracy. Collection of accurate, representative, and standardized data for facilities with low emissions is necessary especially in view of MACT standard setting procedures.

Cement kiln pyro-processing systems located throughout the US will be included in this request. Individual facilities have a wide range of kiln system configurations and air pollution control (APC) trains. Site-specific considerations will be required to capture emissions profiles for the target analytes that represent the extent of control or possible emissions increases from these controls.

1.2 PLANT NAME, ADDRESS, AND CONTACT

Holcim (US) Inc. - Theodore Facility
3051 Hamilton Blvd
Theodore, AL 36582

Mr. Duane Cannon
Tel: (251) 443-1202
Fax: (251) 443-5127
E-Mail duane.cannon@holcim.com

1.3 PROCESS OF INTEREST

The process to be tested at the Theodore facility operates one dry cement kiln, equipped with a preheater and a 4-stage inline precalciner. It is equipped with two, inline dryers. The kiln is fed a variety of fuels including, but not limited to, coal, pet coke, natural gas, tire-derived fuel (TDF), wood waste, non-hazardous waste solids, fuel oil and non-hazardous waste liquids. It is capable of producing up to 250 tons of clinker per hour (TPH), when operating both dryers.

1.4 AIR POLLUTION CONTROL EQUIPMENT

The Holcim Theodore kiln uses two reverse air baghouses for air pollution control. Each reverse air baghouse has sixteen compartments with an air-to-cloth ratio of 1.35. They are rated for 800,000 actual cubic feet per minute (acfm). A selective non-catalytic reduction (SNCR) post combustion emissions control technology reduces NO_x by injecting ammonia into the process at a properly determined location. Raw materials fed to the dryers, in conjunction with a water spray system, protects the baghouses from high temperature preheater tower exhaust.

1.5 EMISSION POINTS AND SAMPLING LOCATIONS

The emissions from the clinker cooler and kiln are fed into two parallel dryers, before commingling in a common stack. Emissions will be measure at the common stack.

1.6 POLLUTANTS TO BE MEASURED

Emission testing will be conducted for hydrogen cyanide (HCN), hydrogen fluoride (HF), and diatomic chlorine (Cl₂). Concurrent measurements to determine volumetric flow rate will be made. The sampling and analytical procedures to be followed are discussed in detail in Section 4.

1.7 EXPECTED TEST DATES

Test dates are to be determined.

1.8 TEST PROGRAM ORGANIZATION

The test program organizational chart is presented in Figure 1.1.




Figure 1.1 Organizational Chart

2.0 SOURCE DESCRIPTION

2.1 PROCESS DESCRIPTION

The Holcim facility operates one dry cement kiln at the Theodore, AL facility. It is equipped with two, inline dryers. The kiln is fueled by a variety of fuels including, but not limited to, coal, pet coke, natural gas, tire-derived fuel(TDF), wood waste, non-hazardous waste solids, fuel oil and non-hazardous waste liquids. The Kiln is capable of producing about 250 TPH of clinker, when operating both dryers.

A portion of kiln gases are diverted to the coal mill system, which are then exhausted through a separate stack.

2.2 CONTROL EQUIPMENT DESCRIPTION

The Holcim Theodore kiln uses two reverse air baghouses for air pollution control. Each reverse air baghouse has sixteen compartments with an air-to-cloth ratio of 1.35. They are rated for 800,000 actual cubic feet per minute (acfm). A selective non-catalytic reduction (SNCR) post combustion emissions control technology reduces NO_x by injecting ammonia into the process at a properly determined location. Raw materials fed to the dryers, in conjunction with a water spray system, protects the baghouses from high temperature preheater tower exhaust.

A schematic of the Theodore process, including control equipment is shown below in Figure 2.1.




Figure 2.1 Theodore Detailed Process Schematic

3.0 TEST PROGRAM

3.1 OBJECTIVES

An air emissions sampling and analytical program will be conducted on the main stack at the Theodore cement facility located in Theodore, Alabama. All testing will be performed following accepted EPA methodology. The test program is to provide a standardized data set to the EPA and the cement industry so that reliable facility inter-comparisons of emissions can be made.

All testing will be performed in strict accordance with "DRAFT GENERAL TEST PLAN Testing To Determine HCN, HF, and Cl₂ Emissions From Cement Kilns" dated March 2, 2023" and the specifications stipulated in 40 CFR 60, Appendix A for flow rate following EPA Method 1, 2, 3A, and 4) and hydrogen fluoride (HF) and diatomic chlorine (Cl₂) following EPA Method 26A and in 40 CFR 63, Appendix A for hydrogen cyanide (HCN) and (HF) following EPA Method 320. All sampling runs will be one hour long.

The source emission test will be performed on a date to be determined. Testing will be conducted under representative process and control system operating conditions. The Theodore kiln has no inline raw mill, however the inline dryers are treated similar; therefore both "Dryers On" and "Dryers Off" operating conditions are anticipated to be tested; unless market or process conditions dictate a single dryer (a.k.a. "single string") operation.

3.2 TEST MATRIX

Table 3-1 presents the sampling and analytical matrix and proposed test schedule.

TABLE 3-1 PROGRAM OUTLINE AND TENTATIVE TEST SCHEDULE

Sampling Location	No. of runs	Sample/Type Pollutant	Sampling Method	Sample Run Times (min)	Analytical Method	Analytical Laboratory
Day 1						
Stack	Arrive on-site and set up test equipment on the common stack					
Day 2						
Stack; Both Dryers On	3	O ₂ /CO ₂	EPA Method 3A	60	Paramagnetic (O ₂) NDIR (CO ₂)	DEECO
	3	HF and Cl ₂	EPA Method 26A ¹	60	Ion Chromatograph	Element One
	3	HCN and HF	EPA Method 320	60	FTIR (Method 320)	DEECO
Day 3						
Stack; Both Dryers Off	3	O ₂ /CO ₂	EPA Method 3A	60	Paramagnetic (O ₂) NDIR (CO ₂)	DEECO
	3	HF and Cl ₂	EPA Method 26A ¹	60	Ion Chromatograph	Element One
	3	HCN and HF	EPA Method 320	60	FTIR (Method 320)	DEECO

¹ Stack gas flow rate and moisture measurement may be taken from concurrent Method 26A sampling trains.

3.3 TEST COORDINATION

Mr. Duane Cannon, the Theodore facility contact, will serve as the test coordinator and will be responsible for:

1. Scheduling the start of all testing
2. Principal contact with the agency officials concerning the tests
3. Principal contact with DEECO concerning the tests
4. Recording the process data during the testing
5. Providing copies of any field test data to the agency

If there is a temporary equipment malfunction in the middle of a test, radio contact will be made with the test crew in order to delay the test. When problems have been corrected, the test will continue from the point where it was delayed. If the malfunction or upset condition results in an extended test delay, then the affected test run(s) may be aborted and a new run(s) conducted when the malfunction has been corrected or process upset cleared. Any samples or field data from aborted runs may be discarded.

4.0 SAMPLING LOCATION DESCRIPTIONS

4.1 SAMPLING LOCATION DESCRIPTION

The common stack is a vertically-oriented circular stack with an inside diameter of 204". The stack gas sampling ports are located 1680 inches (8.2 duct diameters) above the duct breaching and 1380 inches (6.8 duct diameters) below the stack outlet.

This sampling location meets the minimum specifications for selection of a measurement site as outlined in EPA Method 1. Cyclonic flow checks, as described in EPA Method 1 Section 2.4, using the Type-S pitot null procedure and angle measurements will be conducted at the common stack test location.

A twelve (12) point sampling traverse will be made using six (6) point traverses in each of two perpendicular directions (or 3 points in each of 4 sampling ports) at the common stack. Each traverse will be made at each sampling location using a type-S pitot tube in accordance with EPA Methods 2 procedures. Gas temperatures are to be measured using calibrated Type K thermocouples and digital readout devices. All measurements are to be performed in accordance with the procedures in EPA Methods 2, and 26A.

A schematic of the common stack is provided in Figure 4.1.




Figure 4.1 Schematic of Stack Sampling Location

5.0 SAMPLING AND ANALYTICAL PROCEDURES

This section contains a brief description of the sampling and analytical procedures for each method that will be employed during the test program. All equipment, procedures, and quality assurance measures necessary for completion of the test program will meet or exceed the specifications of the appropriate methods. Any deviations from the methods to ensure quality representativeness of the results are also discussed.

5.1 TEST METHODS

The methods for the test program are described below, and apply to all process operating conditions (e.g. where there is an inline raw mill, testing will be performed while operating in the "Mill On" and "Mill Off" conditions). Table 3-1 outlines expected operating conditions for this test.

5.1.1 SAMPLING POINT DETERMINATION - EPA METHOD 1

The number and location of the sampling or traverse points will be determined according to the procedures outlined in EPA Method 1. The sample location will be inspected to insure EPA Method 1 criteria is met. All points will be at least 1.0 inches from the stack wall, per Method 1.

5.1.2 FLUE GAS VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2

The flue gas velocity and volumetric flow rate will be determined according to the procedures outlined in EPA Method 2. Velocity measurements will be made using type S pitot tubes conforming to the calibration specifications outlined in EPA Method 2, Section 10.1. Each Type-S pitot tube, calibrated according to these standards, will have an assigned coefficient. Differential pressures will be measured with Magnehelic gauges of appropriate range or with fluid manometers. Effluent gas temperatures will be measured with chromel-alumel thermocouples equipped with digital readouts.

5.1.3 OUTLET FLUE GAS COMPOSITION - EPA METHOD 3A

Outlet flue gas analysis for oxygen (O₂) and carbon dioxide (CO₂) concentrations, and the calculation of percent excess air and flue gas dry molecular weight will be performed in accordance with EPA Method 3A.

To evaluate the sampling location and points for FTIR and O₂ sampling, a three-point O₂ concentration stratification test on a line passing through the centroidal area at 16.7, 50.0 and 83.3 percent of the measurement line (or for stacks is greater than 2.4 meters (7.8 ft) at 0.4, 1.2 and 2.0 meters from the stack or duct wall). The procedures in Section 8.1.2 of Method 7E will be followed, but oxygen will be used as parameter as allowed by fourth sentence in Section 8.1.2. The plant O₂ CEMS as a control. A criteria of <5% variation from combined mean for each point will be used as indication of non-stratification and allowing single point sampling at the point closest to the mean. Otherwise, sampling for equal periods at the three test points during test run will be conducted.

Per EPA Method 3A for determining molecular weight, integrated sampling will be obtain using the Method 320 sampling system described in Section 5.1.6.

A portion of the hot, wet gas sample will be sent through a condensing system to remove the stack moisture, A portion of the moisture-free gas sample will be sent to a CAI Model 200 O₂ (or

equivalent) analyzer measures using the paramagnetic technique. An oxygen molecule, because of its sp³ electron orbital distribution, has an unpaired electron and hence displays a magnetic orientation. Since other elements that display this magnetic phenomenon are not common gasses at normal temperatures, the paramagnetic measurement technique is virtually specific for oxygen. The sample gas flows through a detection cell located in a very strong magnetic field. The concentration of O₂ gas present induces a pressure differential in the detector cell. The amount of differential pressure is proportional to the concentration of O₂ gas present.

Calibration procedures will be performed in accordance with EPA methodology. Analyzers will be calibrated before and after each test and a calibration check between each test run.

The pretest calibrations will consist of the following steps:

- Internal (direct) calibration of each analyzer to adjust calibration and check linearity.
- External (through the entire sampling system) calibration to check the system bias on zero and span gases.

The post test calibration will consist of an external system bias calibration check.

The analyzer will be as calibrated using a certified zero and span (mid or high range) gas. Zero and span gases were directed to each analyzer through the appropriate plumbing, the calibration gas flow rates will be adjusted to the correct flow rate and the analyzer will be adjusted with the appropriate span pot.

After the analyzer is properly adjusted the linearity will be checked using a low and high range calibration gas. The maximum allowable limit for linearity is 2% of the analyzer range. All analyzers will be shown to be linear within these limits before proceeding.

The external calibration bias check will be performed by placing the CEM system in sampling mode and injecting a zero and span gas into the sample line at the probe exit. This check shows if there is any sampling system related bias, and also checks the integrity of the sample line.

5.1.3.1 Calibration Gases-DEECO will use EPA Protocol and/or $\pm 2\%$ NIST Traceable gases for calibration as required by the various reference methods employed in this test program. Calibration gases will be selected from previous experience with similar sources and/or from information obtained from the facility engineer prior to sampling. In some cases if the gases that are selected are out of the optimum range of operation then no significant impact of data quality is expected due to the linear nature of the analyzers that were used.

Audit gases, if available from a federal or a state agency, will be analyzed.

5.1.3.2 Sampling Procedures-At the completion of the pretest calibration routine, the CEM system will be ready for operation. No further adjustments of sample flow rates, analyzer zero or span adjustments, or other critical CEM operating parameters will be made until testing and post test calibration were complete.

Each sampling run will be one hour. At the completion for each test run, calibration gases will be used to check between test runs. A zero and the upscale calibration gas closest to the actual emission concentrations will be used for the pretest and post test calibrations.

5.1.4 FLUE GAS MOISTURE CONTENT - EPA METHOD 4

The flue gas moisture content will be determined in conjunction with the EPA Method 26A trains according to the sampling and analytical procedures outlined in EPA Method 4. (**NOTE:** In order to maintain isokinetic sampling, the sampling rate used may be required to temporarily exceed the EPA Method 4-specified maximum sampling rate of 0.75 CFM, based on observed stack gas pitot readings.) The impingers will be connected in series and will contain reagents as described below. The impingers will be contained in an ice bath in order to assure condensation of the moisture in the flue gas stream. Any moisture that is not condensed in the impingers is captured in the silica gel, therefore all moisture can be weighed and entered into moisture content calculations.

5.1.5 HYDROGEN FLUORIDE AND DIATOMIC CHLORINE - EPA METHOD 26A

Sampling and analytical procedures will be similar to those outlined in EPA Method 26A to determine primarily diatomic chlorine (Cl_2) emissions and hydrogen fluoride (HF) emissions at main stack outlet sampling locations. Duplicate simultaneous trains (a.k.a “paired trains”) for each test run will be used to determine precision.

Sample is collected through a heated glass probe, followed by a heated quartz fiber filter, where stack gas HF and Cl_2 are collected in a series of chilled impingers. The sampling train impingers will contain 50 ml of 0.1N sulfuric acid in the first impinger (optional should high moisture warrant a modified short stem), 100 ml of 0.1N sulfuric acid in the second and third, an empty fourth impinger, 100 ml of 0.1N NaOH in the fifth and sixth and 200 grams of silica gel in the last impinger. (**NOTE:** For plants with scrubbers, the optional cyclone may be used since the gas stream may be saturated with moisture.)

Sampling will be conducted isokinetically ($\pm 10\%$) with readings of flue gas parameters recorded at traverse points selected according to EPA Method 1. Leak-checks on the Method 26A sampling train will be performed before and after each sampling run and optionally for any port change. In the event that any portion of the train needed to be disassembled and reassembled (i.e., due to filter or resin changes), leak-checks are performed. The sampling train leak-checks and leakage rate (where applicable) are documented on the field test data sheet for each respective run. All leak checks will be acceptable.

The glass button hook nozzle and probe liner will be constructed of borosilicate glass or quartz. The filter holder will be constructed of borosilicate glass with a Teflon frit filter support and a sealing gasket. A heated quartz fiber filter, for sources above 210°C , or PTFE-bonded glass fiber filter will be used. The probe and filter housing will be heated to above 248°F and not exceed an upper boundary of 273°F . Probe liners and filter holders will be cleaned thoroughly prior to testing.

The Method 26A trains will be operated isokinetically for a minimum of 60 minutes and collect a minimum of 1 dry, standard cubic meter (DSCM). Pretest preparations, preliminary determinations, and leak check procedures will be those outlined in EPA Method 5.

After completion of sampling the train will be leak checked and transferred to the sample recovery trailer. All leak checks will be acceptable. The impingers will be weighed to determine moisture gain in accordance with EPA Method 4.

Sample recovery will involve quantitative recovery of the sulfuric acid impinger contents and the NaOH impinger contents into separate tare-weighed, precleaned polyethylene sample containers.

The nozzle, probe, filter and filter housing will not be recovered.

The contents of sulfuric acid impingers, including the contents if any of the empty (2nd knockout or fourth) impinger will be quantitatively transferred to the tare-weighted, precleaned polyethylene sample container, followed by three rinses with deionized (DI) water of the impingers and all connecting glassware (including the connecting glassware to the first impinger) placed in the same H₂SO₄ container. The container will be labeled and weighed to determine the final sample volume. The liquid level will be marked on the sample container.

The contents NaOH impingers will be quantitatively transferred to a second tare-weighted, precleaned polyethylene sample container, followed by three rinses with DI water of the impingers and all connecting glassware placed in the same NaOH container. The container will be labeled and weighed to determine the final sample volume. The liquid level will be marked on the sample container

Sample recovery from each train will include:

1. Container No. 1 - Contents 1st knockout, H₂SO₄ impingers, and 2nd knockout and, and DI rinse of impingers and connecting glassware; and
2. Container No. 2 - Contents NaOH impingers, and DI rinse of impingers and connecting glassware.

Additional quality control consists of collecting and analyzing a field blank train for every three test runs. The blank train is to be assembled from a used train, leak checked and sit for a period equal to the sampling time (i.e, 1-hr). The blank train data will be used to determine the method detection limit for the test program target analytes (ie. The lowest number that could be detected), and compared to stack emissions.

Reagent blanks of 0.1 N H₂SO₄, 0.1N NaOH, and DI water will be collected and archived for later analysis should there be any issues with the field blank train samples

The H₂SO₄ impinger solutions will be analyzed using ion chromatography techniques for fluoride ions (F⁻) (EPA SW-9057). Duplicate analyses will be performed on the samples and a reagent blank. Precision will be demonstrated by duplicate injection of each sample, the results of each individual analysis must be within 5% of their mean to be acceptable. If the precision criteria is not met, analysis of the sample is repeated until consecutive injections meet the criteria.

The NaOH impinger solutions will be treated with sodium thiosulfate to ensure complete conversion of hypochlorous acid (HClO) to chloride ions (Cl⁻). The resulting solution will be analyzed using ion chromatography techniques for chloride ions (EPA SW-9057). Duplicate analyses will be performed on the samples and a reagent blank. Precision will be demonstrated by duplicate injection of each sample, the results of each individual analysis must be within 5% of their mean to be acceptable. If the precision criteria is not met, analysis of the sample is repeated until consecutive injections meet the criteria.

All EPA Method 26A HF/Cl₂ samples will be analyzed by Element One of Wilmington NC. Refer to Section 1, Figure 1.1 for contact information.

The relative deviation (RD) will be calculated as described in EPA Method 30B between the Cl₂ concentrations measured with the paired trains.

5.1.6 HYDROGEN CYANIDE AND HYDROGEN FLUORIDE - EPA METHOD 320

EPA Method 320 will be performed to determine emissions of concentrations of HCN and HF. Three, 1-hour sampling runs will be conducted under representative process and control system operating conditions.

The gas sample will be extracted from the stack through a glass-lined probe and filter heated to 375° F. For external calibration checks and analyte spikes, the gases will be introduced in front of the heated filter. Any excess calibration gas will be diverted through the sample probes into the source. Outflow of gas from the heated filter enclosure was transported through a Teflon sample line heated to 375° F. For this source approximately 100' of sample line will be required. The heated sample line will be connected directly to the FTIR sample cell. Using heat-traced Teflon tubing the exit of the FTIR cell will be connected to a sample pump with a heated stainless steel pump head. The pump discharge will be directed to a proprietary chiller-type gas conditioner to remove moisture prior to delivery sample gas to the O₂/CO₂ monitors.

The distribution of the gas sample to the monitors will be accomplished using a panel equipped with valves and rotometers. The gas sample was then divided and directed to the analyzers.

FTIR sample cell will be maintained at 191° C and connected to a MKS Instruments Multigas 2030 Fourier Transform Infrared Spectrometer and Detector.

The FTIR spectrometer will measure vapor phase organic or inorganic compounds which absorb energy in the mid-infrared spectral region, about 400 to 4000 cm⁻¹ (25 to 2.5 μm). Continuous measurement will be made by matching sample absorbance bands with bands in reference spectra, and comparing sample band intensities with reference band intensities.

The principle limitation to FTIR spectroscopy are the presence of interfering compounds that also absorb energy in the mid-infrared spectral region. In a cement kiln stack gas matrix, water vapor (H₂O) and carbon dioxide (CO₂) are the primary interferents that must be incorporated into the identification and quantitation method.

The FTIR software performs the computation for a single compound by subtracting all the other compounds (interferants and target) from the absorbance spectra and quantifies the single compound based on the remain absorbance. The FTIR software provides a Standard Error Calculation (SEC) value that is an indication of how well the identification and quantitation has been performed. A high SEC indicates that other interferants have not been accounted for in the analysis method, and a low SEC is indicative of greater confidence measurement.

The instrument is operated with a resolution of 0.5 cm⁻¹ with 4x zero filling. Beer-Norton Medium apodization is used with amplitude phase correction.

For this RTR test program, following specific QA/QC activities for EPA Method 320 will be performed and criterium met.

5.1.6.1 Laboratory QA/QC Activities Before Field Test Program- Before field testing occurs, the following QA/QC activities will be conducted;

- 1) Seven consecutive samples of dry nitrogen through the sampling system will be acquired and used to calculate the standard deviation for each of the test program target analytes multiplied

- by a factor of 3. These data will be considered representative of detection limits for this test program and are to be compared to the 0.5 ppm required DL;
- 2) From these seven dry nitrogen samples, the results for the Signal-to-Noise Ratio (SNR) @ 2500 cm^{-1} should be >2500 , at 64 scans and the results for single beam intensity @ 2500 cm^{-1} should be >0.9 ; and
 - 3) Upon receipt of HCN calibration gases a direct analysis will be performed to verify FTIR response agrees with tag value within 5%. Analysis results will be reported to PCA to assess need for modified reference spectra and/or change to direct analysis criterion:

5.1.6.2 QA/QC Activities During Field Test Program- During the field test program, following QA/QC activities will be performed and criterion met;

- 1) On each test day prior to any testing, an instrument background will be collected using dry nitrogen directed to the gas cell. The background will be collected with at least 128 scans;
- 2) The probe, filter, sample line and all sample system components in contact with effluent will be maintained at or above 375°F or 191°C (consistent with FTIR calibration temperature) to avoid any possible “cold spots;”
- 3) Heated sample lines will be ≤ 100 feet wherever possible, and not longer than 200 feet, without prior approval for unusual test circumstances;
- 4) A system zero with all sampling system components at operating temperature will be performed by injecting nitrogen at the sample probe and through sample filter and entire measurement system. After zero equilibration has been achieved, all measurement components will be quantified for at least 128 scans;
- 5) Ambient air will be sampled until equilibration of the measurement system has been achieved and all measurement components will be quantified for at least 128 scans;
- 6) The sample probe will be positioned at effluent measurement point and sampling will continue until equilibration of the measurement system has been achieved. At this point, the effluent concentrations will be quantified with two consecutive 64-scan samples as the initial native concentration for the dynamic spike;
- 7) Analyte spiking will be conducted for HCN before the first test run, and after each successive test run for a minimum of 4 spikes per test condition. (Additional spikes would be required before and after corrective action for the sampling or analysis system and/or before and after removing the sampling system from the stack.) These results will determine accuracy;
- 8) The spike gas injections will be maintained at 10% or less of total sample volume. The spike gas concentration and flow rate will be selected to approximately double the native effluent concentration, or the spike will be conducted to add 3-4 ppm to native concentration, whichever results in greater spiked concentration. Spike recovery results will be within $\pm 20\%$ of the expected value or ± 0.5 ppm, whichever is least restrictive. (Specific HCN gases will be manufactured for this test program in the range of 50-100 ppm to provide spikes in the 5-10 ppm range, or lower. An SF_6 or appropriate tracer will be used to calculate the exact spike gas dilution ratio of 10% or less;)
- 9) After the dynamic spike, nitrogen will be sent through the sampling system until all traces of spike gas are removed and lines are proven below DL for target analytes;
- 10) The nitrogen purge will be discontinued and the sampling system will be allowed to equilibrate with stack gas before starting a test run. The first two consecutive 64-scan samples of a sample run will be used for the final native concentration. Residual results for HCN and HF will be verified to be less than 0.2-0.3 ppm for data acceptance, or less than 5% of the measured value, whichever is least restrictive. Calculate the standard deviation for

- each of the test program target analytes for seven consecutive sample spectra from Run 1, multiplied by a factor of 3. These data will be compared to the pre-test system nitrogen standard deviation results and also included in the facility test report;
- 11) The SNR @ 2500 cm^{-1} , at 64 scans, and the results for single beam intensity @ 2500 cm^{-1} will be verified to meet the >2500 and >0.9 criterium; respectively. The analyte spiking for HCN and subsequent system nitrogen injection will be conducted after each test run. Continue sequence until at least three valid runs per test condition are completed.

6.0 QUALITY ASSURANCE/QUALITY CONTROL ACTIVITIES

6.1 QA/QC PROCEDURES

The QA/QC procedures for this RTR test program are summarized in Table 6-1.

TABLE 6-1 QA/QC PROCEDURES AND REQUIREMENTS

Target Analyte	Test Method	Detection Limit	QA/QC
HCN	EPA Method 320	0.5 ppm	Increase scans if needed to achieve detection limits. Increasing to 400 from relative 64 (gives a 2.5 S/N advantage). HCN spiking before and after each run by adding 10% or less spike to approximately double the native effluent concentration, or conduct spike to add 3-4 ppm to native concentration, whichever results in greater spiked concentration. Spike recovery results shall be within $\pm 20\%$ of the expected value or ± 0.5 ppm, whichever is least restrictive 5% pre-to-post run calibration transfer standard (CTS) requirement
HF		0.2-0.3 ppm	Rely on CTS (5%), HCN and tracer gas responses to validate HF FTIR data
Cl ₂	EPA Method 26A	~ 0.07 mg/m ³ (~0.2 ppm)	Duplicate Simultaneous Trains; Collect minimum of 1 dscm for each sample train. Acceptance criteria for paired samples: 10% Relative Deviation or 0.2 ppm absolute difference, whichever is least restrictive. Insert dry impinger between acid and base impingers
Effluent Flow Rate	EPA Methods 1-4	Not Applicable	As per M26A isokinetic testing or separately by Methods 1-3. FTIR measurements for H₂O. Wind Tunnel calibrated pitot tube having a Cp of 0.84 or less is required for all flow measurements. Compare preliminary velocity traverse measurements and sample run flow rate measurements to installed certified flow rate monitor. Investigate and resolve differences greater than 10% of average flow rate.
O ₂	EPA Method 3A	Not Applicable	Analyte concentrations corrected @ 7% O₂ Span is 10%, 15%, or 20% (for co-mingled stacks only) Acceptance criteria are 0.2% O₂ difference for analyzer calibration error, and 0.3% O₂ for system bias checks, and zero and upscale drift checks.

6.2 SAMPLE IDENTIFICATION AND CUSTODY

Sample custody procedures for this program are based on EPA recommended procedures. Since samples will be analyzed by one or more laboratories as well as in the field, the custody procedures emphasize careful documentation of sample collection and field analytical data and the use of chain of custody records for samples being transported. The procedures which will be used are discussed below.

The project manager will be responsible for ensuring that proper custody and documentation procedures are followed for the field sampling and field analytical efforts. He will be assisted in this effort by key sampling personnel involved in sampling recovery.

Samples will be collected, transported, and stored in clean containers which are constructed of materials inert to the analytical matrix such as glass jars. Only containers which allow air tight seals will be used. Amber glass jars will be employed when containers are needed to inhibit photochemical reactions.

All sampling data, including information regarding sampling times, locations, and any specific considerations associated with sample acquisition will be recorded on preformatted data sheets. All samples will be given unique, identifying alphanumeric sample codes which will serve to track samples from the field to the laboratory.

Samples will be stored for transport from the lab to the field to the lab in storage boxes constructed in a fashion which minimizes movement and thus prevents breakage of containers. For example, boxes used for transporting glass containers will have foam inserts with form-fitting cutouts. Sample transport boxes will be locked except when in use. Vans containing equipment and samples will be locked whenever they are left unattended.

A daily activity log will be maintained by the project supervisor. This will be an informal log used to record various types of information, such as minor problems which arise, sketches of sampling locations, names and phone numbers of plant contacts, daily activity summaries, etc.

This section provides information regarding the organization of the sampling and analytical program. The following details the key positions and their responsibilities. Once personnel have been assigned to these positions, their qualifications will be provided as an addendum.

The organization of the project team, including QA functions, is shown in the project organization chart (see Figure 1.1).

7.0 SAMPLE CUSTODY

Sample custody procedures for this program are based on EPA recommended procedures. Since samples will be analyzed by one or more laboratories as well as in the field, the custody procedures emphasize careful documentation of sample collection and field analytical data and the use of chain of custody records for samples being transported. The procedures which will be used are discussed below.

7.1 FIELD SAMPLING OPERATIONS

The project manager will be responsible for ensuring that proper custody and documentation procedures are followed for the field sampling and field analytical efforts. He will be assisted in this effort by key sampling personnel involved in sampling recovery.

Samples will be collected, transported, and stored in clean containers which are constructed of materials inert to the analytical matrix such as glass jars. Only containers which allow air tight seals will be used. Amber glass jars will be employed when containers are needed to inhibit photochemical reactions.

All sampling data, including information regarding sampling times, locations, and any specific considerations associated with sample acquisition will be recorded on preformatted data sheets. All samples will be given unique, identifying alphanumeric sample codes which will serve to track samples from the field to the laboratory.

Samples will be stored for transport from the lab to the field to the lab in storage boxes constructed in a fashion which minimizes movement and thus prevents breakage of containers. For example, boxes used for transporting glass containers will have foam inserts with form-fitting cutouts. Sample transport boxes will be locked except when in use. Vans containing equipment and samples will be locked whenever they are left unattended.

A daily activity log will be maintained by the project supervisor. This will be an informal log used to record various types of information, such as minor problems which arise, sketches of sampling locations, names and phone numbers of plant contacts, daily activity summaries, etc.

7.2 ANALYTICAL OPERATIONS

Analytical operations will be performed on-site in the laboratory as well as in the remote laboratories. Samples analyzed by outside laboratories are transported with a Change of Custody form. This form will list sample identifications, analytical parameters, sample matrices, anticipated date of results, and other relevant information necessary to ensure the appropriate analyses are performed and to document the progress of the samples.

8.0 INTERNAL QUALITY CONTROL CHECKS

Specific quality control (QC) procedures will be followed to ensure the continuous production of useful and valid data throughout the course of this test program. The QC checks and procedures described in this section represent an integral part of the overall sampling and analytical scheme. Strict adherence to prescribed procedures is quite often the most applicable QC check. A discussion of both the sampling and analytical QC checks that will be utilized during this program is presented below.

8.1 EQUIPMENT INSPECTION AND MAINTENANCE

Each item of field test equipment will be assigned a unique, permanent identification number. An effective preventative maintenance program is necessary to ensure data quality. Each item of equipment returning from the field will be inspected before it is returned to storage. During the course of these inspections, items are cleaned, repaired, reconditioned, and recalibrated where necessary.

Each item of equipment transported to the field for this test program will be inspected again before being packed to detect equipment problems which may originate during periods of storage. This minimizes lost time on the job site due to equipment failure.

Occasional equipment failure in the field is unavoidable despite the most rigorous inspection and maintenance procedures. For this reason, replacement equipment for all critical sampling train components will be transported to the job site.

8.2 EQUIPMENT CALIBRATION

New items for which calibration is required will be calibrated before initial field use. Equipment whose calibration status may change with use or time will be inspected in the field before testing begins and again upon return from each field use. When an item of equipment is found to be out of calibration, it will be repaired and recalibrated or retired from service. All equipment will be periodically recalibrated in full, regardless of the outcome of these regular inspections.

Calibrations will be conducted in a manner, and at a frequency, which meets or exceeds U.S. EPA specifications. The calibration procedures outlined in the EPA Methods will be followed. When these methods are inapplicable, methods such as those prescribed by the American Society for Testing Materials (ASTM) will be used.

Data obtained during calibrations will be recorded on standardized forms, which will be checked for completeness and accuracy by the quality assurance manager. Data reduction and subsequent calculations will be performed using computer facilities. Calculations will be checked at least twice for accuracy. Copies of calibration forms will be included in the test or projects reports.

Emissions sampling equipment requiring calibration includes pitot tubes, pressure gauges, thermometers, dry gas meters and barometers. The following sections elaborate on the calibration procedures to be followed for these items of equipment.

A: Pitot Tubes. All Type S pitot tubes used, whether separate or attached to a sampling probe, will be constructed in-house or by a third-party vendor. Each new pitot will

be calibrated in accordance with Section 10.1 of EPA Method 2. Each Type-S pitot tube, calibrated according to these standards, will have an assigned coefficient. This coefficient should not change as long as the pitot tube is not damaged.

Each pitot tube will be inspected visually upon return from the field. If a cursory inspection indicates damage or raises doubt that the pitot remains in accordance with the EPA geometry standards, the pitot tube will be refurbished as needed and recalibrated.

- B: Differential Pressure Gauge.** All meter consoles used are equipped with 10-inch water column (W.C.) inclined-vertical manometers. Fluid manometers do not require calibration other than leak checks. Manometers will be leak checked in the field prior to each test series, and again upon return from the field.
- C: Impinger Thermometer.** Prior to the start of testing, the thermometer used to monitor the temperature of the gas leaving the last impinger will be compared with a mercury-in-glass thermometer which meets ASTM E-1 No. 63F specifications. The impinger thermometer is adjusted if necessary until it agrees within 2°F of the reference thermometer. If the thermometer is not adjustable, it is labeled with a correction factor.
- D: Dry Gas Meter Thermometer.** The thermometer used to measure the temperature of the metered gas sample will be checked prior to each field trip against an ASTM mercury-in-glass thermometer. The dry gas meter thermometer is acceptable if the values agree within $\pm 5.4^{\circ}\text{F}$. Thermometers not meeting this requirements will be adjusted or labeled with a correction factor.
- E: Flue Gas Temperature Sensor.** All thermocouples employed for the measurement of flue gas temperature are calibrated upon receipt. Initial calibrations will be performed at three points (ice bath, boiling water, and hot oil). An ASTM mercury-in-glass thermometer will be used as a reference. The thermocouple is acceptable if the agreement is within 1.5 percent (absolute) at each of the three calibration points.

Before and after each field use, the reading from the flue gas thermocouple-potentiometer combination will be compared with an ASTM mercury-in-glass reference thermometer at ambient conditions. If the two agree within ± 1.5 percent (absolute), the thermocouple and potentiometer are considered to be in proper working order.

- F: Dry Gas Meter and Orifice.** Two procedures will be used to calibrate the dry gas meter and orifice simultaneously. The full calibration will be a complete laboratory procedure used to obtain the calibration factor of the dry gas meter. Full calibrations will be performed over a wide range of orifice settings. A simpler procedure, the post-test calibration, will be designed to check whether the calibration factor has changed.

A dry gas meter that is calibrated annually against a spirometer or a set of calibrated critical orifices will be used as a transfer standard. During the annual calibration, triplicate calibration runs will be performed at seven flow rates ranging from 0.25 to 1.40 cfm.

G: Dry Gas Meter. Each metering system receives a full calibration at the time of purchase and a post-test calibration after each field use. If the calibration factor, γ , deviates by less than five percent from the initial value, the test data are acceptable. If γ deviates by more than 5 percent, the meter is recalibrated and the meter coefficient (initial or recalibrated) that yields the lowest sample volume for the test runs is used.

EPA Method 5 requires another full calibration anytime the post-test calibration check indicates that γ changed by more than 5 percent. Standard practice is to adjust and recalibrate the dry gas meter anytime γ is found to be outside the range of 0.96 to 1.04. Post-test calibrations will be performed after each field test series per EPA Method 5, section 16.3 procedures.

H: Orifice. An orifice calibration factor will be calculated for each flow setting during a full calibration. If the range of values does not vary by more than 0.20 in H_2O over a range of 0.4 to 4.0 in H_2O , the arithmetic average of the values obtained during the calibration is used.

I: Barometer. Each field barometer will be adjusted before each test series to agree within ± 0.1 inches of a reference aneroid barometer. The reference barometer will be checked against the station pressure value (corrected for elevation difference) reported by the National Weather Service.

8.3 SAMPLING QUALITY CONTROL PROCEDURES

The following pretest QC checks will be conducted:

- All sampling equipment will be thoroughly checked to ensure clean and operable components.
- Equipment will be inspected for possible damage from shipment.
- The oil manometer or Magnehelic gauge used to measure pressure across the Type S pitot tube will be leveled and zeroed.
- The number and location of the sampling traverse points will be checked before taking measurements.
- The temperature measurement system will be visually checked for damage and operability by measuring the ambient temperature prior to each traverse.

In addition to the general QC procedures listed above, QC procedures specific to each sampling method will also be incorporated into the sampling scheme. These methods and specific procedures are discussed below.

A: Sampling Train QC checks. The following QC procedures will be emphasized:

Prior to Start of Tests

- Keep all cleaned glassware and sample train components sealed until train assembly.
- Assemble the sampling trains in an environment free from uncontrolled dust.
- Visually inspect each sampling train for proper assembly.
- Perform pretest calculations to determine the proper sampling nozzle size.

Prior to Each Test Run

- Visually inspect the sampling nozzle.
- Visually inspect the Type S pitot tube.
- Leak check each leg of the Type S pitot tube.
- Leak check the entire sampling train.

During Each Test Run

- Readings of temperature and differential pressure will be taken at each transverse point.
- All sampling data and calculations will be recorded on preformatted data sheets.
- All calibration data forms will be reviewed for completeness and accuracy.
- Any unusual occurrences will be noted during each run on the appropriate data form.
- The project supervisor will review sampling data sheets daily during testing.
- Properly maintain the roll and pitch axis of the Type S pitot tube and the sampling nozzle.
- Leak check the train before and after any move from one sampling port to another during a run (at DEECO's option) or if a filter change takes place.
- Conduct additional leak checks if the sampling time exceeds 4 hours.
- Maintain the probe, filter, and impingers at the proper temperatures.
- Maintain ice in the ice bath at all times.
- Make proper readings of the dry gas meter, delta P and delta H, temperature, and pump vacuum during sampling at each traverse point.
- Maintain isokinetic sampling within $\pm 10\%$ of 100%.

After Each Test Run

- Visually inspect the sampling nozzle.
- Visually inspect the Type S pitot tube.
- Leak check each leg of the Type S pitot tube.
- Leak check the entire sampling train.

B: QC for Volumetric air flow rate determinations

Flue Gas Velocity. Data required to determine the flue gas velocity will be collected using the methodology specified in EPA Method 2. Quality control procedures are as follows.

- Visually inspect the Type S pitot tube before and after sampling.
- Leak check both legs of the pitot tube before and after sampling.
- Check the number and location of the sampling traverse points before taking measurements.

Flue Gas Molecular Weight. In the event that that integrated bag samples are to be used for determination of flue gas molecular weight, EPA Method 3 will be the sampling technique specified. Quality control will focus on the following procedures:

- The sampling train will be leak checked before and after each run.
- A constant sampling rate will be used in withdrawing a sample.
- The sampling train will be purged prior to sample collection.
- The sampling port will be properly sealed to prevent air in-leakage.

Moisture Content. The moisture content of the gas stream will be determined using the technique specified in EPA Method 4. The following QC checks will be performed:

- The sampling train will be leak checked before and after each run.
- Ice will be maintained in the ice bath throughout each run to insure an exit temperature (after the silica gel impinger) of $\leq 67^{\circ}\text{F}$.

8.4 ANALYTICAL QUALITY CONTROL PROCEDURES

All analyses for this program will be performed using accepted laboratory procedures in accordance with the specified analytical protocols. Adherence to prescribed QC procedures will ensure data of consistent and measurable quality. Analytical QC will focus upon the use of control standards to provide a measure of analytical precision and accuracy. Also, specific acceptance criteria are defined for various analytical operations including calibrations, control standard analyses, drift checks, blanks, etc. The following general QC procedures will be incorporated into the analytical effort:

- The on-site project manager will review all analytical data and QC data on a daily basis for completeness and acceptability.
- Analytical QC data will be tabulated using the appropriate charts and forms on a daily basis
- Copies of the QC data tabulation will be submitted to the quality assurance manager following the completion of the test program.
- All hard copy raw data (i.e., chromatograms, computer printouts, etc.) will be maintained in organized files.

Specific analytical QC procedures for the Orsat analyzer (if used) are listed below.

- The analyzer will be leveled and the fluid levels zeroed prior to use.
- The analyzer will be leak checked prior to use.
- The analyzer will be thoroughly purged with sample prior to use.
- The analyzer will be checked by analyzing an ambient air sample.

EPA Method 26A Sample Analysis QC Checks are listed below.

- Calibration curve consisting of 4 calibration levels that bracket the expected sample range. Dilute samples as necessary to reach the calibration range;
- Duplicate analysis of calibration standards, before and after sample analysis, with duplicate injections being within 5% of their mean;
- Duplicate analysis of reagent blanks, quality control samples and field samples with duplicate injections being within 5% of their mean;
- Matrix spike samples may be prepared and analyzed. Matrix spike recoveries should be 90-110%
- A field blank will be carried through the procedure and analyzed with the field samples.
- An audit sample will be analyzed for if available from two or more independent, Approved Audit Sample Providers no less than 60 days prior to the test effort.

9.0 REPORTING AND DATA REDUCTION REQUIREMENTS

9.1 DATA REPORTING

The results will be presented in a format which meets the requirements of the TCEQ reporting requirements. Any data that is not acceptable because of technical difficulties will be indicated, and an explanation of the technical problem will be given. All related QC and calibration data will be in the final report.

9.2 REPORT CONTENTS

Copies of the test report will be submitted after the test series has been completed. Results reported will include, but not be limited to emission rates and concentrations of gaseous pollutants, and process sample determinations, any liquid stream constituents determinations, and any other type of data requested. This report will also include a list of all personnel present during testing, summary results, descriptions of test procedures used, a description of the source and its operation during testing, test locations drawings, example calculations, raw field data, and equipment calibrations.

9.3 DATA REDUCTION

Care will be exercised to ensure hand recorded data is written accurately and legibly. Additionally, the use of prepared data recording forms, conveniently formatted, is an important aid to verify that all necessary data items are recorded. The collected field and laboratory data will be reviewed by the analyst and the Project Manager.

The Project Manager will reduce and validate all of the sampling and analytical data that is collected. The sampling data will include flow measurements, calibrations, etc. Each laboratory will reduce all analytical results prior to their submission to the Project Manager. The analytical data will be used to determine concentrations and emission rates of the compounds of interest.

Data reduction follows guidelines published in EPA Reference Methods, where applicable, and by guideline documents where EPA Reference Methods are not available. Validated computer programs will be used to calculate all reported values.

9.4 DATA VALIDATION

A second technical review of the data will be performed and documented by a qualified scientist other than the one who performed the actual analyses. The second reviewer will include evidence (e.g., check marks, recalculations, etc.) that show which data points were checked. Finally, the second reviewer will sign and date the cover page of the data packet or the record that was reviewed.

In-situ measurements will be validated by demonstrated acceptable post-test leak checks and calibration verifications according to the referenced method used.

Analysis data may be validated according to defined criteria by a secondary reviewer or by the analyst. At a minimum and if applicable, analysis data will be validated according to the following criteria (additional method-specific criteria or project requirements may apply):

- Sampling records complete and traceable
- All appropriate QC samples included with the analytical batch and reported with the sample results
- Routine tuning, calibration and inspection of analytical instrumentation documented and performed prior to analyses
- Initial and continuing calibration criteria met
- Method/reagent blanks confirm no background contamination
- Surrogate recoveries within criteria
- Qualitative sample results (e.g., retention times, mass spectra, isotopic ratios) consistent with standard data
- Sample data within the calibrated range of the instrument
- Chromatograms or other raw data consistent with computer-generated quantitation reports
- Accuracy of intermediate data manipulations, transcribed numbers and/or final reported results verified
- Reference standards, instrumentation, sample identification, analysts, methodology, and sequence of processing clearly identified and traceable in the project records
- Lost data or corrective actions documented (e.g., loss of sample, reanalysis, redilutions, additional cleanup steps, alternative calculations etc.)
- Data that does not meet the validation requirements flagged accordingly
- Data reported in the correct units (e.g., "ppm" should not be used without specifying volume or mass units; "ug/g" are preferred units for data reporting)

10.0 PLANT ENTRY AND SAFETY

10.1 SAFETY RESPONSIBILITIES

The Project Manager is responsible for ensuring compliance with plant entry, health, and safety requirements. The Facility Contact (refer to Section 1.2) as the authority to impose or waive facility restrictions. The Project Manager has the authority to negotiate with facility person any deviations from the facility restrictions.

10.2 SAFETY PROGRAM

DEECO has a comprehensive health and safety program that satisfies Federal OSHA and MSHA requirements. The basic elements include: (1) written policies and procedures, (2) routine training of employees and supervisors, (3) medical monitoring, (4) use of personal protection equipment, (5) hazard communication, (6) pre-mobilization meetings with Holcim personnel and DEECO test team personnel, and (7) routine surveillance of the on-going test work.

10.3 SAFETY REQUIREMENTS

All test personnel will adhere to the following standard safety and precautionary measures as follows:

- 1) Confine activities to test area only;
- 2) Wear hard hats at all times on-site, except inside sample recovery trailers and mobile CEM laboratory;
- 3) Wear protective shoes or boots in test area;
- 4) Wear protective glasses or goggles at the outlet test sites, and other areas as designated;
- 5) Have readily available first aid equipment and fire extinguishers.

Before or on the first day on-site, the Project Manager will fill out the Emergency Response Procedure form and provide copies to be posted at each test site.

Appendix A

Sampling and Analytical Methods

The sampling and analytical methods for this sampling effort can be found at the following website:

Promulgated EPA test methods, 40 CFR 60 (Methods 1-4, 26A, and 320)

<https://www.epa.gov/emc/emc-promulgated-test-methods>