

Note: This material is related to a section in *AP42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the file number, the AP42 chapter and then the section. The file name "rel01_c01s02.pdf" would mean the file relates to AP42 chapter 1 section 2. The document may be out of date and related to a previous version of the section. The document has been saved for archival and historical purposes. The primary source should always be checked. If current related information is available, it will be posted on the AP42 webpage with the current version of the section.

AP42 Section:	Chapters 1 and 3
Related:	4
Title:	Source Test Review, Hershey Chocolate USA, Derry Township, PA Entropy Inc for Pennsylvania Dept of Environmental Protection November 1996

PDEP 0009

COMMONWEALTH OF PENNSYLVANIA
Department of Environmental Protection

November 8, 1996

717-787-4310

SUBJECT: Source Test Review
Hershey Chocolate USA
Hershey East Plant
Derry Township, Dauphin County

TO: Richard D. Roller
Air Pollution Control Engineer
Southcentral Regional Office

FROM: Michael S. Hopko
Air Quality Program Specialist
Stationary Source Section
Division of Air Resource Management

THROUGH: L. Blaine DeHaven
Chief
Division of Source Testing and Monitoring

Timothy R. Brooks
Chief
Source Testing Section
Division of Source Testing and Monitoring

NG/#6FO
fired Boilers

Hershey Chocolate USA operates two identical natural gas/No. 6 fuel oil fired boilers, designated as Boiler Nos. 2 and 3, at the aforementioned location. Each boiler is rated at 99.9 MMBtu/hr (approximately 80,000 lb/hr steam capacity). The emissions from these boilers are discharged to the atmosphere through a 69 inches inside diameter common stack.

Entropy, Inc. conducted testing for Oxides of Nitrogen (NO_x) and Carbon Monoxide (CO) on April 10-11, 1996 to demonstrate compliance with the Plan Approval emission limits. Emissions of NO_x are not to exceed 0.04 lb/MMBtu when fired with natural gas or 0.3 lb/MMBtu when fired with No. 6 fuel oil. Emissions of CO are not to exceed 0.1 lb/MMBtu when fired with either fuel. Testing was conducted in the common stack for the two boilers. One boiler was shut down while the other boiler was being tested. This process was repeated on the second day with a change in fuel. The test runs were conducted in accordance with the preapproved test protocol and EPA Methods 3A, 7E, and 10. The results are acceptable to the Department.

The following is a summary of data presented in the test report:

Boiler Number 2-Natural Gas

Test Run No.	1	2	3
Test Date	04/10/96	04/10/96	04/10/96
CO Concentration [ppm]	1.7	1.7	1.4
NOx Concentration [ppm]	31.1	30.7	30.5
CO Emission Rate [lb/mmBtu]	0.00121	0.00121	0.00100
NOx Emission Rate [lb/mmBtu]	0.0363	0.0359	0.0357

Boiler Number 1-No.6 Fuel Oil

Test Run No.	1	2	3
Test Date	04/11/96	04/11/96	04/11/96
CO Concentration [ppm]	11.2	9.0	8.6
NOx Concentration [ppm]	253.9	295.0	296.6
CO Emission Rate [lb/mmBtu]	0.0020	0.00709	0.00676
NOx Emission Rate [lb/mmBtu]	0.33	0.382	0.383

Boiler Number 3-Natural Gas

Test Run No.	1	2	3
Test Date	04/10/96	04/10/96	04/10/96
CO Concentration [ppm]	4.0	4.8	4.3
NOx Concentration [ppm]	29.5	29.6	29.5
CO Emission Rate [lb/mmBtu]	0.00322	0.00356	0.00319
NOx Emission Rate [lb/mmBtu]	0.0391	0.0361	0.0360

Boiler Number 3-No.6 Fuel Oil

Test Run No.	1	2	3
Test Date	04/11/96	04/11/96	04/11/96
CO Concentration [ppm]	84.9	22.2	25.3
NOx Concentration [ppm]	293.0	302.9	308.0
CO Emission Rate [lb/mmBtu]	0.0666	0.0175	0.020
NOx Emission Rate [lb/mmBtu]	0.378	0.393	0.392

cc: Data File, Source Testing ✓
 RACT OP 22-2004
 Permit File 22-302-109
 Krish Ramamurthy, Permits
 Scott Kepner, Compliance and Enforcement
 EPA/TRB
 Reading File, Source Testing Section

LBD:TRB:MSH:msh

Environmental Protection
May 23, 1996

SUBJECT: Source Test Review
Hershey Chocolate USA
Hershey East Plant
Derry Township, Dauphin County
File: 22-2004 and 22-302-109

TO: L. Blaine DeHaven, Chief
Division of Source Testing and Monitoring

FROM: Richard D. Roller *RDR*
Air Pollution Control Engineer
Southcentral Regional Office

Please review the attached source tests which were conducted on the two new natural gas/No. 6 fuel oil fired boilers at the above location. The identical Tappella Power boilers are each rated at 99.9 MBtu/hr (approximately 80,000 lb/hr steam capacity) and are subject to both NSPS, Subpart Dc and several special permit conditions. The pretest procedure was reviewed by Jay Pai.


The following should be considered when reviewing the test report:

1. Testing was conducted to demonstrate compliance only with the non-NSPS special permit conditions (Conditions 8, 9 and 12 thru 15 of RACT Plan Approval 22-2004 and Conditions 9, 10 and 15 thru 18 of Plan Approval 22-302-109).
2. The applicable NO_x and CO emission standards are:
 - a. NO_x: 0.04 lb/MBtu when fired with natural gas and 0.30 lb/MBtu when fired with No. 6 fuel oil

Note: Hershey is in the process of seeking a revision to the No. 6 fuel oil NO_x limit
 - b. CO: 0.10 lb/MBtu when fired with either natural gas or No. 6 fuel oil
3. The boilers were originally referred to as Boilers A and B. Hershey now refers to them as Boilers 2 and 3.

Should you have any questions or comments, please contact me at 657-4587.

cc: Southcentral Region 22-2004
Southcentral Region 22-302-109



ENTROPY, INC.

Specialists in Air Emissions Technology

P.O. Box 12291 • Research Triangle Park, North Carolina 27709-2291
(919) 781-3550 • (800) 486-3550 • Fax (919) 787-8442

STATIONARY SOURCE SAMPLING REPORT

REFERENCE NO. 13929

HERSHEY CHOCOLATE

HERSHEY, PENNSYLVANIA

Derry Twp., Dauphin County

EMISSIONS:

CARBON MONOXIDE

NITROGEN OXIDES

Hershey East Plant

File 22-2004

22-302-109

APRIL 1996

BOILER NOS. 2 AND 3

PERFORMED FOR:

HERSHEY CHOCOLATE

HERSHEY, PENNSYLVANIA

Table of Contents

1.0 INTRODUCTION	1-1
1.1 Outline of Test Program	1-1
1.2 Test Participants	1-1
2.0 SUMMARY OF RESULTS.....	2-1
3.0 PROCESS DESCRIPTION AND OPERATION	3-1
4.0 TEST EQUIPMENT AND PROCEDURES	4-1
4.1 Instrumental Reference Method Test Equipment and Procedures	4-1
4.2 Equipment Calibration.....	4-4
 APPENDIX A. TEST RESULTS	
1. Boiler No. 2	
a. Natural Gas.....	1
b. No. 6 Fuel Oil	9
2. Boiler No. 3	
a. Natural Gas.....	17
b. No. 6 Fuel Oil	25
3. Example Calculations	33
 APPENDIX B. FIELD DATA	
1. Boiler No. 2	
a. Natural Gas.....	37
b. No. 6 Fuel Oil	49
2. Boiler No. 3	
a. Natural Gas.....	63
b. No. 6 Fuel Oil	81
 APPENDIX C. CALIBRATION DATA.....	95
APPENDIX D. PROCESS DATA.....	113

REPORT CERTIFICATION

El Reference Number 13929

The sampling and analysis performed for this report were carried out under my direction and supervision, and I hereby certify that, to the best of my knowledge, the test report is authentic and accurate.

Signature: J. Gary Bulluck

Date: 5-7-96

J. Gary Bulluck
Project Director
Client Services Division

1.0 INTRODUCTION

1.1 Outline of Test Program

Hershey Chocolate has conducted a testing program to quantify specific emissions from Boiler Nos. 2 and 3 in Hershey, Pennsylvania.

EPA Method 3A, 7E, and 10 tests were conducted concurrently on April 10 and 11, 1996 at Boiler Nos. 2 and 3 using two different fuels. Natural Gas was used to fire each boiler on April 10, 1996 and No. 6 low sulfur fuel oil was used to fire each boiler on April 11, 1996.

1.2 Test Participants

Table 1-1 lists the personnel involved in the test program.

**TABLE 1-1
TEST PARTICIPANTS
BOILER NOS. 2 AND 3
APRIL 1996**

Hershey Chocolate	Chuck Stoner Test Coordinator
Commonwealth of Pennsylvania, Department of Environmental Resources, Bureau of Air Quality Control	Richard Roller Test Observer
	Jaydeb Pai Protocol Reviewer
Entropy, Inc.	J. Gary Bulluck Project Director
	Lauren A. Sherwood Project Manager
	Michael S. Riedel Engineering Technician

2.0 SUMMARY OF RESULTS

This testing program is to demonstrate compliance with the nitrogen oxides and carbon monoxide emission limits of the construction permit as described in Chapter 139 of the Department Source Testing Manual. Emissions of nitrogen oxides are not to exceed 0.04 lb/MMBtu when fired with natural gas or 0.3 lb/MMBtu when fired with No. 6 fuel oil. Emissions of carbon monoxide are not to exceed 0.1 lb/MMBtu when fired with either fuel.

During the testing, the process was operating at full capacity. The No. 2 boiler was operating within a steam production range of 79.7 - 80.4 klbs/hr and at 78.0 - 79.0 klbs/hr while burning natural gas and No. 6 fuel oil, respectively. The No. 3 boiler's operating range for natural gas and No. 6 fuel oil was 78.4 - 79.8 and 77.7 - 80.0, respectively. See **Appendix D** for the process data provided by plant personnel.

Table 2-1 presents a summary of the test results vs. permitted limits. Detailed test results are presented in **Appendix A**; field and calibration data are given in **Appendices B** and **C**, respectively.

TABLE 2-1
TEST RESULTS VS. PERMITTED LIMITS
BOILER NOS. 2 AND 3
APRIL 1996

	Rep 1	Rep 2	Rep 3	Average	Permit Limit
BOILER NO. 2-Natural Gas					
Concen., ppm					
Carbon Monoxide	1.7	1.7	1.4	1.6	NA
Nitrogen Oxides	31.1	30.7	30.5	30.8	NA
Emission Rate, lb/mmBtu					
Carbon Monoxide	0.00121	0.00121	0.00100	0.00114	0.1
Nitrogen Oxides	0.0363	0.0359	0.0357	0.0360	0.04
BOILER NO. 2-No. 6 Fuel Oil					
Concen., ppm					
Carbon Monoxide	15.2	9.0	8.6	10.9	NA
Nitrogen Oxides	293.9	295.0	296.6	295.2	NA
Emission Rate, lb/mmBtu					
Carbon Monoxide	0.0120	0.00709	0.00676	0.00862	0.1
Nitrogen Oxides	0.383	0.382	0.383	0.383	0.3
BOILER NO. 3-Natural Gas					
Concen., ppm					
Carbon Monoxide	4.0	4.8	4.3	4.4	NA
Nitrogen Oxides	29.5	29.6	29.5	29.5	NA
Emission Rate, lb/mmBtu					
Carbon Monoxide	0.00322	0.00356	0.00319	0.00332	0.1
Nitrogen Oxides	0.0391	0.0361	0.0360	0.0371	0.04
BOILER NO. 3-No. 6 Fuel Oil					
Concen., ppm					
Carbon Monoxide	84.9	22.2	25.3	44.1	NA
Nitrogen Oxides	293.0	302.9	308.0	301.3	NA
Emission Rate, lb/mmBtu					
Carbon Monoxide	0.0666	0.0175	0.020	0.0347	0.1
Nitrogen Oxides	0.378	0.393	0.392	0.388	0.3

3.0 PROCESS DESCRIPTION AND OPERATION

Hershey Chocolate manufactures chocolate at their facility located in Hershey, Pennsylvania. Power for this facility is generated by two 99 MMBtu mirror image package boilers. These two boilers can be fired with either natural gas or No. 6 low sulfur fuel oil. Testing will be conducted on the two mirror image boilers. Since the two boilers share a common stack, one boiler was shut down while the other boiler was being tested. This process was repeated on the second day with a change in fuel. On the first and second days of testing, the boilers were fueled with natural gas and No. 6 fuel oil, respectively.

The testing covered in this report was performed at the Boiler Nos. 2 and 3. The sampling location is a circular vertical stack with a 69 inch internal diameter and is outfitted with two 4 inch diameter sampling ports.

4.0 TEST EQUIPMENT AND PROCEDURES

4.1 Instrumental Reference Method Test Equipment and Procedures

Instrumental reference method testing was conducted for carbon monoxide (CO) and nitrogen oxide (NO_x) emissions and oxygen (O₂) concentrations. Entropy's extractive measurement system and all sampling and analytical procedures for the O₂, NO_x and CO testing conformed with the requirements of EPA Test Methods 3A, 7E, and 10 (40 CFR 60), respectively.

Table 4-1 presents a list of the analyzers that Entropy used during the test program to quantify the gas concentration levels at the sample point locations. Figure 4-1 is a simplified schematic of Entropy's Instrumental reference method measurement system.

The extractive monitors require that the effluent gas sample be conditioned to eliminate any possible interference (i.e., water vapor and/or particulate matter) before being transported and injected into each analyzer. All components of the sampling system which contacted the sample were constructed of Type 316 stainless steel or Teflon. The outputs from the monitors were connected to a computerized data acquisition system (DAS).

The O₂, NO_x, and CO sample collection system consisted of a heated probe with an in-stack glass wool particulate filter, heated sample lines, a moisture removal trap, an out-of-stack secondary particulate filter, and a pump. All samples were routed through a distribution manifold board for delivery to the analyzers. The configuration of the sampling system allows for the injection of calibration gases directly to the analyzers or through the sampling system. A Thomas Model 2107CA 18-TFE pump was used to move the effluent sample through the system. All pretest and posttest calibration procedures were performed as outlined in the specific EPA methods. The operation of each analyzer and the DAS are described below.

TABLE 4-1
REFERENCE METHOD GAS ANALYZERS
APRIL 1996

PARAMETER (RANGE)	ANALYZER/MODEL NUMBER	ANALYTICAL TECHNIQUE
CO (0-500 ppm-oil) (0-200 ppm-natural gas)	Thermo Environmental Instruments / 48	Gas Filter Correlation
O ₂ (0-25%)	Teledyne Model / 320P-4	Fuel Cell
NO _x (0-200%)	Thermo Environmental Instruments / 10	Chemiluminescence




FIGURE 4-1. INSTRUMENTAL REFERENCE MEASUREMENT SYSTEM

Thermo Environmental Instruments Model 48/GFC CO Analyzer. The analyzer utilizes the gas filter correlation (GFC) technique to determine CO concentrations. The GFC technique involves the use of a high CO concentration filter which, when inserted into the infrared light beam, produces a reference beam, i.e., no further infrared radiation can be attenuated by the CO in the effluent sample. The CO filter is located on a modulated copper wheel which allows the use of a single infrared source and detector. A multiple pass optical bench/sample chamber of the white cell design provides improved sensitivity with a smaller chamber length.

TECO Model 10 NO/NO_x Analyzer. This analyzer automatically and continuously determines the concentration of the nitric oxide (NO) or nitrogen oxides (NO_x) in the effluent. The analytical technique is chemiluminescence. The sample is routed through a converter where the NO₂ is dissociated to form NO. The sample is then passed through a reaction chamber where the NO is quantitatively converted to NO₂ by gas phase oxidation with molecular ozone produced within the analyzer. In this reaction, the NO₂ molecules are elevated to an electronically excited state and immediately reverted to a nonexcited ground state. This reversion is accompanied by the emission of photons, which impinge on a photomultiplier detector and generate a low level DC current. The current is then amplified and used to drive a front panel meter and a data recorder. The NO_x concentration seen by the instrument includes the contributions of both the NO in the sample and the NO resulting from the dissociation of the NO₂ in the sample.

Teledyne Model 320P-4 O₂ Analyzer. This analyzer was designed specifically to measure O₂ in flue gas streams. It utilizes a patented micro-fuel cell that consumes O₂ from the atmosphere surrounding the measuring probe. The consumption of O₂ generates a proportional electric current, which is amplified and used to drive a built-in front panel meter with a scale of 0 to 25%. The analyzer incorporates its own integral pump and power system.

Data Acquisition System. Entropy's (DAS) uses an IBM-compatible computer with hard disk storage and an internal 12-bit analog-to-digital converter with a 16-channel multiplexer. In addition to providing an instantaneous display of analyzer responses, the DAS compiles the analyzer data collected once each second and averages them, calculates emission rates, and documents analyzer calibrations. The test data and calibrations are stored on hard disk and then printed.

All test run concentration results were determined from the average gas concentrations measured during the run and adjusted based on the zero and upscale sampling system bias check results (Equation 6C-1 presented in Method 6C, Section 8). The emission rate values (in units of lb/mmBtu of heat input) were computed from the corrected reference CO and NO_x emission rate values using the O₂-based fuel specific F-factor, 8,710 for Natural Gas and 9,190 for No. 6 Fuel Oil, and the equation presented in EPA Method 19, Section 2.1.

4.2 Equipment Calibration

EPA Protocol 1 gases were used on this compliance test. The calibration gas certificates of analysis, the reference method system performance tests, and the NO₂ to NO conversion efficiency tests are provided in **Appendix C**.

APPENDIX A. TEST RESULTS

1. Boller No. 2

a. Natural Gas

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 2 - GAS

RUN: 2G-CEM-1<1505-1605>

DATE: 04/10/96.

GAS VALUE		INITIAL CAL	FINAL CAL	MEAN CAL
0.0	ppm NOx	0.8	1.0	0.9
46.9	ppm NOx	46.8	47.4	47.1
0.0	ppm CO	0.5	0.3	0.4
59.3	ppm CO	57.4	57.4	57.4
0.00	% Oxygen	0.21	0.13	0.17
12.02	% Oxygen	11.82	11.81	11.82

Uncorrected Data: - 31.5 ppm NOx - 2.36 % Oxygen
2.0 ppm CO

CORRECTED RESULTS

31.1	ppm NOx	0.0363	lb NOx/MBtu
1.7	ppm CO	0.00121	lb CO/MBtu
2.26	% Oxygen		

$$\text{Corrected Conc.} = C_{ma}(C^- - C_o) / (C_m - C_o)$$

Where: $\bar{C}$ = mean reference measurement
 C_0 = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 2 - GAS

RUN: 2G-CEM-2<1615-1715>

DATE: 04/10/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	1.0	1.1	1.1
46.9 ppm NOx	47.4	48.2	47.8
0.0 ppm CO	0.3	0.4	0.4
59.3 ppm CO	57.4	57.4	57.4
0.00 % Oxygen	0.13	0.07	0.10
12.02 % Oxygen	11.81	11.84	11.83

Uncorrected Data: 31.7 ppm NOx 2.33 % Oxygen
2.0 ppm CO

CORRECTED RESULTS

30.7 ppm NOx 0.0359 lb NOx/MBtu
1.7 ppm CO 0.00121 lb CO/MBtu
2.29 % Oxygen

$$\text{Corrected Conc.} = C_{ma}(C - C_o)/(C_m - C_o)$$

Where: C = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

NOx AND CO EMISSIONS

DATE: 04/10/96

GAS VALUE		INITIAL CAL	FINAL CAL	MEAN CAL
0.0	ppm NOx	1.1	1.3	1.2
46.9	ppm NOx	48.2	47.2	47.7
0.0	ppm CO	0.4	1.0	0.7
59.3	ppm CO	57.4	57.6	57.5
0.00	% Oxygen	0.07	0.10	0.09
12.02	% Oxygen	11.84	11.87	11.86

Uncorrected Data: - 31.4 ppm NOx - 2.39 % Oxygen
 2.0 ppm CO

CORRECTED RESULTS

30.5	ppm NOx	0.0357	lb NOx/MBtu
1.4	ppm CO	0.00100	lb CO/MBtu
2.35	% Oxygen		

$$\text{Corrected Conc.} = C_{ma}(C^- - C_o) / (C_m - C_o)$$

Where: $\bar{C}$ = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE
SOURCE: UNIT 2 - GAS

TEST DATE: 04/10/96

RUN NUMBER: 2G-CEN-1<1505-1605>

SPAN VALUES: 100.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	0.8	0.30	1.0	0.50	0.20
NOx UP-SCALE	46.5	46.8	0.30	47.4	0.90	0.60
CO ZERO GAS	0.4	0.5	0.05	0.3	-0.05	-0.10
CO UP-SCALE	59.3	57.4	-0.95	57.4	-0.95	0.00
O2 ZERO GAS	0.22	0.21	-0.04	0.13	-0.36	-0.32
O2 UP-SCALE	12.06	11.82	-0.96	11.81	-1.00	-0.04

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE
SOURCE: UNIT 2 - GAS

TEST DATE: 04/10/96

RUN NUMBER: 2G-CEM-2<1615-1715>

SPAN VALUES: 100.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	1.0	0.50	1.1	0.60	0.10
NOx UP-SCALE	46.5	47.4	0.90	48.2	1.70	0.80
CO ZERO GAS	0.4	0.3	-0.05	0.4	0.00	0.05
CO UP-SCALE	59.3	57.4	-0.95	57.4	-0.95	0.00
O2 ZERO GAS	0.22	0.13	-0.36	0.07	-0.60	-0.24
O2 UP-SCALE	12.06	11.81	-1.00	11.84	-0.88	0.12

SYSTEM CAL. RESPONSE - ANALYZER CAL. RESPONSE
SYSTEM CAL. BIAS = _____ X 100
SPAN

FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE
DRIFT = _____ X 100
SPAN

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE
SOURCE: UNIT 2 - GAS

TEST DATE: 04/10/96

RUN NUMBER: 2G-CEN-3<1725-1825>

SPAN VALUES: 100.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	1.1	0.62	1.3	0.80	0.18
NOx UP-SCALE	46.5	48.2	1.70	47.2	0.70	-1.00
CO ZERO GAS	0.4	0.4	0.00	1.0	0.30	0.30
CO UP-SCALE	59.3	57.4	-0.95	57.6	-0.85	0.10
O2 ZERO GAS	0.22	0.07	-0.60	0.10	-0.48	0.12
O2 UP-SCALE	12.06	11.84	-0.88	11.87	-0.76	0.12

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

APPENDIX A. TEST RESULTS

1. Boiler No. 2

b. No. 6 Fuel Oil

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 2 - OIL

RUN: 20-CEM-1<0815-0915>

DATE: 04/11/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	0.8	2.9	1.9
257.0 ppm NOx	253.0	253.7	253.4
0.0 ppm CO	0.4	0.4	0.4
59.3 ppm CO	57.4	57.4	57.4
0.00 % Oxygen	0.20	0.14	0.17
12.02 % Oxygen	12.07	12.07	12.07

Uncorrected Data: 289.5 ppm NOx 3.42 % Oxygen
15.0 ppm CO

CORRECTED RESULTS

293.9 ppm NOx 0.383 lb NOx/MBtu
15.2 ppm CO 0.0120 lb CO/MBtu
3.28 % Oxygen

$$\text{Corrected Conc.} = C_{ma}(C - C_o)/(C_m - C_o)$$

Where: $\bar{C}$ = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 2 - OIL

RUN: 20-CEM-2<0925-1025>

DATE: 04/11/96

GAS VALUE		INITIAL CAL	FINAL CAL	MEAN CAL
0.0	ppm NOx	2.9	2.3	2.6
257.0	ppm NOx	253.7	251.4	252.6
0.0	ppm CO	0.4	0.4	0.4
59.3	ppm CO	57.4	57.2	57.3
0.00	% Oxygen	0.14	0.28	0.21
12.02	% Oxygen	12.07	12.17	12.12

Uncorrected Data: . 289.6 ppm NOx . 3.38 % Oxygen
 . 9.0 ppm CO

=====

CORRECTED RESULTS

295.0 ppm NOx 0.382 lb NOx/MBtu
 9.0 ppm CO 0.00709 lb CO/MBtu
 3.20 % Oxygen

=====

$$\text{Corrected Conc.} = C_{ma}(C - C_o)/(C_m - C_o)$$

Where: C = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 2 - OIL

RUN: 20-CEM-3<1045-1145>

DATE: 04/11/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	2.3	2.5	2.4
257.0 ppm NOx	251.4	254.3	252.9
0.0 ppm CO	0.4	1.0	0.7
59.3 ppm CO	57.2	57.2	57.2
0.00 % Oxygen	0.28	0.11	0.20
12.02 % Oxygen	12.17	12.10	12.14

Uncorrected Data: 291.5 ppm NOx 3.34 % Oxygen
8.9 ppm CO

CORRECTED RESULTS

296.6 ppm NOx 0.383 lb NOx/MBtu
8.6 ppm CO 0.00676 lb CO/MBtu
3.16 % Oxygen

$$\text{Corrected Conc.} = C_{ma}(C - C_o)/(C_m - C_o)$$

Where: $\bar{C}$ = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 2 - OIL

TEST DATE: 04/11/96

RUN NUMBER: 20-CEM-1<0815-0915>

SPAN VALUES: 500.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	0.8	0.06	2.9	0.48	0.42
NOx UP-SCALE	252.8	253.0	0.04	253.7	0.18	0.14
CO ZERO GAS	0.2	0.4	0.10	0.4	0.10	0.00
CO UP-SCALE	59.1	57.4	-0.85	57.4	-0.85	0.00
O2 ZERO GAS	0.24	0.20	-0.16	0.14	-0.40	-0.24
O2 UP-SCALE	12.17	12.07	-0.40	12.07	-0.40	0.00

SYSTEM CAL. RESPONSE - ANALYZER CAL. RESPONSE
SYSTEM CAL. BIAS = _____ X 100
SPAN

FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE
DRIFT = _____ X 100
SPAN

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 2 - OIL

TEST DATE: 04/11/96

RUN NUMBER: 20-CEN-2<0925-1025>

SPAN VALUES: 500.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	2.9	0.48	2.3	0.36	-0.12
NOx UP-SCALE	252.8	253.7	0.18	251.4	-0.28	-0.46
CO ZERO GAS	0.2	0.4	0.10	0.4	0.10	0.00
CO UP-SCALE	59.1	57.4	-0.85	57.2	-0.95	-0.10
O2 ZERO GAS	0.24	0.14	-0.40	0.28	0.16	0.56
O2 UP-SCALE	12.17	12.07	-0.40	12.17	0.00	0.40

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE
SOURCE: UNIT 2 - OIL

TEST DATE: 04/11/96

RUN NUMBER: 20-CEM-3<1045-1145>

SPAN VALUES: 500.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	2.3	0.36	2.5	0.40	0.04
NOx UP-SCALE	252.8	251.4	-0.28	254.3	0.30	0.58
CO ZERO GAS	0.2	0.4	0.10	1.0	0.40	0.30
CO UP-SCALE	59.1	57.2	-0.95	57.2	-0.95	0.00
O2 ZERO GAS	0.24	0.28	0.16	0.11	-0.52	-0.68
O2 UP-SCALE	12.17	12.17	0.00	12.10	-0.28	-0.28

SYSTEM CAL. RESPONSE - ANALYZER CAL. RESPONSE
SYSTEM CAL. BIAS = _____ X 100
SPAN

FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE
DRIFT = _____ X 100
SPAN

APPENDIX A. TEST RESULTS

2. Boiler No. 3

a. Natural Gas

CALCULATION OF AVERAGE NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - GAS

RUN: 3G-CEM-1<1000-1100>

DATE: 04/10/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	0.6	0.8	0.7
46.9 ppm NOx	46.4	46.5	46.5
0.0 ppm CO	0.6	1.0	0.8
59.3 ppm CO	58.5	57.4	58.0
0.00 % Oxygen	0.27	0.30	0.29
12.02 % Oxygen	11.97	11.97	11.97

Uncorrected Data: - 29.5 ppm NOx - 4.65 % Oxygen
4.7 ppm CO

CORRECTED RESULTS

29.5 ppm NOx 0.0391 lb NOx/MBtu
4.0 ppm CO 0.00322 lb CO/MBtu
4.49 % Oxygen

$$\text{Corrected Conc.} = C_{ma}(C - C_o)/(C_m - C_o)$$

Where: $\bar{C}$ = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - GAS

RUN: 3G-CEM-2<1110-1210>

DATE: 04/10/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	0.8	0.8	0.8
46.9 ppm NOx	46.5	47.0	46.8
0.0 ppm CO	1.0	0.4	0.7
59.3 ppm CO	57.4	57.4	57.4
0.00 % Oxygen	0.30	0.08	0.19
12.02 % Oxygen	11.97	11.84	11.91

Uncorrected Data: 29.8 ppm NOx 3.20 % Oxygen
5.3 ppm CO

CORRECTED RESULTS

29.6 ppm NOx 0.0361 lb NOx/MBtu
4.8 ppm CO 0.00356 lb CO/MBtu
3.09 % Oxygen

$$\text{Corrected Conc.} = C_{ma}(C - C_o)/(C_m - C_o)$$

Where: C = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - GAS

RUN: 3G-CEM-3<1220-1320>

DATE: 04/10/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	0.8	0.8	0.8
46.9 ppm NOx	47.0	46.8	46.9
0.0 ppm CO	0.4	0.5	0.5
59.3 ppm CO	57.4	57.4	57.4
0.00 % Oxygen	0.08	0.21	0.15
12.02 % Oxygen	11.84	11.82	11.83

Uncorrected Data: 29.8 ppm NOx 3.16 % Oxygen
4.6 ppm CO

CORRECTED RESULTS

29.5 ppm NOx 0.0360 lb NOx/MBtu
4.3 ppm CO 0.00319 lb CO/MBtu
3.10 % Oxygen

$$\text{Corrected Conc.} = C_{ma}(C - C_o)/(C_m - C_o)$$

Where: $\bar{C}$ = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE
SOURCE: UNIT 3 - GAS

TEST DATE: 04/10/96

RUN NUMBER: 3G-CEM-1<1000-1100>

SPAN VALUES: 100.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	ANALYZER CAL. RESPONSE	-----INITIAL VALUES-----		-----FINAL VALUES-----		DRIFT (% OF SPAN)
		SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	
NOx ZERO GAS	0.5	0.6	0.10	0.8	0.30	0.20
NOx UP-SCALE	46.5	46.4	-0.10	46.5	0.00	0.10
CO ZERO GAS	0.4	0.6	0.10	1.0	0.30	0.20
CO UP-SCALE	59.3	58.5	-0.40	57.4	-0.95	-0.55
O2 ZERO GAS	0.22	0.27	0.20	0.30	0.32	0.12
O2 UP-SCALE	12.06	11.97	-0.36	11.97	-0.36	0.00

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE
SOURCE: UNIT 3 - GAS

TEST DATE: 04/10/96

RUN NUMBER: 3G-CEM-2<1110-1210>

SPAN VALUES: 100.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	0.8	0.30	0.8	0.30	0.00
NOx UP-SCALE	46.5	46.5	0.00	47.0	0.50	0.50
CO ZERO GAS	0.4	1.0	0.30	0.4	0.00	-0.30
CO UP-SCALE	59.3	57.4	-0.95	57.4	-0.95	0.00
O2 ZERO GAS	0.22	0.30	0.32	0.08	-0.56	-0.88
O2 UP-SCALE	12.06	11.97	-0.36	11.84	-0.88	-0.52

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - GAS

TEST DATE: 04/10/96

RUN NUMBER: 3G-CEM-3<1220-1320>

SPAN VALUES: 100.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	0.8	0.30	0.8	0.30	0.00
NOx UP-SCALE	46.5	47.0	0.50	46.8	0.30	-0.20
CO ZERO GAS	0.4	0.4	0.00	0.5	0.05	0.05
CO UP-SCALE	59.3	57.4	-0.95	57.4	-0.95	0.00
O2 ZERO GAS	0.22	0.08	-0.56	0.21	-0.04	0.52
O2 UP-SCALE	12.06	11.84	-0.88	11.82	-0.96	-0.08

SYSTEM CAL. RESPONSE - ANALYZER CAL. RESPONSE
SYSTEM CAL. BIAS = _____ X 100
SPAN

FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE
DRIFT = _____ X 100
SPAN

APPENDIX A. TEST RESULTS

2. Boiler No. 3

b. No. 6 Fuel Oil

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - OIL

RUN: 30-CEM-1<1430-1530>

DATE: 04/11/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	2.5	3.1	2.8
257.0 ppm NOx	254.3	253.2	253.8
0.0 ppm CO	1.0	1.1	1.1
59.3 ppm CO	57.2	56.8	57.0
0.00 % Oxygen	0.11	0.25	0.18
12.02 % Oxygen	12.10	11.87	11.99

Uncorrected Data: 289.0 ppm NOx 3.26 % Oxygen
81.1 ppm CO

CORRECTED RESULTS

293.0 ppm NOx 0.378 lb NOx/MBtu
84.9 ppm CO 0.0666 lb CO/MBtu
3.13 % Oxygen

$$\text{Corrected Conc.} = \text{Cma}(\bar{C} - \text{Co}) / (\text{Cm} - \text{Co})$$

Where: $\bar{C}$ = mean reference measurement
Co = mean zero calibration response
Cm = mean mid or upscale calibration gas response
Cma = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - OIL

RUN: 30-CEM-2<1540-1640>

DATE: 04/11/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	3.1	4.6	3.9
257.0 ppm NOx	253.2	256.0	254.6
0.0 ppm CO	1.1	1.9	1.5
59.3 ppm CO	56.8	56.6	56.7
0.00 % Oxygen	0.25	0.12	0.19
12.02 % Oxygen	11.87	12.17	12.02

Uncorrected Data: 299.4 ppm NOx - 3.38 % Oxygen
22.2 ppm CO

CORRECTED RESULTS

302.9 ppm NOx 0.393 lb NOx/MBtu
22.2 ppm CO 0.0175 lb CO/MBtu
3.24 % Oxygen

$$\text{Corrected Conc.} = C_m(C - C_o)/(C_m - C_o)$$

Where: $\bar{C}$ = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_m = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE

NOx AND CO EMISSIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - OIL

RUN: 30-CEM-3<1650-1750>

DATE: 04/11/96

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	4.6	3.6	4.1
257.0 ppm NOx	256.0	255.9	256.0
0.0 ppm CO	1.9	1.7	1.8
59.3 ppm CO	56.6	56.4	56.5
0.00 % Oxygen	0.12	0.20	0.16
12.02 % Oxygen	12.17	12.08	12.13

Uncorrected Data: 306.0 ppm NOx 3.04 % Oxygen
25.1 ppm CO

CORRECTED RESULTS

308.0 ppm NOx 0.392 lb NOx/MBtu
25.3 ppm CO 0.020 lb CO/MBtu
2.89 % Oxygen

$$\text{Corrected Conc.} = C_{ma}(C - C_o)/(C_m - C_o)$$

Where: $\bar{C}$ = mean reference measurement
 C_o = mean zero calibration response
 C_m = mean mid or upscale calibration gas response
 C_{ma} = actual mid or upscale calibration gas concentration

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - OIL

TEST DATE: 04/11/96

RUN NUMBER: 30-CEN-1<1430-1530>

SPAN VALUES: 500.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	2.5	0.40	3.1	0.52	0.12
NOx UP-SCALE	252.8	254.3	0.30	253.2	0.08	-0.22
CO ZERO GAS	0.2	1.0	0.40	1.1	0.45	0.05
CO UP-SCALE	59.1	57.2	-0.95	56.8	-1.15	-0.20
O2 ZERO GAS	0.24	0.11	-0.52	0.25	0.04	0.56
O2 UP-SCALE	12.17	12.10	-0.28	11.87	-1.20	-0.92

SYSTEM CAL. RESPONSE - ANALYZER CAL. RESPONSE
SYSTEM CAL. BIAS = _____ X 100
SPAN

FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE
DRIFT = _____ X 100
SPAN

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - OIL

TEST DATE: 04/11/96

RUN NUMBER: 30-CEM-2<1540-1640>

SPAN VALUES: 500.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	3.1	0.52	4.6	0.82	0.30
NOx UP-SCALE	252.8	253.2	0.08	256.0	0.64	0.56
CO ZERO GAS	0.2	1.1	0.45	1.9	0.85	0.40
CO UP-SCALE	59.1	56.8	-1.15	56.6	-1.25	-0.10
O2 ZERO GAS	0.24	0.25	0.04	0.12	-0.48	-0.52
O2 UP-SCALE	12.17	11.87	-1.20	12.17	0.00	1.20

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

COMPANY: HERSHEY CHOCOLATE

SOURCE: UNIT 3 - OIL

TEST DATE: 04/11/96

RUN NUMBER: 30-CEM-3<1650-1750>

SPAN VALUES: 500.0 ppm NOx
200.0 ppm CO
25.00 % Oxygen

		-----INITIAL VALUES-----		-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	0.5	4.6	0.82	3.6	0.62	-0.20
NOx UP-SCALE	252.8	256.0	0.64	255.9	0.62	-0.02
CO ZERO GAS	0.2	1.9	0.85	1.7	0.75	-0.10
CO UP-SCALE	59.1	56.6	-1.25	56.4	-1.35	-0.10
O2 ZERO GAS	0.24	0.12	-0.48	0.20	-0.16	0.32
O2 UP-SCALE	12.17	12.17	0.00	12.08	-0.36	-0.36

SYSTEM CAL. RESPONSE - ANALYZER CAL. RESPONSE
SYSTEM CAL. BIAS = _____ X 100
SPAN

FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE
DRIFT = _____ X 100
SPAN

APPENDIX A. TEST RESULTS

3. Example Calculations

NOTE

The example values shown in these calculations have been rounded for presentation purposes. Any hand calculations conducted using these example values may produce slightly different results than those presented.

CONSTANTS, DEFINITIONS, NOMENCLATURE, AND UNITS

460	0 degrees Fahrenheit in degrees Rankin. The sum of 460 and the standard temperature (60, 68, 77, etc. in °F) gives Tstd in degrees Rankin.
273	0 degrees Celsius in degrees Kelvin. The sum of 273 and the standard temperature (18, 20, 25, etc. in °C) gives Tstd in degrees Kelvin.
29.92	Standard absolute pressure (Pstd), inches of mercury. English unit.
760	Standard absolute pressure (Pstd), millimeters of mercury. Metric unit.
24.056*	Liters per gram-mole at standard conditions.
385.3*	Molar volume cubic feet/pound-mole at standard conditions.
0.04707*	Standard cubic feet per gram or mL of H2O at standard conditions.
7000	Grains per pound.
453.592	Grams per pound.
0.02832	Cubic meters per cubic foot.
28.32	Liters per cubic foot.
0.03531	Cubic feet per liter.
35.31	Cubic feet per cubic meter.
1000	Conversion from milligrams to grams, milliliters to liters, and liters to cubic meters.
10 ⁶	Conversion factor for decimal fraction to parts per million.
144	Square inches per square foot.
60	Minutes per hour and seconds per minute.
13.6	Specific gravity of mercury (1 inch of mercury = 13.6 inches of H2O).
20.9	Percent O2 by volume (dry basis) in ambient air.
85.49	Pitot tube constant (Kp): $\frac{\text{feet}}{\text{second}} \sqrt{\frac{(\text{lb} / \text{lb} - \text{mole}) * (\text{inches Mercury})}{(\text{degrees Rankin}) * (\text{inches H2O})}}$
A	Stack cross-sectional area, square inches.

* Where applicable, these constants must be corrected (if the standard temperature is not 68°F) by multiplying them by the ratio of the standard temperatures. For example to convert to 77° F: (460 + 77)/(460 + 68)

EXAMPLE TEST CALCULATIONS

Boiler No. 2

RUN NUMBER: 2G-CEM-1

EMISSION RATE, CARBON MONOXIDE, lb/MMBtu

$$\text{lb/mmBtu} = (\text{ppm}_{\text{vd}} \cdot \text{fwl}) / (385.3 \cdot 10^6) \cdot F \cdot 20.9 / (20.9 - \%O_2)$$

$$\text{lb/mmBtu} = (1.7 \cdot 28.01) / (385.3 \cdot 10^6) \cdot 8710 \cdot 20.9 / (20.9 - 2.3)$$

$$\text{lb/mmBtu} = 0.00121 \text{ lb/mmBtu}$$

APPENDIX B. FIELD DATA

1. Boiler No. 2

a. Natural Gas

UNIT #3.645
UNIT #2.645

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN ³ PRE RUN ⁴ SYSTEM BIAS CHECK
UNIT #2 RUN 1

DATE : 04-10-1996 TIME: 13:20 - 13:27

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3 UNIT 2	ppm NOX	0.0	0.8
1	UNIT 3	ppm NOX	46.5	46.9 46.8
2	UNIT 3	ppm CO	0.0	0.5
2	UNIT 3	ppm CO	57.1	59.3 57.4
3	UNIT 3	% O2	0.00	0.21
3	UNIT 3	% O2	12.02	11.82

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppm NOX	ppm CO	% O2	MM-BTU	MM-BTU
15:06	30.8	2.4	2.39	0.036	0.002
15:07	30.8	1.5	2.39	0.036	0.001
15:08	30.9	1.6	2.36	0.036	0.001
15:09	30.8	2.2	2.26	0.036	0.002
15:10	30.8	2.9	2.23	0.036	0.002
15:11	30.9	2.1	2.36	0.036	0.002
15:12	30.9	1.9	2.38	0.036	0.001
15:13	31.1	1.6	2.39	0.037	0.001
15:14	31.1	1.3	2.56	0.037	0.001
15:15	31.0	1.7	2.29	0.036	0.001
15:16	31.0	2.3	2.41	0.036	0.002
15:17	31.1	1.7	2.33	0.036	0.001
15:18	30.8	3.1	2.29	0.036	0.002
15:19	30.9	2.2	2.34	0.036	0.002
15:20	31.2	1.7	2.41	0.037	0.001

AVERAGE VALUES FOR THE LAST 15 MINUTES

15:20	30.9	2.0	2.36	0.036	0.001
15:21	31.0	2.1	2.32	0.036	0.002
15:22	31.1	1.9	2.41	0.037	0.001
15:23	31.0	1.4	2.44	0.037	0.001
15:24	31.0	1.4	2.51	0.037	0.001
15:25	31.2	1.4	2.42	0.037	0.001
15:26	31.8	2.0	2.29	0.037	0.001
15:27	31.9	3.1	2.28	0.037	0.002
15:28	32.0	2.0	2.28	0.037	0.001
15:29	32.0	1.9	2.33	0.037	0.001
15:30	31.9	2.1	2.33	0.037	0.002
15:31	31.9	1.8	2.40	0.037	0.001
15:32	32.0	1.2	2.46	0.038	0.001
15:33	31.9	1.8	2.29	0.037	0.001
15:34	31.7	3.0	2.27	0.037	0.002
15:35	31.8	2.7	2.28	0.037	0.002

AVERAGE VALUES FOR THE LAST 15 MINUTES

15:35	31.6	2.0	2.35	0.037	0.001
15:36	31.9	2.0	2.33	0.037	0.001
15:37	31.8	1.8	2.43	0.037	0.001
15:38	31.9	1.3	2.44	0.038	0.001
15:39	31.8	1.8	2.42	0.037	0.001
15:40	31.9	1.3	2.40	0.038	0.001
15:41	31.7	2.4	2.24	0.037	0.002
15:42	31.8	2.3	2.37	0.037	0.002
15:43	31.8	1.8	2.42	0.037	0.001
15:44	31.8	1.8	2.41	0.037	0.001
15:45	31.8	1.5	2.39	0.037	0.001
15:46	31.7	2.3	2.31	0.037	0.002
15:47	31.7	2.3	2.32	0.037	0.002
15:48	31.7	1.6	2.38	0.037	0.001

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	1b NOX	1b CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
15:49	31.7	1.9	2.40	0.037	0.001
15:50	31.6	2.1	2.40	0.037	0.002

AVERAGE VALUES FOR THE LAST 15 MINUTES

15:50	31.8	1.9	2.38	0.037	0.001
15:51	31.7	1.8	2.41	0.037	0.001
15:52	31.7	1.7	2.40	0.037	0.001
15:53	31.7	1.6	2.40	0.037	0.001
15:54	31.6	2.0	2.33	0.037	0.001
15:55	31.6	1.6	2.42	0.037	0.001
15:56	31.7	2.0	2.33	0.037	0.001
15:57	31.4	3.5	2.17	0.036	0.002
15:58	31.8	2.0	2.39	0.037	0.001
15:59	31.6	1.5	2.39	0.037	0.001
16:00	31.7	1.6	2.48	0.037	0.001
16:01	31.6	1.3	2.37	0.037	0.001
16:02	31.5	2.1	2.41	0.037	0.002
16:03	31.5	1.8	2.32	0.037	0.001
16:04	31.6	2.4	2.28	0.037	0.002
16:05	31.5	2.4	2.28	0.037	0.002

AVERAGE VALUES FOR THE LAST 15 MINUTES

16:05	31.6	2.0	2.36	0.037	0.001
-------	------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

16:05	31.5	2.0	2.36	0.037	0.001
-------	------	-----	------	-------	-------

COMMENTS: END RUN 1

UNIT 2 GAS

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

(4)

REASON: POST RUN 1 PRE RUN 2 SYSTEM BIAS CHECK

UNIT 2

DATE : 04-10-1996 TIME: 16:05 - 16:11

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
-1	UNIT 2	ppmNOX	0.0	1.0
1	UNIT 2	ppmNOX	46.5 46.9 <i>46.9</i>	47.4
2	UNIT 2	ppm CO	0.0	0.3
2	UNIT 2	ppm CO	59.3	57.4
3	UNIT 2	% O2	0.00	0.13
3	UNIT 2	% O2	12.02	11.81

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
16:16	31.0	2.0	2.39	0.036	0.001
16:17	30.8	1.4	2.38	0.036	0.001
16:18	31.0	2.3	2.27	0.036	0.002
16:19	31.2	1.4	2.33	0.037	0.001
16:20	31.2	2.3	2.21	0.036	0.002
16:21	31.3	2.1	2.34	0.037	0.001
16:22	31.2	2.2	2.27	0.036	0.002
16:23	31.3	1.7	2.35	0.037	0.001
16:24	31.3	1.5	2.32	0.037	0.001
16:25	31.3	1.9	2.30	0.037	0.001
16:26	31.4	3.5	2.17	0.036	0.002
16:27	31.7	2.6	2.32	0.037	0.002
16:28	31.4	2.6	2.19	0.037	0.002
16:29	31.6	1.8	2.33	0.037	0.001
16:30	31.7	1.5	2.33	0.037	0.001

AVERAGE VALUES FOR THE LAST 15 MINUTES

16:30	31.3	2.1	2.30	0.037	0.001
16:31	31.5	1.8	2.35	0.037	0.001
16:32	31.6	1.9	2.29	0.037	0.001
16:33	31.5	2.2	2.37	0.037	0.002
16:34	31.6	1.6	2.30	0.037	0.001
16:35	31.6	2.3	2.28	0.037	0.002
16:36	31.5	3.5	2.18	0.037	0.002
16:37	31.4	2.4	2.58	0.037	0.002
16:38	32.4	2.4	2.26	0.038	0.002
16:39	32.3	2.1	2.34	0.038	0.001
16:40	32.4	2.4	2.38	0.038	0.002
16:41	32.2	1.6	2.45	0.038	0.001
16:42	32.2	1.3	2.47	0.038	0.001
16:43	32.1	2.0	2.31	0.038	0.001
16:44	32.2	1.8	2.41	0.038	0.001
16:45	32.1	1.8	2.32	0.038	0.001

AVERAGE VALUES FOR THE LAST 15 MINUTES

16:45	31.9	2.1	2.35	0.037	0.001
16:46	32.1	2.9	2.32	0.038	0.002
16:47	32.2	1.9	2.36	0.038	0.001
16:48	32.2	1.6	2.46	0.038	0.001
16:49	32.2	1.5	2.40	0.038	0.001
16:50	32.0	2.5	2.35	0.037	0.002
16:51	32.1	1.7	2.43	0.038	0.001
16:52	32.0	2.0	2.28	0.037	0.001
16:53	32.2	2.0	2.43	0.038	0.001
16:54	32.0	2.1	2.31	0.037	0.002
16:55	31.9	2.2	2.43	0.038	0.002
16:56	31.4	1.3	2.41	0.037	0.001
16:57	31.4	2.0	2.32	0.037	0.001
16:58	31.4	1.9	2.34	0.037	0.001

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppm NOX	ppm CO	% O2	MM-BTU	MM-BTU
16:59	31.4	1.9	2.25	0.037	0.001
17:00	31.4	2.1	2.30	0.037	0.001

AVERAGE VALUES FOR THE LAST 15 MINUTES

17:00	31.9	2.0	2.36	0.037	0.001
17:01	31.4	2.0	2.32	0.037	0.001
17:02	31.6	2.3	2.26	0.037	0.002
17:03	31.5	2.8	2.24	0.037	0.002
17:04	31.6	2.0	2.30	0.037	0.001
17:05	31.5	1.9	2.28	0.037	0.001
17:06	31.7	1.5	2.44	0.037	0.001
17:07	31.6	1.5	2.36	0.037	0.001
17:08	31.4	2.5	2.25	0.037	0.002
17:09	31.5	2.0	2.29	0.037	0.001
17:10	31.6	2.7	2.24	0.037	0.002
17:11	31.7	2.4	2.31	0.037	0.002
17:12	31.8	2.2	2.30	0.037	0.002
17:13	31.8	2.3	2.29	0.037	0.002
17:14	31.8	1.7	2.39	0.037	0.001
17:15	31.7	1.7	2.35	0.037	0.001

AVERAGE VALUES FOR THE LAST 15 MINUTES

17:15	31.6	2.1	2.31	0.037	0.001
-------	------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

17:15	31.7	2.0	2.33	0.037	0.001
-------	------	-----	------	-------	-------

COMMENTS: END RUN 2

UNIT 2 - GAS

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN 2 PRE RUN 3 SYSTEM BIAS CHECK

DATE : 04-10-1996 TIME: 17:15 - 17:20

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	1.1
1	UNIT 2	ppmNOX	46.5 46.9 48.2	48.2
2	UNIT 2	ppm CO	0.0	0.4
2	UNIT 2	ppm CO	59.3 -	57.4
3	UNIT 2	% O2	0.00	0.07
3	UNIT 2	% O2	12.02 -	11.84

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
17:26	31.5	2.9	2.27	0.037	0.002
17:27	31.7	2.1	2.32	0.037	0.001
17:28	31.5	2.3	2.25	0.037	0.002
17:29	31.6	2.1	2.26	0.037	0.001
17:30	31.7	1.8	2.27	0.037	0.001
17:31	31.5	1.7	2.37	0.037	0.001
17:32	31.7	1.2	2.42	0.037	0.001
17:33	31.5	1.2	2.37	0.037	0.001
17:34	31.5	2.0	2.31	0.037	0.001
17:35	31.5	2.3	2.26	0.037	0.002
17:36	31.5	2.2	2.26	0.037	0.002
17:37	31.5	2.8	2.27	0.037	0.002
17:38	31.6	2.0	2.31	0.037	0.001
17:39	31.6	2.0	2.24	0.037	0.001
17:40	31.5	1.9	2.43	0.037	0.001

AVERAGE VALUES FOR THE LAST 15 MINUTES

17:40	31.6	2.0	2.31	0.037	0.001
17:41	31.6	1.4	2.37	0.037	0.001
17:42	31.5	2.0	2.28	0.037	0.001
17:43	31.4	1.6	2.38	0.037	0.001
17:44	31.4	2.3	2.24	0.037	0.002
17:45	31.5	2.3	2.25	0.037	0.002
17:46	31.3	1.9	2.76	0.038	0.001
17:47	32.2	1.5	2.38	0.038	0.001
17:48	32.1	2.5	2.33	0.038	0.002
17:49	32.0	2.2	2.37	0.038	0.002
17:50	31.9	2.0	2.44	0.038	0.001
17:51	32.0	1.4	2.50	0.038	0.001
17:52	32.0	2.0	2.38	0.037	0.001
17:53	32.0	1.9	2.34	0.037	0.001
17:54	32.1	2.2	2.40	0.038	0.002
17:55	31.9	2.2	2.31	0.037	0.002

AVERAGE VALUES FOR THE LAST 15 MINUTES

17:55	31.8	2.0	2.38	0.037	0.001
17:56	31.8	1.9	2.39	0.037	0.001
17:57	31.9	1.6	2.51	0.038	0.001
17:58	31.8	1.4	2.43	0.037	0.001
17:59	32.0	2.1	2.35	0.037	0.002
18:00	31.6	2.7	2.35	0.037	0.002
18:01	31.6	2.0	2.35	0.037	0.001
18:02	31.6	3.1	2.28	0.037	0.002
18:03	31.7	2.0	2.44	0.037	0.001
18:04	31.5	2.1	2.34	0.037	0.001
18:05	31.5	1.7	2.44	0.037	0.001
18:06	31.2	1.5	2.58	0.037	0.001
18:07	31.2	2.6	2.56	0.037	0.002
18:08	30.8	1.6	2.54	0.036	0.001

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
18:09	30.6	1.7	2.46	0.036	0.001
18:10	30.6	1.8	2.48	0.036	0.001

AVERAGE VALUES FOR THE LAST 15 MINUTES

18:10	31.4	2.0	2.43	0.037	0.001
18:11	30.5	1.6	2.48	0.036	0.001
18:12	30.6	1.8	2.45	0.036	0.001
18:13	30.5	2.9	2.32	0.036	0.002
18:14	30.7	2.2	2.39	0.036	0.002
18:15	30.6	2.6	2.37	0.036	0.002
18:16	30.9	1.6	2.61	0.037	0.001
18:17	30.8	1.4	2.44	0.036	0.001
18:18	30.7	2.7	2.36	0.036	0.002
18:19	30.9	1.5	2.48	0.036	0.001
18:20	30.8	1.9	2.40	0.036	0.001
18:21	30.8	2.3	2.37	0.036	0.002
18:22	30.7	2.4	2.36	0.036	0.002
18:23	30.9	2.2	2.37	0.036	0.002
18:24	30.8	2.2	2.48	0.036	0.002
18:25	30.9	1.6	2.55	0.037	0.001

AVERAGE VALUES FOR THE LAST 15 MINUTES

18:25	30.7	2.1	2.43	0.036	0.001
-------	------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

18:25	31.4	2.0	2.39	0.037	0.001
-------	------	-----	------	-------	-------

COMMENTS: END RUN 3

UNIT 2 GAS

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST TEST 3 (6) SYSTEM BIAS CHECK

DATE : 04-10-1996 TIME: 18:25 - 18:29

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	1.3
1	UNIT 2	ppmNOX	46.5 46.9 47.2	47.2
2	UNIT 2	ppm CO	0.0	1.0
2	UNIT 2	ppm CO	59.3	57.6
3	UNIT 2	% O2	0.00	0.10
3	UNIT 2	% O2	12.02	11.87

APPENDIX B. FIELD DATA

1. Boiler No. 2

b. No. 6 Fuel Oil

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: DIRECT CALIBRATION ERROR CHECK *DIC PR*

DATE : 04-11-1996 TIME: 06:31 - 06:43

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	0.5
1	UNIT 2	ppmNOX	<u>252.0</u> <i>257 PR</i>	252.8
1	UNIT 2	ppmNOX	<u>452.0</u> <i>457 PR</i>	452.7
2	UNIT 2	ppm CO	0.0	0.2
2	UNIT 2	ppm CO	59.3	59.1
2	UNIT 2	ppm CO	91.0	90.5
2	UNIT 2	ppm CO	<u>151.0</u> <i>151.4 PR</i>	151.0
3	UNIT 2	% O2	0.00	0.24
3	UNIT 2	% O2	12.02	12.17
3	UNIT 2	% O2	20.12	20.26

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: PRE RUN 1 SYSTEM BIAS CHECK

DATE : 04-11-1996 TIME: 06:44 - 07:24

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	0.8
1	UNIT 2	ppmNOX	155.0	156.7
1	UNIT 2	ppmNOX	(252.0) 257.02	253.0
2	UNIT 2	ppm CO	0.0	0.4
2	UNIT 2	ppm CO	91.0	91.5
2	UNIT 2	ppm CO	151.0	151.4
3	UNIT 2	% O2	0.00	0.20
3	UNIT 2	% O2	12.02	12.07

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: PRE RUN 1 SYSTEM BIAS CHECK - CO ANALYZER

DATE : 04-11-1996 TIME: 07:33 - 07:38

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
2	UNIT 2	ppm CO	0.0	0.4
2	UNIT 2	ppm CO	59.3	57.4

HERSHRY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
08:16	283.6	28.3	3.28	0.350	0.021
08:17	284.3	26.8	3.28	0.351	0.020
08:18	283.9	26.2	3.31	0.351	0.020
08:19	284.0	26.2	3.27	0.350	0.020
08:20	284.1	20.7	3.29	0.351	0.016
08:21	283.9	22.7	3.27	0.350	0.017
08:22	284.5	26.8	3.33	0.352	0.020
08:23	285.2	18.8	3.40	0.354	0.014
08:24	285.4	23.5	3.33	0.353	0.018
08:25	284.5	20.9	3.40	0.353	0.016
08:26	284.3	26.5	3.32	0.352	0.020
08:27	284.7	22.9	3.35	0.353	0.017
08:28	285.0	20.5	3.35	0.353	0.015
08:29	284.8	24.1	3.37	0.353	0.018
08:30	284.9	23.0	3.26	0.351	0.017

AVERAGE VALUES FOR THE LAST 15 MINUTES

08:30	284.5	23.9	3.32	0.352	0.018
08:31	283.9	20.6	3.37	0.352	0.016
08:32	283.8	23.0	3.31	0.351	0.017
08:33	283.7	21.4	3.37	0.352	0.016
08:34	283.1	23.3	3.35	0.350	0.018
08:35	282.8	25.1	3.37	0.351	0.019
08:36	283.7	21.3	3.41	0.353	0.016
08:37	271.8	25.5	3.69	0.343	0.020
08:38	283.0	17.8	3.36	0.351	0.013
08:39	283.1	21.8	3.31	0.350	0.016
08:40	282.9	19.4	3.44	0.352	0.015
08:41	283.0	22.6	3.34	0.350	0.017
08:42	283.4	25.4	3.39	0.352	0.019
08:43	283.4	19.0	3.51	0.354	0.014
08:44	283.5	19.0	3.42	0.352	0.014
08:45	283.8	18.1	3.58	0.356	0.014

AVERAGE VALUES FOR THE LAST 15 MINUTES

08:45	282.6	21.5	3.41	0.351	0.016
08:46	287.0	15.7	3.45	0.358	0.012
08:47	283.2	16.6	3.46	0.353	0.013
08:48	288.0	15.3	3.61	0.362	0.012
08:49	299.3	5.0	3.54	0.375	0.004
08:50	300.7	4.1	3.56	0.377	0.003
08:51	301.4	3.7	3.62	0.379	0.003
08:52	301.4	3.6	3.55	0.378	0.003
08:53	301.2	3.6	3.61	0.379	0.003
08:54	301.7	3.5	3.61	0.379	0.003
08:55	301.1	3.5	3.63	0.379	0.003
08:56	300.4	3.5	3.61	0.378	0.003
08:57	301.0	4.0	3.54	0.377	0.003
08:58	297.9	4.6	3.50	0.372	0.004

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	1b NOX	1b CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
08:59	297.5	4.8	3.50	0.372	0.004
09:00	296.2	5.6	3.42	0.368	0.004

AVERAGE VALUES FOR THE LAST 15 MINUTES

09:00	297.2	6.5	3.55	0.372	0.005
09:01	297.0	5.4	3.40	0.369	0.004
09:02	295.0	5.9	3.44	0.367	0.004
09:03	294.6	6.1	3.42	0.366	0.005
09:04	294.2	6.3	3.41	0.366	0.005
09:05	293.6	7.8	3.35	0.364	0.006
09:06	295.5	6.6	3.46	0.368	0.005
09:07	294.1	7.7	3.32	0.364	0.006
09:08	293.0	8.2	3.42	0.364	0.006
09:09	292.6	9.9	3.38	0.363	0.007
09:10	292.6	7.9	3.41	0.364	0.006
09:11	293.0	8.7	3.36	0.363	0.007
09:12	293.2	10.3	3.31	0.362	0.008
09:13	293.3	11.3	3.36	0.363	0.009
09:14	293.5	8.5	3.39	0.364	0.006
09:15	292.0	10.9	3.36	0.362	0.008

AVERAGE VALUES FOR THE LAST 15 MINUTES

09:15	293.8	8.1	3.39	0.365	0.006
-------	-------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

09:15	289.5	15.0	3.42	0.360	0.011
-------	-------	------	------	-------	-------

COMMENTS: END RUN 1

UNIT 2 OIL

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN 1 PRE RUN 2 SYSTEM BIAS CHECK

DATE : 04-11-1996 TIME: 09:15 - 09:22

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	2.9
1	UNIT 2	ppmNOX	155.0	157.0
1	UNIT 2	ppmNOX	252.0	257.92 253.7
2	UNIT 2	ppm CO	0.0	0.4
2	UNIT 2	ppm CO	59.3	57.4
3	UNIT 2	% O2	0.00	0.14
3	UNIT 2	% O2	12.02	12.07

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
09:26	290.1	7.6	3.49	0.362	0.006
09:27	289.9	9.7	3.43	0.361	0.007
09:28	290.8	7.4	3.52	0.364	0.006
09:29	290.9	7.2	3.48	0.363	0.005
09:30	290.9	7.8	3.47	0.363	0.006
09:31	290.6	8.0	3.43	0.362	0.006
09:32	290.8	8.3	3.42	0.362	0.006
09:33	291.1	7.9	3.43	0.362	0.006
09:34	290.0	7.9	3.51	0.362	0.006
09:35	290.4	9.0	3.41	0.361	0.007
09:36	291.0	8.1	3.43	0.362	0.006
09:37	289.9	8.9	3.43	0.361	0.007
09:38	290.2	10.2	3.42	0.361	0.008
09:39	289.1	8.9	3.41	0.359	0.007
09:40	290.2	8.0	3.47	0.362	0.006

AVERAGE VALUES FOR THE LAST 15 MINUTES

09:40	290.4	8.3	3.45	0.362	0.006
09:41	289.8	9.3	3.40	0.360	0.007
09:42	289.0	8.6	3.45	0.360	0.007
09:43	289.9	8.9	3.40	0.360	0.007
09:44	289.3	9.1	3.41	0.360	0.007
09:45	288.9	9.6	3.39	0.359	0.007
09:46	288.8	9.2	3.45	0.360	0.007
09:47	282.3	9.1	3.74	0.358	0.007
09:48	288.1	11.9	3.28	0.356	0.009
09:49	288.7	9.2	3.38	0.358	0.007
09:50	287.9	12.2	3.30	0.356	0.009
09:51	289.0	9.1	3.37	0.358	0.007
09:52	287.1	9.8	3.36	0.356	0.007
09:53	288.6	9.6	3.34	0.357	0.007
09:54	288.0	8.1	3.41	0.358	0.006
09:55	289.6	7.7	3.36	0.359	0.006

AVERAGE VALUES FOR THE LAST 15 MINUTES

09:55	288.3	9.4	3.40	0.358	0.007
09:56	288.7	7.3	3.39	0.358	0.006
09:57	287.5	8.2	3.38	0.357	0.006
09:58	288.0	7.9	3.36	0.357	0.006
09:59	288.8	7.9	3.41	0.359	0.006
10:00	289.1	7.4	3.43	0.360	0.006
10:01	288.0	9.0	3.33	0.356	0.007
10:02	289.3	7.6	3.42	0.360	0.006
10:03	289.2	9.3	3.31	0.357	0.007
10:04	288.9	10.0	3.31	0.357	0.008
10:05	289.2	9.6	3.38	0.359	0.007
10:06	288.0	10.3	3.40	0.358	0.008
10:07	287.7	8.7	3.28	0.355	0.007
10:08	291.4	7.9	3.33	0.361	0.006

Unit 2 Oil
Run 2

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppm NOX	ppm CO	% O2	MM-BTU	MM-BTU
10:09	289.2	9.9	3.38	0.359	0.007
10:10	289.3	9.3	3.29	0.357	0.007

AVERAGE VALUES FOR THE LAST 15 MINUTES

10:10	288.8	8.7	3.36	0.358	0.007
10:11	289.2	10.6	3.32	0.358	0.008
10:12	290.0	8.5	3.38	0.360	0.006
10:13	289.8	8.4	3.38	0.360	0.006
10:14	289.1	9.1	3.28	0.357	0.007
10:15	290.3	9.8	3.34	0.359	0.007
10:16	290.9	10.3	3.28	0.359	0.008
10:17	290.6	8.4	3.35	0.360	0.006
10:18	290.3	9.4	3.29	0.358	0.007
10:19	290.9	11.3	3.32	0.360	0.009
10:20	291.9	9.8	3.34	0.361	0.007
10:21	291.3	9.4	3.30	0.360	0.007
10:22	291.1	10.2	3.25	0.359	0.008
10:23	291.9	9.3	3.36	0.362	0.007
10:24	292.0	9.5	3.32	0.361	0.007
10:25	292.0	7.6	3.27	0.360	0.006

AVERAGE VALUES FOR THE LAST 15 MINUTES

10:25	290.8	9.4	3.32	0.360	0.007
-------	-------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

10:25	289.6	9.0	3.38	0.359	0.007
-------	-------	-----	------	-------	-------

COMMENTS: END RUN 2
UNIT 2 OIL

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN 2 PRE RUN 3 SYSTEM BIAS CHECK

DATE : 04-11-1996 TIME: 10:25 - 10:31

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	2.3
1	UNIT 2	ppmNOX	252.0	257.4-251.4
2	UNIT 2	ppm CO	0.0	0.4
2	UNIT 2	ppm CO	59.3	57.2
3	UNIT 2	% O2	0.00	0.28
3	UNIT 2	% O2	12.02	12.17

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
10:46	290.3	7.8	3.39	0.380	0.006
10:47	290.9	10.4	3.36	0.380	0.008
10:48	290.8	9.0	3.36	0.380	0.007
10:49	289.9	9.6	3.42	0.380	0.008
10:50	290.1	9.2	3.32	0.378	0.007
10:51	290.8	11.4	3.32	0.380	0.009
10:52	290.1	10.2	3.33	0.379	0.008
10:53	289.5	10.8	3.32	0.378	0.009
10:54	289.4	8.5	3.40	0.379	0.007
10:55	289.3	10.1	3.36	0.378	0.008
10:56	289.0	10.9	3.29	0.376	0.009
10:57	291.2	10.1	3.34	0.380	0.008
10:58	289.3	9.5	3.35	0.378	0.008
10:59	289.5	10.2	3.29	0.377	0.008
11:00	289.8	8.9	3.39	0.380	0.007

AVERAGE VALUES FOR THE LAST 15 MINUTES

11:00	290.0	9.8	3.35	0.379	0.008
11:01	289.9	8.9	3.31	0.378	0.007
11:02	289.8	9.8	3.39	0.380	0.008
11:03	290.3	9.0	3.32	0.379	0.007
11:04	290.4	9.5	3.30	0.378	0.008
11:05	289.7	9.6	3.33	0.378	0.008
11:06	289.8	8.5	3.38	0.379	0.007
11:07	288.4	9.2	3.32	0.376	0.007
11:08	289.3	9.1	3.37	0.378	0.007
11:09	290.1	9.9	3.42	0.381	0.008
11:10	289.6	8.7	3.37	0.379	0.007
11:11	290.1	10.3	3.32	0.379	0.008
11:12	289.8	8.8	3.44	0.381	0.007
11:13	290.3	9.4	3.33	0.379	0.007
11:14	289.8	9.1	3.39	0.380	0.007
11:15	289.2	9.6	3.41	0.379	0.008

AVERAGE VALUES FOR THE LAST 15 MINUTES

11:15	289.8	9.3	3.36	0.379	0.007
11:16	291.0	8.2	3.36	0.381	0.007
11:17	289.8	11.1	3.35	0.379	0.009
11:18	289.0	8.7	3.39	0.379	0.007
11:19	289.6	9.6	3.34	0.378	0.008
11:20	289.2	10.9	3.33	0.378	0.009
11:21	289.8	11.7	3.38	0.379	0.009
11:22	289.9	9.4	3.36	0.379	0.008
11:23	290.6	8.8	3.37	0.380	0.007
11:24	290.4	8.2	3.39	0.380	0.007
11:25	290.2	10.5	3.32	0.379	0.008
11:26	289.8	8.8	3.33	0.378	0.007
11:27	292.5	8.6	3.29	0.381	0.007
11:28	292.3	8.9	3.29	0.381	0.007

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 2	UNIT 2	UNIT 2	1b NOX	1b CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
11:29	292.2	8.4	3.27	0.380	0.007
11:30	292.7	9.2	3.27	0.381	0.007

AVERAGE VALUES FOR THE LAST 15 MINUTES

11:30	290.6	9.4	3.34	0.379	0.007
11:31	293.2	9.5	3.27	0.381	0.007
11:32	294.1	8.3	3.29	0.383	0.007
11:33	294.1	8.2	3.24	0.382	0.007
11:34	293.7	7.7	3.30	0.383	0.006
11:35	294.1	7.5	3.35	0.384	0.006
11:36	294.2	8.0	3.26	0.382	0.006
11:37	294.2	7.7	3.33	0.384	0.006
11:38	295.9	6.6	3.32	0.386	0.005
11:39	296.5	6.2	3.30	0.386	0.005
11:40	296.1	6.2	3.32	0.386	0.005
11:41	296.6	7.6	3.26	0.386	0.006
11:42	296.2	6.6	3.32	0.386	0.005
11:43	297.1	7.7	3.28	0.387	0.006
11:44	298.4	6.3	3.29	0.389	0.005
11:45	299.2	5.9	3.31	0.390	0.005

AVERAGE VALUES FOR THE LAST 15 MINUTES

11:45	295.6	7.3	3.30	0.385	0.006
-------	-------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

11:45	291.5	8.9	3.34	0.381	0.007
-------	-------	-----	------	-------	-------

COMMENTS: END RUN 3

UNIT 2 OIL

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN 3 PRE RUN 4 (RUN 1 OIL UNIT 3) SYSTEM BIAS CHECK

DATE : 04-11-1996 TIME: 11:45 - 11:52

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	2.5
1	UNIT 2	ppmNOX	252.0 257.1R	254.3
2	UNIT 2	ppm CO	0.0	1.0
2	UNIT 2	ppm CO	59.3	57.2
3	UNIT 2	% O2	0.00	0.11
3	UNIT 2	% O2	12.02	12.10

APPENDIX B. FIELD DATA

2. Boiler No. 3

a. Natural Gas

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: DIRECT CALIBRATION ERROR CHECK GAS *172*

DATE : 04-10-1996 TIME: 06:30 - 06:43

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3	ppmNOX	0.0	0.7
1	UNIT 3	ppmNOX	<u>46.5</u> <i>46.9 172</i>	45.2
1	UNIT 3	ppmNOX	<u>88.9</u> <i>89.7 172</i>	88.7
2	UNIT 3	ppm CO	0.0	0.4
2	UNIT 3	ppm CO	59.3	59.3
2	UNIT 3	ppm CO	91.0	92.1
2	UNIT 3	ppm CO	151.4	153.0
3	UNIT 3	% O2	0.00	0.31
3	UNIT 3	% O2	<u>12.11</u> <i>12.02 172</i>	12.13
3	UNIT 3	% O2	20.12	20.10

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: PRE RUN 1 SYSTEM BIAS CHECK GAS PR

DATE : 04-10-1996 TIME: 06:43 - 06:52

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3	ppmNOX	0.0	0.7
1	UNIT 3	ppmNOX	(46.5) 46.9 PR	46.1
2	UNIT 3	ppm CO	0.0	0.6
2	UNIT 3	ppm CO	59.3	58.5
3	UNIT 3	% O2	(12.11) 12.02 PR	11.96
3	UNIT 3	% O2	20.12	19.95

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: PRE RUN 1 RE-DIRECT NOX

DATE : 04-10-1996 TIME: 06:52 - 06:55

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3	ppmNOX	0.0	0.5
1	UNIT 3	ppmNOX	46.5 46.9 P12	46.5
1	UNIT 3	ppmNOX	88.9 89.7 P12	89.6

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: PRE RUN 1 NOX SYSTEM BIAS CHECK

DATE : 04-10-1996 TIME: 06:55 - 06:59

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3	ppmNOX	0.0	0.6
1	UNIT 3	ppmNOX	(46.5) 46.9 Az	46.4

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: O2 ANALYZER REDIRECT - NEW CYLINDER

DATE : 04-10-1996 TIME: 07:31 - 07:35

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
3	UNIT 3	% O2	0.00	0.22
3	UNIT 3	% O2	12.02	12.06
3	UNIT 3	% O2	20.12	20.29

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: PRE RUN 1 SYSTEM BIAS CHECK - O2 ANALYZER

DATE : 04-10-1996 TIME: 07:35 - 07:38

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
3	UNIT 3	% O2	0.00	0.27
3	UNIT 3	% O2	12.02	11.97

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 3	UNIT 3
	UNIT 3	UNIT 3	UNIT 3	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
10:01	29.3	3.3	4.79	0.040	0.003
10:02	29.3	4.8	4.61	0.039	0.004
10:03	29.4	5.5	4.64	0.039	0.004
10:04	29.4	6.2	4.55	0.039	0.005
10:05	29.4	5.1	4.73	0.040	0.004
10:06	29.5	4.8	4.77	0.040	0.004
10:07	29.4	6.0	4.69	0.039	0.005
10:08	29.5	3.8	4.85	0.040	0.003
10:09	29.6	3.5	4.81	0.040	0.003
10:10	29.6	3.8	4.77	0.040	0.003
10:11	29.6	4.3	4.68	0.040	0.004
10:12	29.5	4.7	4.61	0.039	0.004
10:13	29.5	5.9	4.62	0.039	0.005
10:14	29.6	5.4	4.66	0.040	0.004
10:15	29.5	3.4	4.85	0.040	0.003

AVERAGE VALUES FOR THE LAST 15 MINUTES

10:15	29.5	4.7	4.71	0.040	0.004
10:16	29.5	3.3	4.70	0.040	0.003
10:17	29.4	4.7	4.64	0.039	0.004
10:18	29.5	6.1	4.62	0.039	0.005
10:19	29.5	4.9	4.64	0.039	0.004
10:20	29.5	4.6	4.74	0.040	0.004
10:21	29.1	3.9	5.30	0.041	0.003
10:22	29.9	4.3	4.47	0.040	0.003
10:23	30.0	6.1	4.45	0.040	0.005
10:24	30.0	4.0	4.43	0.040	0.003
10:25	30.0	3.7	4.46	0.040	0.003
10:26	29.9	3.1	4.51	0.040	0.003
10:27	29.9	6.9	4.44	0.040	0.006
10:28	29.8	5.6	4.36	0.039	0.004
10:29	29.8	5.3	4.36	0.039	0.004
10:30	29.8	3.7	4.53	0.040	0.003

AVERAGE VALUES FOR THE LAST 15 MINUTES

10:30	29.7	4.7	4.58	0.040	0.004
10:31	29.7	6.1	4.41	0.039	0.005
10:32	29.9	8.2	4.36	0.039	0.007
10:33	29.9	7.1	4.43	0.039	0.006
10:34	29.9	4.0	4.43	0.039	0.003
10:35	30.0	3.7	4.54	0.040	0.003
10:36	29.9	3.5	4.68	0.040	0.003
10:37	29.8	3.7	4.53	0.040	0.003
10:38	29.6	4.1	4.44	0.039	0.003
10:39	29.9	5.3	4.43	0.039	0.004
10:40	29.4	6.5	4.34	0.039	0.005
10:41	29.6	5.1	4.44	0.039	0.004
10:42	29.6	5.1	4.30	0.039	0.004
10:43	29.7	5.8	4.43	0.039	0.005

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 3	UNIT 3
	UNIT 3	UNIT 3	UNIT 3	1b NOX	1b CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
10:44	29.4	4.1	4.79	0.040	0.003
10:45	29.2	4.0	4.94	0.040	0.003

AVERAGE VALUES FOR THE LAST 15 MINUTES

10:45	29.7	5.1	4.50	0.039	0.004
10:46	29.2	2.5	4.92	0.040	0.002
10:47	29.2	5.2	4.93	0.040	0.004
10:48	29.0	4.8	4.75	0.039	0.004
10:49	29.0	5.9	4.70	0.039	0.005
10:50	29.2	4.6	4.77	0.039	0.004
10:51	29.2	6.3	4.94	0.040	0.005
10:52	29.1	4.6	4.76	0.039	0.004
10:53	29.2	3.7	4.83	0.040	0.003
10:54	29.1	4.3	4.79	0.039	0.004
10:55	29.3	3.7	4.89	0.040	0.003
10:56	29.2	2.5	4.92	0.040	0.002
10:57	29.2	3.6	4.88	0.040	0.003
10:58	29.0	2.7	4.82	0.039	0.002
10:59	29.1	5.8	4.77	0.039	0.005
11:00	29.1	7.9	4.68	0.039	0.006

AVERAGE VALUES FOR THE LAST 15 MINUTES

11:00	29.2	4.5	4.82	0.039	0.004
-------	------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

11:00	29.5	4.7	4.65	0.039	0.004
-------	------	-----	------	-------	-------

COMMENTS: END RUN 1

UNIT 3 GAS

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: ^{UNIT 3} POST RUN1 PRE RUN 2 SYSTEM BIAS CHECK

DATE : 04-10-1996 TIME: 11:00 - 11:07

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3	ppmNOX	0.0	0.0
1	UNIT 3	ppmNOX	46.5 46.9 AL	46.5
2	UNIT 3	ppm CO	0.0	1.0
2	UNIT 3	ppm CO	59.3	57.4
3	UNIT 3	% O2	0.00	0.30
3	UNIT 3	% O2	12.02	11.97

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 3	UNIT 3
	UNIT 3	UNIT 3	UNIT 3	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
11:11	29.9	3.0	3.30	0.037	0.002
11:12	29.9	4.1	3.21	0.037	0.003
11:13	29.9	5.6	3.24	0.037	0.004
11:14	29.9	13.1	3.27	0.037	0.010
11:15	29.9	6.5	3.18	0.037	0.005
11:16	30.0	4.0	3.21	0.037	0.003
11:17	29.9	6.5	3.25	0.037	0.005
11:18	30.1	4.5	3.31	0.037	0.003
11:19	30.0	3.4	3.27	0.037	0.003
11:20	29.9	7.6	3.17	0.037	0.006
11:21	29.9	4.0	3.30	0.037	0.003
11:22	29.9	5.8	3.20	0.037	0.004
11:23	30.0	4.3	3.31	0.037	0.003
11:24	30.1	2.7	3.33	0.037	0.002
11:25	30.0	2.6	3.27	0.037	0.002

AVERAGE VALUES FOR THE LAST 15 MINUTES

11:25	29.9	5.2	3.25	0.037	0.004
11:26	29.8	6.2	3.25	0.037	0.005
11:27	30.0	3.2	3.22	0.037	0.002
11:28	29.9	3.8	3.23	0.037	0.003
11:29	30.0	3.7	3.24	0.037	0.003
11:30	29.9	5.1	3.09	0.036	0.004
11:31	30.0	4.9	3.19	0.037	0.004
11:32	29.8	9.2	3.17	0.037	0.007
11:33	29.9	4.7	3.25	0.037	0.004
11:34	29.4	2.8	3.63	0.037	0.002
11:35	30.4	4.7	3.04	0.037	0.003
11:36	30.2	4.8	3.00	0.037	0.004
11:37	30.2	6.5	2.97	0.037	0.005
11:38	30.3	5.3	3.05	0.037	0.004
11:39	30.2	4.4	2.97	0.037	0.003
11:40	30.2	6.1	3.04	0.037	0.004

AVERAGE VALUES FOR THE LAST 15 MINUTES

11:40	30.0	5.0	3.16	0.037	0.004
11:41	30.1	5.5	3.01	0.037	0.004
11:42	30.1	4.7	3.07	0.037	0.004
11:43	30.1	6.6	2.98	0.036	0.005
11:44	30.1	4.2	3.08	0.037	0.003
11:45	30.0	3.6	3.08	0.037	0.003
11:46	30.0	3.9	3.10	0.037	0.003
11:47	30.1	2.9	3.07	0.037	0.002
11:48	30.0	3.1	3.06	0.037	0.002
11:49	29.9	10.0	2.97	0.036	0.007
11:50	30.1	5.8	2.97	0.036	0.004
11:51	29.9	3.9	3.03	0.036	0.003
11:52	29.7	4.9	3.15	0.036	0.004
11:53	29.7	3.1	3.39	0.037	0.002

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 3	UNIT 3
	UNIT 3	UNIT 3	UNIT 3	1b NOX	1b CO
TIME	PPM NOX	PPM CO	% O2	MM-BTU	MM-BTU
11:54	29.7	5.9	3.29	0.037	0.004
11:55	29.5	3.7	3.28	0.036	0.003

AVERAGE VALUES FOR THE LAST 15 MINUTES

11:55	29.9	4.8	3.10	0.037	0.004
11:56	29.4	4.9	3.22	0.036	0.004
11:57	29.4	7.4	3.27	0.036	0.006
11:58	29.4	6.2	3.19	0.036	0.005
11:59	29.5	6.5	3.31	0.036	0.005
12:00	29.5	10.4	3.25	0.036	0.008
12:01	29.6	4.0	3.31	0.037	0.003
12:02	29.5	3.6	3.28	0.036	0.003
12:03	29.5	3.8	3.22	0.036	0.003
12:04	29.4	6.3	3.32	0.036	0.005
12:05	29.5	9.9	3.34	0.037	0.007
12:06	29.3	2.7	3.38	0.036	0.002
12:07	29.4	5.3	3.36	0.036	0.004
12:08	29.5	5.5	3.38	0.037	0.004
12:09	29.4	6.7	3.29	0.036	0.005
12:10	29.5	9.0	3.23	0.036	0.007

AVERAGE VALUES FOR THE LAST 15 MINUTES

12:10	29.5	6.1	3.29	0.036	0.005
-------	------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

12:10	29.8	5.3	3.20	0.037	0.004
-------	------	-----	------	-------	-------

COMMENTS: END RUN 2

UNIT 3 GAS

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

UNIT 3

REASON: POST RUN2 PRE RUN 3 SYSTEM BIAS CHECK

DATE : 04-10-1996 TIME: 12:11 - 12:16

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3	ppmNOX	0.0	0.8
1	UNIT 3	ppmNOX	46.5 46.9 pp	47.0
2	UNIT 3	ppm CO	0.0	0.4
2	UNIT 3	ppm CO	59.3 -	57.4
3	UNIT 3	% O2	0.00	0.08
3	UNIT 3	% O2	12.02 -	11.84

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 3	UNIT 3
	UNIT 3	UNIT 3	UNIT 3	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MM-BTU	MM-BTU
12:21	29.9	6.2	3.12	0.037	0.005
12:22	30.0	4.6	3.17	0.037	0.003
12:23	30.0	3.9	3.19	0.037	0.003
12:24	30.0	4.0	3.20	0.037	0.003
12:25	29.9	4.0	3.26	0.037	0.003
12:26	29.9	2.6	3.25	0.037	0.002
12:27	30.0	3.5	3.21	0.037	0.003
12:28	29.9	5.6	3.06	0.036	0.004
12:29	30.0	7.7	3.14	0.037	0.006
12:30	30.0	5.0	3.19	0.037	0.004
12:31	29.9	4.7	3.17	0.037	0.004
12:32	30.0	4.2	3.24	0.037	0.003
12:33	30.1	4.1	3.15	0.037	0.003
12:34	30.0	4.8	3.29	0.037	0.004
12:35	30.0	3.2	3.31	0.037	0.002

AVERAGE VALUES FOR THE LAST 15 MINUTES

12:35	30.0	4.5	3.20	0.037	0.003
12:36	30.0	5.4	3.09	0.037	0.004
12:37	30.0	4.3	3.23	0.037	0.003
12:38	30.0	4.9	3.29	0.037	0.004
12:39	30.1	4.1	3.20	0.037	0.003
12:40	30.0	3.8	3.16	0.037	0.003
12:41	29.7	7.3	3.37	0.037	0.006
12:42	30.3	5.3	3.03	0.037	0.004
12:43	30.3	4.8	3.07	0.037	0.004
12:44	30.4	3.6	3.05	0.037	0.003
12:45	30.1	3.9	3.05	0.037	0.003
12:46	30.3	4.0	2.95	0.037	0.003
12:47	30.1	5.2	3.01	0.037	0.004
12:48	30.2	3.4	3.00	0.037	0.002
12:49	30.2	3.7	3.01	0.037	0.003
12:50	30.0	3.1	3.04	0.036	0.002

AVERAGE VALUES FOR THE LAST 15 MINUTES

12:50	30.1	4.5	3.10	0.037	0.003
12:51	30.0	3.9	3.02	0.037	0.003
12:52	30.0	2.9	3.06	0.037	0.002
12:53	29.9	3.4	3.03	0.036	0.003
12:54	30.0	4.1	3.05	0.037	0.003
12:55	29.9	5.2	3.05	0.036	0.004
12:56	30.0	4.0	3.01	0.036	0.003
12:57	29.8	7.0	2.94	0.036	0.005
12:58	29.9	4.3	3.05	0.036	0.003
12:59	29.8	4.2	3.06	0.036	0.003
13:00	29.9	4.1	3.00	0.036	0.003
13:01	29.8	4.2	3.08	0.036	0.003
13:02	29.8	6.6	3.01	0.036	0.005
13:03	29.4	5.0	3.02	0.036	0.004

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-10-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 3	UNIT 3
	UNIT 3	UNIT 3	UNIT 3	lb NOX	lb CO
TIME	ppm NOX	ppm CO	% O2	MM-BTU	MM-BTU
13:04	29.5	5.5	3.24	0.036	0.004
13:05	29.2	6.4	3.24	0.036	0.005

AVERAGE VALUES FOR THE LAST 15 MINUTES

13:05	29.8	4.7	3.06	0.036	0.004
13:06	29.2	4.5	3.27	0.036	0.003
13:07	29.3	4.9	3.29	0.036	0.004
13:08	29.2	3.0	3.28	0.036	0.002
13:09	29.2	3.3	3.34	0.036	0.003
13:10	29.2	3.7	3.30	0.036	0.003
13:11	29.2	7.7	3.23	0.036	0.006
13:12	29.3	7.9	3.24	0.036	0.006
13:13	29.3	5.9	3.22	0.036	0.004
13:14	29.3	4.3	3.28	0.036	0.003
13:15	29.3	4.5	3.27	0.036	0.003
13:16	29.2	5.1	3.35	0.036	0.004
13:17	29.3	4.4	3.27	0.036	0.003
13:18	29.2	4.5	3.19	0.036	0.003
13:19	29.5	4.1	3.21	0.036	0.003
13:20	29.1	3.4	3.25	0.036	0.003

AVERAGE VALUES FOR THE LAST 15 MINUTES

13:20	29.3	4.8	3.27	0.036	0.004
-------	------	-----	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

13:20	29.8	4.6	3.16	0.036	0.003
-------	------	-----	------	-------	-------

COMMENTS: END RUN 3
UNIT 3 GAS

UNIT 2.043
UNIT 2.045

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN ³ PRE RUN ⁴ SYSTEM BIAS CHECK
UNIT #2 RUN 1

DATE : 04-10-1996 TIME: 13:20 - 13:27

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3	ppmNOX	0.0	0.8
1	UNIT 3	ppmNOX	(46.5) 46.9 M	46.8
2	UNIT 3	ppm CO	0.0	0.5
2	UNIT 3	ppm CO	(57.3) 59.3 M	57.4
3	UNIT 3	% O2	0.00	0.21
3	UNIT 3	% O2	12.02	11.82

APPENDIX B. FIELD DATA

2. Boiler No. 3

b. No. 6 Fuel Oil

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: DIRECT CALIBRATION ERROR CHECK 014 *PR*

DATE : 04-11-1996 TIME: 06:31 - 06:43

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2 <i>PR</i>	ppmNOX	0.0	0.5
1	UNIT 2	ppmNOX	252.0	252.8
1	UNIT 2	ppmNOX	452.0	452.7
2	UNIT 2	ppm CO	0.0	0.2
2	UNIT 2	ppm CO	59.3	59.1
2	UNIT 2	ppm CO	91.0	90.5
2	UNIT 2	ppm CO	151.0	151.0
3	UNIT 2	% O2	0.00	0.24
3	UNIT 2	% O2	12.02	12.17
3	UNIT 2	% O2	20.12	20.26

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: PRE RUN 1 SYSTEM BIAS CHECK

DATE : 04-11-1996 TIME: 06:44 - 07:24

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	0.8
1	UNIT 2	ppmNOX	155.0	156.7
1	UNIT 2	ppmNOX	252.0 257 A2	253.0
2	UNIT 2	ppm CO	0.0	0.4
2	UNIT 2	ppm CO	91.0	91.5
2	UNIT 2	ppm CO	151.0	151.4
3	UNIT 2	% O2	0.00	0.20
3	UNIT 2	% O2	12.02	12.07

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2 ³	UNIT 2 ³
	UNIT 2 ³	UNIT 2 ³	UNIT 2 ³	lb NOX	lb CO
TIME	PPM NOX	PPM CO	% O ₂	MM-BTU	MM-BTU
14:31	297.7	26.9	3.06	0.383	0.021
14:32	299.2	26.0	3.13	0.386	0.020
14:33	298.8	25.4	3.10	0.385	0.020
14:34	298.8	26.7	3.07	0.384	0.021
14:35	299.4	29.4	3.12	0.386	0.023
14:36	297.9	31.9	3.04	0.383	0.025
14:37	291.6	57.1	3.16	0.377	0.045
14:38	291.8	64.6	3.16	0.377	0.051
14:39	291.7	67.3	3.02	0.374	0.053
14:40	291.2	82.3	3.15	0.376	0.065
14:41	291.8	69.0	3.11	0.376	0.054
14:42	290.5	71.2	3.10	0.374	0.056
14:43	291.1	76.4	3.06	0.374	0.060
14:44	290.1	75.8	3.15	0.375	0.060
14:45	291.0	89.5	3.10	0.375	0.070

AVERAGE VALUES FOR THE LAST 15 MINUTES

14:45	294.2	54.6	3.10	0.379	0.043
14:46	291.4	120.3	3.07	0.375	0.094
14:47	289.2	85.1	3.02	0.371	0.066
14:48	289.2	104.0	3.18	0.374	0.082
14:49	288.0	139.4	3.02	0.369	0.109
14:50	288.8	112.9	3.15	0.373	0.089
14:51	286.8	92.2	3.09	0.369	0.072
14:52	287.9	70.4	3.31	0.375	0.056
14:53	286.9	65.0	3.31	0.374	0.052
14:54	285.5	86.6	3.28	0.372	0.069
14:55	283.2	119.9	3.28	0.369	0.095
14:56	283.1	113.8	3.28	0.368	0.090
14:57	283.5	123.9	3.35	0.371	0.099
14:58	285.4	105.3	3.25	0.371	0.083
14:59	286.8	93.3	3.34	0.374	0.074
15:00	286.8	106.5	3.29	0.374	0.084

AVERAGE VALUES FOR THE LAST 15 MINUTES

15:00	286.8	102.6	3.21	0.372	0.081
15:01	286.9	73.7	3.33	0.375	0.059
15:02	288.9	62.3	3.34	0.377	0.050
15:03	288.4	66.8	3.37	0.377	0.053
15:04	289.6	60.6	3.36	0.379	0.048
15:05	288.2	60.6	3.26	0.375	0.048
15:06	287.3	88.3	3.32	0.375	0.070
15:07	286.1	103.8	3.33	0.373	0.082
15:08	287.8	89.1	3.25	0.374	0.070
15:09	289.6	90.6	3.36	0.379	0.072
15:10	291.3	70.7	3.25	0.378	0.056
15:11	288.2	53.4	3.41	0.378	0.043
15:12	287.1	76.5	3.41	0.377	0.061
15:13	286.6	87.4	3.35	0.375	0.070

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1 UNIT 2 ³	CHAN 2 UNIT 2 ³	CHAN 3 UNIT 2 ³	UNIT 2 ³ lb NO _x	UNIT 2 ³ lb CO
TIME	ppm NO _x	ppm CO	% O ₂	MM-BTU	MM-BTU
15:14	287.2	80.6	3.49	0.378	0.065
15:15	286.8	70.4	3.36	0.375	0.056

AVERAGE VALUES FOR THE LAST 15 MINUTES

15:15	288.0	75.6	3.35	0.376	0.060
15:16	288.7	86.4	3.34	0.377	0.069
15:17	289.5	68.3	3.44	0.380	0.055
15:18	290.2	54.4	3.45	0.382	0.043
15:19	290.0	76.5	3.33	0.379	0.061
15:20	290.6	53.9	3.40	0.381	0.043
15:21	289.2	48.2	3.46	0.380	0.039
15:22	289.5	87.6	3.36	0.378	0.070
15:23	289.8	77.8	3.40	0.380	0.062
15:24	283.9	83.4	3.43	0.373	0.067
15:25	284.3	124.3	3.35	0.371	0.099
15:26	283.9	136.6	3.36	0.371	0.109
15:27	284.4	109.4	3.39	0.373	0.087
15:28	283.5	135.1	3.34	0.370	0.107
15:29	283.9	97.2	3.39	0.372	0.077
15:30	281.6	132.1	3.42	0.370	0.106

AVERAGE VALUES FOR THE LAST 15 MINUTES

15:30	286.9	91.4	3.39	0.376	0.073
-------	-------	------	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

15:30	289.0	81.1	3.26	0.376	0.064
-------	-------	------	------	-------	-------

COMMENTS: END RUN 1

UNIT 3 OIL

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN 1 (4) PRE RUN 2 (5) SYSTEM BIAS CHECK

DATE : 04-11-1996 TIME: 15:30 - 15:37

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2 3	ppmNOX	0.0	2.1
1	UNIT 2 3	ppmNOX	252.0	257.12-253.2
2	UNIT 2 3	ppm CO	0.0	1.1
2	UNIT 2 3	ppm CO	59.3	56.8
3	UNIT 2 3	% O2	0.00	0.25
3	UNIT 2 3	% O2	12.02	11.87

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 3	UNIT 3	UNIT 3	1b NOX	1b CO
TIME	ppmNOX	ppm CO	% O2	MBTU	MBTU
15:41	295.5	25.9	3.47	0.389	0.021
15:42	296.3	21.2	3.58	0.393	0.017
15:43	296.6	16.6	3.53	0.391	0.013
15:44	295.6	24.9	3.51	0.390	0.020
15:45	296.6	26.6	3.44	0.390	0.021
15:46	297.1	19.8	3.53	0.392	0.016
15:47	297.9	18.8	3.49	0.392	0.015
15:48	298.4	20.9	3.51	0.394	0.017
15:49	297.6	18.4	3.49	0.392	0.015
15:50	297.3	25.4	3.44	0.391	0.020
15:51	299.8	13.2	3.51	0.395	0.011
15:52	299.6	15.0	3.48	0.394	0.012
15:53	300.2	17.2	3.50	0.396	0.014
15:54	302.6	10.0	3.59	0.401	0.008
15:55	301.1	10.4	3.49	0.397	0.008

AVERAGE VALUES FOR THE LAST 15 MINUTES

15:55	298.2	19.0	3.50	0.393	0.015
15:56	300.8	15.0	3.46	0.396	0.012
15:57	301.5	9.9	3.58	0.399	0.008
15:58	303.6	7.2	3.59	0.402	0.006
15:59	304.1	7.5	3.52	0.401	0.006
16:00	302.9	6.8	3.62	0.402	0.006
16:01	302.1	8.1	3.51	0.398	0.007
16:02	303.2	8.7	3.57	0.401	0.007
16:03	302.5	9.4	3.61	0.401	0.008
16:04	304.1	9.8	3.54	0.402	0.008
16:05	305.0	8.2	3.45	0.401	0.007
16:06	305.0	6.9	3.59	0.404	0.006
16:07	305.3	6.6	3.55	0.404	0.005
16:08	305.0	5.6	3.53	0.403	0.005
16:09	303.9	7.2	3.47	0.400	0.006
16:10	298.6	13.6	3.39	0.391	0.011

AVERAGE VALUES FOR THE LAST 15 MINUTES

16:10	303.2	8.7	3.53	0.400	0.007
16:11	297.5	35.5	3.24	0.386	0.028
16:12	298.9	25.7	3.24	0.388	0.020
16:13	298.8	31.7	3.25	0.388	0.025
16:14	299.0	27.8	3.20	0.388	0.022
16:15	300.1	24.4	3.33	0.392	0.019
16:16	297.9	28.5	3.23	0.387	0.022
16:17	296.8	43.3	3.24	0.385	0.034
16:18	296.5	28.8	3.22	0.385	0.023
16:19	296.6	47.4	3.17	0.384	0.037
16:20	296.8	40.6	3.36	0.388	0.032
16:21	295.8	41.2	3.19	0.383	0.032
16:22	296.2	40.1	3.25	0.385	0.032
16:23	297.5	31.6	3.20	0.385	0.025

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 3	UNIT 3	UNIT 3	1b NOX	1b CO
TIME	ppmNOX	ppm CO	% O2	MBTU	MBTU
16:24	297.7	30.5	3.24	0.387	0.024
16:25	298.6	25.0	3.28	0.389	0.020

AVERAGE VALUES FOR THE LAST 15 MINUTES

16:25	297.6	33.5	3.24	0.387	0.026
16:26	297.4	25.6	3.28	0.387	0.020
16:27	296.2	37.9	3.24	0.385	0.030
16:28	296.7	30.3	3.25	0.386	0.024
16:29	296.9	35.7	3.24	0.386	0.028
16:30	297.7	31.3	3.32	0.388	0.025
16:31	299.2	29.5	3.22	0.388	0.023
16:32	298.2	30.1	3.21	0.387	0.024
16:33	299.3	38.9	3.20	0.388	0.031
16:34	299.4	23.4	3.25	0.389	0.018
16:35	299.6	26.6	3.32	0.391	0.021
16:36	299.9	14.6	3.34	0.392	0.012
16:37	299.8	16.0	3.37	0.392	0.013
16:38	299.0	20.8	3.17	0.387	0.016
16:39	299.4	28.4	3.17	0.387	0.022
16:40	300.2	24.0	3.22	0.389	0.019

AVERAGE VALUES FOR THE LAST 15 MINUTES

16:40	298.6	27.5	3.25	0.388	0.022
-------	-------	------	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

16:40	299.4	22.2	3.38	0.392	0.018
-------	-------	------	------	-------	-------

COMMENTS: END RUN 2
UNIT 3 OIL

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN 2 (5) PRE RUN 3 (6) SYSTEM BIAS CHECK

DATE : 04-11-1996 TIME: 16:40 - 16:45

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 2	ppmNOX	0.0	4.6
1	UNIT 3	ppmNOX	252.0	257 MP 256.0
2	UNIT 3	ppm CO	0.0	1.9
2	UNIT 3	ppm CO	59.3	56.6
3	UNIT 4	% O2	0.00	0.12
3	UNIT 5	% O2	12.02	12.17

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 3	UNIT 3	UNIT 3	1b NOX	1b CO
TIME	ppmNOX	ppm CO	% O2	MBTU	MBTU
16:51	302.2	10.9	3.27	0.393	0.009
16:52	304.1	10.1	3.39	0.398	0.008
16:53	304.3	8.5	3.36	0.398	0.007
16:54	303.1	9.6	3.25	0.394	0.008
16:55	303.5	9.9	3.27	0.395	0.008
16:56	303.9	7.6	3.24	0.395	0.006
16:57	304.0	9.2	3.21	0.394	0.007
16:58	304.1	7.5	3.21	0.394	0.006
16:59	304.0	7.9	3.30	0.396	0.006
17:00	305.2	7.5	3.22	0.396	0.006
17:01	305.8	6.6	3.23	0.397	0.005
17:02	306.8	6.9	3.17	0.397	0.005
17:03	309.4	4.7	3.30	0.403	0.004
17:04	309.1	4.7	3.22	0.401	0.004
17:05	309.4	4.1	3.32	0.404	0.003

AVERAGE VALUES FOR THE LAST 15 MINUTES

17:05	305.3	7.7	3.26	0.397	0.006
17:06	309.0	4.3	3.23	0.401	0.003
17:07	308.9	4.2	3.36	0.404	0.003
17:08	309.6	3.8	3.36	0.405	0.003
17:09	309.5	4.2	3.20	0.401	0.003
17:10	310.3	4.8	3.25	0.403	0.004
17:11	310.9	4.0	3.18	0.402	0.003
17:12	310.4	4.6	3.11	0.400	0.004
17:13	309.6	4.4	3.12	0.399	0.003
17:14	302.4	4.8	3.39	0.396	0.004
17:15	312.0	4.1	3.00	0.400	0.003
17:16	310.7	4.4	2.98	0.398	0.003
17:17	313.1	4.1	3.12	0.404	0.003
17:18	313.1	3.8	3.05	0.402	0.003
17:19	313.7	3.9	3.07	0.403	0.003
17:20	311.6	3.9	3.03	0.400	0.003

AVERAGE VALUES FOR THE LAST 15 MINUTES

17:20	310.3	4.2	3.16	0.401	0.003
17:21	312.4	4.1	3.09	0.402	0.003
17:22	312.6	3.7	3.08	0.402	0.003
17:23	313.1	3.6	3.05	0.402	0.003
17:24	313.5	3.7	3.09	0.404	0.003
17:25	312.1	3.6	3.04	0.401	0.003
17:26	313.2	3.7	3.09	0.403	0.003
17:27	313.5	3.6	3.15	0.405	0.003
17:28	314.0	3.4	3.18	0.406	0.003
17:29	312.4	3.7	3.01	0.401	0.003
17:30	309.2	4.4	3.00	0.396	0.003
17:31	296.0	53.6	2.87	0.377	0.041
17:32	293.3	61.7	3.07	0.378	0.048
17:33	300.6	84.1	2.59	0.377	0.064

HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE 04-11-1996

	CHAN 1	CHAN 2	CHAN 3	UNIT 2	UNIT 2
	UNIT 3	UNIT 3	UNIT 3	lb NOX	lb CO
TIME	ppmNOX	ppm CO	% O2	MBTU	MBTU
17:34	301.0	78.9	2.61	0.377	0.060
17:35	299.9	72.7	2.66	0.377	0.056

AVERAGE VALUES FOR THE LAST 15 MINUTES

17:35	307.8	25.9	2.97	0.394	0.020
17:36	298.4	84.0	2.64	0.375	0.064
17:37	299.4	101.8	2.59	0.375	0.078
17:38	300.0	72.4	2.63	0.377	0.055
17:39	299.6	70.3	2.65	0.377	0.054
17:40	299.4	84.0	2.62	0.376	0.064
17:41	298.6	100.8	2.59	0.374	0.077
17:42	299.0	80.4	2.69	0.377	0.062
17:43	298.7	90.5	2.60	0.374	0.069
17:44	301.9	63.1	2.86	0.384	0.049
17:45	301.5	36.0	2.86	0.383	0.028
17:46	301.5	47.2	2.89	0.384	0.037
17:47	302.2	23.7	2.99	0.387	0.018
17:48	303.9	21.4	2.95	0.388	0.017
17:49	301.9	29.1	2.91	0.385	0.023
17:50	302.4	31.5	2.97	0.387	0.025

AVERAGE VALUES FOR THE LAST 15 MINUTES

17:50	300.6	62.4	2.76	0.380	0.048
-------	-------	------	------	-------	-------

AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

17:50	306.0	25.1	3.04	0.393	0.019
17:51	302.7	21.6	3.03	0.388	0.017

COMMENTS: END RUN 3
UNIT 3 OIL

CALIBRATION SUMMARY

SOURCE: HERSHEY CHOCOLATE - BOILER 2 & 3 COMPLIANCE

REASON: POST RUN 3 (6) SYSTEM BIAS CHECK

DATE : 04-11-1996 TIME: 17:51 - 17:56

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
1	UNIT 3	ppmNOX	0.0	3.6
1	UNIT 3	ppmNOX	252.0	257.9
2	UNIT 3	ppm CO	0.0	1.7
2	UNIT 3	ppm CO	59.3	56.4
3	UNIT 3	% O2	0.00	0.20
3	UNIT 3	% O2	12.02	12.08

APPENDIX C. CALIBRATION DATA



Scott Specialty Gases

6141 EASTON ROAD, P.O. BOX 310, PLUMSTEADVILLE, PA 18949-0310

(215) 766-8861 FAX: (215) 766-0320

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
Entropy
8724 Glenwood Ave
Raleigh, NC 27612

Assay Laboratory
Scott Specialty Gases, Inc.
6141 Easton Road
P.O. Box 310
Plumsteadville, PA 18949-0310

Purchase Order 5071-MAXWEJ
Scott Project # 01-73802-005

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; 1 Procedure #G1, Section Number 3.0.4; September, 1993.

Cylinder Number ALM058282
Cylinder Pressure 2000 psig+

Certification Date 11-28-95
Previous Certification Dates None

Expiration Date 11-28-97

ANALYZED CYLINDER

Components
Nitric Oxide
Total Oxides of Nitrogen
Balance Gas: Nitrogen

Certified Concentration
46.5 ppm
46.9 ppm

Analytical Uncertainty*
±1% NIST Traceable
Reference Value Only

*Do not use when cylinder is less than 150 psig.

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type NTRM1684
Expiration Date 06-07-97

Cylinder Number
ALM049155

Concentration
94.4 ppm NO in N₂

INSTRUMENTATION

Instrument/Model/Serial #
NO: Horiba/CLA220/5708850810

Last Date Calibrated
11-10-95

Analytical Principle
Chemiluminescent

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
Nitric Oxide	Date: 11-21-95 Response Units: Volts Z1=-0.0001 R1=0.9477 T1=0.4632 R2=0.9452 Z2=0.0001 T2=0.4618 Z3=0.0000 T3=0.4616 R3=0.9433 Avg. Conc. of Cust. Cyl. 46.7 ppm	Date: 11-28-95 Response Units: Volts Z1=-0.0003 R1=0.9454 T1=0.4638 R2=0.9474 Z2=0.0005 T2=0.4670 Z3=-0.0003 T3=0.4684 R3=0.9486 Avg. Conc. of Cust. Cyl. 46.4 ppm	Concentration = $A + Bx + Cx^2 + Dx^3 + Ex^4$ $r = 0.99992$ NTRM1684 Constants: A = -2.4890E-01 B = 9.8680E+01 C = 0.0000E+00 D = 0.0000E+00 E = 0.0000E+00

Special Notes:

97

Analyst Wesley Blenner



Scott Specialty Gases

1750 EAST CLUB BOULEVARD, DURHAM, NC 27704

(919) 220-0803 FAX: (919) 220-0808

CERTIFICATE OF ANALYSIS: Interference-Free™ Multi-Component EPA Protocol Gas

Customer
Entropy Environmentalists
Attn: John Maxwell
Accounts Payable
P.O. Box 12291
Research Triangle Park, NC 27709

Assay Laboratory
Scott Specialty Gases, Inc.
1750 East Club Boulevard
Durham, NC 27704

Purchase Order MAXWELL
Scott Project # 12-16095

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol Procedure #G1, issued September, 1993.

Cylinder Number ALM-000970
Cylinder Pressure 1923 PSIG

Certification Date 03-06-95
Previous Certification None

Expiration Date 03-06-98

ANALYZED CYLINDER

Components

Nitric Oxide

Nox

Nitrogen

Certified Concentration

88.89 PPM

89.74 PPM

Analytical Uncertainty*

+/- 1% NIST Directly Traceable
Reference Value Only
Balance

Do not use when cylinder pressure is less than 150 PSIG.

*Analytical uncertainty is inclusive of usual known error sources which at least includes precision of the measurement processes.

REFERENCE STANDARD

Type NTRM# 1684
Expiration Date 06-97

Cylinder Number
ALM-049051

Concentration
94.4 PPM NO Balance in N2

INSTRUMENTATION

Instrument/Model/Serial #
NICOLET / 8220 / AAB9400252

Last Date Calibrated
02-06-96

Analytical Principle
Scott Enhanced FTIR

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

Nitric Oxide

First Triad Analysis

Date: 02-28-96 Response Units: PPM
Z1= -0.155 R2= 94.44 Z3= -0.045
R1= 94.28 Z2= 0.048 T3= 88.88
T1= 88.84 T2= 89.24 R3= 94.42
Average Concentration : 88.99 PPM

Second Triad Analysis

Date: 03-06-96 Response Units: PPM
Z1= -0.184 R2= 94.37 Z3= -0.018
R1= 94.50 Z2= -0.155 T3= 88.95
T1= 88.82 T2= 88.60 R3= 94.33
Average Concentration : 88.79 PPM

Calibration Curve

Date: 02-06-96
Concentration = A+Br+Cx2+Dx3+Ex4+Fx5
R=0.99999 A= -2.04523E-1
B=7.55972E-1 C=2.59896E-4
D=5.37748E-7 E=1.13202E-1
F=1.91805E-13

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date:

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date:

B. Becton
Analyst B. Becton

Air Produ and Chemicals, Inc.
P.O. BOX 31
R.D. #1
TAMAQUA, PA 18252

Certificate of Analysis - EPA Protocol Gas Standard

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer: AIR PRODUCTS & CHEMICALS
1680 OAK TREE RD.
EDISON NJ 08820

Notes:

Order No: 147-034169-25
Batch No: 255-69382
Cylinder No: SG9121024BAL
Cylinder Pressure*: 2000 psig
Certification Date: 06/09/95
Expiration Date: 06/09/97

*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****
Component Concentration Certified Instrument Serial Last Measurement
NITRIC OXIDE 155 ±0.40 PPM SG9138639BAL GMIS 97.8700 PPM Thermal Enviro 10S-4502 05/17/95 CHEMILUMINESCENCE

Balance Gas: Nitrogen

* Standard should not be used below 150 psig

CO
CO

Analyst: Jeff LaGrassa

Approved By: K. Roubik
Ken Roubik



Scott Specialty Gases

6141 EASTON ROAD, P.O. BOX 310, PLUMSTEADVILLE, PA 18949-0310

(215) 766-8861 FAX: (215) 766-0320

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
Entropy
Cem Division
8724 Glenwood Avenue
Raleigh, NC 27612

Assay Laboratory
Scott Specialty Gases, Inc.
6141 Easton Road
P.O. Box 310
Plumsteadville, PA 18949-0310

Purchase Order 4783-MAXWELJ
Scott Project # 01-63890-007

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol 1 Procedure #G1, Section Number 3.0.4

Cylinder Number	ALM055644	Certification Date	01-11-95	Expiration Date	01-11-97
Cylinder Pressure	2000 psig+	Previous Certification Dates	None		

ANALYZED CYLINDER

Components

Nitric Oxide
Total Oxides of Nitrogen
Balance Gas: Air

Certified Concentration

252 ppm
257 ppm

Analytical Uncertainty*

±1% NIST Traceable
Reference Value Only

+Do not use when cylinder is less than 150 psig.

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type	Expiration Date	Cylinder Number	Concentration
NTRM 1686	08-04-96	ALM025120	495 ppm NO in N ₂

INSTRUMENTATION

Instrument/Model/Serial #	Last Date Calibrated	Analytical Principle
NO: Teco/10/9741111S	01-10-95	Chemiluminescent

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
Nitric Oxide	Date: 01-04-95 Response Units: Volts Z1=0.0000 R1=7.3100 T1=7.5000 R2=7.2563 Z2=0.0000 T2=7.4930 Z3=0.0000 T3=7.2911 R3=7.4991 Avg. Conc. of Cust. Cyl. 252 ppm	Date: 01-11-95 Response Units: Volts Z1=0.0000 R1=4.6955 T1=2.3873 R2=4.7143 Z2=0.0000 T2=2.3911 Z3=0.0000 T3=2.3900 R3=4.7099 Avg. Conc. of Cust. Cyl. 251 ppm	Concentration= A+Bx+Cx²+Dx³+Ex⁴ r=0.99999 NTRM1687 Constants: A=7.5202E-01 B=1.0413E+02 C=0.0000E+00 D=0.0000E+00 E=0.0000E+00

Special Notes:

☐ Check this box if certified concentration has been corrected for analytical interferences.

100

Wesley Pfeiler
Analyst Wesley Pfeiler



Scott Specialty Gases

6141 EASTON ROAD, P.O. BOX 310, PLUMSTEADVILLE, PA 18949-0310

(215) 766-8861 FAX (215) 766-0320

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

Entropy
Cem Division
8724 Glenwood Avenue
Raleigh, NC 27612

Assay Laboratory

Scott Specialty Gases, Inc.
6141 Easton Road
P.O. Box 310
Plumsteadville, PA 18949-0310

Purchase Order 5011-MAXWELJ
Scott Project # 01-71229-019

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; 1 Procedure #G1, Section Number 3.0.4; September, 1993.

Cylinder Number ALM041868
Cylinder Pressure 2000 psig+

Certification Date 08-25-95
Previous Certification Dates None

Expiration Date 08-25-97

ANALYZED CYLINDER

Components

Nitric Oxide
Total Oxides of Nitrogen
Balance Gas: Nitrogen

Certified Concentration

452 ppm
457 ppm

Analytical Uncertainty*

±1% NIST Traceable
Reference Value Only

*Do not use when cylinder is less than 150 psig.

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type NTRM1686
Expiration Date 08-04-96

Cylinder Number
ALM021309

Concentration
495 ppm NO in N₂

INSTRUMENTATION

Instrument/Model/Serial #
NO: Teco/10/9741111S

Last Date Calibrated
08-03-95

Analytical Principle
Chemiluminescent

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

Nitric Oxide

First Triad Analysis

Date: 08-17-95 Response Units: Volts
Z1=0.0067 R1=9.4633 T1=4.3801
R2=9.5028 Z2=0.0198 T2=4.3975
Z3=0.0221 T3=4.4170 R3=9.5499
Avg. Conc. of Cust. Cyl 451 ppm

Second Triad Analysis

Date: 08-25-95 Response Units: Volts
Z1=0.0020 R1=4.8025 T1=4.3923
R2=4.8016 Z2=0.0162 T2=4.3982
Z3=0.0169 T3=4.4268 R3=4.8245
Avg. Conc. of Cust. Cyl 453 ppm

Calibration Curve

Concentration = $A + Bx + Cx^2 + Dx^3 + Ex^4$
r=1.00000 NTRM1687
Constants: A=4.3165E-01
B=1.0274E+02 C=0.0000E+00
D=0.0000E+00 E=0.0000E+00

Special Notes:

101

Analyst Wesley Bleker



Scott Specialty Gases, Inc.

Shipped 1750 EAST CLUB BLVD.
 From: DURHAM NC 27704
 Phone: 919-220-0803 Fax: 919-220-0808

C E R T I F I C A T E O F A N A L Y S I S

ENTROPY PROJECT #: 12-09145-004
 MR. JOHN MAXWELL PO#: 4704-MAXWELLJ
 CEM DIVISION ITEM #: 12024311 4AL
 8724 GLENWOOD AVENUE DATE: 11/17/94
 RALEIGH NC 27612

CYLINDER #: AAL9093

ANALYTICAL ACCURACY: +/-2%

BLEND TYPE : CERTIFIED MASTER GAS

COMPONENT	REQUESTED GAS		ANALYSIS	
	CONC	MOLES	(MOLES)	
CARBON MONOXIDE	50.	PPM	49.8	PPM
METHANE	50.	PPM	50.1	PPM
AIR		BALANCE		BALANCE

ANALYST:

K. COOKE

102



Scott Specialty Gases

1750 EAST CLUB BOULEVARD, DURHAM, NC 27704

(919) 220-0803 FAX: (919) 220-0808

CERTIFICATE OF ANALYSIS: Interference-Free™ Multi-Component EPA Protocol Gas

Customer
Entropy Environmentalists
Attn: John Maxwell
Accounts Payable
P.O. Box 12291
Research Triangle Park, NC 27709

Assay Laboratory
Scott Specialty Gases, Inc.
1750 East Club Boulevard
Durham, NC 27704

Purchase Order MAXWELL
Scott Project # 12- 16095

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol Procedure #G1, issued September, 1993.

Cylinder Number ALM-038607
Cylinder Pressure 1957 PSIG

Certification Date 03-05-96
Previous Certification None

Expiration Date 03-05-99

ANALYZED CYLINDER

Components

Carbon Monoxide
Nitrogen

Certified Concentration
59.26 PPM

Analytical Uncertainty*

+/- 1% NIST Directly Traceable
Balance

Do not use when cylinder pressure is less than 150 PSIG.

*Analytical uncertainty is inclusive of usual known error sources which at least includes precision of the measurement processes.

REFERENCE STANDARD

Type Expiration Date
NTRM# 1679 08-96

Cylinder Number
ALM-041546

Concentration
97.1 PPM CO Balance in N2

INSTRUMENTATION

Instrument/Model/Serial #
NICOLET / 8220 / AAB9400252

Last Date Calibrated
02-06-96

Analytical Principle
Scott Enhanced FTIR

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

First Triad Analysis

Carbon Monoxide

Date: 02-27-96 Response Units: PPM
Z1=-0.037 R2=97.16 Z3=0.033
R1=97.01 Z2=-0.007 T3=59.35
T1=59.29 T2=59.18 R3=97.13
Average Concentration: 59.27 PPM

Second Triad Analysis

Date: 03-05-96 Response Units: PPM
Z1=-0.045 R2=97.13 Z3=0.014
R1=97.09 Z2=-0.008 T3=59.22
T1=59.20 T2=59.31 R3=97.07
Average Concentration: 59.24 PPM

Calibration Curve

Date: 02-06-96
Concentration = A+Bx+Cx2+Dx3+Ex4+Fx5
R=0.99999 A=-3.23459E-1
B=2.69481E-1 C=3.28372E-4
D=4.54495E-6 E=3.89233E-9
F=1.80390E-12

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date:

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date:

B. Becton
Analyst B. Becton

Air Products and Chemicals, Inc.
P.O. BOX 351
R.D. #1
TAMAQUA, PA 18252

Certificate of Analysis - EPA Protocol Gas Standard

Page 1 of 1

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS AND CHEMICALS, INC.
HOMETOWN FACILITY
R.R. #1, P.O. BOX 351
TAMAQUA PA 18252-

Notes:

Order No: 255-055424-02
Batch No: 255-73395

Cylinder No: SG9147500BAL
Cylinder Pressure*: 2000 psig
Certification Date: 08/24/95
Expiration Date: 08/24/98

FO:

*** Certified Concentration *** ***** Reference Standards ***** Analytical Instrumentation *****

Certified Standard

Instrument Serial Last Measurement
Make/Model Number Calibration Principal

Component Concentration Cylinder #
CARBON MONOXIDE 91.0 ±0.23 PPM SG887934

GMIS

91.7000 PPM Hewlett Packar 2518A052 08/12/95 GC-FID

Balance Gas: Nitrogen

* Standard should not be used below 150 psig

104

Analyst:

Mike Pascolini
Mike Pascolini

Approved By:

Ken Roubik
Ken Roubik



Scott Specialty Gases

1750 EAST CLUB BOULEVARD, DURHAM, NC 27704

(919) 220-0803 FAX: (919) 220-0808

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
Entropy Environmentalist
Attn: John Maxwell
Attn: Accts Payable
P.O. Box 12291
Research Triangle Park, NC 27709

Assay Laboratory
Scott Specialty Gases, Inc.
1750 East Club Boulevard
Durham, N.C. 27704

Purchase Order 5011-MAXWELLJ
Scott Project # 12-13047

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol Procedure #G1, issued September, 1993.

Cylinder Number	AAL-774	Certification Date	08-21-95	Expiration Date	08-21-98
Cylinder Pressure	1929 PSIG	Previous Certification	None		

ANALYZED CYLINDER

Components
Carbon Monoxide
Nitrogen

Certified Concentration
151.4 PPM

Analytical Uncertainty*
+/- 1% NIST Directly Traceable
Balance

Do not use when cylinder pressure is less than 150 PSIG.

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type NTRM# 2636
Expiration Date 08-96

Cylinder Number
ALM-034275

Concentration
244.2 PPM CO Balance in N2

INSTRUMENTATION

Instrument/Model/Serial #
NICOLET / 8220 / AAB9400252

Last Date Calibrated
08-01-95

Analytical Principle
FTIR

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

First Triad Analysis

Second Triad Analysis

Calibration Curve

Carbon Monoxide

Date: 08-11-95 Response Units: PPM
Z1=0.058 R2=243.8 Z3=0.133
R1=244.2 Z2=0.068 T3=151.1
T1=151.1 T2=151.0 R3=243.8

Date: 08-21-95 Response Units: PPM
Z1=0.028 R2=243.8 Z3=0.200
R1=244.2 Z2=0.017 T3=151.5
T1=151.6 T2=151.7 R3=243.5

Date: 08-01-95

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date:

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date: Response Units:
Z1= R2= Z3=
R1= Z2= T3=
T1= T2= R3=

Date:

B. Becton
Analyst B. Becton



Scott Specialty Gases

1750 EAST CLUB BOULEVARD, DURHAM, NC 27704

(919) 220-0803 FAX: (919) 220-0808

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
Entropy
ATTN: Mr. John Maxwell
CEM Division
8724 Glenwood Avenue
Raleigh, NC 27612

Assay Laboratory
Scott Specialty Gases, Inc.
1750 East Club Boulevard
Durham, NC 27704

Purchase Order 4965-MAXWELLJ
Scott Project # 12-12390

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol Procedure #G1, issued September, 1993.

Cylinder Number	AAL-18882	Certification Date	06-28-95	Expiration Date	06-28-98
Cylinder Pressure	2000 PSIG	Previous Certification	None		

ANALYZED CYLINDER

Components

Oxygen
Nitrogen

Certified Concentration
12.02 %

Analytical Uncertainty*
+/- 1% NIST Directly Traceable
Balance

Do not use when cylinder pressure is less than 150 PSIG.

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type
NIRM # 2658

Expiration Date
11-96

Cylinder Number
ALM-031884

Concentration
9.68% O2 Balance in N2

INSTRUMENTATION

Instrument/Model/Serial #
Varian /3400/16804

Last Date Calibrated
05-22-95

Analytical Principle
Gas Chromatography

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

Oxygen

First Triad Analysis

Date: 06-28-95	Response Units: Area
STD-261883	SPL-325175
SPL-325305	STD-261454
STD-261818	SPL-324821

Second Triad Analysis

Date:	Response Units:
STD-	SPL-
SPL-	STD-
STD-	SPL-

Calibration Curve

Date: 05-22-95

Date:	Response Units:
STD-	SPL-
SPL-	STD-
STD-	SPL-

Date:	Response Units:
STD-	SPL-
SPL-	STD-
STD-	SPL-

Date:

Date:	Response Units:
STD-	SPL-
SPL-	STD-
STD-	SPL-

Date:	Response Units:
STD-	SPL-
SPL-	STD-
STD-	SPL-

B. Becton
Analyst B. Becton



Scott Specialty Gases

1750 EAST CLUB BOULEVARD, DURHAM, NC 27704

(919) 220-0803 FAX: (919) 220-0808

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
Entropy
Attn: John Maxwell
Research Division
8724 Glenwood Avenue
Raleigh, NC 27612

Assay Laboratory
Scott Specialty Gases, Inc.
1750 East Club Boulevard
Durham, NC 27704

Purchase Order 5051-MXWELJ
Scott Project # 12-14198

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol Procedure #G1, issued September, 1993.

Cylinder Number AAL-18203
Cylinder Pressure 2000 PSIG

Certification Date 10-16-95
Previous Certification None

Expiration Date 10-16-98

ANALYZED CYLINDER

Components

Carbon Dioxide
Oxygen
Nitrogen

Certified Concentration

17.33 %
20.12 %

Analytical Uncertainty*

+/- 1% NIST Directly Traceable
+/- 1% NIST Directly Traceable
Balance

Do not use when cylinder pressure is less than 150 PSIG.

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type **Expiration Date**
NIRM # 18000 12-96
NIRM # 2659 11-96

Cylinder Number
ALM-047691
ALM-031720

Concentration
17.95% CO2 Balance in N2
20.72% O2 Balance in N2

INSTRUMENTATION

Instrument/Model/Serial #
Varian /3400/0160
Varian /3400/16804

Last Date Calibrated
09-19-95
10-06-95

Analytical Principle
Gas Chromatography
Gas Chromatography

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

First Triad Analysis

Second Triad Analysis

Calibration Curve

Carbon Dioxide

Date: 10-16-95 Response Units: Area
STD-3125609 SPL-3037381
SPL-3046850 STD-3171492
STD-3154008 SPL-3045314

Date: Response Units:
STD- SPL-
SPL- STD-
STD- SPL-

Date: 09-19-95

Oxygen

Date: 10-16-95 Response Units: Area
STD-551721 SPL-536386
SPL-535741 STD-551695
STD-552421 SPL-535367

Date: Response Units:
STD- SPL-
SPL- STD-
STD- SPL-

Date: 10-06-95

Date: Response Units:
STD- SPL-
SPL- STD-
STD- SPL-

Date: Response Units:
STD- SPL-
SPL- STD-
STD- SPL-

B. Becton
Analyst B. Becton

INTERFERENCE RESPONSE

Analyzer Type.....TECO 10 NOX EEI#14
Serial number.....10S-52956-294

Span..... 100
Date.....6/16/95

Gas Type	Concentration	Analyzer response	(a) % of span
CO/N2	30.0 ppm	0.000	0.0000
SO2/N2	89.8 ppm	0.000	0.0000
CO2/N2	0.11 %	0.000	0.0000
O2/N2	20.9 %	0.000	0.0000

INTERFERENCE TEST PROCEDURES

ENTROPY followed the manufacturer's recommended set-up procedures contained in the analyzer manual. After the initial set-up procedures were completed, the electronics of the monitor were adjusted according to the manufacturer's guidelines. The monitor was calibrated by flowing NO calibration gases into the instrument. The SO2, CO, CO2 and O2 calibration gases listed above were injected into the monitor and the responses were recorded with a data aquisition system, which was analyzed to determine if the gases caused interference (ie. deviations from a zero reading) in the NOx monitor.

Note: This is a summary of the data collected, all corresponding data will be provided upon request.

INTERFERENCE RESPONSE

Analyzer Type.....TECO MODEL 48 CO
 Serial number.....48-40957-264
 EEI#..... 8

Span..... 1000
 Date.....1/29/93

Gas Type	Concentration	Analyzer response	(a) % of span
NOx/N2	247.0 ppm	0.000	0.0000
SO2/N2	246.0 ppm	0.000	0.0000
CO2/N2	10.85 %	0.000	0.0000
O2/N2	20.5 %	0.000	0.0000
(b) Totals			0.0000

(a) % of span = ANALYZER RESPONSE/INSTRUMENT SPAN X 100

(b) SPECIFICATION (EPA METHODS MANUAL FOR COMPLIANCE WITH BIF REGULATION 2.1.6.4.2.2). CO ANALYZER RESPONSE MUST BE LESS THAN 1% OF THE APPLICABLE MEASUREMENT RANGE.

INTERFERENCE TEST PROCEDURES

ENTROPY followed the manufacturer's recommended set-up procedures contained in the analyzer manual. After the initial set-up procedures were completed, the electronics of the monitor were adjusted according to the manufacturer's guidelines. The monitor was calibrated by flowing CO calibration gases into the instrument. The SO2, NOx, CO2 and O2 calibration gases listed above were injected into the monitor and the responses were recorded with a data acquisition system, which was analyzed to determine if the gases caused interference (ie. deviations from a zero reading) in the NOx monitor.

NOTE: This is a summary of the data collected. All supporting data is available upon request.

INTERFERENCE RESPONSE

Analyzer Type.....TELEDYNE 320P-4
 Serial number.....101233
 EEI #.....8

Span..... 25 %
 Date.....3\15\90

Gas Type	Concentration	Analyzer response	(a) % of span
CO/N2	246.0 ppm	0.000	0.0000
SO2/N2	449.0 ppm	0.000	0.0000
NO/N2	747.0 ppm	0.000	0.0000
CO2/N2	9.9 %	0.000	0.0000
(b) Totals			0.0000

(a) % of span = ANALYZER RESPONSE/INSTRUMENT SPAN X 100

(b) SPECIFICATION (EPA METHOD 20): SUM OF INTERFERENCE RESPONSES MUST NOT EXCEED 2% OF SPAN.

INTERFERENCE TEST PROCEDURES

ENTROPY followed the manufacturer's recommended set-up procedures contained in the analyzer manual. After the initial set-up procedures were completed, the electronics of the monitor were adjusted according to the manufacturer's guidelines. The monitor was calibrated by flowing O2 calibration gases into the instrument. The SO2, CO, NOx and CO2 calibration gases listed above were injected into the monitor and the responses were recorded with a data acquisition system, which was analyzed to determine if the gases caused interference (ie. deviations from a zero reading) in the O2 monitor.

NO2-NO CONVERSION EFFICIENCY

Analyzer Type.....TECO 10 NOX EEI#14
Serial number.....10S-52956-294

Span..... 500
Date.....11-06-95

PEAK RESPONSE RECORDED DURING CONVERTER EFFICIENCY TEST..... 264.4 ppm
RESPONSE RECORDED AT THE END OF THE 30-MINUTE TEST..... 260.5 ppm
PERCENT DECREASE FROM PEAK RESPONSE..... 1.48 %
CONVERTER EFFICIENCY..... 98.5 %

SPECIFICATIONS (EPA METHOD 20): RESPONSE AT 30 MINUTES MUST NOT
DECREASE BY MORE THAN 2% OF THE PEAK RESPONSE VALUE.

NO2-NO CONVERTER EFFICIENCY TEST PROCEDURES

ENTROPY followed the manufacturer's recommended set-up procedures contained in the analyzer manual. After the initial set-up procedures were completed, the electronics of the monitor were adjusted according to the manufacturer's guidelines. The monitor was then calibrated by flowing NO calibration gases into the instrument. A calibration gas was then diluted (1:1) with purified compressed air. The gas mixture was routed through a manifold into a Tedlar bag, which was previously leak tested and evacuated. This arrangement afforded sufficient volume to allow the sampling system to operate for the required 30 minutes. Immediately after the bag was filled, the manifold was connected to the sampling system. The system was turned on and the analyzer response was recorded on a data acquisition system. The one minute averages from the data acquisition system was analyzed for the peak response and the response at the end of the 30-minute sampling period.

APPENDIX D. PROCESS DATA

DATA SHEET

Date: 4-10-96

#3 Boiler

Stack Test No. 2

Fuel/Process: GAS

Trial No.:

SOx

NOx

Part:

Firing Rate: Full

Time	Steam Production (Lbs) ^{x1000}				Fuel Usage (GPM or MCF) /	Steam Press Gas Meter	Drum Press Gauge Plate
	SO ₂	Exh Temp	Boiler out Exh Temp	Lbs/Hr			
10:00 A.M.	1.4	334.3	739	79.8	97	174.6	191.7
10:10	1.4	334.9	740	79.7	96.7	175.3	192.4
10:20	1.4	336.4	739	79.7	96.9	175.1	192.2
10:30	1.4	337.1	740	79.7	96.8	175.6	192.6
10:40	1.4	337.3	739	80	96.1	175.3	192.5
10:50	1.3	336.9	740	80.2	96.3	175.6	192.8
11:00	1.4	336.8	740	81	96.1	176.2	193.3
11:10	1.5	338.6	740	80	96.9	174.4	191.7
11:20	1.5	339	740	80.1	96	175.8	193.2
11:30	1.5	338.3	739	80.1	96.6	175.3	192.4
11:40	1.3	337.3	740	80.2	95.8	175.8	192.9
11:50	1.3	337.5	739	80.4	96	175.6	192.8
12:00	1.4	337.2	740	80.2	96.2	175.6	192.6
12:10	1.3	335.3	739	79.7	96.2	175.1	192.3
12:20	1.4	336.4	739	80.3	95.9	176.5	193.5
12:30	1.5	335.8	739	80.1	95.8	175.9	192.9
12:40	1.4	337	738	79.9	95.9	176	193.1
12:50	1.4	336.6	739	80.4	96.4	174.7	191.8
1:00	1.4	335.5	738	80.3	96.5	174.8	191.9
1:10	1.4	336	739	80.1	96.1	175.5	192.1
1:20	1.4	336.3	739	80.0	96.1	175.2	192.2

DATA SHEET

Date:

4-10-96

#2 Boiler

Back Test No.

3

Fuel/Process:

GAS

Serial No.:

SOx

NOx

Part.

Firing Rate:

Full

Time	Steam Production (lbs) $\times 1000$				Fuel Usage (GPM or (NCF))	Steam Press Gas Meter	Drum Press Oilfield Gauge
	20 ₂	Exh Temp	Exh Temp	Lbs/Hr			
3:05	1.4	311.1	618	79.8	91.5	175.2	191.3
3:15	1.4	311.4	618	79	91.5	175.9	192
3:25	1.5	310.3	619	78.7	92.2	174.4	190.5
3:35	1.3	310.3	620	79.5	91.5	175.9	192.1
3:45	1.4	311.1	619	78.9	91.6	175.9	192.1
3:55	1.4	310.6	619	78.4	92.0	175.5	191.6
4:05	1.3	310.2	620	79.2	91.5	176.8	192.9
4:15	1.4	310.9	621	79.8	91.7	175.1	191.3
4:25	1.4	310.0	619	78.8	92.0	175.1	191.2
4:35	1.5	310.7	619	78.9	91.9	174.9	191.2
4:45	1.3	311.1	620	79.5	91.5	175.7	192.1
4:55	1.4	311.2	620	79.2	92.1	174.7	190.9
5:05	1.4	310.9	621	79.4	91.6	175.0	191.2
5:15	1.4	310.8	620	78.7	92.0	175.3	191.3
5:25	1.5	311.5	620	78.7	91.7	175.3	191.4
5:35	1.4	311.5	619	78.7	91.7	175.1	191.2
5:45	1.4	311.8	620	79.7	91.7	174.7	190.8
5:55	1.4	311.1	620	79.6	91.8	175.2	191.2
6:05	1.4	310.3	620	78.7	91.8	175.8	191.8
6:15	1.4	309.9	621	79.6	91.5	175.6	191.9
6:25	1.4	310.4	620	78.7	92.1	175.1	191.2

DATA SHEET

#2 Boiler

Date: 4-1-96

Back Test No. 1

Fuel/Process: oil

Serial No.:

SOx

NOx

Part.

Firing Rate: Full

Time	Steam Production (Lbs) * 1000				Fuel Usage (GPM) or MCF / lb/min	Steam Press Gas Meter	Boiler Drum Orifice Plate
	20, Sek Temp	Drum Temp	Out Temp	Lbs/Hr			
8:15	2.8	305.8	603	78.1	88.8 lb/min	175.4	191.4
8:25	2.8	305.6	603	78	88.7	175.9	191.8
8:35	2.8	304.8	601	78	88.3	174.6	190.5
8:45	2.8	305.3	602	78.2	88.6	174.2	190.2
8:55	2.8	306.5	604	78.1	88.9	175.6	191.7
9:05	2.8	305.9	602	78.3	88.5	176	192.1
9:15	2.8	305.1	602	78.5	89	174.8	190.9
9:25	2.9	305.7	603	78.4	88.3	175	191.1
9:35	2.8	305.4	602	78.1	88.8	175.4	191.3
9:45	2.8	303.6	602	77.1	88.4	175.5	191.6
9:55	2.9	303.6	603	77.9	88.4	175.1	190.9
10:05	2.8	303.9	602.1	78.2	88.9	175.2	191.1
10:15	2.8	304	602	77.4	89	175.5	191.4
10:25	2.8	305.3	602	78	88.5	175.4	191.3
10:45	2.8	305.5	603	78.1	88.7	175.2	191.2
10:55	2.8	306.6	602	79	88.9	174.2	190.4
11:05	2.8	307.2	603	78.7	88.8	175	191.3
11:15	2.8	307.8	602	78.4	88.7	174.2	190.3
11:25	2.8	308.1	603	78.3	88.9	175.6	191.6
11:35	2.8	308.2	603	78.6	89.0	175.2	191.2
11:45	2.8	306.1	604	77.8	88.7	175.9	191.9

$$GPM = (lb/min) (7.26 lb/gal)$$

DATA SHEET

Date: 4-11-96

Stack Test No. 2

Fuel/Process: Oil

Trial No.:

SOx

NOx

Part.

Firing Rate: Full

16/min

Time	Steam Production (Lbs)				Fuel Usage (GPM or MCF) / 16/min	Steam Press	Boiler Drum
	20.2	Stack Temp	Boiler Temp	Lbs/Hr		Gas Meter	Orifice plate
2:30	3.1	318.8	698	78.7	87.6	174.6	191.7
2:40	3.0	318.5	696	78.8	87.6	175.3	192.3
2:50	3.1	318.6	697	77.7	87.9	174.5	191.2
3:00	2.8	318.3	696	72.8	88.1	174.5	191.3
3:10	3.1	318.9	697	79.4	88.1	173.4	190.5
3:20	3.0	318.7	697	78.4	87.8	175.8	192.6
3:30	3.0	318.7	696	78.7	87.6	175.6	193.3
3:40	3.0	319.3	699	78.7	87.7	174.9	191.8
3:50	3.2	319.5	699	79.0	87.5	174.7	191.8
4:00	2.9	320.1	702	79.0	87.8	176.6	193.7
4:10	2.7	318.9	698	79.4	87.7	175.7	192.8
4:20	2.7	317.8	695	78.2	87.9	176.8	193.6
4:30	2.6	317.4	695	78.5	87.6	175.0	191.9
4:40	2.7	317.6	695	79.0	88.1	175.6	192.5
4:50	2.6	317.5	695	78.7	87.9	175.8	192.8
5:00	2.3	316.6	694	78.9	88.4	175.3	192.3
5:10	2.2	316.7	695	80.0	87.9	173.6	190.7
5:20	2.3	316.1	695	78.7	87.3	175.7	192.4
5:30	2.2	315.7	691	78.9	87.9	174.9	191.9
5:40	2.4	314.7	689	79.4	87.5	175.0	192.0
5:50	2.6	315.9	691	78.0	87.9	174.5	193.2