

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section: 1.3

Background Chapter 4

Reference: 20

Title: Trace emissions from coal and oil combustion

ER Krishnan

Environmental Progress Vol. 1 no.4

November 1982

LITERATURE CITED

1. Burnett, T. A. and K. D. Anderson, "Technical Review and Economic Evaluation of Spray Dryer FGD Systems," report prepared for U.S.E.P.A., August, 1980. (Also presented in part at Sixth FGD Symposium, Houston, Texas, October, 1980).
2. Hurst, T. B., "Dry Scrubbing Eliminates Wet Sludge," Joint Power Generation Conference, Charlotte, N.C., October, 1979.
3. Downs, W., W. J. Sanders, and C. E. Miller, "Control of SO₂ Emission By Dry Scrubbing," American Power Conference, Chicago, Ill., April, 1980.
4. Hurst, T. B. and G. T. Bielawski, "Dry Scrubber Demonstration Plant—Operating Results," Sixth F.G.D. Symposium, Houston, Texas, October, 1980.
5. Parsons, E. L., Jr., L. F. Hemenway, O. T. Kragh, and T. G. Brna, "SO₂ Removal by Dry F.G.D.," Sixth F.G.D. Symposium, Houston, Texas, October, 1980.
6. Parsons, E. L., Jr. *et al.*, "Waste Disposal from Dry FGD," Symposium, Orlando, Fla., February, 1981.
7. Kelly, M. E. and J. C. Dickerman, "Current Status of Dry Flue Gas Desulfurization Systems," Sixth F.G.D. Symposium, Houston, Texas, October, 1980.
8. Ahman, Stefan, Tom Lillestolen, and James Farrington, Jr., "Flakt's Dry F.G.D. Technology: Capabilities and Experience," Sixth F.G.D. Symposium, Houston, Texas, October, 1980.
9. Argonne National Laboratory, RFP No. 80-19-007 (June, 1980).
10. Stevens, N. J., "Dry SO₂ Scrubbing Pilot Test Results," Sixth F.G.D. Symposium, Houston, Texas, October, 1980.
11. Gehri, D. C., R. L. Adams, and H. Phelan, "Sequential Removal of Sulfur Oxides from Hot Gases," U.S. Patent 4,197,278 (April 8, 1980).
12. Brna, T. G., S. J. Lutz, and J. A. Kezerle, "Performance Evaluation of an Industrial Spray Dryer for SO₂ Control," Sixth F.G.D. Symposium, Houston, Texas, October, 1980.
13. Bergmann, Lutz, "Fiber/Fabric Selection for SO₂ Dry Removal Baghouse Systems," *Power Engineering*, 86-88 (October, 1980).



Section 4, Reference 95

tion, he consults with TVA on spray dryer scrubber development. He received his degrees at Rice and Princeton Universities. Previously he has been a faculty member at Tulane, Yale, and Prairie View A & M Universities and he has worked for the Department of Energy. He is a member of AIChE and APCQA.



Russell F. Robards graduated from Bellarmine College in Louisville, KY in 1974 with a BA in chemistry. Since that time he has worked with the Tennessee Valley Authority as a Chemical Engineer on various gaseous emission control projects including coal gasification, pilot and prototype FGD testing, full-scale FGD evaluations, and economics.



William L. Wells is currently program manager of Gaseous Emission Control in the Environmental Control and Assessment Branch, Office of Power, at Tennessee Valley Authority in Chattanooga, TN. Before assuming his present position, he was Chemical Engineer and Projects Manager with involvement in SO₂, NO₂, and particulate control technologies for flue gas cleanup. He has also served as TVA representative on both EPA and EPRI technical committees. He has degrees in both Chemistry and Chemical Engineering and is a Registered Professional Engineer in S.C. His professional affiliations include American Institute of Chemical Engineers, American Chemical Society, The Royal Society of Chemistry, and National Society of Professional Engineers.

NOTICE: This Material
may be protected by copyright
law. (Title 17 U.S. Code)

Trace Emissions from Coal and Oil Combustion

How real is the threat from trace emissions of metals and organics? Here are experimentally based national estimates.

E. Radha Krishnan, PEDCo Environmental, Inc., Cincinnati, Ohio 45246
G. Vinson Hellwig, PEDCo Environmental, Inc., Durham, N.C. 27001

Due to the need of national energy self-sufficiency and increasing energy demands in the United States, coal is supplanting imported oil as a fuel supply. Combustion of coal and oil results in varying quantities of trace pollutant emissions, many of which may be harmful to human health.

The U.S. Environmental Protection Agency is currently engaged in a program to assess the environmental, economic, and energy impacts of stationary conventional processes firing coal, oil, and other fuels [1]. The program focuses on the assessment of trace pollutants in the gaseous emission streams from conventional combustion sources.

This article presents background information on atmospheric emissions of certain trace metals and hazardous pollutants from coal and oil combustion based on a review of the existing literature.

The following four principal categories of conventional stationary combustion systems are analyzed in this summary:

- Utility boilers
- Industrial boilers
- Commercial/institutional boilers
- Residential boilers

A minimum size of 264 GJ/hr (250×10^6 Btu/hr) heat input was selected for the utility category in accordance with EPA's guidelines for New Source Performance Standards (NSPS). The industrial category includes both indus-

trial and commercial boilers with a minimum heat input of 26 GJ/hr (25×10^6 Btu/hr) while those with capacities below 26 GJ/hr (25×10^6 Btu/hr) are included in the commercial/institutional category. Residential boilers studied had a maximum size of 422 MJ/hr (0.4×10^6 Btu/hr) heat input.

The boiler categories are further divided into sub-categories according to a classification scheme based on fuel type and firing technique, as shown in Table 1. The choice of the various categories is based on representativeness and data availability of boiler population and emissions.

PRIORITIZATION OF TRACE POLLUTANTS

Several trace elements and organic species have received individual attention in the literature with regard to the environmental and health impacts of their emission from coal- and oil-fired plants. In order to limit the number of trace pollutants considered in this study, a preliminary prioritization technique was employed using the following criteria for selection of pollutants:

- Known or suspected carcinogens
- Substances listed by EPA as hazardous to human health
- Elements preferentially enriched in the fly ash as compared to the bottom ash
- Elements showing pronounced concentration trends with decreasing particle size

Based on the above considerations, the following list of pollutants comprising 10 trace metals and 4 organic species was developed.

Trace Metals

1. Arsenic (As)
2. Beryllium (Be)
3. Cadmium (Cd)
4. Chromium (Cr)
5. Lead (Pb)
6. Manganese (Mn)

TABLE 1. COMBUSTION SOURCE CATEGORIES

Category	Fuel type	Firing type
Utility	Bituminous coal	Pulverized dry bottom Pulverized wet bottom Cyclone Stoker
	Anthracite coal	Pulverized dry bottom Stoker
	Lignite coal	Pulverized dry bottom Pulverized wet bottom Cyclone Stoker
	Residual oil	Tangential Wall
Industrial	Coal (all types)	Pulverized Stoker
	Residual oil	Tangential Wall
	Distillate oil	Tangential Wall
Commercial/institutional	Coal (all types)	Pulverized Stoker
	Residual oil	Tangential Wall
	Distillate oil	Tangential Wall
Residential	Bituminous coal	All types
	Anthracite coal	All types
	Lignite coal	All types
	Distillate oil	All types

7. Mercury (Hg)
8. Nickel (Ni)
9. Selenium (Se)
10. Vanadium (V)

Organic Species

1. Benzo(a)pyrene (BaP)
2. Dioxins
3. Formaldehyde (HCHO)
4. Polycyclic organic matter (POM)

Among the trace metals, arsenic, beryllium, cadmium, chromium, and mercury are either known or suspected carcinogenic agents [2, 3]. With respect to organic emissions, a number of POM compounds have also been identified as active carcinogens. It should be noted that BaP is listed separately from POM even though BaP is a POM compound, since analysis is generally specific for BaP and reported emission data for other POM compounds are sparse by comparison [4]. Formaldehyde has been listed as a suspected carcinogen in the literature [3], and is therefore included in the list of trace pollutants. The acute toxic nature which has been reported [5] for a number of dioxin isomers supports the inclusion of dioxins in the trace pollutant list.

Arsenic, cadmium, chromium, lead, nickel, and selenium have been found to have a tendency to preferentially concentrate in the fly ash from coal-fired plants [6]. The above elements in addition to beryllium, manganese, and vanadium, show pronounced concentration trends with decreasing particle size. This is an important consideration since pollutants present in respirable particulates may pose an environmental hazard. Principal trace elements in oil include cadmium, chromium, nickel, and vanadium [7].

EXISTING EMISSIONS DATA BASE

An extensive literature search was conducted to obtain emissions data for the 14 trace pollutants from the combustion source categories described earlier. Available data and statistical reports from Federal Government agencies, e.g., Bureau of Census, Bureau of Mines, Bureau of Domestic Commerce, National Institute of Health, etc., were surveyed. Other significant sources of information included the Combustion Emissions Analysis Catalog System, computerized data bases, technical papers and reports by trade organizations, such as the Electric Power Research Institute. A concentrated effort was made to assess the trace emissions in terms of the type of particulate control device employed. Decisions as to the adequacy of the existing data base involved a consideration of both the reliability and variability of the data.

A brief discussion of the emissions data base is presented below for each of the four boiler categories.

Utility Boilers

Despite the widespread application of control devices, particulate emissions from utility boilers still pose a significant environmental problem, accounting for approximately 25 percent of the total particulate emissions from all stationary sources [8]. The literature is abundant in emissions data for the trace pollutants from bituminous coal-fired boilers equipped with electrostatic precipitators and from uncontrolled residual oil-fired utility boilers. Relatively less information, though, is available on trace emissions from lignite-firing, while data on emissions from anthracite-firing sources are almost nonexistent. For coal combustion in general, the data base characterizing gaseous emissions primarily represents sources equipped with electrostatic precipitators for pulverized and cyclone-fired boilers, and multicyclone-equipped stoker units. Trace

emissions data are seldom available for oil-fired boilers equipped with particulate control devices.

Industrial Boilers

The existing trace emissions data base for industrial boilers is inadequate, particularly for coal-fired units. Most of the existing data on coal-firing is for bituminous coal pulverized units equipped with multicyclones or scrubbers, and for stoker units equipped with multicyclones. No data on dioxin emissions, though, were found.

In the case of oil-firing, the data base covers uncontrolled as well as scrubber-equipped units.

Commercial/Institutional Boilers

The data base on commercial/institutional boilers is similarly limited for trace emissions; all reported data are for uncontrolled emissions.

Residential Boilers

Available literature contains extensive data on trace organic emissions, with the exception of dioxins, from both coal- and oil-fired residential units. The variability in the data, however, is significant since these emissions vary widely depending on boiler combustion efficiency. Data on trace metal emissions from residential units, though, are relatively sparse.

EMISSION FACTORS

Based on a review of the existing emissions data base and employing engineering judgement where needed, emission factors were estimated for the trace pollutants from the various combustion-source categories, as a function of particulate control device. The emission factor estimates for utility, industrial, commercial/institutional, and residential boilers are presented in Tables 2 through 5. As with all emission factors, these are only general estimators of the actual emissions and could vary widely from plant to plant.

Importance was given to the reliability of reported emissions data in estimating the emission factors. Average trace-element removal efficiencies reported in the literature were used where emissions were unavailable for certain control devices. Since emissions data on anthracite coal-fired emissions from utility boilers were unavailable in the literature, emission factors estimated for bituminous coals were assumed to apply for anthracite coals too. The type of oil used, residual or distillate, was not generally specified for industrial boilers, and hence estimated emission factors could not be delineated for the two oil types for this category.

For the utility category, flue gas emissions of arsenic, chromium, lead, manganese, nickel, and vanadium from bituminous coal-fired boilers are relatively high. Due to high emissions of arsenic, cadmium, nickel, and vanadium from residual oil-fired utility boilers, these pollutants warrant special concern. POM and BaP emissions are considerably lower for both coal- and oil-fired utility boilers; formaldehyde emissions are somewhat high for coal-fired utility boilers. Although dioxin emissions appear to be insignificant from combustion sources, additional emissions data on dioxins would be required to confirm the reported emission factor.

In the industrial category, trace metals comprising arsenic, chromium, lead, nickel, selenium, and vanadium are emitted at the highest concentrations in flue-gas streams from coal-fired boilers. For oil-fired boilers, arsenic, cadmium, chromium, nickel, and vanadium have high emission factors. POM emissions are generally low for both coal- and oil-fired industrial sources.

Emissions of all the selected trace metals and organic compounds, with the exception of beryllium, cadmium, and mercury, appear to be considerably high from stoker-fired commercial boilers. Significant quantities of POM, BaP, and formaldehyde are also emitted from these sources. For oil-fired combustion, arsenic, cadmium, chromium, nickel, and vanadium are emitted in substantial quantities.

The seven trace metals with a high level of emissions from commercial coal-fired boilers also have the highest emission factors for residential coal-fired boilers. POM and BaP emissions are very high due to the poor combustion efficiency of such units. For residential oil-fired units, nickel and formaldehyde are the only trace pollutants which are emitted in high concentrations.

FUEL CONSUMPTION FOR COMBUSTION SOURCE CATEGORIES

In order to quantify emissions of trace pollutants on a national basis, fuel (coal and oil) consumptions for the various combustion-source categories were estimated based on existing boiler population and fuel use data. The most reliable and current available information was used.

Fuel consumption estimates for utility, industrial, commercial/institutional, and residential boilers are presented in Tables 6 and 7. Utility boilers account for about 90% of the total coal consumption for the four categories. Combustion of bituminous coal represents 88% of the utility coal combustion, pulverized dry bottom units being the predominant furnace type. The utility category is responsible for about 66% of total residual-oil consumption, the remainder being shared almost equally between the industrial and commercial categories. The residential boiler category is the largest consumer of distillate oil (64%), followed by the commercial/institutional category (27%).

CONTROL-DEVICE POPULATION FOR EXISTING BOILERS

The national trace emissions from coal and oil combustion depend on the extent and type of particulate control employed in existing boilers, since control devices influence pollutant emission factors considerably. Comprehensive data on control-device population are, however, not readily available for the various categories.

Utility Boilers

Electrostatic precipitators (ESP) constitute the most popular type of control device employed for utility boilers firing pulverized coal [11]. ESP's also control over 83% of the capacity of cyclone-fired boilers using bituminous coal [12]. Wet scrubbers and baghouses are employed to a much lesser extent. Multicyclones are extensively employed on stoker units and on lignite-fired cyclone units. Utility oil-fired boilers typically do not utilize particulate controls [13], and it has been estimated the only 20% of such units are equipped with particulate control devices [14].

For the present study, the following simplifying assumptions were made regarding the control-device population for utility boilers (1978):

- All pulverized coal units are equipped with ESP's
- All stoker units are equipped with multicyclones
- All cyclone units firing bituminous coal are equipped with ESP's; lignite-fired cyclone units are equipped with multicyclones for 80% of their capacity, and with ESP's for the remaining 20%
- Oil-fired units are uncontrolled for 80% of their capacity, and equipped with ESP's for the remaining 20%.

TABLE 2. EMISSION FACTORS FOR TRACE POLLUTANTS FROM COAL- AND OIL-FIRED COMBUSTION: UTILITY BOILERS
(>264 GJ/hr INPUT)

Fuel type	Furnace type	Control device	Emission factor, pg/J														
			As	Be	Cd	Cr	Hg	Mn	Ni	Pb	Se	V	Di-oxins	HCHO	POM	BaP	
Bituminous coal	Pulverized dry bottom	ESP	15.3	2.1	0.8	60.2*	7.7	41.3	30.1	39.1	13.0	39.4	0.01	59.3	1.0	0.03	
		Multicyclones		6.9			7.7							59.3	1.2	0.03	
		Scrubber	5.3	0.3	1.7	170	1.5	48.2	22.1	10.4	16.3	62.8					
		None	133	23.7	8.9	1505	7.7	98.0	130	537	161	110					
	Pulverized wet bottom	ESP	12.4	1.7	0.6	49.0	7.7	33.5	24.3	31.0	10.5	32.3	0.01	35.3	1.0	0.08	
		Multicyclones		5.6			7.7							35.3	1.0	0.08	
		Scrubber		0.2			1.5										
		None		18.9			7.7										
	Cyclone	ESP	3.0	0.6	0.3	8.0	7.7	26.1	2.0	5.0	1.4	30.1	0.01	56.8	1.0	0.08	
		Multicyclones		1.2			7.7										
		Scrubber		0.7			46.0	2.1	54.2		33.0	30.0					
		None		4.0			7.7	98.0	130								
	Stoker	Multicyclones	206	5.6	5.5	16.3	6.0	47.3	29.2	610	36.1	24.9	0.01	37.4	0.9	0.09	
		None		18.1			6.0							60.2			
		ESP	15.3	2.1	0.8	60.2	7.7	41.3	30.1	39.1	13.0	39.8	0.01	59.3	1.0	0.06	
Anthracite coal	Pulverized dry bottom	Multicyclones	206	5.6	5.5	16.3	6.0	47.3	29.2	610	36.1	24.9	0.01	37.4	1.2	0.10	
		ESP	6.8	0.6	0.3	26.5	10.3	18.1	13.2	2.5	5.7	17.5	0.01	56.8	1.1	0.07	
		Multicyclones		15.1	3.2		10.3										
		Scrubber		0.3			2.1										
	Pulverized wet bottom	None		64.5			10.3										
		ESP	5.5	0.5	0.3	21.6	10.3	14.7	10.7	2.0	4.6	14.2	0.01	35.3	1.2	0.09	
		Multicyclones		120	3.0	9.8	430	10.3	711	320	154	3.4	291	0.01	78.3	1.1	0.09
		Scrubber		0.2			2.1										
	Cyclone	None		55.9			10.3										
		ESP	6.7	0.3	0.7	17.8	10.3	57.2	4.5	11.2	3.1	233	0.01	56.8	1.1	0.09	
		Multicyclones		120	3.0	9.8	430	10.3	711	320	154	3.4	291	0.01	78.3	1.1	0.09
		Scrubber		0.2			2.1										
	Stoker	None		24.1			2.4										
		ESP	9.5	0.6	14.4	5.7	0.9	2.2	57.2	4.0	2.0	3-3			10.8	0.04	
		Scrubber		0.02			0.2										
		None		47.3	2.3	71.8	28.6	0.9	11.0	287	20.0	10.1	1516		10.8	0.09	0.02
Residual oil	Tangential	ESP	9.5	0.6	14.4	5.7	0.9	2.2	57.2	4.0	2.0	3-3					
		Scrubber		0.02			0.2										
		None		47.3	2.3	71.8	28.6	0.9	11.0	287	20.0	10.1	1516		10.8	0.09	0.02
		None		47.3	2.3	71.8	28.6	0.9	11.0	287	20.0	10.1	1516		10.8	0.09	
	Wall	ESP	9.5	0.6	14.4	5.7	0.9	2.2	57.2	4.0	2.0	303					
		Scrubber		0.02			0.2										
		None		47.3	2.3	71.8	28.6	0.9	11.0	287	20.0	10.1	1516		10.8	0.09	
		None		47.3	2.3	71.8	28.6	0.9	11.0	287	20.0	10.1	1516		10.8	0.09	

*Not detected.

TABLE 3. EMISSION FACTORS FOR TRACE POLLUTANTS FROM COAL- AND OIL-FIRED COMBUSTION: INDUSTRIAL BOILERS
(>26 GJ/hr INPUT)

Fuel type	Furnace type	Control device	Emission factor, pg/J													
			As	Be	Cd	Cr	Hg	Mn	Ni	Pb	Se	V	Di-oxins	HCHO	POM	BaP
Coal	Pulverized	ESP					7.7									
		Multicyclones	280	6.5	2.7	71.8	7.7	29.4	39.0	161	48.6	33.0		38.7	9.5	0.03
		Scrubber	92.0	1.0	0.4	54.2	1.6	6.3	26.0	8.8	41.0	24.0		24.1	ND*	ND*
		None	21.5	8.9		7.7										
	Stoker	Multicyclones	206	5.6	5.5	16.3	22.4	47.3	29.2	121	36.1	24.9		60.2	13.2	0.03
		None	482	18.1	12.9	38.3	6.0	11.0	68.4	282	84.3	58.1		94.6	31.0	0.06
		Scrubber	9.4	0.3	21.0	5.7	0.2	1.3	62.8	4.1	2.0	260		63.6	ND*	ND*
		None	47.3	1.9	71.8	28.6	0.9	6.5	314	20.4	10.1	1300		86.0	0.5	0.13
Oil	Tangential	Scrubber	9.4	0.3	21.0	5.7	0.2	1.3	62.8	4.1	2.0	26		63.6	ND*	ND*
		None	47.3	1.9	71.8	28.6	0.9	6.5	314	20.4	10.1	1300		86.0	0.8	0.2
	Wall	Scrubber	9.4	0.3	21.0	5.7	0.2	1.3	62.8	4.1	2.0	26				
		None	47.3	1.9	71.8	28.6	0.9	6.5	314	20.4	10.1	1300				

Industrial Boilers

The extent of particulate control employed in industrial boilers depends, to a great extent, on the size of the boiler. Large pulverized coal industrial boilers are often equipped with fine particulate control devices, while multicyclones are the only form of control devices employed in smaller units [15]. Stoker-fired units also employ multicyclones in some cases, but are usually uncontrolled. In the case of oil-firing, control is rarely employed, except possibly for the larger residual oil-fired boilers.

The control-device population postulated in the current study for different size ranges of industrial boilers is shown in Table 8. Estimates of fuel consumption for the various size ranges are available in Reference 10.

Commercial/Institutional Boilers

Air pollution-control equipment is generally not installed on smaller commercial/institutional units [16]. It was assumed for this study that such sources are totally uncontrolled.

TABLE 4. EMISSION FACTORS FOR TRACE POLLUTANTS FROM COAL- AND OIL-FIRED COMBUSTION: COMMERCIAL BOILERS (<26 GJ/hr INPUT)

Fuel type	Furnace type	Control device	Emission factor, pg/J													
			As	Be	Cd	Cr	Hg	Mn	Ni	Pb	Se	V	Di-oxins	HCHO	POM	BaP
Coal	Pulverized	None		9.1		7.8									19.1	
Residual oil	Stoker	None	482	18.1	12.9	38.3	6.2	111	68.4	282	84.3	58.1		163	45.2	4.7
	Tangential	None	47.3	0.1	71.8	50.0	0.9	6.5	804	20.4	10.1	3660		86.0	44.0	0.4
Distillate oil	Wall	None		47.3	0.1	71.8	50.0	0.9	6.5	804	20.4	10.1	3660	86.0	44.0	0.4
	Tangential	None		47.3	0.1	71.8	36.0	0.9	6.5	112	20.4	10.1	30.0	86.0	20.0	0.4
	Wall	None		47.3	0.1	71.8	36.0	0.9	6.5	112	20.4	10.1	30.0	86.0	20.0	0.4

TABLE 5. EMISSION FACTORS FOR TRACE POLLUTANTS FROM COAL- AND OIL-FIRED COMBUSTION: RESIDENTIAL BOILERS (<422 MJ/hr INPUT)

Fuel type	Furnace type	Control device	Emission factor, pg/J													
			As	Be	Cd	Cr	Hg	Mn	Ni	Pb	Se	V	Di-oxins	HCHO	POM	BaP
Bituminous coal	All	None	717	7.2	17.9	71.8	7.2	2150	71.8	359	143	71.8		43.0	1737	108
Anthracite coal	All	None	166	6.6	6.6	66.2	6.6	66.2	66.2	265	99.3	66.2		43.0	1032	108
Lignite coal	All	None	430	1.7	1.7	17.2	172	430	17.2	172	51.6	34.4		43.0	8600	108
Distillate oil	All	None	1.5	1.9	11.0	1.1	1.2	0.6	103	9.5	2.9	10.1		262	10.3	0.1

TABLE 6. FUEL CONSUMPTION IN UTILITY BOILERS, U.S., 1978^a
Fuel consumption, PJ

Pulverized	Pulverized	Bituminous		Coal		Anthracite		Lignite		All coal		Residual oil				
		dry	wet	Cy-	clone	Pul-	verized	Pul-	verized	dry	wet	Cy-	clone	Stoker	Total	
		bottom	bottom	clone	Stoker	Total	verized	Stoker	Total	bottom	bottom	clone	Stoker	Total	Total	
		7558	1242	711	19	9530	6	6	12	1100	140	19	13	1272	10814	1738
														Wall	1904	3642

^aBased on data in Reference [9].

TABLE 7. FUEL CONSUMPTION, U.S.

Category	Fuel consumption, PJ				
	Coal	Pulverized	Stoker	Oil	
	Pulverized	Stoker	Total	Residual Distillate Total	
Industrial ^a	343	612	955	967	288 1255
Commercial/institutional ^a		207	207	891	897 1788
Residential ^b		113			2097 2097

^aBased on data in Reference [10], 1977.

^bBased on data in Reference [9], 1978.

Residential Boilers

Residential coal- and oil-fired units were assumed to be uncontrolled.

NATIONAL EMISSIONS

From a knowledge of fuel consumption and particulate control-device population for the various boiler categories, national emissions of the trace pollutants were estimated for coal and oil combustion sources, based on emission factors presented earlier. Results are summarized in Table 9.

Trace Metals

As would be expected, national emissions of trace metals are highest for the utility sector. Arsenic, chromium, lead, manganese, nickel, selenium, and vanadium are emitted at rates greater than 100 metric tons/yr from utility coal-fired boilers. Only arsenic and lead are emitted at such rates from industrial coal-fired boilers. These two metals are also emitted in significant quantities from commercial and residential coal-fired boilers. In addition, national emissions of manganese are considerably high for residential coal-fired units.

TABLE 8. POSTULATED CONTROL DEVICE POPULATION FOR INDUSTRIAL BOILERS

Size range, GJ/h	Pulverized coal	Stoker coal	Residual oil	Distillate oil
26-53	100 _M	50 _M 50 _U	100 _U	100 _U
53-106	80 _M 20 _S	70 _M 30 _U	100 _U	100 _U
106-264	60 _M 40 _S	80 _M 20 _U	80 _M 20 _S	100 _U
>264	100 _S	100 _M	60 _M 40 _S	100 _U

*Numbers represent the percentage of the total capacity and suffix denotes the type of control employed. M - Multicyclones, U - Uncontrolled, S - Scrubbers, e.g., 100_M means that 100% of the capacity is controlled by multicyclones.

TABLE 9. NATIONAL EMISSIONS OF TRACE POLLUTANTS FROM COAL AND OIL COMBUSTION
(metric tons/yr)

Trace pollutant	Utility boilers ^a (>264 GJ/hr input)		Industrial boilers ^b (>26 GJ/hr input)		Commercial boilers ^b (<26 GJ/hr input)		Residential boilers ^b (<422 MJ/hr input)	
	Coal	Oil	Coal	Oil	Coal	Oil	Coal	Oil
Arsenic (As)	149.1	144.7	214.8	54.7	99.3	84.6	60.3	3.2
Beryllium (Be)	19.2	7.0	6.2	2.2	3.7	0.1	0.8	4.1
Cadmium (Cd)	7.7	219.7	4.9	83.9	2.7	128.4	1.6	23.1
Chromium (Cr)	561.3	87.5	33.3	33.1	7.9	76.8	7.8	2.3
Lead (Pb)	360.0	61.1	113.3	23.6	58.2	36.5	36.8	19.9
Manganese (Mn)	407.2	33.7	31.5	7.5	22.8	11.6	163.9	1.2
Mercury (Hg)	86.9	3.1	4.6	1.0	1.3	1.5	1.0	2.5
Nickel (Ni)	281.1	877.3	34.0	363.1	14.1	818.0	7.8	216.4
Selenium (Se)	120.9	30.9	44.4	11.7	17.4	18.1	14.5	21.2
Vanadium (V)	390.0	4637	29.4	1505	12.0	3293	7.8	6.1
Benzo-a-pyrene (BaP)	0.5	0.1	0.1	0.2	1.0	0.8	12.2	0.2
Dioxins	0.1	ND	ND	ND	ND	ND	ND	ND
Formaldehyde (HCHO)	603.2	39.1	51.6	105.2	33.7	153.8	4.9	550.1
POM	11.2	0.3	11.6	0.8	9.3	57.4	171.6	21.6
a-1978. b-1977. ND-Not determined.								

For oil-firing, trace-metal emissions of arsenic, cadmium, nickel, and vanadium are substantial from utility, industrial, and commercial boilers. Vanadium emissions exceed 1000 metric tons/yr from each of the three categories. For residential oil-fired boilers, nickel is the only trace metal emitted at a significant rate.

Organic Emissions

POM and BaP emissions are only significant from residential coal-fired units. Formaldehyde emissions exceed 100 metric tons/yr for utility coal-fired boilers and industrial and commercial oil-fired boilers. Owing to lack of data, national emissions of dioxins could not be projected for most of the boiler categories.

SUMMARY

In summary, coal combustion emits significant quantities of a greater number of trace pollutants than does oil combustion. Ongoing risk assessment studies will provide a greater insight into the hazards posed by such pollutants. Meanwhile, emissions data on toxic pollutants, such as dioxins, is required for the various boiler sectors to fill gaps in the existing emissions data base.

LITERATURE CITED

1. Ponder, W. H., "Conventional Combustion Environmental Assessment Program," presented at Joint Symposium on Stationary Combustion NO_x Control, Denver, Colo., October 6-9, 1980.
2. Edwards, L. O., C. A. Muela, R. E. Sawyer, C. M. Thompson, D. H. Williams, and R. D. Delleney. "Trace Metals and Stationary Conventional Combustion Sources," Vol. I. Technical Report, EPA-600/7-80-155a (August, 1980).
3. U.S. Department of Health, Education and Welfare, "Suspected Carcinogens" 2nd Edition, HEW Publication No. (NIOSH) 77-149 (December, 1976).
4. U.S. Environmental Protection Agency, "Scientific and Technical Assessment Report on Particulate Polycyclic Organic Matter (PPOM)," EPA-600/6-75-001 (March, 1975).
5. Esposito, M. P., T. O. Tiernan, and F. E. Dryden. "Dioxins," EPA-600/2-80-197 (November, 1980).
6. Ray, S. S. and F. G. Parker, "Characterization of Ash from Coal-Fired Power Plants," EPA-600/7-77-010 (January, 1977).
7. Magee, E. M., H. J. Hall, and G. M. Varga, Jr. "Potential Pollutants in Fossil Fuels," EPA-R2-73-249 (June, 1973).
8. Shih, C. C., R. A. Orsini, D. G. Ackerman, R. Moreno, E. L. Moon, L. L. Scinto, and C. Yu. "Emissions Assessment of Conventional Stationary Combustion Systems: Volume III. External Combustion Sources for Electricity Generation - Project Summary," EPA-600/S7-81-003a (April, 1981).
9. U.S. Department of Energy, "State Energy Data Report Statistical Tables and Technical Documentation 1960 through 1978," DOE/EIA-0214(78) (April, 1980).
10. Devitt, T., P. Spaite, and L. Gibbs. "Population and Characteristics of Industrial/Commercial Boilers in the U.S.," EPA-600/7-79-178a (August, 1979).
11. DeAngelis, D. G., R. B. Reznick, D. S. Ruffin, J. N. Rigano, W. R. McCurley, J. C. Ochsner, and T. W. Hughes. "Source Assessment: Dry Bottom Utility Boilers Firing Pulverized Bituminous Coal - Project Summary," EPA-600/S2-80-042C (January, 1981).
12. Leavitt, C., K. Arledge, C. Shih, R. Orsini, A. Saur, W. Hamersma, R. Maddalone, R. Beimer, G. Richard, S. Unge, and M. Yamada. "Environmental Assessment of a Coal-Fired Controlled Utility Boiler," EPA-600/7-80-086 (April, 1980).
13. Leavitt, C., K. Arledge, C. Shih, R. Orsini, A. Saur, W. Hamersma, R. Maddalone, R. Beimer, G. Richard, S. Unge, and M. Yamada. "Environmental Assessment of an Oil-Fired Controlled Utility Boiler," EPA-600/7-80-087 (April, 1980).
14. Suprenant, N., R. Hall, S. Slater, T. Susa, M. Sussman, and C. Young, "Preliminary Emissions Assessment of Conventional Stationary Combustion Systems: Vol. II. Final Report," EPA-600/2-76-046b (March, 1976).
15. PEDCo Environmental, Inc., Cincinnati, Ohio. "Summary of Status of Industrial Boilers and Air Pollution Compliance Problems and Solutions. Phase I," prepared for U.S. Environmental Protection Agency (March, 1980).
16. Suprenant, N. F., P. Hung, R. Li, K. T. McGregor, W. Piispainen, and S. M. Sandberg. "Emissions Assessment of Conventional Stationary Combustion Systems: Vol. IV. Commercial/Institutional Combustion Sources - Project Summary," EPA-600/S7-81-003b (April, 1981).