

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.



METCO
ENVIRONMENTAL
P.O. Box 598
Addison, TX 75001
(214) 931-7127

**SOURCE EMISSIONS SURVEY
OF
FIRESTONE SYNTHETIC
RUBBER & LATEX COMPANY
BOILER EB-114 EXHAUST STACK
TACB PERMIT R-2565
ORANGE, TEXAS**

NOVEMBER 1990

FILE NUMBER 90-22

RECEIVED

DEC 16 1990

**REGION 10
TEXAS AIR CONTROL BOARD**

Company Name Firststone Rubber & Latex Co. TACB Account No. _____
City Orange County Orange TACB Region 10

Testing required by: TACB Permit

TACB Permit No. R-2565

PSD Permit No. _____

NSPS Subpart _____

(INCLUDE A COPY OF PERMIT SPECIAL PROVISIONS)

Source Tested Boiler EB-114 TACB E. I. Point No. EB-114
Stack Height 45 feet Stack Diameter 4 feet 10 1/8 inches

Sampling Ports Location:

Downstream Distance to Obstruction 6 feet 6 inches

Upstream Distance to Obstruction 7 feet 10 1/2 inches

Checked for Cyclonic Flow? X Yes No

Cyclonic Flow Present? Yes X No

(INCLUDE A DRAWING OF STACK SHOWING SAMPLING PORTS AND MEASUREMENTS)

Design Operating Rate _____ Maximum Operating Rate _____

Normal Operating Rate _____ Operating Schedule _____

TACB Test Observer _____

TABLE OF CONTENTS

	PAGE
INTRODUCTION	1
SUMMARY OF RESULTS	2
DISCUSSION OF RESULTS	11
DESCRIPTION OF SAMPLING LOCATION	12
SAMPLING AND ANALYTICAL PROCEDURES	14
DESCRIPTION OF TESTS	18
APPENDICES	20
A. Location of Sampling Points	
B. Source Emissions Calculations	
C. Calibration Data	
D. Field Testing Data	
E. Oxides of Nitrogen Monitor Data	
F. Carbon Monoxide Monitor Data	
G. Total Hydrocarbons Monitor Data	
H. Plant Operational Data	
I. TACB Permit	
J. Resumes of Test Personnel	

**SOURCE EMISSIONS SURVEY
FIRESTONE SYNTHETIC RUBBER & LATEX COMPANY
BOILER EB-114 EXHAUST STACK
TACB PERMIT R-2565
ORANGE, TEXAS
FILE NUMBER 90-22**

INTRODUCTION

METCO Environmental, Dallas, Texas, conducted a source emissions survey of Firestone Synthetic Rubber & Latex Company located in Orange, Texas, on November 5, 6, 7, 8, and 9, 1990. The purpose of these tests was to determine the concentrations of oxides of nitrogen, carbon monoxide, and total hydrocarbons being emitted to the atmosphere via the exhaust stack of Boiler EB-114 under different operating conditions.

The sampling followed the procedures set forth in the Appendix to the Code of Federal Regulations, Title 40, Chapter I, Part 60, Methods 1, 2, 3, 4, 7E, 10, and 25A, and in the "Sampling Procedures Manual, Texas Air Control Board, January 1983."

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack

Condition		Steam Load (lbs/hr)	Fuel	Run Number	Oxides of Nitrogen Emissions (ppm) (lbs/hr)	Carbon Monoxide Emissions (ppm) (lbs/hr)	Hydrocarbons Emissions as Propane (ppm) (lbs/hr)	Total
I	Gas	30,000		1	140	5	<0.5	<0.02
				2	133	5	2.0	0.09
				3	135	5	<0.5	<0.02
				Average	136	5	<1.0	<0.04
		90,000		4	162	35	4.0	0.55
				5	161	35	3.5	0.45
				6	161	35	3.0	0.38
				Average	161	35	3.5	0.46
II	Gas & Stream 1	30,000		1	280	5	<0.5	<0.03
				2	140	<5	<0.5	<0.02
				3	155	<5	<0.5	<0.02
				Average	192	<5	<0.5	<0.02
		70,000		4	132	5	2.0	0.20
				5	134	12	2.0	0.22
				6	134	20	2.5	0.27
				Average	133	12	2.2	0.23
Allowable Emission Rate				36.6	13.97		0.19	

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack

<u>Condition</u>	<u>Fuel</u>	<u>Steam Load</u> <u>(lbs/hr)</u>	<u>Run Number</u>	<u>Oxides of Nitrogen Emissions</u> <u>(ppm) (lbs/hr)</u>	<u>Carbon Monoxide Emissions</u> <u>(ppm) (lbs/hr)</u>	<u>Total Hydrocarbons Emissions as Propane</u> <u>(ppm) (lbs/hr)</u>
III	Gas & Stream 3	70,667	1	78	20	1.0
			2	113	15	0.5
			3	96	12	1.5
				10.2	0.8	0.15
			Average	96	16	1.0
				10.5	1.1	0.10
		30,000	4	87	12	3.5
			5	85	15	2.5
			6	60	20	3.5
				3.5	0.7	0.20
			Average	77.3	16	3.2
				4.5	0.6	0.18
IV	Gas & Stream 2	72,000	1	88	13	1.0
			2	97	8	0.5
			3	95	5	0.05
				10.0	0.3	<0.05
			Average	93	9	<0.7
				10.0	0.5	<0.07
Allowable Emission Rate				36.6	13.97	0.19

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack Condition I

Run Number	1	2	3
Date	11/6/90	11/6/90	11/6/90
Time	0850-0950	1030-1130	1145-1245
Stack Flow Rate - ACFM	11,250	10,955	10,649
Stack Flow Rate - DSCFM*	6,541	6,450	6,299
% Water Vapor - % Vol.	18.75	17.72	17.18
% CO ₂ - % Vol.	9.5	9.0	9.5
% O ₂ - % Vol.	2.5	2.0	2.5
% Excess Air @ Sampling Point	12	9	12
Stack Temperature - °F	283	283	284
Stack Pressure - "Hg	30.00	30.00	30.00
Oxides of Nitrogen Emissions - ppm	140	133	135
Oxides of Nitrogen Emissions - lbs/hr	6.6	6.1	6.1
Carbon Monoxide Emissions - ppm	5	5	5
Carbon Monoxide Emissions - lbs/hr	0.1	0.1	0.1
Total Hydrocarbons Emissions as Propane - ppm	<0.5	2.0	<0.5
Total Hydrocarbons Emissions as Propane - lbs/hr	<0.02	0.09	<0.02
Production Rate Steam Load - lbs/hr	30,000	30,000	30,000

* 29.92 "Hg, 68°F (760 mm Hg, 20°C)

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack Condition I

Run Number	4	5	6
Date	11/6/90	11/6/90	11/6/90
Time	1542-1642	1700-1800	1810-1910
Stack Flow Rate - ACFM	37,025	35,809	35,631
Stack Flow Rate - DSCFM*	19,929	18,909	18,322
% Water Vapor - % Vol.	16.65	17.34	18.43
% CO ₂ - % Vol.	9.3	8.0	8.3
% O ₂ - % Vol.	2.8	2.5	3.1
% Excess Air @ Sampling Point	14	12	15
Stack Temperature - °F	366	375	386
Stack Pressure - "Hg	30.11	30.11	30.11
Oxides of Nitrogen Emissions - ppm	162	161	161
Oxides of Nitrogen Emissions - lbs/hr	23.1	21.8	21.1
Carbon Monoxide Emissions - ppm	35	35	35
Carbon Monoxide Emissions - lbs/hr	3.0	2.9	2.8
Total Hydrocarbons Emissions as Propane - ppm	4.0	3.5	3.0
Total Hydrocarbons Emissions as Propane - lbs/hr	0.55	0.45	0.38
Production Rate Steam Load - lbs/hr	90,000	90,000	90,000

* 29.92 "Hg, 68°F (760 mm Hg, 20°C)

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack Condition II

Run Number	1	2	3
Date	11/7/90	11/7/90	11/7/90
Time	0905-1005	1020-1120	1136-1236
Stack Flow Rate - ACFM	13,678	12,050	11,418
Stack Flow Rate - DSCFM*	8,101	7,268	6,830
% Water Vapor - % Vol.	16.30	15.03	16.11
% CO ₂ - % Vol.	9.5	9.8	9.5
% O ₂ - % Vol.	3.2	2.8	3.0
% Excess Air @ Sampling Point	16	14	15
Stack Temperature - °F	294	292	289
Stack Pressure - "Hg	30.14	30.14	30.14
Oxides of Nitrogen Emissions - ppm	280	140	155
Oxides of Nitrogen Emissions - lbs/hr	16.2	7.3	7.6
Carbon Monoxide Emissions - ppm	5	<5	<5
Carbon Monoxide Emissions - lbs/hr	0.2	<0.2	<0.1
Total Hydrocarbons Emissions as Propane - ppm	<0.5	<0.5	<0.5
Total Hydrocarbons Emissions as Propane - lbs/hr	<0.03	<0.02	<0.02
Production Rate Steam Load - lbs/hr	30,000	30,000	30,000

* 29.92 "Hg, 68°F (760 mm Hg, 20°C)

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack Condition II

Run Number	4	5	6
Date	11/7/90	11/7/90	11/7/90
Time	1412-1512	1522-1622	1630-1730
Stack Flow Rate - ACFM	25,500	26,921	26,484
Stack Flow Rate - DSCFM*	14,845	15,816	15,511
% Water Vapor - % Vol.	13.76	14.06	14.31
% CO ₂ - % Vol.	11.2	11.6	11.8
% O ₂ - % Vol.	3.3	3.0	3.3
% Excess Air @ Sampling Point	17	15	17
Stack Temperature - °F	330	320	320
Stack Pressure - "Hg	30.11	30.11	30.11
Oxides of Nitrogen Emissions - ppm	132	134	134
Oxides of Nitrogen Emissions - lbs/hr	14.0	15.2	14.9
Carbon Monoxide Emissions - ppm	5	12	20
Carbon Monoxide Emissions - lbs/hr	0.3	0.8	1.4
Total Hydrocarbons Emissions as Propane - ppm	2.0	2.0	2.5
Total Hydrocarbons Emissions as Propane - lbs/hr	0.20	0.22	0.27
Production Rate Steam Load - lbs/hr	70,000	70,000	70,000

* 29.92 "Hg, 68°F (760 mm Hg, 20°C)

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack Condition III

Run Number	1	2	3
Date	11/8/90	11/8/90	11/8/90
Time	0846-0946	1002-1105	1120-1220
Stack Flow Rate - ACFM	29,079	26,988	26,609
Stack Flow Rate - DSCFM*	16,113	15,306	14,801
% Water Vapor - % Vol.	15.38	14.05	15.85
% CO ₂ - % Vol.	11.4	11.2	11.4
% O ₂ - % Vol.	2.8	3.0	3.0
% Excess Air @ Sampling Point	14	15	15
Stack Temperature - °F	351	344	341
Stack Pressure - "Hg	29.99	29.95	29.90
Oxides of Nitrogen Emissions - ppm	78	113	96
Oxides of Nitrogen Emissions - lbs/hr	9.0	12.4	10.2
Carbon Monoxide Emissions - ppm	20	15	12
Carbon Monoxide Emissions - lbs/hr	1.4	1.0	0.8
Total Hydrocarbons Emissions as Propane - ppm	1.0	0.5	1.5
Total Hydrocarbons Emissions as Propane - lbs/hr	0.11	0.05	0.15
Production Rate Steam Load - lbs/hr	70,667	70,667	70,667

* 29.92 "Hg, 68°F (760 mm Hg, 20°C)

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack Condition III

Run Number	4	5	6
Date	11/8/90	11/8/90	11/8/90
Time	1307-1407	1417-1517	1530-1630
Stack Flow Rate - ACFM	13,538	14,408	13,977
Stack Flow Rate - DSCFM*	7,916	8,405	8,248
% Water Vapor - % Vol.	16.60	16.77	16.19
% CO ₂ - % Vol.	9.6	9.6	10.2
% O ₂ - % Vol.	3.0	3.0	3.5
% Excess Air @ Sampling Point	15	15	18
Stack Temperature - °F	293	293	290
Stack Pressure - "Hg	29.80	29.80	29.80
Oxides of Nitrogen Emissions - ppm	87	85	60
Oxides of Nitrogen Emissions - lbs/hr	4.9	5.1	3.5
Carbon Monoxide Emissions - ppm	12	15	20
Carbon Monoxide Emissions - lbs/hr	0.4	0.6	0.7
Total Hydrocarbons Emissions as Propane - ppm	3.5	2.5	3.5
Total Hydrocarbons Emissions as Propane - lbs/hr	0.19	0.14	0.20
Production Rate Steam Load - lbs/hr	30,000	30,000	30,000

* 29.92 "Hg, 68°F (760 mm Hg, 20°C)

SUMMARY OF RESULTS

Boiler EB-114 Exhaust Stack Condition IV

Run Number	1	2	3
Date	11/9/90	11/9/90	11/9/90
Time	0800-0905	0915-1015	1024-1124
Stack Flow Rate - ACFM	27,238	27,363	26,522
Stack Flow Rate - DSCFM*	14,890	15,207	14,628
% Water Vapor - % Vol.	16.26	14.67	15.04
% CO ₂ - % Vol.	10.4	11.0	11.4
% O ₂ - % Vol.	2.8	2.9	2.6
% Excess Air @ Sampling Point	14	15	13
Stack Temperature - °F	348	350	353
Stack Pressure - "Hg	29.79	29.79	29.79
Oxides of Nitrogen Emissions - ppm	88	97	95
Oxides of Nitrogen Emissions - lbs/hr	9.4	10.6	10.0
Carbon Monoxide Emissions - ppm	13	8	5
Carbon Monoxide Emissions - lbs/hr	0.8	0.5	0.3
Total Hydrocarbons Emissions as Propane - ppm	1.0	0.5	<0.5
Total Hydrocarbons Emissions as Propane - lbs/hr	0.10	0.05	<0.05
Production Rate Steam Load - lbs/hr	72,000	72,000	72,000

* 29.92 "Hg, 68°F (760 mm Hg, 20°C)

DISCUSSION OF RESULTS


The three tests for oxides of nitrogen, carbon monoxide, and total hydrocarbons taken at each of the seven operating conditions appeared to be valid representations of the actual emissions during the tests.

The indicative parameters calculated from the field data were in close agreement. The variations in moisture percentages from the mean value at each operating condition were less than 6.9 percent. The variations in the measured flow rates (Q_m) from the mean value at each operating condition were less than 9.5 percent.

DESCRIPTION OF SAMPLING LOCATION

The sampling location on the stack is approximately 39 feet above the ground. The sampling ports are located 7 feet 10 1/2 inches (1.63 stack diameters) downstream from the inlet to the stack and 6 feet 6 inches (1.34 stack diameters) upstream from the outlet of the stack.

SAMPLING LOCATION



SAMPLING AND ANALYTICAL PROCEDURES

The sampling followed the procedures outlined in the Appendix to the Code of Federal Regulations, Title 40, Chapter I, Part 60, Methods 1, 2, 3, 4, 7E, 10, and 25A, and in the "Sampling Procedures Manual, Texas Air Control Board, January 1983."

A velocity traverse was made at each of the two ports on the stack, in order to determine the uniformity and magnitude of the flow during each test. All traverse points were checked for cyclonic flow and the average angle of cyclonic flow was equal to 2.1 degrees. Eight traverse points were sampled from each of the two ports for a total of sixteen traverse points.

On all tests, the moisture sampling train was leak-checked at the nozzle at 15 inches of mercury vacuum before each test, and leak-checked at the nozzle after each test at the highest vacuum reading recorded during the test. This was done to predetermine the possibility of a diluted sample.

Also before and after each test, the pitot tube lines were checked for leaks under both a vacuum and a pressure. The lines were also checked for clearance and the manometer was zeroed before each test.

The "front-half" of the moisture sampling train consisted of a heated, glass-lined probe and a heated filter. The "back-half" of the sampling train contained the following impingers:

<u>Impinger Number</u>	<u>Contents</u>	<u>Amount</u>	<u>Parameter Collected</u>
1	Deionized Water	100 ml	Moisture
2	Deionized Water	100 ml	Moisture
3	Empty	-----	Moisture
4	Silica Gel	200 g	Moisture

An integrated orsat sample was taken during each test and analyzed according to EPA Method 3.

For all of the gas sampling, the gas was drawn continuously through a stainless steel probe into a dry impinger to condense moisture. The sample was then drawn through a teflon sample line and delivered to the monitors. A Thermo Electron Model 10S Chemiluminescent NO-NO₂-NO_x

Analyzer was used for the Method 7E sampling. The analyzer was operated at ranges of 0 to 250 parts per million and 0 to 1,000 parts per million.

The following calibration gases were used to calibrate the monitor:

Zero Nitrogen

49.6 ppm NO in N₂ (BAL 4381)

124.3 ppm NO in N₂ (ALM 5430)

229.1 ppm NO in N₂ (CAL 3086)

The carbon monoxide samples were taken and analyzed according to EPA Method 10 using both the integrated and continuous sampling procedures.

The samples were analyzed on a Thermo Electron Model 48 Carbon Monoxide Analyzer operated at ranges of 0 to 500 parts per million and 0 to 1,000 parts per million. The calibration gases were as follows:

Zero Nitrogen

29.6 ppm CO in N₂ (CAL 12581)

49.4 ppm CO in N₂ (CAL 9911)

499.5 ppm CO in N₂ (CAL 1606)

894.3 ppm CO in N₂ (CAL 11768)

The total hydrocarbons samples were taken and analyzed according to EPA Method 25A. The samples were analyzed on a Ratfisch Model RS55 Total Hydrocarbon Analyzer. The analyzer was operated at a range of 0 to 100 parts per million using the following calibration gases:

Zero Nitrogen

9.9 ppm C_3H_8 in N_2 (CAL 9194)

51.3 ppm C_3H_8 in N_2 (CAL 10045)

91.8 ppm C_3H_8 in N_2 (CLM 2304)

Calibration gas certifications are included in Appendix C.

DESCRIPTION OF TESTS

Personnel from METCO Environmental arrived at the plant at 1:30 p.m. on Monday, November 5, 1990. After meeting with plant personnel and obtaining a vehicle entry permit, the sampling van was parked at the base of the Boiler EB-114 Exhaust Stack. The sampling equipment was moved onto the stack and the monitors were set up in the sampling van. All work was completed at 5:30 p.m.

On Tuesday, November 6, work began at 7:00 a.m. The sampling equipment was prepared for testing and the monitors were calibrated. The first test for oxides of nitrogen, carbon monoxide, and total hydrocarbons at the first condition began at 9:11 a.m. Testing continued without interruption until the completion of the sixth test at 7:00 p.m. The monitors were calibrated and all work was completed at 8:30 p.m.

On Wednesday, November 7, work began at 7:00 a.m. The first test for oxides of nitrogen, carbon monoxide, and total hydrocarbons at the second condition began at 9:05 a.m. Testing continued without interruption until the completion of the sixth test at 5:30 p.m. The monitors were calibrated and all work was completed at 6:00 p.m.

On Thursday, November 8, work began at 7:00 a.m. The equipment was prepared for testing and the monitors were calibrated. The first test for oxides of nitrogen, carbon monoxide, and total hydrocarbons at the third condition began at 8:46 a.m. Testing continued without interruption until the completion of the sixth test at 4:30 p.m. The monitors were calibrated and all work was completed at 5:00 p.m.

On Friday, November 9, work began at 6:00 a.m. The equipment was prepared for testing and the monitors were calibrated. Testing was delayed due to plant operational problems. The first test for oxides of nitrogen, carbon monoxide, and total hydrocarbons at the fourth condition began at 8:00 a.m. Testing continued without interruption until the completion of the third test at 11:24 a.m. Plant personnel decided not to run the low load condition on the fourth fuel.

The equipment was moved off of the stack and loaded into the sampling van. The monitors were calibrated and secured for transport. The data was transported to METCO Environmental's laboratory in Dallas, Texas, for further analysis and evaluation.

Operations at Firestone Synthetic Rubber & Latex Company, Boiler EB-114 Exhaust Stack, located in Orange, Texas, were completed at 1:00 p.m. on Friday, November 9, 1990.


Billy S. Mullins, Jr., P.E.
President

APPENDICES

- A. Location of Sampling Points
- B. Source Emissions Calculations
- C. Calibration Data
- D. Field Testing Data
- E. Oxides of Nitrogen Monitor Data
- F. Carbon Monoxide Monitor Data
- G. Total Hydrocarbons Monitor Data
- H. Plant Operational Data
- I. TACB Permit
- J. Resumes of Test Personnel

APPENDIX A

Location of Sampling Points

Boiler EB-114 Exhaust Stack

The sampling ports are located 7 feet 10 1/2 inches (1.63 stack diameters) downstream from the inlet to the stack and 6 feet 6 inches (1.34 stack diameters) upstream from the outlet of the stack. The locations of the sampling points were calculated as follows:


Port and Wall Thickness = 6 1/4 inches

Inside Stack Diameter = 58 1/8 inches

<u>Point Number</u>	<u>Percent of Diameter From Wall</u>	<u>Distance From Wall</u>
1	3.2	1 7/8"
2	10.5	6 1/8"
3	19.4	11 1/4"
4	32.3	18 3/4"
5	67.7	39 3/8"
6	80.6	46 7/8"
7	89.5	52 "
8	96.8	56 1/4"

APPENDIX A

Location of Sampling Points Boiler EB-114 Exhaust Stack



APPENDIX B

Nomenclature and Equations
for
Calculation of Source Emissions

Nomenclature for Particulate Calculations

<u>Symbol</u>	<u>English Units</u>	<u>Metric Units</u>	<u>Description</u>
A_s	in. ²	m ²	Stack Area
C_{an}	gr/dscf*	g/dscm*	Particulate - probe, cyclone and filter
C_{ao}	gr/dscf*	g/dscm*	Particulate - total
C_{at}	gr/CF @ stack conditions	g/m ³	Particulate - probe, cyclone and filter
C_{au}	gr/CF @ stack conditions	g/m ³	Particulate - total
C_{aw}	lbs/hr	kg/hr	Particulate - probe, cyclone and filter
C_{ax}	lbs/hr	kg/hr	Particulate - total
C_p			Pitot Tube Calibration Factor
D_n	in.	m	Sampling Nozzle Diameter
%EA			Percent Excess Air at sampling point
g	32.2 ft/sec ²		Acceleration of gravity
%I			Percent isokinetic
%M			Percent moisture in the stack gas by volume
M_d			Mole fraction of dry gas
m_f	mg	mg	Particulate - probe, cyclone and filter
M_{H_2O}	18 lb/lb-mole		Molecular Weight of Water
m_t	mg	mg	Particulate - total

* 29.92 "Hg, 528°R (760 mm Hg, 20°C)

<u>Symbol</u>	<u>English Units</u>	<u>Metric Units</u>	<u>Description</u>
MW	lb/lb-mole	g/g-mole	Molecular Weight of stack gas
MW _{air}	28.95 lb/lb-mole		Molecular Weight of air
MW _d	lb/lb-mole	g/g-mole	Molecular Weight of dry stack gas
P _b	"Hg Absolute	mm Hg	Barometric Pressure
P _m	"H ₂ O	mm H ₂ O	Orifice Pressure drop
P _s	"Hg Absolute	mm Hg	Stack Pressure
ΔP	"H ₂ O	mm H ₂ O	Velocity Head of stack gas
P _{std}	29.92 "Hg	760 mm Hg	Standard Barometric Pressure
Q _a	ACFM	m ³ /hr	Stack Gas Volume at Actual Stack Conditions
Q _s	DSCFM*	dscm/hr*	Stack Gas Volume at 29.92 "Hg, 528°R, dry
R	21.83 "Hg-ft ³ /lb-mole°R		Universal Gas Constant
T _m	°F	°C	Average Gas Meter Temperature
T _t	min	min	Net time of test
T _s	°F	°C	Stack Temperature
T _{std}	528°R	293°K	Standard Temperature
V _m	ft ³	m ³	Volume of dry gas sampled at meter conditions
V _{mstd}	dscf*	dscm*	Volume of dry gas sampled @ standard conditions
V _s	fpm	m/sec	Stack velocity @ stack conditions
V _w	ml	ml	Total Water Collected in Impingers and Silica Gel

* 29.92 "Hg, 528°R (760 mm Hg, 20°C)

<u>Symbol</u>	<u>English Units</u>	<u>Metric Units</u>	<u>Description</u>
$V_{w\text{ gas}}$	scf*	scm*	Volume of Water Vapor Collected @ standard conditions
ρ_{air}	0.0748 lbs/ft ³		Density of Air
$\rho_{\text{H}_2\text{O}}$	1 g/ml		Density of Water
ρ_{man}	51.63 lbs/ft ³		Density of Manometer Oil

Standard Conditions: 29.92 "Hg, 68°F (760 mm Hg, 20°C)

Example Particulate Calculations

1. Volume of dry gas sampled at standard conditions.*

$$V_{mstd} = V_m \left(\frac{T_{std}}{T_m + 460} \right) \left[\frac{P_b + \frac{P_m}{13.6}}{P_{std}} \right]$$

$$V_{mstd} = 17.65 V_m \left[\frac{P_b + \frac{P_m}{13.6}}{T_m + 460} \right] = \text{dscf}$$

$$V_{mstd} = \text{dscf} \times 0.028317 = \text{dscm}$$

2. Volume of water vapor collected at standard conditions.*

$$V_{wgas} = \frac{(V_w - \text{gms SO}_2 - \text{gms H}_2\text{S}) P_{\text{H}_2\text{O}} R T_{std}}{P_{std} M_{\text{H}_2\text{O}} 453.6}$$

$$V_{wgas} = 0.0472 (V_w - \text{gms SO}_2 - \text{gms H}_2\text{S}) = \text{scf}$$

$$V_{wgas} = \text{scf} \times 0.028317 = \text{scm}$$

3. Percent moisture in stack gas.

$$\%M = \frac{V_{wgas}}{V_{mstd} + V_{wgas}} \times 100 = \%$$

4. Mole fraction of dry gas.

$$M_d = \frac{100 - \%M}{100}$$

5. Average molecular weight of dry stack gas.

$$MW_d = \left[\%CO_2 \times \frac{44}{100} \right] + \left[\%O_2 \times \frac{32}{100} \right] + \left[\%N_2 \times \frac{28}{100} \right] + \left[\%CO \times \frac{28}{100} \right] = \begin{matrix} \text{lb/lb-mole} \\ \text{g/g-mole} \end{matrix}$$

6. Molecular weight of stack gas.

$$MW = MW_d \times M_d + 18 (1 - M_d) = \frac{\text{lb}}{\text{lb-mole}} = \text{g/g-mole}$$

7. Percent excess air at sampling point.

$$\%EA = \frac{100 (\%O_2 - 0.5\% CO)}{0.265 (\%N_2) - (\%O_2) + 0.5 (\%CO)}$$

8. Stack Pressure.

$$P_s = P_b + \frac{\text{stack pressure "H}_2\text{O}}{13.6} = \text{"Hg Absolute}$$

$$P_s = \text{"Hg Abs.} \times 25.4 = \text{mm Hg}$$

9. Stack velocity at stack conditions.

$$V_s = C_p \cdot 60 \left[\frac{2g \times \rho_{\text{man}} \times P_{\text{std}} \times MW_{\text{air}} \times (T_s + 460) \times \Delta P_s}{12 \times \rho_{\text{air}} \times P_s \times MW \times T_{\text{std}}} \right]^{\frac{1}{2}}$$

$$V_s = 5123.8 C_p \left[\frac{(T_s + 460) \times \Delta P_s}{P_s \times MW} \right]^{\frac{1}{2}} = \text{fpm}$$

$$V_s = \text{fpm} \times 0.00508 = \text{m/sec}$$

10. Dry stack gas volume at standard conditions.*

$$Q_s = \frac{1}{144} V_s \times A_s \times M_d \times \frac{T_{\text{std}}}{T_s + 460} \times \frac{P_s}{P_{\text{std}}}$$

$$Q_s = \frac{0.123 V_s \times A_s \times M_d \times P_s}{T_s + 460} = \text{DSCFM}$$

$$Q_s = \text{DSCFM} \times 1.6990 = \text{dscm/hr}$$

11. Actual stack gas volume at stack conditions.

$$Q_a = \frac{V_s \times A_s}{144} = \text{ACFM}$$

$$Q_a = \text{ACFM} \times 1.6990 = \text{m}^3/\text{hr}$$

12. Percent isokinetic.

$$\%I = \frac{V_{m_{std}} \times (T_s + 460) \times P_{std} \times 100 \times 144}{M_d \times T_{std} \times P_s \times T_t \times V_s \times \frac{\pi D_n^2}{4}}$$

$$\%I = \frac{1039 V_{m_{std}} \times (T_s + 460)}{M_d \times P_s \times T_t \times V_s \times D_n^2}$$

13. Particulate - probe, cyclone and filter.

$$C_{an} = \frac{m_f}{V_{m_{std}}} \times \frac{1 \text{ gr}}{64.8 \text{ mg}}$$

$$C_{an} = 0.0154 \frac{m_f}{V_{m_{std}}} = \text{gr/dscf}^*$$

$$C_{an} = \text{gr/dscf} \times 2.290 = \text{g/dscm}^*$$

14. Particulate total.

$$C_{ao} = 0.0154 \times \frac{m_t}{V_{m_{std}}} = \text{gr/dscf}^*$$

$$C_{ao} = \text{gr/dscf} \times 2.290 = \text{g/dscm}^*$$

15. Particulate - probe, cyclone and filter at stack conditions.

$$C_{at} = C_{an} \times \frac{P_s}{P_{std}} \times \frac{(T_{std})}{(T_s + 460)} \times M_d$$

$$C_{at} = \frac{17.65 \times C_{an} \times P_s \times M_d}{T_s + 460} = \text{gr/CF}$$

$$C_{at} = \text{gr/CF} \times 2.290 = \text{g/m}^3$$

16. Particulate - total, at stack conditions.

$$C_{au} = \frac{17.65 \times C_{ao} \times P_s \times M_d}{T_s + 460} = \text{gr/CF}$$

$$C_{au} = \text{gr/CF} \times 2.290 = \text{g/m}^3$$

17. Particulate - probe, cyclone and filter.

$$C_{aw} = C_{an} \times Q_s \times \frac{60 \text{ min}}{1 \text{ hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}}$$

$$C_{aw} = 0.00857 \times C_{an} \times Q_s = \text{lbs/hr}$$

$$C_{aw} = \text{lbs/hr} \times 0.4536 = \text{kg/hr}$$

18. Particulate - total.

$$C_{ax} = 0.00857 \times C_{ao} \times Q_s = \text{lbs/hr}$$

$$C_{ax} = \text{lbs/hr} \times 0.4536 = \text{kg/hr}$$

SOURCE EMISSION SURVEY

JOB NUMBER: 90-22
 JOB NAME: FIRESTONE
 LOCATION: ORANGE, TEXAS
 UNIT TESTED: EB-114 EXHAUST, CONDITION #1

SOURCE EMISSION CALCULATIONS

SYMBOL	DESCRIPTION	UNITS	1	2	3
RUN #					
DATE			11-6-90	11-6-90	11-6-90
BEGIN TIME			911	1030	1145
END TIME			941	1100	1215
IP(b)	BAROMETRIC PRESSURE	"Hg Abs. (mm Hg)	30.00 (762)	30.00 (762)	30.00 (762)
IP(m)	ORIFICE PRESSURE DROP	"H2O (mm H2O)	2.000 (50.8)	2.000 (50.8)	2.000 (50.8)
IV(m)	VOLUME DRY GAS SAMPLED @ METER CONDITIONS	ft.^3 (m^3)	22.526 (0.638)	23.208 (0.657)	23.551 (0.667)
IT(m)	AVERAGE GAS METER TEMPERATURE	DEG.F (DEG.C)	67 (19)	75 (24)	78 (26)
IV(m[std])	VOLUME DRY GAS SAMPLED @ STANDARD CONDITIONS*	DSCF (DSCM)	22.744 (0.644)	23.082 (0.654)	23.293 (0.660)
IV(w)	TOTAL WATER COLLECTED, IMPINGERS & SILICA GEL	ml	111.2	105.3	102.4
IV(w[gas])	VOLUME WATER VAPOR COLLECTED @ STANDARD CONDITIONS*	SCF (SCM)	5.249 (0.149)	4.970 (0.141)	4.833 (0.137)
%M	MOISTURE IN STACK GAS BY VOLUME	%	18.75	17.72	17.18
ITt	INET TIME OF TEST	MINUTES	30	30	30

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg)

SOURCE EMISSION CALCULATIONS

FIRESTONE
 ORANGE, TEXAS
 EB-114 EXHAUST, CONDITION #1

SYMBOL	DESCRIPTION	UNITS			
IMd	MOL FRACTION OF DRY GAS		0.8125	0.8228	0.8282
IC02	%		9.5	9.0	9.5
IO2	%		2.5	2.0	2.5
IC0	%		0.0	0.0	0.0
IN2	%		88.0	89.0	88.0
IXEA	EXCESS AIR @ SAMPLING POINT	%	12.0	9.3	12.0
IMWD	MOLECULAR WEIGHT OF DRY STACK GAS	LB/LB-MOLE (g/g-MOLE)	29.62 (29.62)	29.52 (29.52)	29.62 (29.62)
IMW	MOLECULAR WEIGHT OF STACK GAS	LB/LB-MOLE (g/g-MOLE)	27.44 (27.44)	27.48 (27.48)	27.62 (27.62)
DELTA P	VELOCITY HEAD OF STACK GAS	"H2O (mm H2O)	0.025 (0.6)	0.024 (0.6)	0.023 (0.6)
ITs	STACK TEMPERATURE	DEG. F (DEG. C)	283 (139)	283 (139)	284 (140)
IPs	STACK PRESSURE	"Hg Abs. (mm Hg)	30.00 (762)	30.00 (762)	30.00 (762)
IVs	STACK VELOCITY @ STACK CONDITIONS	FPM (m/SEC.)	611 (3.10)	595 (3.02)	578 (2.94)
IAs	STACK AREA	(SQ. INCHES) (SQ. METERS)	2,653 (1.71)	2,653 (1.71)	2,653 (1.71)
IQs	DRY STACK GAS VOLUME @ STANDARD CONDITIONS*	DSCFM (DSCM/HR)	6,541 (11,113)	6,450 (10,959)	6,299 (10,702)
IQa	ACTUAL STACK GAS VOLUME @ STACK CONDITIONS	ACFM (m^3/HR)	11,250 (19,114)	10,955 (18,613)	10,649 (18,093)

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg) B-11

SOURCE EMISSION SURVEY

JOB NUMBER: 90-22
 JOB NAME: FIRESTONE
 LOCATION: ORANGE, TEXAS
 UNIT TESTED: EB-114 EXHAUST (CONDITION #1)

SOURCE EMISSION CALCULATIONS

SYMBOL	DESCRIPTION	UNITS			
RUN #			4	5	6
DATE			11-6-90	11-6-90	11-6-90
BEGIN TIME			1604	1706	1812
END TIME			1634	1736	1842
IP(b)	BAROMETRIC PRESSURE	"Hg Abs. (mm Hg)	30.10 (765)	30.10 (765)	30.10 (765)
IP(m)	ORIFICE PRESSURE DROP	"H ₂ O (mm H ₂ O)	2.000 (50.8)	2.000 (50.8)	2.000 (50.8)
IV(m)	VOLUME DRY GAS SAMPLED @ METER CONDITIONS	ft. ³ (m ³)	24.379 (0.690)	23.612 (0.669)	24.080 (0.682)
IT(m)	AVERAGE GAS METER TEMPERATURE	DEG.F (DEG.C)	85 (29)	87 (31)	87 (31)
IV(m[std])	VOLUME DRY GAS SAMPLED @ STANDARD CONDITIONS*	DSCF (DSCM)	23.881 (0.676)	23.045 (0.653)	23.582 (0.666)
IV(w)	TOTAL WATER COLLECTED, IMPINGERS & SILICA GEL	ml	101.1	102.4	112.5
IV(w[gas])	VOLUME WATER VAPOR COLLECTED @ STANDARD CONDITIONS*	SCF (SCM)	4.772 (0.135)	4.833 (0.137)	5.310 (0.150)
%M	MOISTURE IN STACK GAS BY VOLUME	%	16.65	17.34	18.43
Itt	NET TIME OF TEST	MINUTES	30	30	30

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg)

SOURCE EMISSION CALCULATIONS

FIRESTONE
ORANGE, TEXAS
EB-114 EXHAUST (CONDITION #1)

SYMBOL	DESCRIPTION	UNITS			
IMd	IMOL FRACTION OF DRY GAS		0.8335	0.8266	0.8157
ICD2	%		9.3	8.0	8.3
IO2	%		2.8	2.5	3.1
ICD	%		0.0	0.0	0.0
IN2	%		87.9	89.5	88.6
IXEA	IXCESS AIR @ SAMPLING IPOINT	%	13.7	11.8	15.2
IMWd	IMOLECULAR WEIGHT OF IDRY STACK GAS	LB/LB-MOLE (g/g-MOLE)	29.60 (29.60)	29.38 (29.38)	29.45 (29.45)
IMW	IMOLECULAR WEIGHT OF ISTACK GAS	LB/LB-MOLE (g/g-MOLE)	27.67 (27.67)	27.41 (27.41)	27.34 (27.34)
IDELTA P	IVELOCITY HEAD OF STACK IGAS	"H2O (mm H2O)	0.244 (6.2)	0.224 (5.7)	0.219 (5.6)
ITs	ISTACK TEMPERATURE	DEG. F (DEG. C)	366 (186)	375 (191)	386 (197)
IPs	ISTACK PRESSURE	"Hg Abs. (mm Hg)	30.11 (765)	30.11 (765)	30.11 (765)
IVs	ISTACK VELOCITY @ STACK ICONDITIONS	FPM (m/SEC.)	2,010 (10.21)	1,944 (9.88)	1,934 (9.82)
IAs	ISTACK AREA	(SQ. INCHES) (SQ. METERS)	2,653 (1.71)	2,653 (1.71)	2,653 (1.71)
IQs	IDRY STACK GAS VOLUME @ ISTANDARD CONDITIONS*	DSCFM (DSCM/HR)	19,929 (33,859)	18,909 (32,126)	18,322 (31,129)
IQa	IACTUAL STACK GAS VOLUME I@ STACK CONDITIONS	ACFM (m^3/HR)	37,025 (62,985)	35,809 (60,839)	35,631 (60,537)

SOURCE EMISSION SURVEY

JOB NUMBER: 90-22
 JOB NAME: FIRESTONE
 LOCATION: ORANGE, TEXAS
 UNIT TESTED: EB-114 EXHAUST (CONDITION #2)

SOURCE EMISSION CALCULATIONS

SYMBOL	DESCRIPTION	UNITS	1	2	3
RUN #					
DATE			11-7-90	11-7-90	11-7-90
BEGIN TIME			910	1025	1130
END TIME			940	1055	1200
IP(b)	BAROMETRIC PRESSURE	"Hg Abs. (mm Hg)	30.14 (766)	30.14 (766)	30.14 (766)
IP(m)	ORIFICE PRESSURE DROP	"H2O (mm H2O)	2.000 (50.8)	2.000 (50.8)	2.000 (50.8)
IV(m)	VOLUME DRY GAS SAMPLED @ METER CONDITIONS	ft.^3 (m^3)	23.325 (0.660)	23.642 (0.669)	23.886 (0.676)
IT(m)	AVERAGE GAS METER TEMPERATURE	DEG.F (DEG.C)	76 (24)	80 (27)	84 (29)
IV(m[std])	VOLUME DRY GAS SAMPLED @ STANDARD CONDITIONS*	DSCF (DSCH)	23.263 (0.659)	23.404 (0.663)	23.472 (0.665)
IV(w)	TOTAL WATER COLLECTED, IMPINGERS & SILICA GEL	ml	96.0	87.7	95.5
IV(w[gas])	VOLUME WATER VAPOR COLLECTED @ STANDARD CONDITIONS*	SCF (SCH)	4.531 (0.128)	4.139 (0.117)	4.500 (0.128)
%M	MOISTURE IN STACK GAS BY VOLUME	%	16.30	15.03	16.11
Itt	NET TIME OF TEST	MINUTES	30	30	30

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg)

SOURCE EMISSION CALCULATIONS

FIRESTONE
ORANGE, TEXAS
EB-114 EXHAUST (CONDITION #2)

SYMBOL	DESCRIPTION	UNITS			
IMd	IMOL FRACTION OF DRY GAS		0.8370	0.8497	0.8389
IC02	%		9.5	9.8	9.5
IO2	%		3.2	2.8	3.0
ICO	%		0.0	0.0	0.0
IN2	%		87.3	87.4	87.5
IXEA	IXCESS AIR @ SAMPLING IPOINT	%	16.1	13.8	14.9
IMWd	IMOLECULAR WEIGHT OF IDRY STACK GAS	LB/LB-MOLE (g/g-MOLE)	29.65 (29.65)	29.68 (29.68)	29.64 (29.64)
IMW	IMOLECULAR WEIGHT OF ISTACK GAS	LB/LB-MOLE (g/g-MOLE)	27.75 (27.75)	27.92 (27.92)	27.76 (27.76)
IDELTA P	IVELOCITY HEAD OF STACK IGAS	"H2O (mm H2O)	0.037 (0.9)	0.029 (0.7)	0.026 (0.7)
ITs	ISTACK TEMPERATURE	DEG. F (DEG. C)	294 (146)	292 (144)	289 (143)
IPs	ISTACK PRESSURE	"Hg Abs. (mm Hg)	30.14 (766)	30.14 (766)	30.14 (766)
IVs	ISTACK VELOCITY @ STACK ICONDITIONS	FPM (m/SEC.)	742 (3.77)	654 (3.32)	620 (3.15)
IAs	ISTACK AREA	(SQ. INCHES) (SQ. METERS)	2,653 (1.71)	2,653 (1.71)	2,653 (1.71)
IQs	IDRY STACK GAS VOLUME @ ISTANDARD CONDITIONS*	DSCFM (DSCM/HR)	8,101 (13,764)	7,268 (12,348)	6,830 (11,604)
IQa	IACTUAL STACK GAS VOLUME I@ STACK CONDITIONS	ACFM (m^3/HR)	13,678 (23,239)	12,050 (20,473)	11,418 (19,399)

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg) B-15

SOURCE EMISSION SURVEY

JOB NUMBER: 90-22
 JOB NAME: FIRESTONE
 LOCATION: ORANGE, TEXAS
 UNIT TESTED: EB-114 EXHAUST (CONDITION #2)

SOURCE EMISSION CALCULATIONS

SYMBOL	DESCRIPTION	UNITS			
RUN #			4	5	6
DATE			11-7-90	11-7-90	11-7-90
BEGIN TIME			1416	1526	1633
END TIME			1446	1556	1703
IP(b)	BAROMETRIC PRESSURE	"Hg Abs. (mm Hg)	30.10 (765)	30.10 (765)	30.10 (765)
IP(m)	ORIFICE PRESSURE DROP	"H2O (mm H2O)	2.000 (50.8)	2.000 (50.8)	2.000 (50.8)
IV(m)	VOLUME DRY GAS SAMPLED @ METER CONDITIONS	ft.^3 (m^3)	23.595 (0.668)	24.263 (0.687)	24.105 (0.683)
IT(m)	AVERAGE GAS METER TEMPERATURE	DEG.F (DEG.C)	84 (29)	89 (32)	90 (32)
IV(m[std])	VOLUME DRY GAS SAMPLED @ STANDARD CONDITIONS*	DSCF (DSCM)	23.155 (0.656)	23.594 (0.668)	23.398 (0.663)
IV(w)	TOTAL WATER COLLECTED, IMPINGERS & SILICA GEL	ml	78.3	81.8	82.8
IV(w[gas])	VOLUME WATER VAPOR COLLECTED @ STANDARD CONDITIONS*	SCF (SCM)	3.696 (0.105)	3.861 (0.109)	3.908 (0.111)
%M	MOISTURE IN STACK GAS BY VOLUME	%	13.76	14.06	14.31
ITt	NET TIME OF TEST	MINUTES	30	30	30

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg)

SOURCE EMISSION CALCULATIONS

FIRESTONE
 ORANGE, TEXAS
 EB-114 EXHAUST (CONDITION #2)

SYMBOL	DESCRIPTION	UNITS			
IMd	IMOL FRACTION OF DRY GAS		0.0624	0.0594	0.0569
ICD2		%	11.2	11.6	11.8
IO2		%	3.3	3.0	3.3
ICD		%	0.0	0.0	0.0
IN2		%	85.5	85.4	84.9
IXEA	IXCESS AIR @ SAMPLING IPOINT	%	17.0	15.3	17.2
IMWd	IMOLECULAR WEIGHT OF IDRY STACK GAS	LB/LB-MOLE (g/g-MOLE)	29.92 (29.92)	29.98 (29.98)	30.02 (30.02)
IMW	IMOLECULAR WEIGHT OF ISTACK GAS	LB/LB-MOLE (g/g-MOLE)	28.28 (28.28)	28.29 (28.29)	28.30 (28.30)
IDELTA P	IVELOCITY HEAD OF STACK IGAS	"H2O (mm H2O)	0.124 (3.1)	0.140 (3.6)	0.136 (3.5)
ITs	ISTACK TEMPERATURE	DEG. F (DEG. C)	330 (166)	320 (160)	320 (160)
IPs	ISTACK PRESSURE	"Hg Abs. (mm Hg)	30.11 (765)	30.11 (765)	30.11 (765)
IVs	ISTACK VELOCITY @ STACK ICONDITIONS	FPM (m/SEC.)	1,384 (7.03)	1,461 (7.42)	1,437 (7.30)
IAs	ISTACK AREA	(SQ. INCHES) (SQ. METERS)	2,653 (1.71)	2,653 (1.71)	2,653 (1.71)
IQs	IDRY STACK GAS VOLUME @ ISTANDARD CONDITIONS*	DSCFM (DSCM/HR)	14,845 (25,222)	15,816 (26,871)	15,511 (26,353)
IQa	IACTUAL STACK GAS VOLUME I@ STACK CONDITIONS	ACFM (m³/HR)	25,500 (43,325)	26,921 (45,739)	26,484 (44,996)

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg) B-17

SOURCE EMISSION SURVEY

JOB NUMBER: 90-22
 JOB NAME: FIRESTONE
 LOCATION: ORANGE, TEXAS
 UNIT TESTED: EB-114 EXHAUST (CONDITION #3)

SOURCE EMISSION CALCULATIONS

SYMBOL	DESCRIPTION	UNITS			
IRUN #			1	2	3
DATE			11-8-90	11-8-90	11-8-90
IBEGIN TIME			850	1032	1138
IEND TIME			920	1102	1208
IP(b)	BAROMETRIC PRESSURE	"Hg Abs. (mm Hg)	29.98 (761)	29.94 (760)	29.89 (759)
IP(m)	ORIFICE PRESSURE DROP	"H2O (mm H2O)	2.000 (50.8)	2.000 (50.8)	2.000 (50.8)
IV(m)	VOLUME DRY GAS SAMPLED @ METER CONDITIONS	ft.^3 (m^3)	23.561 (0.667)	23.528 (0.666)	23.325 (0.660)
IT(m)	AVERAGE GAS METER TEMPERATURE	DEG.F (DEG.C)	73 (23)	75 (24)	78 (26)
IV(m[std])	VOLUME DRY GAS SAMPLED @ STANDARD CONDITIONS*	DSCF (DSCM)	23.505 (0.666)	23.354 (0.661)	22.985 (0.651)
IV(w)	TOTAL WATER COLLECTED, IMPINGERS & SILICA GEL	ml	90.5	80.9	91.7
IV(w[gas])	VOLUME WATER VAPOR COLLECTED @ STANDARD CONDITIONS*	SCF (SCM)	4.272 (0.121)	3.818 (0.108)	4.328 (0.123)
IXM	MOISTURE IN STACK GAS BY VOLUME	%	15.38	14.05	15.85
It	NET TIME OF TEST	MINUTES	30	30	30

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg)

SOURCE EMISSION CALCULATIONS

FIRESTONE
ORANGE, TEXAS
EB-114 EXHAUST (CONDITION #3)

SYMBOL	DESCRIPTION	UNITS			
IMd	IMOL FRACTION OF DRY GAS		0.8462	0.8595	0.8415
IC02	%		11.4	11.2	11.4
IO2	%		2.8	3.0	3.0
IC0	%		0.0	0.0	0.0
IN2	%		85.8	85.8	85.6
IXEA	EXCESS AIR @ SAMPLING POINT	%	14.0	15.2	15.2
IMWd	IMOLECULAR WEIGHT OF DRY STACK GAS	LB/LB-MOLE (g/g-MOLE)	29.94 (29.94)	29.91 (29.91)	29.94 (29.94)
IMW	IMOLECULAR WEIGHT OF STACK GAS	LB/LB-MOLE (g/g-MOLE)	28.10 (28.10)	28.24 (28.24)	28.05 (28.05)
DELTA P	VELOCITY HEAD OF STACK GAS	"H2O (mm H2O)	0.156 (4.0)	0.136 (3.5)	0.131 (3.3)
ITs	STACK TEMPERATURE	DEG. F (DEG. C)	351 (177)	344 (173)	341 (172)
IPs	STACK PRESSURE	"Hg Abs. (mm Hg)	29.99 (762)	29.95 (761)	29.90 (759)
IVs	STACK VELOCITY @ STACK CONDITIONS	FPM (m/SEC.)	1,578 (8.02)	1,465 (7.44)	1,444 (7.34)
IAs	STACK AREA	(SQ. INCHES) (SQ. METERS)	2,653 (1.71)	2,653 (1.71)	2,653 (1.71)
IQs	DRY STACK GAS VOLUME @ STANDARD CONDITIONS*	DSCFM (DSCM/HR)	16,113 (27,376)	15,306 (26,005)	14,801 (25,147)
IQa	ACTUAL STACK GAS VOLUME @ STACK CONDITIONS	ACFM (m^3/HR)	29,079 (49,405)	26,908 (45,853)	26,609 (45,209)

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg) B-19

SOURCE EMISSION SURVEY

JOB NUMBER: 90-22
 JOB NAME: FIRESTONE
 LOCATION: ORANGE, TEXAS
 UNIT TESTED: EB-114 EXHAUST (CONDITION #3)

SOURCE EMISSION CALCULATIONS

SYMBOL	DESCRIPTION	UNITS	4	5	6
RUN #					
DATE			11-8-90	11-8-90	11-8-90
BEGIN TIME			1312	1418	1535
END TIME			1342	1448	1605
IP(b)	BAROMETRIC PRESSURE	"Hg Abs. (mm Hg)	29.80 (757)	29.80 (757)	29.80 (757)
IP(m)	ORIFICE PRESSURE DROP	"H2O (mm H2O)	2.000 (50.8)	2.000 (50.8)	2.000 (50.8)
IV(m)	VOLUME DRY GAS SAMPLED @ METER CONDITIONS	ft.^3 (m^3)	23.552 (0.667)	24.389 (0.691)	23.800 (0.674)
IT(m)	AVERAGE GAS METER TEMPERATURE	DEG.F (DEG.C)	79 (26)	81 (27)	83 (28)
IV(m[std])	VOLUME DRY GAS SAMPLED @ STANDARD CONDITIONS*	DSCF (DSM)	23.096 (0.654)	23.028 (0.675)	23.167 (0.656)
IV(w)	TOTAL WATER COLLECTED, IMPINGERS & SILICA GEL	ml	97.4	101.7	94.8
IV(w[gas])	VOLUME WATER VAPOR COLLECTED @ STANDARD CONDITIONS*	SCF (SCM)	4.597 (0.130)	4.800 (0.136)	4.475 (0.127)
IXM	MOISTURE IN STACK GAS BY VOLUME	%	16.60	16.77	16.19
ITt	NET TIME OF TEST	MINUTES	30	30	30

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg)

SOURCE EMISSION CALCULATIONS

 FIRESTONE
 ORANGE, TEXAS
 EB-114 EXHAUST (CONDITION #3)

SYMBOL	DESCRIPTION	UNITS			
IMd	IMOL FRACTION OF DRY GAS		0.8340	0.8323	0.8381
IC02		%	9.6	9.6	10.2
IO2		%	3.0	3.0	3.5
ICO		%	0.0	0.0	0.0
IN2		%	87.4	87.4	86.3
I%EA	IEXCESS AIR @ SAMPLING IPOINT	%	14.9	14.9	18.1
IMWd	IMOLECULAR WEIGHT OF IDRY STACK GAS	LB/LB-MOLE (g/g-MOLE)	29.66 (29.66)	29.66 (29.66)	29.77 (29.77)
IMW	IMOLECULAR WEIGHT OF ISTACK GAS	LB/LB-MOLE (g/g-MOLE)	27.72 (27.72)	27.70 (27.70)	27.87 (27.87)
IDELTA P	IVELOCITY HEAD OF STACK IGAS	"H2O (in H2O)	0.036 (0.9)	0.040 (1.0)	0.038 (1.0)
ITs	ISTACK TEMPERATURE	DEG. F (DEG. C)	293 (145)	293 (145)	290 (143)
IPs	ISTACK PRESSURE	"Hg Abs. (in Hg)	29.80 (757)	29.80 (757)	29.80 (757)
IVs	ISTACK VELOCITY @ STACK ICONDITIONS	FPM (m/SEC.)	735 (3.73)	782 (3.97)	759 (3.86)
IAs	ISTACK AREA	(SQ. INCHES) (SQ. METERS)	2,653 (1.71)	2,653 (1.71)	2,653 (1.71)
IQs	IDRY STACK GAS VOLUME @ ISTANDARD CONDITIONS*	DSCFM (DSCM/HR)	7,916 (13,449)	8,405 (14,280)	8,248 (14,013)
IQa	IACTUAL STACK GAS VOLUME I@ STACK CONDITIONS	ACFM (m^3/HR)	13,538 (23,001)	14,408 (24,479)	13,977 (23,747)

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg) B-21

SOURCE EMISSION SURVEY

JOB NUMBER: 90-22
 JOB NAME: FIRESTONE
 LOCATION: ORANGE, TEXAS
 UNIT TESTED: EB-114 EXHAUST (CONDITION #4)

SOURCE EMISSION CALCULATIONS

SYMBOL	DESCRIPTION	UNITS	1	2	3
IRUN #			1	2	3
IDATE			11-9-90	11-9-90	11-9-90
IBEGIN ITIME			805	918	1030
IEND ITIME			835	948	1100
IP(b)	BAROMETRIC PRESSURE	"Hg Abs. (mm Hg)	29.78 (756)	29.78 (756)	29.78 (756)
IP(m)	ORIFICE PRESSURE DROP	"H2O (mm H2O)	2.000 (50.8)	2.000 (50.8)	2.000 (50.8)
IV(m)	VOLUME DRY GAS SAMPLED @ METER CONDITIONS	ft.^3 (m^3)	22.789 (0.645)	23.465 (0.664)	23.470 (0.665)
IT(m)	AVERAGE GAS METER TEMPERATURE	DEG.F (DEG.C)	73 (23)	75 (24)	77 (25)
IV(m[std])	VOLUME DRY GAS SAMPLED @ STANDARD CONDITIONS*	DSCF (DSCM)	22.584 (0.640)	23.167 (0.656)	23.086 (0.654)
IV(w)	TOTAL WATER COLLECTED, IMPINGERS & SILICA GEL	ml	92.9	84.4	86.6
IV(w[gas])	VOLUME WATER VAPOR COLLECTED @ STANDARD CONDITIONS*	SCF (SCM)	4.385 (0.124)	3.984 (0.113)	4.088 (0.116)
IXM	MOISTURE IN STACK GAS BY VOLUME	%	16.26	14.67	15.04
It	NET TIME OF TEST	MINUTES	30	30	30

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg)

SOURCE EMISSION CALCULATIONS

FIRESTONE
ORANGE, TEXAS
EB-114 EXHAUST (CONDITION #4)

SYMBOL	DESCRIPTION	UNITS			
Yd	MOL FRACTION OF DRY GAS		0.8374	0.8533	0.8496
YCO2		%	10.4	11.0	11.4
YCO		%	0.0	0.0	0.0
YN2		%	86.8	86.1	86.0
YEA	EXCESS AIR @ SAMPLING POINT	%	13.9	14.6	12.9
MWd	MOLECULAR WEIGHT OF DRY STACK GAS	LB/LB-MOLE (g/g-MOLE)	29.78 (29.78)	29.88 (29.88)	29.93 (29.93)
MW	MOLECULAR WEIGHT OF STACK GAS	LB/LB-MOLE (g/g-MOLE)	27.86 (27.86)	28.13 (28.13)	28.13 (28.13)
DELTA P	VELOCITY HEAD OF STACK GAS	"H2O (mm H2O)	0.134 (3.4)	0.137 (3.5)	0.128 (3.3)
Ts	STACK TEMPERATURE	DEG. F (DEG. C)	348 (176)	350 (177)	353 (178)
Ps	STACK PRESSURE	"Hg Abs. (mm Hg)	29.79 (757)	29.79 (757)	29.79 (757)
Vs	STACK VELOCITY @ STACK CONDITIONS	FPM (m/SEC.)	1,478 (7.51)	1,485 (7.54)	1,440 (7.32)
As	STACK AREA	(SQ. INCHES) (SQ. METERS)	2,653 (1.71)	2,653 (1.71)	2,653 (1.71)
Qs	DRY STACK GAS VOLUME @ STANDARD CONDITIONS*	DSCFM (DSCM/HR)	14,890 (25,298)	15,207 (25,837)	14,628 (24,853)
Qa	ACTUAL STACK GAS VOLUME @ STACK CONDITIONS	ACFM (m^3/HR)	27,238 (46,277)	27,363 (46,490)	26,522 (45,061)

* 68 Deg.F, 29.92 "Hg (20 Deg.C, 760 mm Hg) B-23

APPENDIX C

Calibration Data

<u>Equipment</u>	<u>Calibration Factor</u>	<u>Calibration Date</u>
Pitot Tube #5	0.799	7/13/90
Dry Gas Meter #10	1.016	7/11/90
Stack Unit Orifice #10		7/11/90
Digital Temperature Indicator #10		7/11/90
Barometer #15		8/17/90
Oxides of Nitrogen Monitor		11/ 6/90 11/ 7/90 11/ 8/90 11/ 9/90
Carbon Monoxide Monitor		11/ 6/90 11/ 7/90 11/ 8/90 11/ 9/90
Total Hydrocarbons Monitor		11/ 6/90 11/ 7/90 11/ 8/90 11/ 9/90

PITOT TUBE CALIBRATION

Date: 13 JULY 1990

Time: 1500

Pitot No. 5
5' x 1/4"

P_b: 29.46 "Hg P_s: — "H₂O
T_s: 78 °F C_{pstd}: 0.99

Motor Setting	fps mark	CALIBRATOR STANDARD		STANDARD AVERAGE	HIGH	HIGH	CAL. FACTOR	LOW	LOW	CAL. FACTOR
		START	END							
39	20	0.10	0.10	0.316	0.15	0.387	0.808	0.15	0.387	0.808
48	30	0.22	0.22	0.469	0.33	0.574	0.808	0.33	0.574	0.808
55	40	0.34	0.34	0.583	0.53	0.728	0.793	0.53	0.728	0.793
63	50	0.54	0.54	0.735	0.84	0.917	0.794	0.83	0.911	0.799
70	60	0.80	0.81	0.897	1.25	1.118	0.794	1.25	1.118	0.794
76	70	1.00	1.00	1.000	1.55	1.245	0.795	1.55	1.245	0.795
84	80	1.30	1.30	1.140	2.00	1.414	0.798	2.00	1.414	0.798
100	90	1.60	1.60	1.265	2.45	1.565	0.800	2.45	1.565	0.800
63	50	0.54	0.54	0.735	0.83	0.911	0.799	0.83	0.911	0.799
63	50	0.54	0.55	0.738	0.83	0.911	0.802	0.83	0.911	0.802
Average							0.799			0.799

Summary of Results:

Normal high side calibration factor
variation

0.799
1.13% - 0.75

Normal low side calibration factor
variation

0.799
1.13% - 0.75

Mark Glie
Signature of Calibrator

Dry Gas Meter Calibration

Dry Gas Meter Number 10Date: 11 July 1990

ΔH ("H ₂ O)	C_{DG}	
0.5	<u>1.013</u> ✓	
1.0	<u>1.014</u> ✓	
1.5	<u>1.017</u> ✓	
2.0	<u>1.018</u> ✓	
3.0	<u>1.016</u> ✓	
4.0	<u>1.015</u> ✓	
Average	<u>1.016</u> ✓	Variation: + <u>0.20 %</u> ✓ - <u>0.30 %</u> ✓

Calibrator: John PellegrineChecked by: R. Patterson C_{DG} @ 2 liters/min. = 1.016 ✓

DRY GAS METER CALIBRATION

Meter Number: 10

Calibrator: John Pellegri

Date: 11 July 1990

$$\text{Calibration Factor (C}_{\text{DG}}) = \frac{\text{Wet Test Meter } V_{\text{m std}}}{\text{Dry Gas Meter } V_{\text{m std}}}$$

Run No.: 1 at 0.50 "H₂O

P_b: 29.40 "Hg

Control Module Vacuum 5.4 "Hg

WET TEST METER (No. 2)

DRY GAS METER

	Time	Meter Reading	Temp.	P _m		Meter Reading	In	Temp.	Out	P _m
End	1017	4.976 cf	72 °F	0.90 "H ₂ O		103.686 cf	79 °F	77 °F	0.50 "H ₂ O	
Start	1005	2.000 cf	72 °F	0.90 "H ₂ O		98.743 cf	79 °F	76 °F	0.50 "H ₂ O	
	12.0	4.976 cf	72 °F	0.90 "H ₂ O		4.943 cf	79 °F	78 °F	0.50 "H ₂ O	

$$\text{Wet Test Meter } V_{\text{m std}} = 17.65 \times 4.976 \left(\frac{29.40 + \frac{-0.900}{13.6}}{72 + 460} \right) \times 0.999_{(C_f)} = 4838 \text{ dscf}$$

$$\text{Dry Gas Meter } V_{\text{m std}} = 17.65 \times 4.943 \left(\frac{29.40 + \frac{0.50}{13.6}}{78 + 460} \right) = 4.774 \text{ dscf}$$

$$C_{\text{DG}} = \frac{4.838}{4.774} = \boxed{1.013}$$

DRY GAS METER CALIBRATION

Meter Number: 10

Calibrator: John Pellegrine

Date: 11 July 1990

$$\text{Calibration Factor (C}_{\text{DG}}) = \frac{\text{Wet Test Meter } V_{\text{m std}}}{\text{Dry Gas Meter } V_{\text{m std}}}$$

Run No.: 1 at 1.00" H₂O

P_b: 29.40 "Hg

Control Module Vacuum 5.0 "Hg

WET TEST METER (No. 2)

DRY GAS METER

	Time	Meter Reading	Temp.	P _m	Meter Reading	In	Temp. Out	P _m
End	1030	5.253 cf	72 °F	-1.80 "H ₂ O	109.469 cf	80 °F	78 °F	1.00 "H ₂ O
Start	1021	0.000 cf	72 °F	-1.80 "H ₂ O	104.260 cf	80 °F	78 °F	1.00 "H ₂ O
	9.0	5.253' cf	72' °F	-1.80' "H ₂ O	5.209' cf	80 °F	78 °F	1.00' "H ₂ O
						79 ✓		

$$\text{Wet Test Meter } V_{\text{m std}} = 17.65 \times 5.253 \left(\frac{29.40 + \frac{1.80}{13.6}}{72 + 460} \right) \times 0.999_{(C_f)} = 5.096 \text{ dscf}$$

$$\text{Dry Gas Meter } V_{\text{m std}} = 17.65 \times 5.209 \left(\frac{29.40 + \frac{1.000}{13.6}}{79 + 460} \right) = 5.027 \text{ dscf}$$

$$C_{\text{DG}} = \frac{5.096}{5.027} = \boxed{1.014 \checkmark}$$

DRY GAS METER CALIBRATION

Meter Number: 10

Calibrator: John Pellegrini

Date: 11 July 1990

$$\text{Calibration Factor } (C_{DG}) = \frac{\text{Wet Test Meter } V_{m \text{ std}}}{\text{Dry Gas Meter } V_{m \text{ std}}}$$

Run No.: 1 at 1.50

P_b : 29.40 "Hg

Control Module Vacuum 5.5 "Hg

WET TEST METER (No. 2)

DRY GAS METER

	Time	Meter Reading	Temp.	P_m	Meter Reading	In	Temp.	Out	P_m
End	1047	10.524 cf	72 °F	-2.30 "H ₂ O	120.738 cf	85 °F	79 °F	1.50 "H ₂ O	
Start	1033	0.000 cf	72 °F	-2.30 "H ₂ O	110.320 cf	81 °F	78 °F	1.50 "H ₂ O	
	14.0	10.524 ✓ cf	72 ✓ °F	-2.30 ✓ "H ₂ O	10.418 ✓ cf	83 ✓ °F	79 ✓ °F	1.50 ✓ "H ₂ O	

$$\text{Wet Test Meter } V_{m \text{ std}} = 17.65 \times 10.524 \left(\frac{29.40 + \frac{-2.30}{13.6}}{72 + 460} \right) \times 0.999 = 10.196 \text{ dscf} \quad (C_F)$$

$$\text{Dry Gas Meter } V_{m \text{ std}} = 17.65 \times 10.418 \left(\frac{29.40 + \frac{1.50}{13.6}}{81 + 460} \right) = 10.030 \text{ dscf}$$

$$C_{DG} = \frac{10.196}{10.030} = \boxed{1.017}$$

DRY GAS METER CALIBRATION

Meter Number: 10

Calibrator: John Pellegrini

Date: 11 July 1990

$$\text{Calibration Factor (C}_{\text{DG}}) = \frac{\text{Wet Test Meter } V_{\text{m std}}}{\text{Dry Gas Meter } V_{\text{m std}}}$$

Run No.: 1 at 2.00" H₂O

P_b: 29.40 "Hg

Control Module Vacuum 5.5 "Hg

WET TEST METER (No. 2)

DRY GAS METER

	Time	Meter Reading	Temp.	P _m	Meter Reading	Temp.		P _m
						In	Out	
End	1103	10.595 cf	72 °F	-2.80 "H ₂ O	131.729cf	87 °F	79 °F	2.00 "H ₂ O
Start	1050	0.000 cf	72 °F	-2.80 "H ₂ O	121.240cf	85 °F	79 °F	2.00 "H ₂ O
	13.0	10.595 cf	72 °F	-2.80 "H ₂ O	10.489 cf	86 °F	79 °F	2.00 "H ₂ O
						83 ✓		

$$\text{Wet Test Meter } V_{\text{m std}} = 17.65 \times 10.595 \left(\frac{29.40 + \frac{-2.80}{13.6}}{72 + 460} \right) \times 0.999 = 10.252 \text{ dscf (C}_f)$$

$$\text{Dry Gas Meter } V_{\text{m std}} = 17.65 \times 10.489 \left(\frac{29.40 + \frac{2.00}{13.6}}{83 + 460} \right) = 10.074 \text{ dscf}$$

$$C_{\text{DG}} = \frac{10.252}{10.074} = \boxed{1.018 \checkmark}$$

DRY GAS METER CALIBRATION

Meter Number: 10

Calibrator: John Pellegrine

Date: 11 July 1990

$$\text{Calibration Factor (C}_{\text{DG}}) = \frac{\text{Wet Test Meter } V_{\text{m std}}}{\text{Dry Gas Meter } V_{\text{m std}}}$$

Run No.: 1 at 3.00" H₂O

P_b: 29.40 "Hg

Control Module Vacuum 5.9 "Hg

WET TEST METER (No. 2)

DRY GAS METER

	Time	Meter Reading	Temp.	P _m	Meter Reading	Temp.		P _m
						In	Out	
End	1116	10.075 cf	72 °F	3.95 "H ₂ O	141.910 cf	88 °F	80 °F	3.00 "H ₂ O
Start	1106	0.000 cf	72 °F	3.95 "H ₂ O	131.950 cf	86 °F	80 °F	3.00 "H ₂ O
	10.0	10.075 cf	72 °F	3.95 "H ₂ O	9.960 cf	87 °F	80 °F	3.00 "H ₂ O
						84 -		

$$\text{Wet Test Meter } V_{\text{m std}} = 17.65 \times 10.075 \left(\frac{29.40 + \frac{3.95}{13.6}}{72 + 460} \right) \times 0.999 \text{ (C}_f) = 9.720 \text{ dscf}$$

$$\text{Dry Gas Meter } V_{\text{m std}} = 17.65 \times 9.960 \left(\frac{29.40 + \frac{3.00}{13.6}}{84 + 460} \right) = 9.572 \text{ dscf}$$

$$C_{\text{DG}} = \frac{9.720}{9.572} = \boxed{1.016}$$

DRY GAS METER CALIBRATION

Meter Number: 10

Calibrator: John Pellegrine

Date: 11 July 1990

$$\text{Calibration Factor (C}_{\text{DG}}) = \frac{\text{Wet Test Meter } V_{\text{m std}}}{\text{Dry Gas Meter } V_{\text{m std}}}$$

Run No.: 1 at 4.00" H₂O

P_b: 29.40 "Hg

Control Module Vacuum 5.8 "Hg

WET TEST METER (No. 2)

DRY GAS METER

	Time	Meter Reading	Temp.	P _m	Meter Reading	In	Temp. Out	P _m
End	1127	10.439 cf	72 °F	-5.05 "H ₂ O	152.491 cf	90 °F	81 °F	4.00 "H ₂ O
Start	1118	0.000 cf	72 °F	-5.05 "H ₂ O	142.200 cf	88 °F	79 °F	4.00 "H ₂ O
	9.0	10.439 cf	72 °F	-5.05 "H ₂ O	10.291 cf	89 °F	80 °F	4.00 "H ₂ O
						85		

$$\text{Wet Test Meter } V_{\text{m std}} = 17.65 \times 10.439 \left(\frac{29.40 + \frac{-5.05}{13.6}}{72 + 460} \right) \times 0.999 = 10.043 \text{ dscf} \quad (\text{C}_f)$$

$$\text{Dry Gas Meter } V_{\text{m std}} = 17.65 \times 10.291 \left(\frac{29.40 + \frac{4.00}{13.6}}{85 + 460} \right) = 9.896 \text{ dscf}$$

$$C_{\text{DG}} = \frac{10.043}{9.896} = \boxed{1.015}$$

DRY GAS METER CALIBRATION

Meter Number: 10

Calibrator: John Pellegrini

Date: 11 July 1990

$$\text{Calibration Factor (C}_{\text{DG}}) = \frac{\text{Wet Test Meter } V_{\text{m std}}}{\text{Dry Gas Meter } V_{\text{m std}}}$$

Run No.: 1 at 2 l/min.

P_b: 29.41 "Hg

Control Module Vacuum 5.5 "Hg

WET TEST METER (No. 1)

DRY GAS METER

	Time	Meter Reading	Temp.	P _m	Meter Reading	Temp.	P _m
					In	Out	
End	1224	2039 cf	74 °F	-0.40 "H ₂ O	156380cf	81 °F	81 °F 0.00 "H ₂ O
Start	1155	0000 cf	74 °F	-0.40 "H ₂ O	154.350cf	82 °F	81 °F 0.00 "H ₂ O
	29.0	2039 cf	74 °F	-0.40 "H ₂ O	2.030cf	82 °F	81 °F 0.00 "H ₂ O

$$\text{Wet Test Meter } V_{\text{m std}} = 17.65 \times 2.039 \left(\frac{29.41 + \frac{-0.40}{13.6}}{74 + 460} \right) \times 0.999_{(\text{C}_f)} = 1.978 \text{ dscf}$$

$$\text{Dry Gas Meter } V_{\text{m std}} = 17.65 \times 2.030 \left(\frac{29.41 + \frac{0.00}{13.6}}{81 + 460} \right) = 1.948 \text{ dscf}$$


$$C_{\text{DG}} = \frac{1.978}{1.948} = \boxed{1.016}$$

K-2E 0.8 X 1.2 X 0.2 INCHES
 NEUPFEL & EBER CO. MADE IN U.S.A.
 46 1320
 ✓ 4, 1, 2

CM10

11 JULY 19 90

MSG



DIGITAL TEMPERATURE INDICATOR NO. 10

CALIBRATION DATA

Date: 11 JULY 1990

<u>Media</u>	<u>Time</u>	<u>Mercury Thermometer (°F)</u>	<u>DTI (°F)</u>
Ice Bath	<u>1010</u>	<u>33</u>	<u>33</u>
Ambient Air	<u>1009</u>	<u>75</u>	<u>75</u>
Boiling Water	<u>1012</u>	<u>212</u>	<u>212</u>
Oven	<u>1035</u>	<u>158</u>	<u>159</u>
Oven	<u>1102</u>	<u>260</u>	<u>260</u>
Oven	<u>1115</u>	<u>301</u>	<u>303</u>
Oven	<u>1138</u>	<u>389</u>	<u>390</u>

Meter Adjusted? Yes _____ No ✓John Pellegri
Signature of Calibrator

BAROMETER CALIBRATION

 Barometer No. 15

 Date: 8/17/90

 Time: 1543

 Barometric Pressure @ Addison Field @ 719 ft. = 29.97

 - 0.719


 Absolute Pressure at Addison Field = 29.251

 + 0.083


 Absolute Pressure @ METCO @ 636 ft. = 29.334

 Barometer Reading = 29.34

 Variation = -0.006

 Barometer Adjusted? Yes ☐ No ☒

 Signature of Calibrator


90-32 Firestone
Oxides of Nitrogen Monitor Calibration Curve 80.1% EB-1141 Stack 11/6/90



Oxides of Nitrogen Concentration (ppm)

NO_x Monitor Reading (% of scale) C-14

90-22 Firestone Oxides of Nitrogen Monitor Calibration Curve $\beta_{0.14}$ EB-114 Stack 11/7/90




90-22 Freshone

Oxides of Nitrogen Monitor Calibration Curve

Serial - EG-114 Stack


11/7/90



C-16

90-22 Firestone

Oxides of Nitrogen Monitor Calibration Curve 60,14,EB-114 Skk 11/8/90




Oxides of Nitrogen Concentration (ppm)

NO_x Monitor Reading (% of scale) C-17

Carbon Monoxide Monitor Calibration Curve

93-22 Firestone


Boiler-ES 114 Stack 11/8/90



Carbon Monoxide Monitor Calibration Curve

90-22 Emerson


Bailey B-114 Stach 11/7/90



Carbon Monoxide Monitor Calibration Curve

90-21 Firestone

Boiler FB114 Stack 11/8/90




46 1240

90-22 FIRESTONE


Carbon Monoxide Monitor Calibration Curve

Boiler E6-114 STACK 11/19/90



C-22


90-22 Fresno Total Hydrocarbon Analyzer Calibration Curve Baker EB 114 Scale 11/6/90



90-22 Firestone

Total Hydrocarbon Analyzer Calibration Curve

Boiler EB-114 Stack 11/7/92



461240


10-84

20 X THE KEUFFEL & ESSER CO. MADE IN U.S.A.

Total Hydrocarbon Analyzer Calibration Curve

90-22 Freshener


Boiler EP114 Stack 11/8/90



461240

20 X 1/2 THE HUBBARD 7 X 1/2 S
H-Z REUPPEL & ESSER CO. MADE IN U.S.A.

90-23 Firestone
Total Hydrocarbon Analyzer Calibration Curve
Baker EB 114 Scale 11/9/90





Scott Environmental Technology, Inc.
a division of

Our Project # : 10630

Your P.O. is:

NETCO ENVIRONMENTAL

FORMERLY MULLENB ENV.

16115 DOOLEY RD

DALLAS TX 75244

1290 COMBERMERE STREET, TROY, MICHIGAN 48064 (313) 589-2950

♦ ♦ ♦ CERTIFICATE OF ANALYSIS - EPA PROTOCOL BASED ♦ ♦ ♦

PERFORMED ACCORDING TO SECTION 3.0.4

Certified Per Traceability

Protocol 1

File # P04967

Certified Accuracy ! 2 MB8 Traceable

REFERENCE STD

COMPONENT	CERTIFIED CONC.	SN# 0 (CRM 0)	CYLINDER NUMBER	CONC.	MAKE/MODEL	LAST CALIBRATION DATE	ANALYTICAL PRINCIPLE
NITRIC OXIDE	49.62 PPM	1605	AAL-9851	236.00 PPM	BECKMAN	4-2-70	CHEMILUMINESCENCE
		081180	AAL-14484	145.30 PPM	951A		
		1604	ALH-003623	97.28 PPM			

BALANCE GAS : NITROGEN

NITROGEN DIOXIDE
0.30 PPM

C-27

[illegible]

THIS - GAS MANUFACTURER'S INTERNAL STANDARD

Analyst: 

Approved by:

The only liability of this Company for gas which falls to comply with this analysis shall be replacement thereof by the Company without extra cost



Scott Environmental Technology, Inc.
a division of

1290 COMBERMERE STREET, TROY, MICHIGAN 48064 (313) 589-2950

1935 : 1935

Our first job

YOUR P.O. # : 916

Expiration Date : 10-4-01

Cylinder Number 100-1731

0175564J JAPU114J

အသံအသံအသံ

MEICO ENVIRONMENTAL
FORMERLY MULLENS ENV.
16115 DOOLEY RD.
DALLAS TX. 75244

1000 S3505 76701654 033 - BIEA TWD in E-VOTING 0000

SECTION 10 SECTION 10, 4

15-01-1964 41162-7 211-7

— 15 —

12680 J 511 J

1. **Introduction**
 2. **Background**
 3. **Methodology**
 4. **Results**
 5. **Conclusion**
 6. **References**
 7. **Appendix**
 8. **Index**
 9. **Table of Contents**
 10. **Summary**
 11. **Abstract**
 12. **Keywords**
 13. **Subject Headings**
 14. **Notes**
 15. **Footnotes**
 16. **References**
 17. **Appendix**
 18. **Index**
 19. **Table of Contents**
 20. **Summary**
 21. **Abstract**
 22. **Keywords**
 23. **Subject Headings**
 24. **Notes**
 25. **Footnotes**
 26. **References**
 27. **Appendix**
 28. **Index**
 29. **Table of Contents**
 30. **Summary**
 31. **Abstract**
 32. **Keywords**
 33. **Subject Headings**
 34. **Notes**
 35. **Footnotes**
 36. **References**
 37. **Appendix**
 38. **Index**
 39. **Table of Contents**
 40. **Summary**
 41. **Abstract**
 42. **Keywords**
 43. **Subject Headings**
 44. **Notes**
 45. **Footnotes**
 46. **References**
 47. **Appendix**
 48. **Index**
 49. **Table of Contents**
 50. **Summary**
 51. **Abstract**
 52. **Keywords**
 53. **Subject Headings**
 54. **Notes**
 55. **Footnotes**
 56. **References**
 57. **Appendix**
 58. **Index**
 59. **Table of Contents**
 60. **Summary**
 61. **Abstract**
 62. **Keywords**
 63. **Subject Headings**
 64. **Notes**
 65. **Footnotes**
 66. **References**
 67. **Appendix**
 68. **Index**
 69. **Table of Contents**
 70. **Summary**
 71. **Abstract**
 72. **Keywords**
 73. **Subject Headings**
 74. **Notes**
 75. **Footnotes**
 76. **References**
 77. **Appendix**
 78. **Index**
 79. **Table of Contents**
 80. **Summary**
 81. **Abstract**
 82. **Keywords**
 83. **Subject Headings**
 84. **Notes**
 85. **Footnotes**
 86. **References**
 87. **Appendix**
 88. **Index**
 89. **Table of Contents**
 90. **Summary**
 91. **Abstract**
 92. **Keywords**
 93. **Subject Headings**
 94. **Notes**
 95. **Footnotes**
 96. **References**
 97. **Appendix**
 98. **Index**
 99. **Table of Contents**
 100. **Summary**
 101. **Abstract**
 102. **Keywords**
 103. **Subject Headings**
 104. **Notes**
 105. **Footnotes**
 106. **References**
 107. **Appendix**
 108. **Index**
 109. **Table of Contents**
 110. **Summary**
 111. **Abstract**
 112. **Keywords**
 113. **Subject Headings**
 114. **Notes**
 115. **Footnotes**
 116. **References**
 117. **Appendix**
 118. **Index**
 119. **Table of Contents**
 120. **Summary**
 121. **Abstract**
 122. **Keywords**
 123. **Subject Headings**
 124. **Notes**
 125. **Footnotes**
 126. **References**
 127. **Appendix**
 128. **Index**
 129. **Table of Contents**
 130. **Summary**
 131. **Abstract**
 132. **Keywords**
 133. **Subject Headings**
 134. **Notes**
 135. **Footnotes**
 136. **References**
 137. **Appendix**
 138. **Index**
 139. **Table of Contents**
 140. **Summary**
 141. **Abstract**
 142. **Keywords**
 143. **Subject Headings**
 144. **Notes**
 145. **Footnotes**
 146. **References**
 147. **Appendix**
 148. **Index**
 149. **Table of Contents**
 150. **Summary**
 151. **Abstract**
 152. **Keywords**
 153. **Subject Headings**
 154. **Notes**
 155. **Footnotes**
 156. **References**
 157. **Appendix**
 158. **Index**
 159. **Table of Contents**
 160. **Summary**
 161. **Abstract**
 162. **Keywords**
 163. **Subject Headings**
 164. **Notes**
 165. **Footnotes**
 166. **References**
 167. **Appendix**
 168. **Index**
 169. **Table of Contents**
 170. **Summary**
 171. **Abstract**
 172. **Keywords**
 173. **Subject Headings**
 174. **Notes**
 175. **Footnotes**
 176. **References**
 177. **Appendix**
 178. **Index**
 179. **Table of Contents**
 180. **Summary**
 181. **Abstract**
 182. **Keywords**
 183. **Subject Headings**
 184. **Notes**
 185. **Footnotes**
 186. **References**
 187. **Appendix**
 188. **Index**
 189. **Table of Contents**
 190. **Summary**
 191. **Abstract**
 192. **Keywords**
 193. **Subject Headings**
 194. **Notes**
 195. **Footnotes**
 196. **References**
 197. **Appendix**
 198. **Index**
 199. **Table of Contents**
 200. **Summary**
 201. **Abstract**
 202. **Keywords**
 203. **Subject Headings**
 204. **Notes**
 205. **Footnotes**
 206. **References**
 207. **Appendix**
 208. **Index**
 209. **Table of Contents**
 210. **Summary**
 211. **Abstract**
 212. **Keywords**
 213. **Subject Headings**
 214. **Notes**
 215. **Footnotes**
 216. **References**
 217. **Appendix**
 218. **Index**
 219. **Table of Contents**
 220. **Summary**
 221. **Abstract**
 222. **Keywords**
 223. **Subject Headings**
 224. **Notes**
 225. **Footnotes**
 226. **References**
 227. **Appendix**
 228. **Index**
 229. **Table of Contents**
 230. **Summary**
 231. **Abstract**
 232. **Keywords**
 233. **Subject Headings**
 234. **Notes**
 235. **Footnotes**
 236. **References**
 237. **Appendix**
 238. **Index**
 239. **Table of Contents**
 240. **Summary**
 241. **Abstract**
 242. **Keywords**
 243. **Subject Headings**
 244. **Notes**
 245. **Footnotes**
 246. **References**
 247. **Appendix**
 248. **Index**
 249. **Table of Contents**
 250. **Summary**
 251. **Abstract**
 252. **Keywords**
 253. **Subject Headings**
 2

REFERENCE: 1-1
SAC: ANALYZER

**CERTIFIED
COM.**

CARBON MONOXIDE

BALANCE GAS : NITROGEN

C-30

515A-1515

DATE : 7-29-99

213. 214.

Page 1-1-50

0337 : 1501

595 : E05

(۱) : ۱۲۵

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
84

67.70 67.70

0.00 1 67.70

[illegible]

01.773 1 3881

PAID BY AIRTEL

031477767

5176234

AIR PACE

AMERICAN

01
02
03
04
05
06
07
08
09
10
11
12

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
84

1000

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

How is



Scott Specialty Gases

a division of
Scott Environmental Technology, Inc.

1290 COMBERMERE STREET, TROY, MICHIGAN 48064 (313) 589-2950

Customer:

NETCO ENVIRONMENTAL
FORMERLY MULLENS ENV.
15115 DOOLEY RD.
DALLAS TX. 75244

Our Project # : 10032

Your P.O. # : 512

Expiration Date : 10-4-77

Cylinder Number : CAL-9911

Cylinder Pressure : 2000 PSIG

*** CERTIFICATE OF ANALYSIS - GSA PROTOCOL GASES ***

PERFORMED ACCORDING TO SECTION 3.0.4

Certified for Traceability Procedure # 01

Protocol # 1

File # 554925

Certified Accuracy : 1.7% Indefinite

REFERENCE GAS ANALYZER

COMPONENT	CERTIFIED CONC.	SCH # (GEM #)	CYLINDER NUMBER	DATE	LAST CALIBRATION DATE
CARBON MONOXIDE	49.41 PPM	1679A	06-5-1	10/1/76	3-12-76
		BM13	06-5-1	10/1/76	

BALANCE GAS : NITROGEN

FIRST ANALYSIS

DATE : 3-20-77

TEST GAS : CO

INTERNAL STANDARD : 47.20 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

REFERENCE : 100.00 PPM

RESULTS : 49.41 PPM

SECOND ANALYSIS

DATE : 4-4-77

TEST GAS : CO

INTERNAL STANDARD : 47.20 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

REFERENCE : 100.00 PPM

RESULTS : 47.20 PPM

CALIBRATION CURVE

3 rd SERIES

SEN #	CONC.	SPLIT	DM	PERCENT
(CONC #)	PPM	PT (2)	(4-7)	VALUE
1679A	47.20	100	100.00	47.20
	24.31	52	51.80	24.40
	20.79	44	44.00	20.67
	9.90	21	21.40	9.95
	0.00	0	0.00	0.00
	0	0	0.00	0.00
	0	0	0.00	0.00
1677	9.90	LOW	21.40	9.95
N/A	20.79	SMIS	44.00	20.67

*** GMS - GAS MANUFACTURER'S INTERNAL STANDARD

ANALYST :

APPROVED BY :

J. Shapiro

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.



Scott Specialty Gases

a division of
Scott Environmental Technology, Inc.

1290 COMBERMERE STREET, TROY, MICHIGAN 48064 (313) 589-2950

Customer :

NETCO ENVIRONMENTAL
FORMERLY MULLENS AVE
16115 DOOLEY RD
DALLAS TX 75244

Shipped From : Scott Troy

Our Project # : 5150

Your P.O. # : 740

Expiration Date : 10-5-91

Cylinder Number CAL-1606

Cylinder Pressure 2000 psig

*** CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES ***

PERFORMED ACCORDING TO SECTION 3.0.4

Certified Per Traceability Procedure # 61

Protocol # 1

File # F03227

Certified Accuracy 1 % NBS Traceable

REFERENCE STD

GAS ANALYZER

COMPONENT	CERTIFIED CONC.	SRM # (CRM #)	CYLINDER NUMBER	CONC.	MAKE/MODEL/SERIAL #	LAST CALIBRATION DATE	ANALYTICAL PRINCIPLE
CARBON MONOXIDE	499.5 PPM	1681	AAL-6540	970.5 PPM	HORIBA/DOE-144E/560172153	3-1-89	NDIR-DISPERSIVE INFRARED
		GH150	AAL-19066	1000 PPM			

BALANCE GAS : NITROGEN

FIRST ANALYSIS

DATE : 9-29-89

SECOND ANALYSIS

DATE : 10-5-89

FIRST ANALYSIS				SECOND ANALYSIS				CALIBRATION CURVE			
ZERO	TEST	REFERENCE	RESULTS	ZERO	TEST	REFERENCE	RESULTS	SRM # (CRM #)	CONC. (PPM)	SPLIT FT (%)	DVM FITTED PERCENT ERROR
0.00	52.00	98.00	402.2	0.00	52.00	98.00	402.2	1681	970.5	100	997.5 -0.27
0.00	52.00	98.00	402.2	0.00	52.00	98.00	402.2		750.2	75	970.5 .00
0.00	52.00	98.00	402.2	0.00	52.00	98.00	402.2		499.4	50	747.6 -0.35
									244.0	24	499.0 -0.08
									0.0000	0	244.1 0.03
									0	0	0.0000 0.00
											0.00 0.00
								2636	244.0 LOW	32.00	244.1 0.03
									1000 GH150	123.10	997.5 -0.27

CALCULATED RESULTS 499.5

AVERAGE : 499.5 PPM

GH15 - GAS MANUFACTURER'S INTERNAL STANDARD

Analyst :

Robert A. Patel

Approved By :

J. Shapiro

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.



Scott Environmental Technology, Inc.
a division of

Our Project # : 08552

1290 COMBERMERE STREET, TROY, MICHIGAN 48064 (313) 589-2950

Your P.O. # : **855**

**METCO ENVIRONMENTAL
FORMERLY MULLENS ENV
16115 DOOLEY ROAD
DALLAS TX 75244**

0000 CERTIFICATE OF ANALYSIS - EPA PROTOCOL BASES 0000
PERFORMED ACCORDING TO SECTION 3.0.4

Certified For Traceability
Protocol # 1
Procedure # 61

File # P04586

Certified Accuracy: 1 % HAS Traceable

Cylinder Pressure 1900 psi

REFERENCE STD

COMPONENT	CERTIFIED CONC.	SRM # (CRM #)	CYLINDER NUMBER	CONC.	MAKE/MODEL/SERIAL #	LAST CALIBRATION DATE
CARBON MONOXIDE	894.32 PPM	1681	CAL-7913	970.00 PPM	HORIBA/DOE-144E/360172153	1-30-90
		6MIS#	XA-9163	1001.00 PPM		

BALANCE GAS : NITROGEN

FIRST ANALYSIS

DATE : 1-31-90

SISAJMH Q10735

DATE : 2-6-90

[illegible]

† THIS - BAS MANUFACTURER'S INTERNAL STANDARD

Analyst :

Approved By :

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost

Scott Specialty Gases, Inc.

PLUMSTEADVILLE, PA 18949

PHONE: 215-788-8861

FAX: 215-788-0320

METCO ENVIRONMENTAL
FORMERLY MULLENS ENV
16115 DOOLEY ROAD
DALLAS TX 75244

ATTN: DOUG SATHOFF

Cylinder Number CAL 8568
CP = 2000PSIG

Certified Accuracy $\pm 1\%$ NBS Traceable

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES*

(Concentrations are in mole % or ppm)

Analysis Dates: First 8-6-90 Last NR

Date Shipped 8-8-90

Our Project No: 21243

Your P.O. No: 1031

Page 1 of 1

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM'S	REPLICATE CONCENTRATIONS FIRST SECOND
PROPANE	9.85 PPM	2-6-92	FID	1666b	9.832 PPM
					9.850 PPM
NITROGEN	BALANCE				9.860 PPM

Cylinder Number CAL 9194
CP = 2000PSIG

Certified Accuracy $\pm 1\%$ NBS Traceable

Analysis Dates: First 8-6-90 Last NR

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM'S	REPLICATE CONCENTRATIONS FIRST SECOND
PROPANE	9.85 PPM	2-6-92	FID	1666b	9.847 PPM
					9.852 PPM
NITROGEN	BALANCE				9.846 PPM

*We hereby certify the cylinder gas has been analyzed according to EPA Protocol No: 1 PROCEDURE G1

Analyst Red Neame Approved By MARK SIRINIDES

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

CERTIFIED REFERENCE MATERIALS ■ EPA PROTOCOL GASES ■ ACUBLEND® ■ CALIBRATION & SPECIALTY GAS MIXTURES
PURE GASES ■ ACCESSORY PRODUCTS ■ CUSTOM ANALYTICAL SERVICES

TROY, MICHIGAN / SAN BERNARDINO, CALIFORNIA / HOUSTON, TEXAS
SOUTH PLAINFIELD, NEW JERSEY / FREMONT, CALIFORNIA / WAKEFIELD, MASSACHUSETTS / LONGMONT, COLORADO



Scott Specialty Gases

PLUMSTEADVILLE, PA. 18949 PHONE: 215-766-8861 TWX: 510-665-9344

METCO ENVIRONMENTAL

Date Shipped 1-4-90
Our Project No: 15947
Your P.O. No: 819
Page 2 of 4

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES*

(Concentrations are in mole % or ppm)

Cylinder Number CAL 9925 Certified Accuracy ±1 % NBS Traceable Analysis Dates: First 12-20-89 Last NR
cp=2000psig

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST SECOND
PROPANE	51.1ppm	6-20-91	FID	1667B	51.11ppm
					51.24ppm
					51.07ppm
NITROGEN	BAL				

Cylinder Number CAL 10045 Certified Accuracy ±1 % NBS Traceable Analysis Dates: First 12-20-89 Last NR
cp=2000psig

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST SECOND
PROPANE	51.3ppm	6-20-91	FID	1667B	51.37ppm
					51.28ppm
					51.31ppm
NITROGEN	BAL				

*We hereby certify the cylinder gas has been analyzed according to EPA Protocol No: 1 PROCEDURE G1

Analyst Jennifer Mease Approved By Mark S. Strinides
JENNIFER MEASE MARK S. STRINIDES

CERTIFIED REFERENCE MATERIALS ■ EPA PROTOCOL GASES ■ ACUBLEND® ■ CALIBRATION & SPECIALTY GAS MIXTURES
PURE GASES ■ ACCESSORY PRODUCTS ■ CUSTOM ANALYTICAL SERVICES

TROY, MICHIGAN / SAN BERNARDINO, CALIFORNIA / HOUSTON, TEXAS / WHEELING, ILLINOIS
SOUTH PLAINFIELD, NEW JERSEY / FREMONT, CALIFORNIA / WAKEFIELD, MASSACHUSETTS / LONGMONT, COLORADO



Scott Specialty Gases, Inc.

PLUMSTEADVILLE, PA 18949 PHONE: 215-788-8861 FAX: 215-788-0320

METRO ENVIRONMENTAL

ADDISON TX

ATTN: DOUG SATHOFF

Date Shipped 10-11-90
Our Project No: 22777
Your P.O. No: 1072
Page 2 of 4

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES*

(Concentrations are in mole % or ppm)

Cylinder Number CLM 002304 Certified Accuracy ±1 % NBS Traceable Analysis Dates: First 10-10-90 Last N.R.
CP = 2000 psig

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST SECOND
PROPANE	91.8 ppm	4-10-92	F.I.D.	2651	91.33 ppm
					91.96 ppm
					92.03 ppm
NITROGEN	BALANCE				

Cylinder Number CAL 12258 Certified Accuracy ±1 % NBS Traceable Analysis Dates: First 10-10-90 Last N.R.
CP = 2000 psig

COMPONENTS	CERTIFIED CONC	EXPIRATION DATE	ANALYTICAL PRINCIPLE	PRIMARY STANDARD NBS/SRM's	REPLICATE CONCENTRATIONS FIRST SECOND
PROPANE	91.7 ppm	4-10-92	F.I.D.	2651	91.94 ppm
					91.85 ppm
					91.31 ppm
NITROGEN	BALANCE				

*We hereby certify the cylinder gas has been analyzed according to EPA Protocol No:

Analyst Red Dean Approved By Mark S. Sirinides 1 Procedure G1

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

CERTIFIED REFERENCE MATERIALS ■ EPA PROTOCOL GASES ■ ACUBEND® ■ CALIBRATION & SPECIALTY GAS MIXTURES
PURE GASES ■ ACCESSORY PRODUCTS ■ CUSTOM ANALYTICAL SERVICES

TROY, MICHIGAN / SAN BERNARDINO, CALIFORNIA / HOUSTON, TEXAS
SOUTH PLAINFIELD, NEW JERSEY / FREMONT, CALIFORNIA / WAKEFIELD, MASSACHUSETTS / LONGMONT, COLORADO

APPENDIX D

Field Testing Data

Job No. 90-221
 Job Name FIRESTADE
 Run No. 1 (COND. #1)
 Location ED-114 EXHAUST
 Date 6 NOVEMBER 1990
 Operator RANDY B. 11
 Sample Box No. 30 Meter Box No. 10

Very Moist FIELD DATA
 Read and record at the
 start of each test point.
 Purge to: ---
 Purge time: ---

METCO ENVIRONMENTAL
 Ambient Temp. °F 68
 Assumed Moisture % 14.0
 Probe Length 3'
 C Factor --- to reference
 Initial Leak @ 45.0 "Hg = 0.000 cfm
 Final Leak @ 10.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	ΔP_s		P_m		Pump Vacuum In. Hg Gauge	T_s		Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	T_m Dry Gas Temp. °F		Remarks
			Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Stack Temp. °F		Dry Gas Temp. Inlet °F	Dry Gas Temp. Outlet °F						
				Desired	Actual										
A8	0911	804.129	0.02	2.00	2.00	5.0	240	260	254	254	65	66	67	UNDER	
A7	0916	807.18	0.03	2.00	2.00	5.0	264	262	254	254	60	67	66	UNDER	
A6	0921	811.03	0.03	2.00	2.00	5.0	273	262	255	255	56	67	66	UNDER	
A5	0926	815.26	0.03	2.00	2.00	5.0	280	263	258	258	56	68	66	UNDER	
A4	0931	818.62	0.02	2.00	2.00	5.0	285	261	253	253	58	69	66	UNDER	
A3	0936	822.80	0.02	2.00	2.00	5.0	310	262	256	256	59	70	67	UNDER	
A2	0941	826.300	0.03	—	—	—	362	—	—	—	—	—	—	—	—
A1	END	—	0.02	—	—	—	275	—	—	—	—	—	—	—	—
END	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
B8	—	—	0.02	—	—	—	278	—	—	—	—	—	—	—	—
B7	—	—	0.03	—	—	—	290	—	—	—	—	—	—	—	—
B6	—	—	0.03	—	—	—	286	—	—	—	—	—	—	—	—
B5	—	—	0.03	—	—	—	290	—	—	—	—	—	—	—	—
B4	—	—	0.02	—	—	—	287	—	—	—	—	—	—	—	—
B3	—	—	0.02	—	—	—	282	—	—	—	—	—	—	—	—
B2	—	—	0.02	—	—	—	282	—	—	—	—	—	—	—	—
B1	—	—	0.03	—	—	—	276	—	—	—	—	—	—	—	—
END	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Pitot Tube Calibration Factor C_p 0.789
 Volume Collected V_m 22.526 ft³ Baro. Press. P_b 30.00 "Hg
 Water Collected V_w 11.2 ml Probe Tip Dia. D_n --- in.
 Time of Test T_t 30 min. % CO₂ 9.3 % CO 0.0
 Stack Pressure P_s 10.03 "H₂O % O₂ 2.5 % N₂ 88.0
 Area Stack A_s 26.53 in²

Pitot Tube No. 5 Barometer No. 15
 Probe Tip No. ---
 V_m = Dry Gas Meter Calibration Factor 1.016 x 22.171
 Dry Gas Meter Reading --- ft³ - $(T_t - T_m) \times \text{Leak Rate}$ --- cfm
 $M_F = \text{---$ $M_T = \text{---$

Impinger Box No. 30

Impinger 1 Final Weight 672.5
Initial Weight 610.6
Increase

Impinger 2 Final Weight 690.8
Initial Weight 611.6
Increase

Impinger 3 Final Weight 511.1
Initial Weight 501.8
Increase

Impinger 4 Final Weight 890.7
Initial Weight 879.9
Increase

Impinger 5 Final Weight _____
Initial Weight _____
Increase

Impinger 6 Final Weight _____
Initial Weight _____
Increase

Filter # _____ Final Weight _____
Initial Weight _____
Increase _____

Water Weight Gain Impinger 1 61.9

Impinger 2 29.2

Impinger 3 9.3

Impinger 4 10.8

Impinger 5 _____

Impinger 6 _____

$V_w =$

$g SO_2 = -$

$V_w =$

Total 111.2 = V_w

$P_b = 30.00 \checkmark$ %CO₂ = 9.5✓

$V_m = 22.526 \checkmark$ %O₂ = 2.5✓

$V_w = 111.2 \checkmark$ %CO = 0.0✓

$P_m = 2.000 \checkmark$ %N₂ = 88.0✓

Avg $\Delta P = 0.025 \checkmark$ $A_s = 2653 \checkmark$

Avg $\sqrt{\Delta P} = 0.157 \checkmark$ $D_n =$

$C_p = 0.799 \checkmark$ $T_t = 30 \checkmark$

$P_s = +0.03 \checkmark$ H₂O 30.00 "Hg✓

$T_m = 67 \checkmark$ °F 527 °R✓

$T_s = 28.3 \checkmark$ °F 743 °R✓

Moisture Content: %M = 18.75 $M_d = 0.8125$ $MW_d = 29.620$ $MW = 27.44$

$$V_{mstd} = 17.65 V_m \left(\frac{P_b + P_m}{T_m + 460} \right) = 17.65 \times 22.526 \left(\frac{30.00 + 2.00}{67 + 460} \right) = 22.744 \text{ sft}^3 \checkmark$$

$$0.758 \text{ scfm} \checkmark$$

$$V_{wgas} = 0.0472 \times V_w = 0.0472 \times 111.2 = 5.249 \text{ sft}^3 \checkmark$$

$$\% \text{ Moisture} = \frac{V_{wgas}}{V_{mstd} + V_{wgas}} \times 100 = \frac{5.249}{5.249 + 22.744} \times 100 = 18.75 \% \checkmark$$

$$V_s = 5123.8 \times 0.799 \sqrt{\frac{743}{30.00 \times 27.44}} \times 0.157 = 611 \text{ fpm} \checkmark$$

$$\% I = \frac{1039 \times \quad \times \quad \times \quad \times (\quad)^2}{\quad} = \quad \%$$

ACFM: 11250✓

SCFM: 6537✓

%EA: 20.8✓

VERMONT/0007 FIELD DATA

METCO ENVIRONMENTAL

Job No. 90-22
 Job Name FLINTSTONE
 Run No. 02 (COMP.#1)
 Location EB-14 EXHAUST
 Date 6 NOVEMBER 1990
 Operator RANDOLPH, B.11
 Sample Box No. 30 Meter Box No. 10

Read and record at the
 start of each test point.

Purge to:
 Purge time:

Ambient Temp. °F 73
 Assumed Moisture % 14.0
 Probe Length 3'

C Factor to reference
 Initial Leak @ 65.0 "Hg = 0.002 cfm
 Final Leak @ 8.0 "Hg = 0.000 cfm

ΔP_s P_m T_s

T_m 7.101 Tubes Leak
check

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
A8	1030	826.757	0.02	2.00	2.00	4.5	267	265	255	60	25	71	11/22
A7	1035	830.15	0.03	2.00	2.00	4.5	267	263	257	60	26	71	05/07
A6	1040	834.72	0.02	2.00	2.00	5.0	274	265	260	58	28	72	
A5	1045	838.36	0.02	2.00	2.00	5.0	251	263	265	58	30	72	
A4	1050	842.00	0.03	2.00	2.00	5.0	253	260	254	59	31	72	
A3	1055	846.05	0.03	2.00	2.00	5.0	313	254	256	60	32	73	
A2	1100	841.600	0.02	—	—	—	314	—	—	—	—	—	
A1	END	—	0.01	—	—	—	251	—	—	—	—	—	
END	—	—	—	—	—	—	—	—	—	—	—	—	
B8	—	—	0.02	—	—	—	261	—	—	—	—	—	
B7	—	—	0.03	—	—	—	261	—	—	—	—	—	
B6	—	—	0.03	—	—	—	261	—	—	—	—	—	
B5	—	—	0.03	—	—	—	252	—	—	—	—	—	
B4	—	—	0.03	—	—	—	258	—	—	—	—	—	
B3	—	—	0.03	—	—	—	258	—	—	—	—	—	
B2	—	—	0.02	—	—	—	255	—	—	—	—	—	
B1	—	—	0.02	—	—	—	253	—	—	—	—	—	
END ALL	—	—	—	—	—	—	271	—	—	—	—	—	

Pitot Tube Calibration Factor C_p 0.799

Pitot Tube No. 5 Barometer No. 15

Volume Collected V_m 23.208 ft³ Baro. Press. P_b 30.00 "Hg

Water Collected V_w 105.3 ml Probe Tip Dia. D_n — in.

Time of Test T_t 30 min. % CO₂ 2.0 % CO 0.0

Stack Pressure P_s 10.03 "H₂O % O₂ 2.0 % N₂ 89.0

Area Stack A_s 2653 in²

V_m = Dry Gas Meter Calibration Factor 1.016 x 22.843

Dry Gas Meter Reading ft³ - $(T_t - T_m)$ min x Rate cfm
 M_F = M_T =

Impinger Box No. 30

Impinger 1 Final Weight 753.1
Initial Weight 672.5
Increase

Impinger 2 Final Weight 657.2
Initial Weight 640.8
Increase

Impinger 3 Final Weight 514.0
Initial Weight 511.1
Increase

Impinger 4 Final Weight 896.1
Initial Weight 890.7
Increase

Impinger 5 Final Weight _____
Initial Weight _____
Increase

Impinger 6 Final Weight _____
Initial Weight _____
Increase

Filter # _____ Final Weight _____
Initial Weight _____
Increase _____

Water Weight Gain Impinger 1 80.6

Impinger 2 16.4

Impinger 3 2.9

Impinger 4 5.4

Impinger 5 _____

Impinger 6 _____

Total 105.3 = V_w

$P_b = 30.00$ ✓ %CO₂ = 9.0 ✓

$V_m = 23.208$ ✓ %O₂ = 2.0 ✓

$V_w = 105.3$ ✓ %CO = 0.0 ✓

$P_m = 2.000$ ✓ %N₂ = 89.0 ✓

Avg $\Delta P = 0.024$ ✓ $A_s = 2653$ ✓

Avg $\sqrt{\Delta P} = 0.153$ ✓ $D_n =$ _____

$C_p = 0.799$ ✓ $T_t = 30$ ✓

$P_s = 70.03$ "H₂O 30.00 "Hg ✓

$T_m = 75$ °F ✓ 535 °R ✓

$T_s = 28.3$ °F ✓ 743 °R ✓

Moisture Content: %M = 17.64⁷² $M_d = 0.823$ ²⁸ $MW_d = 27.520$ $MW = 27.18$

$$V_{m_{std}} = 17.65 V_m \left(\frac{P_b + \frac{P_m}{13.6}}{T_m + 460} \right) = 17.65 \times 23.208 \left(\frac{30.00 + \frac{2.00}{13.6}}{75 + 460} \right) = 23.082 \text{ sft}^3 \checkmark$$

$$0.769 \text{ scfm} \checkmark$$

$$V_{w_{gas}} = 0.0472 \times V_w = 0.0472 \times 105.3 = 4.970 \text{ sft}^3 \checkmark$$

$$\% \text{ Moisture} = \frac{V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}} \times 100 = \frac{4.970}{4.970 + 23.082} \times 100 = 17.64\% \checkmark$$

$$V_s = 5123.8 \times 0.799 \times \sqrt{\frac{743}{30.00 \times 27.18}} \times 0.153 = 595 \text{ fpm} \checkmark$$

ACFM: 1095.5 ✓

SCFM: 645.2 ✓

%EA: 9.3 ✓

$$\%I = \frac{1039 \times \quad \times \quad \times \quad \times (\quad)^2}{\quad} = \quad \%$$

Job No. 90-202
 Job Name FIRESTONE
 Run No. 3 (COND. #1)
 Location EB-114 EXHAUST
 Date 6 NOVEMBER 1990
 Operator RAUDOLPH, Bill
 Sample Box No. 30 Meter Box No. 10

VENTILATION FIELD DATA
 Read and record at the
 start of each test point.
 Purge to: ---
 Purge time: ---

METCO ENVIRONMENTAL
 Ambient Temp. °F 77
 Assumed Moisture % 18.0
 Probe Length 3'
 C Factor --- to reference
 Initial Leak @ 15.0"Hg = 0.002cfm
 Final Leak @ 10.0"Hg = 0.002cfm

Point	Clock Time	Dry Gas Meter, CF	ΔP_s	Pitot in. H ₂ O	P_m		Pump Vacuum In. Hg Gauge	T_s Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks	
					Orifice ΔH in. H ₂ O							Inlet	Outlet		
					Desired	Actual									
B8	1145	850.190	TRANSVERSE	0.02	2.00	2.00	5.0	275	263	258	68	75	75	WATER	
B7	1150	864.12		0.03	2.00	2.00	5.0	278	267	262	69	78	75	WATER	
B6	1155	858.25		0.03	2.00	2.00	5.0	288	262	260	69	80	75	WATER	
B5	1200	861.30		0.02	2.00	2.00	5.0	291	265	257	70	83	76		
B4	1205	865.65		0.02	2.00	2.00	5.0	287	263	257	70	83	76		
B3	1210	864.56		0.02	2.00	2.00	5.0	283	261	258	71	83	76		
B2	1215	873.370		0.02	—	—	—	281	—	—	—	—	—	—	
B1	END	—		0.01	—	—	—	265	—	—	—	—	—	—	
END	—	—		—	—	—	—	—	—	—	—	—	—	—	
A8	—	—		0.02	—	—	—	267	—	—	—	—	—	—	
A7	—	—		0.02	—	—	—	266	—	—	—	—	—	—	
A6	—	—		0.02	—	—	—	270	—	—	—	—	—	—	
A5	—	—		0.02	—	—	—	276	—	—	—	—	—	—	
A4	—	—		0.03	—	—	—	300	—	—	—	—	—	—	
A3	—	—		0.03	—	—	—	306	—	—	—	—	—	—	
A2	—	—		0.03	—	—	—	311	—	—	—	—	—	—	
A1	—	—		0.02	—	—	—	300	—	—	—	—	—	—	
END ALL	—	—		—	—	—	—	—	—	—	—	—	—	—	

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.55/ft³ Baro. Press. P_b 30.02"Hg

Water Collected V_w 102.4 ml Probe Tip Dia. D_n --- in.

Time of Test T_t 30 min. % CO₂ 9.5 % CO 0.0

Stack Pressure P_s 10.03 "H₂O % O₂ 21.5 % N₂ 68.0

Area Stack A_s 2653 in²

Pitot Tube No. 5 Barometer No. 15

Probe Tip No. ---

V_m = Dry Gas Meter Calibration Factor 1.016 x 23.00

Dry Gas Meter Reading --- ft³ - $(T_t - T_t)$ min x Rate --- cfm
 $M_F =$ --- $M_T =$ ---

Impinger Box No. 30

Impinger 1 Final Weight 834.4
Initial Weight 763.1
Increase

Impinger 2 Final Weight 671.5
Initial Weight 657.2
Increase

Impinger 3 Final Weight 515.5
Initial Weight 514.0
Increase

Impinger 4 Final Weight 901.4
Initial Weight 896.1
Increase

Impinger 5 Final Weight _____
Initial Weight _____
Increase

Impinger 6 Final Weight _____
Initial Weight _____
Increase

Filter # _____ Final Weight _____
Initial Weight _____
Increase _____

Water Weight Gain Impinger 1 81.3

Impinger 2 14.3

Impinger 3 1.5

Impinger 4 5.3

Impinger 5 _____

Impinger 6 _____

Total 102.4 = V_w

$P_b = 30.00 \checkmark$ %CO₂ = 9.5 ✓

$V_m = 23.551 \checkmark$ %O₂ = 2.5 ✓

$V_w = 102.4 \checkmark$ %CO = 0.0 ✓

$P_m = 2.000 \checkmark$ %N₂ = 88.0 ✓

Avg $\Delta P = 0.023 \checkmark$ A_s = 2653 ✓

Avg $\sqrt{\Delta P} = 0.149 \checkmark$ D_n = _____

C_p = 0.799 ✓ T_t = 30 ✓

P_s = 10.03 "H₂O 30.00 "Hg ✓

T_m = 78 °F ✓ 538 °R ✓

T_s = 284 °F ✓ 744 °R ✓

Moisture Content: %M = 17.18 ✓ M_d = 0.8282 ✓ MW_d = 29.620 ✓ MW = 27.62

$$V_{m_{std}} = 17.65 V_m \left(\frac{P_b + \frac{P_m}{13.6}}{T_m + 460} \right) = 17.65 \times 23.551 \left(\frac{30.00 + \frac{2.00}{13.6}}{78 + 460} \right) = 23.293 \text{ sft}^3 \checkmark$$

$$0.776 \text{ scfm} \checkmark$$

$$V_{w_{gas}} = 0.0472 \times V_w = 0.0472 \times 102.4 = 4.833 \text{ sft}^3 \checkmark$$

$$\% \text{ Moisture} = \frac{V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}} \times 100 = \frac{4.833}{1.833 + 23.293} \times 100 = 17.18 \% \checkmark$$

$$V_s = 5123.8 \times 0.799 \times \sqrt{\frac{744}{30.00 \times 27.62}} \times 0.149 = 578 \text{ fpm} \checkmark$$

ACFM: 10649 ✓

SCFM: 6299 ✓

%EA: 30.4 / 12.0 ✓

$$\%I = \frac{1039 \times \quad \times \quad \times \quad \times (\quad)^2}{\quad} = \quad \%$$

Job No. 90-202
Job Name FIRESTONE
Run No. A (CONDITIONAL #1)
Location EB-114 EXHAUST
Date 6 NOVEMBER 1990
Operator PANDOLPH, B.L.
Sample Box No. 30 Meter Box No. 10

VENTILATION FIELD DATA

METCO ENVIRONMENTAL

Ambient Temp. °F 65
Assumed Moisture % 14.0
Probe Length 3'
C Factor to reference
Initial Leak @ 15.0 "Hg = 0.000 cfm
Final Leak @ 10.0 "Hg = 0.000 cfm

Read and record at the
start of each test point.
Purge to:
Purge time:

ΔP_s

P_m

T_s

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
B8	1604	902.620	0.24	2.00	2.00	7.0	340	238	252	54	82	82	WATER
B7	1609	906.65	0.25	2.00	2.00	7.0	351	255	255	54	84	83	WATER
B6	1614	910.97	0.25	2.00	2.00	7.0	364	260	251	57	85	83	WATER
B5	1619	915.00	0.24	2.00	2.00	7.0	372	263	252	60	87	84	WATER
B4	1624	918.52	0.24	2.00	2.00	7.0	355	267	254	62	90	87	WATER
B3	1629	922.35	0.25	2.00	2.00	7.0	338	262	255	64	91	85	WATER
B2	1634	926.615	0.25				341						
B1	END		0.18				342						
END													
A8			0.24				317						
A7			0.25				323						
A6			0.25				325						
A5			0.25				335						
A4			0.28				411						
A3			0.30				449						
A2			0.25				439						
A1			0.18				435						
END ALL													

TEMPERATURE CHECK

Pitot Tube Calibration Factor C_p 0.749

Volume Collected V_m 24.379 ft³ Baro. Press. P_b 30.10 "Hg

Water Collected V_w 101.1 ml Probe Tip Dia. D_n in.

Time of Test T_t 30 min. % CO₂ 0.0 % CO 0.0

Stack Pressure P_s +0.15 "H₂O % O₂ 3.0 % N₂ 87.5

Area Stack A_s 265.2 in²

Pitot Tube No. 5

Probe Tip No.

V_m = Dry Gas Meter Calibration Factor 1.06 X 23.995

[Dry Gas Meter Reading ft³ - (T_t min X Rate cfm)]
 M_F = M_T =

Barometer No. 15

Impinger Box No. 30

Impinger 1 Final Weight 794.6
 Initial Weight 722.5
 Increase

Impinger 2 Final Weight 670.5
 Initial Weight 652.9
 Increase

Impinger 3 Final Weight 520.9
Initial Weight 518.8
Increase

Impinger 4	Final Weight	<u>836.4</u>
	Initial Weight	<u>828.2</u>
	Increase	

Impinger 5 Final Weight _____
 Initial Weight _____
 Increase _____

Impinger 6 Final Weight _____
 Initial Weight _____
 Increase _____

Filter # _____ Final Weight _____
Initial Weight _____
Increase _____

Water Weight Gain Impinger 1 24.1

Impinger 2 17.6

Impinger 3 1.2

Impinger 4 8.2

Impinger 5 _____

Impinger 6 _____

Total 104.1 ✓ = v_w

$P_b = 30.10 \checkmark$ $\%CO_2 = 9.3 \checkmark$

$$V_m = 24.379 \checkmark \quad \%O_2 = 2.8 \checkmark$$

$V_w = 101.1 \checkmark$ %CO = 0.0 ✓

$P_m = 2.00 \checkmark \quad \%N_2 = 87.9 \checkmark$

$$\text{Avg } \Delta P = 0.244 \text{ ✓} \quad A_c = 26.53 \text{ ✓}$$

Avg $\sqrt{\Delta P} = 0.493 \checkmark$ D =

$C_p = 0.799 \checkmark$ $T_c = 30 \checkmark$

$P_c = +0.15 \text{ } ^\circ\text{H}_2\text{O}$ 30.11 "Hg

$$T_1 = 85^\circ\text{F} \quad 54.5^\circ\text{R}$$

T = 366 °F $\swarrow$ 826 °R

Moisture Content: $\%M = \frac{16.65}{M_d} = 0.8335$ $MW_d = \frac{29.600}{MW} = 27.67$

$$V_{m\text{std}} = 17.65 V_m \left(\frac{P_b + \frac{P_m}{13.6}}{T_m + 460} \right) = 17.65 \times 24.379 \left(\frac{\frac{30.10}{85} + \frac{2.00}{13.6}}{+ 460} \right) = \frac{23.881}{0.796} \text{ sft}^3 \checkmark$$

$$V_{w_{\text{gas}}} = 0.0472 \times V_w = 0.0472 \times \underline{101.1} = \underline{4.772} \text{ sft}^3 \checkmark$$

$$\% \text{ Moisture} = \frac{V_{w \text{ gas}}}{V_{m \text{ std}} + V_{w \text{ gas}}} \times 100 = \frac{4.772}{4.772 + 23.88} \times 100 = 16.65\% \checkmark$$

$$V_s = 5123.8 \times \frac{0.799}{30.11 \times 27.67} \times \sqrt{\frac{826}{27.67}} \times 0.493 = 2010 \text{ fpm} \checkmark$$

ACFM: 370251

SCFM: 1992\$ ✓

$$I = \frac{1039 \times \times \times \times}{\times \times \times \times ()^2} = \frac{\times}{\times} \%$$

%EA: 13.7 ✓

Job No. 90-22
Job Name FIRESTONE
Run No. 5 (CONDITION #1)
Location EB-14 EXHAUST
Date 6 NOVEMBER 1990
Operator RANDOLPH, B.11
Sample Box No. 30 Meter Box No. 10

Very noisy FIELD DATA
Read and record at the
start of each test point.
Purge to: —
Purge time: —

METCO ENVIRONMENTAL
Ambient Temp. °F 75
Assumed Moisture % 18.0
Probe Length 3'
C Factor — to reference
Initial Leak @ 15.0 "Hg = 0.002 fpm
Final Leak @ 9.0 "Hg = 0.002 fpm

Point	Clock Time	Dry Gas Meter, CF	ΔP_s		P_m		Pump Vacuum In. Hg Gauge	T_s		Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	T_m		Remarks
			Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Stack Temp. °F		Dry Gas Temp. °F	Outlet						
				Desired	Actual										
A 8	1706	937.000	0.19	2.00	2.00	7.0	325	242	257	58	85	85	INTER		
A 7	1711	930.60	0.19	2.00	2.00	7.0	339	250	257	57	87	85	ORSA		
A 6	1716	934.57	0.17	2.00	2.00	7.0	333	257	256	57	89	86			
A 5	1721	938.40	0.21	2.00	2.00	7.0	341	260	261	60	90	87			
A 4	1726	942.73	0.24	2.00	2.00	7.0	321	259	258	62	91	87			
A 3	1731	946.37	0.29	2.00	2.00	7.0	359	262	257	63	90	86			
A 2	1736	950.840	0.31	—	—	—	469	—	—	—	—	—			
A 1	END	—	0.20	—	—	—	440	—	—	—	—	—			
END	—	—	—	—	—	—	—	—	—	—	—	—			
B 8	—	—	0.22	—	—	—	349	—	—	—	—	—			
B 7	—	—	0.23	—	—	—	360	—	—	—	—	—			
B 6	—	—	0.23	—	—	—	371	—	—	—	—	—			
B 5	—	—	0.23	—	—	—	365	—	—	—	—	—			
B 4	—	—	0.23	—	—	—	367	—	—	—	—	—			
B 3	—	—	0.25	—	—	—	350	—	—	—	—	—			
B 2	—	—	0.24	—	—	—	350	—	—	—	—	—			
B 1	—	—	0.16	—	—	—	355	—	—	—	—	—			
END ALL	—	—	—	—	—	—	—	—	—	—	—	—			

Pitot Tube Calibration Factor C_p 0.799
Volume Collected V_m 23.612 ft³ Baro. Press. P_b 30.10 "Hg
Water Collected V_w 102.4 ml Probe Tip Dia. D_n — in.
Time of Test T_t 30 min. % CO₂ 8.0 % CO 0.0
Stack Pressure P_s +0.17 "H₂O % O₂ 2.5 % N₂ 89.5
Area Stack A_s 2653 in²

Pitot Tube No. 5 Barometer No. 15
Probe Tip No. —
 V_m = Dry Gas Meter Calibration Factor 1.016 X 23.240
[Dry Gas Meter Reading — ft³ - (T_t min X Rate — cfm)]
 M_F = — M_T = —

Impinger Box No. 30

Impinger 1 Final Weight 823.0
Initial Weight 799.6
Increase

Impinger 2 Final Weight 732.0
Initial Weight 690.5
Increase

Impinger 3 Final Weight 523.2
Initial Weight 500.0
Increase

Impinger 4 Final Weight 845.7
Initial Weight 836.4
Increase

Impinger 5 Final Weight _____
Initial Weight _____
Increase

Impinger 6 Final Weight _____
Initial Weight _____
Increase

Filter # _____ Final Weight _____
Initial Weight _____
Increase _____

Water Weight Gain

Impinger 1 28.4

Impinger 2 61.5

Impinger 3 3.2

Impinger 4 9.3

Impinger 5 _____

Impinger 6 _____

Total 102.4 = V_w

$P_b = 30.10$ ✓ %CO₂ = 8.0 ✓

$V_m = 23.612$ ✓ %O₂ = 2.5 ✓

$V_w = 102.4$ ✓ %CO = 89.50.0 ✓

$P_m = 2.000$ ✓ %N₂ = 89.5 ✓

Avg $\Delta P = 0.224$ ✓ $A_s = 26.53$ ✓

Avg $\sqrt{\Delta P} = 0.472$ ✓ $D_n =$ _____

$C_p = 0.799$ ✓ $T_t = 30$ ✓

$P_s = 30.17$ ✓ $T_{H_2O} = 30.11$ °Hg ✓

$T_m = 87$ °F ✓ 547 °R ✓

$T_s = 375$ °F ✓ 835 °R ✓

Moisture Content:

%M = 17.34 $M_d = 0.8266$ $MW_d = 29.380$ $MW = 27.41$

$$V_{m_{std}} = 17.65 V_m \left(\frac{P_b + P_m}{T_m + 460} \right) = 17.65 \times 23.612 \left(\frac{30.10 + 2.00}{87 + 460} \right) = 23.045 \text{ sft}^3 \checkmark$$

$$0.768 \text{ scfm} \checkmark$$

$$V_{w_{gas}} = 0.0472 \times V_w = 0.0472 \times 102.4 = 4.833 \text{ sft}^3 \checkmark$$

$$\% \text{ Moisture} = \frac{V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}} \times 100 = \frac{4.833}{4.833 + 23.045} \times 100 = 17.34 \% \checkmark$$

$$V_s = 5123.8 \times 0.799 \sqrt{\frac{835}{30.11 \times 27.41}} \times 0.472 = 1944 \text{ fpm} \checkmark$$

ACFM: 35809 ✓

SCFM: 18905 ✓

%EA: 11.8 ✓

$$\%I = \frac{1039 \times \quad \times \quad \times \quad \times (\quad)^2}{\quad} = \quad \%$$

Job No. 90-222Job Name ELKSTONERun No. 6 (CONDITION #1)Location EB-14 EXHAUSTDate 6 NOVEMBER 1990Operator RAIMONDI, B.11Sample Box No. 30 Meter Box No. 10

VELOCITY/HUMIDITY FIELD DATA

Read and record at the
start of each test point.Purge to: ---Purge time: ---

METCO ENVIRONMENTAL

Ambient Temp. °F 72Assumed Moisture % 17.0Probe Length 3'C Factor --- to referenceInitial Leak @ 15.0 "Hg = 0.000 cfmFinal Leak @ 9.0 "Hg = 0.002 cfm

Point	Clock Time	Dry Gas Meter, CF	ΔP_s Pitot in. H ₂ O	P_m Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	T_s Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	T_m Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
A8	1812	450.615	0.18	2.00	2.00	7.0	340	260	253	68	87	85	WATER
A7	1817	451.47	0.18	2.00	2.00	7.0	343	261	250	65	87	85	OR SAT
A6	1822	458.44	0.19	2.00	2.00	7.0	345	260	253	65	90	85	
A5	1827	462.38	0.21	2.00	2.00	7.0	350	259	255	66	91	85	
A4	1832	466.15	0.27	2.00	2.00	7.0	434	259	255	65	92	86	
A3	1837	470.18	0.26	2.00	2.00	7.0	469	260	255	65	92	83	
A2	1842	474.316	0.24	---	---	---	480	---	---	---	---	---	
A1			0.14	---	---	---	456	---	---	---	---	---	
END			---	---	---	---	---	---	---	---	---	---	
B8			0.33	---	---	---	---	---	---	---	---	---	
B7			0.23	---	---	---	362	---	---	---	---	---	
B6			0.23	---	---	---	374	---	---	---	---	---	
B5			0.24	---	---	---	382	---	---	---	---	---	
B4			0.23	---	---	---	394	---	---	---	---	---	
B3			0.24	---	---	---	378	---	---	---	---	---	
B2			0.25	---	---	---	356	---	---	---	---	---	
B1			0.18	---	---	---	354	---	---	---	---	---	
END	ALL		---	---	---	---	350	---	---	---	---	---	

Pitot Tube Calibration Factor C_p 0.799Volume Collected V_m 24.080 ft³ Baro. Press. P_b 30.10 "HgWater Collected V_w 112.5 ml Probe Tip Dia. D_n --- in.Time of Test T_t 30 min. % CO₂ 8.5 % CO 8.5Stack Pressure P_s +0.17 "H₂O % O₂ 3.0 % N₂ 88.5Area Stack A_s 2653 in²Pitot Tube No. 5 Barometer No. 15Probe Tip No. --- V_m = Dry Gas Meter Calibration Factor 1.06 X 23.701

Dry Gas Meter Reading --- ft³ - $\left(T_t - \left(T_t \text{ min} \times \text{Leak Rate} \right) \right)$

$M_F = \text{---$ $M_T = \text{---$

Job No. 90-22

Job Name FIRESTONE

Run No. 1 CONDITIONAL #2

Location EB-14 EXHAUST

Date 7 NOVEMBER 1990

Operator RAIMUND, B. II

Sample Box No. 30 Meter Box No. 10

VENTILATION FIELD DATA

METCO ENVIRONMENTAL

Ambient Temp. °F 77

Assumed Moisture % 18.0

Probe Length 2'

C Factor --- to reference

Initial Leak @ 15.0 "Hg = 0.000 cfm

Final Leak @ 9.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	P _m		Pump Vacuum In. Hg Gauge	T _s Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
			Pitot in. H ₂ O	Orifice ΔH in. H ₂ O						Inlet	Outlet	
A 8	0910	974.542	0.03	2.00	6.5	265	244	250	65	72	72	11/20/90
A 7	0915	976.50	0.03	2.00	6.5	277	241	255	63	74	73	08/5/91
A 6	0920	982.21	0.03	2.00	7.0	282	244	258	63	76	73	
A 5	0925	986.85	0.04	2.00	7.0	286	245	264	57	80	74	
A 4	0930	989.90	0.04	2.00	7.0	301	250	260	57	81	74	
A 3	0935	993.80	0.05	2.00	7.0	316	252	260	58	84	74	
A 2	0940	997.500	0.05	---	---	333	---	---	---	---	---	
A 1	END	---	0.03	---	---	300	---	---	---	---	---	
END	---	---	---	---	---	---	---	---	---	---	---	
B 8	---	---	0.04	---	---	285	---	---	---	---	---	
B 7	---	---	0.04	---	---	280	---	---	---	---	---	
B 6	---	---	0.04	---	---	293	---	---	---	---	---	
B 5	---	---	0.04	---	---	303	---	---	---	---	---	
B 4	---	---	0.04	---	---	303	---	---	---	---	---	
B 3	---	---	0.04	---	---	303	---	---	---	---	---	
B 2	---	---	0.03	---	---	296	---	---	---	---	---	
B 1	---	---	0.02	---	---	290	---	---	---	---	---	
END	ALL	---	---	---	---	---	---	---	---	---	---	

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.325 ft³ Baro. Press. P_b 30.17 "Hg

Water Collected V_w 96.0 ml Probe Tip Dia. D_n --- in.

Time of Test T_t 30 min. % CO₂ 9.5 % CO 0.0

Stack Pressure P_s +0.03 "H₂O % O₂ 3.2 % N₂ 87.3

Area Stack A_s 2653 in²

Pitot Tube No. 5 Barometer No. 15

Probe Tip No. ---

V_m = Dry Gas Meter Calibration Factor 10/6 X 22.958

Dry Gas Meter Reading --- ft³ (T_t --- min X Rate --- cfm)
M_F = --- M_T = ---

Impinger Box No. 30

Impinger 1 Final Weight 677.7
Initial Weight 616.0
Increase

Impinger 2 Final Weight 634.2
Initial Weight 614.0
Increase

Impinger 3 Final Weight 506.5
Initial Weight 502.9
Increase

Impinger 4 Final Weight 855.7
Initial Weight 850.2
Increase

Impinger 5 Final Weight _____
Initial Weight _____
Increase

Impinger 6 Final Weight _____
Initial Weight _____
Increase

Water Weight Gain Impinger 1 66.7
Impinger 2 20.2
Impinger 3 3.6
Impinger 4 5.5
Impinger 5 _____
Impinger 6 _____

Total 96.0 = V_w

$P_b = 30.14$ ✓ $\%CO_2 = 9.5$ ✓
 $V_m = 23.325$ ✓ $\%O_2 = 3.2$ ✓
 $V_w = 96.0$ ✓ $\%CO = 0.0$ ✓
 $P_m = 2.000$ ✓ $\%N_2 = 87.3$ ✓
Avg $\Delta P = 0.037$ ✓ $A_s = 2653$
Avg $\sqrt{\Delta P} = 0.191$ ✓ $D_n =$ _____
 $C_p = 0.799$ ✓ $T_t = 30$ ✓
 $P_s = 30.03$ H_2O 30.14 "Hg ✓
 $T_m = 76$ °F ✓ 536 °R ✓
 $T_s = 294$ °F ✓ 754 °R ✓

Moisture Content: $\%M = 16.30$ ✓ $M_d = 0.8370$ ✓ $MW_d = 29.648$ ✓ $MW = 27.75$ ✓

$$V_{m_{std}} = 17.65 V_m \left(\frac{P_b + \frac{P_m}{13.6}}{T_m + 460} \right) = 17.65 \times 23.325 \left(\frac{30.14 + \frac{2.00}{13.6}}{76 + 460} \right) = 23.263 \text{ sft}^3 \checkmark$$

$$0.775 \text{ scfm} \checkmark$$

$$V_{w_{gas}} = 0.0472 \times V_w = 0.0472 \times 96.0 = 4.531 \text{ sft}^3 \checkmark$$

$$\% \text{ Moisture} = \frac{V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}} \times 100 = \frac{4.531}{4.531 + 23.263} \times 100 = 16.30 \% \checkmark$$

$$V_s = 5123.8 \times 0.799 \times \sqrt{\frac{754}{30.14 \times 27.75}} \times 0.191 = 742 \text{ fpm} \checkmark$$

ACFM: 13.678 ✓

SCFM: 810.8 ✓

%EA: 16.1 ✓

$$\%I = \frac{1039 \times \quad \times \quad \times \quad \times (\quad)^2}{\quad} = \quad \%$$

Job No. 90-22

Job Name ELBERTALE

Run No. 2 (CADDIS) 2

Location EB-114 EXHAUST

Date 7 NOVEMBER 1990

Operator ANDREW, B.11

Sample Box No. 30 Meter Box No. 10

VENTILATION FIELD DATA

METCO ENVIRONMENTAL

Ambient Temp. °F 81

Assumed Moisture % 18.0

Probe Length 3'

C Factor to reference

Initial Leak 95.0 "Hg = 0.000 cfm

Final Leak @ 12.0 "Hg = 0.001 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	T _s			T _m Pitot Tube Temp. °F			Remarks
				Desired	Actual		Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Inlet	Outlet	
A8	1005	997.830	0.02	2.00	2.00	6.5	283	201	255	65	77	77	1078 OK
A7	1030	8.000	0.03	2.00	2.00	6.5	278	208	253	63	80	77	1078 OK
A6	1035	5.82	0.03	2.00	2.00	6.5	279	238	255	60	83	77	1050 OK
A5	1040	9.60	0.03	2.00	2.00	6.5	284	247	252	60	85	77	
A4	1045	13.65	0.03	2.00	2.00	6.5	287	250	254	61	87	78	
A3	1050	17.58	0.05	2.00	2.00	7.0	318	254	253	61	89	78	
A2	1055	21.00	0.04	—	—	—	324	—	—	—	—	—	
END	—	—	0.04	—	—	—	320	—	—	—	—	—	
B8	—	—	0.03	—	—	—	283	—	—	—	—	—	
B7	—	—	0.03	—	—	—	285	—	—	—	—	—	
B6	—	—	0.03	—	—	—	285	—	—	—	—	—	
B5	—	—	0.03	—	—	—	295	—	—	—	—	—	
B4	—	—	0.03	—	—	—	300	—	—	—	—	—	
B3	—	—	0.03	—	—	—	299	—	—	—	—	—	
B2	—	—	0.02	—	—	—	297	—	—	—	—	—	
B1	—	—	0.02	—	—	—	282	—	—	—	—	—	
END	—	—	0.01	—	—	—	280	—	—	—	—	—	

D-16

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.642 ft³ Baro. Press. P_b 30.14 "Hg

Water Collected V_w 87.7 ml Probe Tip Dia. D_n in.

Time of Test T_t 30 min. % CO₂ 2.8 % CO 0.0

Stack Pressure P_s 10.03 "H₂O % O₂ 8.6 % N₂ 87.4

Area Stack A_s 26.53 in²

Pitot Tube No. 5

Barometer No. 15

Probe Tip No.

V_m = Dry Gas Meter Calibration Factor 1.016 x 23.270

Dry Gas Meter Reading ft³ (T_t min x Leak Rate cfm)

M_F = M_T =

Water Weight Gain

Impinger 1	72.6
Impinger 2	12.3
Impinger 3	1.8
Impinger 4	1.0
Impinger 5	
Impinger 6	
Total	87.71 = V _w

$$V_{SO_2} = -$$

$$V_w =$$

Impinger 1	Final Weight	750.3
	Initial Weight	672.7
	Increase	

Impinger 2	Final Weight	646.5
	Initial Weight	637.2
	Increase	

Impinger 3	Final Weight	508.3
	Initial Weight	526.5
	Increase	

Impinger 4	Final Weight	856.7
	Initial Weight	855.7
	Increase	

Impinger 5	Final Weight	
	Initial Weight	
	Increase	

Impinger 6	Final Weight	
	Initial Weight	
	Increase	

Filter #	Final Weight	Initial Weight	Increase
----------	--------------	----------------	----------

Moisture Content:

$$\%M = 15.03 \quad M_d = 0.8497 \quad M_w = 29.680 \quad M_w = 27.92$$

$$V_{m, std} = 17.65 \quad V_m = \left(\frac{P_b + P_m}{P_m} \right) \left(\frac{T_m + 460}{13.6} \right) = 17.65 \times 23.642 = 415.5$$

$$V_{gas} = 0.0472 \times V_m = 0.0472 \times 415.5 = 19.71 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{m, std} + V_{gas}}{V_{gas}} \times 100 = \frac{17.65 + 19.71}{19.71} \times 100 = 15.03 \%$$

$$V_{gas} = 5123.8 \times 0.799 \sqrt{\frac{752}{0.14 \times 27.92}} \times 0.165 = 654 \text{ fpm}$$

$$\% \text{ Moisture} = \frac{V_{m, std} + V_{gas}}{V_{gas}} \times 100 = \frac{17.65 + 19.71}{19.71} \times 100 = 15.03 \%$$

$$V_s = 5123.8 \times 0.799 \sqrt{\frac{752}{0.14 \times 27.92}} \times 0.165 = 654 \text{ fpm}$$

$$\%EA = \frac{SCFM}{ACFM} = \frac{7268}{12050} = 60.31$$

Job No. 90-22

Job Name FIRESTONE

Run No. 3 (CORROSION) #2

Location EB-114 EXHAUST

Date 7 NOVEMBER 1990

Operator RAUDMAN, B.I.

Sample Box No. 30 Meter Box No. 10

VELOCITY/EXHAUST FIELD DATA

Read and record at the start of each test point.

Purge to:

Purge time:

METCO ENVIRONMENTAL

Ambient Temp. °F 75

Assumed Moisture % 18.0

Probe length 3'

C Factor to reference

Initial Leak @ 45.0 "Hg = 0.002 cfm

Final Leak @ 8.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
1	11:38	21.855	0.03	2.00	2.00	7.0	265	247	251	58	80	80	14705
2	11:43	25.23	0.03	2.00	2.00	7.0	274	250	253	58	83	80	0550
3	11:48	29.11	0.03	2.00	2.00	7.0	279	251	256	57	85	82	
4	11:53	32.44	0.03	2.00	2.00	7.0	286	254	257	56	87	82	
5	11:58	36.23	0.03	2.00	2.00	7.0	303	255	256	57	88	82	
6	12:03	41.02	0.03	2.00	2.00	7.0	317	256	260	58	89	84	
7	12:08	44.865	0.03	2.00	2.00	7.0	332	256	260	58	89	84	
8	END	—	0.01	—	—	—	344	—	—	—	—	—	
9	—	—	0.03	—	—	—	260	—	—	—	—	—	
10	—	—	0.03	—	—	—	276	—	—	—	—	—	
11	—	—	0.03	—	—	—	283	—	—	—	—	—	
12	—	—	0.03	—	—	—	290	—	—	—	—	—	
13	—	—	0.03	—	—	—	291	—	—	—	—	—	
14	—	—	0.02	—	—	—	291	—	—	—	—	—	
15	—	—	0.02	—	—	—	285	—	—	—	—	—	
16	—	—	0.02	—	—	—	287	—	—	—	—	—	
17	—	—	0.01	—	—	—	278	—	—	—	—	—	
18	END	—	—	—	—	—	—	—	—	—	—	—	

D-18

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.886 ft³ Baro. Press. P_b 30.14 "Hg

Water Collected V_w 95.5 ml Probe Tip Dia. D_n in.

Time of Test T_t 30 min. % CO₂ 8.5 % CO 0.0

Stack Pressure P_s ±0.03 "H₂O % O₂ 3.0 % N₂ 87.5

Area Stack A_s 2653 in²

Pitot Tube No. 5

Probe Tip No.

V_m = Dry Gas Meter Calibration Factor 1.016 x 23.510

Dry Gas Meter Reading ft³ - $(T_t - T_r) \frac{M_r}{M_t} = \frac{M_r}{M_t} \frac{P_r}{P_t} \frac{T_t}{T_r}$ min x Leak Rate cfm

Impinger Box No. 30

Water Weight Gain

Impinger 1 74.8

Impinger 2 10.9

Impinger 3 0.7

Impinger 4 9.1

Impinger 5

Impinger 6

Total

95.5

$P_b = 30.14$

$V_m = 23.86$

$V_w = 95.5$

$P_m = 0.0001$

$Avg \Delta P = 0.026$

$Avg \Delta P = 0.160$

$C_p = 0.799$

$P_s = 30.14$

$T_m = 84$

$T_s = 289$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

$T_s = 749$

Final Weight 825.1
Initial Weight 750.3

Final Weight 657.4
Initial Weight 646.5

Final Weight 509.0
Initial Weight 508.3

Final Weight 865.8
Initial Weight 856.7

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Final Weight
Initial Weight

Impinger 1

Impinger 2

Impinger 3

Impinger 4

Impinger 5

Impinger 6

Impinger #

Final Weight

Initial Weight

Final Weight

Initial Weight

Final Weight

Initial Weight

Final Weight

Initial Weight

Final Weight

Initial Weight

Moisture Content:

$$\%M = \frac{16.11}{16.11 + 0.5359} \times 100 = 95.5$$

$$V_{gas} = 0.0472 \times V_m = 0.0472 \times 95.5 = 4.508 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{gas}}{V_{gas} + V_{std}} \times 100 = \frac{4.508}{4.508 + 23.472} \times 100 = 16.11\%$$

$$V_s = 5123.8 \times 0.799 \times \frac{749}{30.14 \times 27.76} \times 0.160 = 620 \text{ fpm}$$

$$\%I = \frac{1039 \times 100}{1039 \times 100} = 100\%$$

$$\%EA = 14.9$$

$$\%SCFM = 68.37$$

$$\%ACFM = 119.18$$

Job No. 90-22

Job Name FINASTOKE

Run No. 4 CONDITIAL 12

Location EB-114 EXH2457

Date 7 NOVEMBER 1990

Operator ANDREW B. ILL

Sample Box No. 30 Meter Box No. 10

LEAKITY/FINASTOKE FIELD DATA

METCO ENVIRONMENTAL

Ambient Temp. °F 28

Assumed Moisture % 18.0

Probe length 3'

C Factor to reference

Initial Leak @ 15.0 "Hg = 0.000 cfm

Final Leak @ 9.0 "Hg = 0.002 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
B8	1416	35.430	0.12	2.00	2.00	7.0	310	243	260	20	80	80	1000
B7	1421	38.922	0.12	2.00	2.00	7.0	322	248	258	60	83	83	1000
B6	1426	52.720	0.11	2.00	2.00	7.0	320	254	256	56	84	83	1000
B5	1431	56.722	0.13	2.00	2.00	7.0	316	258	255	56	85	83	1000
B4	1436	60.533	0.12	2.00	2.00	7.0	316	256	259	58	89	88	1000
B3	1441	69.688	0.13	2.00	2.00	7.0	310	257	260	60	91	85	1000
B2	1446	68.343	0.14	2.00	2.00	7.0	315	257	260	60	91	85	1000
B1	1450	—	0.08	—	—	—	311	—	—	—	—	—	—
END	—	—	—	—	—	—	—	—	—	—	—	—	—
A8	—	—	0.10	—	—	—	287	—	—	—	—	—	—
A7	—	—	0.11	—	—	—	223	—	—	—	—	—	—
A6	—	—	0.11	—	—	—	307	—	—	—	—	—	—
A5	—	—	0.11	—	—	—	349	—	—	—	—	—	—
A4	—	—	0.16	—	—	—	320	—	—	—	—	—	—
A3	—	—	0.18	—	—	—	383	—	—	—	—	—	—
A2	—	—	0.17	—	—	—	340	—	—	—	—	—	—
A1	—	—	0.10	—	—	—	385	—	—	—	—	—	—
END	ALL	—	—	—	—	—	—	—	—	—	—	—	—

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.595 ft³ Baro. Press. P_b 30.10 "Hg

Water Collected V_w 28.3 ml Probe Tip Dia. D_n — in.

Time of Test T_t 30 min. % CO₂ 11.2 % CO 0.0

Stack Pressure P_s 0.10 "H₂O % O₂ 3.3 % N₂ 85.5

Area Stack A_s 265.3 in²

Pitot Tube No. 5

Probe Tip No. —

Dry Gas Meter Calibration Factor 1.016 X 23.223

Dry Gas Meter Reading — ft³ - (T_t — min X Leak Rate — cfm)

M_F = — M_T = —

Barometer No. 15

Impinger Box No. 30

Impinger 1
Final Weight 874.6
Initial Weight 825.1
Increase

Impinger 2
Final Weight 679.2
Initial Weight 652.9
Increase

Impinger 3
Final Weight 510.8
Initial Weight 504.0
Increase

Impinger 4
Final Weight 871.0
Initial Weight 865.8
Increase

Impinger 5
Final Weight
Initial Weight
Increase

Impinger 6
Final Weight
Initial Weight
Increase

Filter #
Final Weight
Initial Weight
Increase

Moisture Content:

$$\%M = \frac{13.76}{M_D} = \frac{0.8627}{M_D} = \frac{29.927}{M_D} = 28.28$$

$$V_m^{\text{std}} = 17.65 V_m \left(\frac{p_b + \frac{p_m}{13.6}}{\frac{T_m}{460} + 1} \right) = 17.65 \times 23.595 \left(\frac{30.10 + 13.6}{84 + 460} \right) = 23.155 \text{ sft}^3$$

$$0.772 \text{ scfm} \times 17.65 = 13.76 \text{ sft}^3$$

$$V_{\text{gas}} = 0.0472 \times V_m = 0.0472 \times 78.3 = 3.696 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{\text{gas}} + V_m^{\text{std}}}{V} \times 100 = \frac{3.696 + 23.155}{30.11 \times 28.28} \times 100 = 13.76 \%$$

$$V_s = 5123.8 \times 0.799 \times \frac{790}{1790} \times 0.351 = 1384 \text{ fpm}$$

$$\%I = \frac{1039 \times \text{---} \times \text{---} \times \text{---} \times \text{---}}{\text{---}} = \text{---}$$

ACFM: 25500
SCFM: 14848
%EA: 17.0

Water Weight Gain

Impinger 1 49.5

Impinger 2 21.8

Impinger 3 1.8

Impinger 4 5.2

Impinger 5

Impinger 6

Total

78.3

V

V

SO₂

V

$P_b = 30.101$
 $V_m = 23.595$
 $V = 78.3$
 $\%CO_2 = 3.3$
 $\%CO = 0.0$
 $\%N_2 = 85.5$
 $A_s = 2653$
 $D_n =$
 $T_t = 30$
 $C_p = 0.799$
 $P_s = 30.10$
 $T_m = 84$
 $T_s = 330$

Job No. 90-22

Job Name ELLSBORO

Run No. 5 CONCRETE '02

Location EB-114 EXHAUST

Date 7 APRIL 1990

Operator Handy, Bill

Sample Box No. 30 Meter Box No. 10

WELLS/FIELD DATA

Read and record at the start of each test point.

Purge to: ---

Purge time: ---

METCO ENVIRONMENTAL

Ambient Temp. °F 76

Assumed Moisture % 14.0

Probe length 3'

C Factor --- to reference

Initial Leak 0.50 "Hg = 0.000 cfm

Final Leak @ 10.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
A8	1526	68.752	0.11	2.00	2.00	2.0	242	220	259	53	86	86	14.5
A7	1531	72.85	0.12	2.00	2.00	2.0	303	234	258	56	89	86	14.5
A6	1536	77.00	0.13	2.00	2.00	2.0	304	240	258	56	91	87	14.5
A5	1541	81.15	0.13	2.00	2.00	2.0	303	259	256	59	93	87	14.5
A4	1546	84.65	0.15	2.00	2.00	2.0	248	264	260	60	95	87	14.5
A3	1551	88.60	0.17	2.00	2.00	2.0	249	263	259	61	95	87	14.5
A2	1556	92.633	0.18	---	---	---	302	---	---	---	---	---	---
A1	EUD	---	0.15	---	---	---	367	---	---	---	---	---	---
EUD	---	---	---	---	---	---	---	---	---	---	---	---	---
B8	---	---	0.13	---	---	---	302	---	---	---	---	---	---
B7	---	---	0.14	---	---	---	303	---	---	---	---	---	---
B6	---	---	0.15	---	---	---	337	---	---	---	---	---	---
B5	---	---	0.15	---	---	---	345	---	---	---	---	---	---
B4	---	---	0.14	---	---	---	333	---	---	---	---	---	---
B3	---	---	0.14	---	---	---	330	---	---	---	---	---	---
B2	---	---	0.14	---	---	---	322	---	---	---	---	---	---
B1	---	---	0.11	---	---	---	304	---	---	---	---	---	---
EUD	ALL	---	---	---	---	---	---	---	---	---	---	---	---

D-22

Pitot Tube Calibration Factor C_p 0.999

Volume Collected V_m 24.263 ft³ Baro. Press. P_b 30.10 "Hg

Water Collected V_w 81.8 ml Probe Tip Dia. D_n --- in.

Time of Test T_t 30 min. % CO₂ 11.6 % CO 0.0

Stack Pressure P_s 20.18 "H₂O % O₂ 3.0 % N₂ 85.4

Area Stack A_s 2653 in²

Pitot Tube No. 5 Barometer No. 15

Probe Tip No. ---

Dry Gas Meter Calibration Factor 1.016 x 23.851

Dry Gas Meter Reading --- ft³ - $\left(\frac{T}{T_t} \right)$ min x Leak Rate --- cfm

$M_F =$ --- $M_T =$ ---

Impinger Box No. 30

Water Weight Gain

Impinger 1 60.8

Impinger 2 15.3

Impinger 3 11.6

Impinger 4 4.1

Impinger 5

Impinger 6

$V_{SO_2} =$
 $V_w =$

Impinger 1
Final Weight 673.5
Initial Weight 618.7
Increase

Impinger 2
Final Weight 694.5
Initial Weight 679.2
Increase

Impinger 3
Final Weight 512.9
Initial Weight 510.8
Increase

Impinger 4
Final Weight 875.1
Initial Weight 871.0
Increase

Impinger 5
Final Weight
Initial Weight
Increase

Impinger 6
Final Weight
Initial Weight
Increase

Filter #

Final Weight
Initial Weight

Increase

Moisture Content:

$$\%M = \frac{14.06 M_d}{29976 MW} = 0.8599 \quad \frac{30.10}{29976} = 0.001004$$

$$V_{m std} = 17.65 V_m \left(\frac{P_b + P_m}{T_m + 460} \right) = 17.65 \times 27.263 \left(\frac{30.10 + 13.6}{89 + 460} \right) = 23.594 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{w gas} + V_{m std}}{V_{w gas}} \times 100 = \frac{3.861 + 23.594}{3.861} \times 100 = 1406 \%$$

$$V_{w gas} = 0.0472 \times V_w = 0.0472 \times 81.8 = 3.861 \text{ sft}^3$$

$$V_s = 5123.8 \times 0.779 \times \frac{780}{30.11 \times 28.29} \times 0.373 = 1461 \text{ fpm}$$

$$\%I = \frac{1039 \times \dots \times \dots \times \dots \times \dots}{\dots} = \dots$$

ACFM: 2692.1
SCFM: 1581.4
FEA: 15.3

Job No. 90-82

Job Name FIRESTONE

Run No. 6 CONDITIOE 12

Location EB-119 EXHAUST

Date 7 NOVEMBER 1990

Operator RANDOLPH, B. J.

Sample Box No. 30 Meter Box No. 10

LEADY WAS FIELD DATA

Read and record at the start of each test point.

Purge to: ---

Purge time: ---

METCO ENVIRONMENTAL

Ambient Temp. °F 76

Assumed Moisture % 16.0

Probe Length 3'

C Factor --- to reference

Initial Leak @ 15.0 "Hg = 0.002 cfm

Final Leak @ 10.0 "Hg = 2.00 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
A 8	16:33	93.050	0.10	2.00	2.00	6.0	300	243	259	62	88	88	14725
A 7	16:38	91.05	0.11	2.00	2.00	6.0	300	250	259	62	89	88	14725
A 6	16:43	101.02	0.13	2.00	2.00	6.0	313	257	256	65	93	88	14725
A 5	16:48	105.10	0.13	2.00	2.00	6.0	311	259	260	67	94	88	14725
A 4	16:53	109.23	0.14	2.00	2.00	6.0	320	258	261	68	94	88	14725
A 3	16:58	112.92	0.17	2.00	2.00	6.0	320	259	259	70	94	88	14725
A 2	17:03	116.775	0.18	---	---	---	323	---	---	---	---	---	---
A 1	END	---	0.10	---	---	---	300	---	---	---	---	---	---
END	---	---	---	---	---	---	---	---	---	---	---	---	---
B 8	---	---	0.12	---	---	---	343	---	---	---	---	---	---
B 7	---	---	0.13	---	---	---	330	---	---	---	---	---	---
B 6	---	---	0.15	---	---	---	338	---	---	---	---	---	---
B 5	---	---	0.15	---	---	---	336	---	---	---	---	---	---
B 4	---	---	0.14	---	---	---	330	---	---	---	---	---	---
B 3	---	---	0.15	---	---	---	335	---	---	---	---	---	---
B 2	---	---	0.14	---	---	---	330	---	---	---	---	---	---
B 1	---	---	0.11	---	---	---	310	---	---	---	---	---	---
END	ALL	---	---	---	---	---	---	---	---	---	---	---	---

D-24

Pitot Tube Calibration Factor C_p 0.795

Volume Collected V_m 24.105 ft³ Baro. Press. P_b 30.10 "Hg

Water Collected V_w 82.8 ml Probe Tip Dia. D_n --- in.

Time of Test T_t 30 min. % CO₂ 11.8 % CO 0.0

Stack Pressure P_s +0.14 "H₂O % O₂ 3.3 % N₂ 84.9

Area Stack A_s 2653 in²

Pitot Tube No. 5 Barometer No. 15

Probe Tip No. ---

Dry Gas Meter Calibration Factor 1016 x 23.725

Dry Gas Meter Reading --- ft³ - (T_t --- min x Leak Rate --- cfm)

M_F = --- M_T = ---

Impinger Box No. 30

Water Weight Gain

Impinger 1 67.2

Impinger 2 9.8

Impinger 3 1.1

Impinger 4 4.7

Impinger 5

Impinger 6

$V_{SO_2} =$
 $V_w =$

Total 82.8 = V_w

$P_b = 30.10$ ✓ $\%CO_2 = 11.8$ ✓

$V_m = 29.105$ ✓ $\%O_2 = 3.3$ ✓

$V_w = 82.8$ ✓ $\%CO = 0.0$ ✓

$P_m = 0.0201$ ✓ $\%N_2 = 84.9$ ✓

$Avg \Delta P = 0.136$ ✓ $A_s = 2653$ ✓

$C_p = 0.739$ ✓ $T_t = 30$ ✓

$P_s = 70.14$ ✓ $H_2O = 30.11$ ✓

$T_m = 90$ ✓ $F_v = 780$ ✓

$T_s = 320$ ✓ $F_v = 780$ ✓

Impinger 1

Final Weight 740.7
Initial Weight 673.5

Impinger 2

Final Weight 704.3
Initial Weight 699.3

Impinger 3

Final Weight 513.5
Initial Weight 512.7

Impinger 4

Final Weight 579.8
Initial Weight 576.7

Impinger 5

Final Weight
Initial Weight

Impinger 6

Final Weight
Initial Weight

Filter #

Final Weight
Initial Weight

Moisture Content:

$\%M = 4.09$ ✓ $M_p = 0.859$ ✓ $M_{ND} = 30.020$ ✓ $M_{ND} = 38.38$ ✓

$V_{m \text{ std}} = 17.65$ ✓

$\left(\frac{P_b + P_m}{T_m + 460} \right) = 17.65 \times 29.105$

$V_{w \text{ gas}} = 0.0472 \times V_m = 0.0472 \times 82.8 = 3.908$ sft³

$\% \text{ Moisture} = \frac{V_{w \text{ gas}}}{V_{m \text{ std}} + V_{w \text{ gas}}} \times 100 = \frac{3.908}{3.908 + 23.531} \times 100 = 14.29$ %

$V_s = 5123.8 \times 0.799$

$\frac{780}{30.11 \times 28.38} \times 0.367 = 1437$ fpm

$\%I = 1039 \times \frac{1}{2} =$

$\frac{11}{84} \times 15598 = 26478$ ✓

$\%EA: 17.2$ ✓

$\%SCFM: 15598$ ✓

Job No. 90-22

Job Name FIRESTONE

Run No. 1

Location EB-114 EXHAUST

Date 8 NOVEMBER 1990

Operator RAMONA, B11

Sample Box No. 30 Meter Box No. 0

Leak Test FIELD DATA

Read and record at the start of each test point.

Purge to: ---

Purge time: ---

METCO ENVIRONMENTAL

Ambient Temp. °F 69

Assumed Moisture % 110

Probe Length 3'

C Factor --- to reference

Initial Leak 0.50 "Hg = 0.000 cfm

Final Leak @ 10.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Temperatures °F			Dry Gas Temp. °F			Remarks
				Desired	Actual		Stack	Probe	Oven	Effluent	Inlet	Outlet	
48	0855	158.180	0.14	2.00	2.00	4.5	309	261	252	69	72	72	1078
47	0855	122.00	0.14	2.00	2.00	4.5	317	262	250	65	72	72	0558
46	0900	124.10	0.14	2.00	2.00	4.5	302	265	256	65	74	72	
45	0905	124.70	0.15	2.00	2.00	4.5	306	265	256	65	74	72	
44	0910	133.40	0.17	2.00	2.00	4.5	374	265	259	67	77	73	
43	0915	137.31	0.20	2.00	2.00	4.5	402	265	260	67	78	73	
42	0900	141.370	0.20	---	---	---	404	---	---	---	---	---	
41	END	---	0.17	---	---	---	---	---	---	---	---	---	
38	---	---	0.14	---	---	---	333	---	---	---	---	---	
37	---	---	0.16	---	---	---	343	---	---	---	---	---	
36	---	---	0.15	---	---	---	352	---	---	---	---	---	
35	---	---	0.15	---	---	---	358	---	---	---	---	---	
34	---	---	0.15	---	---	---	355	---	---	---	---	---	
33	---	---	0.17	---	---	---	335	---	---	---	---	---	
32	---	---	0.16	---	---	---	338	---	---	---	---	---	
B1	---	---	0.10	---	---	---	332	---	---	---	---	---	
END	ALL	---	---	---	---	---	---	---	---	---	---	---	

D-26

Pitot Tube Calibration Factor C_p 0.995

Volume Collected V_m 23.56 ft³ Baro. Press. P_b 29.98 "Hg

Water Collected V_w 90.5 ml Probe Tip Dia. D_n --- in.

Time of Test T_t 30 min. % CO₂ 11.4 % CO 0.0

Stack Pressure P_s 10.14 "H₂O % O₂ 2.8 % N₂ 65.8

Area Stack A_s 2653 in²

Pitot Tube No. 5

Probe Tip No. ---

Dry Gas Meter Calibration Factor 1016 x 23.190

Dry Gas Meter Reading --- ft³ - (T_t min x Leak Rate cfm)

M_p = --- M_T = ---

Filter #	Final Weight	Initial Weight	Increase
Impinger 1	657.3	607.3	Increase
Impinger 2	625.1	600.0	Increase
Impinger 3	519.5	514.0	Increase
Impinger 4	848.2	841.3	Increase
Impinger 5			Increase
Impinger 6			Increase

Water Weight Gain

Impinger 1	53.0
Impinger 2	25.1
Impinger 3	5.5
Impinger 4	6.9
Impinger 5	
Impinger 6	
Total	90.5

Moisture Content:

$$\%M = \frac{V_{m, std} - V_{m, gas}}{V_{m, gas}} \times 100 = \frac{17.65 - 0.0472 \times 90.5}{0.0472 \times 90.5} \times 100 = 15.38\%$$

$$V_{m, std} = 17.65 \text{ V}_m = 17.65 \times \left(\frac{P_b + P_m}{P_b + 460} \right) = 17.65 \times 23.521 = 412.2 \text{ sft}^3$$

$$V_{m, gas} = 0.0472 \times V = 0.0472 \times 90.5 = 4.272 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{m, std} - V_{m, gas}}{V_{m, gas}} \times 100 = \frac{4.272 - 0.0472 \times 90.5}{0.0472 \times 90.5} \times 100 = 15.38\%$$

$$V_s = 5123.8 \times 0.799 = 4099 \text{ sft}^3$$

$$V_s = 5123.8 \times \frac{811}{2999 \times 28.10} \times 0.393 = 1578 \text{ fpm}$$

ACFM: 29079
SCFM: 1611
%EA: 14.0

Job No. 92-202

Job Name FIRESTONE

Run No. 2 (00000001) 3

Location EB-114 EXHAUST

Date 8 NOVEMBER 1990

Operator PAUL D. BELL

Sample Box No. 30 Meter Box No. 10

VERIFY/LOGS FIELD DATA

Read and record at the start of each test point.

Purge to: ---

Purge time: ---

METCO ENVIRONMENTAL

Ambient Temp. °F 73

Assumed Moisture % 16.0

Probe Length 3'

C Factor --- to reference

Initial Leak @ 150"Hg = 0.000 cfm

Final Leak @ 90"Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F		Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual		Stack	Probe				Inlet	Outlet	
A 8	1032	141.59	0.10	2.00	2.00	5.0	300	245	268	64	24	24	24	1472
A 7	1037	145.04	0.12	2.00	2.00	5.0	310	250	268	64	24	24	24	1472
A 6	1042	148.92	0.13	2.00	2.00	5.0	316	246	258	65	24	24	24	1450
A 5	1047	152.73	0.13	2.00	2.00	5.0	320	256	251	67	24	24	24	1450
A 4	1052	156.65	0.14	2.00	2.00	5.0	323	260	255	67	24	24	24	1450
A 3	1057	160.57	0.17	2.00	2.00	5.0	327	261	257	68	24	24	24	1450
A 2	1102	164.48	0.18	---	---	---	---	---	---	---	---	---	---	---
A 1	END	---	0.10	---	---	---	---	---	---	---	---	---	---	---
END	---	---	---	---	---	---	---	---	---	---	---	---	---	---
B 8	---	---	0.11	---	---	---	---	---	---	---	---	---	---	---
B 7	---	---	0.14	---	---	---	---	---	---	---	---	---	---	---
B 6	---	---	0.15	---	---	---	---	---	---	---	---	---	---	---
B 5	---	---	0.15	---	---	---	---	---	---	---	---	---	---	---
B 4	---	---	0.15	---	---	---	---	---	---	---	---	---	---	---
B 3	---	---	0.15	---	---	---	---	---	---	---	---	---	---	---
B 2	---	---	0.15	---	---	---	---	---	---	---	---	---	---	---
B 1	---	---	0.10	---	---	---	---	---	---	---	---	---	---	---
END	ALL	---	---	---	---	---	---	---	---	---	---	---	---	---

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.528 ft³ Baro. Press. P_b 29.94 "Hg

Water Collected V_w 80.9 ml Probe Tip Dia. D_n --- in.

Time of Test T_t 30 min. % CO₂ 11.2 % CO 8.8

Stack Pressure P_s 10.14 "H₂O % O₂ 3.0 % N₂ 85.8

Area Stack A_s 2653 in²

Pitot Tube No. 5 Barometer No. 15

Probe Tip No. ---

Dry Gas Meter Calibration Factor 1.016 x 23.157

Dry Gas Meter Reading --- ft³ (T_t --- min x Leak Rate --- cfm)

M_F = --- M_T = ---

Water Weight Gain

Impinger 1 65.9

Impinger 2 10.2

Impinger 3 1.2

Impinger 4 3.6

Impinger 5

Impinger 6

Total

80.9 = V

%CO₂ = 11.2

V_m = 23.528

V_w = 80.9

%N₂ = 85.8

Avg ΔP = 0.136

Avg ΔP = 0.367

C_p = 0.799

P_s = 70.14

T_m = 75

T_s = 344

%EA: 15.2

SCFM: 15.308

ACFM: 26988

% Moisture = 14.05

V_{gas} = 0.0472 x V_w = 0.0472 x 80.9 = 3.818

V_{std} = 5123.8 x 0.799

% Moisture = 14.05

V_{std} = 17.65

% Moisture = 14.05

V_{std} = 17.65

V_{std} = 17.65

V_{std} = 17.65

V_{std} = 17.65

V_{std} = 17.65

V_{std} = 17.65

Job No. 90-22

Job Name FIRESTONE

Run No. 3 (CONDITION) *3

Location EB-114 EXHAUST

Date 8 NOVEMBER 1990

Operator RAUDORPH, B.11

Sample Box No. 30 Meter Box No. 10

VELOCITY/INSTRUMENT FIELD DATA

Read and record at the start of each test point.

Purge to: ---

Purge time: ---

METCO ENVIRONMENTAL

Ambient Temp. °F 79

Assumed Moisture % 16.0

Probe Length 3'

C Factor --- to reference

Initial Leak @ 15.0 "Hg = 0.000 cfm

Final Leak @ 8.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	T _s			T _m		Remarks	
				Desired	Actual		Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		
											Inlet		Outlet
A8	1138	165.000	0.11	2.00	2.00	5.0	303	296	258	71	77	75	1178
A7	1143	168.75	0.13	2.00	2.00	5.0	305	298	258	69	77	75	0850
A6	1148	172.45	0.13	2.00	2.00	5.0	314	250	260	70	79	76	
A5	1153	176.62	0.15	2.00	2.00	5.0	318	250	262	70	80	76	
A4	1158	180.75	0.14	2.00	2.00	5.0	361	253	260	71	81	76	
A3	1203	184.60	0.17	2.00	2.00	5.0	402	254	257	70	83	76	
A2	1208	187.458	0.17	—	—	—	407	—	—	—	—	—	
A1	END	—	0.10	—	—	—	340	—	—	—	—	—	
END	—	—	—	—	—	—	—	—	—	—	—	—	
B8	—	—	0.13	—	—	—	320	—	—	—	—	—	
B7	—	—	0.13	—	—	—	330	—	—	—	—	—	
B6	—	—	0.13	—	—	—	343	—	—	—	—	—	
B5	—	—	0.13	—	—	—	347	—	—	—	—	—	
B4	—	—	0.13	—	—	—	340	—	—	—	—	—	
B3	—	—	0.13	—	—	—	325	—	—	—	—	—	
B2	—	—	0.12	—	—	—	326	—	—	—	—	—	
B1	—	—	0.10	—	—	—	304	—	—	—	—	—	
END ALL	—	—	—	—	—	—	—	—	—	—	—	—	

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.325 ft³ Baro. Press. P_b 29.89 "Hg

Water Collected V_w 91.7 ml Probe Tip Dia. D_n --- in.

Time of Test T_t 30 min. % CO₂ 11.4 % CO 0.0

Stack Pressure P_s +0.14 "H₂O % O₂ 3.0 % N₂ 85.6

Area Stack A_s 2653 in²

Pitot Tube No. 5 Barometer No. 15

Probe Tip No. ---

Dry Gas Meter Calibration Factor 1.016 x 22.958

Dry Gas Meter Reading --- ft³ - (T_t --- min x Leak Rate --- cfm)

M_F = --- M_T = ---

Impinger 1
Final Weight 789.2
Initial Weight 723.2
Increase

Impinger 2
Final Weight 649.3
Initial Weight 635.3
Increase

Impinger 3
Final Weight 523.2
Initial Weight 520.7
Increase

Impinger 4
Final Weight 861.0
Initial Weight 851.8
Increase

Impinger 5
Final Weight
Initial Weight
Increase

Impinger 6
Final Weight
Initial Weight
Increase

Filter #
Final Weight
Initial Weight
Increase

Water Weight Gain

Impinger 1 66.0

Impinger 2 14.0

Impinger 3 2.5

Impinger 4 9.2

Impinger 5

Impinger 6

$V_w =$
 $SO_2 =$
 $V_w =$

Total $V_w = 91.7$
 $\%CO_2 = 11.4$
 $V_m = 23.325$
 $V_w = 91.7$
 $P_m = 2.000$
 $\%N_2 = 85.6$
 $Avg \Delta P = 0.131$
 $Avg \Delta P = 0.361$
 $C_p = 0.799$
 $P_s = +0.14$
 $T_m = 78$
 $T_s = 341$
 $P_s = 29.90$
 $T_c = 30$
 $A_s = 2653$
 $D_n =$
 $\%Hg = 29.90$
 $\%R = 538$
 $\%R = 801$

Moisture Content: $\%M = 15.85$
 $M_d = 0.8415$
 $MW_d = 29.944$
 $MW = 28.05$

$V_m^{std} = 17.65 V_m \left(\frac{P_b + P_m}{P_m + 13.6} + \frac{T_m + 460}{T_m + 460} \right) = 17.65 \times 23.325 \times \left(\frac{29.94 + 13.6}{29.94 + 460} + \frac{78}{78} \right) = 22.985$
 $V_m^{std} = 22.985$
 $V_w^{std} = 0.0472 \times V_m = 0.0472 \times 91.7 = 4.328$
 $\% Moisture = \frac{V_m^{std} + V_w^{std}}{V_m^{std}} \times 100 = \frac{4.328 + 22.985}{4.328} \times 100 = 15.85$

$V_s = 5123.8 \times 0.799$
 $\frac{801}{801} \times 0.361 = 14.44$
 $\%I = 1039 \times \frac{1}{2} =$

ACFM: 26609
SCFM: 14808
%EA: 15.2

Job No. 90-22

Job Name FIELD DATA

Run No. 4 (200/170) "3"

Location EB-114 EXHAUST

Date 8 NOVEMBER 1980

Operator DAVID M. B. 11

Sample Box No. 30 Meter Box No. 10

Read and record at the start of each test point.

Purge to:

Purge time:

METCO ENVIRONMENTAL

Ambient Temp. °F 79

Assumed Moisture % 16.0

Probe Length 3'

C Factor to reference

Initial Leak @ 15.0 "Hg = 0.002 cfm

Final Leak @ 10.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
28	1312	186.377	0.03	2.00	2.00	5.0	250	241	260	68	77	77	1128
27	1317	182.40	0.03	2.00	2.00	5.0	251	245	259	67	77	76	058
26	1322	180.39	0.03	2.00	2.00	5.0	253	250	260	66	77	77	
25	1327	200.42	0.04	2.00	2.00	5.0	255	253	261	64	81	77	
24	1332	203.95	0.04	2.00	2.00	5.0	203	258	262	62	83	77	
23	1337	208.01	0.04	2.00	2.00	5.0	215	257	260	64	85	77	
22	1342	211.558	0.04	—	—	—	320	—	—	—	—	—	
21	END	—	0.02	—	—	—	300	—	—	—	—	—	
20	—	—	—	—	—	—	—	—	—	—	—	—	
19	—	—	0.04	—	—	—	282	—	—	—	—	—	
18	—	—	0.04	—	—	—	285	—	—	—	—	—	
17	—	—	0.04	—	—	—	288	—	—	—	—	—	
16	—	—	0.04	—	—	—	293	—	—	—	—	—	
15	—	—	0.04	—	—	—	297	—	—	—	—	—	
14	—	—	0.04	—	—	—	295	—	—	—	—	—	
13	—	—	0.04	—	—	—	290	—	—	—	—	—	
12	—	—	0.03	—	—	—	291	—	—	—	—	—	
11	—	—	0.03	—	—	—	291	—	—	—	—	—	
10	ALL	—	0.03	—	—	—	283	—	—	—	—	—	

D-32

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.552 m³ Baro. Press. P_b 29.80 "Hg

Water Collected V_w 91.4 ml Probe Tip Dia. D_n — in.

Time of Test T_t 30 min. % CO₂ 4.6 % CO 8.8

Stack Pressure P_s ±0.03 "H₂O % O₂ 3.0 % N₂ 8.74

Area Stack A_s 2653 in²

Pitot Tube No. 5 Barometer No. 15

Probe Tip No. —

Dry Gas Meter Calibration Factor 1.016 x 23.151

Dry Gas Meter Reading — ft³ (T_t — min x Leak Rate — cfm)

M_F = — M_T = —

Water Weight Gain

Impinger 1 80.4

Impinger 2 10.7

Impinger 3 1.4

Impinger 4 5.2

Impinger 5

Impinger 6

$V =$
 $SO_2 =$
 $V =$

Total

97.7 = V

$P_b = 29.50$ $\%CO_2 = 9.6$

$V_m = 23.55$ $\%CO_2 = 3.0$

$V_w = 97.4$ $\%CO_2 = 0.0$

$P_m = 0.001$ $\%N_2 = 87.4$

$Avg \Delta P = 0.0386$ $A_s = 0.653$

$C_p = 0.799$ $T_c = 30$

$P_s = 79$ ± 0.03 $H_2O = 29.80$

$T_m = 79$ $T_s = 293$

$T_s = 293$ $F = 753$

Impinger 1 Final Weight 869.6 Initial Weight 789.2 Increase

Impinger 2 Final Weight 659.7 Initial Weight 679.3 Increase

Impinger 3 Final Weight 529.6 Initial Weight 523.2 Increase

Impinger 4 Final Weight 866.2 Initial Weight 861.0 Increase

Impinger 5 Final Weight Initial Weight Increase

Impinger 6 Final Weight Initial Weight Increase

Filter # Initial Weight Final Weight Increase

Moisture Content:

$$V_{m \text{ std}} = 17.65 V_m \left(\frac{P_b + P_m}{P_b + \frac{13.6}{T_m + 460}} \right) = 17.65 \times 23.55 = 414.0$$

$$V_{w \text{ gas}} = 0.0472 \times V_w = 0.0472 \times 97.4 = 4.597 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{w \text{ gas}} + V_{m \text{ std}}}{V} \times 100 = \frac{4.597 + 414.0}{97.7} \times 100 = 424.6\%$$

$$V_s = 5123.8 \times 0.799 \sqrt{\frac{753}{29.80 \times 0.188}} = 735 \text{ fpm}$$

$$\%I = \frac{1039 \times \dots \times \dots \times \dots \times \dots}{\dots} = \dots$$

ACFM: 13,538
SCFM: 791.6
%EA: 14.9

Impinger Box No. 30

Impinger 1	Final Weight 870.9	Initial Weight 869.6	Increase
Impinger 2	Final Weight 752.5	Initial Weight 659.7	Increase
Impinger 3	Final Weight 526.8	Initial Weight 524.6	Increase
Impinger 4	Final Weight 871.6	Initial Weight 866.2	Increase
Impinger 5	Final Weight	Initial Weight	Increase
Impinger 6	Final Weight	Initial Weight	Increase

Water Weight Gain

Impinger 1	1.3
Impinger 2	92.8
Impinger 3	2.2
Impinger 4	5.4
Impinger 5	
Impinger 6	
Total	101.7
%CO ₂	9.6
%O ₂	3.0
%CO	0.0
%N ₂	87.4
Avg ΔP	0.0401
Avg ΔP	0.0200
C _p	0.799
P _s	10.04 mmHg
T _m	81 °F
T _s	753 °F

Moisture Content:

$$V_{m, std} = 17.65 V_m \left(\frac{P_b + P_m}{P_b + 460} \right) = 17.65 \times 24.389 \left(\frac{29.80 + 13.6}{29.80 + 460} \right) = 23.828 \text{ sft}^3$$

$$V_{gas} = 0.0472 \times V_m = 0.0472 \times 101.7 = 4.800 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{m, std}}{V_{gas}} \times 100 = \frac{23.828}{4.800} \times 100 = 49.85\%$$

$$V_s = 5123.8 \times 0.799 \times \sqrt{\frac{753}{29.80 \times 27.70}} \times 0.200 = 782 \text{ fpm}$$

$$\% I = \frac{1039 \times \dots \times \dots}{\dots} = \dots$$

ACFM: 14408
SCFM: 84051
%EA: 14.9

Job No. 980-222
Job Name FIRESTORM
Run No. 6 (CALIBRATION) #3
Location EB-114 EXHAUST
Date 8 NOVEMBER 1990
Operator RAIDNEY, Bill
Sample Box No. 30 Meter Box No. 10

Verdery/1405 FIELD DATA

METCO ENVIRONMENTAL

Ambient Temp. °F 79
Assumed Moisture % 16.0
Probe Length 3'
C Factor to reference
Initial Leak @ 15.0 "Hg = 0.000 cfm
Final Leak @ 8.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp °F		Remarks
				Desired	Actual						Inlet	Outlet	
A 8	1535	236.230	0.04	2.00	2.00	5.0	260	258	258	68	81	81	1422
A 7	1540	240.18	0.03	2.00	2.00	5.0	273	257	259	63	82	81	1422
A 6	1545	244.17	0.03	2.00	2.00	5.0	280	257	259	62	83	81	1422
A 5	1550	248.35	0.04	2.00	2.00	5.0	286	258	259	63	85	81	1422
A 4	1555	252.10	0.04	2.00	2.00	5.0	300	259	260	65	86	81	1422
A 3	1600	256.25	0.04	2.00	2.00	5.0	316	259	260	66	87	81	1422
A 2	1605	259.655	0.04	—	—	—	320	259	260	—	—	—	1422
A 1	END	—	0.04	—	—	—	328	—	—	—	—	—	1422
END	—	—	—	—	—	—	330	—	—	—	—	—	1422
B 8	—	—	0.04	—	—	—	337	—	—	—	—	—	1422
B 7	—	—	0.04	—	—	—	337	—	—	—	—	—	1422
B 6	—	—	0.04	—	—	—	337	—	—	—	—	—	1422
B 5	—	—	0.04	—	—	—	337	—	—	—	—	—	1422
B 4	—	—	0.04	—	—	—	337	—	—	—	—	—	1422
B 3	—	—	0.04	—	—	—	337	—	—	—	—	—	1422
B 2	—	—	0.04	—	—	—	337	—	—	—	—	—	1422
B 1	—	—	0.04	—	—	—	337	—	—	—	—	—	1422
END	ALL	—	0.03	—	—	—	337	—	—	—	—	—	1422

D-36

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.800 ft³ Baro. Press. P_b 29.80 "Hg

Water Collected V_w 94.8 ml Probe Tip Dia. D_n — in.

Time of Test T_t 30 min. % CO₂ 10.2 % CO 0.0

Stack Pressure P_s +0.07 "H₂O % O₂ 3.5 % N₂ 86.3

Area Stack A_s 2653 in²

Pitot Tube No. 5

Probe Tip No. —

Dry Gas Meter Calibration Factor 1.016 x 23.825

Barometer No. 75

Dry Gas Meter Reading — ft³ - (T_t min x Leak Rate cfm)
M_F = — M_T = —

D-37

BEA: 18.1
SCFM: 8278
ACFM: 13977

$$V_s = 5123.8 \times 0.794 \sqrt{\frac{1.80 \times 27.87}{0.195}} = 759 \text{ fpm}$$

1039 X

X X X X

2

Job No. 90-22
 Job Name Firestack
 Run No. 1 Condensed (1/1/64)
 Location EB-114 EXHAUST
 Date 9 NOVEMBER 1990
 Operator BAUDRY, B.I.
 Sample Box No. 30 Meter Box No. 10

Read and record at the
 start of each test point.
 Purge to: —
 Purge time: —

Point	Clock Time	Dry Gas Meter, CF	Pilot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F
				Desired	Actual			
0505	0505	260.150	0.11	2.00	2.00	5.0	317	233
0510	0510	263.60	0.11	2.00	2.00	5.0	317	250
0515	0515	267.55	0.13	2.00	2.00	5.0	319	251
0520	0520	271.20	0.13	2.00	2.00	5.0	324	253
0525	0525	275.28	0.14	2.00	2.00	5.0	380	256
0530	0530	278.93	0.16	2.00	2.00	5.0	410	256
0535	0535	282.580	0.16	—	—	—	411	—
0540	0540	—	0.14	—	—	—	402	—
0545	0545	—	0.12	—	—	—	—	—
0550	0550	—	0.13	—	—	—	331	—
0555	0555	—	0.13	—	—	—	335	—
0600	0600	—	0.14	—	—	—	340	—
0605	0605	—	0.13	—	—	—	356	—
0610	0610	—	0.13	—	—	—	337	—
0615	0615	—	0.13	—	—	—	336	—
0620	0620	—	0.14	—	—	—	331	—
0625	0625	—	0.14	—	—	—	334	—

D-38

Pitot Tube Calibration Factor C_p 0.799
 Volume Collected V_m 22.789 ft³ Baro. Press. P_b 29.78 "Hg
 Water Collected V_w 92.9 ml Probe Tip Dia. D_n — in.
 Time of Test T_t 30 min. % CO₂ 12.2 % CO 0.0
 Stack Pressure P_s 70.14 "H₂O % O₂ 8.9 % N₂ 83.2
 Area Stack A_s 2653 in²

Pitot Tube
 Probe Tip
 V_m = Dry Cal
 Dry Gas
 Meter 1

Impinger Box No. 30

Water Weight Gain

Impinger 1	50.4
Impinger 2	25.9
Impinger 3	6.0
Impinger 4	10.6
Impinger 5	
Impinger 6	

$$V_{SO_2} = -$$

$$V_w =$$

Impinger 1
Final Weight 728.0
Initial Weight 671.6
Increase

Impinger 2
Final Weight 641.5
Initial Weight 615.6
Increase

Impinger 3
Final Weight 535.3
Initial Weight 529.3
Increase

Impinger 4
Final Weight 583.5
Initial Weight 570.9
Increase

Impinger 5
Final Weight
Initial Weight
Increase

Impinger 6
Final Weight
Initial Weight
Increase

Filter #

Final Weight
Initial Weight

Increase

Moisture Content:

$$\%M = \frac{16.26}{M_p} = \frac{0.8374}{M_p} = \frac{29.776}{M_p} = 27.86$$

$$V_{m, std} = 17.65 V_m = 17.65 \times 22.789 = 402.789$$

$$V_{m, std} = \left(\frac{P_b + P_m}{T_m + 460} \right) = \left(\frac{29.78 + 13.6}{73 + 460} \right) = 0.0472$$

$$V_{w, gas} = 0.0472 \times V_m = 0.0472 \times 92.9 = 4.385 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{w, gas}}{V_{w, gas} + V_m} \times 100 = \frac{4.385}{4.385 + 22.584} \times 100 = 16.26 \%$$

$$V_{w, gas} = 5123.8 \times 0.799 = 4097.8$$

$$V_s = 1039 \times \frac{V_{w, gas}}{V_{w, gas} + V_m} = 1039 \times \frac{4.385}{4.385 + 22.584} = 147.8 \text{ fpm}$$

$$\%I = \frac{1039 \times V_{w, gas}}{V_{w, gas} + V_m} = \frac{1039 \times 4.385}{4.385 + 22.584} = 147.8$$

$$\%EA = 13.9$$

$$SCFM = 1489.1$$

$$ACFM = 2723.8$$

Job No. 90-22 VENTILATOR FIELD DATA

Job Name FIRESTROKE

Run No. 02 GAZOLINE 11/16/54 (1000) Read and record at the start of each test point.

Location EB-114 EXHAUST

Date NOVEMBER 1950

Operator RAUNDEN B.11

Sample Box No. 30 Meter Box No. 0

METCO ENVIRONMENTAL
Ambient Temp. °F 70
Assumed Moisture % 16.0
Probe Length 3'
C Factor — to reference
Initial leak @ 45.0 "Hg = 0.002 cfm
Final leak @ 112.0 "Hg = 0.002 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	T _s			T _m		Remarks	
				Desired	Actual		Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		
											Inlet		Outlet
B8	0918	284.350	0.13	2.00	2.00	5.0	330	238	260	65	74	73	WATER
B7	0923	288.13	0.13	2.00	2.00	5.0	340	246	252	60	75	73	
B6	0928	290.05	0.14	2.00	2.00	5.0	348	254	256	59	76	73	0.057
B5	0933	296.00	0.14	2.00	2.00	5.0	358	258	253	59	78	74	
B4	0938	299.68	0.14	2.00	2.00	5.0	365	258	252	59	79	74	
B3	0943	303.60	0.15	2.00	2.00	5.0	370	258	256	60	79	74	
B2	0948	307.445	0.15	2.00	2.00	5.0	377	258	256	60	79	74	
B1	END	—	0.14	—	—	—	380	—	—	—	—	—	
END	—	—	—	—	—	—	—	—	—	—	—	—	
A8	—	—	0.09	—	—	—	262	—	—	—	—	—	
A7	—	—	0.11	—	—	—	317	—	—	—	—	—	
A6	—	—	0.11	—	—	—	322	—	—	—	—	—	
A5	—	—	0.12	—	—	—	327	—	—	—	—	—	
A4	—	—	0.14	—	—	—	351	—	—	—	—	—	
A3	—	—	0.16	—	—	—	408	—	—	—	—	—	
A2	—	—	0.17	—	—	—	416	—	—	—	—	—	
A1	—	—	0.17	—	—	—	408	—	—	—	—	—	
END	ALL	—	—	—	—	—	—	—	—	—	—	—	

D-40

Pitot Tube Calibration Factor C_p 0.799
Volume Collected V_m 23.765 ft³ Baro. Press. P_b 29.78 "Hg
Water Collected V_w 844 ml Probe Tip Dia. D_n — in.
Time of Test T_t 30 min. % CO₂ 11.0 % CO 0.0
Stack Pressure P_s +0.14 "H₂O % O₂ 8.9 % N₂ 86.1
Area Stack A_s 26.53 in²

Pitot Tube No. 5 Barometer No. 15
Probe Tip No. —
V_m = Dry Gas Meter Calibration Factor 1.016 x 23.095
[Dry Gas Meter Reading — ft³ - (T_t min x Leak Rate — cfm)]
M_F = — M_T = —

Impinger Box No. 30

Water Weight Gain

Impinger 1	6.5
Impinger 2	15.3
Impinger 3	1.9
Impinger 4	5.7
Impinger 5	
Impinger 6	
Total	84.4
$V = V_w$	
$V_{SO_2} = V_w$	
$V_{SO_2} = V_w$	
$P_b = 29.78$	
$V_m = 23.4651$	
$V_w = 84.4$	
$P_m = 2.0001$	
$A_{avg} \Delta P = 0.1371$	
$A_{avg} \Delta P = 0.369$	
$C_p = 0.799$	
$P_s = +0.14$	
$T_m = 75$	
$T_s = 350$	

Filter #	Final Weight	Initial Weight	Increase
Impinger 1	783.5	702.0	Increase
Impinger 2	656.8	641.5	Increase
Impinger 3	537.2	535.3	Increase
Impinger 4	889.2	883.5	Increase
Impinger 5			Increase
Impinger 6			Increase

Moisture Content:

$$\%M = \frac{M}{M_D} = \frac{4.67}{0.8533} = 5.47 \quad \text{MM}_D = 29.876 \quad \text{MM} = 28.13$$

$$V_m^{std} = 17.65 V_m \left(\frac{P_b + P_m}{P_m} + \frac{T_m + 460}{13.6} \right) = 17.65 \times 23.465 = 413.6$$

$$V_{W_{gas}} = 0.0472 \times V_m = 0.0472 \times 84.4 = 3.984 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{W_{gas}} + V_m^{std}}{V_{W_{gas}} + V_m^{std} + V} \times 100 = \frac{3.984 + 413.6}{3.984 + 413.6 + 84.4} \times 100 = 19.67\%$$

$$V_s = 5123.8 \times 0.799 \times \frac{810}{29.78 \times 28.13} \times 0.369 = 1485 \text{ fpm}$$

$$\%I = \frac{1039 \times \dots \times \dots \times \dots \times \dots}{\dots} = \dots$$

ACFM: 2736.3
SCFM: 1527.1
%EA: 4.6

Job No. 90-22

Job Name FIRESTONE

Run No. 3 (Goodman) # 4 (1164)

Location ERB-114 EXHAUST

Date 9 NOVEMBER 1990

Operator RAUDEN, B.11

Sample Box No. 30 Meter Box No. 10

Leakage WASTFIELD DATA

METCO ENVIRONMENTAL

Ambient Temp. °F 70

Assumed Moisture % 16.0

Probe Length 3'

C Factor to reference

Initial Leak @ 15.0 "Hg = 0.000 cfm

Final Leak @ 11.0 "Hg = 0.000 cfm

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O	Orifice ΔH in. H ₂ O		Pump Vacuum In. Hg Gauge	Stack Temp. °F	Probe Temp. °F	Oven Temp. °F	Effluent Temp. °F	Dry Gas Temp. °F		Remarks
				Desired	Actual						Inlet	Outlet	
A8	1030	307.900	0.10	2.00	2.00	5.5	315	245	253	63	76	75	11222
A7	1035	311.50	0.11	2.00	2.00	5.5	300	256	258	58	76	75	11222
A6	1040	315.65	0.11	2.00	2.00	5.5	324	265	255	56	77	75	11222
A5	1045	319.26	0.12	2.00	2.00	5.5	330	263	259	56	79	75	11222
A4	1050	323.15	0.13	2.00	2.00	5.5	400	268	260	57	80	75	11222
A3	1055	327.20	0.15	2.00	2.00	5.5	413	265	258	59	81	75	11222
A2	1100	331.000	0.15	—	—	—	418	—	—	—	—	—	11222
A1	END	—	0.13	—	—	—	404	—	—	—	—	—	11222
END	—	—	—	—	—	—	—	—	—	—	—	—	11222
B8	—	—	0.12	—	—	—	327	—	—	—	—	—	11222
B7	—	—	0.13	—	—	—	344	—	—	—	—	—	11222
B6	—	—	0.14	—	—	—	350	—	—	—	—	—	11222
B5	—	—	0.14	—	—	—	357	—	—	—	—	—	11222
B4	—	—	0.14	—	—	—	344	—	—	—	—	—	11222
B3	—	—	0.14	—	—	—	336	—	—	—	—	—	11222
B2	—	—	0.14	—	—	—	337	—	—	—	—	—	11222
B1	—	—	0.14	—	—	—	334	—	—	—	—	—	11222
END	—	—	0.10	—	—	—	—	—	—	—	—	—	11222

D-42

Pitot Tube Calibration Factor C_p 0.799

Volume Collected V_m 23.470 ft³ Baro. Press. P_b 29.78 "Hg

Water Collected V_w 86.6 ml Probe Tip Dia. D_n — in.

Time of Test T_t 30 min. % CO₂ 11.4 % CO 0.0

Stack Pressure P_s +0.14 "H₂O % O₂ 21.6 % N₂ 86.0

Area Stack A_s 26.53 in²

Pitot Tube No. 5

Probe Tip No. —

V_m = Dry Gas Meter Calibration Factor 1.016 x 23.100

Dry Gas Meter Reading — ft³ - (T_t min x Leak Rate — cfm)

M_F = — M_T = —

Impinger Box No. 30

Water Weight Gain

Impinger 1	22.3
Impinger 2	57.2
Impinger 3	2.1
Impinger 4	5.0
Impinger 5	
Impinger 6	

$V_{SO_2} = -$
 $V_w =$

Impinger 1	Final Weight	805.8
	Initial Weight	783.5
	Increase	
Impinger 2	Final Weight	719.0
	Initial Weight	656.8
	Increase	
Impinger 3	Final Weight	539.3
	Initial Weight	537.2
	Increase	
Impinger 4	Final Weight	894.2
	Initial Weight	869.2
	Increase	
Impinger 5	Final Weight	
	Initial Weight	
	Increase	
Impinger 6	Final Weight	
	Initial Weight	
	Increase	

Filter #

Final Weight
Initial Weight
Increase

$P_b = 29.78$	$P_s = 29.79$	$T_m = 77$	$T_s = 85.3$
$V_m = 23.470$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$V_w = 86.6$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$\%CO_2 = 11.4$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$\%O_2 = 2.6$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$\%CO = 0.0$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$\%N_2 = 86.0$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$A_s = 26.53$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$D_n =$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$C_p = 0.799$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$Av_8 \Delta P = 0.357$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$Av_8 \Delta P = 0.1281$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$A_s = 26.53$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$T_c = 30$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$P_s = 29.79$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$T_m = 77$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$
$T_s = 85.3$	$P_s = 70.14$	$T_m = 77$	$T_s = 85.3$

Moisture Content: $\%M = 15.04$ $M_d = 0.8496$ $MW_d = 29.928$ $MW = 28.13$

$$V_{m\text{std}} = 17.65 V_m \left(\frac{P_b + P_m}{P_m + 460} \right) \left(\frac{T_m + 460}{T_m} \right) = 17.65 \times 23.470 \times \left(\frac{29.78 + 13.6}{29.78} \right) \left(\frac{77 + 460}{77} \right) = 23.086 \text{ sft}^3$$

$$V_{w\text{gas}} = 0.0472 \times V_m = 0.0472 \times 86.6 = 4.088 \text{ sft}^3$$

$$\% \text{ Moisture} = \frac{V_{w\text{gas}} + V_{m\text{std}}}{V_{\text{gas}}} \times 100 = \frac{4.088 + 23.086}{265.221} \times 100 = 15.09\%$$

$$V_s = 5123.8 \times 0.799 \times \left(\frac{813}{29.78} \right) \times 0.357 = 1440 \text{ fpm}$$

$$\%I = \frac{1039 \times \dots \times \dots \times \dots \times \dots}{2} = \dots$$


ACFM: 265.221
SCFM: 146.281
%EA: 12.91

Oxides of Nitrogen Monitor Data

APPENDIX E

90-22 Fireshore

Oxides of Nitrogen Monitor Calibration Curve B.12 EG-1141 Stack 11/6/90



6-11-93
6-11-93

11/2/70
11/2/70

7-06

NOT RECORDED - 250 PM

240 NEW SOUTH BRITAIN

0665 MW

14.30% 339.1 MW

1856708


580-1-001-225


0510 4780


2001 10/10/01 01:51 PM


[illegible]

APR 27 1965










90-22 Firestone

Oxides of Nitrogen Monitor Calibration Curve B₁ 100 E8-114 Scale 11/2/92





93-22 Freshone

Oxides of Nitrogen Monitor Calibration Curve


Beiler EG-114 Stack

11/7/90





E-12



Cable 14 Cable 12
0.1512

Cable 15 Cable 10
0.1512


Cable 16 Cable 11
0.1512

End Test (P.O.)
 7 NOVEMBER 1950
 1755
 SAVING LINES AND CHART
 BOX 4921 1950
 BOX 4921 1950
 BOX 3092 221.174.100
 AN 5700 125.5.100
 End Test 6 (End Test 6 0 1700)

90-22 Emerson

Oxides of Nitrogen Monitor Calibration Curve 8014r E8-114 Skel

11/8/90



FB-117 EX-157
100-44-117

44-38861-10000
10000-10000
10000-10000

100x 100x

NY 100-108861

THESE EXHIBITS ARE
PROPERTY OF THE
FEDERAL BUREAU OF
INVESTIGATION
DO NOT REMOVE
OR DESTROY
100-157-105-106-107-108-109-110-111-112-113-114-115-116-117-118-119-120-121-122-123-124-125-126-127-128-129-130-131-132-133-134-135-136-137-138-139-140-141-142-143-144-145-146-147-148-149-150-151-152-153-154-155-156-157-158-159-160-161-162-163-164-165-166-167-168-169-170-171-172-173-174-175-176-177-178-179-180-181-182-183-184-185-186-187-188-189-190-191-192-193-194-195-196-197-198-199-200-201-202-203-204-205-206-207-208-209-210-211-212-213-214-215-216-217-218-219-220-221-222-223-224-225-226-227-228-229-230-231-232-233-234-235-236-237-238-239-240-241-242-243-244-245-246-247-248-249-250-251-252-253-254-255-256-257-258-259-260-261-262-263-264-265-266-267-268-269-270-271-272-273-274-275-276-277-278-279-280-281-282-283-284-285-286-287-288-289-290-291-292-293-294-295-296-297-298-299-300-301-302-303-304-305-306-307-308-309-310-311-312-313-314-315-316-317-318-319-320-321-322-323-324-325-326-327-328-329-330-331-332-333-334-335-336-337-338-339-340-341-342-343-344-345-346-347-348-349-350-351-352-353-354-355-356-357-358-359-360-361-362-363-364-365-366-367-368-369-370-371-372-373-374-375-376-377-378-379-380-381-382-383-384-385-386-387-388-389-390-391-392-393-394-395-396-397-398-399-400-401-402-403-404-405-406-407-408-409-410-411-412-413-414-415-416-417-418-419-420-421-422-423-424-425-426-427-428-429-430-431-432-433-434-435-436-437-438-439-440-441-442-443-444-445-446-447-448-449-450-451-452-453-454-455-456-457-458-459-460-461-462-463-464-465-466-467-468-469-470-471-472-473-474-475-476-477-478-479-480-481-482-483-484-485-486-487-488-489-490-491-492-493-494-495-496-497-498-499-500-501-502-503-504-505-506-507-508-509-510-511-512-513-514-515-516-517-518-519-520-521-522-523-524-525-526-527-528-529-530-531-532-533-534-535-536-537-538-539-540-541-542-543-544-545-546-547-548-549-550-551-552-553-554-555-556-557-558-559-560-561-562-563-564-565-566-567-568-569-570-571-572-573-574-575-576-577-578-579-580-581-582-583-584-585-586-587-588-589-590-591-592-593-594-595-596-597-598-599-600-601-602-603-604-605-606-607-608-609-610-611-612-613-614-615-616-617-618-619-620-621-622-623-624-625-626-627-628-629-630-631-632-633-634-635-636-637-638-639-640-641-642-643-644-645-646-647-648-649-650-651-652-653-654-655-656-657-658-659-660-661-662-663-664-665-666-667-668-669-670-671-672-673-674-675-676-677-678-679-680-681-682-683-684-685-686-687-688-689-690-691-692-693-694-695-696-697-698-699-700-701-702-703-704-705-706-707-708-709-710-711-712-713-714-715-716-717-718-719-720-721-722-723-724-725-726-727-728-729-730-731-732-733-734-735-736-737-738-739-740-741-742-743-744-745-746-747-748-749-750-751-752-753-754-755-756-757-758-759-760-761-762-763-764-765-766-767-768-769-770-771-772-773-774-775-776-777-778-779-780-781-782-783-784-785-786-787-788-789-790-791-792-793-794-795-796-797-798-799-800-801-802-803-804-805-806-807-808-809-810-811-812-813-814-815-816-817-818-819-820-821-822-823-824-825-826-827-828-829-830-831-832-833-834-835-836-837-838-839-840-841-842-843-844-845-846-847-848-849-850-851-852-853-854-855-856-857-858-859-860-861-862-863-864-865-866-867-868-869-870-871-872-873-874-875-876-877-878-879-880-881-882-883-884-885-886-887-888-889-890-891-892-893-894-895-896-897-898-899-900-901-902-903-904-905-906-907-908-909-910-911-912-913-914-915-916-917-918-919-920-921-922-923-924-925-926-927-928-929-930-931-932-933-934-935-936-937-938-939-940-941-942-943-944-945-946-947-948-949-950-951-952-953-954-955-956-957-958-959-960-961-962-963-964-965-966-967-968-969-970-971-972-973-974-975-976-977-978-979-980-981-982-983-984-985-986-987-988-989-990-991-992-993-994-995-996-997-998-999-1000-1001-1002-1003-1004-1005-1006-1007-1008-1009-1010-1011-1012-1013-1014-1015-1016-1017-1018-1019-1020-1021-1022-1023-1024-1025-1026-1027-1028-1029-1030-1031-1032-1033-1034-1035-1036-1037-1038-1039-1040-1041-1042-1043-1044-1045-1046-1047-1048-1049-1050-1051-1052-1053-1054-1055-1056-1057-1058-1059-1060-1061-1062-1063-1064-1065-1066-1067-1068-1069-1070-1071-1072-1073-1074-1075-1076-1077-1078-1079-1080-1081-1082-1083-1084-1085-1086-1087-1088-1089-1090-1091-1092-109

SAMPLE LINE LEFT SIDE

DEL. NY

67

100 144 1-12 780 148

152-170

Quesada

13-26-1949

5102

Stacy L. Smith

5th Feb 2020

(Cleaning out the house)


02/19 02:25 PM

1476

St. Louis, Mo. 12-1-1915

2nd Law, 2nd Law, 2nd Law

1997-1998




Station 10+00.00
10+00.00

Station 10+00.00
10+00.00

Station 10+00.00
10+00.00


Station 10+00.00
10+00.00


Station 10+00.00
10+00.00



90-22 Firestone

Oxides of Nitrogen Monitor Calibration Curve R_{0.12} EG-1/4 Slack 11/9/90








Carbon Monoxide Monitor Data


APPENDIX F

Carbon Monoxide Monitor Calibration Curve

93-22 Firestone

Boyle ES 114 Stack 11/2/90






STATION 100

STATION 100

STATION 100

STATION 100



Long 100,000 ft @ 1500 km
Long 90,000 ft @ 1450 km
Long 1430 km
Long to ~102,000 ft @ 1350 km
Long up in land to ~60,000 lbs @ 1300 km

Long 100,000 ft @ 1500 km
Long 90,000 ft @ 1450 km
Long 1430 km
Long to ~102,000 ft @ 1350 km
Long up in land to ~60,000 lbs @ 1300 km

Long 100,000 ft @ 1500 km
Long 90,000 ft @ 1450 km
Long 1430 km
Long to ~102,000 ft @ 1350 km
Long up in land to ~60,000 lbs @ 1300 km

STATION 1000
1000

STATION 1000

STATION 1000

STATION 1000


STATION 1000


STATION 1000

STATION 1000

STATION 1000

STATION 1000






90-22 Freshney

Boiler FB-114 Skel 11/7/90

Carbon Monoxide Monitor Calibration Curve



CO LINE
D-1000
1 + 2
THIN SECTION
SCALE 1:1000
CHART SPEED 6.7 IN

90-24
KILBROOK
OCEANIC
E-B-14 EXHIBIT
7 WORKSHEET

SAMPLE LINE LONG LIVED ON

TH. 5 PM 00 CAL 1608

CHART SPEED 6.7 IN

13500


START LINE 1, DISTANCE 2.0 NOS

CHART SPEED 6.7 IN

End Line 2, Distance 2.0 NOS

START LINE 2, Distance 2.0 NOS

13500



200
held
9-6

ALSO TWO

STAY Luv's Combined 2.0 1136

Find line 12 Confusion 120 1120


20 Feb 13 Corbett #2 2/1936

SECRETED COPY

44-5741-141

STATE LAW & GOVERNMENT


100-443887-100



90-22 Firestone

Carbon Monoxide Monitor Calibration Curve

Boiler, FB114 Stack 11/8/90



20 days of no rain
Chlor Spent 6.1 hr

29.60 CAR 10531


SHAME LIES LEAKED
REVEALED

100-100-0
3000 02

[illegible]


STRT Run 15 Q-1000's 0.1000

29.00 29.00




STRT Run 15 Q-1000's 0.1105

29.00 29.00



STRT Run 15 Q-1000's 0.1200

29.00 29.00



Start line #4 Condition #3 1530
CH 9911
End line #5 Condition #3 1517

Start line #6 Condition #3 1417
CH 9911
End line #4 Condition #3 1407

Start line #4 Condition #3 1307
CH 9911

End Test line
8 DECEMBER 1990

Thomas B. D
1700


SAMPLE LINE LINE
CHECK OK

0-60 CAL 1250 (0-500 MM RANGE)
0-60 CAL 1250 (0-1000 MM RANGE)

491.5 MM CAL 1406 491.5 MM CO 1000.16
1941 CAL 9911 (0-500 MM)
CAL 9911

End line #6 Condition #3 21630

Carbon Monoxide Monitor Calibration Curve



START Run #2 Condition #1 (High Load) @ 0915

19-11-1964 CHX 944

End Run #2 Condition #1 @ 0905

START Run #1 Condition #1 @ 0800 (High Load)

(WAITING ON FUEL)

19-11-1964 CHX 944

19-11-1964 CHX 944

19-11-1964 CHX 944

90-100
AIRSTANE
OKLAHOMA, TX

ER-114 EXHAUST
@ WAKEFIELD, MASS

SHINE LIGHTS LEAK CHX 94
CO. RANGE
D-500 1000
1.50
THIRD CONDUIT
HOLD 10
QUARTER PITCHER #10
QUARTER SPEED 1000

End Run 1
9 October 1960

1200 hrs

14.60 PM 1958

14.5 PM

1606

14.11 PM 1911

- End Run #3 Condition #4 @ 1024 (High Load)

1 2 3 4 5 6 7 8 9 10

10 9 8 7 6 5 4 3 2 1 0

- START Run #3 Condition #4 @ 1024 (High Load)


14.11 PM 1911

1 2 3 4 5 6 7 8 9 10

APPENDIX G

Total Hydrocarbons Monitor Data

90-22 Freshene
Total Hydrocarbon Analyzer Calibration Curve *Boiler EB 114 Stack* 11/6/90



(2nd CONDENSED SYSTEM)

Start Run #1 2.9.83

SLIPPER CAL 10075

End Run #1 2.9.83

SLIPPER CAL 10075

Start Run #1 2.9.83

SLIPPER CAL 999

9.8 PM

CLX 1247

SLIPPER CAL 10025

SAMPLE LINE DATA SYSTEM

90-22
FIRESTONE
DENVER, TX

WET RANGE 0-100 MPH
L-2-R
RANGE 0-55 MPH
WET RANGE 0-55 MPH
WET RANGE 0-55 MPH

going up in bed to 110, 110, 110, 110

START CAL 9144

513 PM

100000

914 PM CAL 9144


End Test Run #3 01376

START Run #3 01145

513 PM

100000

End Run #2 01150



START Run # 2 @ 1810 HRS.

51.37PM

CH 10075

End Run # 5 @ 1820 HRS

CHANGED AIR CYLINDER

START Run # 5 @ 1700 HRS.

51.38PM

CH 10075

End Run # 4 @ 1642

COND TEST RUN
6 November 1990

2030 hrs

9.85 MPa CAL 9199

Sample line back
check OK

9.85 MPa CAL 10095


9.85 MPa CAL 10095

- Cond line 60 1910

Total Hydrocarbon Analyzer Calibration Curve

90-22 Firestone

Boiler EB-114 Stack 11/7/92



START Run #2 Condition #2 @ 1020

31.3 PM - CM 10095

End Run #1 Condition #2 @ 1005

CHART SPEED 6"/IN

START Run #1 Condition #2 @ 0705

9:55 PM - CAL 9194

56.3 PM - CM 10095


91.8 PM - CM 12301

SAVING LISTS BACK CHANGED OK

90-22
FLRSTAD
ORANGE, TX

PG-114 EXHIBIT
7 NOVEMBER 1990

THE PROGE
0-100 PM
L-9R
RATHON RS-55
UNIT 1.3
CHART NUMBER 98
CHART SPEED 6"/IN





SAMPLE LAMS
LEAK CHECK OK

End Test Run
7 NOVEMBER 1990

Thomas Bell
1755

9:05 PM CAL 9194

5:13 PM

CAL 10045


9:18 PM CAL 1304

End Run to Condition #2 01710

Total Hydrocarbon Analyzer Calibration Curve

90-22 Evesham

Boiler EP14 Stack 11/8/90



Start Run #2 Condition #3 @ 1000

End Run #1 Condition #3 @ 0946

Start Run #1 Condition #3 @ 0816

VOC Range 0-100 PPM
LPR
CHART SPEED 6"/IN

Stop test 00878 (cleaning out fuel lines)

Start Run #1 Condition #3 @ 0815

9.85 PPM @ 91 PPM

51.3 PPM @ 100 PPM

91.5 PPM @ 100 PPM

SAME LINES 100 PPM

90-25
FLO-5000
DRAUG, TX

ER-44 EXHAUST
8 NOVEMBER 1990

VOC RANGE 0-100 PPM
LPR
RATISMAN RS-55 UNIT #3
CHART FORWARD #8
CHART SPEED 6"/IN

Start Run #1 Condition #3 1007

9.15 CH 1004

9.17 MIN

CH 1004

51.3 MIN CH 1004

End Run #3 Condition #3 1020

Start Run #2 Condition #3 1000


End Run #2 1005

Start Run #6 Counter #3 G-1530

End Run #6 Counter #3 G-1517 5:30 PM 10045

Start Run #6 Counter #3 G-1419


End Run #6 Counter #3 G-1407 5:30 PM 10045



90-22 Firestone

Total Hydrocarbon Analyzer Calibration Curve

Revised E8 114 Skel 11/9/90



[illegible]

9/18 PM 4:14 PM
SOURCE LIVES HERE OK

5/11/55

9.55 AM 2.11.8 PM 9.19.8

(CONTINUED ON REVERSE)

Shah Bhai's London 1900 (Vgl. not)

End Date: 1 June 1983

3. *Staph. aureus* (gold) =

STB 1000 1000 1000

STB 1000 1000 1000 (High Load)

STB 1000 1000 1000

STB 1000 1000 1000 (High Load)

STB 1000 1000 1000

STB 1000 1000 1000

STB 1000 1000 1000

Plant Operational Data

APPENDIX H

FUEL
 TIME
 DATE
 OXYGEN-% CO-PPM
 STM. LOAD
 LB/HR
 OIL RATE(GPM)

GAS	11:45A	11/6	2.9	1	30000	1.8
GAS	3:30P	11/6	2.82	56	90000	4.5
GAS	3:40P	11/6	3.43	43	90000	4.5
GAS	3:50P	11/6	2.53	72	90000	0
GAS & STRM 1	9:50A	11/7	2.45	17	30000	1.8
GAS & STRM 1	11:05A	11/7	2.78	17	30000	1.6
GAS & STRM 1	2:15P	11/7	3.4	48	70000	4.8
GAS & STRM 1	3:30P	11/7	3.64	44	70000	4.5
GAS & STRM 1	4:05P	11/7	2.99	82	70000	4.5
GAS & STRM 3	8:45A	11/8	2.76	13	72000	5
GAS & STRM 3	8:50A	11/8	3.03	11	70000	5
GAS & STRM 3	9:00A	11/8	2.88	13	70000	5.5
GAS & STRM 3	1:15P	11/8	3.53	14	30000	1.9
GAS & STRM 3	2:15P	11/8	2.92	19	30000	1.7
GAS & STRM 2	8:05A	11/9	2.52	74	72000	5.1
GAS & STRM 2	8:15A	11/9	3.01	31	72000	5.1
GAS & STRM 2	8:50A	11/9	2.91	4	72000	5.1
GAS & STRM 2	9:50A	11/9	2.87	5	72000	5.1
GAS & STRM 2	10:15A	11/9	2.74	8	72000	5.1

TACB Permit

APPENDIX I

GENERAL PROVISIONS

R-2565

1. Equivalency of Methods - It shall be the responsibility of the holder of this permit to demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods and monitoring methods proposed as alternatives to methods indicated in the provisions of this permit. Alternative methods shall be applied for in writing and shall be reviewed and approved by the Executive Director prior to their use in fulfilling any requirements of this permit.

2. Sampling Requirements - If sampling of stacks or process vents is required, the holder of this permit must contact the quality Assurance Division of the Texas Air Control Board (TACB) prior to sampling to obtain the proper data forms and procedures. The holder of this permit is also responsible for providing sampling facilities and conducting the sampling operations at his own expense.
3. Appeal - This permit may be appealed pursuant to Rule 103.81 of the Procedural Rules of the TACB and Section 6.01 of the Texas Clean Air Act. Failure to take such appeal constitutes acceptance by the applicant of all terms of the permit.

4. Construction Progress - Start of construction, construction interruptions exceeding 45 days and completion of construction shall be reported to the appropriate regional office of the TACB not later than 10 working days after occurrence of the event. This provision shall not apply to operating permits.

5. Recordkeeping - Information and data concerning production, operating hours, sampling and monitoring data, if applicable, fuel type and fuel sulfur content, if applicable, shall be maintained in a file at the plant site and made available at the request of personnel from the TACB or any local air pollution control program having jurisdiction. The file shall be retained for at least two years following the date that the information or data is obtained.

6. Maintenance of Emission Control - The facilities covered by this permit shall not be operated unless all air pollution emission capture equipment and abatement equipment are maintained in good working order and operating properly during normal facility operations.

1. This permit covers those sources of emissions listed in the attached tables entitled "Emissions Sources - Maximum Allowable Emissions Rates," and those sources are limited to the emission limits and other conditions specified in those attached tables. This permit also covers those other sources of emissions as originally permitted and amended which are not listed on the attached tables.
2. Upon request by the Executive Director of the Texas Air Control Board or any local air pollution control program having jurisdiction, the holder of this permit shall provide a sample and/or an analysis of the fuel(s) utilized in this facility or shall allow air pollution control agency representatives to obtain a sample for analysis.
3. Fuel for the 126.6 MM Btu boilers identified as Emission Points EB-110, EB-111, EB-113, and EB-114 shall be limited to natural gas, fuel oil, the waste from hexane drawdown residues, butane residues and pentane residues.
- A. The boiler(s) shall be operated at no less than 25 percent of maximum design load while firing waste stream residue.
- B. The natural gas fuel shall contain no more than 0.25 grains of hydrogen sulfide and 5 grains total sulfur per 100 decf.
- C. The fuel oil shall contain no more than 0.5 weight percent sulfur.
- D. The typical composition of the waste fuel stream shall be as described in the attached table entitled "Waste Stream Composition." Individual compounds shall not exceed the maximum weight percent listed in the table.
- E. At least 50 percent of the fuel heat input being fired shall be either natural gas or fuel oil.
- F. Firing of the waste streams shall be limited to 2520 lbs/hr.
- G. Waste stream residue fuel shall not be fired during boiler start-up, shutdown, upset or malfunction.
- H. Use of any other fuel will require modification of this permit.
- I. The waste stream fuel shall be fired in only one boiler at any given time.

SPECIAL PROVISIONS

R-2566

4. The concentration of carbon monoxide (CO) present in the exhaust stream shall be limited to a maximum of 100 parts per million by volume (ppmv) based on an 8-hour average.

5. The concentration of oxygen (O_2) present in the exhaust stream shall be limited to a maximum of 3.6 percent (dry basis) based on an 8-hour average.

6. Noncomplying emissions of CO are defined as each 8-hour period of boiler operation, except during start-up or shutdown, during which the average emissions of CO exceed the emission limitation of Special Provision No. 4. Such emissions shall also be considered a violation of the emission limitations of Special Provision No. 1.

7. For each boiler, records of boiler operating hours shall be made and maintained on-site for at least a two-year period (rolling retention basis) and shall include at least the following parameters.

- A. Type and quantity of each fuel fired in lb/hr.
- B. Percent of boiler design load.

Records shall be made available to members of the TACB staff or any other air pollution control program with jurisdiction. Firing of waste stream fuels in excess of 2520 lb/hr. shall be considered to be an exceedance of the Volatile Organic Compound (VOC) emission limit.

The holder of this permit shall perform stack sampling and other testing as required to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the boiler. Sampling must be conducted in accordance with appropriate procedures of the TACB Sampling Procedures Manual and in accordance with EPA Reference Method 3 for the concentration of VOCs.

of this permit is responsible for providing sampling and testing facilities and conducting the sampling and testing operation at his expense.

The applicable TACB Regional Office shall be contacted as soon as testing is scheduled, but not less than 45 days prior to sampling, to schedule a [redacted] The notice shall include:

1. Date for pretest meeting.
2. Date sampling will occur.
3. Name of firm conducting sampling.
4. Type of sampling equipment to be used.
5. Methods or procedures to be used in sampling.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording the pertinent data, and to review the format procedures for submitting the test reports.

A written proposed description of any deviation from sampling procedures specified in permit provisions or TACB sampling the pretest meeting. The Regional Director or the Director of the Quality Assurance Division shall approve or disapprove of any deviation from specified sampling procedures.

Air emissions from Emission Points EB-110, EB-111, EB-113 and EB-114 which shall be ~~_____~~ include (but are not limited to) the following: CO, NO_x and VOC. The boiler(s) shall be tested while firing:

Natural gas.
Fuel oil.

A fuel mixture of either natural gas or fuel oil and the waste stream residue fuel.

If that boiler fails the performance test then one or more of the remaining boilers shall be tested at the discretion of the TACB regional office.

C. Sampling for natural gas and the waste stream residue fuel shall occur within 90 days after the date of approval of this amendment to the facilities and at such other times as may be required by the Executive Director of the TACB. Requests for additional time to perform sampling shall be submitted to the regional office.

D. Within 30 days of the commencement of burning fuel oil in these facilities, the holder of this permit shall submit a schedule for testing to the Executive Director and the appropriate regional office of the TACB. Air contaminants to be tested for shall be those specified in Special Provision No. 8. B. of the amended operating permit. The testing shall be completed and reports submitted within 60 days of the date of commencement of oil firing or as agreed upon by the regional office. If the facilities fail to meet the emission

limits for fuel oil burning as required by the operating permit, the holder of this permit shall cease burning oil immediately upon notification of such failure by the Executive Director. The Executive Director may specify retesting on an appropriate schedule.

The boiler(s) shall operate at design maximum load and the minimum point in the normal operating range during stack emission testing. Primary operating parameters that enable determination of load shall be monitored and recorded during the stack test. These parameters are to be determined at the maximum load during testing, then future rates may be limited to the rates established during testing. Additional stack testing may be required when higher load rates are achieved.

F. Two copies of the final sampling report shall be forwarded to the TACB within 30 days after sampling is completed. Sampling reports shall comply with the attached provisions of Chapter 14 of the TACB Sampling Procedures Manual. The reports shall be distributed as follows:

One copy to the appropriate TACB regional office.
One copy to the Quality Assurance Division, TACB, Austin Office.

The holder of this permit shall operate in accordance with the following provisions:

- A. Measure and record on the boiler firing the waste stream the concentrations of ~~CO~~ in the exhaust stack. 8-hour average concentrations shall be calculated in percent concentration.
- B. Measure and record on the boiler firing the waste stream the concentrations of ~~CO~~ in the exhaust stack. 8-hour average concentrations shall be calculated in ppmv.
- C. The CEMS required in Special Provision No. 9A and 9B shall comply with the following requirements:

1. The CEMS shall meet the design and performance specifications, pass the field tests and meet the installation requirements and data analysts and reporting requirements specified in the applicable Performance Specifications in 40 CFR 60, Appendix B. The Performance Specification tests shall be conducted during the sampling required by Special Provision No. 8 and written copies of the results shall be submitted within 60 days

of completion of the tests to the TACB Regional Office in Beaumont and the TACB Quality Assurance Division in Austin.

2. The system shall be zeroed and spanned daily and corrective action taken when the 24-hour span drift exceeds two times the amounts specified in 40 CFR 60, Appendix B. Each gaseous monitor shall be quality assured at least quarterly using cylinder gas audits (CGA). The CGA method to be used is contained in 40 CFR 60, Appendix F, Procedure 1, Section 5.1.2.
3. The gaseous monitoring data shall be reduced to 8-hour average concentrations at least once every day, using a minimum of eight equally spaced data points from each 8-hour period. Three 8-hour averages shall be generated per day.

4. All cylinder gas audit exceedances greater than ± 15 percent accuracy and any unscheduled CEMS downtime shall be reported to the TACB Regional Office in Beaumont and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the Regional Director.

10. The holder of this permit shall submit to the TACB Regional Office in Beaumont and the TACB Compliance Division in Austin quarterly reports as described in 40 CFR 60.7. Such reports are required for each emission unit which is required to be continuously monitored pursuant to Special Provision No. 9. In addition to the information specified in 40 CFR 60.7(c), each report shall contain the hours of operation of the facility and a report summary of the periods of noncomplying emissions and CEMS downtimes by cause.

Standard of Performance for New and Stationary Sources

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

R-2565

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA			
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates* #/hr TPY

Case I: Natural Gas Firing (4)

EB-110	126.6 MM Btu/Hr Boiler	SO2 NOX CO VOC PM	0.08 36.6 13.97 0.19 0.4
EB-111	126.6 MM Btu/Hr Boiler	SO2 NOX CO VOC PM	0.08 36.6 13.97 0.19 0.4
EB-113	126.6 MM Btu/Hr Boiler	SO2 NOX CO VOC PM	0.08 36.6 13.97 0.19 0.4
EB-114	126.6 MM Btu/Hr Boiler	SO2 NOX CO VOC PM	0.08 36.6 13.97 0.19 0.4

Case II: Oil Firing (4)

EB-110	126.6 MM Btu/Hr Boiler	SO2 NOX CO VOC PM	76.95 41.2 13.97 0.75 10.8
EB-111	126.6 MM Btu/Hr Boiler	SO2 NOX CO VOC PM	337.0 180.5 61.2 3.29 47.3

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	AIR CONTAMINANTS DATA Emission Rates	
			#/hr	TPY
EB-113	126.6 MM Btu/Hr Boiler	SO ₂	76.95	337.0
		NO _X	41.2	180.5
		(5) CO	13.97	61.2
		VOC	0.75	3.29
		PM	10.8	47.3
EB-114	126.6 MM Btu/Hr Boiler	SO ₂	76.95	337.0
		NO _X	41.2	180.5
		(5) CO	13.97	61.2
		VOC	0.75	3.29
		PM	10.8	47.3

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name.
- (3) VOC - volatile organic compounds as defined in General Rule 101.1
 NO_X - total oxides of nitrogen
 SO₂ - sulfur dioxide
 PM - particulate matter
 CO - carbon monoxide
- (4) As much as 50 percent of the fuel heat input may be obtained from waste stream residue firing as described in Special Provision 3D.
- (5) CO emission limits are based on a maximum CO exhaust concentration of 100 ppmv.

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

Hrs/day _____ Days/week _____ Weeks/year _____ or Hrs/year 8760

APPENDIX J

Resumes of Test Personnel

BILLY J. MULLINS, JR., President

Education

Post Graduate Study in Environmental Engineering at Southern Methodist University, Dallas, Texas, 1970.

M.S. 1969, New York University, New York, New York, in Civil Engineering (Air Resources).

B.S. 1968, Texas Tech University, Lubbock, Texas, in Civil Engineering (Water Resources).

Studies in Engineering at U.S. Naval Academy, Annapolis, Maryland, 1963-1964.

**Professional
Training
Courses**

Attended Short Course on Air Pollution Engineering at the University of Texas at Austin, February 1970.

Attended four-week management course presented by the American Management Association, 1976.

Certification

Registered Professional Engineer
Certified Visible Emissions Evaluator
Certified Fallout Shelter Analyst
Licensed Private Pilot (Multi-Engine-Land, Instrument)
Diplomat in the American Academy of Environmental Engineers
Inductee into the Stack Sampling Hall of Fame

**Professional
Memberships**

Air Pollution Control Association - Past Chairman,
Southwest Section; Chairman - Consultants Committee
Source Evaluation Society - Past President
Texas Society of Professional Engineers
National Society of Professional Engineers
American Management Association

MULLINS

Technical Experience

Directed and performed stack sampling on over 1400 sources of which over 300 were sampled simultaneously using more than one sampling train at several points in the flue gas stream. 1972-present.

Directed and performed over 200 short-term ambient air studies using mobile sampling vans and various ambient air sampling equipment. 1972-present.

Designed, directed and operated over 20 permanent ambient air networks of various size and duration for a variety of parameters. 1972-present.

Designed surface and underground drainage systems for residential subdivisions, public works projects, and shopping centers. 1969-1972.

Designed several residential subdivisions including lot layout, street design, drainage design, and utility design. 1969-1972.

Research Projects

Supervised and conducted a study made by the Hawaiian Sugar Planters' Association to characterize the emissions for several bagasse-fired boilers. April-May 1976.

Supervised and conducted a study made by the Rio Grande Valley Sugar Growers, Inc. to determine the area affected by the burning of sugarcane fields prior to harvesting. November 1974-April 1975.

Supervised and conducted a study by a lightweight aggregate manufacturer to develop a material balance around the process through sampling and analysis of several parameters. November 1973.

Conducted a study in New York City to attempt to develop a correlation in the ambient air between carbon dioxide and sulfur dioxide to provide a tool for predicting air pollution episodes. January-May 1969.

MULLINS

Publications

Co-authored "Sulfur Compound Emissions of the Petroleum Production Industry," December 1974.

Co-authored "Field Procedure for Stabilizing Hydrogen Sulfide Samples to be Analyzed Using Modified Methylene Blue Technique," presented at the Conference on Ambient Air Quality Measurements, Austin, Texas, March 1975.

Co-authored "Atmospheric Emissions Survey of the Sour Gas Industry," October 1975.

Co-authored "Technique for Insuring the Validity of Samples for High Concentrations of Sulfur Dioxide Using the EPA Method 5 Sampling Train," presented at the Third National Conference on Energy and the Environment, College Corner, Ohio, September 1975.

Teaching Experience

Served as a lecturer in the Environmental Protection Agency's training course number 450, "Source Sampling for Particulate Pollutants," for two years from January 1974 to October 1975.

Conducted a two-day training course entitled "Technical Assistance in Source Sampling" at Iowa State University, Ames, Iowa, for the Environmental Protection Agency, October 1974.

Conducted EPA's training course number 450, "Source Sampling for Particulate Pollutants," for the EPA at Research Triangle Park, North Carolina, September 1975.

Conducted a two-day short course entitled "Performing and Observing Source Sampling" at Dallas, Texas, July 1976, May 1977, October 1977; at Lake Charles, Louisiana, May 1977; and at Casper, Wyoming, May 1977.

Served as a lecturer in the Environmental Protection Agency's two-day seminar entitled "Asphalt Industry Environmental Solutions," presented in Dallas, Texas, on March 21 and 22, 1979.

Conducted a two-day short course entitled "Performing and Observing Source Sampling" in Lincoln, Nebraska, in March 1980 for the State of Nebraska, Air Quality Control Division.

THOMAS J. BILL, Senior Environmental Field Technician

Education

B.S. 1976, Kent State University, Kent, Ohio, in Chemistry with a minor in Psychology.

Technical Experience

Participated in the sampling of over 500 sources, including several of which were sampled simultaneously using more than one sampling train. Thoroughly trained in all EPA testing procedures. 1980-present.

Thoroughly trained and familiar with the operation of Hach/Carle Gas Chromatograph Model 100 (both TCD and FID), Shimadzu GC-Mini 2 Gas Chromatograph, Thermo Electron Model 48 Gas Correlation CO Analyzer, Thermo Electron Model 10AR Chemiluminescent NO_x Analyzer, Horiba CO Analyzer, Teledyne Oxygen Monitor, Western Research Institute Model 721 AT Sulfur Dioxide Analyzer, CEA CO₂ NDIR Analyzer, and Ratfisch RS 55 and RS 103 FID Total Hydrocarbon Analyzers.

Have performed on-site gravimetric particulate matter analysis, SO₂ analysis, and H₂S gas analysis.

Professional Training Courses

Industrial Management Council Seminar, Washington, D.C., 1979. Essential Skills for the Successful Manager, University of Toledo, 1981. Assertiveness Training for Managers, Wright State University, 1982. How to Make Better Decisions and Successful Delegation, AMA Extension Courses, 1985.

Inactive Hazardous Waste Sites Training Program (40 hours) given by The University of Texas Health Center at Tyler, Texas, May 1990.

BILL

**Research
Projects**

Catalytic Reactions on High Temperature
Dimer-Polyamides. Polymeric Materials Absorbance
of Electrical and Thermal Target Sources.

**Professional
Memberships**

Air and Waste Management Association

WASTE STREAM COMPOSITIONS

R-2565

<u>Compound</u>	<u>Typical Percent by Weight</u>	<u>Maximum Percent by Weight</u>
<u>Stream 1 - Hexane Drawdown Residue</u>		
Hexane	38.95	75.0
Methyl Cyclopentane	8.4	25.0
Cyclohexane	29.2	50.0
Heptane	0.2	1.0
4-Vinylcyclohexane-1	5.9	80.0
Styrene	16.0	80.0
Divinylbenzene	1.3	10.0
Di-tert-butyl-para cresol	0.06	6.0
<u>Stream 2 - Butene Residue</u>		
Trans & Cis Butene	60.02	95.0
Butadiene	33.03	60.0
2 & 3-Methylbutene-1	0.10	0.5
Ethyl Acetylene	7.74	10.0
<u>Stream 3 - Pentane Residue</u>		
Cis-butene 2	0.03	1.0
N & Isopentane	0.6	3.0
3-Methylbutene-1	55.89	75.0
C5 Isomers	38.49	50.0
Butadiene	4.0	8.0

Percentages may not add to 100% due to rounding errors.