

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Texaco Refining & Marketing, Inc.
P. O. Box 1476
Bakersfield, California 93302

BOILERS A AND B

Prepared by
Steiner Environmental, Inc.
4930 Boylan Street
Bakersfield, California 93308

ANNUAL COMPLIANCE TEST


June 19, 1992

EPA NSR 4-4-8; SJ 7877
Kern County APCD Number 2007213 and 2007214

Report PS-92-2818/Project 7204-92

Test Team Leader: Phil Sandberg

Approved by :


Jim Steiner, Project Manager
July 8, 1992

SUMMARY OF SOURCE TEST RESULTS FOR EPA

Company : TEXACO R & M Permit Number : NSR 4-4-8;SJ 7877
 Unit Number or Name : BOILERS A & B Location : COMMON STACK

Pollutant/Other	Test Method	Test Date	Emission / Other*	
			Test Results	Permit Limit
SO2	U.S. EPA METHOD 5/8	JUNE 19, 1992	lb/MMBtu	lb/MMBtu
NOx as NO2	CARB Method 1-100	JUNE 19, 1992	0.047 lb/MMBtu	0.020 lb/MMBtu
Hydrocarbon			4.47 lb/hr	15.00 lb/hr
Sulfur Content			lb/MMBtu	lb/MMBtu
Fuel Usage			percent	percent
Excess Oxygen				
Other				

* Emissions/Other should be at standard conditions (68dF and 29.92 inches of Hg) and in units of EPA's Authority to Construct/Modify.

Prepared by : Jim Steiner
 Title : President
 Date : 7/8/92

Company :	TEXACO R & M	Test Date:	JUNE 19, 1992	APCD No.:	2007213	Unit No. :	BOILERS A & B
					2007214		

POLLUTANT	INLET			OUTLET			Removal Percent	Emission Factor Outlet
	Concentration	Mass Flow Rate	Concentration	Mass Flow Rate	Concentration	Mass Flow Rate		
Particulate				0.0039	0.0062			0.34
avg.				0.0034	0.0056			0.30
				0.0025	0.0036			0.21
				0.0033	0.0051			0.28
Sulfate				0.0013	0.0020			0.11
avg.				0.0013	0.0021			0.11
				0.0011	0.0016			0.09
				0.0012	0.0019			0.10
SO2 (wet)						19.95		2.01
avg.						20.11		2.03
						18.07		1.80
						19.38		1.95
NOx as NO2 (dry)						70.09	93.91	4.51
avg.						67.97	89.33	4.32
						72.01	88.23	4.58
						70.02	90.49	4.47
HC (> C1)								
avg.								
CO						1.00		0.04
avg.						1.80		0.07
						1.02		0.04
						1.27		0.05
avg.								
Scrubber Liquor Analysis : Chlorides - mg/l Specific Gravity -								
For Kern County Use Only ANNUAL 210.1 + EPA								
Comments : 3.0 % O2 correction.								

TABLE OF CONTENTS

Section		Page
1	INTRODUCTION	1-1
2	WET METHODS DATA SUMMARIES	2-1
3	WET TEST METHOD CALCULATIONS	3-1
4	CONTINUOUS METHODS DATA	4-1
5	ANALYSIS PROCEDURES	5-1
6	SAMPLING PROCEDURES	6-1
7	RAW DATA	7-1
8	QUALITY ASSURANCE	8-1
	APPENDIX A - RESULTS AT EPA CONDITIONS .	A-1

SECTION 1

INTRODUCTION

At the request of Texaco Refining & Marketing, Inc., Steiner Environmental, Inc. conducted a series of measurements on the effluent of Boilers A and B located at their Bakersfield Refinery Plant. These tests were conducted on June 19, 1992. The purpose of these tests was to determine compliance with EPA and Kern County Rules and Regulations.

Triplicate 60-minute continuous monitor tests for NO_x , CO, CO_2 and O_2 were performed at the common stack using CARB Method 1-100. Triplicate particulate, sulfate and SO_2 tests were performed using EPA Method 5/8. A sample of the fuel gas fired in the boilers was collected by Steiner Environmental, Inc. and analyzed by Pacific Gas Technology using ASTM procedures.

Messrs. Phil Sandberg and Scott Wine of Steiner Environmental conducted these tests. Mr. Bill Kerstan of Texaco Refining & Marketing was on-site to oversee the operation of the boilers. Kern County APCD did not have a representative present to observe the test program.

SECTION 2
WET METHOD DATA SUMMARIES

A. FIELD DATA SUMMARY

PLANT : TEXACO R & M
BOILERS A & B
DATE : JUNE 19,1992

	RUN 1	RUN 2	RUN 3
Vlc = Vol water collected in train, ml	219.5	253.6	222.2
Vm = Sample gas vol, meter cond., dacf	89.220	86.512	85.347
Y = Meter calibration factor	1.0076	1.0076	1.0076
Pbar = Barometric pressure, in. Hg	29.91	29.88	29.82
Pstatic = Stack static pressure, in. H2O	-0.28	-0.23	-0.24
dH = Avg meter pressure diff, in. H2O	2.41	2.34	2.29
Tm = Absolute meter temp., degrees R	566.9	548.3	543.9
Vm(std) = Sample gas vol, Std. cond., dscf	82.929	83.031	82.408
Bws = Water vapor in gas stream, fraction	0.109	0.124	0.111
MF = Moisture factor (1 - Bws)	0.891	0.876	0.889
CO2 = Carbon Dioxide, dry, volume %	8.43	8.46	9.17
O2 = Oxygen, dry, volume %	7.54	7.28	6.29
N2 = Nitrogen, dry volume %	84.03	84.26	84.54
Md = Molecular weight of stack gas, dry	29.65	29.64	29.72
Ms = Molecular weight of stack gas, wet	28.38	28.20	28.42
Cp = Pitot tube coefficient	0.84	0.84	0.84
Sq.Rt. dP = Avg. square root of each dP	0.4677	0.4684	0.4661
Ts = Absolute stack temp., degrees R	973.0	972.7	979.5
A = Area of stack, ft2	8.62	8.62	8.62
Qstd = Volumetric flowrate, dscfm	8,845	8,737	8,749
An = Nozzle area, ft2	8.25E-04	8.25E-04	8.25E-04
O = Sample time, minutes	96.00	96.00	96.00
%I = Isokinetic variation, percent	101.98	103.38	102.46

B. PARTICULATE DATA SUMMARY

PLANT : TEXACO R & M
BOILERS A & B
DATE : JUNE 19,1992

	RUN 1	RUN 2	RUN 3
Particulate Weight (FHW + MF + BHW), mg ...	23.86	21.44	15.05
Meter Volume, standard cond., Vm(std)	82.929	83.031	82.408
Carbon Dioxide, percent	8.43	8.46	9.17
Particulate Concentration :			
gr/scf	0.0040	0.0035	0.0025
gr/dscf	0.0044	0.0040	0.0028
gr/dscf @ 12 % CO2	0.0063	0.0057	0.0037
Particulate Emission Rate :			
lbs/hr	0.34	0.30	0.21

C. SULFATE DATA SUMMARY

PLANT : TEXACO R & M
 BOILERS A & B
DATE : JUNE 19,1992

Normality of BaCl₂, Front Half: 0.0099601
Normality of BaCl₂, Back Half : 0.0099800

	RUN 1	RUN 2	RUN 3
FILTERABLE SULFATE :			
Front Half Sulfate (FHS), mg H ₂ SO ₄	5.03	4.73	4.05
Sample Volume, ml	100	100	100
Sample Aliquot, ml	10	10	10
Volume of Titer, ml	1.10	1.04	0.90
Volume of Titer Blank, ml	0.07	0.07	0.07
CONDENSIBLE SULFATE :			
Back Half Sulfate (BHS) , mg H ₂ SO ₄	2.69	3.33	2.64
Sample Volume, ml	100	100	100
Sample Aliquot, ml	10	10	10
Volume of Titer, ml	0.62	0.75	0.61
Volume of Titer IPA Blank, ml	0.06	0.06	0.06
grains, [mg x (15.4324E-3)], Front Half ...	0.077625	0.072995	0.062501
grains, [mg x (15.4324E-3)], Back Half	0.041513	0.051390	0.040742
grains, Total (Front Half + Back Half)	0.119138	0.124385	0.103243
Meter Volume, standard cond., Vm(std)	82.929	83.031	82.408
Carbon Dioxide, percent	8.43	8.46	9.17
Total Sulfate Concentration :			
gr/scf	0.0013	0.0013	0.0011
gr/dscf	0.0014	0.0015	0.0013
gr/dscf @ 12 % CO ₂	0.0020	0.0021	0.0016
Total Sulfate Emission Rate :			
lbs/hr	0.11	0.11	0.09

D. SULFUR DIOXIDE DATA SUMMARY

PLANT : TEXACO R & M
 BOILERS A & B
DATE : JUNE 19,1992

Normality of BaCl2 0.0099601

	RUN 1	RUN 2	RUN 3
SO2 ANALYSIS :			
SO2 Analysis, mg H2SO4	217.67	223.29	196.30
Sample Volume, ml	400	430	410
Sample Aliquot, ml	10	10	10
Volume of Titer, ml	11.24	10.73	9.90
Volume of Titer Blank, ml	0.09	0.09	0.09
Meter Volume, standard cond., Vm(std)	82.929	83.031	82.408
Qstd = Volumetric flowrate, dscfm	8,845	8,737	8,749
Sulfur Dioxide Concentration :			
lb/dscf x 1+E6	3.783	3.875	34.328
ppm (wet)	19.95	20.11	18.07
Sulfur Dioxide Emission Rate :			
lbs/hr	2.01	2.03	1.80

G. CONTINUOUS MONITOR DATA

TEXACO R & M
BOILERS A & B

Date : 6/19/92

3 % O2 Correction

Nitrogen Dioxide

Run #	% O2	Corrected ppm (dry)	Corrected ppm (dry) @O2 Corr.*	lb/hr
1	7.54	70.09	93.87	4.51
2	7.28	67.97	89.35	4.32
3	6.29	72.01	88.20	4.58
Average	7.03	70.02	90.47	4.47

Sulfur Dioxide

Run #	ppm (wet)	ppm (dry)	lb/hr
1			
2			
3			
Average			

Carbon Monoxide

Run #	Corrected ppm (dry)	lb/hr
1	1.00	0.04
2	1.80	0.07
3	1.02	0.04
Average	1.27	0.05

SECTION 3
WET TEST METHOD CALCULATIONS

SOURCE TEST CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 1
DATE : JUNE 19,1992

STANDARD TEMP.: 60 DEG. F

METER TEMP.	=	106.85 DEG. F		STATIC PRESS.=	-0.28 in. H2O
STACK TEMP.	=	513.00 DEG. F		Cp	= 0.840
SQ.RT. dP	=	0.4677 in. H2O		STACK I.D.	= 39.75 inch
METER ORIFICE	=	2.41 in. H2O		DUCT LENGTH	= inch
METER VOLUME	=	89.220 Cu.Ft.		DUCT WIDTH	= inch
METER Y	=	1.0076		STACK AREA	= 8.618 Sq.Ft.
BAR. PRESSURE	=	29.91 in.Hg		TEST TIME	= 96.00 min.
COND.(Vlc)	=	219.5 ml		NOZZLE DIA.	= 0.3890 inch

GAS ANALYSIS	=	7.54 % O2		0.00 % CO
		8.43 % CO2		84.03 % N2

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times$
 $(Pb + (dH / 13.6)) / (Tm + 460) \dots\dots = 82.929 \text{ dscf}$

$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic = 10.175 \text{ scf}$

$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots = 0.109$ | Lower
| Bws

Bws @ Saturated Conditions = Vapor Press. of H2O
@ Dew Point Temp. / (Ps, in.Hg.) $\dots\dots\dots = 1.000$ | value
| used.

$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 51.49$

$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.65$

$Ms = (Md \times (1-Bws)) + (18.0 \times Bws) \dots\dots\dots = 28.38$

$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots = 29.89 \text{ in. Hg}$

$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460)$
 $/ (Ms \times Ps)] \dots\dots\dots = 35.97 \text{ ft/sec}$

$Qs = vs \times As \times 60 \dots\dots\dots = 18,601 \text{ acf/min}$

$Qs(std) = Qs \times (1-Bws) \times ((Tstd + 460) / (Ts + 460))$
 $\times (Ps / 29.92) \dots\dots\dots = 8,845 \text{ dscf/min}$

$I = (Ts+460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd +$
 $460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) = 101.98 \%$

SOURCE TEST CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 2
DATE : JUNE 19,1992

STANDARD TEMP.: 60 DEG. F

METER TEMP.	=	88.33 DEG. F		STATIC PRESS.=	-0.23 in. H2O
STACK TEMP.	=	512.67 DEG. F		Cp	= 0.840
SQ.RT. dP	=	0.4684 in. H2O		STACK I.D.	= 39.75 inch
METER ORIFICE	=	2.34 in. H2O		DUCT LENGTH	= inch
METER VOLUME	=	86.512 Cu.Ft.		DUCT WIDTH	= inch
METER Y	=	1.0076		STACK AREA	= 8.618 Sq.Ft.
BAR. PRESSURE	=	29.88 in.Hg		TEST TIME	= 96.00 min.
COND.(Vlc)	=	253.6 ml		NOZZLE DIA.	= 0.3890 inch

GAS ANALYSIS	:	7.28 % O2	0.00 % CO
		8.46 % CO2	84.26 % N2

$$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots\dots = 83.031 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic = 11.756 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots = 0.124 \text{ | Lower Bws value used.}$$

$$Bws @ \text{ Saturated Conditions} = \text{Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)} \dots\dots\dots = 1.000 \text{ | used.}$$

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 48.65$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.64$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots = 28.20$$

$$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots = 29.86 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots\dots\dots = 36.15 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots\dots\dots = 18,692 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots\dots\dots = 8,737 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92)] \times 100 / (Time \times Ps \times An \times vs \times 60) = 103.38 \%$$

SOURCE TEST CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 3
DATE : JUNE 19,1992

STANDARD TEMP.: 60 DEG. F

METER TEMP.	=	83.88 DEG. F		STATIC PRESS.=	-0.24 in. H2O
STACK TEMP.	=	519.50 DEG. F		Cp	= 0.840
SQ.RT. dP	=	0.4661 in. H2O		STACK I.D.	= 39.75 inch
METER ORIFICE	=	2.29 in. H2O		DUCT LENGTH	= inch
METER VOLUME	=	85.347 Cu.Ft.		DUCT WIDTH	= inch
METER Y	=	1.0076		STACK AREA	= 8.618 Sq.Ft.
BAR. PRESSURE	=	29.82 in.Hg		TEST TIME	= 96.00 min.
COND.(Vlc)	=	222.2 ml		NOZZLE DIA.	= 0.3890 inch

GAS ANALYSIS	:	6.29 % O2	0.00 % CO
		9.17 % CO2	84.54 % N2

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times$ $(Pb + (dH / 13.6)) / (Tm + 460) \dots\dots$	=	82.408	dscf
$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic$	=	10.301	scf
$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots$	=	0.111	Lower Bws value used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000	
$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100$	=	39.24	
$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)]$	=	29.72	
$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots$	=	28.42	
$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots$	=	29.80 in. Hg	
$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460)$ $/ (Ms \times Ps)] \dots\dots\dots$	=	36.00	ft/sec
$Qs = vs \times As \times 60 \dots\dots\dots$	=	18,613	acf/min
$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460))$ $\times (Ps / 29.92) \dots\dots\dots$	=	8,749	dscf/min
$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd +$ $460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) =$		102.46	%

EMISSION RATE CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 1
DATE : JUNE 19, 1992
O2 CORR.: 3.0 %

STANDARD TEMP. : 60 DEG. F

```
*****
Front Half Wash (FHW)      0.01753 grams   | Vm(std)  82.929 ft3
Mass Filter (MF)           0.00185 grams   | Vw(std)  10.175 ft3
Back Half Wash (BHW)       0.00448 grams   | Qs(std)   8,845 dscfm
Front Half Sulfate (FHS)    5.03 mg H2SO4  | Bws       0.109
Back Half Sulfate (BHS)     2.69 mg H2SO4  | CO2       8.43 %
H2O2 Catch (SO2)           217.67 mg H2SO4 | O2        7.54 %
*****
```

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] 8476.93 dscf/MMBtu

FILTERABLE PARTICULATE

```
15.432 x (FHW + MF) / [Vm(std) + Vw(std)] ..... 0.0032 gr/scf
15.432 x (FHW + MF) / Vm(std) ..... 0.0036 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0051 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.27 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0068 lb/MMBtu
```

TOTAL PARTICULATE

```
15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std))] ... 0.0040 gr/scf
15.432 x (FHW + MF + BHW) / Vm(std) ..... 0.0044 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0063 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.34 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0084 lb/MMBtu
```

TOTAL SULFATE

```
0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)] ..... 0.0013 gr/scf
0.015432 x (FHS + BHS) / Vm(std) ..... 0.0014 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0020 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.11 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0027 lb/MMBtu
```

SULFUR DIOXIDE (SO2)

```
1.60982 x [T(std) + 460] x (mg H2SO4) / [ 98.076 x
Vm(std)] ..... 22.40 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)] ..... 30.02 @ O2 corr.
ppm x (1 - Bws) ..... 19.95 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460].. 2.01 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x
[20.9 / (20.9 - %O2)] x ppm ..... 0.0502 lb/MMBtu
lb/hr / (dscfm x 60 min/hr) ..... 3.78E-06 lb/dscf
```

SULFUR (S)

```
(lb/MMBtu SO2) / 2 ..... 0.0251 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076) ..... 0.0009 lb/MMBtu
Total Sulfur ..... 0.0260 lb/MMBtu
```


EMISSION RATE CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 2
DATE : JUNE 19, 1992
O2 CORR.: 3.0 %

STANDARD TEMP. : 60 DEG. F

```
*****
Front Half Wash (FHW)      0.01510 grams   | Vm(std)  83.031 ft3
Mass Filter (MF)           0.00085 grams   | Vw(std)  11.756 ft3
Back Half Wash (BHW)       0.00549 grams   | Qs(std)   8,737 dscfm
Front Half Sulfate (FHS)    4.73 mg H2SO4   | Bws       0.124
Back Half Sulfate (BHS)     3.33 mg H2SO4   | CO2       8.46 %
H2O2 Catch (SO2)           223.29 mg H2SO4   | O2        7.28 %
*****
```

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] 8476.93 dscf/MMBtu

FILTERABLE PARTICULATE

```
-----
15.432 x (FHW + MF) / [Vm(std) + Vw(std)] ..... 0.0026 gr/scf
15.432 x (FHW + MF) / Vm(std) ..... 0.0030 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0042 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.22 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0055 lb/MMBtu
```

TOTAL PARTICULATE

```
-----
15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std))] ... 0.0035 gr/scf
15.432 x (FHW + MF + BHW) / Vm(std) ..... 0.0040 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0057 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.30 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0074 lb/MMBtu
```

TOTAL SULFATE

```
-----
0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)] ..... 0.0013 gr/scf
0.015432 x (FHS + BHS) / Vm(std) ..... 0.0015 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0021 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.11 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0028 lb/MMBtu
```

SULFUR DIOXIDE (SO2)

```
-----
1.60982 x [T(std) + 460] x (mg H2SO4) / [ 98.076 x  
Vm(std)] ..... 22.95 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)] ..... 30.17 @ O2 corr.
ppm x (1 - Bws) ..... 20.11 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460].. 2.03 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x  
[20.9 / (20.9 - %O2)] x ppm ..... 0.0504 lb/MMBtu
lb/hr / (dscfm x 60 min/hr) ..... 3.88E-06 lb/dscf
```

SULFUR (S)

```
(lb/MMBtu SO2) / 2 ..... 0.0252 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076) ..... 0.0009 lb/MMBtu
Total Sulfur ..... 0.0261 lb/MMBtu
```

EMISSION RATE CALCULATIONS

PLANT :TEXACO R & M
BOILERS A & B

RUN NO.: 3
DATE : JUNE 19,1992
O2 CORR.: 3.0 %

STANDARD TEMP. : 60 DEG. F

```
*****
Front Half Wash (FHW)      0.00956 grams | Vm(std)  82.408 ft3
Mass Filter (MF)           0.00150 grams | Vw(std)  10.301 ft3
Back Half Wash (BHW)       0.00399 grams | Qs(std)   8,749 dscfm
Front Half Sulfate (FHS)    4.05 mg H2SO4 | Bws       0.111
Back Half Sulfate (BHS)     2.64 mg H2SO4 | CO2       9.17 %
H2O2 Catch (SO2)           196.30 mg H2SO4 | O2        6.29 %
*****
```

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] 8476.93 dscf/MMBtu

FILTERABLE PARTICULATE

```
15.432 x (FHW + MF) / [Vm(std) + Vw(std)] ..... 0.0018 gr/scf
15.432 x (FHW + MF) / Vm(std) ..... 0.0021 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0027 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.16 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0036 lb/MMBtu
```

TOTAL PARTICULATE

```
15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ... 0.0025 gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std) ..... 0.0028 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0037 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.21 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0049 lb/MMBtu
```

TOTAL SULFATE

```
0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)] ..... 0.0011 gr/scf
0.015432 x (FHS + BHS) / Vm(std) ..... 0.0013 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0016 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.09 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0022 lb/MMBtu
```

SULFUR DIOXIDE (SO2)

```
1.60982 x [T(std) + 460] x (mg H2SO4) / [ 98.076 x
Vm(std)] ..... 20.33 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)] ..... 24.91 @ O2 corr.
ppm x (1 - Bws) ..... 18.07 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460].. 1.80 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x
[20.9 / (20.9 - %O2)] x ppm ..... 0.0416 lb/MMBtu
lb/hr / (dscfm x 60 min/hr) .....3.43E-06 lb/dscf
```

SULFUR (S)

```
(lb/MMBtu SO2) / 2 ..... 0.0208 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076) ..... 0.0007 lb/MMBtu
Total Sulfur ..... 0.0215 lb/MMBtu
```

SECTION 4
CONTINUOUS METHODS DATA

A. CALIBRATION AND CORRECTION DATA

Company : TEXACO R & M Date : 6/19/92
 Station : BOILERS A & B Test Run : 1
 REF GAS

Concentration : Drift Uncorrected (A) / Corrected (B)											
Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx		
	A	B	A	B	A	B	A	B	A	B	
1	7.90	7.87	8.40	8.42	1.00	1.00			72.80	72.61	
2	7.80	7.72	8.44	8.49	1.00	1.00			71.80	71.25	
3	7.40	7.28	8.50	8.58	1.00	1.00			72.20	71.28	
4	7.48	7.31	8.44	8.56	1.00	1.00			71.80	70.53	
5	6.85	6.66	8.74	8.90	1.00	1.00			75.60	73.88	
6	7.25	7.00	8.54	8.73	1.00	1.00			71.60	69.63	
7	8.05	7.72	8.12	8.33	1.00	1.00			74.70	72.28	
8	9.13	8.71	7.24	7.46	1.00	1.00			61.50	59.24	
MEAN		7.54		8.43		1.00					70.09

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.00		0.00		0.00				-0.20
Span Check		17.02		14.98		392.50				85.20
Cal. Gas		16.18		15.47		392.00				81.80
Scf		0.00649		-0.00396		0.00016				0.00550
Zcf		0.00000		0.00000		0.00000				-0.02500

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : TEXACO R & M Date : 6/19/92
 Station : BOILERS A & B Test Run : 2
 Test Condition: REF GAS

Concentration : Drift Uncorrected (A) / Corrected (B)										
Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	6.00	6.00	9.10	9.11	0.53	0.53			75.40	75.38
2	7.63	7.62	8.40	8.42	2.00	2.01			68.00	67.96
3	7.38	7.36	8.34	8.38	0.70	0.70			67.00	66.93
4	8.13	8.09	8.16	8.21	3.00	3.02			67.00	66.90
5	6.88	6.84	8.30	8.36	2.80	2.83			65.50	65.38
6	7.85	7.80	8.20	8.28	1.70	1.72			65.40	65.25
MEAN		7.28		8.46		1.80				67.97

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.00		0.00		0.00				0.00
Span Check		16.30		15.38		7.70				82.00
Cal. Gas		16.18		15.54		7.80				81.80
Scf		0.00124		-0.00172		-0.00214				0.00041
Zcf		0.00000		0.00000		0.00000				0.00000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : TEXACO R & M Date : 6/19/92
 Station : BOILERS A & B Test Run : 3
 Test Condition: REF GAS

Concentration : Drift Uncorrected (A) / Corrected (B)										
Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	6.33	6.34	8.80	8.80	1.00	1.00			68.20	68.12
2	5.25	5.28	9.66	9.65	1.00	1.00			75.80	75.55
3	7.18	7.24	8.74	8.73	1.00	1.00			68.70	68.32
4	5.73	5.80	9.36	9.34	1.00	1.00			74.30	73.72
5	6.25	6.35	9.46	9.43	1.10	1.10			77.00	76.23
6	6.58	6.71	9.10	9.07	1.00	1.00			71.00	70.14
MEAN		6.29		9.17		1.02				72.01

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.00		0.00		0.00				0.00
Span Check		15.85		15.60		199.20				82.90
Cal. Gas		16.18		15.54		199.80				81.30
Scf		-0.00340		0.00064		-0.00050				0.00224
Zcf		0.00000		0.00000		0.00000				0.00000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

B. ZERO AND SPAN DRIFT PERCENT CALCULATIONS

Company : TEXACO R & M

Date : 6/19/92

Station : BOILERS A & B

Run 1	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	16.18	15.47	392.00		81.80
Measured Span	17.02	14.98	392.50		85.20
Zero Drift	0.00	0.00	0.00		-0.20
Final, Actual Span	17.02	14.98	392.50		85.40
Percent Drift	5.2	-3.2	0.1		4.4
*****	*****	*****	*****	*****	*****
Run 2	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	16.18	15.54	7.80		81.80
Measured Span	16.30	15.38	7.70		82.00
Zero Drift	0.00	0.00	0.00		0.00
Final, Actual Span	16.30	15.38	7.70		82.00
Percent Drift	0.7	-1.0	-1.3		0.2
*****	*****	*****	*****	*****	*****
Run 3	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	16.18	15.54	199.80		81.80
Measured Span	15.85	15.60	199.20		82.90
Zero Drift	0.00	0.00	0.00		0.00
Final, Actual Span	15.85	15.60	199.20		82.90
Percent Drift	-2.0	0.4	-0.3		1.3

Final, Actual Span = Measured Span - Zero Drift

Percent Drift = (Final, Actual Span - Initial Span) / Initial Span x 100

EMISSION RATE CALCULATIONS

PLANT : TEXACO R & M
SOURCE : BOILERS A & B

Temp. Std. : 60 dF
Press. Std.: 29.92 in. Hg. 3 % O2 Correction

Run No.	1	2	3	AVERAGE
Date	6/19/92	6/19/92	6/19/92	
Oxygen (%)	7.54	7.28	6.29	7.03
Qs(std), dscfm	8,845	8,737	8,749	8,777
NOx, ppm	70.09	67.97	72.01	70.02
SO2, ppm				
CO, ppm	1.00	1.80	1.02	1.27
HC, ppm				
F-Factor	8476.93	8476.93	8476.93	8476.93

NOx, MW = 46.005				
NOx, lb/hr	4.51	4.32	4.58	4.47
NOx, ppm @ O2	93.87	89.35	88.20	90.47
NOx, lb/MMBtu	0.1127	0.1073	0.1059	0.1086

SO2, MW = 64.058
SO2, lb/hr
SO2, ppm @ O2
SO2, lb/MMBtu

CO, MW = 28.010				
CO, lb/hr	0.04	0.07	0.04	0.05
CO, ppm @ O2	1.34	2.37	1.25	1.65
CO, lb/MMBtu	0.0010	0.0017	0.0009	0.0012

HC, MW = 16.043
HC, lb/hr
HC, ppm @ O2
HC, lb/MMBtu

$$* \text{ lb/hr} = 8.223\text{E-}5 \times \text{Qs(std)} \times \text{MW} \times \text{ppm} / (\text{Tstd} + 460)$$

$$* \text{ ppm @ O2} = \text{ppm measured} \times [(20.9 - \text{O2\% correction}) / (20.9 - \text{\%O2 measured})]$$

$$* \text{ lb/MMBtu} = \text{F-Factor} \times \text{MW} \times [1.3711\text{E-}6 / (\text{Tstd} + 460)] \times [20.9 / (20.9 - \text{O2\%})] \times \text{ppm}$$

$$* \text{ lb/Bbl} = (\text{lb/MMBtu}) \times (\text{MMBtu/Bbl})$$

SECTION 5

ANALYSIS PROCEDURES

This section of the report describes the procedures used to analyze the samples collected during the test program. Pacific Gas Technology performed the fuel gas analysis. All other analyses were performed in the Steiner Environmental laboratory in Bakersfield.

5.1 ANALYSIS OF PARTICULATE-SO_x SAMPLES

5.1.1 Nozzle, Probe, Filter Holder Wash

The volume of the acetone washings was measured and the washings were transferred to clean, tared, aluminum weighing dishes. The dishes were placed on temperature-controlled water bath under a fume hood and gently heated to dryness (100°F). The dishes with the dry residue were desiccated and weighed repeatedly at 6-hour intervals until a constant weight was achieved (to the nearest 0.01 mg with a tolerance of <0.1 mg between weighings). The ACS reagent grade acetone blank was treated in the same manner.

5.1.2 Filter

The 100-mm filter was removed from its petri dish and transferred to an oven where it was heated for 2 hours at 105°C. The filter was then desiccated and weighed repeatedly at 6-hour intervals until a constant

weight was achieved (to nearest 0.01 mg with a tolerance of <0.1 mg between weighings). An unused, tared blank filter was treated in the same manner.

5.1.3 Filterable Particulate Sulfate

The acetone washings residue and the 100-mm filter were combined and then leached with distilled water to remove sulfate and the leachate was diluted to 100-ml. An aliquot was passed through ion exchange resin and titrated against 0.01N BaCl₂ (which was previously standardized against 0.0100N H₂SO₄) using the barium-thorin titration procedure specified in EPA Method 8. The acetone blank and 100-mm filter blank were treated in an identical manner.

5.1.4 Condensable Particulate, Sulfate, and SO₂

The 47-mm glass fiber filter was leached with distilled water and the leachate was added to the contents and washings from impinger 1. The volume was measured and the entire volume was transferred to a clean, tared glass evaporating dish. The dish was placed on a temperature-controlled hot plate under a fume hood and gently heated to dryness (150°F). The dish with the dry residue was desiccated and weighed repeatedly at 6-hour intervals until a constant weight was achieved (to nearest 0.01 mg with a tolerance of <0.1 mg between weighings). The dry residue was dissolved in distilled water and diluted to 100-ml using distilled water and analyzed for sulfate using the barium-thorin titration procedure. A blank 47-mm filter and 80-percent IPA solution were treated in the same manner.

5.1.5 SO₂

The volume of contents and washings from bubbler 2 and impinger 3 was measured and an aliquot was analyzed for sulfate using the barium-thorin procedure. A 3-percent H₂O₂ blank was treated in the same manner.

5.2 FUEL

A sample of the fuel fired during this test program was collected and sent to Pacific Gas Technology for analysis. Analysis was performed by PGT in accordance with EPA Title 40 Section 60.45. The specific procedures are itemized in Table 5-1. The results appear at the end of this section.

TABLE 5-1. FUEL ANALYSIS METHODS
LABORATORY TEST PROCEDURES FOR FUEL OILS AND FUEL GASES

Reference: EPA Title 40, Section 60.45

FUEL OIL TESTS:

Sediment and Water, Vol. %	ASTM D4007-81
Gravity by Hydrometer (API)	ASTM D1298-80
API Gravity Corrected to 60°F	ASTM Table 5A
Gross Calorific Value (Btu/lb)	ASTM D2015-77
Ultimate Analysis (C, H, O, N, S, wt. %)	
Carbon, Hydrogen	ASTM D3178-73
Nitrogen (chemiluminescence detector)	ASTM D3431-80
Sulfur	ASTM D2622-82
Ash	ASTM D482
Oxygen	ASTM D3176-74

GASEOUS FUELS BY GAS-LIQUID CHROMATOGRAPHY:

Gas Analysis	ASTM D1945-81
Sulfur Analysis	CPA B16
Calculation of Gross Calorific Value	ASTM D3588-81
Component Weight %, F-factor calculations	EPA 40:60.45

PROCEDURES FOR SCRUBBER LIQUOR ANALYSIS:

Specific Gravity	ASTM D1429
Chlorides	ASTM D512-67

PACIFIC GAS TECHNOLOGY



2122 Q Street
Bakersfield, California 93301
805/324-1317
Fax: 805/324-2746

GAS ANALYSIS BY CHROMATOGRAPH

STEINER ENVIRONMENTAL, INC
4930 Boylan Street
Bakersfield, CA 93308

Attention: J. Steiner

RECEIVED

JUN 26 1992

Ans'd.....

SAMPLED: JUNE 19, 1992

SUBMITTED: JUNE 22, 1992

REPORTED: JUNE 23, 1992

LAB # 4421

Sample ID : TEXACO\AREA 3
BOILERS A & B
REFINERY GAS

STEINER ID # 33077

ANALYZED GAS	MOLE %	WT %	CHONS WT %
OXYGEN	0.04	0.06	CARBON 77.42
NITROGEN	0.13	0.18	HYDROGEN 22.34
CARBON DIOXIDE	ND	0.00	OXYGEN 0.06
HYDROGEN	12.86	1.25	NITROGEN 0.18
CARBON MONOXIDE	ND	0.00	SULFUR 0.00
HYDROGEN SULFIDE	ND	0.00	
METHANE	58.14	45.10	
ETHANE	17.09	24.85	
ETHYLENE	1.37	1.86	
PROPYLENE	1.48	3.01	
PROPANE	4.00	8.53	
iso-BUTANE	0.49	1.38	
n-BUTANE	1.69	4.75	
1-BUTENE/isoBUTYLENE	0.63	1.71	
TRANS BUTENE	0.15	0.41	
Cis BUTENE	0.08	0.22	
1,3-BUTADIENE	0.17	0.44	
iso-PENTANE	0.45	1.57	
n-PENTANE	0.65	2.27	
HEXANE +	0.58	2.42	
SPECIFIC GRAVITY * :	0.714		SPECIFIC VOLUME : 18.35 cu ft/lb
HYDROGEN SULFIDE :		ppm	
(Draeger)			
TOTAL * DRY :	1265		NET * DRY : 1149
BTU/cu ft			BTU/cu ft
WET :	1243		WET : 1129
BTU/lb :	23209		BTU/lb : 21087

* CALCULATED ACCORDING TO : ASTM D-3588

SECTION 6

SAMPLING PROCEDURES

This section of the report describes the equipment and procedures used to conduct the particulate and gaseous tests on this program.

6.1 PRELIMINARY MEASUREMENTS

Before conducting the stack tests a series of preliminary measurements were made to determine:

- The location of the sampling site and the number and location of the sampling points to be used (EPA Method 1)
- The velocity, temperature, and pressure of the gases in the stack (EPA Method 2)
- The composition of the stack gases (EPA Method 3)
- The moisture content of the stack gases (EPA Method 4)

Using the results of these preliminary measurements and the calibration constants for the sampling train, a series of calculations were made to determine the value of K, a constant, and N_d , ideal nozzle diameter, required to run an isokinetic test according to the equation:

$$\Delta H = \left[\frac{60^2 \pi^2 (K_p)^2 (C_p)^2 (1 - B_{wo})^2 P_s MW_d}{576^2 (K_o)^2 MW_s P_m} \right] (N_d)^4 \left(\frac{T_m}{T_s} \right) (\Delta P)$$

where

$$K = \left[\frac{60^2 \pi^2 (K_p)^2 (C_p)^2 (1 - B_{wo})^2 P_s MW_d}{576^2 (K_o)^2 MW_s P_m} \right]$$

An actual nozzle, whose diameter was as close as possible to the ideal nozzle diameter, was selected for the test. Isokinetic sampling rates for each sampling point in the stack were computed using the equation:

$$\Delta H = (K) (N_d)^4 \left(\frac{T_m}{T_s} \right) (\Delta P)$$

Since K and N_d are known, and remain constant during a test, the only variables are the meter temperatures, the stack gas temperature and the velocity pressure for each sampling point.

6.2 PREPARATION OF THE PARTICULATE-SO_x SAMPLING TRAIN

All sampling train components were cleaned in the laboratory (soap and water, tap water rinse, distilled water rinse, and IPA rinse) to eliminate previous contamination. The sampling train components were sealed and transported to the sampling site in a mobile lab. The EPA Method 5/8 equipment used to measure particulates (filterable and total) and SO_x consisted of:

- A calibrated Quartz nozzle for isokinetic sampling
- A heated Quartz sampling probe (6 feet long) equipped with an S-type pitot tube and a thermocouple to measure stack velocity pressure and temperature

- A heated Pyrex glass filter holder containing a weighed 100-mm Whatman 934 AH glass fiber filter
- A Pyrex glass impinger train in an icebath (impinger 1 contained 100-ml 80-percent IPA; a Pyrex glass filter holder containing a 47-mm Whatman 934 AH filter; bubbler 2 and impinger 3 each contained 100-ml of 3-percent H_2O_2 ; bubbler 4 contained a weighed amount of silica gel)
- An umbilical to connect the probe and sample box to the control module
- A control module containing a vacuum pump, a calibrated dry gas meter and a calibrated orifice meter to measure the pressure, temperature and flowrate throughout the train.

The sampling train was charged in the mobile lab using freshly prepared reagents. Each impinger and its contents was weighed to the nearest 0.1 gm on a calibrated electronic balance. Blanks of all filters and reagents were retained for subsequent analysis. The sampling point locations were marked on the probe using a high-temperature marker. The sampling train was completely assembled and lifted to the sampling site.

6.3 SAMPLING PROCEDURES FOR PARTICULATE-SO_x SAMPLING TRAIN

Prior to a test, the sampling train was heated and leak-checked at 15-inches Mercury to insure leakage was less than 0.02 or 4% of the average sampling rate. The S-type pitot tube was also leak-checked. The sampling train was installed on the unirail and the probe was inserted into the stack at the farthest point. An isokinetic sampling rate was calculated using an HP-41CV calculator for each sampling point on the traverse (12 points per traverse; 2 traverses at 90°). Each point was

sampled for an equal period of time (4 minutes) and all pertinent data were recorded on the data sheet for each point. The probe and sample box were maintained at 250°F throughout the traverse. The gases leaving the impinger train were maintained at <68°F. At the end of a traverse, the probe was withdrawn from the stack and the entire sampling train was transferred intact to the next sampling port. Another traverse of the stack was completed and the sampling train was withdrawn for the final leak-check. This leak-check was performed at 15-inches Mercury or at the highest vacuum achieved during the test. The S-type pitot tube was also checked at this time. The sampling train was then purged with ambient air for 15-minutes using the highest ΔH measured during the test. After the train was purged, the filter holder and impinger train were sealed with aluminum foil and lowered to the mobile lab for sample recovery.

6.4 SAMPLE RECOVERY PROCEDURES FOR PARTICULATE-SO_x SAMPLING TRAIN

Sample recovery for the nozzle and probe occurred on the stack. The nozzle and probe were brushed and rinsed three times using ACS reagent grade acetone into a polyethylene sample bottle. Sample recovery for the filter holder and impinger train occurred in the mobile lab. The 100-mm filter was removed from the 4-inch filter holder and sealed in its petri dish. The glass fibers stuck to the gasket were scraped off and put into the petri dish. The front half of the 4-inch glass filter holder was brushed and rinsed with acetone. Each impinger was removed from the icebath, wiped dry and weighed to the nearest 0.1 gm. The contents of impinger 1 were transferred to a polyethylene sample bottle. The back half of the 4-inch glass filter holder, the glass connectors, impinger 1, and the front half of the 2-inch filter holder were rinsed

with 80-percent IPA and the rinsings were transferred to this same bottle. The 47-mm filter from the 2-inch filter holder was sealed in its petri dish. The contents of bubbler 2 and impinger 3 were transferred to a polyethylene sample bottle. Distilled water rinsings of the back half of the 2-inch filter holder, bubbler 2, the connector, and impinger 3 were transferred to this same bottle. All sample bottles and petri dishes were marked and labeled. A chain-of-custody log was completed and the field data sheet was also labeled with the sample ID numbers. The sampling train was then recharged in preparation for the next test.

6.5 SAMPLING PROCEDURES FOR CONTINUOUS MONITORING

The continuous monitors used in the Steiner Environmental Mobile Monitoring Lab are shown in Table 6-1. Figure 6-1 is a schematic of the continuous monitoring system. The procedures used to continuously monitor stack gases for NO_x , O_2 , CO and CO_2 strictly follow CARB Method 1-100.

Sample was taken from the stack at a single point using a 316 stainless steel probe. A heated Balston filter holder and fiberglass filter (99.9999 percent efficiency retention of 0.6 micron particles) was connected to the outlet of the probe. Sample gas was transported through heated Teflon sample line (maintained at $>250^\circ\text{F}$) by a Teflon-lined diaphragm pump to a 316 stainless steel refrigeration type conditioner (Hankison Model E-4G-SS). The sample gas was passed through the conditioner two separate times under vacuum before entering the pump, then two additional times under pressure. The clean, dry sample gas ($\sim 35^\circ\text{F}$) was then transported to the continuous analyzer system through an unheated Teflon line. A series of flowmeters, valves, and regulators maintain constant flow through the system at a constant pressure.

TABLE 6-1. CONTINUOUS MONITORING LAB - TRAILERS 1, 2 AND 4

NO_x CHEMILUMINESCENT ANALYZER -- THERMO ELECTRON MODEL 10

Response Time (0-90%)	1.5 sec -- NO mode; 1.7 sec -- NO _x mode
Zero Drift	Negligible after 1/2 hour warmup
Linearity	±1% of full scale
Accuracy	Derived from the NO or NO ₂ calibration gas, ±1% of full scale
Output	0-10 V
Operating Ranges	0-2, 10, 25, 100, 250, 1000, 2500 and 10,000 ppm
Flowrate = 2 scfh	0-2.5

O₂ ANALYZER, FUEL TYPE -- TELEDYNE MODEL 326

Response Time (0-90%)	60 seconds
Accuracy	±1% of scale at constant temperatures; ±1% of scale of ±5% of reading, whichever is greater, over the operating temperature range
Output	0-1 V
Operating Ranges	0-5%, 10%, 25% O ₂
Flowrate	2 scfh

CO₂/CO INFRARED ANALYZER -- ANARAD MODEL AR-600

Response Time (0-90%)	5 seconds
Zero Drift	±1%
Span Drift	±1%
Linearity	1%
Resolution	Less than 1% of full scale
Output	0-1 V
Operating Ranges	0-20% CO ₂ /0-10,000 ppm CO
Flowrate	1000 cc/min

CO GAS FILTER CORRELATION -- THERMO ELECTRON MODEL 48

Response Time (0-95%)	1 minute
Zero Drift	±0.2 ppm CO
Span Drift	Less than 1% full scale in 24 hours
Linearity	±1% full scale, all ranges
Accuracy	±0.1 ppm CO
Output	0-10 V
Operating Ranges	1, 2, 5, 10, 20, 50, 100, 200, 500, 1000 ppm
Flowrate	.5 - 2 lpm

SO₂ UV ANALYZER -- DUPONT MODEL 400

Response Time (0-90%)	Less than 60 seconds
Zero Drift	Less than 2% full scale in 24 hours
Linearity	±1% full scale
Accuracy	±2% full scale
Output	0-5 V
Operating Ranges	0-100 ppm, 1-1000 ppm
Flowrate	500 - 1500 cc/min

STRIP CHART RECORDERS (3) -- LINSEIS 7025

Pen Response	0.35 seconds Full Scale
Input Spans	1, 2, 5, 10, 20, 50, 100 MV
Zero Set	Stable across entire chart-width ±100%
Accuracy	.35% of Span
Dead Band	.15% of Span
Linearity	.25% of Span
Chart Speed	1, 2, 5, 10, 20, 50, 100 cm/min; 1, 2, 5, 10, 20, 50 cm/hr; fast advance 100 cm/min; LED indicator; forward and reverse selector
Recording Pen	Fiber tip pen
Chart Width	250 mm

SCOTSMAN TRAILER

Fully Insulated	Air Conditioned -- 8 feet x 14 feet x 11 feet
-----------------	---

1. Filter 0.6 μ , 99.9999 percent efficient
2. Duct
3. 316 stainless steel probe
4. 3/8-inch, heated (250°F) Teflon
5. Four-pass conditioner-dryer, 316 stainless steel internals
6. 3/8-inch, unheated Teflon
7. Teflon-lined sample pump
8. 3/8-inch unheated Teflon
9. Rotameter
10. 1/4-inch Teflon tubing
11. Calibration gas manifold
12. Calibration gas selector valve
13. Calibration gas cylinders
14. Backpressure regulator
15. Auxiliary analysis port




FIGURE 6-1. SCHEMATIC OF CONTINUOUS MONITORING SYSTEM

Calibrations of the continuous analyzers were performed using EPA Protocol 1 calibration gases ($\pm 1\%$) for NO_x and NBS certified calibration gases ($\pm 1\%$) for CO , CO_2 and O_2 . Copies of the gas certifications are included in the Quality Assurance Section of this report. All pertinent data (date, time, test locations, analyzer range, cal gas value) were recorded on both the field data sheets and continuous analyzer strip charts in the field.

At the start of a test day, a leak-check was performed. The sample probe was removed from the stack and the end was sealed. A leak-check was successful only if pressure at the analyzer system and flow through the rotameters to the individual analyzers all dropped to zero. A mandatory leak-check was performed at the completion of each test day.

An initial calibration was performed at the start of a test period by introducing zero and span gases for each analyzer and making the necessary adjustments. Calibration gas values were recorded on the continuous monitor strip charts and field data sheets. A calibration check was completed at the end of a test and adjustments (if necessary) to the analyzers were made in preparation for another test.

An external calibration of the sampling system was performed at the start of a test day. EPA Protocol 1 gas was flowed through the entire sampling system from the probe tip. The response of the analyzers had to be within $\pm 5\%$ of the certified tank value before testing could proceed. An external calibration was also performed at the end of each test day.

Test data was collected by recording 10-minute averages from the strip chart recordings onto the field data sheets. Data collected over

the test period was averaged and reported. A fuel analysis was used to calculate the F-factor, dscf/MMBtu corrected to zero percent O₂ (standard conditions 60°F, 29.92 inches Mercury), as described in 40 CFR 60.45. The pollutant concentration and the F-factor were used to calculate an emission factor in lb/MMBtu.

SECTION 7

RAW DATA

SAMPLING POINT LOCATION DATA SHEET

Plant TEXACO Area 3 BKFLD

Date 6-19-92

Test Location Bailers A+B

Upstream Dist./Dia. 186" / 4.7 Ø


Downstream Dist./Dia. 312" / 7.8 Ø

No. of Sampling Points 24

Stack Dimension 39.75"

Coupling Length 11.25"

4-inch MPT/FPT/Flange
50' rope 100' power wire on stack
BRING TRANSFORMER HAS HOOKS.
 XEQ PNT



Sample Point	Dist	Sample Point	Dist	Sample Point	Dist	Sample Point	Dist
1	12.1						
2	13.9						
3	15.9						
4	18.3						
5	21.2						
6	25.4						
7	36.9						
8	41.4						
9	44.0						
10	46.3						
11	48.3						
12	50.2						

SAMPLING POINT RELOCATION: # 1 to 12.3"
 # 12 to 50.0"

PLANT

Texaco Area 3

TEST TYPE

M-5/8

FIELD TEST DATA SHEET (Page

1 of 2)

EPD

Date 6-19-92 Barometric Pressure 29.91
 Test Location Boilers A+B Static in.wg. -0.28
 Run Number #1 Probe Type/Length QT./6'
 Stack Diameter 39.75 Pitot Coefficient 0.84
 Operator SAJ Meter Box No./Y 21313/1.0076
 Filter No. 890 Nozzle No./Size 1023/0.3890

IMPIGGER				VOLUMES/WEIGHTS				GAS COMPOSITION			
Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO	Leakrate	cfm	"Hg	
80% IPA	670.7	560.3	110.4								
3% H ₂ O	594.5	557.5	42.0								
3% H ₂ O	561.5	542.6	18.9								
S.G.	780.0	731.8	48.2					Initial	0.015	15"	
		TOTAL	219.5					Final	0.008	6"	

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F							Pump Vacuum in.Hg	√ΔP	Comments
					Stack	Probe	Oven	Imp.	Gas Meter					
									In	Out				
A-1	1720	0.20	2.23	841.356	503	260	257	75	111	111	5.0	0.447	270+ OK	
2	4	0.24	2.64	844.971	517	267	261	69	112	109	5.5	0.490	33078	
3	8	0.25	2.76	848.824	510	258	271	68	110	108	6.0	0.500		
4	12	0.25	2.71	852.818	525	245	271	67	109	107	6.0	0.500	33077	
5	16	0.26	2.81	856.757	529	262	271	65	109	107	6.0	0.510		
6	20	0.24	2.61	860.780	522	262	260	68	109	106	5.5	0.490	33076	
7	24	0.23	2.51	864.672	518	263	251	67	109	107	5.5	0.480		
8	28	0.245	2.68	868.474	518	244	251	68	110	107	6.0	0.495	33075	
9	32	0.21	2.32	872.408	508	255	242	71	109	108	5.5	0.458		
10	36	0.20	2.19	876.094	514	258	252	72	109	106	5.0	0.447	33074	
11	40	0.19	2.10	879.661	509	251	257	73	109	107	5.0	0.436		
12	44	0.15	1.67	883.142	503	261	242	73	109	107	4.0	0.387	33073	
	18:08			886.240										
														33072



Steiner Environmental, Inc.

PLANT	TEST TYPE	FIELD TEST DATA SHEET (Page	of
TEXACO AREA 3		11-5/8	2
DATE 6-19-92		RUN NO. 1	
TEST LOCATION Boilers A+B		OPERATOR SW	

[illegible]

PLANT TEXACO AREA 3 BKFLD

Date 6-19-92 Barometric Pressure 29.88
 Test Location Baileys A+B Static in.wg. - 0.23
 Run Number #2 Probe Type/Length QT/6'
 Stack Diameter 39.75" Pitot Coefficient 0.84
 Operator SW Meter Box No./Y 21313/1.0076
 Filter No. 881 Nozzle No./Size 1023/3890

IMPIGNER				VOLUMES/WEIGHTS				GAS COMPOSITION			
Contents	Final	Initial	Net					Time	CO ₂	O ₂	CO
80% IPA	645.9	517.1	128.8								
3% H ₂ O ₂	575.2	537.3	37.9								
3% H ₂ O ₂	585.8	548.6	37.2								
								Leakrate	cfm	"Hg	
S.G.	864.5	844.8	49.7					Initial	0.013	15"	
		TOTAL	253.6					Final	0.008	5"	

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	T E M P E R A T U R E °F							Pump Vacuum in. Hg	√ΔP	Comments
					Stack	Probe	Oven	Imp.	Gas Meter					
									In	Out				
A-1	2030	0.22	2.38	953.453	503	262	241	72	93	92	4.0	0.469	Pitot OK	
2	4	0.26	2.73	957.134	526	255	240	70	91	91	4.5	0.510		
3	8	0.24	2.55	961.053	513	262	245	67	90	90	4.0	0.490	33071	
4	12	0.26	2.69	964.824	537	273	247	65	88	89	4.5	0.510		
5	16	0.245	2.61	968.686	510	268	244	61	89	89	4.5	0.495	33069	
6	20	0.20	2.11	972.493	518	256	254	67	88	88	4.0	0.447		
7	24	0.19	2.05	975.951	500	256	254	65	89	89	4.0	0.436	33070	
8	28	0.225	2.37	979.310	520	255	259	68	89	89	4.5	0.474		
9	32	0.205	2.19	982.948	508	257	257	71	89	89	4.0	0.453	33067	
10	36	0.21	2.24	986.459	509	265	255	71	89	89	4.0	0.458		
11	40	0.13	1.39	989.990	505	271	253	71	88	89	3.5	0.361	33068	
12	44	0.175	1.88	992.828	503	262	258	70	89	88		0.418		
	21:18			996.032									33066	

PLANT Texaco Area 3 BKFD TEST TYPE EPA FIELD TEST DATA SHEET (Page 2 of 2)
 DATE 6-19-92 RUN NO. 11-5/8 #2
 TEST LOCATION Boilers A+B OPERATOR SC

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	T E M P E R A T U R E ° F							Pump Vacuum in. Hg	$\sqrt{\Delta P}$	Comments
					Stack	Probe	Oven	Imp.	Gas Meter					
									In	Out				
B-1	21:25	0.18	1.93	996.032	503	259	255	79	88	89	3.5	0.424		
2	4	0.23	2.47	999.278	501	249	259	72	89	88	4.0	0.480		
3	8	0.23	2.44	1002.939	511	263	257	69	88	88	4.0	0.480		
4	12	0.25	2.64	1006.648	517	256	255	69	88	88	4.5	0.500		
5	16	0.265	2.77	1010.477	525	258	260	68	88	87	5.0	0.515		
6	20	0.24	2.53	1014.390	517	254	256	66	87	88	4.5	0.490		
7	24	0.23	2.41	1018.173	522	265	260	66	87	87	4.5	0.480		
8	28	0.24	2.53	1021.854	517	256	258	65	87	87	4.5	0.490		
9	32	0.24	2.51	1025.601	523	270	258	65	87	87	4.5	0.490		
10	36	0.23	2.44	1029.354	508	255	257	63	86	87	4.5	0.480		
11	40	0.18	1.92	1033.043	504	251	258	64	87	86	4.0	0.424		
12	44	0.22	2.35	1036.345	504	248	257	64	86	86	4.0	0.469	Total 10X	
				1039.965									Averaged 15 min	
T/A	96 min		2.34	86.512	512.67					88.33		2.4684		

Date 6/19/92 Barometric Pressure 29.82
 Test Location Bileas A+B Static in.wg. -0.24
 Run Number #3 Probe Type/Length QT/6'
 Stack Diameter 39.75 Pitot Coefficient 0.84
 Operator SWD Meter Box No./Y #21313/1.0076
 Filter No. 891 Nozzle No./Size #10 /3890

IMPIGNER				VOLUMES/WEIGHTS				GAS COMPOSITION			
Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO	Leakrate	cfm	"Hg	
IPA	692.6	577.6	115.0								
37H ₂ O ₂	602.2	561.9	40.3								
37H ₂ O ₂	557.2	534.9	22.3								
S.G.	754.6	710.0	44.6					Initial	0.019	15"	
		TOTAL	222.2	Final	0.010	4"					

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F						Pump Vacuum in. Hg	√ΔP	Comments	
					Stack	Probe	Oven	Imp.	Gas Meter					
									In	Out				
A-1	11:55	0.20	2.14	058.784	508	252	243	78	91	88	5.0	0.447	Flat OK	
2	4	0.25	2.61	059.198	521	259	250	71	84	83	7.0	0.500	MF 33104	
3	8	0.19	2.00	063.000	512	269	253	64	84	83	5.0	0.436	B/K	
4	12	0.20	2.10	066.368	514	254	252	63	84	83	5.0	0.444	MF 33105	
5	16	0.24	2.45	069.771	544	246	252	62	84	83	6.5	0.490	B/K	
6	20	0.235	2.38	073.463	549	273	242	63	84	83	6.0	0.485	MF 33106	
7	24	0.20	2.03	077.097	546	258	248	63	84	83	5.0	0.447	B/K	
8	28	0.105	1.07	080.469	540	240	250	63	83	83	3.0	0.324	IPA 33107	
9	32	0.23	2.43	083.007	506	260	245	63	83	83	6.0	0.480	B/K	
10	36	0.235	2.44	086.618	522	267	250	62	83	82	6.0	0.485	DI 33108	
11	40	0.23	2.40	090.323	520	267	250	62	83	83	6.0	0.480	B/K	
12	44	0.17	1.78	093.977	516	259	247	63	83	82	4.0	0.412	33109 ₃	
	00:43			097.177										MF 33110 ₃
														MF 33111 ₃
														MF 33112 ₃
														MF 33113 ₃
														MF 33114 ₃
														MF 33115 ₃
														MF 33116 ₃

TENARD

DATE 6-19-92

TEST LOCATION	TEST DATE	TEST TIME	TEST TYPE	TEST RESULT	TEST COMMENTS
1. 1000	10/10/10	10:00	1000	1000	1000
2. 1000	10/10/10	10:00	1000	1000	1000
3. 1000	10/10/10	10:00	1000	1000	1000
4. 1000	10/10/10	10:00	1000	1000	1000
5. 1000	10/10/10	10:00	1000	1000	1000
6. 1000	10/10/10	10:00	1000	1000	1000
7. 1000	10/10/10	10:00	1000	1000	1000
8. 1000	10/10/10	10:00	1000	1000	1000
9. 1000	10/10/10	10:00	1000	1000	1000
10. 1000	10/10/10	10:00	1000	1000	1000
11. 1000	10/10/10	10:00	1000	1000	1000
12. 1000	10/10/10	10:00	1000	1000	1000
13. 1000	10/10/10	10:00	1000	1000	1000
14. 1000	10/10/10	10:00	1000	1000	1000
15. 1000	10/10/10	10:00	1000	1000	1000
16. 1000	10/10/10	10:00	1000	1000	1000
17. 1000	10/10/10	10:00	1000	1000	1000
18. 1000	10/10/10	10:00	1000	1000	1000
19. 1000	10/10/10	10:00	1000	1000	1000
20. 1000	10/10/10	10:00	1000	1000	1000
21. 1000	10/10/10	10:00	1000	1000	1000
22. 1000	10/10/10	10:00	1000	1000	1000
23. 1000	10/10/10	10:00	1000	1000	1000
24. 1000	10/10/10	10:00	1000	1000	1000
25. 1000	10/10/10	10:00	1000	1000	1000
26. 1000	10/10/10	10:00	1000	1000	1000
27. 1000	10/10/10	10:00	1000	1000	1000
28. 1000	10/10/10	10:00	1000	1000	1000
29. 1000	10/10/10	10:00	1000	1000	1000
30. 1000	10/10/10	10:00	1000	1000	1000
31. 1000	10/10/10	10:00	1000	1000	1000
32. 1000	10/10/10	10:00	1000	1000	1000
33. 1000	10/10/10	10:00	1000	1000	1000
34. 1000	10/10/10	10:00	1000	1000	1000
35. 1000	10/10/10	10:00	1000	1000	1000
36. 1000	10/10/10	10:00	1000	1000	1000
37. 1000	10/10/10	10:00	1000	1000	1000
38. 1000	10/10/10	10:00	1000	1000	1000
39. 1000	10/10/10	10:00	1000	1000	1000
40. 1000	10/10/10	10:00	1000	1000	1000
41. 1000	10/10/10	10:00	1000	1000	1000
42. 1000	10/10/10	10:00	1000	1000	1000
43. 1000	10/10/10	10:00	1000	1000	1000
44. 1000	10/10/10	10:00	1000	1000	1000
45. 1000	10/10/10	10:00	1000	1000	1000
46. 1000	10/10/10	10:00	1000	1000	1000
47. 1000	10/10/10	10:00	1000	1000	1000
48. 1000	10/10/10	10:00	1000	1000	1000
49. 1000	10/10/10	10:00	1000	1000	1000
50. 1000	10/10/10	10:00	1000	1000	1000
51. 1000	10/10/10	10:00	1000	1000	1000
52. 1000	10/10/10	10:00	1000	1000	1000
53. 1000	10/10/10	10:00	1000	1000	1000
5					

[illegible]

CONTINUOUS MONITOR DATA SHEET

Plant TEXACO - AREA 3 APCD Witness/Number NONE
 Date 6/19/92 Run No. #1 Client Rep BILL KERSTAN
 Test Location BOILERS A & B - COMMON STACK Generator Type _____
 Operator ARS Burner Type _____
 Fuel Type REFGAS Trailer No. #1 O₂ Controller Type _____

Time	Sample Point	Dry Uncorrected					Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm		
1523		Φ	Φ	Φ		Φ	ZERO VALUES	CALIBRATION GASES
		16.18	15.47	836		81.8	SPAN VALUES	NO _x <u>CC40233</u>
1553		Φ.Φ				81.8	EXTERNAL CHECKS	-SO ₂ <u>CC40111</u>
1716		Φ	Φ	Φ		Φ	REAL-ZERO VALUE	CO <u>CC81166</u> , <u>CC91386</u>
		16.18	15.20	392		81.8	SPAN VALUES	CO/CO ₂ /O ₂ <u>CC81159</u> , <u>CC37841</u>
							START RUN #1 @ 1734	Wet Bulb: _____ Dry Bulb: _____
1734	A1	7.90	8.40	<1		72.8		Barometric Press: _____
1744	A2	7.80	8.44	<1		71.8		RESPONSE TIME
1754	A3	7.40	8.50	<1		72.2		Upscale: _____ Downscale: _____
1804	A4	7.48	8.44	<1		71.8		Upscale: _____ Downscale: _____
1814	B1	6.85	8.74	<1		75.6		Upscale: _____ Downscale: _____
1824	B2	7.25	8.54	<1		71.6		PROCESS DATA
1834	B3	8.05	8.12	<1		74.7		Fuel Flow: _____
1844	B4	9.13	7.24	<1		61.5		Steam Flow: _____
1854		Φ	Φ	Φ		-0.2	ZERO CHECK - NO ADJ	Rating: _____
		17.02	14.98	392.5		85.2	SPAN CHECK - NO ADJ	
								CONVERTER GAS
								Cal Gas Values Actual Values
								NO _____ _____
								NO ₂ _____ _____
								Conv. Efficiency: _____

CONTINUOUS MONITOR DATA SHEET

Plant TEXACO - AREA 3 APCD Witness/Number NONE
 Date 6/19/92 Run No. #2 Client Rep BILL KERSTAN
 Test Location BOILERS A & B COMMON STACK Generator Type _____
 Operator PES Burner Type _____
 Fuel Type REF GAS Trailer No. #1 O₂ Controller Type _____

Time	Sample Point	Dry Uncorrected					Comments	Miscellaneous Information	
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm			NO _x ppm
1950		16.18	15.54	7.80			81.8	SPAN GAS VALUES ZERO VALUES START RUN #2026 * INDICATES CO "SPIKE" (MAY SPIKE = 6.52 PPM)	CALIBRATION GASES NO _x SEE RUN #1 CM SHEET SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____
		Ø	Ø	Ø		Ø			
2026	1	6.00	9.10	0.53			75.4		
2036	2	7.63	8.40	2.0*			68.0		
2046	3	7.38	8.34	0.7*			67.0		
2056	4	8.13	8.16	3.0*			65.5	Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____	
2106	5	6.88	8.30	2.8*					
2116	6	7.85	8.20	1.7*					
2026		Ø	Ø	Ø					
		16.30	15.38	7.70			82.0	RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____	
								PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: _____	
								CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____	

CONTINUOUS MONITOR DATA SHEET

Plant TEXACO - AREA 3 APCD Witness/Number NONE
 Date 6/19/92 Run No. #3 Client Rep BILL KERSTON
 Test Location BOILERS AREA COMMON STACK Generator Type _____
 Operator RES Burner Type _____
 Fuel Type REF GAS Trailer No. #1 O₂ Controller Type _____

Time	Sample Point	Dry Uncorrected					NO _x ppm	Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm			
2311		16.18	15.54	7.80			81.8	SPAN GAS VALUES	CALIBRATION GASES NO _x <u>SEE RUN #1 SHEET</u> SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____
2337		Φ	Φ	Φ		Φ		ZERO VALUE	
				199.8				REAL CO-SPAN VALUE	
				Φ				ZERO VALUE	
				8.0				CO RANGE = 0-200 PPM	
2353		4.33	8.80	4.0			68.2	CO LIN V (7.8 PPM)	Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
0003		5.25	9.66	4.0			75.8		
0013		7.18	8.74	4.0			68.7	START RUN #3 @ 2353	
0023		5.73	9.36	4.0			74.3		RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____
0033		6.25	9.46	1.1			77.0		
0043		6.58	9.10	4.0			71.0		
0053		Φ	Φ	Φ			Φ	ZERO CHECK - NO ADJ	PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: _____
		15.85	15.60	199.2			82.9	SPAN CHECK - NO ADJ	
0117		Φ.Φ					81.2	EXTERNAL CHECK	
				8.00				CO LIN V (7.8 PPM)	
									CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____

CHART NO. CL2172-8

Chart No.

(4971)

CHART NO. CL2172-8

Chart No.




CHART NO. CL2172-R

Distance

0 10 20 30 40 50 60 70 80 90 100

O₂ Span = 16.30%

O₂ Z = 0
NO_x Z = 0

NO_x Span = 82.0 ppm

START Run # 2 @ 2024

10 CM/HR

(4971)

0 10 20 30 40 50 60 70 80 90 100

O₂ Span Avg = 16.18%

NO_x Span Avg = 81.8 ppm

CHART NO. CL2172-R

Distance

0 10 20 30 40 50 60 70 80 90 100

NO_x Span Avg = 81.8 ppm

O₂ Span Avg = 16.18%

O₂ Span = 17.02%

NO_x Span = 85.2 ppm

NO₂ Z Avg

O₂ Z = 0

NO_x Z = -0.2 ppm


1344

1334

1344

35

1334



START RUN #1 @ 1734 HRS 10 CM/HR

CHART NO. CL-2172-R

Chart No.

(4971)

CHART NO. CL-2172-R

Chart No.

RECAL. 1716 HRS
CO = 0 - 500 PPM
RANGE

CO₂ Span Adj = 15.2%

CO Span Adj = 392 PPM


CO Span Adj = 854 PPM


CO₂ Span Adj = 15.41%


CO₂ Span Adj = 15.41%

N₂ Z ADJ
REC Z ADJ

6/19/42 TEXACO BOILERS A/B Common Stock
CO₂ = 0 - 20%
CO = 0 - 1000 PPM
PES







Date: 6/19/92Test Location: TEXACO - AREA 3
BOILERS A & B

SAMPLE HANDLING/LOG-IN

NO	SAMPLE TYPE	VOLUME	COMMENTS
1	33078 $\frac{5}{8}$ MF $\frac{1}{\text{Meth Sample Test}}$		RUN #1
2	33077 $\frac{5}{8}$ FUEL $\frac{1}{\text{Meth Sample Test}}$		RUN #1
3	33076 $\frac{5}{8}$ FHW $\frac{1}{\text{Meth Sample Test}}$	~130ml	RUN #1
4	33075 $\frac{5}{8}$ HC $\frac{1}{\text{Meth Sample Test}}$		RUN #1
5	33074 $\frac{5}{8}$ AMF $\frac{1}{\text{Meth Sample Test}}$		RUN #1
6	33073 $\frac{5}{8}$ FHW $\frac{1}{\text{Meth Sample Test}}$	~300ml	RUN #2
7	33072 $\frac{5}{8}$ H ₂ O $\frac{1}{\text{Meth Sample Test}}$	~350	RUN #1
8	33071 $\frac{5}{8}$ HC $\frac{2}{\text{Meth Sample Test}}$		RUN #2
9	33069 $\frac{5}{8}$ FHW $\frac{2}{\text{Meth Sample Test}}$		
10	33070 $\frac{5}{8}$ MF $\frac{2}{\text{Meth Sample Test}}$		
11	33067 $\frac{5}{8}$ FHW $\frac{2}{\text{Meth Sample Test}}$		
12	33068 $\frac{5}{8}$ AMF $\frac{2}{\text{Meth Sample Test}}$		

33066 $\frac{5}{8}$ H₂O $\frac{2}{\text{Meth Sample Test}}$

IN-OF-CUSTODY

Signature

Date/Time

Signature

Date/Time

P. Samly 6/19/92 ALL NITE!

M. Carasso 6/22/92

Date: 6-20-92Test Location: TEXACO Area 3 BKFLD
Boilers A+B

SAMPLE HANDLING/LOG-IN

NO	SAMPLE TYPE	VOLUME	COMMENTS
1	33104 <u>5/8</u> <u>AMF</u> <u>BIK</u> Meth Sample Test		
2	33105 <u>5/8</u> <u>MF</u> <u>BIK</u> Meth Sample Test		
3	33106 <u>5/8</u> <u>FHW</u> <u>BIK</u> Meth Sample Test		
4	33107 <u>5/8</u> <u>BHW</u> <u>BIK</u> Meth Sample Test		
5	33108 <u>5/8</u> <u>BHW</u> <u>BIK</u> Meth Sample Test		
6	33109 <u>5/8</u> <u>AMF</u> <u>3</u> Meth Sample Test		
7	33110 <u>5/8</u> <u>BHW</u> <u>3</u> Meth Sample Test		
8	33111 <u>5/8</u> <u>IPA</u> <u>3</u> Meth Sample <u>BHW</u> Test		
9	33112 <u>5/8</u> <u>MF</u> <u>3</u> Meth Sample Test		
10	33113 <u>5/8</u> <u>FHW</u> <u>3</u> Meth Sample Test		
11	33114 <u>5/8</u> <u>HC</u> <u>3</u> Meth Sample Test		
12	33115 <u>5/8</u> <u>H₂O₂</u> <u>BIK</u> Meth Sample Test		

CHAIN-OF-CUSTODY

Signature

Date/Time

Signature

Date/Time

Scott E. Win 6-20-92/17:15
M. Carnacci 6/22/92

ANALYTICAL REPORT

SAMPLE TYPE	: FHW ANALYSIS (g)	TEST DATE	: 06-19-92
SAMPLING METHOD	: M5/8	ANALYSIS DATE	: 06-29-92
SAMPLE COMPONENT	: ACETONE	ANALYST :	MC/WB
REQUESTED BY	: TEXACO BOILERS A & B		
ANALYTICAL METHOD	: GRAVIMETRIC		

Sample ID #	Test No.	Sample Volume (ml)	Analytical Result (total sample)	
			Uncorrected	Blank Corr. (g)
33076	1	195	0.01776	0.01753
33069	2	260	0.01541	0.01510
33113	3	190	0.00979	0.00956
33106	Bk	100	0.00012	

A N A L Y T I C A L R E P O R T

SAMPLE TYPE : FILTERABLE PARTICULATE TEST DATE :06-19-92
 SAMPLING METHOD : M5/8 ANALYSIS DATE :06-29-92
 SAMPLE COMPONENT : 100 mm FILTER ANALYST :MC/WB
 REQUESTED BY : TEXACO BOILERS A & B
 ANALYTICAL METHOD : GRAVIMETRIC

Sample ID #	Test No.	Filter No.	Analytical Result (total sample)	
			Uncorrected	Blank Corr. (g)
33078	1	890	0.00200	0.00185
33070	2	881	0.00103	0.00088
33112	3	891	0.00165	0.00150
33105	Bk	927	0.00015	

A N A L Y T I C A L R E P O R T

SAMPLE TYPE : CONDENSIBLE PARTICULATE TEST DATE :06-19-92
 SAMPLING METHOD : M5/8 ANALYSIS DATE:06-29-92
 SAMPLE COMPONENT : 80% IPA + Amf ANALYST :
 REQUESTED BY : TEXACO BOILERS A & B
 ANALYTICAL METHOD : GRAVIMETRIC

Sample ID #	Test No.	Sample Volume	Analytical Result (total sample)	
			Uncorrected	Blank Corr. (g)
33073	1	415	0.00582	0.00448
33067	2	415	0.00683	0.00549
33111	3	415	0.00533	0.00399
33107	IPA Bk	100	0.00011	
33104	Amf Bk	100	0.00108	
	DI Bk	100	0.00020	

A N A L Y T I C A L R E P O R T

SAMPLE TYPE	: FILTERABLE SO4	TEST DATE	:06-19-92
SAMPLING METHOD	: M5/8	ANALYSIS DATE	:06-29-92
SAMPLE COMPONENT	: FHW + MF	ANALYST	:MC/WB
REQUESTED BY	: TEXACO BOILERS A & B		
ANALYTICAL METHOD	: BaCl2 Titration		

Test No.	Sample Volume	Sample Aliquot	TITER mls or (Absorbance)	Analyt. Result (total sample) mg H2SO4
-----	-----	-----	-----	-----
1	100	10	1.10	5.03
2	100	10	1.04	4.73
3	100	10	0.90	4.05
Blank	100	10	0.07	0.34
% Duplicate = 97.3 RUN NO. 1				
% Recovery = 99.5 RUN NO. 3				
% CONFIDENCE = 101.9 EPA SO2 LOT 0882 3XXX				
NORMALITY = 0.0099601				

ANALYTICAL REPORT

SAMPLE TYPE	: CONDENSIBLE SULFATE	TEST DATE	: 06-19-92
SAMPLING METHOD	: M5/8	ANALYSIS DATE	: 06-29-92
SAMPLE COMPONENT	: BHW + AMF	ANALYST	: MC/WB
REQUESTED BY	: TEXACO BOILERS A & B		
ANALYTICAL METHOD	: BaCL2 Titration		

Test No.	Sample Volume	Sample Aliquot	TITER mls or (Absorbance)	Analyt. Result (total sample) mg H2SO4
-----	-----	-----	-----	-----
1	100	10	0.62	2.69
2	100	10	0.75	3.33
3	100	10	0.61	2.64
IPA BK	100	10	0.06	0.29
AMF BK	100	10	0.06	0.29
DI BK	100	10	0.05	0.24
% Duplicate =		103.3 RUN NO. 1		

% Recovery =	99.3	RUN NO. 3	
% CONFIDENCE =	99.8	EPA SO2 LOT	0882 3XXX
NORMALITY =	0.00998		

ANALYTICAL REPORT

SAMPLE TYPE	: SO2	TEST DATE	:06-19-92
SAMPLING METHOD	: M5/8	ANALYSIS DATE	:06-29-92
SAMPLE COMPONENT	: 3% H2O2	ANALYST	:WB
REQUESTED BY	: TEXACO BOILERS A & B		

ANALYTICAL METHOD : BaCL2 Titration

Sample ID #	Test No.	Sample Volume	Sample Aliquot	TITER mls or (Absorbance)	Analyt. Result (total sample) mg H2SO4
-----	-----	-----	-----	-----	-----
33072	1	400	10	11.24	217.67
33066	2	430	10	10.73	223.29
33110	3	410	10	9.90	196.30
33115	Bk	100	10	0.09	0.44

% Duplicate = 100.7 RUN NO. 1

% Recovery = 99.1 RUN NO. 3

% CONFIDENCE = 101.9 EPA SO2 LOT 0584 3XXX
 NORMALITY = 0.0099601

SECTION 8

QUALITY ASSURANCE

8.1 PARTICULATE/SO_x SAMPLING EQUIPMENT

A detailed record of repair and maintenance to each sampling train is kept. Preventative maintenance to each system is performed periodically to avoid complete component breakdown during a field test.

A detailed record of sampling system calibrations is also kept. Calibration data for the sampling nozzles, pitot tubes, dry gas meters and orifice meters are available for review. Results of the EPA Quality Assurance Branch biannual audits of the dry gas meter and orifice meter combinations are also logged and verify our in-house calibration data. The calibration data for the equipment used on this program can be found at the end of this section.

8.2 LAB ANALYSIS

All field samples are assigned a label and an ID number. This ID is also affixed to a chain-of-custody log and to the field data sheet to eliminate any chance of sample mixup.

Prior to analysis, all glassware is thoroughly cleaned (soap and water, tap water rinse, distilled water rinse, IPA rinse) to eliminate any contamination. The evaporating dishes used to evaporate the washings are treated the same as a sample (dried in an oven, desiccated and

weighed repeatedly at 6-hour intervals until a constant weight is achieved). The glassware used to measure volumes and make transfers and dilutions are all NBS Class A to insure accurate measurements. All weighings are carried out on a Sartorius Research Model R160P electronic semi-micro balance supported by a marble table in a separate room from the main analytical laboratory. The balance is calibrated regularly against an NBS Class S-1 weight.

All reagents used in the field and in the laboratory are ACS reagent grade and blanks of these reagents are evaluated for every set of tests. Blanks are taken in the field from the squeeze bottles and not the original container. Records are kept on these blanks to insure consistent quality of the reagents. Prior to use, the IPA is also analyzed to insure no peroxides are present which could lead to high SO_3 and low SO_2 values.

A quality control program consisting of duplicate analyses (to measure precision), spikes (to measure recovery efficiency) or analysis of blind standards supplied by EPA's Quality Assurance Branch (to measure accuracy) is implemented for each test program. Table 8-1 summarizes the results of the QC checks on this program. Records of our lab's participation in the EPA biannual audits for SO_2 are kept on file and verify our in-house QA/QC effort.

8.3 CONTINUOUS MONITORS

The NO_x analyzer is calibrated before and after each test using an EPA Protocol 1 gas ($\pm 1\%$) traceable to NBS. The CO , CO_2 and O_2 analyzers are calibrated before and after each test using a NBS certified gas mixture ($\pm 1\%$). Copies of the calibration gas certificates appear in the at the end of this section.

A sampling system check was performed at the beginning and end of each test day. This was done by introducing an EPA Protocol 1 gas at the sampling probe and measuring the system response. The purpose of this was to check the system for leaks and sample loss.

Multipoint calibration linearity checks of the continuous analyzers were performed on January 28, 1992 through January 30, 1992. These results were well within CARB limitations of $\pm 2\%$ of full scale. Tables 8-2 through 8-6 list the results of these checks.

TABLE 8-1. QUALITY ASSURANCE CHECKS

<u>Test No.</u>	<u>Sample Description</u>	<u>Duplicate %</u>	<u>Spike Recovery %</u>	<u>Confidence %</u>
1	Filterable Sulfate	97.3		
3	Filterable Sulfate		99.5	
	EPA SO ₂ Lot 0882 3XXX			101.9
1	Condensible Sulfate	103.3		
3	Condensible Sulfate		99.3	
	EPA SO ₂ Lot 0882 3XXX			99.8
1	SO ₂	100.7		
3	SO ₂		99.1	
	EPA SO ₂ Lot 0882 3XXX			101.9

TABLE 8-2. NO_x CALIBRATION SUMMARY

Monitoring Trailer: 1		Calibrated by: JP 1/30/92	
Analyzer:	TECO	Calibrator Manufacturer:	EnviroNics
Model:	10 AR	Model:	201-1520
Serial Number:	15311-154	Serial Number:	1122
NO _x Standard:		CC7204, CC72048	
Concentration:		9760 ppm, 1039 ppm	
Cylinder Pressure:		1900 psi, 1900 psi	

NO_x CALIBRATION AND LINEARITY CHECKS

Range 0-10,000 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	980	--	0	0	0
80% URL	182	810	7968	7968	0
1	381	597	5962	6010	+ .48
2	579	399	3984	4105	+ 1.21
3	780	202	2005	2100	+ .95

Range 0-1000 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	8852	--	0	0	0
80% URL	8128	716	791	791	0
1	8306	538	594	600	+ .6
2	8488	360	397	407	+ 1.0
3	8669	182	201	203	+ .2

TABLE 8-2. NO_x CALIBRATION AND LINEARITY CHECKS (Concluded)

TECO Model 10-AR/Trailer #1/January 30, 1992

Range 0-100 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	8360	--	0	0	0
80% URL	7716	636	79.2	79.2	0
1	7878	478	59.5	60.0	+ .5
2	8037	320	39.8	40.2	+ .4
3	8196	162	20.1	20.5	+ .4

Range 0-25 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	2169	--	0	0	0
80% URL	2130	42.0	19.86	19.86	0
1	2140	31.4	15.00	15.40	+ 1.6
2	2150	21.1	10.10	10.30	+ .8
3	2159	11.0	5.25	5.27	+ .08

Range 0-10 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9637	0.0	0	0	0
80% URL	9563	73.0	7.90	7.90	0
1	9580	55.0	5.95	5.92	.3
2	9595	37.0	3.98	3.94	.4
3	9615	19.0	2.03	2.02	.1

TABLE 8-3. CO CALIBRATION SUMMARY

Monitoring Trailer: 1		Calibrated by: JP 1/30/92	
Analyzer: ANARAD		Calibrator Manufacturer: Envirionics	
Model: AR 602		Model: 201-1520	
Serial Number: 1482		Serial Number: 1122	
CO Standard: ALM17548			
Concentration: 42490 ppm			
Cylinder Pressure: 1800 psi			

CO CALIBRATION AND LINEARITY CHECKS

Range 0-10,000 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	4921	0	0	0	0
80% URL	3999	930.8	8022	8022	0
1	4230	687.6	5942	5950	+ .08
2	4460	460.0	3974	4009	+ .35
3	4690	232.0	2003	2180	+ 1.77

TABLE 8-4. CO CALIBRATION SUMMARY

Monitoring Trailer: 1		Calibrated by: JP 1/30/92	
Analyzer:	TECO	Calibrator	
Model:	48	Manufacturer:	Enviro-nics
Serial Number:	21130-195	Model:	201-1520
CO Standard:	CC81181	Serial Number:	1122
Concentration:	10430 ppm		
Cylinder Pressure:	1700 psi		

CO CALIBRATION AND LINEARITY CHECKS

Range 0-20 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9500	0	0	0	0
80% URL	9335	16.5	18.4	18.4	0
1	9686	11.6	12.5	12.7	+ 1.0
2	9688	8.0	8.6	8.8	+ 1.0
3	9691	4.3	4.7	5.0	+ 1.5

Range 0-100 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9600	0	0	0	0
80% URL	9568	74.3	80.4	80.4	0
1	9585	55.0	59.5	59.5	0
2	9605	37.0	39.9	39.4	- .5
3	9627	19.0	20.3	19.9	- .4

TABLE 8-4. CO CALIBRATION AND LINEARITY CHECKS (Concluded)

TECO Model 48/Trailer #1/January 30, 1992

Range 0-500 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9500	0	0	0	0
80% URL	8985	356.0	397.4	397.4	0
1	9078	267.5	298.5	300.0	.3
2	9166	180.0	200.5	195.0	- 1.1
3	9453	91.7	100.3	95.5	- .96

Range 0-1000 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9000	0	0	0	0
80% URL	8181	671.0	790.6	790.6	0
1	8346	504.0	594.0	594.0	0
2	8515	337.0	397.0	398.0	.1
3	8684	170.3	200.8	196.2	- .46

TABLE 8-5. CO₂ CALIBRATION SUMMARY

Monitoring Trailer: 1		Calibrated by: JP 1/30/92	
Analyzer: ANARAD		Calibrator Manufacturer: Environics	
Model: AR 602		Model: 201-1520	
Serial Number: 1482		Serial Number: 1122	
CO ₂ Standard: CC86353			
Concentration: 41.2%			
Cylinder Pressure: 1000 psi			

CO₂ CALIBRATION AND LINEARITY CHECKS

Range 0-20 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO ₂ out %	Chart %	% Difference +2% Full Scale
Zero	2172	0	0	0	0
80% URL	1339	973.8	17.40	17.40	0
1	1549	718.0	13.05	13.00	-.25
2	1762	471.6	8.70	8.56	-.70
3	1968	237.1	4.40	4.29	-.55

TABLE 8-6. O₂ CALIBRATION SUMMARY

Monitoring Trailer: 1		Calibrated by: JP 1/28/92	
Analyzer:	Teledyne	Calibrator Manufacturer:	Enviro-nics
Model:	326A	Model:	201-1520
Serial Number:	36423	Serial Number:	1122
O ₂ Standard:	A14722		
Concentration:	45%		
Cylinder Pressure:	1700 psi		

O₂ CALIBRATION AND LINEARITY CHECKS

Range 0-5 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	O ₂ out %	Chart %	% Difference +2% Full Scale
Zero	3945	0	0	0	0
80% URL	3597	356.7	4.07	4.07	0
1	7348	532.6	3.04	3.11	+ 1.4
2	7525	356.2	2.04	2.09	+ 1.0
3	7699	180.2	1.03	1.09	+ 1.2

Range 0-10 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	O ₂ out %	Chart %	% Difference +2% Full Scale
Zero	4925	--	0	0	0
80% URL	4056	900.0	8.17	8.17	0
1	4271	664.0	6.06	6.18	+ 1.20
2	4487	444.0	4.05	4.24	+ 1.90
3	4705	223.7	2.04	2.21	+ .80

TABLE 8-6. O₂ CALIBRATION AND LINEARITY CHECKS (Concluded)

Teledyne Model 326A/Trailer #1/January 28, 1992

Range 0-25 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	O ₂ out %	Chart %	% Difference +2% Full Scale
Zero	1973	0	0	0	0
80% URL	1101	899.2	20.30	20.30	0
1	1317	663.8	15.09	15.16	+ .28
2	1535	443.9	10.10	10.15	+ .20
3	1753	223.7	5.09	5.14	+ .20

DRY GAS METER / ORIFICE METER CALIBRATION DATA

DateAPRIL 30 1992
 Bar. Press, in.Hg 29.89
 Meter Box No. ... 21313

Dry Gas Meter No. ... 1037070
 Standard Test Meter # 69279
 Operator AB


STANDARD TEST METER			DRY TEST METER				Time t (min)
Press. dHs (in. H2O)	Temp. Ts (dF)	Volume Vs (ft3)	Press. dH (in. H2O)	Temp. Tdi (dF)	Temp. Tdo (dF)	Volume Vd (ft3)	
-1.1	65.0	630.526	0.5	75	73	165.753	56.0
	64.0	606.826		77	74	141.754	
Avg/Net :	64.5	23.700			75	23.999	
-1.7	64.0	605.793	1.0	77	74	140.712	66.0
	64.0	566.692		78	77	101.261	
Avg/Net :	64.0	39.101			77	39.451	
-2.2	64.0	508.084	1.5	80	75	42.635	34.0
	66.0	484.515		75	74	18.804	
Avg/Net :	65.0	23.569			76	23.831	
-2.8	64.0	536.524	2.0	82	78	71.192	34.0
	64.0	509.106		80	75	43.653	
Avg/Net :	64.0	27.418			79	27.539	
-3.9	64.0	565.873	3.0	78	77	100.434	28.0
	64.0	538.049		82	78	72.722	
Avg/Net :	64.0	27.824			79	27.712	

$$y = V_s \times (P_{bar} + (dH_s / 13.6)) \times (Avg. T_d + 460) / [V_d \times (P_{bar} + (dH / 13.6)) \times (T_s + 460)]$$

$$K_o = [(V_s/t) \times [(T_{do} + 460) / (T_s + 460)] \times [(P_{bar} + (dH_s/13.6)) / (P_{bar} + (dH/13.6))] / [((T_{do} + 460) \times dH) / (P_{bar} + (dH/13.6))] \times (M_m)]^{0.5}$$

dH :	0.5	1.0	1.5	2.0	3.0	Avg.	Std.Dev.
y :	1.0029	1.0080	1.0006	1.0116	1.0149	1.0076	0.0053
Ko :	0.7729	0.7656	0.7280	0.7347	0.7369	0.7476	0.0180
y :	0.53 % Relative Std. Dev.						
Ko :	2.41 % Relative Std. Dev.						

NOZZLE CALIBRATION



DIAMETER (in.)

A 0.387

B 0.390

C 0.389

D 0.390

E _____

F _____

AVG. 0.3890

DATE 3-24-92

NOZZLE NO. #1023

OPERATOR SW

REPORT OF ANALYSIS

CUSTOMER ORDER NUMBER: SP-2750-90 R.59

PAGE 2 05/21/92

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.:	CC40033		Monitor Labs Model 8440		
Nitric Oxide	81.8 ± 0.8 ppm	GMIS	S/N 136	11/21/93	81.7 ppm
NOx	81.8 ppm	Cylinder #	Continuous		81.9 ppm
Nitrogen, O2-Free Balance		CC186651	Chemiluminescence		81.7 ppm
Cylinder Pressure: 2000 psig		@ 98.9 ppm	Last Cal Date: 03/05/92	Mean: 81.7 ppm	81.8 ppm

$$\text{ppm} = \mu\text{mole/mole}$$

% = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (714) 653-6780 • FAX (714) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

STEI01

TO:

SUE POWERS
STEINER ENVIRONMENTAL
4930 BOYLAN STREET
BAKERSFIELD, CA 93308-

DATE : 06/16/92

CUSTOMER ORDER NUMBER: SP-2750-90REL63

PAGE 1

XX

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.: CC91386					
Carbon Monoxide	7.80 ± 0.16 ppm	GMIS	Carle Insts Model 8000 S/N 8249	12/15/93	06/08/92 06/15/92 7.78 ppm 7.84 ppm
Nitrogen	Balance	Cylinder #	Methanation/FID		7.86 ppm 7.70 ppm
		CC163	Gas Chromatography		7.84 ppm 7.74 ppm
Cylinder Pressure:	2000 psig	@ 9.84 ppm	Last Cal Date: 05/05/92	Mean: 7.83 ppm	7.76 ppm

CYLINDER NO.: CC28732					
Carbon Monoxide	7.87 ± 0.16 ppm	GMIS	Carle Insts Model 8000 S/N 8249	12/15/93	06/08/92 06/15/92 7.85 ppm 7.85 ppm
Nitrogen	Balance	Cylinder #	Methanation/FID		7.91 ppm 7.92 ppm
		CC163	Gas Chromatography		7.88 ppm 7.78 ppm
Cylinder Pressure:	2000 psig	@ 9.84 ppm	Last Cal Date: 05/05/92	Mean: 7.88 ppm	7.85 ppm

CYLINDER NO.: CC182					
Carbon Monoxide	7.75 ± 0.16 ppm	GMIS	Carle Insts Model 8000 S/N 8249	12/15/93	06/08/92 06/15/92 7.70 ppm 7.81 ppm
Nitrogen	Balance	Cylinder #	Methanation/FID		7.69 ppm 7.83 ppm
		CC163	Gas Chromatography		7.71 ppm 7.75 ppm
Cylinder Pressure:	2000 psig	@ 9.84 ppm	Last Cal Date: 05/05/92	Mean: 7.70 ppm	7.80 ppm

ppm = umole/mole % = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.

Analyst: M. J. Monson
M.J. Monson

Approved: J. T. Marrin
J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507

TELEPHONE (714) 784-1240

REPORT OF ANALYSIS
NIST TRACEABLE GAS MIXTURES

STEI01

TO:

SUE POWERS
STEINER ENVIRONMENTAL INC.
4930 BOYLAN STREET
BAKERSFIELD, CA 93308

DATE: 11/21/91

CUSTOMER ORDER NUMBER: SP-2750-90REL45

PAGE 1

<XX>

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC101245	Carbon Monoxide	16.15 ± 0.32 ppm	SRM 2613a
	Carbon Dioxide	4.83 ± 0.05 %	SRM 1674b
	Oxygen	16.32 ± 0.16 %	SRM 2659
	Nitrogen	Balance	
CC37841	Carbon Monoxide	15.71 ± 0.31 ppm	SRM 2613a
	Carbon Dioxide	4.72 ± 0.05 %	SRM 1674b
	Oxygen	16.18 ± 0.16 %	SRM 2659
	Nitrogen	Balance	

ppm = umole/mole

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above.

Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

Analyst:

M.S. Calhoun

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

APPENDIX A
RESULTS AT EPA STANDARD CONDITIONS

Table A-1 presents the summary of source emission test data collected during this program. The data is presented at EPA standard conditions (68°F, 29.2 inches Mercury).

The particulate mass is reported in two ways -- front half and front half plus back half. The front half catch (nozzle, probe, filter holder wash and filter) represent matter which is filterable at 250°F. EPA bases compliance on this value. The back half catch represents condensable matter which is caught in the 80-percent isopropanol impinger and the acid mist filter. Kern County APCD bases compliance on the combined front half and back half catches. The sulfate data is reported as H_2SO_4 and represents the total sulfate measured in the front and back half catches. Kern County bases compliance on this value. The SO_2 values reported represent the SO_2 collected in the hydrogen peroxide portion of the sample train.

TABLE A-1. SUMMARY OF SOURCE EMISSION TEST DATA (68°F)

Unit Tested: Texaco R & M
 Boilers A & B

Date: June 19, 1992

Test Number	1	2	3	Average
Barometric Pressure (in. Hg)	29.91	29.88	29.82	29.87
Stack Pressure (in. Hg)	29.89	29.86	29.80	29.85
Stack Area (Ft ²)	8.62	8.62	8.62	8.62
Elapsed Sampling Time (min.)	96.00	96.00	96.00	96.00
Volume Gas Sampled (dscf)	84.205	84.308	83.676	84.063
F-Factor	8,607.34	8,607.34	8,607.34	8,607.34

GAS DATA

Average Gas Velocity (fps)	35.97	36.15	36.00	36.04
Average Gas Temperature (°F)	513.00	512.67	519.50	515.06
Gas Flowrate (dscfm)	8,981	8,871	8,884	8,912
Gas Analysis (Volume %)				
Carbon Dioxide, dry	8.43	8.46	9.17	8.69
Oxygen, dry	7.54	7.28	6.29	7.04
Water	10.93	12.40	11.11	11.48

EMISSION CONCENTRATION

Filterable Particulate (gr/dscf)	0.0036	0.0029	0.0020	0.0028
Total Particulate (gr/dscf)	0.0044	0.0039	0.0028	0.0037
Total Sulfate (gr/dscf)	0.0014	0.0015	0.0012	0.0014
CO (ppm)	1.00	1.80	1.02	1.27
SO ₂ (ppm)	22.40	22.95	20.33	21.90
NO _x (ppm)	70.09	67.97	72.01	70.02

EMISSION RATE - lb/hr

Filterable Particulate	0.27	0.22	0.16	0.22
Total Particulate	0.34	0.30	0.21	0.28
Total Sulfate	0.11	0.11	0.09	0.10
CO	0.04	0.07	0.04	0.05
SO ₂	2.01	2.03	1.80	1.95
NO _x	4.51	4.32	4.58	4.47

EMISSION FACTOR - lb/MMBtu

Filterable Particulate	0.0068	0.0055	0.0036	0.0053
Total Particulate	0.0084	0.0074	0.0049	0.0069
Total Sulfate	0.0027	0.0028	0.0022	0.0026
CO	0.0010	0.0017	0.0009	0.0012
SO ₂	0.0502	0.0504	0.0416	0.0474
NO _x	0.1127	0.1072	0.1059	0.1086

SOURCE TEST CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 1
DATE : JUNE 19,1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	106.85 DEG. F		STATIC PRESS.=	-0.28 in. H2O
STACK TEMP.	=	513.00 DEG. F		Cp	= 0.840
SQ.RT. dP	=	0.4677 in. H2O		STACK I.D.	= 39.75 inch
METER ORIFICE	=	2.41 in. H2O		DUCT LENGTH	= inch
METER VOLUME	=	89.220 Cu.Ft.		DUCT WIDTH	= inch
METER Y	=	1.0076		STACK AREA	= 8.618 Sq.Ft.
BAR. PRESSURE	=	29.91 in.Hg		TEST TIME	= 96.00 min.
COND.(Vlc)	=	219.5 ml		NOZZLE DIA.	= 0.3890 inch

GAS ANALYSIS	=	7.54 % O2	0.00 % CO
		8.43 % CO2	84.03 % N2

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times$ $(Pb + (dH / 13.6)) / (Tm + 460) \dots\dots$	=	84.205	dscf
$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic$	=	10.332	scf
$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots$	=	0.109	Lower Bws
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000	value used.
$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100$	=	51.49	
$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)]$	=	29.65	
$Ms = (Md \times (1-Bws)) + (18.0 \times Bws) \dots\dots\dots$	=	28.38	
$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots$	=	29.89	in. Hg
$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots\dots\dots$	=	35.97	ft/sec
$Qs = vs \times As \times 60 \dots\dots\dots$	=	18,601	acf/min
$Qs(std) = Qs \times (1-Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots\dots\dots$	=	8,981	dscf/min
$I = (Ts+460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) =$		101.98	%

SOURCE TEST CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 2
DATE : JUNE 19,1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	88.33 DEG. F		STATIC PRESS.=	-0.23 in. H2O
STACK TEMP.	=	512.67 DEG. F		Cp	= 0.840
SQ.RT. dP	=	0.4684 in. H2O		STACK I.D.	= 39.75 inch
METER ORIFICE	=	2.34 in. H2O		DUCT LENGTH	= inch
METER VOLUME	=	86.512 Cu.Ft.		DUCT WIDTH	= inch
METER Y	=	1.0076		STACK AREA	= 8.618 Sq.Ft.
BAR. PRESSURE	=	29.88 in.Hg		TEST TIME	= 96.00 min.
COND.(Vlc)	=	253.6 ml		NOZZLE DIA.	= 0.3890 inch

GAS ANALYSIS	:	7.28 % O2	0.00 % CO
		8.46 % CO2	84.26 % N2

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times$ $(Pb + (dH / 13.6)) / (Tm + 460) \dots\dots$	=	84.308	dscf
$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic$	=	11.937	scf
$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots$	=	0.124	Lower Bws
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000	value used.
$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100$	=	48.65	
$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)]$	=	29.64	
$Ms = (Md \times (1-Bws)) + (18.0 \times Bws) \dots\dots\dots$	=	28.20	
$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots$	=	29.86	in. Hg
$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460)$ $/ (Ms \times Ps)] \dots\dots\dots$	=	36.15	ft/sec
$Qs = vs \times As \times 60 \dots\dots\dots$	=	18,692	acf/min
$Qs(std) = Qs \times (1-Bws) \times ((Tstd + 460) / (Ts + 460))$ $\times (Ps / 29.92) \dots\dots\dots$	=	8,871	dscf/min
$I = (Ts+460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd +$ $460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) =$		103.38	%

SOURCE TEST CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 3
DATE : JUNE 19,1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	83.88 DEG. F		STATIC PRESS.	=	-0.24 in. H2O
STACK TEMP.	=	519.50 DEG. F		Cp	=	0.840
SQ.RT. dP	=	0.4661 in. H2O		STACK I.D.	=	39.75 inch
METER ORIFICE	=	2.29 in. H2O		DUCT LENGTH	=	inch
METER VOLUME	=	85.347 Cu.Ft.		DUCT WIDTH	=	inch
METER Y	=	1.0076		STACK AREA	=	8.618 Sq.Ft.
BAR. PRESSURE	=	29.82 in.Hg		TEST TIME	=	96.00 min.
COND.(Vlc)	=	222.2 ml		NOZZLE DIA.	=	0.3890 inch

GAS ANALYSIS	:	6.29 % O2		0.00 % CO
		9.17 % CO2		84.54 % N2

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times$ $(Pb + (dH / 13.6)) / (Tm + 460) \dots\dots$	=	83.676	dscf
$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic$	=	10.459	scf
$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots$	=	0.111	Lower Bws
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000	value used.
$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100$	=	39.24	
$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)]$	=	29.72	
$Ms = (Md \times (1-Bws)) + (18.0 \times Bws) \dots\dots\dots$	=	28.42	
$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots$	=	29.80 in. Hg	
$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460)$ $/ (Ms \times Ps)] \dots\dots\dots$	=	36.00	ft/sec
$Qs = vs \times As \times 60 \dots\dots\dots$	=	18,613	acf/min
$Qs(std) = Qs \times (1-Bws) \times ((Tstd + 460) / (Ts + 460))$ $\times (Ps / 29.92) \dots\dots\dots$	=	8,884	dscf/min
$I = (Ts+460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd +$ $460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) =$		102.46	%

EMISSION RATE CALCULATIONS

PLANT :TEXACO R & M
BOILERS A & B

RUN NO.: 1
DATE : JUNE 19,1992
O2 CORR.: 3.0 %

STANDARD TEMP. : 68 DEG. F

```
*****
Front Half Wash (FHW)      0.01753 grams | Vm(std)  84.205 ft3
Mass Filter (MF)           0.00185 grams | Vw(std)  10.332 ft3
Back Half Wash (BHW)       0.00448 grams | Qs(std)   8,981 dscfm
Front Half Sulfate (FHS)    5.03 mg H2SO4 | Bws       0.109
Back Half Sulfate (BHS)     2.69 mg H2SO4 | CO2       8.43 %
H2O2 Catch (SO2)           217.67 mg H2SO4 | O2        7.54 %
*****
```

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] 8607.34 dscf/MMBtu

FILTERABLE PARTICULATE

```
-----
15.432 x (FHW + MF) / [Vm(std) + Vw(std)] ..... 0.0032 gr/scf
15.432 x (FHW + MF) / Vm(std) ..... 0.0036 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0051 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.27 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0068 lb/MMBtu
```

TOTAL PARTICULATE

```
-----
15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std))] ... 0.0039 gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std) ..... 0.0044 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0062 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.34 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0084 lb/MMBtu
```

TOTAL SULFATE

```
-----
0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)] ..... 0.0013 gr/scf
0.015432 x (FHS + BHS) / Vm(std) ..... 0.0014 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0020 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.11 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0027 lb/MMBtu
```

SULFUR DIOXIDE (SO2)

```
-----
1.60982 x [T(std) + 460] x (mg H2SO4) / [ 98.076 x  
Vm(std)] ..... 22.40 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)] ..... 30.02 @ O2 corr.
ppm x (1 - Bws) ..... 19.95 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460].. 2.01 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x  
[20.9 / (20.9 - %O2)] x ppm ..... 0.0502 lb/MMBtu
lb/hr / (dscfm x 60 min/hr) .....3.73E-06 lb/dscf
```

SULFUR (S)

```
(lb/MMBtu SO2) / 2 ..... 0.0251 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076) ..... 0.0009 lb/MMBtu
Total Sulfur ..... 0.0260 lb/MMBtu
```

EMISSION RATE CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 2
DATE : JUNE 19, 1992
O2 CORR.: 3.0 %

STANDARD TEMP. : 68 DEG. F

```
*****
Front Half Wash (FHW)      0.01510 grams | Vm(std)  84.308 ft3
Mass Filter (MF)           0.00085 grams | Vw(std)  11.937 ft3
Back Half Wash (BHW)       0.00549 grams | Qs(std)  8,871 dscfm
Front Half Sulfate (FHS)    4.73 mg H2SO4 | Bws      0.124
Back Half Sulfate (BHS)     3.33 mg H2SO4 | CO2      8.46 %
H2O2 Catch (SO2)           223.29 mg H2SO4 | O2       7.28 %
*****
```

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] 8607.34 dscf/MMBtu

FILTERABLE PARTICULATE

```
-----
15.432 x (FHW + MF) / [Vm(std) + Vw(std)] ..... 0.0026 gr/scf
15.432 x (FHW + MF) / Vm(std) ..... 0.0029 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0041 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.22 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0055 lb/MMBtu
```

TOTAL PARTICULATE

```
-----
15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std))] ... 0.0034 gr/scf
15.432 x (FHW + MF + BHW) / Vm(std) ..... 0.0039 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0056 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.30 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0074 lb/MMBtu
```

TOTAL SULFATE

```
-----
0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)] ..... 0.0013 gr/scf
0.015432 x (FHS + BHS) / Vm(std) ..... 0.0015 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0021 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.11 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0028 lb/MMBtu
```

SULFUR DIOXIDE (SO2)

```
-----
1.60982 x [T(std) + 460] x (mg H2SO4) / [ 98.076 x
Vm(std)] ..... 22.95 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)] ..... 30.17 @ O2 corr.
ppm x (1 - Bws) ..... 20.11 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460].. 2.03 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x
[20.9 / (20.9 - %O2)] x ppm ..... 0.0504 lb/MMBtu
lb/hr / (dscfm x 60 min/hr) ..... 3.82E-06 lb/dscf
```

SULFUR (S)

```
(lb/MMBtu SO2) / 2 ..... 0.0252 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076) ..... 0.0009 lb/MMBtu
Total Sulfur ..... 0.0261 lb/MMBtu
```

EMISSION RATE CALCULATIONS

PLANT : TEXACO R & M
BOILERS A & B

RUN NO.: 3
DATE : JUNE 19, 1992
O2 CORR.: 3.0 %

STANDARD TEMP. : 68 DEG. F

```
*****
Front Half Wash (FHW)      0.00956 grams   | Vm(std)  83.676 ft3
Mass Filter (MF)           0.00150 grams   | Vw(std)  10.459 ft3
Back Half Wash (BHW)       0.00399 grams   | Qs(std)  8,884 dscfm
Front Half Sulfate (FHS)    4.05 mg H2SO4   | Bws      0.111
Back Half Sulfate (BHS)     2.64 mg H2SO4   | CO2      9.17 %
H2O2 Catch (SO2)           196.30 mg H2SO4  | O2       6.29 %
*****
```

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] 8607.34 dscf/MMBtu

FILTERABLE PARTICULATE

```
-----
15.432 x (FHW + MF) / [Vm(std) + Vw(std)] ..... 0.0018 gr/scf
15.432 x (FHW + MF) / Vm(std) ..... 0.0020 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0027 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.16 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0036 lb/MMBtu
```

TOTAL PARTICULATE

```
-----
15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)) ... 0.0025 gr/scf
15.432 x (FHW + MF + BHW) / Vm(std) ..... 0.0028 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0036 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.21 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0049 lb/MMBtu
```

TOTAL SULFATE

```
-----
0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)] ..... 0.0011 gr/scf
0.015432 x (FHS + BHS) / Vm(std) ..... 0.0012 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0016 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.09 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0022 lb/MMBtu
```

SULFUR DIOXIDE (SO2)

```
-----
1.60982 x [T(std) + 460] x (mg H2SO4) / [ 98.076 x  
Vm(std)] ..... 20.33 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)] ..... 24.91 @ O2 corr.
ppm x (1 - Bws) ..... 18.07 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460].. 1.80 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x  
[20.9 / (20.9 - %O2)] x ppm ..... 0.0416 lb/MMBtu
lb/hr / (dscfm x 60 min/hr) ..... 3.38E-06 lb/dscf
```

SULFUR (S)

```
(lb/MMBtu SO2) / 2 ..... 0.0208 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076) ..... 0.0007 lb/MMBtu
Total Sulfur ..... 0.0215 lb/MMBtu
```