

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

N0537A

Post 1012

U.S. Navy - NCBC

*Reviewed 11-13-90
Complies with A/C
and Rules
Z*

NEESA 2-164

OCTOBER 1990

SOURCE EMISSION TEST
FOR NO_x, CO, AND ROC
FROM CONVENTIONAL STEAM BOILER

AT

THOMAS PLANT, BUILDING 373
NAVAL CONSTRUCTION BATTALION CENTER
PORT HUENEME, CALIFORNIA

By:

James C. Reichle, P.E.

Naval Energy and Environmental Support Activity
Port Hueneme, California 93043-5014
AUTOVON 551-3549 or commercial (805) 982-3549

EXECUTIVE SUMMARY

This report describes source emission tests performed on the Cleaver-Brooks steam boiler located at the Thomas Plant aboard the Naval Construction Battalion Center (NCBC) Port Hueneme, CA.

The tests were required to determine compliance with conditions set by the Ventura County Air Pollution Control District (VCAPCD). Specifically, the NO_x emission concentration may not exceed 40 parts per million on a dry volume basis (ppmdv), while burning natural gas, or 115 ppmdv while burning #2 fuel oil. The carbon monoxide concentration may not exceed 400 ppmdv while burning either fuel. All figures are referenced to 3% oxygen concentration. See Appendix (F) for correspondence setting these limits.

NEESA conducted the field work on September 20, 21, and 24, 1990, using United States Environmental Protection Agency (USEPA) Methods 1, 2, 3A, 4, 7E, 10, and 18. Section II of this report contains the complete test protocol, as agreed with VCAPCD. Pacific Gas Technology of Bakersfield analyzed the samples collected with USEPA Method 18. BC Laboratories of Bakersfield analyzed the fuel sample.

The following table summarizes the most important results:

TABLE 1
TEST RESULTS

	NATURAL GAS					FUEL OIL #2				
	VCAPCD LIMIT	LOAD				VCAPCD LIMIT	LOAD			
		25%	50%	75%	100%		25%	50%	75%	100%
CO	400	145	193	179	135	400	65	90	13	9
NO _x	40	29	20	29	37	115	115	105	103	98

Note: All values are averages, expressed as parts per million, dry basis, referenced to 3% oxygen.

FUEL SULFUR CONTENT: 0.04%

I. INTRODUCTION

The Thomas Plant provides steam for space heating to the entire base. Recently, three aging Erie City boilers were replaced with one Cleaver-Brooks conventional steam boiler and a Solar gas turbine under MILCON project P-386. The turbine generates both steam (using a heat-recovery boiler) and electricity.

The Cleaver-Brooks boiler is equipped to burn both natural gas and #2 fuel oil. It has a low- NO_x burner, flue gas recirculation (FGR), and an oxygen trim system, all intended to reduce the formation of NO_x . In the authority to construct the boiler, VCAPCD limited operation of the boiler to 8000 hours per year, of which not more than 1080 hours may be used to burn fuel oil. These limits may be changed by VCAPCD; they are used here only as a basis for estimating yearly mass emissions of the pollutants of interest.

II. TEST PROTOCOL

NEESA tested the boiler for emissions of oxides of nitrogen (NO_x), carbon monoxide (CO), and reactive organic compounds (ROC). We ran tests while burning each of two fuels (natural gas and #2 fuel oil) at four different loads: 25%, 50%, 75%, and full load (or as close to these load settings as could reasonably be achieved). There was good agreement between the first two test runs in all cases. There was never a need to conduct a third run.

We used three sampling trains: one for stack gas velocity and moisture content, one for instrumental gas measurements, and one for bag samples taken to measure ROC. The duration of each instrumental gas sampling run was one hour. We recorded NO_x concentrations continuously with a strip chart recorder. We recorded measurements of all other instrumentally determined gas concentrations every five minutes. See Figure 1 for the sampling trains, and refer to the following description.




FIGURE 1
SAMPLING TRAINS

A. SAMPLE TRAIN 1.

1. We used United States Environmental Protection Agency (USEPA) Method 1 to determine sampling locations. Since we made no particulate measurements during these tests, we followed the guidance for velocity traverses. We used existing ports on the boiler stack, which were installed to allow boiler tune-up. See Figure 2 for a description of the geometry of the ports and stack.
2. We used USEPA Method 2 to determine stack gas velocity, with an S-type pitot tube. We determined moisture content of the stack gas with USEPA Method 4. We ran each of these methods a total of eight times - once at each load on each fuel. We ran these methods independently of the gas sampling methods.

B. SAMPLE TRAIN 2.

All calibration gasses are traceable to the National Institute of Standards and Technology (NIST). See Appendix (C) for the certificates.

We drew the stack gas through a sintered filter into a heated stainless steel sampling probe, followed by four empty standard impingers in an ice bath. The first impinger had a short stem, to minimize any gas contact with the collected condensate. The gas was then passed to the analyzers. See Figure 1.

1. We used USEPA Method 3A to measure the concentrations of O_2 and CO_2 in the stack gas, and to determine its excess air and dry molecular weight. We measured the concentration of CO with USEPA Method 10. We used non-dispersive infrared analyzers to measure CO and CO_2 . We measured O_2 with a paramagnetic analyzer. We calibrated the O_2 analyzer at zero with a CO/ CO_2 mixture containing no O_2 ; at approximately 3.0% with an O_2/N_2 mixture; and at 20.9% with ambient air. We calibrated the CO_2 analyzer at zero with an NO/ NO_2 mixture containing no CO_2 and at approximately 50% of the scale used with a CO/ CO_2 gas mixture. We calibrated the CO analyzer at zero with an NO/ NO_2 mixture containing no O_2 , and at approximately 25% and 50% of full scale with CO/ CO_2 mixtures.
2. We measured NO_x concentration in the stack gas with a chemiluminescence analyzer according to USEPA Method 7E. The zero span gas was a CO/ CO_2 mixture containing no NO_x . We calibrated the analyzer at 50 - 60% of the scale used, and again at 80 - 90% of this scale, with NO/ NO_2 mixtures. We used a strip chart recorder attached to the NO_x analyzer to provide a continuous record of NO_x measurements (including calibration). We did not traverse the stack for NO_x measurements.




FIGURE 2
TEST PORT LOCATIONS

C. SAMPLE TRAIN 3.

1. We collected stack gas samples according to USEPA Method 18 for later laboratory analysis for reactive organic compounds. We took two Tedlar bag samples at each load setting for each fuel, with one exception. We took only one sample while at 25% load on fuel oil, due to a lack of spare bags. This was agreed upon in advance in a conversation between NEESA and VCAPCD. A number of the sample bags leaked after sample collection, precluding analysis. The contents of the bags which were intact were then analyzed for C_1 through C_6 alkanes via gas chromatography. The methane portion, which is non-reactive, was subtracted from the total. See Figure 1 for a diagram of the sampling train.

III. RESULTS

We entered the raw data taken during the tests in the computer spreadsheet shown in the following pages as Table 2. All calculations were performed with this spreadsheet. All equations and constants used to perform these calculations are documented at the end of the spreadsheet. Table 3 shows the results of the fuel analysis.

this section revised

TABLE 2
EMISSION DATA AND CALCULATIONS

	GAS-25-1	GAS-25-2	GAS-50-1	GAS-50-2
GENERAL DATA				
1. HOURS PER YEAR ON GAS	6500	6500	6500	6500
2. HOURS PER YEAR ON OIL	1080	1080	1080	1080
3. HOURS PER YEAR TOTAL	7580	7580	7580	7580
4. DATE (DD-MMM-YY)	20-Sep-90	20-Sep-90	20-Sep-90	20-Sep-90
5. DESIRED LOAD (%)	25	25	50	50
6. ESTIMATED ACTUAL LOAD (%)	25	25	50	50
7. STACK DIAMETER (INCHES)	40.00	40.00	40.00	40.00
8. STACK AREA (SQUARE FEET)	8.73	8.73	8.73	8.73
SAMPLE TRAIN 1				
9. TIME BEGIN (HH:MM AM/PM)	7:33 PM	7:33 PM	4:10 PM	4:10 PM
10. TIME END (HH:MM AM/PM)	8:09 PM	8:09 PM	4:46 PM	4:46 PM
11. RUN DURATION (MINUTES)	36	60	36	36
12. AMBIENT TEMP (DEGREES F)	64	70	70	70
13. BAROMETRIC PRESSURE (INCHES MERCURY)	29.763	29.763	29.763	29.763
14. STACK STATIC PRESSURE (INCHES WATER, GAUGE)	0.04	0.04	0.03	0.03
15. STACK TEMP (DEGREES F)	353.15	356.31	385.54	380.85
16. METHOD 4 DRY GAS VOLUME (DSCF)	24.30	24.30	27.46	27.46
17. METHOD 4 COLLECTED WATER WEIGHT (GRAMS)	91.28	91.28	119.18	119.18
18. VOLUME % H2O IN STACK GAS	15.06	15.06	17.00	17.00
19. MOLE FRACTION DRY GAS	0.85	0.85	0.83	0.83
20. AVG STACK VELOCITY (FEET PER MINUTE)	423	424	444	443
21. STACK FLOWRATE (ACFM)	3,694	3,702	3,874	3,864
22. STACK FLOWRATE (DSCFM)	2,027	2,023	1,997	2,003
SAMPLE TRAIN 2				
23. TIME BEGIN (HH:MM AM/PM)	7:08 PM	8:30 PM	3:48 PM	5:12 PM
24. TIME END (HH:MM AM/PM)	8:08 PM	9:30 PM	4:48 PM	6:12 PM
25. RUN DURATION (MINUTES)	60	60	60	60
26. NATURAL GAS INPUT DURING TEST (STD CUBIC FT)	5,970	6,030	9,260	9,350
27. FUEL OIL INPUT DURING TEST (GALLONS)	0	0	0	0
28. ENERGY INPUT DURING TEST (BTU)	6,268,500	6,331,500	9,723,000	9,817,500
29. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	6,268,500	6,331,500	9,723,000	9,817,500
30. STACK GAS DRY MOLECULAR WEIGHT (LB/LB MOLE)	29.54	29.53	29.68	29.67
31. STACK GAS WET MOLECULAR WEIGHT (LB/LB MOLE)	27.80	27.80	27.69	27.69
32. EXCESS AIR (%)	45.83	43.82	26.26	23.61
33. FUEL FACTOR FO	1.76	1.78	1.74	1.76
34. AVG CO2 (VOLUME % RAW)	7.84	7.86	9.31	9.38
35. AVG O2 (VOLUME % RAW)	7.06	6.86	4.72	4.35
36. AVG CO (PPMDV RAW)	119.09	106.73	180.62	171.78
37. AVG CO (PPMDV @ 3% O2)	154	136	200	186
38. AVG CO (LBS/HR)	0.68	0.61	0.98	0.94
39. AVG CO (LBS/MM BTU)	0.11	0.10	0.10	0.10
40. AVG CO (TONS/YEAR)	2.21	1.97	3.17	3.04
41. AVG NOX (PPMDV RAW)	22.5	22.99	18.24	18.17
42. AVG NOX (PPMDV @ 3% O2)	29	29	20	20
43. AVG NOX (LBS/HR)	0.21	0.21	0.16	0.16
44. AVG NOX (LBS/MM BTU)	0.03	0.03	0.02	0.02
45. AVG NOX (TONS/YEAR)	1.37	1.39	1.05	1.06
SAMPLE TRAIN 3				
46. DATE (DD-MMM-YY)	24-Sep-90	25-Sep-90	24-Sep-90	25-Sep-90
47. TIME BEGIN (HH:MM AM/PM)	10:30 AM	7:30 AM	3:00 PM	7:45 AM
48. TEST DURATION (MIN)	GRAB	GRAB	GRAB	GRAB
49. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	6,268,500	6,331,500	9,723,000	9,817,500
50. SAMPLE VOLUME (LITERS)	10	10	10	10
51. C1 ALKANES (PPMWV RAW) (NON-REACTIVE)	SEE NOTE	SEE NOTE	7.80	SEE NOTE
52. C2 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
53. C3 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
54. C4 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
55. C5 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
56. C6 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
57. TOTAL ROC (C2 THROUGH C6) (LBS/HR)	SEE NOTE	SEE NOTE	0.07	SEE NOTE
58. TOTAL ROC (C2 THROUGH C6) (LBS/MM BTU)	SEE NOTE	SEE NOTE	0.01	SEE NOTE
59. TOTAL ROC (C2 THROUGH C6) (TONS/YEAR)	SEE NOTE	SEE NOTE	0.22	SEE NOTE

TABLE 2
EMISSION DATA AND CALCULATIONS

	GAS-75-1	GAS-75-2	GAS-100-1	GAS-100-2
GENERAL DATA				
1. HOURS PER YEAR ON GAS	6500	6500	6500	6500
2. HOURS PER YEAR ON OIL	1080	1080	1080	1080
3. HOURS PER YEAR TOTAL	7580	7580	7580	7580
4. DATE (DD-MM-YY)	20-Sep-90	20-Sep-90	20-Sep-90	20-Sep-90
5. DESIRED LOAD (%)	75	75	100	100
6. ESTIMATED ACTUAL LOAD (%)	75	75	100	100
7. STACK DIAMETER (INCHES)	40.00	40.00	40.00	40.00
8. STACK AREA (SQUARE FEET)	8.73	8.73	8.73	8.73
SAMPLE TRAIN 1				
9. TIME BEGIN (HH:MM AM/PM)	12:44 PM	12:44 PM	9:39 AM	9:39 AM
10. TIME END (HH:MM AM/PM)	1:20 PM	1:20 PM	10:16 AM	10:16 AM
11. RUN DURATION (MINUTES)	36	36	36	36
12. AMBIENT TEMP (DEGREES F)	70	70	59	59
13. BAROMETRIC PRESSURE (INCHES MERCURY)	29.763	29.763	29.763	29.763
14. STACK STATIC PRESSURE (INCHES WATER, GAUGE)	0.03	0.03	0.03	0.00
15. STACK TEMP (DEGREES F)	451.92	452.23	543.92	542.31
16. METHOD 4 DRY GAS VOLUME (DSCF)	23.16	23.16	24.20	24.20
17. METHOD 4 COLLECTED WATER WEIGHT (GRAMS)	102.76	102.76	106.62	106.62
18. VOLUME % H2O IN STACK GAS	17.32	17.32	17.21	17.22
19. MOLE FRACTION DRY GAS	0.83	0.83	0.83	0.83
20. AVG STACK VELOCITY (FEET PER MINUTE)	811	811	1486	1485
21. STACK FLOWRATE (ACFM)	7,073	7,074	12,968	12,959
22. STACK FLOWRATE (DSCFM)	3,368	3,368	5,617	5,622
SAMPLE TRAIN 2				
23. TIME BEGIN (HH:MM AM/PM)	12:22 PM	1:44 PM	8:57 AM	10:22 AM
24. TIME END (HH:MM AM/PM)	1:22 PM	2:44 PM	9:57 AM	11:22 AM
25. RUN DURATION (MINUTES)	60	60	60	60
26. NATURAL GAS INPUT DURING TEST (STD CUBIC FT)	15,690	15,950	26,790	26,630
27. FUEL OIL INPUT DURING TEST (GALLONS)	0	0	0	0
28. ENERGY INPUT DURING TEST (BTU)	16,474,500	16,747,500	28,129,500	27,961,500
29. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	16,474,500	16,747,500	28,129,500	27,961,500
30. STACK GAS DRY MOLECULAR WEIGHT (LB/LB MOLE)	29.69	29.70	29.71	29.70
31. STACK GAS WET MOLECULAR WEIGHT (LB/LB MOLE)	27.67	27.67	27.69	27.69
32. EXCESS AIR (%)	24.63	24.43	22.10	22.22
33. FUEL FACTOR FO	1.74	1.73	1.74	1.74
34. AVG CO2 (VOLUME % RAW)	9.44	9.48	9.65	9.60
35. AVG O2 (VOLUME % RAW)	4.49	4.46	4.12	4.14
36. AVG CO (PPMDV RAW)	162.44	165.9	127.23	124.7
37. AVG CO (PPMDV @ 3% O2)	177	181	136	133
38. AVG CO (LBS/HR)	1.37	1.40	1.63	1.60
39. AVG CO (LBS/MM BTU)	0.08	0.08	0.06	0.06
40. AVG CO (TONS/YEAR)	4.46	4.55	5.29	5.20
41. AVG NOX (PPMDV RAW)	26.49	26.07	34.5	34.21
42. AVG NOX (PPMDV @ 3% O2)	29	28	37	37
43. AVG NOX (LBS/HR)	0.37	0.36	0.73	0.72
44. AVG NOX (LBS/MM BTU)	0.02	0.02	0.03	0.03
45. AVG NOX (TONS/YEAR)	2.39	2.35	4.72	4.69
SAMPLE TRAIN 3				
46. DATE (DD-MM-YY)	24-Sep-90	24-Sep-90	25-Sep-90	24-Sep-90
47. TIME BEGIN (HH:MM AM/PM)	2:20 PM	2:35 PM	8:00 AM	1:00 PM
48. TEST DURATION (MIN)	GRAB	GRAB	GRAB	GRAB
49. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	16,474,500	16,747,500	28,129,500	27,961,500
50. SAMPLE VOLUME (LITERS)	10	10	10	10
51. C1 ALKANES (PPMWV RAW) (NON-REACTIVE)	6.40	8.10	SEE NOTE	13.00
52. C2 ALKANES (PPMWV RAW)	1.00	1.00	SEE NOTE	1.00
53. C3 ALKANES (PPMWV RAW)	1.00	1.00	SEE NOTE	1.00
54. C4 ALKANES (PPMWV RAW)	1.00	1.00	SEE NOTE	1.00
55. C5 ALKANES (PPMWV RAW)	1.00	1.00	SEE NOTE	1.00
56. C6 ALKANES (PPMWV RAW)	1.00	1.00	SEE NOTE	1.00
57. TOTAL ROC (C2 THROUGH C6) (LBS/HR)	0.11	0.11	SEE NOTE	0.16
58. TOTAL ROC (C2 THROUGH C6) (LBS/MM BTU)	0.01	0.01	SEE NOTE	0.01
59. TOTAL ROC (C2 THROUGH C6) (TONS/YEAR)	0.34	0.34	SEE NOTE	0.52

← 1.51

← 0.68

← 0.15

TABLE 2
EMISSION DATA AND CALCULATIONS

	OIL-25-1	OIL-25-2	OIL-50-1	OIL-50-2
GENERAL DATA				
1. HOURS PER YEAR ON GAS	6500	6500	6500	6500
2. HOURS PER YEAR ON OIL	1080	1080	1080	1080
3. HOURS PER YEAR TOTAL	7580	7580	7580	7580
4. DATE (DD-MMM-YY)	21-Sep-90	21-Sep-90	21-Sep-90	21-Sep-90
5. DESIRED LOAD (%)	25	25	50	50
6. ESTIMATED ACTUAL LOAD (%)	25	25	50	50
7. STACK DIAMETER (INCHES)	40.00	40.00	40.00	40.00
8. STACK AREA (SQUARE FEET)	8.73	8.73	8.73	8.73
SAMPLE TRAIN 1				
9. TIME BEGIN (HH:MM AM/PM)	6:40 PM	6:40 PM	4:09 PM	4:09 PM
10. TIME END (HH:MM AM/PM)	7:16 PM	7:16 PM	4:45 PM	4:45 PM
11. RUN DURATION (MINUTES)	36	36	36	36
12. AMBIENT TEMP (DEGREES F)	73	73	76	76
13. BAROMETRIC PRESSURE (INCHES MERCURY)	29.923	29.923	29.923	29.923
14. STACK STATIC PRESSURE (INCHES WATER, GAUGE)	0.03	0.03	0.04	0.04
15. STACK TEMP (DEGREES F)	355.23	354.08	379.69	384.00
16. METHOD 4 DRY GAS VOLUME (DSCF)	34.97	34.97	32.10	32.10
17. METHOD 4 COLLECTED WATER WEIGHT (GRAMS)	86.66	86.66	90.72	90.72
18. VOLUME % H2O IN STACK GAS	10.47	10.47	11.77	11.77
19. MOLE FRACTION DRY GAS	0.90	0.90	0.88	0.88
20. AVG STACK VELOCITY (FEET PER MINUTE)	328	328	501	502
21. STACK FLOWRATE (ACFM)	2,865	2,864	4,369	4,381
22. STACK FLOWRATE (DSCFM)	1,661	1,663	2,424	2,419
SAMPLE TRAIN 2				
23. TIME BEGIN (HH:MM AM/PM)	6:11 PM	7:28 PM	3:05 PM	4:25 PM
24. TIME END (HH:MM AM/PM)	7:11 PM	8:28 PM	4:05 PM	5:25 PM
25. RUN DURATION (MINUTES)	60	60	60	60
26. NATURAL GAS INPUT DURING TEST (STD CUBIC FT)	0	0	0	0
27. FUEL OIL INPUT DURING TEST (GALLONS)	57.73	57.73	86.66	86.66
28. ENERGY INPUT DURING TEST (BTU)	8,139,930	8,139,930	12,219,060	12,219,060
29. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	8,139,930	8,139,930	12,219,060	12,219,060
30. STACK GAS DRY MOLECULAR WEIGHT (LB/LB MOLE)	29.96	29.94	30.16	30.14
31. STACK GAS WET MOLECULAR WEIGHT (LB/LB MOLE)	28.71	28.69	28.73	28.72
32. EXCESS AIR (%)	44.56	45.78	25.35	25.38
33. FUEL FACTOR FO	1.34	1.35	1.33	1.34
34. AVG CO2 (VOLUME % RAW)	10.57	10.40	12.40	12.29
35. AVG O2 (VOLUME % RAW)	6.73	6.86	4.44	4.45
36. AVG CO (PPMDV RAW)	50.63	51.14	82.7	82.83
37. AVG CO (PPMDV @ 3% O2)	64	65	90	90
38. AVG CO (LBS/HR)	0.24	0.24	0.55	0.55
39. AVG CO (LBS/MM BTU)	0.03	0.03	0.04	0.04
40. AVG CO (TONS/YEAR)	0.13	0.13	0.30	0.29
41. AVG NOX (PPMDV RAW)	90.86	90.15	95.32	96.4
42. AVG NOX (PPMDV @ 3% O2)	115	115	104	105
43. AVG NOX (LBS/HR)	0.70	0.70	1.04	1.04
44. AVG NOX (LBS/MM BTU)	0.09	0.09	0.09	0.09
45. AVG NOX (TONS/YEAR)	0.76	0.75	1.12	1.13
SAMPLE TRAIN 3				
46. DATE (DD-MMM-YY)	24-Sep-90	SEE NOTE	24-Sep-90	24-Sep-90
47. TIME BEGIN (HH:MM AM/PM)	4:47 PM	SEE NOTE	4:20 PM	4:30 PM
48. TEST DURATION (MIN)	GRAB	SEE NOTE	GRAB	GRAB
49. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	8,139,930	SEE NOTE	12,219,060	12,219,060
50. SAMPLE VOLUME (LITERS)	10	SEE NOTE	10	10
51. C1 ALKANES (PPMWV RAW) (NON-REACTIVE)	1.00	SEE NOTE	1.00	1.00
52. C2 ALKANES (PPMWV RAW)	1.80	SEE NOTE	1.10	1.30
53. C3 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
54. C4 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
55. C5 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
56. C6 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
57. TOTAL ROC (C2 THROUGH C6) (LBS/HR)	0.06	SEE NOTE	0.08	0.08
58. TOTAL ROC (C2 THROUGH C6) (LBS/MM BTU)	0.01	SEE NOTE	0.01	0.01
59. TOTAL ROC (C2 THROUGH C6) (TONS/YEAR)	0.03	SEE NOTE	0.04	0.04

$$\text{PPM @ 3\%} = \text{PPM} \times \frac{20.9 - 3\%}{20.9 - \%O_2 \text{ measured}}$$

$$= 90.86 \times \frac{20.9 - 3}{20.9 - 6.73} = 114.78$$

$$90.15 \times \frac{20.9 - 3}{20.9 - 1.86} = 114.93$$

Changed items:

38, 43, 57

Revised 10.31.90

Sources of equations, constants, and information:

1, 2, & 3. From Authority to Construct #1012-1 issued by Ventura County Air Pollution Control District (VCAPCD), dated July 29, 1987. These limits may be modified by VCAPCD, and are presented here only to give an approximate idea of yearly mass emissions.

4. Self explanatory.

5. Desired load settings for the source tests were set forth in a letter from VCAPCD to NCBC Port Hueneme, dated 26 July 1990.

6. Actual load was determined by comparing measured steam rate to the known capacity of the boiler.

7. As measured by NEESA.

8. Calculated as $\pi r^2/144$.

9, 10. As recorded on field data sheets.

11. Run time for Sample Train 1, in minutes.

12. As measured with thermocouple and digital readout.

13. From weather station aboard Naval Air Station, Point Mugu, CA. The sampling location on the boiler stack at the Thomas Plant is 29 feet above sea level, while the NAS Point Mugu weather data is measured at 12 feet above sea level. Therefore, the figure received from Mugu was corrected by subtracting 0.017 inches of mercury per USEPA Method 4.

14. As measured immediately before sampling. A U-tube manometer was used.

15. As measured with thermocouple and digital readout.

16. The measurement taken from the face of the dry gas meter on our sampling equipment was corrected for temperature as follows:

$$V_m(\text{std}) = V_m [T_{\text{std}} / (T_m + 460)] [P_b / P_{\text{std}}]$$

where:

- $V_m(\text{std})$ - Volume of air collected, in dry standard cubic feet
- V_m - Volume read from dry gas meter, dry cubic feet
- T_{std} - 528 °R
- P_b - Barometric pressure at sampling point, inches of mercury
- P_{std} - 29.92126 inches of mercury
- T_m - Average meter temperature, °F

17. Calculated by subtracting pretest impinger weights from post-test impinger weights. We used a Mettler AE PB 3000 electronic balance calibrated with weights traceable to the International Order of Legal Metrology (IOLM).

18. Calculated as follows:

$$\%M = [100 * V_{w(gas)}] / [V_{m(std)} + V_{w(gas)}]$$

where:

$\%M$ - Volume percent water vapor in stack gas
 $V_{w(gas)}$ - Volume of water vapor collected during method 4 run. This is obtained by multiplying the mass of the collected water in grams by 0.0472.
 $V_{m(std)}$ - Dry gas volume collected, as computed in item 16, above.

19. Calculated as 100% - Volume % water vapor.

20. Velocity pressure was measured at each traverse point using an S-type pitot tube and a U-tube manometer.

21. Calculated by multiplying stack area by actual stack velocity.

22. Calculated as follows:

$$Q_{dscfm} = Q_{acfm} [T_{std} / (T_s + 460)] [P_b / P_{std}] [M_d]$$

Q_{dscfm} - Stack flow rate, in dry standard cubic feet per minute
 Q_{acfm} - Stack flow rate, in actual cubic feet per minute
 T_{std} - 528 °R
 P_b - Barometric pressure at sampling point, inches of mercury
 P_{std} - 29.92126 inches of mercury
 T_s - Average stack temperature, °F
 M_d - Mole fraction of dry gas in stack gas

23, 24. As recorded on data sheets

25. Run duration of Sample Train 2.

26. Calculated by subtracting gas meter reading at test start from gas meter reading at test conclusion.

27. Since there is no fuel meter which directly measures fuel input to the boiler, fuel consumption was estimated as follows: The fuel meter which measures input to an intermediate holding tank was monitored during testing, and fuel levels in the tank compared. Due to operator error, this measurement was not performed during the run at 75% load on fuel oil. The figure shown in Table 2 was obtained by straight line interpolation between fuel consumption rates at 50% and 100%.

28. Calculated as follows:

$$H = (1050 \text{ Btu/cf})(G) + (141,000 \text{ Btu/gal})(O)$$

where:

H = Energy input during test, in Btu
G = Natural gas consumed during test, in cubic feet
O = Gallons of #2 fuel oil consumed during test.

The heating values for these two fuels were obtained from the Ventura County APCD emission factors and calculation procedures booklet.

29. Calculated by dividing energy input by test duration.

30. Calculated as follows:

$$MW_d = [0.44(\%CO_2)] + [0.32(\%O_2)] + [0.28(100 - \%O_2 - \%CO_2)]$$

where:

MW_d = Molecular weight of dry stack gas, lb/lb mole
 $\%CO_2$ = Volume % of CO_2 in stack gas, raw
 $\%O_2$ = Volume % of O_2 in stack gas, raw

31. Calculated as follows:

$$MW = (MW_d)(M_d) + 18(1 - M_d)$$

where:

MW = Molecular weight of stack gas, lb/lb mole
 MW_d = Molecular weight of dry stack gas, lb/lb mole
 M_d = Mole fraction of dry gas in stack gas, dimensionless

32. Calculated as follows:

$$\%EA = 100(\%O_2) / [26.4 - 1.264(\%O_2) - 0.264(\%CO_2)]$$

where:

$\%EA$ = % excess air
 $\%CO_2$ = Volume % of CO_2 in stack gas, raw
 $\%O_2$ = Volume % of O_2 in stack gas, raw

33. Calculated as follows:

$$F_o = (20.9 - \%O_2) / \%CO_2$$

where:

F_o = Fuel factor
 $\%CO_2$ = Volume % of CO_2 in stack gas, raw
 $\%O_2$ = Volume % of O_2 in stack gas, raw

This equation is taken from USEPA Method 3. It is useful for comparing calculated values of F_o with expected values, which are dependent on the type of fuel burned. The ranges are:

Natural gas: 1.600 - 1.836
 Fuel oil #2: 1.260 - 1.413

34 - 36. As recorded from the instrumental analyzers, averaged and corrected for analyzer drift per USEPA Method 6C calculations.

37. Calculated as follows:

$$\%CO(@3\% O_2) = [(\%CO_{(raw)})(20.9 - 3.0)] / [20.9 - \%O_2(raw)]$$

where:

$\%CO(@3\% O_2)$ = Volume % CO corrected to 3% O_2
 $\%CO_{(raw)}$ = Volume % CO, as measured
 $\%O_2(raw)$ = Volume % O_2 , as measured

38. Calculated as follows:

$$CO_{(lb/hr)} =$$

$$\left[\frac{[(CO_{(ppmdv)})(MW_{CO})(Q)(60 \text{ min/hr})]}{(24.13 \text{ l/mole})(454 \text{ g/lb})(1000 \text{ ml/l})(35.31 \text{ ft}^3/\text{m}^3)(T/530)(29.92/P)} \right]$$

where:

$CO_{(lb/hr)}$ = Emission rate of CO in pounds per hour
 $CO_{(ppmdv)}$ = Measured CO concentration in stack gas
 MW_{CO} = Molecular weight of CO (= 28)
 Q = Stack flow rate, in dry standard cubic feet per minute
 T = 528 °R
 P = 29.92 inches of mercury

$$24.13 \times 454 \times 1000 \times 35.31 = 386.8 \times 10^6$$

39. Calculated as follows:

$$CO(lb/mmBtu) = CO(lb/hr)/E$$

where:

CO(lb/mmBtu) = Emission rate of CO, in pounds per million Btu of fuel burned
 CO(lb/hr) = Emission rate of CO, in pounds per hour
 E = Energy input rate in million Btu per hour

40. Calculated by multiplying the emission rate in pounds per hour by the number of hours the device will be operated in one year.

41. As measured with the instrumental analyzer, averaged and corrected for analyzer drift using USEPA Method 6C calculations.

42. Calculated as follows:

$$\%NO_x(@3\% O_2) = [(\%NO_x(raw))(20.9 - 3.0)]/[20.9 - \%O_2(raw)]$$

where:

$\%NO_x(@3\% O_2)$ = Volume % NO_x corrected to 3% O_2
 $\%NO_x(raw)$ = Volume % NO_x , as measured
 $\%O_2(raw)$ = Volume % O_2 , as measured

43. Calculated as follows:

$$NO_x(lb/hr) =$$

$$\left[\frac{[(NO_x(ppmdv))(MW_{NO_x})(Q)(60 \text{ min/hr})]}{(24.13 \text{ l/mole})(454 \text{ g/lb})(1000 \text{ ml/l})(35.31 \text{ ft}^3/\text{m}^3)(T/530)(29.92/P)} \right]$$

$22.4 @ 70^\circ$ 549×10^6 $\approx 5.91 \times 10^{-8}$

where:

$NO_x(lb/hr)$ = Emission rate of NO_x in pounds per hour
 $NO_x(ppmdv)$ = Measured NO_x concentration in stack gas
 MW_{NO_x} = Molecular weight of NO_x . To be conservative, all the NO_x will be assumed to be NO_2 . The molecular weight is 46.
 Q = Stack flow rate, in dry standard cubic feet per minute
 T = 528 °R ← *correcting to 68°F*
 P = 29.92 inches of mercury

$$22.4 \times \frac{810}{530} = 34.23$$

$$22.4 \times \frac{530}{460} = 24.13$$

= 25.8

$$22.4 \times 454 \times 1000 \times 35.31 \times \frac{294}{273} = 386.7 \times 10^6 @ 70^\circ F$$

44. Calculated as follows:

$$\text{NO}_x(\text{lb/mmBtu}) = \text{NO}_x(\text{lb/hr})/E$$

where:

$\text{NO}_x(\text{lb/mmBtu})$ - Emission rate of NO_x , in pounds per million Btu of fuel burned
 $\text{NO}_x(\text{lb/hr})$ - Emission rate of NO_x , in pounds per hour
 E - Energy input rate in million Btu per hour

45. Calculated by multiplying the emission rate in pounds per hour by the number of hours the device will be operated in one year.

46 - 47. As recorded on chain-of-custody sheet.

48. All bag samples were taken as grab samples, meaning that approximately 10 L of sample gas was collected at a rate of 1 to 3 liters per minute.

49. Same as item 29.

50. The sample bags used were 12 L capacity. We filled each bag with not more than 10 L of sample, to allow expansion during shipment to the laboratory.

51 - 56. As measured by gas chromatography performed on bag samples. Those runs marked "See note" are bags which leak checked OK prior to the test, but leaked before analysis on bag contents could be performed. The limit of detection for the analysis was 1 ppm for each species. Many of the reported concentrations were below this figure. Where this was the case, 1 ppm was assumed.

57. Calculated as follows:

$$ROC(lb/hr) =$$

$$\sum_{i=2 \text{ to } 6} \left[\frac{[(C_i(ppmdv))(MW_{Ci})(Q)(60 \text{ min/hr})]}{(24.13 \text{ l/mole})(454 \text{ g/lb})(1000 \text{ ml/l})(35.31 \text{ ft}^3/\text{m}^3)(T/530)(29.92/P)} \right]$$

where:

ROC(lb/hr) = Emission rate of ROC in pounds per hour
 $C_i(ppmdv)$ = Measured C_i concentration in stack gas
 MW_{Ci} = Molecular weight of C_i . The following figures were used:

C_2 (ethane) MW = 30
 C_3 (propane) MW = 44
 C_4 (butane) MW = 58
 C_5 (pentane) MW = 72
 C_6 (hexane) MW = 86

Methane is defined as non-reactive by VCAPCD, and was not included in the total.

Q = Stack flow rate, in dry standard cubic feet per minute
T = 528 °R
P = 29.92 inches of mercury

58. Calculated as follows:

$$ROC(lb/mmBtu) = ROC(lb/hr)/E$$

where:

ROC(lb/mmBtu) = Emission rate of ROC, in pounds per million Btu of fuel burned
ROC(lb/hr) = Emission rate of ROC, in pounds per hour
E = Energy input rate in million btu per hour

59. Calculated by multiplying the emission rate in pounds per hour by the number of hours the boiler is currently allowed to operate each year. See items 1 and 2.

TABLE 2
EMISSION DATA AND CALCULATIONS

	GAS-25-1	GAS-25-2	GAS-50-1	GAS-50-2
GENERAL DATA				
1. HOURS PER YEAR ON GAS	6500	6500	6500	6500
2. HOURS PER YEAR ON OIL	1080	1080	1080	1080
3. HOURS PER YEAR TOTAL	7580	7580	7580	7580
4. DATE (DD-MMM-YY)	20-Sep-90	20-Sep-90	20-Sep-90	20-Sep-90
5. DESIRED LOAD (%)	25	25	50	50
6. ESTIMATED ACTUAL LOAD (%)	25	25	50	50
7. STACK DIAMETER (INCHES)	40.00	40.00	40.00	40.00
8. STACK AREA (SQUARE FEET)	8.73	8.73	8.73	8.73
SAMPLE TRAIN 1				
9. TIME BEGIN (HH:MM AM/PM)	7:33 PM	7:33 PM	4:10 PM	4:10 PM
10. TIME END (HH:MM AM/PM)	8:09 PM	8:09 PM	4:46 PM	4:46 PM
11. RUN DURATION (MINUTES)	36	60	36	36
12. AMBIENT TEMP (DEGREES F)	64	70	70	70
13. BAROMETRIC PRESSURE (INCHES MERCURY)	29.763	29.763	29.763	29.763
14. STACK STATIC PRESSURE (INCHES WATER, GAUGE)	0.04	0.04	0.03	0.03
15. STACK TEMP (DEGREES F)	353.15	356.31	385.54	380.85
16. METHOD 4 DRY GAS VOLUME (DSCF)	24.30	24.30	27.46	27.46
17. METHOD 4 COLLECTED WATER WEIGHT (GRAMS)	91.28	91.28	119.18	119.18
18. VOLUME % H2O IN STACK GAS	15.06	15.06	17.00	17.00
19. MOLE FRACTION DRY GAS	0.85	0.85	0.83	0.83
20. AVG STACK VELOCITY (FEET PER MINUTE)	423	424	444	443
21. STACK FLOWRATE (ACFM)	3,694	3,702	3,874	3,864
22. STACK FLOWRATE (DSCFM)	2,027	2,023	1,997	2,003
SAMPLE TRAIN 2				
23. TIME BEGIN (HH:MM AM/PM)	7:08 PM	8:30 PM	3:48 PM	5:12 PM
24. TIME END (HH:MM AM/PM)	8:08 PM	9:30 PM	4:48 PM	6:12 PM
25. RUN DURATION (MINUTES)	60	60	60	60
26. NATURAL GAS INPUT DURING TEST (STD CUBIC FT)	5,970	6,030	9,260	9,350
27. FUEL OIL INPUT DURING TEST (GALLONS)	0	0	0	0
28. ENERGY INPUT DURING TEST (BTU)	6,268,500	6,331,500	9,723,000	9,817,500
29. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	6,268,500	6,331,500	9,723,000	9,817,500
30. STACK GAS DRY MOLECULAR WEIGHT (LB/LB MOLE)	29.54	29.53	29.68	29.67
31. STACK GAS WET MOLECULAR WEIGHT (LB/LB MOLE)	27.80	27.80	27.69	27.69
32. EXCESS AIR (%)	45.83	43.82	26.26	23.61
33. FUEL FACTOR FO	1.76	1.78	1.74	1.76
34. AVG CO2 (VOLUME % RAW)	7.84	7.86	9.31	9.38
35. AVG O2 (VOLUME % RAW)	7.06	6.86	4.72	4.35
36. AVG CO (PPMDV RAW)	119.09	106.73	180.62	171.78
37. AVG CO (PPMDV @ 3% O2)	154	136	200	186
38. AVG CO (LBS/HR)	1.05	0.94	1.57	1.50
39. AVG CO (LBS/MM BTU)	0.17	0.15	0.16	0.15
40. AVG CO (TOMS/YEAR)	3.42	3.06	5.11	4.88
41. AVG NOX (PPMDV RAW)	-22.5	22.99	18.24	18.17
42. AVG NOX (PPMDV @ 3% O2)	29	29	20	20
43. AVG NOX (LBS/HR)	-0.33	0.33	0.26	0.26
44. AVG NOX (LBS/MM BTU)	0.05	0.05	0.03	0.03
45. AVG NOX (TOMS/YEAR)	2.12	2.17	1.70	1.69
SAMPLE TRAIN 3				
46. DATE (DD-MMM-YY)	24-Sep-90	25-Sep-90	24-Sep-90	25-Sep-90
47. TIME BEGIN (HH:MM AM/PM)	10:30 AM	7:30 AM	3:00 PM	7:45 AM
48. TEST DURATION (MIN)	GRAB	GRAB	GRAB	GRAB
49. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	6,268,500	6,331,500	9,723,000	9,817,500
50. SAMPLE VOLUME (LITERS)	10	10	10	10
51. C1 ALKANES (PPMWV RAW) (NON-REACTIVE)	SEE NOTE	SEE NOTE	7.80	SEE NOTE
52. C2 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
53. C3 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
54. C4 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
55. C5 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
56. C6 ALKANES (PPMWV RAW)	SEE NOTE	SEE NOTE	1.00	SEE NOTE
57. TOTAL ROC (C2 THROUGH C6) (LBS/HR)	SEE NOTE	SEE NOTE	0.09	SEE NOTE
58. TOTAL ROC (C2 THROUGH C6) (LBS/MM BTU)	SEE NOTE	SEE NOTE	0.01	SEE NOTE
59. TOTAL ROC (C2 THROUGH C6) (TOMS/YEAR)	SEE NOTE	SEE NOTE	0.29	SEE NOTE

$$\frac{PPM \times Q \times 60 \times MW}{386.7 \times 10^6} = \frac{\#}{hr}$$

10.31.90

9350 SCFH

TABLE 2
EMISSION DATA AND CALCULATIONS

	GAS-75-1	GAS-75-2	GAS-100-1	GAS-100-2
GENERAL DATA				
1. HOURS PER YEAR ON GAS	6500	6500	6500	6500
2. HOURS PER YEAR ON OIL	1080	1080	1080	1080
3. HOURS PER YEAR TOTAL	7580	7580	7580	7580
4. DATE (DD-MMM-YY)	20-Sep-90	20-Sep-90	20-Sep-90	20-Sep-90
5. DESIRED LOAD (%)	75	75	100	100
6. ESTIMATED ACTUAL LOAD (%)	75	75	100	100
7. STACK DIAMETER (INCHES)	40.00	40.00	40.00	40.00
8. STACK AREA (SQUARE FEET)	8.73	8.73	8.73	8.73
SAMPLE TRAIN 1				
9. TIME BEGIN (HH:MM AM/PM)	12:44 PM	12:44 PM	9:39 AM	9:39 AM
10. TIME END (HH:MM AM/PM)	1:20 PM	1:20 PM	10:16 AM	10:16 AM
11. RUN DURATION (MINUTES)	36	36	36	36
12. AMBIENT TEMP (DEGREES F)	70	70	59	59
13. BAROMETRIC PRESSURE (INCHES MERCURY)	29.763	29.763	29.763	29.763
14. STACK STATIC PRESSURE (INCHES WATER, GAUGE)	0.03	0.03	0.03	0.00
15. STACK TEMP (DEGREES F)	451.92	452.23	543.92	542.31
16. METHOD 4 DRY GAS VOLUME (DSCF)	23.16	23.16	24.20	24.20
17. METHOD 4 COLLECTED WATER WEIGHT (GRAMS)	102.76	102.76	106.62	106.62
18. VOLUME % H2O IN STACK GAS	17.32	17.32	17.21	17.22
19. MOLE FRACTION DRY GAS	0.83	0.83	0.83	0.83
20. AVG STACK VELOCITY (FEET PER MINUTE)	811	811	1486	1485
21. STACK FLOWRATE (ACFM)	7,073	7,074	12,968	12,959
22. STACK FLOWRATE (DSCFH)	3,368	3,368	5,617	5,622
SAMPLE TRAIN 2				
23. TIME BEGIN (HH:MM AM/PM)	12:22 PM	1:44 PM	8:57 AM	10:22 AM
24. TIME END (HH:MM AM/PM)	1:22 PM	2:44 PM	9:57 AM	11:22 AM
25. RUN DURATION (MINUTES)	60	60	60	60
26. NATURAL GAS INPUT DURING TEST (STD CUBIC FT)	15,690	15,950	26,790	26,630
27. FUEL OIL INPUT DURING TEST (GALLONS)	0	0	0	0
28. ENERGY INPUT DURING TEST (BTU)	16,474,500	16,747,500	28,129,500	27,961,500
29. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	16,474,500	16,747,500	28,129,500	27,961,500
30. STACK GAS DRY MOLECULAR WEIGHT (LB/LB MOLE)	29.69	29.70	29.71	29.70
31. STACK GAS WET MOLECULAR WEIGHT (LB/LB MOLE)	27.67	27.67	27.69	27.69
32. EXCESS AIR (%)	Y.9 24.63	Y.7 24.43	Y.7 22.10	Y.7 22.22
33. FUEL FACTOR PO	1.74	1.73	1.74	1.74
34. AVG CO2 (VOLUME % RAW)	9.44	9.48	9.65	9.60
35. AVG O2 (VOLUME % RAW)	4.49	4.46	4.12	4.14
36. AVG CO (PPMDV RAW)	162.44	165.9	127.23	124.7
37. AVG CO (PPMDV @ 3% O2)	177	181	136	133
38. AVG CO (LBS/HR)	2.39	2.44	3.12	3.06
39. AVG CO (LBS/MM BTU)	0.14	0.15	0.11	0.11
40. AVG CO (TOMS/YEAR)	7.75	7.92	10.13	9.93
41. AVG NOX (PPMDV RAW)	26.49	26.07	34.5	34.21
42. AVG NOX (PPMDV @ 3% O2)	29	28	37	37
43. AVG NOX (LBS/HR)	0.64	0.63	1.39	1.38
44. AVG NOX (LBS/MM BTU)	0.04	0.04	0.05	0.05
45. AVG NOX (TOMS/YEAR)	4.15	4.09	9.02	8.95
SAMPLE TRAIN 3				
46. DATE (DD-MMM-YY)	24-Sep-90	24-Sep-90	25-Sep-90	24-Sep-90
47. TIME BEGIN (HH:MM AM/PM)	2:20 PM	2:35 PM	8:00 AM	1:00 PM
48. TEST DURATION (MIN)	GRAB	GRAB	GRAB	GRAB
49. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	16,474,500	16,747,500	28,129,500	27,961,500
50. SAMPLE VOLUME (LITERS)	10	10	10	10
51. C1 ALKANES (PPMDV RAW) (NON-REACTIVE)	6.40	8.10	SEE NOTE	13.00
52. C2 ALKANES (PPMDV RAW)	1.00	1.00	SEE NOTE	1.00
53. C3 ALKANES (PPMDV RAW)	1.00	1.00	SEE NOTE	1.00
54. C4 ALKANES (PPMDV RAW)	1.00	1.00	SEE NOTE	1.00
55. C5 ALKANES (PPMDV RAW)	1.00	1.00	SEE NOTE	1.00
56. C6 ALKANES (PPMDV RAW)	1.00	1.00	SEE NOTE	1.00
57. TOTAL ROC (C2 THROUGH C6) (LBS/HR)	0.15	0.15	SEE NOTE	0.25
58. TOTAL ROC (C2 THROUGH C6) (LBS/MM BTU)	0.01	0.01	SEE NOTE	0.01
59. TOTAL ROC (C2 THROUGH C6) (TOMS/YEAR)	0.49	0.49	SEE NOTE	0.82

Ave
28,045,500

3.09 ave
1.39 ave

21 ave
26.1 MCFH
E 100%

0.25

TABLE 2
EMISSION DATA AND CALCULATIONS

	OIL-25-1	OIL-25-2	OIL-50-1	OIL-50-2
GENERAL DATA				
1. HOURS PER YEAR ON GAS	6500	6500	6500	6500
2. HOURS PER YEAR ON OIL	1080	1080	1080	1080
3. HOURS PER YEAR TOTAL	7580	7580	7580	7580
4. DATE (DD-MMM-YY)	21-Sep-90	21-Sep-90	21-Sep-90	21-Sep-90
5. DESIRED LOAD (%)	25	25	50	50
6. ESTIMATED ACTUAL LOAD (%)	25	25	50	50
7. STACK DIAMETER (INCHES)	40.00	40.00	40.00	40.00
8. STACK AREA (SQUARE FEET)	8.73	8.73	8.73	8.73
SAMPLE TRAIN 1				
9. TIME BEGIN (HH:MM AM/PM)	6:40 PM	6:40 PM	4:09 PM	4:09 PM
10. TIME END (HH:MM AM/PM)	7:16 PM	7:16 PM	4:45 PM	4:45 PM
11. RUN DURATION (MINUTES)	36	36	36	36
12. AMBIENT TEMP (DEGREES F)	73	73	76	76
13. BAROMETRIC PRESSURE (INCHES MERCURY)	29.923	29.923	29.923	29.923
14. STACK STATIC PRESSURE (INCHES WATER, GAUGE)	0.03	0.03	0.04	0.04
15. STACK TEMP (DEGREES F)	355.23	354.08	379.69	384.00
16. METHOD 4 DRY GAS VOLUME (DSCF)	34.97	34.97	32.10	32.10
17. METHOD 4 COLLECTED WATER WEIGHT (GRAMS)	86.66	86.66	90.72	90.72
18. VOLUME % H2O IN STACK GAS	10.47	10.47	11.77	11.77
19. MOLE FRACTION DRY GAS	0.90	0.90	0.88	0.88
20. AVG STACK VELOCITY (FEET PER MINUTE)	328	328	501	502
21. STACK FLOWRATE (ACFM)	2,865	2,864	4,369	4,381
22. STACK FLOWRATE (DSCFM)	1,661	1,663	2,424	2,419
SAMPLE TRAIN 2				
23. TIME BEGIN (HH:MM AM/PM)	6:11 PM	7:28 PM	3:05 PM	4:25 PM
24. TIME END (HH:MM AM/PM)	7:11 PM	8:28 PM	4:05 PM	5:25 PM
25. RUN DURATION (MINUTES)	60	60	60	60
26. NATURAL GAS INPUT DURING TEST (STD CUBIC FT)	0	0	0	0
27. FUEL OIL INPUT DURING TEST (GALLONS)	57.73	57.73	86.66	86.66
28. ENERGY INPUT DURING TEST (BTU)	8,139,930	8,139,930	12,219,060	12,219,060
29. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	8,139,930	8,139,930	12,219,060	12,219,060
30. STACK GAS DRY MOLECULAR WEIGHT (LB/LB MOLE)	29.96	29.94	30.16	30.14
31. STACK GAS WET MOLECULAR WEIGHT (LB/LB MOLE)	28.71	28.69	28.73	28.72
32. EXCESS AIR (%)	44.56	45.78	25.35	25.38
33. FUEL FACTOR PO	1.34	1.35	1.33	1.34
34. AVG CO2 (VOLUME % RAW)	10.57	10.40	12.40	12.29
35. AVG O2 (VOLUME % RAW)	6.73	6.86	4.44	4.45
36. AVG CO (PPMDV RAW)	50.63	51.14	82.7	82.83
37. AVG CO (PPMDV @ 3% O2)	64	65	90	90
38. AVG CO (LBS/HR)	0.37	0.37	0.87	0.87
39. AVG CO (LBS/MM BTU)	0.05	0.05	0.07	0.07
40. AVG CO (TONS/YEAR)	0.20	0.20	0.47	0.47
41. AVG NOX (PPMDV RAW)	90.86	90.15	95.32	96.4
42. AVG NOX (PPMDV @ 3% O2)	115	115	104	105
43. AVG NOX (LBS/HR)	1.08	1.07	1.65	1.67
44. AVG NOX (LBS/MM BTU)	0.13	0.13	0.14	0.14
45. AVG NOX (TONS/YEAR)	1.17	1.16	1.79	1.80
SAMPLE TRAIN 3				
46. DATE (DD-MMM-YY)	24-Sep-90	SEE NOTE	24-Sep-90	24-Sep-90
47. TIME BEGIN (HH:MM AM/PM)	4:47 PM	SEE NOTE	4:20 PM	4:30 PM
48. TEST DURATION (MIN)	GRAB	SEE NOTE	GRAB	GRAB
49. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	8,139,930	SEE NOTE	12,219,060	12,219,060
50. SAMPLE VOLUME (LITERS)	10	SEE NOTE	10	10
51. C1 ALKANES (PPM WV RAW) (NON-REACTIVE)	1.00	SEE NOTE	1.00	1.00
52. C2 ALKANES (PPM WV RAW)	1.80	SEE NOTE	1.10	1.30
53. C3 ALKANES (PPM WV RAW)	1.00	SEE NOTE	1.00	1.00
54. C4 ALKANES (PPM WV RAW)	1.00	SEE NOTE	1.00	1.00
55. C5 ALKANES (PPM WV RAW)	1.00	SEE NOTE	1.00	1.00
56. C6 ALKANES (PPM WV RAW)	1.00	SEE NOTE	1.00	1.00
57. TOTAL ROC (C2 THROUGH C6) (LBS/HR)	0.08	SEE NOTE	0.11	0.11
58. TOTAL ROC (C2 THROUGH C6) (LBS/MM BTU)	0.01	SEE NOTE	0.01	0.01
59. TOTAL ROC (C2 THROUGH C6) (TONS/YEAR)	0.04	SEE NOTE	0.06	0.06

TABLE 2
EMISSION DATA AND CALCULATIONS

	OIL-75-1	OIL-75-2	OIL-100-1	OIL-100-2
GENERAL DATA				
1. HOURS PER YEAR ON GAS	6500	6500	6500	6500
2. HOURS PER YEAR ON OIL	1080	1080	1080	1080
3. HOURS PER YEAR TOTAL	7580	7580	7580	7580
4. DATE (DD-MM-YY)	21-Sep-90	21-Sep-90	21-Sep-90	21-Sep-90
5. DESIRED LOAD (%)	75	75	100	100
6. ESTIMATED ACTUAL LOAD (%)	75	75	100	100
7. STACK DIAMETER (INCHES)	40.00	40.00	40.00	40.00
8. STACK AREA (SQUARE FEET)	8.73	8.73	8.73	8.73
SAMPLE TRAIN 1				
9. TIME BEGIN (HH:MM AM/PM)	12:03 PM	12:03 PM	09:17 AM	09:17 AM
10. TIME END (HH:MM AM/PM)	12:39 PM	12:39 PM	09:53 AM	09:53 AM
11. RUN DURATION (MINUTES)	36	36	36	36
12. AMBIENT TEMP (DEGREES F)	75	75	66	66
13. BAROMETRIC PRESSURE (INCHES MERCURY)	29.923	29.923	29.923	29.923
14. STACK STATIC PRESSURE (INCHES WATER, GAUGE)	0.04	0.04	0.04	0.04
15. STACK TEMP (DEGREES F)	435.23	435.62	526.69	528.15
16. METHOD 4 DRY GAS VOLUME (DSCF)	24.59	24.59	28.76	28.76
17. METHOD 4 COLLECTED WATER WEIGHT (GRAMS)	69.16	69.16	80.78	80.78
18. VOLUME % H2O IN STACK GAS	11.72	11.72	11.70	11.70
19. MOLE FRACTION DRY GAS	0.88	0.88	0.88	0.88
20. AVG STACK VELOCITY (FEET PER MINUTE)	721	722	1302	1304
21. STACK FLOWRATE (ACFM)	6,295	6,296	11,366	11,377
22. STACK FLOWRATE (DSCFM)	3,278	3,277	5,371	5,368
SAMPLE TRAIN 2				
23. TIME BEGIN (HH:MM AM/PM)	12:01 PM	1:17 PM	8:54 AM	12:00 PM
24. TIME END (HH:MM AM/PM)	1:01 PM	2:17 PM	9:54 AM	01:00 PM
25. RUN DURATION (MINUTES)	60	60	60	60
26. NATURAL GAS INPUT DURING TEST (STD CUBIC FT)	0	0	0	0
27. FUEL OIL INPUT DURING TEST (GALLONS)	157.58	157.58	228.25	228.25
28. ENERGY INPUT DURING TEST (BTU)	22,218,780	22,218,780	32,183,250	32,183,250
29. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	22,218,780	22,218,780	32,183,250	32,183,250
30. STACK GAS DRY MOLECULAR WEIGHT (LB/LB MOLE)	30.19	30.19	30.19	30.18
31. STACK GAS WET MOLECULAR WEIGHT (LB/LB MOLE)	28.76	28.76	28.77	28.76
32. EXCESS AIR (%)	23.88	24.98	23.95	24.07
33. FUEL FACTOR FO	1.32	1.31	1.32	1.32
34. AVG CO2 (VOLUME % RAW)	12.64	12.61	12.65	12.57
35. AVG O2 (VOLUME % RAW)	4.23	4.38	4.24	4.26
36. AVG CO (PPMDV RAW)	12.07	12.15	6.4	10.43
37. AVG CO (PPMDV @ 3% O2)	13	13	7	11
38. AVG CO (LBS/HR)	0.17	0.17	0.15	0.24
39. AVG CO (LBS/MM BTU)	0.01	0.01	0.00	0.01
40. AVG CO (TONS/YEAR)	0.09	0.09	0.08	0.13
41. AVG NOX (PPMDV RAW)	95.11	95.11	90.07	92.18
42. AVG NOX (PPMDV @ 3% O2)	102	103	97	99
43. AVG NOX (LBS/HR)	2.23	2.23	3.46	3.54
44. AVG NOX (LBS/MM BTU)	0.10	0.10	0.11	0.11
45. AVG NOX (TONS/YEAR)	2.41	2.41	3.74	3.83
SAMPLE TRAIN 3				
46. DATE (DD-MM-YY)	24-Sep-90	24-Sep-90	24-Sep-90	24-Sep-90
47. TIME BEGIN (HH:MM AM/PM)	3:56 PM	4:05 PM	3:35 PM	3:40 PM
48. TEST DURATION (MIN)	GRAB	GRAB	GRAB	GRAB
49. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	22,218,780	22,218,780	32,183,250	32,183,250
50. SAMPLE VOLUME (LITERS)	10	10	10	10
51. C1 ALKANES (PPHWV RAW) (NON-REACTIVE)	1.00	SEE NOTE	1.00	1.00
52. C2 ALKANES (PPHWV RAW)	1.00	SEE NOTE	1.00	1.00
53. C3 ALKANES (PPHWV RAW)	1.00	SEE NOTE	1.00	1.00
54. C4 ALKANES (PPHWV RAW)	1.00	SEE NOTE	1.00	1.00
55. C5 ALKANES (PPHWV RAW)	1.00	SEE NOTE	1.00	1.00
56. C6 ALKANES (PPHWV RAW)	1.00	SEE NOTE	1.00	1.00
57. TOTAL ROC (C2 THROUGH C6) (LBS/HR)	0.15	SEE NOTE	0.24	0.24
58. TOTAL ROC (C2 THROUGH C6) (LBS/MM BTU)	0.01	SEE NOTE	0.01	0.01
59. TOTAL ROC (C2 THROUGH C6) (TONS/YEAR)	0.08	SEE NOTE	0.13	0.13

228.25
gal/hr

0.20

0.11

3.50

0.24

TABLE 2
EMISSION DATA AND CALCULATIONS

	OIL-75-1	OIL-75-2	OIL-100-1	OIL-100-2
GENERAL DATA				
1. HOURS PER YEAR ON GAS	6500	6500	6500	6500
2. HOURS PER YEAR ON OIL	1080	1080	1080	1080
3. HOURS PER YEAR TOTAL	7580	7580	7580	7580
4. DATE (DD-MMM-YY)	21-Sep-90	21-Sep-90	21-Sep-90	21-Sep-90
5. DESIRED LOAD (%)	75	75	100	100
6. ESTIMATED ACTUAL LOAD (%)	75	75	100	100
7. STACK DIAMETER (INCHES)	40.00	40.00	40.00	40.00
8. STACK AREA (SQUARE FEET)	8.73	8.73	8.73	8.73
SAMPLE TRAIN 1				
9. TIME BEGIN (HH:MM AM/PM)	12:03 PM	12:03 PM	09:17 AM	09:17 AM
10. TIME END (HH:MM AM/PM)	12:39 PM	12:39 PM	09:53 AM	09:53 AM
11. RUN DURATION (MINUTES)	36	36	36	36
12. AMBIENT TEMP (DEGREES F)	75	75	66	66
13. BAROMETRIC PRESSURE (INCHES MERCURY)	29.923	29.923	29.923	29.923
14. STACK STATIC PRESSURE (INCHES WATER, GAUGE)	0.04	0.04	0.04	0.04
15. STACK TEMP (DEGREES F)	435.23	435.62	526.69	528.15
16. METHOD 4 DRY GAS VOLUME (DSCF)	24.59	24.59	28.76	28.76
17. METHOD 4 COLLECTED WATER WEIGHT (GRAMS)	69.16	69.16	80.78	80.78
18. VOLUME % H2O IN STACK GAS	11.72	11.72	11.70	11.70
19. MOLE FRACTION DRY GAS	0.88	0.88	0.88	0.88
20. AVG STACK VELOCITY (FEET PER MINUTE)	721	722	1302	1304
21. STACK FLOWRATE (ACFM)	6.295	6.296	11.366	11.377
22. STACK FLOWRATE (DSCFM)	3.278	3.277	5.371	5.368
SAMPLE TRAIN 2				
23. TIME BEGIN (HH:MM AM/PM)	12:01 PM	1:17 PM	8:54 AM	12:00 PM
24. TIME END (HH:MM AM/PM)	1:01 PM	2:17 PM	9:54 AM	01:00 PM
25. RUN DURATION (MINUTES)	60	60	60	60
26. NATURAL GAS INPUT DURING TEST (STD CUBIC FT)	0	0	0	0
27. FUEL OIL INPUT DURING TEST (GALLONS)	157.58	157.58	228.25	228.25
28. ENERGY INPUT DURING TEST (BTU)	22,218,780	22,218,780	32,183,250	32,183,250
29. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	22,218,780	22,218,780	32,183,250	32,183,250
30. STACK GAS DRY MOLECULAR WEIGHT (LB/LB MOLE)	30.19	30.19	30.19	30.18
31. STACK GAS WET MOLECULAR WEIGHT (LB/LB MOLE)	28.76	28.76	28.77	28.76
32. EXCESS AIR (%)	23.88	24.98	23.95	24.07
33. FUEL FACTOR FO	1.32	1.31	1.32	1.32
34. AVG CO2 (VOLUME % RAW)	12.64	12.61	12.65	12.57
35. AVG O2 (VOLUME % RAW)	4.23	4.38	4.24	4.26
36. AVG CO (PPMDV RAW)	12.07	12.15	6.4	10.43
37. AVG CO (PPMDV @ 3% O2)	13	13	7	11
38. AVG CO (LBS/HR)	0.10	0.10	0.08	0.13
39. AVG CO (LBS/MM BTU)	0.00	0.00	0.00	0.00
40. AVG CO (TONS/YEAR)	0.05	0.06	0.04	0.07
41. AVG NOX (PPMDV RAW)	95.11	95.11	90.07	92.18
42. AVG NOX (PPMDV @ 3% O2)	102	103	97	99
43. AVG NOX (LBS/HR)	1.32	1.32	1.85	1.89
44. AVG NOX (LBS/MM BTU)	0.06	0.06	0.06	0.06
45. AVG NOX (TONS/YEAR)	1.42	1.42	2.00	2.04
SAMPLE TRAIN 3				
46. DATE (DD-MMM-YY)	24-Sep-90	24-Sep-90	24-Sep-90	24-Sep-90
47. TIME BEGIN (HH:MM AM/PM)	3:56 PM	4:05 PM	3:35 PM	3:40 PM
48. TEST DURATION (MIN)	GRAB	GRAB	GRAB	GRAB
49. ENERGY INPUT RATE DURING TEST (BTU/HOUR)	22,218,780	22,218,780	32,183,250	32,183,250
50. SAMPLE VOLUME (LITERS)	10	10	10	10
51. C1 ALKANES (PPMWV RAW) (NON-REACTIVE)	1.00	SEE NOTE	1.00	1.00
52. C2 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
53. C3 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
54. C4 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
55. C5 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
56. C6 ALKANES (PPMWV RAW)	1.00	SEE NOTE	1.00	1.00
57. TOTAL ROC (C2 THROUGH C6) (LBS/HR)	0.10	SEE NOTE	0.15	0.15
58. TOTAL ROC (C2 THROUGH C6) (LBS/MM BTU)	0.00	SEE NOTE	0.00	0.00
59. TOTAL ROC (C2 THROUGH C6) (TONS/YEAR)	0.05	SEE NOTE	0.08	0.08

← 0.12

← 1.75

← 0.14

Sources of equations, constants, and information:

1, 2, & 3. From Authority to Construct #1012-1 issued by Ventura County Air Pollution Control District (VCAPCD), dated July 29, 1987. These limits may be modified by VCAPCD, and are presented here only to give an approximate idea of yearly mass emissions.

4. Self explanatory.

5. Desired load settings for the source tests were set forth in a letter from VCAPCD to NCBC Port Hueneme, dated 26 July 1990.

6. Actual load was determined by comparing measured steam rate to the known capacity of the boiler.

7. As measured by NEESA.

8. Calculated as $\pi r^2/144$.

9, 10. As recorded on field data sheets.

11. Run time for Sample Train 1, in minutes.

12. As measured with thermocouple and digital readout.

13. From weather station aboard Naval Air Station, Point Mugu, CA. The sampling location on the boiler stack at the Thomas Plant is 29 feet above sea level, while the NAS Point Mugu weather data is measured at 12 feet above sea level. Therefore, the figure received from Mugu was corrected by subtracting 0.017 inches of mercury per USEPA Method 4.

14. As measured immediately before sampling. A U-tube manometer was used.

15. As measured with thermocouple and digital readout.

16. The measurement taken from the face of the dry gas meter on our sampling equipment was corrected for temperature as follows:

$$V_m(\text{std}) = V_m [T_{\text{std}} / (T_m + 460)] [P_b / P_{\text{std}}]$$

where:

$V_m(\text{std})$ = Volume of air collected, in dry standard cubic feet
 V_m = Volume read from dry gas meter, dry cubic feet
 T_{std} = 528 °R
 P_b = Barometric pressure at sampling point, inches of mercury
 P_{std} = 29.92126 inches of mercury
 T_m = Average meter temperature, °F

17. Calculated by subtracting pretest impinger weights from post-test impinger weights. We used a Mettler AE PB 3000 electronic balance calibrated with weights traceable to the International Order of Legal Metrology (IOLM).

18. Calculated as follows:

$$\%M = [100 * V_{w(gas)}] / [V_{m(std)} + V_{w(gas)}]$$

where:

%M = Volume percent water vapor in stack gas

$V_{w(gas)}$ = Volume of water vapor collected during method 4 run. This is obtained by multiplying the mass of the collected water in grams by 0.0472.

$V_{m(std)}$ = Dry gas volume collected, as computed in item 16, above.

19. Calculated as 100% - Volume % water vapor.

20. Velocity pressure was measured at each traverse point using an S-type pitot tube and a U-tube manometer.

21. Calculated by multiplying stack area by actual stack velocity.

22. Calculated as follows:

$$Q_{dscfm} = Q_{acfm} [T_{std} / (T_s + 460)] [P_b / P_{std}] [M_d]$$

Q_{dscfm} = Stack flow rate, in dry standard cubic feet per minute

Q_{acfm} = Stack flow rate, in actual cubic feet per minute

T_{std} = 528 °R

P_b = Barometric pressure at sampling point, inches of mercury

P_{std} = 29.92126 inches of mercury

T_s = Average stack temperature, °F

M_d = Mole fraction of dry gas in stack gas

23, 24. As recorded on data sheets

25. Run duration of Sample Train 2.

26. Calculated by subtracting gas meter reading at test start from gas meter reading at test conclusion.

27. Since there is no fuel meter which directly measures fuel input to the boiler, fuel consumption was estimated as follows: The fuel meter which measures input to an intermediate holding tank was monitored during testing, and fuel levels in the tank compared. Due to operator error, this measurement was not performed during the run at 75% load on fuel oil. The figure shown in Table 2 was obtained by straight line interpolation between fuel consumption rates at 50% and 100%.

28. Calculated as follows:

$$H = (1050 \text{ Btu/cf})(G) + (141,000 \text{ Btu/gal})(O)$$

where:

H = Energy input during test, in Btu

G = Natural gas consumed during test, in cubic feet

O = Gallons of #2 fuel oil consumed during test.

The heating values for these two fuels were obtained from the Ventura County APCD emission factors and calculation procedures booklet.

29. Calculated by dividing energy input by test duration.

30. Calculated as follows:

$$MW_d = [0.44(\%CO_2)] + [0.32(\%O_2)] + [0.28(100 - \%O_2 - \%CO_2)]$$

where:

MW_d = Molecular weight of dry stack gas, lb/lb mole

$\%CO_2$ = Volume % of CO_2 in stack gas, raw

$\%O_2$ = Volume % of O_2 in stack gas, raw

31. Calculated as follows:

$$MW = (MW_d)(M_d) + 18(1 - M_d)$$

where:

MW = Molecular weight of stack gas, lb/lb mole

MW_d = Molecular weight of dry stack gas, lb/lb mole

M_d = Mole fraction of dry gas in stack gas, dimensionless

32. Calculated as follows:

$$\%EA = 100(\%O_2) / [26.4 - 1.264(\%O_2) - 0.264(\%CO_2)]$$

where:

$\%EA$ = % excess air

$\%CO_2$ = Volume % of CO_2 in stack gas, raw

$\%O_2$ = Volume % of O_2 in stack gas, raw

33. Calculated as follows:

$$F_o = (20.9 - \%O_2)/\%CO_2$$

where:

F_o = Fuel factor

$\%CO_2$ = Volume % of CO_2 in stack gas, raw

$\%O_2$ = Volume % of O_2 in stack gas, raw

This equation is taken from USEPA Method 3. It is useful for comparing calculated values of F_o with expected values, which are dependent on the type of fuel burned. The ranges are:

Natural gas: 1.600 - 1.836

Fuel oil #2: 1.260 - 1.413

34 - 36. As recorded from the instrumental analyzers, averaged and corrected for analyzer drift per USEPA Method 6C calculations.

37. Calculated as follows:

$$\%CO(@3\% O_2) = [(\%CO_{(raw)})(20.9 - 3.0)]/[20.9 - \%O_{2(raw)}]$$

where:

$\%CO(@3\% O_2)$ = Volume % CO corrected to 3% O_2

$\%CO_{(raw)}$ = Volume % CO, as measured

$\%O_{2(raw)}$ = Volume % O_2 , as measured

38. Calculated as follows:

$$CO_{(lb/hr)} =$$

$$\left[\frac{[(CO_{(ppmdv)})(MW_{CO})(Q)(60 \text{ min/hr})]}{(24.13 \text{ l/mole})(454 \text{ g/lb})(1000 \text{ ml/l})(35.31 \text{ ft}^3/\text{m}^3)(T/530)(29.92/P)} \right]$$

where:

$CO_{(lb/hr)}$ = Emission rate of CO in pounds per hour

$CO_{(ppmdv)}$ = Measured CO concentration in stack gas

MW_{CO} = Molecular weight of CO (= 28)

Q = Stack flow rate, in dry standard cubic feet per minute

T = Measured stack temperature, $^{\circ}R$

P = Stack static pressure, inches of mercury

39. Calculated as follows:

$$CO(1b/mmbtu) = CO(1b/hr)/E$$

where:

CO(1b/mmbtu) = Emission rate of CO, in pounds per million Btu of fuel burned
 CO(1b/hr) = Emission rate of CO, in pounds per hour
 E = Energy input rate in million btu per hour

40. Calculated by multiplying the emission rate in pounds per hour by the number of hours the device will be operated in one year.

41. As measured with the instrumental analyzer, averaged and corrected for analyzer drift using USEPA Method 6C calculations.

42. Calculated as follows:

$$\%NO_x(@3\% O_2) = [(\%NO_x(raw))(20.9 - 3.0)]/[20.9 - \%O_2(raw)]$$

where:

%NO_x(@3% O₂) = Volume % NO_x corrected to 3% O₂
 %NO_x(raw) = Volume % NO_x, as measured
 %O₂(raw) = Volume % O₂, as measured

43. Calculated as follows:

$$NO_x(1b/hr) =$$

$$\left[\frac{[(NO_x(ppmdv))(MW_{NO_x})(Q)(60 \text{ min/hr})]}{(24.13 \text{ l/mole})(454 \text{ g/lb})(1000 \text{ ml/l})(35.31 \text{ ft}^3/\text{m}^3)(T/530)(29.92/P)} \right]$$

↖ 22.4

where:

NO_x(1b/hr) = Emission rate of NO_x in pounds per hour
 NO_x(ppmdv) = Measured NO_x concentration in stack gas
 MW_{NO_x} = Molecular weight of NO_x. To be conservative, all the NO_x will be assumed to be NO₂. The molecular weight is 46.
 Q = Stack flow rate, in dry standard cubic feet per minute
 T = Measured stack temperature, °R
 P = Stack static pressure, inches of mercury

$$\frac{\text{gm}}{\text{gm-rate}} \times \frac{\text{ft}^3}{\text{hr}} \times \frac{\text{note}}{\text{liter}} \times \frac{16}{\text{gram}} \times \frac{\text{liter}}{\text{ml}} \times \frac{\text{m}^3}{\text{ft}^3} = \frac{16}{\text{hr}}$$

44. Calculated as follows:

$$\text{NO}_x(\text{lb/mmBtu}) = \text{NO}_x(\text{lb/hr})/E$$

where:

$\text{NO}_x(\text{lb/mmBtu})$ = Emission rate of NO_x , in pounds per million Btu of fuel burned
 $\text{NO}_x(\text{lb/hr})$ = Emission rate of NO_x , in pounds per hour
 E = Energy input rate in million Btu per hour

45. Calculated by multiplying the emission rate in pounds per hour by the number of hours the device will be operated in one year.

46 - 47. As recorded on chain-of-custody sheet.

48. All bag samples were taken as grab samples, meaning that approximately 10 L of sample gas was collected at a rate of 1 to 3 liters per minute.

49. Same as item 29.

50. The sample bags used were 12 L capacity. We filled each bag with not more than 10 L of sample, to allow expansion during shipment to the laboratory.

51 - 56. As measured by gas chromatography performed on bag samples. Those runs marked "See note" are bags which leak checked OK prior to the test, but leaked before analysis on bag contents could be performed. The limit of detection for the analysis was 1 ppm for each species. Many of the reported concentrations were below this figure. Where this was the case, 1 ppm was assumed.

57. Calculated as follows:

ROC(lb/hr) =

$$\sum_{i=2 \text{ to } 6} \left[\frac{[(C_i(\text{ppmdv}))(\text{MW}_{C_i})(Q)(60 \text{ min/hr})]}{(24.13 \text{ l/mole})(454 \text{ g/lb})(1000 \text{ ml/l})(35.31 \text{ ft}^3/\text{m}^3)(T/530)(29.92/P)} \right]$$

where:

ROC(lb/hr) = Emission rate of ROC in pounds per hour
 $C_i(\text{ppmdv})$ = Measured C_i concentration in stack gas
 MW_{C_i} = Molecular weight of C_i . The following figures were used:

C_2 (ethane) MW = 30
 C_3 (propane) MW = 44
 C_4 (butane) MW = 58
 C_5 (pentane) MW = 72
 C_6 (hexane) MW = 86

Methane is defined as non-reactive by VCAPCD, and was not included in the total.

Q = Stack flow rate, in dry standard cubic feet per minute
T = Measured stack temperature, °R
P = Stack static pressure, inches of mercury

58. Calculated as follows:

ROC(lb/mmBtu) = ROC(lb/hr)/E

where:

ROC(lb/mmBtu) = Emission rate of ROC, in pounds per million Btu of fuel burned
ROC(lb/hr) = Emission rate of ROC, in pounds per hour
E = Energy input rate in million Btu per hour

59. Calculated by multiplying the emission rate in pounds per hour by the number of hours the boiler is currently allowed to operate each year. See items 1 and 2.

TABLE 3
FUEL ANALYSIS

SULFUR CONTENT :	0.04%
NITROGEN CONTENT :	0.07%

Note: Concentrations are expressed as weight percentage. Analysis performed by BC Laboratories in Bakersfield, CA.

V. DISCUSSION AND CONCLUSIONS

The measured NO_x and CO levels from the device are under limits set by VCAPCD.
The sulfur content of the fuel oil is under the 0.05% limit set by VCAPCD.

APPENDIX A

CHAIN OF CUSTODY DOCUMENTS
AND LABORATORY ANALYSES

PACIFIC GAS TECHNOLOGY



CRL ENVIRONMENTAL
2810 Bunsen Avenue
Unit A
Ventura, CA 93003

Attention: Leo Robb

4200 Easton Drive - Suite 5
Bakersfield, California 93309
805/324-1317
Fax: 805/324-2746

SAMPLED: SEPTEMBER 25, 1990
REPORTED: SEPTEMBER 28, 1990
SUBMITTED: SEPTEMBER 26, 1990

LAB # 3046

HYDROCARBONS ANALYSIS

=====						
COMPONENTS						
SAMPLE ID :	C1	C2	C3	C4	C5	C6 +
ppm (vol/vol)						
=====						
AMBIENT	1.6	ND	ND	ND	ND	TR < 1
TRIP BLANK	ND	ND	ND	ND	ND	TR < 1
OIL 25-1	TR < 1	1.8	TR < 1	ND	ND	TR < 1
OIL 50-1	TR < 1	1.1	ND	ND	ND	TR < 1
OIL 50-2	TR < 1	1.3	ND	ND	ND	TR < 1
OIL 75-1	ND	ND	ND	ND	ND	TR < 1
OIL 100-1	ND	ND	ND	ND	ND	TR < 1
OIL 100-2	ND	ND	ND	ND	ND	TR < 1
GAS 50-1	7.8	TR < 1	TR < 1	ND	ND	TR < 1
GAS 75-1	6.4	TR < 1	TR < 1	ND	ND	TR < 1
GAS 75-2	8.1	TR < 1	TR < 1	ND	ND	TR < 1
GAS 100-2	13.0	TR < 1	TR < 1	ND	ND	TR < 1
OIL 75-2	LEAKED	-	-	-	-	-
GAS 25-1	LEAKED	-	-	-	-	-
GAS 25-2	LEAKED	-	-	-	-	-
GAS 50-2	LEAKED	-	-	-	-	-
GAS 100-1	LEAKED	-	-	-	-	-

=====

ANALYZED BY WAYNE HAUSAUER

METHOD 18 FIELD DATA AND CUSTODY SHEET

SAMPLE ID	DATE	TIME BEGIN	TIME END	FLOW RATE	SAMPLED BY (TIME)	TRANSPORT BY (TIME)	RECEIVED BY (TIME)
GAS-25-1	9/24	10:30 ^a	10:40 ^a	$\frac{52000}{100}$	JR	DC	REP 17 ⁵⁰
X GAS-25-2	9/24 9/25	10:47^a 7:20 ^A	10:57^a		JR	JR	JH 8 ⁵³ AM 9/25
GAS-50-1	9/24	3:00 ^p	3:05 ^p		JR	DC	REP 17 ⁵⁰
X GAS-50-2	9/24 9/25	3:05^p 7:45	3:10^p		CR	JR	JH 8 ⁵³ AM 9/25
GAS-75-1	9/24	2:20 ^p	2:25 ^p		JR	DC	REP 17 ⁵⁰
GAS-75-2	9/24	2:35 ^p	2:40 ^p		JR	"	REP 17 ⁵⁰
X GAS-100-1	9/24 9/25	12:40^a 8:00	12:45^a		JR	JR	JH 8 ⁵³ AM 9/25
GAS-100-2	9/24	13:00	13:05		CR	DC	REP 17 ⁵⁰
OIL-25-1	9/24	4:47 ^p	4:49 ^p		CR	DC	REP 17 ⁵⁰
OIL-25-2							
OIL-50-1	9/24	4:20 ^p	4:25 ^p		CR	DC	REP 17 ⁵⁰
OIL-50-2	9/24	4:35 ^p	4:37 ^p		CR		REP
OIL-75-1	9/24	3:50 ^p	3:59 ^p		JR		REP
OIL-75-2	9/24	4:05 ^p	4:07 ^p		CR		REP
OIL-100-1	9/24	3:35 ^p	3:40 ^p		CR		REP
OIL-100-2	9/24	3:40 ^p	3:45 ^p		CR		REP
X TRIP BLNK	8/29				EN 3500	JR	JH 8 ⁵³ AM 9/25
AMB BLANK	9/24	10:00 ^a	10:20 ^a		JR	DC	REP 17 ⁵⁰

ENVIRONMENTAL
CHEMICAL ANALYSIS
PETROLEUM

BC

LABORATORIES, INC.

J. J. EGLIN, REG. CHEM. ENGR.

4100 ATLAS CT., BAKERSFIELD, CALIFORNIA 93308 PHONE (805) 327-4911 FAX (805) 327-1918

JAMES C. REICHLE
3111 E. HARBOR
VENTURA, CA 93001
805-644-5065

Date Reported: 10/05/90
Date Received: 09/27/90
Laboratory No.: 8485-1

Page 1

Sample Description: T-PLANT, 9/21/90 (U.S. NAVY)

OIL ANALYSIS

<u>Constituents</u>	<u>Sample Results</u>	<u>Method</u> <u>P.O.L.</u>	<u>Units</u>	<u>Method</u>
Total Nitrogen	0.07	0.05	%	ASTM-D3228
Total Sulfur	0.04	-.	%	ASTM-D2622

BY

J. J. Eglin
J. J. Eglin

APPENDIX B
EQUIPMENT CALIBRATION DATA

S TYPE PITOT TUBE CALIBRATION WORKSHEET
 THOMAS PLANT SOURCE TEST - PROBE #5-8

PITOT #	SIDE	RUN	NBS VP (IN WG)	S TYPE VP (IN WG)	CP(S)	MEAN	DEVIATION	SIGMA
1	A	1	0.200	0.300	0.816	0.808	0.009	-2.8E-17
1	A	2	0.290	0.450	0.803		-0.005	
1	A	3	0.350	0.540	0.805		-0.003	
1	A	4	0.390	0.600	0.806		-0.001	
1	B	1	0.390	0.600	0.806	0.802	0.004	2.8E-17
1	B	2	0.350	0.540	0.805		0.003	
1	B	3	0.290	0.450	0.803		0.000	
1	B	4	0.190	0.300	0.796		-0.007	

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *g.m.*

RUN NO: GAS-25 ANALYZER: 02
BOILER NO: CB SPAN: 20.9
FUEL: NAT GAS UNITS: %
LOAD: 25% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	0	0.0	N/A
	MID	3.116	3.2	0.084	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.1	0.1	0.5	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0	0.0	0.5
	ZERO	0.00	0.1	0.1	0.5	0.5
SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0	0.0	0.5
	ZERO	0.00	0.1	0.1	0.5	0.5

	RUN 1	RUN 2	
Co=	0.05	0.10	Avg zero gas system calibration bias.
Cm=	3.15	3.20	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=	7.07	6.92	Avg gas analyzer concentration reading.
Cgas=	7.06	6.86	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cal. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *gpc*

RUN NO: GAS-25
BOILER NO: CB
FUEL: NAT GAS
LOAD: 25%

ANALYZER: CO2
SPAN: 20
UNITS: %
RESP TIME: 100 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11	0.01	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	11	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	11	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	11.01	10.9	0.1	0.5	0.5
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	11.00	10.95	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=	7.33	7.82	Avg gas analyzer concentration reading.
Cgas=	7.84	7.86	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - Co) * Cma / (Cm - Co)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *JN*

RUN NO: GAS-25 ANALYZER: CO
BOILER NO: CB SPAN: 500
FUEL: NAT GAS UNITS: PPM
LOAD: 25% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	501.5	500	1.5	0.3	N/A
	MID	248.1	250	1.9	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	248.10	247	3	0.6	0.6
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	250.00	248.50	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=	120.00	106.90	Avg gas analyzer concentration reading.
Cgas=	119.09	106.70	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - 0.01 Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 20 SEPT 90
 CAL. BY: NEWTON *LM*

RUN NO: GAS-25
 BOILER NO: CB
 FUEL: NAT GAS
 LOAD: 25%

ANALYZER: NOX
 SPAN: 100
 UNITS: PPM
 RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	90.71	90	0.71	0.7	N/A
	MID	51.98	51.5	0.48	0.5	N/A
	ZERO	0.00	0.5	0.5	0.5	N/A
SYSTEM PRETEST	UPSCALE	51.98	51	0.5	0.5	N/A
	ZERO	0.00	1	0.5	0.5	N/A
SYSTEM POST RUN 1	UPSCALE	51.98	52	0.5	0.5	1
	ZERO	0.00	1.5	1	1.0	0.5
SYSTEM POST RUN 2	UPSCALE	51.98	52	0.5	0.5	1
	ZERO	0.00	1	0.5	0.5	0

	RUN 1	RUN 2	
Co=	1.25	1.25	Avg zero gas system calibration bias.
Cm=	51.50	52.00	Avg upscale gas sys. cal. bias.
Cma=	51.98	51.98	Upscale gas concentration.
C=	23.00	23.70	Avg gas analyzer concentration reading.
Cgas=	22.50	22.99	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cvl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON

RUN NO: GAS-50 ANALYZER: 02
BOILER NO: CB SPAN: 20.9
FUEL: NAT GAS UNITS: %
LOAD: 50% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	0	0.0	N/A
	MID	3.116	3.2	0.084	0.4	N/A
	ZERO	0.00	0.1	0.1	0.5	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.2	0	0.0	N/A
	ZERO	0.00	0.1	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0

	RUN 1	RUN 2	
Co=	0.10	0.10	Avg zero gas system calibration bias.
Cm=	3.20	3.20	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=	4.60	4.43	Avg gas analyzer concentration reading.
Cgas=	4.72	4.38	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - [Cv] Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 5C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *DN*

RUN NO: GAS-50 ANALYZER: CO2
BOILER NO: CB SPAN: 20
FUEL: NAT GAS UNITS: %
LOAD: 50% RESP TIME: 100 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11	0.01	0.0	N/A
	ZERO	0.00	0.1	0.1	0.5	N/A
SYSTEM PRETEST	UPSCALE	11.01	10.8	0.2	1.0	N/A
	ZERO	0.00	0	0.1	0.5	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	10.8	0.2	1.0	0
	ZERO	0.00	0	0.1	0.5	0
SYSTEM POST RUN 2	UPSCALE	11.01	10.5	0.5	2.5	1.5
	ZERO	0.00	0	0.1	0.5	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	10.80	10.65	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=	9.13	9.07	Avg gas analyzer concentration reading.
Cgas=	9.31	9.38	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *DR*

RUN NO: GAS-50 ANALYZER: CO
BOILER NO: CB SPAN: 500
FUEL: NAT GAS UNITS: PPM
LOAD: 50% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	501.5	500	1.5	0.3	N/A
	MID	248.1	250	1.9	0.4	N/A
	ZERO	0.00	2	2	0.4	N/A
SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	2	0.4	N/A
SYSTEM POST RUN 1	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	0	2	0.4	0
SYSTEM POST RUN 2	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	0	2	0.4	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	250.00	250.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=	182.00	173.10	Avg gas analyzer concentration reading.
Cgas=	180.62	171.78	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *gA*

RUN NO: GAS-50
BOILER NO: CB
FUEL: NAT GAS
LOAD: 50%

ANALYZER: NOX
SPAN: 100
UNITS: PPM
RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	90.71	91	0.29	0.3	N/A
	MID	51.98	52	0.02	0.0	N/A
	ZERO	0.00	1	1	1.0	N/A
SYSTEM PRETEST	UPSCALE	51.98	52	0	0.0	N/A
	ZERO	0.00	1	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	51.98	51	1	1.9	1
	ZERO	0.00	0	1	1.9	1
SYSTEM POST RUN 2	UPSCALE	51.98	49.5	2.5	2.5	2.5
	ZERO	0.00	-0.5	1.5	1.5	1.5

	RUN 1	RUN 2
Co=	0.50	-0.25 Avg zero gas system calibration bias.
Cm=	51.50	50.25 Avg upscale gas sys. cal. bias.
Cma=	51.98	51.98 Upscale gas concentration.
C=	18.40	17.40 Avg gas analyzer concentration reading.
Cgas=	18.24	18.17 Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *NR*

RUN NO: GAS-75 ANALYZER: CO2
BOILER NO: CB SPAN: 20
FUEL: NAT GAS UNITS: %
LOAD: 75% RESP TIME: 100 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11	0.01	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	11	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	11	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	11.01	10.8	0.2	1.0	1
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	11.00	10.90	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=	9.43	9.39	Avg gas analyzer concentration reading.
Cgas=	9.44	9.48	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *gn*

RUN NO: GAS-75 ANALYZER: O2
BOILER NO: CB SPAN: 20.9
FUEL: NAT GAS UNITS: %
LOAD: 75% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	0	0.0	N/A
	MID	3.116	3.2	0.084	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.2	0	0.0	N/A
	ZERO	0.00	0.1	0.1	0.5	N/A
SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.1	0.1	0.5	0
SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0.1	0.5	0.5
	ZERO	0.00	0.1	0.1	0.5	0

	RUN 1	RUN 2	
Co=	0.10	0.10	Avg zero gas system calibration bias.
Cm=	3.20	3.25	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=	4.57	4.61	Avg gas analyzer concentration reading.
Cgas=	4.49	4.46	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *NTN*

RUN NO: GAS-75 ANALYZER: CO
BOILER NO: CB SPAN: 500
FUEL: NAT GAS UNITS: PPM
LOAD: 75% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	501.5	500	1.5	0.3	N/A
	MID	248.1	250	1.9	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	0	3	0.6	0.3
SYSTEM POST RUN 2	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	5	5	1.0	1

	RUN 1	RUN 2	
Co=	1.50	4.00	Avg zero gas system calibration bias.
Cm=	250.00	250.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=	164.20	162.50	Avg gas analyzer concentration reading.
Cgas=	162.44	165.80	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 20 SEPT 90
 CAL. BY: NEWTON *SN*

RUN NO: GAS-75
 BOILER NO: CB
 FUEL: NAT GAS
 LOAD: 75%

ANALYZER: NOX
 SPAN: 100
 UNITS: PPM
 RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	90.71	91	0.29	0.3	N/A
	MID	51.98	52	0.02	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	51.98	52	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	51.98	53	1	1.9	1
	ZERO	0.00	1	1	1.9	1
SYSTEM POST RUN 2	UPSCALE	51.98	53	1	1.9	1
	ZERO	0.00	1.5	1.5	1.8	1.5

	RUN 1	RUN 2	
Co=	0.50	1.25	Avg zero gas system calibration bias.
Cm=	52.50	53.00	Avg upscale gas sys. cal. bias.
Cma=	51.98	51.98	Upscale gas concentration.
C=	27.00	27.20	Avg gas analyzer concentration reading.
Cgas=	26.49	26.07	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 20 SEPT 90
 CAL. BY: NEWTON *HC*

RUN NO: GAS-100
 BOILER NO: CB
 FUEL: NAT GAS
 LOAD: 100%

ANALYZER: 02
 SPAN: 20.0
 UNITS: %
 RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	0	0.0	N/A
	MID	3.116	3.1	0.016	0.1	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.1	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0.1	0.5	0.8
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0.1	0.5	0.47346389
	ZERO	0.00	0.1	0.1	0.5	0.47346389

	RUN 1	RUN 2	
Co=	0.00	0.05	Avg zero gas system calibration bias.
Cm=	3.15	3.20	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=	4.16	4.24	Avg gas analyzer concentration reading.
Cgas=	4.12	4.14	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *EN*

RUN NO: GAS-100 ANALYZER: CO2
BOILER NO: CB SPAN: 20
FUEL: NAT GAS UNITS: %
LOAD: 100% RESP TIME: 100 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11	0.01	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	10.9	0.1	0.5	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	10.6	0.4	2.0	1.8
	ZERO	0.00	-0.1	0.1	0.5	0.8
SYSTEM POST RUN 2	UPSCALE	11.01	10.6	0.4	2.0	1.8
	ZERO	0.00	-0.1	0.1	0.5	0.8

	RUN 1	RUN 2	
Co=	-0.05	-0.10	Avg zero gas system calibration bias.
Cm=	10.75	10.60	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=	9.42	9.23	Avg gas analyzer concentration reading.
Cgas=	9.65	9.60	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON *NE*

RUN NO: GAS-100 ANALYZER: CO
BOILER NO: CB SPAN: 500
FUEL: NAT GAS UNITS: PPM
LOAD: 100% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	501.5	500	1.5	0.3	N/A
	MID	248.1	250	1.9	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	248.10	255	5	1.0	1
	ZERO	0.00	5	5	1.0	1

SYSTEM POST RUN 2	UPSCALE	248.10	255	5	1.0	1
	ZERO	0.00	10	10	2.0	2

	RUN 1	RUN 2	
Co=	2.50	7.50	Avg zero gas system calibration bias.
Cm=	252.50	255.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=	130.70	131.90	Avg gas analyzer concentration reading.
Cgas=	127.23	124.70	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEPT 90
CAL. BY: NEWTON

RUN NO: GAS-100 ANALYZER: 80Y
BOILER NO: CB SPAN: 100
FUEL: NAT GAS UNITS: FEM
LOAD: 100% RESP TIME: 50 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	90.71	91	0.29	0.3	N/A
	MID	51.98	52	0.02	0.0	N/A
	ZERO	0.00	1	1	1.0	N/A
SYSTEM PRETEST	UPSCALE	51.98	52	0	0.0	N/A
	ZERO	0.00	1	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	51.98	54	2	2.0	2
	ZERO	0.00	1.5	0.5	0.5	0.5
SYSTEM POST RUN 2	UPSCALE	51.98	54.5	2.5	2.5	2.5
	ZERO	0.00	2	1	1.0	1

	RUN 1	RUN 2	
Co=	1.25	1.75	Avg zero gas system calibration bias.
Cm=	53.00	54.25	Avg upscale gas sys. cal. bias.
Cma=	51.98	51.98	Upscale gas concentration.
C=	35.60	36.50	Avg gas analyzer concentration reading.
Cgas=	34.50	34.21	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *gn*

RUN NO: OIL-25
BOILER NO: CB
FUEL: OIL
LOAD: 25%

ANALYZER: 02
SPAN: 20.9
UNITS: %
RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	0	0.0	N/A
	MID	3.116	3.1	0.016	0.1	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	3.12	3.1	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	3.12	3.1	0	0.0	0
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	3.12	3.1	0	0.0	0.0
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	3.10	3.10	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=	6.70	6.62	Avg gas analyzer concentration reading.
Cgas=	6.73	6.66	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *EN*

RUN NO: OIL-25
BOILER NO: CB
FUEL: OIL
LOAD: 25%

ANALYZER: CO2
SPAN: 20
UNITS: %
RESP TIME: 100 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11	0.01	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	11	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	10.9	0.1	0.5	0.5
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	11.01	10.9	0.1	0.5	0.5
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	10.95	10.90	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=	10.51	10.30	Avg gas analyzer concentration reading.
Cgas=	10.57	10.40	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *gn*

RUN NO: OIL-25
BOILER NO: CB
FUEL: OIL
LOAD: 25%

ANALYZER: CO
SPAN: 500
UNITS: PPM
RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	501.5	500	1.5	0.3	N/A
	MID	248.1	250	1.9	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	248.10	245	5	1.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	248.10	245	5	1.0	0
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	248.10	240	10	2.0	1
	ZERO	0.00	-5	5	1.0	1

	RUN 1	RUN 2	
Co=	0.00	-2.50	Avg zero gas system calibration bias.
Cm=	245.00	242.50	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=	50.00	48.00	Avg gas analyzer concentration reading.
Cgas=	50.63	51.14	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *RL*

RUN NO: OIL-25
BOILER NO: CB
FUEL: OIL
LOAD: 25%

ANALYZER: NOX
SPAN: 250
UNITS: PPM
RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	203.7	205	1.3	0.5	N/A
	MID	131.1	130	1.1	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	131.10	127.5	2.5	1.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	131.10	125	5	2.0	1
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	131.10	125	5	2.0	1
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	126.25	125.00	Avg upscale gas sys. cal. bias.
Cma=	131.10	131.10	Upscale gas concentration.
C=	87.50	85.96	Avg gas analyzer concentration reading.
Cgas=	90.86	90.15	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

AB43: [W12] '@3% O2

READY

	Y	Z	AA	AB	AC	AD	AE
29	-----						
30	SYSTEM						
31	POST RUN 2						
32		UPSCALE	131.10	125	5	2.0	1
33							
34		ZERO	0.00	0	0	0.0	0
35	-----						

		RUN 1	RUN 2	
36				
37				
38	Co=	0.00	0.00	Avg zero gas system calibration bias.
39	Cm=	126.25	125.00	Avg upscale gas sys. cal. bias.
40	Cma=	131.10	131.10	Upscale gas concentration.
41	C=	87.50	85.96	Avg gas analyzer concentration reading.
42	Cgas=	90.86	90.15	Corrected gas concentration.
43		114.81614	114.90172	@3% O2
44				
45	Analyzer Absolute Difference = Analyzer Cal. Response - Cyl. Value			
46	Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100			
47				
48	Sys. Absolute Difference = Sys. Cal. Response - Analyzer Cal. Response			
				CAPS
	21-Sep-90 08:57 PM			

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *2/1*

RUN NO: OIL-50
BOILER NO: CB
FUEL: OIL
LOAD: 50%

ANALYZER: 02
SPAN: 20.9
UNITS: %
RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	0	0.0	N/A
	MID	3.116	3.1	0.016	0.1	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	3.12	3.2	0.1	0.5	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0.1	0.5	0
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0.1	0.5	0
	ZERO	0.00	0.1	0.1	0.5	0.5

	RUN 1	RUN 2	
Co=	0.00	0.05	Avg zero gas system calibration bias.
Cm=	3.20	3.20	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=	4.55	4.55	Avg gas analyzer concentration reading.
Cgas=	4.44	4.45	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON

RUN NO: OIL-50
BOILER NO: CB
FUEL: OIL
LOAD: 50%

ANALYZER: CO2
SPAN: 20
UNITS: %
RESP TIME: 100 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11.1	0.09	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	10.8	0.2	1.5	N/A
	ZERO	0.00	-0.1	0.1	0.5	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	11.2	0.1	0.5	2
	ZERO	0.00	0	0	0.0	0.5
SYSTEM POST RUN 2	UPSCALE	11.01	11.1	0	0.0	1.5
	ZERO	0.00	-0.1	0.1	0.5	0

	RUN 1	RUN 2	
Co=	-0.05	-0.05	Avg zero gas system calibration bias.
Cm=	11.00	11.15	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=	12.40	12.45	Avg gas analyzer concentration reading.
Cgas=	12.40	12.29	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-50 ANALYZER: CO
 BUILDING: 373 THOMAS PLANT BOILER NO: CB SPAN: 500
 DATE: 21 SEPT 90 FUEL: OIL UNITS: PPM
 CAL. BY: NEWTON LOAD: 50% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	501.5	500	1.5	0.3	N/A
	MID	248.1	255	6.9	1.4	N/A
	ZERO	0.00	5	5	1.0	N/A

SYSTEM PRETEST	UPSCALE	248.10	255	0	0.0	N/A
	ZERO	0.00	5	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	248.10	255	0	0.0	0
	ZERO	0.00	10	5	1.0	1

SYSTEM POST RUN 2	UPSCALE	248.10	255	0	0.0	0
	ZERO	0.00	7	2	0.4	0.4

	RUN 1	RUN 2	
Co=	7.50	8.50	Avg zero gas system calibration bias.
Cm=	255.00	255.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=	90.00	90.80	Avg gas analyzer concentration reading.
Cgas=	82.70	82.83	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *MC*

RUN NO: OIL-50
BOILER NO: CB
FUEL: OIL
LOAD: 50%

ANALYZER: NOX
SPAN: 250
UNITS: PPM
RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	203.7	207	3.3	1.3	N/A
	MID	131.1	132	0.9	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	131.10	130	2	0.8	N/A
	ZERO	0.00	1	1	0.4	N/A
SYSTEM POST RUN 1	UPSCALE	131.10	130	2	0.8	0
	ZERO	0.00	2.5	2.5	1.0	0.6
SYSTEM POST RUN 2	UPSCALE	131.10	127.5	4.6	1.8	1
	ZERO	0.00	0	0	0.0	0.4

	RUN 1	RUN 2	
Co=	1.75	1.25	Avg zero gas system calibration bias.
Cm=	130.00	128.75	Avg upscale gas sys. cal. bias.
Cma=	131.10	131.10	Upscale gas concentration.
C=	95.00	95.00	Avg gas analyzer concentration reading.
Cgas=	95.32	95.40	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-75 ANALYZER: 02
 BUILDING: 373 THOMAS PLANT BOILER NO: C3 SPAN: 20.9
 DATE: 21 SEPT 90 FUEL: OIL UNITS: %
 CAL. BY: NEWTON *DN* LOAD: 75% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	0	0.0	N/A
	MID	3.116	3.1	0.016	0.1	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	3.12	3.2	0.1	0.5	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0.1	0.5	0
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0.1	0.5	0
	ZERO	0.00	0.1	0.1	0.5	0.5

	RUN 1	RUN 2	
Co=	0.00	0.05	Avg zero gas system calibration bias.
Cm=	3.20	3.20	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=	4.34	4.48	Avg gas analyzer concentration reading.
Cgas=	4.23	4.38	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *[Signature]*

RUN NO: OIL-75
BOILER NO: CB
FUEL: OIL
LOAD: 75%

ANALYZER: 602
SPAN: 10
UNITS: %
RESP TIME: 150 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11	0.01	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	10.9	0.1	0.5	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	10.8	0.2	1.0	0.5
	ZERO	0.00	0.1	0.1	0.5	0.5
SYSTEM POST RUN 2	UPSCALE	11.01	10.8	0.2	1.0	1.5
	ZERO	0.00	0	0	0.0	

	RUN 1	RUN 2	
Co=	0.05	0.05	Avg zero gas system calibration bias.
Cm=	10.85	10.80	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=	12.45	12.36	Avg gas analyzer concentration reading.
Cgas=	12.64	12.61	Corrected gas concentration.

Analyzer Absolute Difference = [Analyzer Cal. Response - Cal. Value]
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = [Sys. Cal. Response - Analyzer Cal. Response]
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-75 ANALYZER: CO
 BUILDING: 373 THOMAS PLANT BOILER NO: CB SPAN: 500
 DATE: 21 SEPT 90 FUEL: OIL UNITS: PPM
 CAL. BY: NEWTON *DN* LOAD: 75% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	501.5	500	1.5	0.3	N/A
	MID	248.1	255	6.9	1.4	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	248.10	250	5	1.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	248.10	250	5	1.0	
	ZERO	0.00	5	5	1.0	

SYSTEM POST RUN 2	UPSCALE	248.10	250	5	1.0	
	ZERO	0.00	5	5	1.0	

	RUN 1	RUN 2	
Co=	2.50	5.00	Avg zero gas system calibration bias.
Cm=	250.00	250.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=	14.54	17.00	Avg gas analyzer concentration reading.
Cgas=	12.07	12.15	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *DN*

RUN NO: OIL-75
BOILER NO: C8
FUEL: OIL
LOAD: 75%

ANALYZER: NOX
SPAN: 150
UNITS: PPM
RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	203.7	205	1.3	0.5	N/A
	MID	131.1	130	1.1	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	131.10	127.5	2.5	1.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	131.10	127.5	2.5	1.0	0
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	131.10	127.5	2.5	1.0	0
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	127.50	127.50	Avg upscale gas sys. cal. bias.
Cma=	131.10	131.10	Upscale gas concentration.
C=	92.50	92.50	Avg gas analyzer concentration reading.
Cgas=	95.11	95.11	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *Q.N.*

RUN NO: OIL-100 ANALYZER: 02
BOILER NO: CB SPAN: 20.9
FUEL: OIL UNITS: %
LOAD: 100% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	0	0.0	N/A
	MID	3.116	3.2	0.084	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	3.12	3.2	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	3.12	3.3	0.1	0.5	0.5
	ZERO	0.00	0.1	0.1	0.5	0.5

	RUN 1	RUN 2	
Co=	0.00	0.05	Avg zero gas system calibration bias.
Cm=	3.20	3.25	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=	4.35	4.42	Avg gas analyzer concentration reading.
Cgas=	4.24	4.26	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 21 SEPT 90
CAL. BY: NEWTON *NE*

RUN NO: OIL-100 ANALYZER: CO2
BOILER NO: CB SPAN: 10
FUEL: OIL UNITS: %
LOAD: 100% RESP TIME: 150 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11	0.01	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	10.9	0.2	1.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	10.9	0.1	0.5	0.5
	ZERO	0.00		0	0.0	0
SYSTEM POST RUN 2	UPSCALE	11.01	11	0	0.0	1
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	10.85	10.95	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=	12.47	12.50	Avg gas analyzer concentration reading.
Cgas=	12.65	12.57	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-100 ANALYZER: CO
 BUILDING: 373 THOMAS PLANT BOILER NO: CB SPAN: 500
 DATE: 21 SEPT 90 FUEL: OIL UNITS: PPM
 CAL. BY: NEWTON *EN* LOAD: 100% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	501.5	500	1.5	0.3	N/A
	MID	248.1	250	1.9	0.4	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	248.10	245	5	1.0	1
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	248.10	255	5	1.0	1
	ZERO	0.00	5	5	1.0	1

	RUN 1	RUN 2	
Co=	0.00	2.50	Avg zero gas system calibration bias.
Cm=	247.50	250.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=	6.38	12.90	Avg gas analyzer concentration reading.
Cgas=	6.40	10.43	Corrected gas concentration.

Analyzer Absolute Difference = {Analyzer Cal. Response - Cyl. Value}
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = {Sys. Cal. Response - Analyzer Cal. Response}
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-100 ANALYZER: NOX
 BUILDING: 373 THOMAS PLANT BOILER NO: CB SPAN: 250
 DATE: 21 SEPT 90 FUEL: OIL UNITS: PPM
 CAL. BY: NEWTON LOAD: 100% RESP TIME: 90 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	203.7	205	1.3	0.5	N/A
	MID	131.1	126	5.1	2.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	131.10	127.5	1.5	0.6	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	131.10	130	4	1.6	1
	ZERO	0.00	2.5	2.5	1.0	1

SYSTEM POST RUN 2	UPSCALE	131.10	131	5	2.0	1.4
	ZERO	0.00	2.5	2.5	1.0	1

	RUN 1	RUN 2	
Co=	1.25	2.50	Avg zero gas system calibration bias.
Cm=	128.75	130.50	Avg upscale gas sys. cal. bias.
Cma=	131.10	131.10	Upscale gas concentration.
C=	88.85	92.50	Avg gas analyzer concentration reading.
Cgas=	90.07	92.18	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)



Scott Specialty Gases, Inc.

FAX: 714-887-0549
PHONE: 714-887-2571

2600 CAJON BLVD., SAN BERNARDINO, CA 92405

3/22/90

DEPARTMENT OF THE NAVY
MARK FOR N0537A90
P8487

PROJECT #: 02-06923
PO #: N6258390P3487


PORT HUENEME CA 93043-0000
RECEIVING OFFICER BLDG801


CYLINDER #: AAL3761

ANALYTICAL ACCURACY: +/-1%

COMPONENT	REQUESTED CONCENTRATION	ANALYSIS 1 (MOLES) U/M
CARBON MONOXIDE	250.0 PPM	248.1 PPM
NITROGEN	BALANCE GAS	N/A

DATE OF ANALYSIS: 8/21/90

ANALYST:  MAYNARD JOHNSON

APPROVED BY:  ROBERT SHEALY



Scott Specialty Gases

Scott Environmental Technology Inc. 2600 CAJON BLVD., SAN BERNARDINO, CA 92405

U.S. NAVY

TELEX: 510-100-8831 (ScottGas)
FAX: 714-887-0549
PHONE: 714-887-2571

a division of

Shipped From: Scott SAN BERNARDINO, CA
Date Shipped: 2/14/90
Our Project No: 4930
Your PO No: N6258390M1899
Page 1 of 1
Expiration Date: 8/90

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES

Certified For Traceability Protocol No. 1 Procedure No. GL Cylinder No. AAL-4746 Cylinder Pressure 1900 psig Certified Accuracy $\pm 1.3\%$ 1% NDS Traceable

REFERENCE STD

COMPONENTS	CERTIFIED CONC	SRM/CRM NO.	CYL. NO.	CONC.
CARBON MONOXIDE	501.5 ppm	CRM2637	AAL-10133	2412 ppm
CARBON DIOXIDE	11.01%	CRM1675B	ALM-1308	14.08%

GAS ANALYZER

MAKE/MODEL/SERIAL NO.	LAST CAL. DATE	ANALYTICAL PRINCIPLE
HORIBA AIA24 4564403	1/29/90	INFRA-RED
HORIBA PIR2000 406004	1/29/90	INFRA-RED

BALANCE GAS NITROGEN

ANALYZER HEADINGS: Z = Zero Gas T = Test Gas R = Reference Gas

CARBON MONOXIDE			
Component	First Analysis Date	2/5/90	Units
Z	00.0	R	93.3
R	93.3	Z	00.0
Z	00.0	T	35.7
Mean Test Assay			502.1 ppm
CARBON DIOXIDE			
Component	First Analysis Date	2/5/90	Units
Z	00.0	R	93.3
R	93.3	Z	00.0
Z	00.0	T	80.6
Mean Test Assay			11.01%
Second Analysis Date			
Component	2/12/90	Units	
Z	00.0	R	93.3
R	93.3	Z	00.0
Z	00.0	T	35.7
Mean Test Assay			501.5 ppm

Chronology: Date _____ Assay _____

Analyst LIFE OF DIAM _____

Approved By: *James Rose*



Scott Specialty Gases

U.S. Specialty Environmental Technology Inc. 2600 CAJON BLVD., SAN BERNARDINO, CA 92405

US NAVY

TELEX: 510-100-8831 (ScotGas)
FAX: 714-887-0549
PHONE: 714-887-2571

a division of

Shipped From: Scott SAN BERNARDINO, CA
Date Shipped: 2/14/90
Our Project No: 4930
Your PO No: N 6258390M1899
Page 1 of 1
Expiration Date: 8/91

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES

Certified For Traceability: 1 Procedure No. GL

Cylinder No. ALM-3479

Cylinder Pressure: 1900 psig Certified Accuracy: $\pm 1.2\%$ NDS Traceable

REFERENCE STD

GAS ANALYZER

COMPONENTS	CERTIFIED CONC	SRM/CRM NO.	CYL. NO.	CONC.	MAKE/MODEL/SERIAL NO.	LAST CAL. DATE	ANALYTICAL PRINCIPLE
OXYGEN	3.116%	CRM 2658	AAL-18548	10.08%	BECKMAN 755 100410	1/29/90	PARAMAGNETIC

BALANCE GAS NITROGEN

ANALYZER READINGS: Z = Zero Gas T = Test Gas R = Reference Gas

Component	OXYGEN	Units	%
First Analysis Date	2/5/90		
Z	00.0	R	97.4
T	97.4	Z	00.0
R	00.0	T	30.1
Z	30.1	R	97.4
Mean Test Assay	3.116%		

Component	OXYGEN	Units	%
Second Analysis Date			
Z		R	
T		Z	
R		T	
Z		R	
Mean Test Assay			

Component		Units	
Date			
Z		R	
R		Z	
Z		T	
Mean Test Assay			

Component		Units	
Date			
Z		R	
R		Z	
Z		T	
Mean Test Assay			

Chronology: Date
Assay

Analyst: D. BUTTERFIELD

Approved By: *Sharon Kern*

✓

Scott Specialty Gases

Scott Environmental Technology Inc. 2600 CAJON BLVD., SAN BERNARDINO, CA 92405

U.S. NAVY

TELEX: 510-100-8831 (ScotGas)
FAX: 714-887-0549
PHONE: 714-887-2571

a division of

Shipped From: Scott SAN BERNARDINO, CA
Date Shipped: 2/14/90
Our Project No: 4930
Your PO No: N6258390M1899
Page 1 of 1
Expiration Date: 8/91

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES

Certified For Traceability Protocol No. 1 Procedure No. G1 Cylinder No. AAL-6113 Cylinder Pressure 1900 psig Certified Accuracy $\pm 1.3\%$ at NBS Traceable

REFERENCE STD

COMPONENTS	CERTIFIED CONC	SRM/CRM NO.	CYL. NO.	CONC.	MAKE/MODEL/SERIAL NO.	LAST CAL. DATE	ANALYTICAL PRINCIPLE
NITRIC OXIDE	90.60 ppm	CRM 1684B	ALM-3640	97.28 ppm	THERMO-ELECTRON 10 AR 14853-150	11/10/89	CHEMI-LUMINESCENT
NOX	90.71 ppm						

GAS ANALYZER

BALANCE GAS NITROGEN

ANALYZER READINGS: Z = Zero Gas T = Test Gas R = Reference Gas

Component	Date	Units	Mean Test Assay
NITRIC OXIDE	1/31/90	ppm	
0.00	R	97.30	T 90.60
97.42	Z	0.05	T 90.77
0.00	T	90.88	R 97.60
Mean Test Assay			90.60 ppm
Second Analysis Date	2/7/90	Units	ppm
0.00	R	97.25	T 90.55
97.28	Z	0.02	T 90.56
0.00	T	90.60	R 97.23
Mean Test Assay			90.60 ppm

Chronology: Date

Assay

Analyst LEE OLDHAM

Approved By: *James Kim*



Scott's Specialty Gases

Scott Environmental Technology Inc., 2600 CAJON BLVD., SAN BERNARDINO, CA 92405

U.S. NAVY

TELEX: 510-100-8831 (ScottGas)
FAX: 714-887-0549
PHONE: 714-887-2571

a division of

Shipped From: Scott SAN BERNARDINO, CA
Date Shipped: 2/14/90
Our Project No.: 4930

Your PO No.: N6258390M1899

Page 1 of 1

Expiration Date: 8/91

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES

Certified For Traceability Protocol No. 1 Procedure No. G1

Cylinder No. AAL-8361

Cylinder Pressure 1900 psig

Certified Accuracy $\pm 1\%$ 4% NIOS Traceability

REFERENCE STD

COMPONENTS	CERTIFIED CONC	SRM/CRM NO.	CYL. NO.	CONC.	MAKE/MODEL/SERIAL NO.	LAST CAL. DATE	ANALYTICAL PRINCIPLE
NITRIC OXIDE	51.81 ppm	CRM 1684B	ALM-3640	97.28 ppm	THERMO-ELECTRON	11/10/89	CHEMI-LUMINESCENT
NOX	51.98 ppm				10 AR 14853-150		

GAS ANALYZER

BALANCE GAS

NITROGEN

ANALYZER READINGS: Z = Zero Gas T = Test Gas R = Reference Gas

Component	NITRIC OXIDE	1/31/90	Units	ppm	Component	Units
First Analysis Date	1/31/90				Date	
Z 0.00	R 97.33	T 51.80		Z	R	T
R 97.50	Z 0.06	T 51.83		R	Z	T
Z 0.04	T 51.89	R 97.50		Z	T	R
Mean Test Assay	51.73 ppm			Mean Test Assay		
Second Analysis Date	2/7/90				Date	
Z 0.00	R 97.30	T 51.80		Z	R	T
R 97.20	Z 0.03	T 51.80		R	Z	T
Z 0.02	T 51.80	R 97.24		Z	T	R
Mean Test Assay	51.81 ppm			Mean Test Assay		

Chronology: Date

Assay

Analyst LEE OLIVIAN

Approved By: *John Lee*

APPENDIX C
FIELD DATA SHEETS

Method 4

SAMPLE BOX SET UP CHECKLIST

DATE: _____

PLANT: Thomas

RUN NO.: Gas 25-1

LOCATION: _____

STACK NO: _____

PREP. BY: _____

SAMPLE BOX NO.: _____

- () 1. Wash all glassware with distilled water and then acetone.
- () 2. Place approx. 100 ml distilled water in the first impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 3. Place approx. 100 ml distilled water in the second impinger, a standard Greenburg-Smith impinger (caricell tip). Record exact weight to 1/10 of a gram.
- () 4. Impinger three is a dry modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record dry tare weight to 1/10 of a gram.
- () 5. Place approx. 175 ml of silica gel in the fourth impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 6. PLACE ~~_____~~ FILTER INTO FILTER HOLDER ON THE CYCLONE SIDE OF THE HOLDER. Smooth side of filter is to face frittered glass of filter holder. ~~_____~~


Impinger No.	Impinger weights (GRAMS)	Tare	Initial	Final	Condensate	
<u>X-1</u>	1. 100 ml		568.92	639.47	70.55	
<u>X-2</u>	2. 100 ml		550.76	564.89	14.13	
<u>X-3</u>	3. Dry		471.59	472.97	1.38	
<u>X-4</u>	4. 175 g silica gel		566.27	671.49	5.22	
						TOTAL
						91.28

50%

- () 7. Assemble ~~_____~~ filter holder.
- () 8. Assemble impinger bottles and glass elbows so air flows from a small hole to a larger hole.

(SIS rev11/88, #0251Q)

PLANT Thomas	BAROMETRIC PRESSURE, in Hg	MEIER BOX # 110443	PROBE # (PITOT #)	NOZZLE #
LOCATION CBC 8/64 373	AMBIENT TEMPERATURE, °F 64	MEIER ΔIQ	PITOT COEF 0.80	IDEAL NOZZLE DIA, in.
DATE 9/20/90	AVE STATIC PRESSURE, in H ₂ O	MEIER δ	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR JAM	AVE VEL HEAD, in H ₂ O	SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PITOT'S OK @ 14
RUN # GAS-25-1	ASSURED MOISTURE, %	HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM @ in Hg OK @ 14



TRAVERSE POINT #	SAMPLING TIME min	GAS METER READING (V _m) ft ³	SECTION (SLOW TRAVERSE PTS)				IMPINGER TEMPERATURE °F	SAMPLE BOX TEMPERATURE °F	SAMPLE BOX VACUUM in Hg
			VELOCITY HEAD (NEAS) (AP) in H ₂ O	STACK TEMPERATURE (Ts) °F	GAS SAMPLE TEMPERATURE AT DRY GAS METER Inlet (T _m in) °F	Outlet (T _m out) °F			
1	73	135.458	.005	353	66	65	53	248	5.0
2	3	137.493	.01	352	66	66	42	252	
3	6	139.502	.01	352	68	66	41	252	
4	9	141.634	.01	352	69	66	43	250	
5	12	143.692	.01	352	72	67	44	253	
6	15	145.758	.015	351	72	67	45	254	
7	18	147.805	.015	351	74	68	46	255	
8	21	149.83	.017	351	74	68	46	255	
9	24	151.37	.01	351	76	69	46	256	
10	27	153.032	.01	351	77	70	47	253	
11	30	155.710	.011	352	78	70	48	244	
12	33	158.002	.01	353	78	71	47	253	
13	36	160.019	.01	353	78	71	50	244	
TOTAL									
AVERAGE									

OK
OK
OK
OK


100%

PLANT *Thomas*

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT <i>Thomas</i>	BAROMETRIC PRESSURE, in Hg	METER BOX #	PROBE # (PITOT #)	NOZZLE #
LOCATION <i>CBC</i>	AMBIENT TEMPERATURE, °F	METER ΔHQ	PITOT COEF	IDEAL NOZZLE DIA, in.
DATE <i>9/20/90</i>	AVE STATIC PRESSURE, in H ₂ O	METER %	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR <i>Clark</i>	AVE VEL HEAD, in H ₂ O	SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PITOT'S
RUN # <i>GAS-25-1</i>	ASSURED MOISTURE, %	HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM @ in Hg



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

STACK POINT #	SAMPLING TIME	min	STACK TEMPERATURE (Ts) °F	ANALYSIS			
				O ₂ %	CO %	CO ppm	NOX ppm
1	0		360	7.1	7.8	125	22
2	5		356	7.1	7.8	110	23
3	10		355	7.0	7.8	120	23
4	15		354	7.1	7.8	120	23
5	20		354	6.9	7.9	120	23
6	25		353	7.2	7.8	130	23
7	30		352	7.1	7.9	120	23
8	35		352	7.0	7.9	120	23
9	40		351	7.2	7.8	125	23
10	45		351	6.9	7.9	110	23
11	50		351	7.1	7.8	130	23
12	55		351	7.1	7.8	120	23
	60		351	7.1	7.8	110	24
TOTAL				7.07	7.83	120	23
AVERAGE							

FUEL METER
END 2008
FUEL 800509

AVG


SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT <i>Thomas</i>		BAROMETRIC PRESSURE, in Hg		METER BOX #		PROBE # (PITOT #)		NOZZLE #	
LOCATION <i>CBC</i>		AMBIENT TEMPERATURE, °F		METER ΔHQ		PITOT COEF		IDEAL NOZZLE DIA, in.	
DATE <i>2/20/90</i>		AVE STATIC PRESSURE, in H ₂ O		METER %		PROBE LENGTH, in.		ACTUAL NOZZLE DIA, in.	
OPERATOR <i>Blackburn</i>		AVE VEL HEAD, in H ₂ O		SAMPLE BOX #		PROBE LINER MATERIAL		LEAK CHECK @ PITOT'S	
RUN # <i>GAS-25-2</i>		ASSUMED MOISTURE, %		HEATER BOX SETTING		PROBE HEATER SETTING		LEAK RATE CFM @ in Hg	

FUEL METER START

TIME 20:30



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

POINT #	SAMPLING TIME	min	STACK TEMPERATURE (Ts) °F	ANALYSIS			
				O ₂ %	CO %	CO ppm	NOX ppm
1	0		360	7.1	7.9	110	23
2	5		360	7.0	7.9	115	23
3	10		361	6.8	7.9	110	23
4	15		361	6.9	7.8	100	24
5	20		361	6.9	7.8	110	24
6	25		359	7.0	7.7	105	24
7	30		356	6.9	7.8	110	24
8	35		353	7.0	7.7	100	24
9	40		351	7.0	7.8	110	24
10	45		351	6.9	7.8	120	24
11	50		353	6.8	7.9	105	24
12	55		353	6.8	7.8	100	24
	60		353	6.8	7.8	105	23
TOTAL				6.92	7.82	106.9	23.7
AVERAGE							

STOP 21:30

FUEL METER END 20:32.2

ALG

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 9/20/90
 CAL. BY: *Jim N...*

RUN NO: GAS-25
 BOILER NO:
 FUEL: NAT GAS
 LOAD: 25%

ANALYZER: NOX
 SPAN: 100
 UNITS: PPM
 RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	90.71	90	90.71	90.7	N/A
	MID	51.98	51.5	51.98	52.0	N/A
	ZERO	0.00	0.5	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	51.98	51	0	0.0	N/A
	ZERO	0.00	1	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	51.98	52	0	0.0	0
	ZERO	0.00	1.5	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	51.98	52	0	0.0	0
	ZERO	0.00	1	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	51.98	51.98	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: GAS-25 ANALYZER: 02
 BUILDING: 373 THOMAS PLANT BOILER NO: 0 SPAN: 20.9
 DATE: 0 FUEL: NAT GAS UNITS: %
 CAL. BY: 0 LOAD: 25% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	20.9	100.0	N/A
	MID	3.116	3.2	3.116	14.9	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST			20.9			
	UPSCALE	3.12	3.1	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1			20.9			
	UPSCALE	3.12	3.2	0	0.0	
	ZERO	0.00	0.1	0	0.0	
SYSTEM POST RUN 2			20.9			
	UPSCALE	3.12	3.2	0	0.0	
	ZERO	0.00	0.1	0	0.0	

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 0
 CAL. BY: 0

RUN NO: GAS-25
 BOILER NO: 0
 FUEL: NAT GAS
 LOAD: 25%

ANALYZER: CO
 SPAN: 500
 UNITS: PPM
 RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	499.7 501.5	500	499.7	99.9	N/A
	MID	248.1	250	248.1	49.6	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	0	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	248.10	247	0	0.0	0
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = (Analyzer Cal. Response - Cyl. Value)
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = (Sys. Cal. Response - Analyzer Cal. Response)
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 0
 CAL. BY: 0

RUN NO: GAS-25
 BOILER NO: 0
 FUEL: NAT GAS
 LOAD: 25%

ANALYZER: CO2
 SPAN: 20
 UNITS: %
 RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11.0	11.01	55.1	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	11.0	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	11.0	0	0.0	
	ZERO	0.00	0	0	0.0	
SYSTEM POST RUN 2	UPSCALE	11.01	10.9	0	0.0	
	ZERO	0.00	0	0	0.0	

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = [Analyzer Cal. Response - Cyl. Value]
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = [Sys. Cal. Response - Analyzer Cal. Response]
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

Method 4

SAMPLE BOX SET UP CHECKLIST

DATE: _____

PLANT: Thomas

LOCATION: _____

PREP. BY: _____

RUN NO.: GAS-50-1

STACK NO: _____

SAMPLE BOX NO.: _____

- () 1. Wash all glassware with distilled water and then acetone.
- () 2. Place approx. 100 ml distilled water in the first impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 3. Place approx. 100 ml distilled water in the second impinger, a standard Greenburg-Smith impinger (caricell tip). Record exact weight to 1/10 of a gram.
- () 4. Impinger three is a dry modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record dry tare weight to 1/10 of a gram.
- () 5. Place approx. 175 ml of silica gel in the fourth impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 6. PLACE ~~_____~~ FILTER INTO FILTER HOLDER ON THE CYCLONE SIDE OF THE HOLDER. Smooth side of filter is to face frittered glass of filter holder. ~~_____~~

Impinger No.	Impinger weights (GRAMS)	Tare	Initial	Final	Condensate	
<u>1</u>	1. 100 ml		<u>648.49</u>	<u>779.83</u>	<u>91.34</u>	
<u>2</u>	2. 100 ml		<u>622.20</u>	<u>140.08</u>	<u>17.8</u>	
<u>3</u>	3. Dry		<u>502.76</u>	<u>525.41</u>	<u>2.75</u>	
<u>4</u>	4. 175 g silica gel		<u>739.49</u>	<u>746.72</u>	<u>7.23</u>	
				<u>3572</u>		
						TOTAL
						<u>119.13</u>

- () 7. Assemble ~~_____~~ filter holder.
- () 8. Assemble impinger bottles and glass elbows so air flows from a small hole to a larger hole.

(SJS rev11/88, #0251Q)

PLANT Thomas		BAROMETRIC PRESSURE, in Hg		NEETER BOX # 62448		PROBE # (PITOT #)		NOZZLE #	
LOCATION CBC 8164373		AMBIENT TEMPERATURE, °F 70		METER ΔIQ		PITOT COEFF 0.80		IDEAL NOZZLE DIA, in.	
DATE 9/20/40		AVE STATIC PRESSURE, in H ₂ O		METER %		PROBE LENGTH, in.		ACTUAL NOZZLE DIA, in.	
OPERATOR JM		AVE VEL HEAD, in H ₂ O		SAMPLE BOX #		PROBE LINER MATERIAL		LEAK CHECK @ PITOT'S	
RUN # GAS-50-1		ASSURED MOISTURE, %		SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)		HEATER BOX SETTING		PROBE HEATER SETTING	
TRAVERSE POINT #		SAMPLING TIME		GAS METER READING (V _m) ft ³		VELOCITY HEAD (VEAS) (ΔP) in H ₂ O		TEMPERATURE (T _s) °F	
1		4.12 min		166.792		.01		385	
2		5		159.056		.01		385	
3		6		111.435		.01		384	
4		9		113.800		.01		380	
5		12		116.141		.015		380	
6		15		118.473		.015		386	
7		18		122.805		.02		381	
8		21		123.148		.02		384	
9		24		125.477		.005		381	
10		27		127.798		.01		388	
11		30		130.104		.01		388	
12		33		132.411		.01		383	
13		36		134.721		.01		360	
TOTAL									
AVERAGE									

Post: 0.041 ft³
@ 12" H₂

Static

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT <i>Thomas</i>		BAROMETRIC PRESSURE, in Hg		METER BOX #		PROBE # (PILOT #)		NOZZLE #	
LOCATION <i>CBC</i>		AMBIENT TEMPERATURE, °F		METER ΔIQ		PILOT COEF		IDEAL NOZZLE DIA, in.	
DATE <i>9/20/90</i>		AVE STATIC PRESSURE, in H ₂ O		METER Ø		PROBE LENGTH, in.		ACTUAL NOZZLE DIA, in.	
OPERATOR <i>[Signature]</i>		AVE VEL HEAD, in H ₂ O		SAMPLE BOX #		PROBE LINER MATERIAL		LEAK CHECK @ PILOT'S	
RUN # <i>GAS-50-1</i>		ASSURED NOISTURE, %		HEATER BOX SETTING		PROBE HEATER SETTING		LEAK RATE CFM @ in Hg	
SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)		STACK TEMPERATURE (Ts) °F		O ₂ %		CO ppm		NOX ppm	
START FUEL METER <i>797085</i>		min		1		0		180	
START 1548		2		5		10		19	
		3		10		15		19	
		4		15		20		19	
		5		20		25		18	
		6		25		30		18	
		7		30		35		18	
		8		35		40		18	
		9		40		45		18	
		10		45		50		18	
		11		50		55		18	
		12		55		60		18	
STOP 1648		TOTAL		4.8		9.13		182	
FUEL METER 798011		AVERAGE		4.8		9.13		18.4	

AUG

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #02510)

PLANT <i>Thomas</i>	BAROMETRIC PRESSURE, in Hg	METER BOX #	PROBE # (PITOT #)	NOZZLE #
LOCATION <i>COC</i>	AMBIENT TEMPERATURE, °F	METER ΔH _Q	PITOT COEF	IDEAL NOZZLE DIA, in.
DATE <i>9/20/90</i>	AVE STATIC PRESSURE, in H ₂ O	METER γ	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR <i>[Signature]</i>	AVE VEL HEAD, in H ₂ O	SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PITOT'S
RUN # <i>GAS-50-2</i>	ASSURED MOISTURE, %	HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM @ in Hg

FUEL METER START 798372

STOP 1712

FUEL METER END 799307

SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

POINT #	SAMPLING TIME	min	TEMPERATURE (T _s) °F	O ₂ %	CO ppm	NOX ppm
1	0		379	4.5	9.2	240
2	5		379	4.4	9.2	220
3	10		379	4.4	9.2	190
4	15		380	4.4	9.2	190
5	20		381	4.4	9.1	150
6	25		381	4.3	9.2	180
7	30		381	4.4	9.1	190
8	35		381	4.7	8.9	90
9	40		382	4.5	9.0	140
10	45		382	4.5	8.9	130
11	50		382	4.5	8.9	140
12	55		382	4.4	9.0	170
	60		382	4.2	9.1	230
TOTAL				4.4	9.07	173
AVERAGE						17.4

AUG

EMPTY FINGERS
LEAK CHECK GOOD

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: GAS-50 ANALYZER: NOX
BUILDING: 373 THOMAS PLANT BOILER NO: SPAN: 100
DATE: 9/20/90 FUEL: NAT GAS UNITS: PPM
CAL. BY: *DR* LOAD: 50% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	90.71	<i>31</i>	90.71	90.7	N/A
	MID	51.98	<i>52</i>	51.98	52.0	N/A
	ZERO	0.00	<i>1</i>	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	51.98	<i>52</i>	0	0.0	N/A
	ZERO	0.00	<i>1</i>	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	51.98	<i>51</i>	0	0.0	0
	ZERO	0.00	<i>0</i>	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	51.98	<i>49.5</i>	0	0.0	0
	ZERO	0.00	<i>-0.5</i>	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	51.98	51.98	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: GAS-50 ANALYZER: 02
 BUILDING: 373 THOMAS PLANT BOILER NO: 0 SPAN: 10.4
 DATE: 0 FUEL: NAT GAS UNITS: %
 CAL. BY: 0 LOAD: 50% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	20.9	100.0	N/A
	MID	3.116	3.2	3.116	14.9	N/A
	ZERO	0.00	0.1	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.2	0	0.0	N/A
	ZERO	0.00	0.1	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0	0.0	
	ZERO	0.00	0.1	0	0.0	
SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0	0.0	
	ZERO	0.00	0.1	0	0.0	

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|

Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|

System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: GAS-50 ANALYZER: CO
 BUILDING: 373 THOMAS PLANT BOILER NO: 0 SPAN: 200
 DATE: 0 FUEL: NAT GAS UNITS: PPM
 CAL. BY: 0 LOAD: 50% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	499.7 501.5	500	499.7	99.9	N/A
	MID	248.1	250	248.1	49.6	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST			400			
	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1			500			
	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2			500			
	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|

Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|

System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: GAS-50 ANALYZER: 702
 BUILDING: 373 THOMAS PLANT BOILER NO: 0 SPAN: 100
 DATE: 0 FUEL: NAT GAS UNITS: %
 CAL. BY: 0 LOAD: 50% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST						
	HIGH			0	0.0	N/A
	MID	11.01	11.0	11.01	55.1	N/A
	ZERO	0.00	0.1	0	0.0	N/A
SYSTEM PRETEST						
	UPSCALE	11.01	10.8	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1						
	UPSCALE	11.01	10.8	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2						
	UPSCALE	11.01	10.5	0	0.0	0
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = [Analyzer Cal. Response - Cy]. Value

Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = [Sys. Cal. Response - Analyzer Cal. Response]

System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

Method 4.

SAMPLE BOX SET UP CHECKLIST

DATE: _____

PLANT: Thomas

RUN NO.: GAS-75-1

LOCATION: _____

STACK NO: _____

PREP. BY: JR

SAMPLE BOX NO.: _____

- () 1. Wash all glassware with distilled water and then acetone.
- () 2. Place approx. 100 ml distilled water in the first impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 3. Place approx. 100 ml distilled water in the second impinger, a standard Greenburg-Smith impinger (caricell tip). Record exact weight to 1/10 of a gram.
- () 4. Impinger three is a dry modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record dry tare weight to 1/10 of a gram.
- () 5. Place approx. 175 ml of silica gel in the fourth impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 6. PLACE ~~_____~~ FILTER INTO FILTER HOLDER ON THE CYCLONE SIDE OF THE HOLDER. Smooth side of filter is to face frittered glass of filter holder. ~~_____~~

Impinger No.	Impinger weights (GRAMS)	Tare	Initial	Final	Condensate	
<u>X-1</u>	1. 100 ml		572.09	651.60	79.51	
<u>X-2</u>	2. 100 ml		547.44	562.52	15.08	
<u>X-3</u>	3. Dry		471.24	473.06	1.82	
<u>X-4</u>	4. 175 g silica gel		660.01	666.36	6.35	
						TOTAL
						102.76

10%

- () 7. Assemble ~~_____~~ filter holder.
- () 8. Assemble impinger bottles and glass elbows so air flows from a small hole to a larger hole.

11ET1 -5 (-)
SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)


PLANT **Thomas** BAROMETRIC PRESSURE, in Hg

LOCATION **CBC 8049373** AMBIENT TEMPERATURE, °F

DATE **9/20/90** AVE STATIC PRESSURE, in H₂O

OPERATOR **SM** AVE VEL HEAD, in H₂O

RUN # **GAS - 75-1** ASSURED NOISTURE, %



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

TRAVERSE POINT #	SAMPLING TIME	GAS METER READING (V _m) ft ³	VELOCITY HEAD (NEAS) (ΔP) in H ₂ O	STACK TEMPERATURE (T _s) °F	GAS SAMPLE TEMPERATURE AT DRY GAS METER		IMPIGNER TEMPERATURE °F	SAMPLE BOX TEMPERATURE °F	SAMPLE BOX VACUUM in Hg
					(T _m in) °F	(T _m out) °F			
1	12:44 a.m.	82.895	0.044	451	69	69	73	253	5.0
2	3	84.705	0.035	450	70	69	50	253	5.0
3	6	86.698	0.032	454	71	69	48	254	5.0
4	9	88.698	0.02	451	73	70	48	254	5.0
5	12	90.682	0.020	450	73	70	49	255	5.0
6	15	92.664	0.044	452	74	70	50	255	5.0
7	18	94.638	0.05	453	75	71	51	255	5.0
8	21	96.593	0.055	451	76	71	52	255	5.0
9	24	98.571	0.035	452	77	72	53	256	5.0
10	27	100.549	0.035	452	78	72	53	255	5.0
11	30	102.497	0.044	451	78	73	54	254	5.0
12	33	104.463	0.035	450	78	73	50	256	5.0
13	36	106.409	0.022	451	79	73	49	255	5.0
TOTAL									
AVERAGE									

NOZZLE #

PROBE # (PILOT #)

METER BOX #

HEATER BOX SETTING

PROBE HEATER SETTING

IDEAL NOZZLE DIA, in.

PILOT COEF

METER ΔIR

PROBE LENGTH, in.

PROBE LINER MATERIAL

ACTUAL NOZZLE DIA, in.

LEAK CHECK @ PILOT'S

LEAK RATE CFM @ 11" Hg

Leak: OK

Leak: OK

ETM - 5 (- 4) : 1

SOURCE EMISSION TESTING DATA SHEET

PLANT *Thomas*

AMBIENT TEMPERATURE, °F

CRC B/d 373

AVE STATIC PRESSURE, in H₂O

AVE VEL HEAD, in H₂O

6 AF-75-1

READING

51

AVERAGE

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT *Thomas*

LOCATION *CBC*

DATE *20 SEP 92*

OPERATOR *[Signature]*

RUN # *GAS-75-1*


BAROMETRIC PRESSURE, in Hg

AMBIENT TEMPERATURE, °F

AVE STATIC PRESSURE, in H₂O

AVE VEL HEAD, in H₂O

ASSURED MOISTURE, %



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

*GAS METER
START 92138*

1222pm

POINT #	SAMPLING TIME	min	STACK TEMPERATURE (Ts) °F
1	0		454
2	5		452
3	10		452
4	15		451
5	20		452
6	25		452
7	30		452
8	35		452
9	40		452
10	45		452
11			451
12	55		451
	60		
TOTAL			
AVERAGE			

*1322pm
GAS METER
FIN 46
793707*

METER BOX #

METER ΔH_Q

METER γ

SAMPLE BOX #

HEATER BOX SETTING

PROBE # (PITOT #)

PITOT COEF

PROBE LENGTH, in.

PROBE LINER MATERIAL

PROBE HEATER SETTING

NOZZLE #

IDEAL NOZZLE DIA, in.

ACTUAL NOZZLE DIA, in.

LEAK CHECK @ PITOT'S

LEAK RATE CFM@ in Hg


O ₂ %	CO ₂ %	CO ppm	NOX ppm
4.5	9.4	190	26
4.5	9.4	180	26
4.5	9.4	195	27
4.5	9.5	180	27
4.7	9.3	80	27
4.6	9.4	180	27
4.6	9.4	160	27
4.6	9.4	140	27
4.5	9.5	200	27
4.5	9.5	190	27
4.7	9.4	100	28
4.6	9.5	140	28
4.6	9.5	200	27
4.7	9.4	100	27

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)		BAROMETRIC PRESSURE, in Hg		METER BOX #		PROBE # (PITOT #)		NOZZLE #	
PLANT <i>Thomas</i>		AMBIENT TEMPERATURE, °F		METER ΔH _Q		PITOT COEF		IDEAL NOZZLE DIA, in.	
LOCATION <i>CBC</i>		AVE STATIC PRESSURE, in H ₂ O		METER γ		PROBE LENGTH, in.		ACTUAL NOZZLE DIA, in.	
DATE <i>20 SEPT 90</i>		AVE VEL HEAD, in H ₂ O		SAMPLE BOX #		PROBE LINER MATERIAL		LEAK CHECK @ PITOT'S	
OPERATOR <i>W. Smith</i>		ASSURED MOISTURE, %		HEATER BOX SETTING		PROBE HEATER SETTING		LEAK RATE CFM @ in Hg	
RUN # <i>GAS-75-2</i>		SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)							

GAS METER
START 794315

START TIME 13.44



POINT #	SAMPLING TIME min	STACK TEMPERATURE (Ts) °F	O ₂	CO ₂	CO	NOX
			%	%	ppm	ppm
1	0	452	46	9.5	150	27
2	5	452	46	9.5	110	27
3	10	451	47	9.5	125	27
4	15	453	46	9.5	215	27
5	20	452	45	9.5	220	27
6	25	452	48	9.3	120	27
7	30	452	44	9.5	240	27
8	35	452	47	9.3	140	28
9	40	453	46	9.4	190	27
10	45	452	46	9.4	110	27
11	50	452	46	9.3	190	27
12	55	453	46	9.2	150	28
	60	453	47	9.2	140	27
TOTAL			461	9.39	1685	27.2
AVERAGE						

STOP TIME 14:44

OPERATOR W. SMITH

FINAL 795910

AVG

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 20 SEP 90
CAL. BY: [Signature]

RUN NO: GAS-75 ANALYZER: NOX
BOILER NO: SPAN: 100
FUEL: NAT GAS UNITS: PPM
LOAD: 75% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	90.71	91	90.71	10.7	N/A
	MID	51.98	52	51.98	52.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	51.98	52	0	0.0	
	ZERO	0.00	0.0	0	0.0	

SYSTEM POST RUN 1	UPSCALE	51.98	53	0	0.0	
	ZERO	0.00	1	0	0.0	

SYSTEM POST RUN 2	UPSCALE	51.98	53	0	0.0	
	ZERO	0.00	1.5	0	0.0	

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	51.98	51.98	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 60 CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 0
 CAL. BY: 0

RUN NO: GAS-75
 BOILER NO: 6
 FUEL: NAT GAS
 LOAD: 75%

ANALYZER: 02
 SPAN: 20.9
 UNITS: %
 RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER	HIGH	20.90	20.9	20.9	100.0	N/A
PRETEST	MID	3.116	3.2	3.116	14.9	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM			2			
PRETEST	UPSCALE	3.12	3.2	0	0.0	N/A
	ZERO	0.00	0.1	0	0.0	N/A
SYSTEM			24.0			
POST RUN 1	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0
SYSTEM			21.0			
POST RUN 2	UPSCALE	3.12	3.2 3.3	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0

	RUN 1	RUN 2
Co=	0.00	0.00 Avg zero gas system calibration bias.
Cm=	0.00	0.00 Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12 Upscale gas concentration.
C=		Avg gas analyzer concentration reading.
Cgas=	FRR	FRR Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 0
CAL. BY: 0

RUN NO: GAS-75
BOILER NO: 0
FUEL: NAT GAS
LOAD: 75%
ANALYZER: CO
SPAN: 500
UNITS: PPM
RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER	HIGH	499.7	500	499.7	99.9	N/A
PRETEST	MID	248.1	250	248.1	49.6	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM						
PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM						
POST RUN 1	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	3	0	0.0	0
SYSTEM						
POST RUN 2	UPSCALE	248.10	500 250	0	0.0	0
	ZERO	0.00	5	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 0
CAL. BY: 0

RUN NO: GAS-75
BOILER NO: 0
FUEL: NAT GAS
LOAD: 75%

ANALYZER: 002
SPAN: 20
UNITS: %
RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER	HIGH			0	0.0	N/A
PRETEST	MID	11.01	11	11.01	55.1	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM	UPSCALE	11.01	11	0	0.0	N/A
PRETEST	ZERO	0.00	0	0	0.0	N/A
SYSTEM	UPSCALE	11.01	11	0	0.0	0
POST RUN 1	ZERO	0.00	0	0	0.0	0
SYSTEM	UPSCALE	11.01	10.9	0	0.0	0
POST RUN 2	ZERO	0.00	0	0	0.0	0

Co= 0.00 RUN 1
Cm= 0.00 RUN 2
Cma= 11.01
C= 11.01
Cgas= ERR

0.00 Avg zero gas system calibration bias.
0.00 Avg upscale gas sys. cal. bias.
11.01 Upscale gas concentration.
Avg gas analyzer concentration reading.
ERR Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

Method 4

SAMPLE BOX SET UP CHECKLIST

DATE: 9/20/90
PLANT: Thomas
LOCATION: _____
PREP. BY: JR/JM

RUN NO.: GAS-100-1
STACK NO: Boiler-1
SAMPLE BOX NO.: _____

- (X) 1. Wash all glassware with distilled water and then acetone.
- () 2. Place approx. 100 ml distilled water in the first impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 3. Place approx. 100 ml distilled water in the second impinger, a standard Greenburg-Smith impinger (caricell tip). Record exact weight to 1/10 of a gram.
- () 4. Impinger three is a dry modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record dry tare weight to 1/10 of a gram.
- () 5. Place approx. 175 ml of silica gel in the fourth impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 6. PLACE ~~_____~~ FILTER INTO FILTER HOLDER ON THE CYCLONE SIDE OF THE HOLDER. Smooth side of filter is to face frittered glass of filter holder. ~~_____~~

Impinger No.	Impinger weights (GRAMS)
<u>1</u>	1. 100 ml
<u>2</u>	2. 100 ml
<u>3</u>	3. Dry
<u>4</u>	4. 175 g silica gel


Tare	Initial	Final	Condensate	
	580.43 581.09 <u>484.11</u>	<u>649.38</u>	<u>68.45</u>	
	<u>637.25</u>	<u>663.88</u>	<u>26.63</u>	
	<u>500.77</u>	<u>504.39</u>	<u>3.62</u>	
	<u>731.79</u>	<u>739.71</u>	<u>7.92</u>	
		<u>10%</u>		TOTAL
				<u>106.62</u>

- () 7. Assemble ~~_____~~ filter holder.
- () 8. Assemble impinger bottles and glass elbows so air flows from a small hole to a larger hole.

ETL-5-1-4
SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT Thomas	BAROMETRIC PRESSURE, in Hg 29.780	METER BOX # 100448	PROBE # (PITOT #)	NOZZLE #
LOCATION CBC Bldg 373	AMBIENT TEMPERATURE, °F 59	METER Δ10	PITOT COEF 0.80	IDEAL NOZZLE DIA, in.
DATE 9/20/90	AVE STATIC PRESSURE, in H ₂ O	METER γ	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR JM	AVE VEL HEAD, in H ₂ O	SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PITOT'S OK @ 5 1/2"
RUN # GAS-100-1	ASSURED MOISTURE, %	HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM @ in Hg PRE OK 0.02 cfm



TRAVERSE POINT #	SAMPLING TIME	GAS METER READING (V _m) ft ³	VELOCITY		STACK TEMPERATURE		GAS SAMPLE TEMPERATURE		IMPINGER TEMPERATURE	SAMPLE BOX		SAMPLE VACUUM in Hg
			HEAD (NEAS) (ΔP) in H ₂ O	(TS) °F	(T _s) °F	(T _m in) °F	(T _m out) °F	(T _m in) °F		TEMPERATURE (°F)	TEMPERATURE (°F)	
1	9:34 am	58.037	0.12	548	64	64	64	59	59	254	254	5.0
2	3	59.972	0.11	545	64	64	64	48	48	253	253	
3	6	62.058	0.09	549	65	64	64	48	48	254	254	
4	9	64.137	0.07	549	67	65	65	49	49	255	255	
5	12	66.190	0.085	548	69	66	66	50	50	257	257	
6	15	68.743	0.13	549	71	66	66	52	52	258	258	
7	18	70.278	0.16	546	73	67	67	56	56	256	256	
8	21	72.303	0.18	548	74	68	68	57	57	259	259	
9	24	74.324	0.11	543	75	68	68	58	58	260	260	
10	27	76.364	0.115	546	77	69	69	56	56	259	259	
11	30	78.399	0.11	545	76	70	70	56	56	257	257	
12	33	80.432	0.085	542	76	70	70	56	56	258	258	
13	36	82.447	0.06	545	77	71	71	57	57	258	258	
TOTAL												
AVERAGE												

Test OK 0.11 cfm @ 7" Hg
PRE OK 0.02 cfm @ 12" Hg

2000

(SIS rev11/88, #0251Q)

PLANT *Thomas*

LOCATION

LOCATION
CBC Bldg 373
DATE

DATE _____

OPERATOR

RIN #

7/11/77
CAC-100-1

TRAVERSE

TRAVERSE	SAMPLING
POINT #	TIME

POINT #

min (V_m) ft³

 $(V_m)_{IT}$

14

51

16


TOTAL

AVERAGE

SOURCE EMISSION TESTING DATA SHEET

(SJS rev 11/88, #0251Q)

PLANT <i>Thomas</i>	BAROMETRIC PRESSURE, in Hg	METER BOX #	PROBE # (PILOT #)	NOZZLE #
LOCATION <i>CBC</i>	AMBIENT TEMPERATURE, °F	METER ΔH _Q	PILOT ODEF	IDEAL NOZZLE DIA, in.
DATE <i>9/20/90</i>	AVE STATIC PRESSURE, in H ₂ O	METER γ	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR <i>[Signature]</i>	AVE VEL HEAD, in H ₂ O	SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PILOT'S
RUN # <i>GAS-100-1</i>	ASSURED MOISTURE, %	HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM in Hg



SCHEMATIC OF STACK CROSS SECTION (SIDE TRAVERSE PTS)

POINT #	SAMPLING TIME	min	TEMPERATURE (Ts) °F	O ₂ %	CO ₂ %	CO ppm	NOX ppm
1		0	539	4.1	9.6	140	35
2		5	539	4.3	9.4	90	35
3		10	540	4.1	9.6	160	35
4		15	541	4.2	9.5	120	35
5		20	544	4.2	9.5	110	35
6		25	544	4.1	9.6	140	36
7		30	542	4.2	9.4	120	36
8		35	544	4.0	9.5	180	36
9		40	547	4.2	9.4	120	36
10		45	545	4.1	9.3	140	36
11		50	550	4.2	9.3	160	36
12		55	547	4.1	9.3	140	36
		60	547	4.3	9.1	80	36
				4.16	9.4	130	35.6
TOTAL							
AVERAGE							

9:57
GAS METER FINAL
786652

AVG

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #02510)		BAROMETRIC PRESSURE, in Hg		METER BOX #		PROBE # (PITOT #)		NOZZLE #	
PLANT <i>Thames</i>		AMBIENT TEMPERATURE, °F		METER ΔH _Q		PITOT COEF		IDEAL NOZZLE DIA, in.	
LOCATION <i>CRC</i>		AVE STATIC PRESSURE, in H ₂ O		METER γ		PROBE LENGTH, in.		ACTUAL NOZZLE DIA, in.	
DATE <i>2/20/90</i>		AVE VEL HEAD, in H ₂ O		SAMPLE BOX #		PROBE LIQUID MATERIAL		LEAK CHECK @ PITOT'S	
OPERATOR <i>[Signature]</i>		ASSUMED MOISTURE, %		HEATER BOX SETTING		PROBE HEATER SETTING		LEAK RATE CFY@ in Hg	
RUN # <i>GAS-100-2</i>		SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)		HEATER BOX SETTING		PROBE HEATER SETTING		LEAK RATE CFY@ in Hg	
POINT #		SAMPLING TIME		TEMPERATURE (Ts) °F		O ₂ %		CO ppm	
min		min		(Ts) °F		% %		ppm ppm	
1	0	1022 AM		542	4.0	9.4	160	36	
2	5			542	4.3	9.2	100	36	
3	10			545	3.9	9.4	180	36	
4	15			541	4.4	9.2	110	36	
5	20			542	4.2	9.2	120	36	
6	25			542	4.2	9.3	125	37	
7	30			542	4.3	9.2	180	36	
8	35			543	4.3	9.2	120	36	
9	40			542	4.3	9.2	140	37	
10	45			542	4.4	9.1	115	37	
11	50			542	4.3	9.2	125	37	
12	55			543	4.3	9.2	120	36	
	60			542	4.2	9.2	131.9	36.3	
TOTAL								4.2 9.3 131.3 35.9	
AVERAGE									

11:22 AM

GAS METER END
90427

AVG

AVG 1.52

PRETEST LEAK CHECK GOOD
NO FLOW AFTER 10 MIN VACUUM

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 9/20/90
CAL. BY: JMC

RUN NO: GAS-100 ANALYZER: NOX
BOILER NO: SPAN: 100
FUEL: NAT GAS UNITS: PPM
LOAD: 100% RESP TIME: 140" 70s ↑ 80s ↓

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	90.71	91	90.71	90.7	N/A
	MID	51.98	52	51.98	52.0	N/A
	ZERO	0.00	01	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	90.71 51.98	90 52	0	0.0	N/A
	ZERO	0.00	1	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	51.98	54	0	0.0	
	ZERO	0.00	1.5	0	0.0	
SYSTEM POST RUN 2	UPSCALE	90.71 51.98	94 54	0	0.0	
	ZERO	0.00	1.5 2 ppm	0	0.0	

	RUN 1	RUN 2
Co=	0.00	0.00 Avg zero gas system calibration bias.
Cm=	0.00	0.00 Avg upscale gas sys. cal. bias.
Cma=	51.98	51.98 Upscale gas concentration.
C=		Avg gas analyzer concentration reading.
Cgas=	ERR	ERR Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 0
CAL. BY: 0

RUN NO: GAS-100
BOILER NO: 0
FUEL: NAT GAS
LOAD: 100%

ANALYZER: 02
SPAN: 20.9
UNITS: %
RESP TIME: 20.5 sec

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	20.9	100.0	N/A
	MID	3.116	3.1	3.116	14.9	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.1	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC FORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 0
CAL. BY: 0

RUN NO: GAS-100
BOILER NO: 0
FUEL: NAT GAS
LOAD: 100%

ANALYZER: CO
SPAN: 500
UNITS: PPM
RESP TIME: 90S + 50S

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	499.7 500.5	500	499.7	99.9	N/A
	MID	248.1	250	248.1	49.6	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	248.10	255	0	0.0	0
	ZERO	0.00	5	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	248.10	255-260	0	0.0	0
	ZERO	0.00	10	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=			Avg gas analyzer concentration readings.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 60 CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 0
CAL. BY: 0

RUN NO: GAS-100 ANALYZER: CO2
BOILER NO: 0 SPAN: 20
FUEL: NAT GAS UNITS: %
LOAD: 100% RESP TIME: 100 s

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11.0	11.01	55.1	N/A
	ZERO	0.00	0.0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	10.9	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	10.6	0	0.0	0
	ZERO	0.00	-0.1	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	11.01	10.6	0	0.0	0
	ZERO	0.00	-0.1	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

Method 4

SAMPLE BOX SET UP CHECKLIST

DATE: _____

PLANT: Thomas

LOCATION: _____

PREP. BY: _____

RUN NO.: 014-25-1

STACK NO: _____

SAMPLE BOX NO.: _____

- () 1. Wash all glassware with distilled water and then acetone.
- () 2. Place approx. 100 ml distilled water in the first impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 3. Place approx. 100 ml distilled water in the second impinger, a standard Greenburg-Smith impinger (caricell tip). Record exact weight to 1/10 of a gram.
- () 4. Impinger three is a dry modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record dry tare weight to 1/10 of a gram.
- () 5. Place approx. 175 ml of silica gel in the fourth impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 6. PLACE ~~_____~~ FILTER INTO FILTER HOLDER ON THE CYCLONE SIDE OF THE HOLDER. Smooth side of filter is to face frittered glass of filter holder. ~~_____~~

Impinger No.	Impinger weights (GRAMS)	Tare	Initial	Final	Condensate	
<u>X-1</u>	1. 100 ml		587.11	641.64	54.50	
<u>X-2</u>	2. 100 ml		534.71	552.41	17.70	
<u>X-3</u>	3. Dry		477.77	476.42	3.65	
<u>X-4</u>	4. 175 g silica gel		644.88	710.69	10.81	
						TOTAL
						86.66

- () 7. Assemble ~~_____~~ filter holder.
- () 8. Assemble impinger bottles and glass elbows so air flows from a small hole to a larger hole.

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT **Thomas**

LOCATION **CBC 8164 373**

DATE **9/21/80**


OPERATOR **JR**

BAROMETRIC PRESSURE, in Hg **29.940**

AMBIENT TEMPERATURE, °F **73**

AVE STATIC PRESSURE, in H₂O

AVE VEL HEAD, in H₂O



ASSURED MOISTURE, %

TRAVERSE POINT #	SAMPLING TIME min	GAS METER READING (V _m) ft ³	VELOCITY HEAD (NEAS) (ΔP) in H ₂ O	STACK TEMPERATURE (T _s) °F	GAS SAMPLE TEMPERATURE		IMPINGER TEMPERATURE °F	SAMPLE BOX TEMPERATURE °F	SAMPLE VACUUM in Hg
					Inlet (T _m in) °F	Outlet (T _m out) °F			
1	1	247.844	0.0025	336	77	77	56	251	5
2	3	257.76	0.0028	357	77	77	54	249	5
3	3	255.717	0.003	356	76	74	51	252	5
4	9	258.789	0.003	358	79	75	53	253	5
5	12	261.773	0.004	356	81	75	53	253	5
6	12	264.751	0.004	356	83	76	55	253	5
7	4	267.708	0.004	356	84	76	56	255	5
8	27	270.182	0.0045	355	86	77	57	255	5
9	27	273.669	0.005	355	86	78	58	256	5
10	27	276.811	0.005	355	87	79	58	256	5
11	30	279.698	0.005	355	88	79	59	255	5
12	35	282.552	0.005	356	88	79	59	257	5
13	30	285.619	0.005	356	88	80	57	256	5
TOTAL									
AVERAGE									

Pos: **024 (in)**
 @ **7" Hg**
 Correct **1 in** via
 36 (024 - 02)
 = 0.144 in
 New **6 in**
 245 019-249 014-014
 = 35.651 93

PROBE # (PITOT #) **2500**

METER BOX #

METER ΔH₂O

METER °F

SAMPLE BOX #

PROBE HEATER SETTING

IDEAL NOZZLE DIA, in.

ACTUAL NOZZLE DIA, in.

LEAK CHECK @ PITOT'S

LEAK RATE CFM @ in Hg

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT *Thomas*

LOCATION *CBC*

DATE *21 SEPT 90*

OPERATOR *D. Cook*

RUN # *014-25-2*


BAROMETRIC PRESSURE, in Hg

AMBIENT TEMPERATURE, °F

AVE STATIC PRESSURE, in H₂O

AVE VEL HEAD, in H₂O

ASSUMED MOISTURE, %



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

METER BOX #

METER ΔH₀

METER γ

SAMPLE BOX #

HEATER BOX SETTING

PROBE # (PITOT #)

PITOT COEF

PROBE LENGTH, in.

PROBE LINER MATERIAL

PROBE HEATER SETTING

NOZZLE #

IDEAL NOZZLE DIA, in.

ACTUAL NOZZLE DIA, in.

LEAK CHECK @ PITOT'S

LEAK RATE CFM@ in Hg

POINT #

SAMPLING TIME

min

START TEST: 19:28

STACK TEMPERATURE

(T_s) °F

O₂ %

CO %

NOX ppm

TOTAL

AVERAGE

END TIME: 20:28

216

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE:
CAL. BY:

RUN NO: OIL-25
BOILER NO:
FUEL: OIL
LOAD: 25%

ANALYZER: NOX
SPAN: 250
UNITS: PPM
RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	203.7	203.7	203.7	81.5	N/A
	MID	131.1	130	131.1	52.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	131.10	127.5	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	131.10	125	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	131.10	125	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	131.10	131.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 0
 CAL. BY: 0

RUN NO: OIL-25
 BOILER NO: 0
 FUEL: OIL
 LOAD: 25%

ANALYZER: 02
 SPAN: 20.9
 UNITS: %
 RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	20.9	100.0	N/A
	MID	3.116	3.1	3.116	14.9	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.1	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1		20.9	20.9			
	UPSCALE	3.12	3.1	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0
SYSTEM POST RUN 2			20.8			
	UPSCALE	3.12	3.1	0	0.0	0
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = [Analyzer Cal. Response - Cyl. Value]
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = [Sys. Cal. Response - Analyzer Cal. Response]
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-25 ANALYZER: CO
 BUILDING: 373 THOMAS PLANT BOILER NO: 0 SPAN: 500
 DATE: 6 FUEL: OIL UNITS: PPM
 CAL. BY: 0 LOAD: 25% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	499.7	500	499.7	99.9	N/A
	MID	248.1	250	248.1	49.6	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST			490			
	UPSCALE	248.10	245	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1						
	UPSCALE	248.10	245	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2			490			
	UPSCALE	248.10	240	0	0.0	0
	ZERO	0.00	-5	0	0.0	0

RUN 1 RUN 2
 Co= 0.00 0.00 Avg zero gas system calibration bias.
 Cm= 0.00 0.00 Avg upscale gas sys. cal. bias.
 Cma= 248.10 248.10 Upscale gas concentration.
 C= Avg gas analyzer concentration reading.
 Cgas= EPR EPR Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cal. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-25 ANALYZER: CO2
 BUILDING: 373 THOMAS PLANT BOILER NO: 0 SPAN: 10
 DATE: 0 FUEL: OIL UNITS: %
 CAL. BY: 0 LOAD: 25% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST						
	HIGH			0	0.0	N/A
	MID	11.01	11	11.01	55.1	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST						
	UPSCALE	11.01	11	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1						
	UPSCALE	11.01	10.9	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0
SYSTEM POST RUN 2						
	UPSCALE	11.01	10.9	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

Method 4

SAMPLE BOX SET UP CHECKLIST

DATE: _____

PLANT: Thomas

RUN NO.: 01L 50-1

LOCATION: _____

STACK NO: _____

PREP. BY: _____

SAMPLE BOX NO.: _____

- () 1. Wash all glassware with distilled water and then acetone.
- () 2. Place approx. 100 ml distilled water in the first impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 3. Place approx. 100 ml distilled water in the second impinger, a standard Greenburg-Smith impinger (caricell tip). Record exact weight to 1/10 of a gram.
- () 4. Impinger three is a dry modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record dry tare weight to 1/10 of a gram.
- () 5. Place approx. 175 ml of silica gel in the fourth impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 6. PLACE ~~_____~~ FILTER INTO FILTER HOLDER ON THE CYCLONE SIDE OF THE HOLDER. Smooth side of filter is to face frittered glass of filter holder. ~~_____~~


Impinger No.	Impinger weights (GRAMS)	Tare	Initial	Final	Condensate	
<u>1</u>	1. 100 ml		677.44	39.26	6.18	
<u>2</u>	2. 100 ml		660.43	175.88	15.45	
<u>3</u>	3. Dry		506.18	488.41	17.77	
<u>4</u>	4. 175 g silica gel		756.06	767.28	11.22	
				157		
						TOTAL
						90.72

- () 7. Assemble ~~_____~~ filter holder.
- () 8. Assemble impinger bottles and glass elbows so air flows from a small hole to a larger hole.

ETHANOL - #1
SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #02510)

PLANT <i>Thomas</i>		BAROMETRIC PRESSURE, in Hg <i>29.94</i>		NOZZLE #	
LOCATION <i>CBC 8169 373</i>		AMBIENT TEMPERATURE, °F <i>76</i>		IDEAL NOZZLE DIA, in.	
DATE <i>9/21/90</i>		AVE STATIC PRESSURE, in H ₂ O		ACTUAL NOZZLE DIA, in.	
OPERATOR <i>SAL</i>		AVE VEL HEAD, in H ₂ O		LEAK CHECK @ PITOT'S	
RUN # <i>01L-50-1</i>		ASSUMED MOISTURE, %		LEAK RATE CFM @ in Hg	



Pre-OK 0.018 in
@ 6.5 in H₂O

Post-OK 0.018 in
@ 6.5 in H₂O

TRAVERSE POINT #	SAMPLING TIME	GAS METER READING (V _m) ft ³	VELOCITY HEAD (MEAS) in H ₂ O	STACK TEMPERATURE (T _s) °F	GAS SAMPLE TEMPERATURE AT DRY GAS METER		IMPINGER TEMPERATURE °F	SAMPLE TEMPERATURE °F	SAMPLE VACUUM in Hg
					Inlet (T _m in) °F	Outlet (T _m out) °F			
1	4:05 PM	216.548	0.01	384	78	78	65	250	4.0
2	3	219.993	0.015	385	79	78	56	246	4.5
3	6	222.198	0.015	384	81	78	55	244	
4	9	224.994	0.015	385	84	79	53	255	
5	12	227.813	0.015	385	87	80	53	259	
6	15	230.540	0.025	380	88	82	59	256	
7	18	233.296	0.030	385	89	81	60	257	
8	21	236.043	0.030	385	90	82	61	259	
9	24	238.788	0.01	385	91	82	62	257	
10	27	241.575	0.015	380	91	83	62	257	
11	30	244.216	0.02	384	92	83	63	255	
12	33	246.928	0.040	385	92	84	63	258	✓
13	36	249.652	0.040	386	92	85	64	251	
TOTAL									
AVERAGE									

static for

PLANT *Thomas*

[illegible]

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT <i>Thomson</i>	BAROMETRIC PRESSURE, in Hg			METER BOX #	PROBE # (PITOT #)	NOZZLE #
LOCATION <i>CPBC</i>	AMBIENT TEMPERATURE, °F			METER ΔH _Q	PITOT COEF	IDEAL NOZZLE DIA, in.
DATE <i>21 SEP 90</i>	AVE STATIC PRESSURE, in H ₂ O			METER γ	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR <i>ELC</i>	AVE VEL HEAD, in H ₂ O			SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PITOT'S
RUN # <i>01C-50-2</i>	ASSURED MOISTURE, %	SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)	HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM @ in Hg	

STACK TEMPERATURE (Ts) °F	O ₂			CO			NOX		
	%	%	ppm	%	ppm	ppm	%	ppm	ppm
384	4.5	12.5	95	95					
385	4.5	12.5	105	95					
386	4.6	12.5	80	95					
385	4.5	12.6	105	95					
384	4.5	12.5	90	95					
385	4.5	12.5	90	95					
386	4.6	12.4	90	95					
384	4.5	12.5	90	95					
383	4.6	12.4	90	95					
384	4.6	12.4	85	95					
384	4.6	12.4	90	95					
384	4.6	12.3	90	95					
384	4.6	12.4	86	95					
384	4.55	12.45	90.8	95					

START TIME: 16:25

STOP TIME: 17:25

TOTAL	
AVERAGE	

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-50 ANALYZER: NOX
 BUILDING: 373 THOMAS PLANT BOILER NO: SPAN: 150
 DATE: FUEL: OIL UNITS: PPM
 CAL. BY: LOAD: 50% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	203.7	207	203.7	81.5	N/A
	MID	131.1	132	131.1	52.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	131.10	130	0	0.0	N/A
	ZERO	0.00	1	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	131.10	130	0	0.0	0
	ZERO	0.00	2.5	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	131.10	130	0	0.0	0
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	131.10	131.10	upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = (Analyzer Cal. Response - Cyl. Value)
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = (Sys. Cal. Response - Analyzer Cal. Response)
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-50 ANALYZER: 02
 BUILDING: 373 THOMAS PLANT BOILER NO: 0 SPAN: 20.9
 DATE: 0 FUEL: OIL UNITS: %
 CAL. BY: 0 LOAD: 50% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	20.9	100.0	N/A
	MID	3.116	3.1	3.116	14.9	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	3.12	3.2	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	Post SPAN		20.9			
	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0

SYSTEM POST RUN 2			20.9			
	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME RUN NO: OIL-50 ANALYZER: GC
 BUILDING: 373 THOMAS PLANT BOILER NO: 0 SPAN: 500
 DATE: 0 FUEL: OIL UNITS: PPM
 CAL. BY: 0 LOAD: 50% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	499.7	500	499.7	99.9	N/A
	MID	248.1	255	248.1	49.6	N/A
	ZERO	0.00	5	0	0.0	N/A
SYSTEM PRETEST			500			
	UPSCALE	248.10	255	0	0.0	N/A
	ZERO	0.00	5	0	0.0	N/A
SYSTEM POST RUN 1						
	UPSCALE	248.10	255	0	0.0	0
	ZERO	0.00	10	0	0.0	0
SYSTEM POST RUN 2			500			
	UPSCALE	248.10	255	0	0.0	0
	ZERO	0.00	7	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = [Analyzer Cal. Response - I.I. Value]
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = [Sys. Cal. Response - Analyzer Cal. Response]
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - Co) * Cma / (Cm - Co)$

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME	RUN NO: OIL-50	ANALYZER: 002
BUILDING: 373 THOMAS PLANT	BOILER NO: 0	SPAN: 20
DATE: 0	FUEL: OIL	UNITS: %
CAL. BY: 0	LOAD: 50%	RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11.1	11.01	55.1	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST						
	UPSCALE	11.01	10.8	0	0.0	N/A
	ZERO	0.00	-0.1	0	0.0	N/A
SYSTEM POST RUN 1						
	UPSCALE	11.01	11.2	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0
SYSTEM POST RUN 2						
	UPSCALE	11.01	11.1	0	0.0	0
	ZERO	0.00	-0.1	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

Method 4

SAMPLE BOX SET UP CHECKLIST

DATE: _____

PLANT: Thomas

LOCATION: _____

PREP. BY: _____

RUN NO.: 012-75-1

STACK NO: _____

SAMPLE BOX NO.: _____

- () 1. Wash all glassware with distilled water and then acetone.
- () 2. Place approx. 100 ml distilled water in the first impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 3. Place approx. 100 ml distilled water in the second impinger, a standard Greenburg-Smith impinger (caricell tip). Record exact weight to 1/10 of a gram.
- () 4. Impinger three is a dry modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record dry tare weight to 1/10 of a gram.
- () 5. Place approx. 175 ml of silica gel in the fourth impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 6. PLACE ~~_____~~ FILTER INTO FILTER HOLDER ON THE CYCLONE SIDE OF THE HOLDER. Smooth side of filter is to face frittered glass of filter holder. ~~_____~~


Impinger No.	Impinger weights (GRAMS)	Tare	Initial	Final	Condensate	
<u>X-1</u>	1. 100 ml		<u>581.45</u>	<u>587.27</u>	<u>46.82</u>	
<u>X-2</u>	2. 100 ml		<u>520.90</u>	<u>534.00</u>	<u>33.10</u>	
<u>X-3</u>	3. Dry		<u>471.82</u>	<u>472.92</u>	<u>1.10</u>	
<u>X-4</u>	4. 175 g silica gel		<u>671.42</u>	<u>678.22</u>	<u>6.80</u>	
						TOTAL
						<u>89.16</u>

E.H. 804 7/24/75

- () 7. Assemble ~~_____~~ filter holder.
- () 8. Assemble impinger bottles and glass elbows so air flows from a small hole to a larger hole.

(SJS rev11/88, #02510)

PLANT	BAROMETRIC PRESSURE, in Hg		METER BOX #	PROBE # (PITOT #)	NOZZLE #
LOCATION	AMBIENT TEMPERATURE, °F		METER ΔIR	PITOT COEF	IDEAL NOZZLE DIA, in.
DATE	AVE STATIC PRESSURE, in H ₂ O		METER γ	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR	AVE VEL HEAD, in H ₂ O		SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PITOT'S
RUN #	ASSURED MOISTURE, %		HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM @ in Hg



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

POINT #	SAMPLING TIME	STACK TEMPERATURE (Ts) °F	O ₂			CO			NOX		
			%	ppm	ppm	%	ppm	ppm	%	ppm	ppm
1	0	436	4.4	12.5	15	92.5					
2	5	436	4.2	12.5	15	92.5					
3	10	436	4.4	12.4	12	92.5					
4	15	436	4.3	12.5	12	92.5					
5	20	435	4.2	12.4	15	92.5					
6	25	434	4.3	12.4	15	92.5					
7	30	435	4.5	12.5	15	92.5					
8	35	435	4.3	12.5	15	92.5					
9	40	435	4.3	12.5	15	92.5					
10	45	435	4.3	12.5	15	92.5					
11	50	435	4.5	12.3	15	92.5					
12	55	435	4.3	12.5	15	92.5					
	60	435	4.4	12.4	15	92.5					
			4.3	12.45	14.54	92.5					
TOTAL											
AVERAGE											

START 12:01 PM

STOP 13:01 PM

AVG

(SJS rev11/88, #02510)

PLANT <i>Lincoln</i>	BAROMETRIC PRESSURE, in Hg		METER BOX #	PROBE # (PILOT #)	NOZZLE #
LOCATION <i>SJC</i>	AMBIENT TEMPERATURE, °F		METER ΔHQ	PILOT COEF	IDEAL NOZZLE DIA, in.
DATE <i>21 SEP 86</i>	AVE STATIC PRESSURE, in H ₂ O		METER σ	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR <i>D. Cook</i>	AVE VEL HEAD, in H ₂ O		SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PILOT'S
RUN # <i>01C-75-2</i>	ASSURED MOISTURE, %		HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM@ in Hg

TRAVERSE		STACK	
POINT #	SAMPLING TIME	TEMPERATURE (Ts) °F	SECTION (S/D TRAVERSE PTS)
1	0	437	
2	5	437	
3	10	437	
4	15	434	
5	20	433	
6	25	431	
7	30	433	
8	35	434	
9	40	437	
10	45	437	
11	50	440	
12	55	436	
	60	437	
TOTAL			
AVERAGE			

START TIME 1317

STOP 1417

AVG

O ₂	CO ₂	CO	NOX
%	%	ppm	ppm
4.4	12.3	15	92.5
4.4	12.4	15	92.5
4.4	12.4	15	92.5
4.4	12.4	18	92.5
4.4	12.4	15	92.5
4.5	12.2	15	92.5
4.3	12.4	18	92.5
4.3	12.4	19	92.5
4.3	12.5	18	92.5
4.5	12.3	18	92.5
4.5	12.3	18	92.5
4.5	12.3	19	92.5
4.5	12.3	18	92.5
4.48	12.36	17	92.5

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE:
CAL. BY:

RUN NO: OIL-75
BOILER NO:
FUEL: OIL
LOAD: 75%

ANALYZER: NOX
SPAN: 250
UNITS: PPM
RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	203.7	203.7	203.7	81.5	N/A
	MID	131.1	131.1	131.1	52.4	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	131.10	127.5	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	131.10	131.1	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	131.10	127.5	0	0.0	0
	ZERO	0.00	0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	131.10	131.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 0
 CAL. BY: 0

RUN NO: OIL-75
 BOILER NO: 0
 FUEL: OIL
 LOAD: 75%

ANALYZER: 02
 SPAN: 20.9
 UNITS: %
 RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	ANALYZER CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	20.9	100.0	N/A
	MID	3.116	3.1	3.116	14.9	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.2	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = [Analyzer Cal. Response - Cyl. Value]
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = [Sys. Cal. Response - Analyzer Cal. Response]
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

$C_{gas} = (C - C_o) * C_{ma} / (C_m - C_o)$

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 0
 CAL. BY: 0

RUN NO: OIL-75
 BOILER NO: 0
 FUEL: OIL
 LOAD: 75%

ANALYZER: CO
 SPAN: 500
 UNITS: PPM
 RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	499.7	500	499.7	99.9	N/A
	MID	248.1	255	248.1	49.6	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	5	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	248.10	250	0	0.0	0
	ZERO	0.00	5	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = (Analyzer Cal. Response - Cyl. Value)
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = (Sys. Cal. Response - Analyzer Cal. Response)
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 0
CAL. BY: 0

RUN NO: OIL-75
BOILER NO: 0
FUEL: OIL
LOAD: 75%
ANALYZER: CO2
SPAN: 100
UNITS: %
RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11	11.01	55.1	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	10.9	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	10.8	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	11.01	10.8	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR		CSF Corrected gas concentration.

Analyzer Absolute Difference = [Analyzer Cal. Response - Cyl. Value]
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = [Sys. Cal. Response - Analyzer Cal. response]
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

Cgas = (C-Co)*Cma/(Cm-Co)

SAMPLE BOX SET UP CHECKLIST

RUN NO.: 014-100-1

STACK NO: _____

SAMPLE BOX NO.: _____

- () 1. Wash all glassware with distilled water and then acetone.
- () 2. Place approx. 100 ml distilled water in the first impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 3. Place approx. 100 ml distilled water in the second impinger, a standard Greenburg-Smith impinger (caricell tip). Record exact weight to 1/10 of a gram.
- () 4. Impinger three is a dry modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record dry tare weight to 1/10 of a gram.
- () 5. Place approx. 175 ml of silica gel in the fourth impinger, a modified Greenburg-Smith with straight tube 1/2 inch from the impinger bottom. Record exact weight to 1/10 of a gram.
- () 6. PLACE [REDACTED] FILTER INTO FILTER HOLDER ON THE CYCLONE SIDE OF THE HOLDER. Smooth side of filter is to face frittered glass of filter holder. [REDACTED]

Impinger No.	Impinger weights (GRAMS)	Tare	Initial	Final	Condensate
1	1. 100 ml		677.85	677.26	0.59
2	2. 100 ml		639.99	640.24	0.25
3	3. Dry		502.90	506.36	3.46
4	4. 175 g silica gel		746.61	754.27	7.66
					TOTAL
					80.78

457

- () 7. Assemble [REDACTED] filter holder.
- () 8. Assemble impinger bottles and glass elbows so air flows from a small hole to a larger hole.

(SJS rev11/88, #02510)


PLANT **Thomas**
LOCATION **CBC Bldg 373**
DATE **9/21/90**
OPERATOR **JM**

BAROMETRIC PRESSURE, in Hg
29.940
AMBIENT TEMPERATURE, °F
66
AVE STATIC PRESSURE, in H₂O
0.35
AVE VEL HEAD, in H₂O

ASSURED MOISTURE, %

RUN # **01L-100-1**

TRAVERSE POINT #	SAMPLING TIME	GAS METER READING	(V _m) ft ³
1	0	110.5	0
2	3	162.04	
3	6	162.30	
4	9	162.58	
5	12	170.30	
6	15	172.03	
7	18	172.00	
8	21	177.40	
9	24	179.40	
10	27	182.32	
11	30	184.78	
12	33	187.32	
13	36	190.00	
TOTAL			
AVERAGE			



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

VELOCITY HEAD (NEAS)	STACK TEMPERATURE (T _s) °F	GAS SAMPLE TEMPERATURE AT DRY GAS METER	IMPINGER TEMPERATURE	SAMPLE BOX TEMPERATURE	SAMPLE VACUUM
(AP) in H ₂ O	(T _s) °F	Inlet (T _m in) °F	Outlet (T _m out) °F	°F	in Hg
0.45	528	67	67	250	5"
0.85	528	68	67	250	5"
0.65	528	67	67	253	5"
0.55	528	71	67	250	5"
0.75	528	71	74	250	5"
1.1	526	76	69	250	5"
1.14	527	77	70	255	5"
1.55	528	78	70	259	5"
0.85	529	78	70	260	5"
0.45	529	80	72	260	5"
0.45	529	82	73	260	5"
0.75	532	82	73	256	5"
0.55	530	80	75	250	5"


NOZZLE #
PROBE # (PITOT #)
PITOT COEF
PROBE LENGTH, in.
PROBE LINER MATERIAL
PROBE HEATER SETTING
IDEAL NOZZLE DIA, in.
ACTUAL NOZZLE DIA, in.
LEAK CHECK @ PITOT'S
LEAK RATE CFM @ in Hg

Part: OK 0125
@ 11" Hg

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #0251Q)

PLANT <i>Thermal S</i>	BAROMETRIC PRESSURE, in Hg
LOCATION <i>CHE</i>	AMBIENT TEMPERATURE, °F
DATE <i>21 SEPT 90</i>	AVE STATIC PRESSURE, in H ₂ O
OPERATOR <i>D. Coak</i>	AVE VEL HEAD, in H ₂ O
RUN # <i>01C-100-1</i>	ASSURED MOISTURE, %



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

TRAVERSE POINT #	SAMPLING TIME min	STACK TEMPERATURE (Ts) °F	O ₂ %	CO ₂ %	CO ppm	NOX ppm
1	0	523	4.4	12.4	5	87.5
2	5	524	4.4	12.4	5	87.5
3	10	524	4.4	12.4	5	87.5
4	15	527	4.4	12.4	5	87.5
5	20	527	4.4	12.5	3	87.5
6	25	525	4.3	12.5	10	90
7	30	525	4.3	12.5	7	90
8	35	526	4.3	12.5	7	90
9	40	528	4.3	12.5	7	90
10	45	529	4.3	12.5	8	90
11	50	529	4.3	12.5	8	90
12	55	530	4.3	12.5	8	90
	60	530	4.3	12.4	10	90
			4.3	12.4	6.38	88.85
TOTAL						
AVERAGE						

START 854am


STOP 904am

ALG

SOURCE EMISSION TESTING DATA SHEET

(SJS rev11/88, #02510)

PLANT THOMAS	BAROMETRIC PRESSURE, in Hg	METER BOX #	PROBE # (PITOT #)	NOZZLE #
LOCATION CPC Pt Avenue	AMBIENT TEMPERATURE, °F	METER ΔH ₀	PITOT COEF	IDEAL NOZZLE DIA, in.
DATE 21 SEPT 1990	AVE STATIC PRESSURE, in H ₂ O	METER γ	PROBE LENGTH, in.	ACTUAL NOZZLE DIA, in.
OPERATOR D. G. Clark	AVE VEL HEAD, in H ₂ O	SAMPLE BOX #	PROBE LINER MATERIAL	LEAK CHECK @ PITOT'S
RUN # 010-100-2	ASSURED MOISTURE, %	HEATER BOX SETTING	PROBE HEATER SETTING	LEAK RATE CFM @ in Hg



SCHEMATIC OF STACK CROSS SECTION (SHOW TRAVERSE PTS)

POINT #	SAMPLING TIME min	STACK TEMPERATURE		O ₂ %	CO ₂ %	CO ppm	NOX ppm
		(Ts) °F					
1	0	529		4.4	12.7	8	92.5
2	5	529		4.3	12.7	9	92.5
3	10	529		4.3	12.5	10	92.5
4	15	520		4.4	12.4	12	92.5
5	20	530		4.4	12.5	12	92.5
6	25	529		4.4	12.6	12	92.5
7	30	529		4.4	12.5	15	92.5
8	35	528		4.4	12.5	15	92.5
9	40	529		4.4	12.5	15	92.5
10	45	520		4.5	12.4	15	92.5
11	50	520		4.5	12.5	15	92.5
12	55	520		4.5	12.4	15	92.5
	60	524		4.5	12.4	15	92.5
		!		4.4	12.5	12.9	92.5
TOTAL							
AVERAGE							

START TEST 10:13 AM

END TEST 11:13 AM

AVC-

GOOD LEAKCHECK

ANALYZER METHOD GC CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE:
CAL. BY:

RUN NO: OIL-100 ANALYZER: NOX
BOILER NO: SPAN: 250
FUEL: OIL UNITS: PPM
LOAD: 100% RESP TIME: 90

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	203.7	203.7 203.7	203.7	81.5	N/A
	MID	131.1	126.5 126.5	131.1	52.4	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM PRETEST	UPSCALE	131.10	126.5 127.5	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A

SYSTEM POST RUN 1	UPSCALE	131.10	130	0	0.0	0
	ZERO	0.00	2.5	0	0.0	0

SYSTEM POST RUN 2	UPSCALE	131.10	131.25	0	0.0	0
	ZERO	0.00	2.5	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	131.10	131.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
BUILDING: 373 THOMAS PLANT
DATE: 0
CAL. BY: 0

RUN NO: OIL-100 ANALYZER: 02
BOILER NO: 0 SPAN: 20.0
FUEL: OIL UNITS: %
LOAD: 100% RESP TIME:

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER CALIBRATION VALUE	RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	20.90	20.9	20.9	100.0	N/A
	MID	3.116	3.2	3.116	14.9	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	3.12	3.2	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	3.12	3.2	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	3.12	3.3	0	0.0	0
	ZERO	0.00	0.1	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	3.12	3.12	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = [Analyzer Cal. Response - Cyl. Value]
Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = [Sys. Cal. Response - Analyzer Cal. Response]
System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 0
 CAL. BY: 0

RUN NO: OIL-100
 BOILER NO: 0
 FUEL: OIL
 LOAD: 100%

ANALYZER: CO
 SPAN: 500
 UNITS: PPM
 RESP TIME: 30 SEC

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH	499.7	500	499.7	99.9	N/A
	MID	248.1	250	248.1	49.6	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	248.10	250	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	248.10	245	0	0.0	0
	ZERO	0.00	0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	248.10	255	0	0.0	0
	ZERO	0.00	5	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	248.10	248.10	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

ANALYZER METHOD 6C CALIBRATION SHEET

BASE: CBC PORT HUENEME
 BUILDING: 373 THOMAS PLANT
 DATE: 0
 CAL. BY: 0

RUN NO: OIL-100
 BOILER NO: 0
 FUEL: OIL
 LOAD: 100%

ANALYZER: CO2
 SPAN: 20
 UNITS: %
 RESP TIME: 150 SEC

SPAN GAS INPUT	SPAN GAS RANGE	CYLINDER VALUE	CALIBRATION RESPONSE	ABS. DIFF.	CAL. BIAS % OF SPAN	DRIFT % OF SPAN
ANALYZER PRETEST	HIGH			0	0.0	N/A
	MID	11.01	11.0	11.01	55.1	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM PRETEST	UPSCALE	11.01	10.8	0	0.0	N/A
	ZERO	0.00	0	0	0.0	N/A
SYSTEM POST RUN 1	UPSCALE	11.01	10.9	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0
SYSTEM POST RUN 2	UPSCALE	11.01	11.0	0	0.0	0
	ZERO	0.00	0.0	0	0.0	0

	RUN 1	RUN 2	
Co=	0.00	0.00	Avg zero gas system calibration bias.
Cm=	0.00	0.00	Avg upscale gas sys. cal. bias.
Cma=	11.01	11.01	Upscale gas concentration.
C=			Avg gas analyzer concentration reading.
Cgas=	ERR	ERR	Corrected gas concentration.

Analyzer Absolute Difference = |Analyzer Cal. Response - Cyl. Value|
 Analyzer Cal. Bias = Analyzer Absolute Difference / Span * 100

Sys. Absolute Difference = |Sys. Cal. Response - Analyzer Cal. Response|
 System Cal. Bias = System Absolute Difference / Span Range * 100

Drift = (Sys. Cal. Response - Pretest Sys. Cal. Response) / Span * 100

SIDE A

S-8

Run	ΔP_{SID}	ΔP	C_{PWS}	Deviation
1	$\emptyset.2$	$\emptyset.3\emptyset$		
2	$\emptyset.29\emptyset$	$\emptyset.45$		
3	$\emptyset.35\emptyset$	$\emptyset.54\emptyset$		
4	$\emptyset.39\emptyset$	$\emptyset.6\emptyset$		

SIDE B

Run	ΔP_{SID}	ΔP
1	$\emptyset.39$	$\emptyset.60$
2	$\emptyset.35$	$\emptyset.54$
3	$\emptyset.29$	$\emptyset.45$
4	$\emptyset.19$	$\emptyset.3\emptyset$

Plot tube Calibration

BRINGING
BOILER UP

MID SPAN

RESP 0.0215 min

RESP ↓ 40S

RESPONSE ~~40S~~ 70S ↑

AMB
AIR 0

HIGH SPAN

INCREASED
SPAN FLOW TO REQUIRED
CFH 97ppm

52 PPM MID SPAN

PRETEST
ANALYZER
SPAN

OZONE ON

137
SPAN
HI IN

97ppm

0-100 RANGE

7/20/90

0 - FULL SCALE

BACK
GROUND SUPPRESS
0-25 RANGE

705 AM 0

120m/hr

0-100 PPM
SCALE

FULL
SCALE

GAS
TESTS PRETEST CAL

100% LOAD

705am

5

4

3

2

1 1022 am
100% RUN 2
100-GAS-2

UPSCALE
548ppm

AMB AIR ZERO
21.5ppm

RUN 1
POST TEST SPAN

END RUN
GAS-100-1

12

11

10 O2 JUMPED
TO 1.9%
FOR 2 SEC (see screen)

9

8

7

6

5


4

3

2

1 857 am
100% RUN #1
GAS-100-1

PROBE
INSTEAD



-ZERO 115PPM

UPSCALE 53PPM
POST RUN 2
SPAN CHECK

END TEST 14:44
GAS-75-2

-12

-11

-10

-9

-8

-7

-6

-5

-4

-3

-2

① 1344pm
START GAS-75-2

UPSCALE 53PPM

-INB AIR ZERO 18PM

POST RUN 1
SPAN CHECK

1322pm
END 75-GAS-1

-12

-11

-10

-9

-8

① START GAS-50-2
1712

-51 ppm
UPSCALE

PPM

AMB AIR ZERO

POST RUN 1 SYSTEM SPAN CHECK

END GAS-50-1

12

11

10

9

8

7

6

5

4

3

2

① 1548 ppm START GAS-50-2

-90 ppm

DOUBLE CHECK HIGH SYSTEM SPAN


-ZERO SPAN 1 ppm



UPSCALE 52.1 ppm
SYSTEM SPAN

UPSCALE 52 ppm

HIGH 51 ppm
ADJ
UST

ANALYZER ADJ. & SPAN 50% RUN





10 9 8 7 6 5 4 3 2 1 0

STORCHT. 2147
AIR 1 ppm

52 ppm
VPSALE
GAS

CHART NO. 301
 127.5 ppm
 SYSTEM CHECK
 UPGRADE ANALYZER
 126

STOP TL TEST RECHECK ANALYZER SPAN HIGH 205 ppm

126 ppm UPGRADE

CONNECTED SYSTEM LINE RESID NOX

PRETEST ANALYZER SPAN 129 ppm MID RANGE

203 ppm
 ADJUST HIGH SPAN TO STILL

CHART SPEED 12 cm/hr
 SPIKE SWITCH TO 0-250 RANGE

FULL SCALE
 TECO

Ø TECO

OIL

-4

-3

-2

-1 START OIL-100-2 10.17 AM

Post run test 1
NO SPAN
130 ppm- END TEST 9:54 AM
OIL-100-1

-12

-11

-10

-9

-8

-7

-6

-5

-4

-3

-2

START 8:54 am
OIL-100-1

9/21/90

-9

8

-7

-6

-5

-4

-3

-2

-0 ppm ϕ SPAN

-1 START: OIL-75-1 12:01 PM
9/21/90

UPSCALE GAS

PRETEST SYSTEM SPAN CHECK

- MID 130 ppm

HIGH 205 ppm

- NOX 0 ppm
AMB AIR

BACK TO 0-250 RANGE

ADJ BACKGROUND

0-215V RANGE

PRETEST ANALYZER SPAN

SWITCH TO ANAL ZERO

2.5 ppm C

-131 ppm UPSCALE

POST RUN 2 SYSTEM SPAN

- END TEST OIL-100-2
11:13 9/21/90

-12

-11

-10

-9

-8

-7

-6

-5

OIL-4/7

UPSCALE

PRETEST SYSTEM SPAN
SPAN 0ppm

MID SPAN 132ppm

207ppm
HIGH SPAN

50% TEST ANALYZER SPAN (NO ADJUSTMENTS)

127.5
NOX SPAN UPSCALE

POST-TEST SYSTEM ~~SPAN~~ ZERO

NOX 0.0ppm

END OIL-75-2 14:17

12

11

10

9

8

7

6

5

4

3

12

ADJUST CHART
START GAS-75-2
13:17

UPSCALE
127.5ppm

0ppm SPAN

POST RUN 1 SYSTEM SPAN
CHECK
END 1301ppm
OIL-75-1

12

11

10

-9

-8

-7

-6

-5

-4

-3

-2

-1 START TEST: OIL-50-2 14:25

(SYSTEM)
- POST TEST 1 SPAN NOX
130.0

- POST TEST ZERO NOX
(SYSTEM)

- END TEST OIL-50-1 16:05

-12

-11

-10

-9

-8

-7

-6

-5

-4

-3

-2

-1 START OIL-50-1 15:05

9/21/90

0.5024N
1ppm

300ppm

POST RUN 1 ZERO SPAN
END TEST OIL-25-1

-12

-11

-10

-9

-8

-7

-6

-5

-4

-3

-2

START TEST: 18:11
OIL-25-1


SPAN AMB
OYFM

UPSCALE 127.5 ppm

PRETEST SYSTEM SPAN CHECK
MIC 30 ppm

205.1 ppm
HIGH
SPAN

PRETEST 25% ANALYZER SP



UPSCALE
127.5 ppm

SPAN
OYFM

POST RUN 2 SYSTEM SPAN
END OIL-50-2 1124

-12

-11

-10

STOP CHART 2040

UPSCALE
125PPMPPM SPAN
AND AIR

POST RUN 2 SYSTEM SPAN CHECK

END TEST OIL-25-2 20:28

9/21/90

-12

-11

-10

-9

-8

-7

-6

-5

-4

-3

-2

19:28

START TEST OIL-25-2

PPM SPAN
AND AIRPOST RUN 1
SYSTEM NO. SPAN
125PPM

(CUSTOMER)

25%

@ 5:44

23,134

@ 8:23

23,287

2:55 hr

3 hrs 16 min
0 hrs 43 min

50% oil

Beginning of run

End of run 2

36.7 gph

per Ed B
9/21/90
5:25pm

221 gal
153/60 hrs

22.89% @ 243

23,117 gal
@ 5:16

228.25 gph per Ed. 125 min
9/21/90 100% run

~~21907.5~~ @ 9:11
21907.5 gal

bottom of 7/8 mark

~~661/100~~

22383.0

~~661/100~~

@ 11:16 same mark

100%

22383.0
21908
475 gal
125/60 hrs

75% 22,435.0 → @ 11:33

APPENDIX D
OPERATION RECORDS FOR BOILER

CSC 11300/18 REV 9-89 (BACK)

[illegible]

BOILER PLANT RECORD										PLANT NAME		MAKE UP FEED WATER		WATER S/H		SALT BAGS ADDED		CONV TDS		AIR COMPRESSOR		TEMP OUTSIDE	
TIME	STEAM PRESS	STACK TEMP	GAS PRESS	IN	OUT	COND PUMPS	#1 DISCH PRESS	#2 DISCH PRESS	TANK TEMP	SOFTENER #1	GAL USED	SOFTENER #2	GAL USED	WATER S/H	SALT BAGS ADDED	CONV TDS	#1 COMP	#2 COMP	PHOS	TEMP OUTSIDE			
07:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
07:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
08:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
08:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
09:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
09:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
10:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
10:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
11:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
11:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
12:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
12:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
13:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
13:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
14:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
14:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
15:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
15:30	115.0	41.1	34	1/4	1/4	1/4	23.0	8	23.0	00C	00C	00C	00C	5	2035	105	62	105	62	105	62		
16:00	115.0	41.1	34	1/4	1/4	1/4	23.0	8															

BOILER PLANT RECORD

DATE: 11/20/18

TIME: 12:00

PLANT NAME: *Wmms*

MAKE UP FEED WATER: *WATER*

SOFTENER #1: *WATER*

SOFTENER #2: *WATER*

WATER BAGS ADDED: *3*

CONV. TOS: *2800*

AIR CONDENSATION: *11/2*

TEMP OUTSIDE: *70*

TIME	STEAM PRESS	CO2 SET	STACK TEMP	GAS PRESS	BURNER DATA			COND. PUMPS			FEED PUMPS			STATEMENT			WATER SH	SALT ADDED	CONV. TOS	AIR CONDENSATION	TEMP OUTSIDE
					IN	OUT	OUT	#1	#2	#1 DISCH	#2 DISCH	TANK	TANK	WATER	GAL. USED	WATER					
12:00	91	100	100	100	44	45	13	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:05	85	100	100	100	44	37	22	X	100	1	194	1	194	1	194	1	194	1	194	1	194
12:10	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:15	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:20	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:25	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:30	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:35	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:40	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:45	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:50	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
12:55	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:00	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:05	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:10	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:15	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:20	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:25	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:30	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:35	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:40	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:45	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:50	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
1:55	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:00	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:05	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:10	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:15	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:20	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:25	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:30	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:35	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:40	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:45	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:50	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
2:55	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:00	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:05	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:10	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:15	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:20	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:25	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:30	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:35	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:40	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:45	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:50	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
3:55	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:00	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:05	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:10	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:15	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:20	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:25	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:30	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:35	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:40	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:45	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:50	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
4:55	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
5:00	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
5:05	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
5:10	85	100	100	100	44	38	22	X	100	1	184	1	184	1	184	1	184	1	184	1	184
5:15	85	100																			

[illegible]

TIME	STEAM PRESS	CO ₂	STACK TEMP	BURNER DATA				COND PUMPS				FEED PUMPS				STATEMENT			
				GAS PRESS	OIL PRESS	OIL PRESS	OIL PRESS	#1 PRESS	#2 PRESS	#1 DISCH	#2 DISCH	TANK PRESS	TANK TEMP	WATER TEMP	WATER FLOW	SOFTENER #1	SOFTENER #2	WATER SOFTENING	WATER SOFTENING
0:00	116	5.7	75.7	134				11.2	2341			51	820						
0:05	116	5.7	75.7	134				11.2	2341			51	820						
0:10	116	5.7	75.7	134				11.2	2341			51	820						
0:15	116	5.7	75.7	134				11.2	2341			51	820						
0:20	116	5.7	75.7	134				11.2	2341			51	820						
0:25	116	5.7	75.7	134				11.2	2341			51	820						
0:30	116	5.7	75.7	134				11.2	2341			51	820						
0:35	116	5.7	75.7	134				11.2	2341			51	820						
0:40	116	5.7	75.7	134				11.2	2341			51	820						
0:45	116	5.7	75.7	134				11.2	2341			51	820						
0:50	116	5.7	75.7	134				11.2	2341			51	820						
0:55	116	5.7	75.7	134				11.2	2341			51	820						
1:00	116	5.7	75.7	134				11.2	2341			51	820						
1:05	116	5.7	75.7	134				11.2	2341			51	820						
1:10	116	5.7	75.7	134				11.2	2341			51	820						
1:15	116	5.7	75.7	134				11.2	2341			51	820						
1:20	116	5.7	75.7	134				11.2	2341			51	820						
1:25	116	5.7	75.7	134				11.2	2341			51	820						
1:30	116	5.7	75.7	134				11.2	2341			51	820						
1:35	116	5.7	75.7	134				11.2	2341			51	820						
1:40	116	5.7	75.7	134				11.2	2341			51	820						
1:45	116	5.7	75.7	134				11.2	2341			51	820						
1:50	116	5.7	75.7	134				11.2	2341			51	820						
1:55	116	5.7	75.7	134				11.2	2341			51	820						
2:00	116	5.7	75.7	134				11.2	2341			51	820						
2:05	116	5.7	75.7	134				11.2	2341			51	820						
2:10	116	5.7	75.7	134				11.2	2341			51	820						
2:15	116	5.7	75.7	134				11.2	2341			51	820						
2:20	116	5.7	75.7	134				11.2	2341			51	820						
2:25	116	5.7	75.7	134				11.2	2341			51	820						
2:30	116	5.7	75.7	134				11.2	2341			51	820						
2:35	116	5.7	75.7	134				11.2	2341			51	820						
2:40	116	5.7	75.7	134				11.2	2341			51	820						
2:45	116	5.7	75.7	134				11.2	2341			51	820						
2:50	116	5.7	75.7	134				11.2	2341			51	820						
2:55	116	5.7	75.7	134				11.2	2341			51	820						
3:00	116	5.7	75.7	134				11.2	2341			51	820						
3:05	116	5.7	75.7	134				11.2	2341			51	820						
3:10	116	5.7	75.7	134				11.2	2341			51	820						
3:15	116	5.7	75.7	134				11.2	2341			51	820						
3:20	116	5.7	75.7	134				11.2	2341			51	820						
3:25	116	5.7	75.7	134				11.2	2341			51	820						
3:30	116	5.7	75.7	134				11.2	2341			51	820						
3:35	116	5.7	75.7	134				11.2	2341			51	820						
3:40	116	5.7	75.7	134				11.2	2341			51	820						
3:45	116	5.7	75.7	134				11.2	2341			51	820						
3:50	116	5.7	75.7	134				11.2	2341			51	820						
3:55	116	5.7	75.7	134				11.2	2341			51	820						
4:00	116	5.7	75.7	134				11.2	2341			51	820						
4:05	116	5.7	75.7	134				11.2	2341			51	820						
4:10	116	5.7	75.7	134				11.2	2341			51	820						
4:15	116	5.7	75.7	134				11.2	2341			51	820						
4:20	116	5.7	75.7	134				11.2	2341			51	820						
4:25	116	5.7	75.7	134				11.2	2341			51	820						
4:30	116	5.7	75.7	134				11.2	2341			51	820						
4:35	116	5.7	75.7	134				11.2	2341			51	820						
4:40	116	5.7	75.7	134				11.2	2341			51	820						
4:45	116	5.7	75.7	134				11.2	2341			51	820						
4:50	116	5.7	75.7	134				11.2	2341			51	820						
4:55	116	5.7	75.7	134				11.2	2341			51	820						
5:00	116	5.7	75.7	134				11.2	2341			51	820						
5:05	116	5.7	75.7	134				11.2	2341			51	820						
5:10	116	5.7	75.7	134				11.2	2341			51	820						
5:15	116	5.7	75.7	134				11.2	2341			51	820						
5:20	116	5.7	75.7	134				11.2	2341			51	820						
5:25	116	5.7	75.7	134				11.2	2341			51	820						
5:30	116	5.7	75.7	134				11.2	2341			51	820						
5:35	116	5.7	75.7	134				11.2	2341			51	820						
5:40	116	5.7	75.7	134				11.2	2341			51	820						
5:45	116	5.7	75.7	134				11.2	2341			51	820						
5:50	116	5.7	75.7	134				11.2	2341			51	820						
5:55	116	5.7	75.7	134				11.2	2341			51	820						
6:00	116	5.7	75.7	134				11.2	2341			51	820						

FUEL OIL RECEIVED										FUEL OIL SOUNDINGS			
BOILER STEAMING HOURS		TIME		SOUNDINGS		GALLONS RECEIVED		STATEMENT					
BOILER NO	HOURS TODAY	HOURS SERVICE OVERALL	LOADS	BEFORE	AFTER			#1 TANK		#2 TANK			
								TIME	SOUNDING	GALLONS	GALLONS		
1													
2													
3													
FUEL OIL METER		FUEL OIL SUCTON			PLANT STEAM FLOW		CONV. STEAM FLOW		NATURAL GAS CONV.				
INTEG.	GALLONS USED	PUMP #1 PRESS	PUMP #2 PRESS	PUMP #3 PRESS	INTEG.	TOTAL PDS. PER HOUR	INTEG.	TOTAL PDS. PER HOUR	INTEG.	TOTAL CUBIC FOOT			
					12945100	06373900		8244440					
					13111200	114.0	06378900	56.0	8247670	323.0			
					13217600	1064.0	66383100	42.0	8250590	292.0			
					13331300	1137.0	66387400	43.0	8253450	286.0			
					13444300	130.0	06391400	40.0	8256290	284.0			
					13556900	1126.0	06393800	36.0	8259070	288.0			
					13671700	1148.0	06399400	44.0	8261940	287.0			
					13786500	1148.0	06404700	53.0	8264910	297.0			
					13906400	1199.0	06410600	59.0	8269120	421.0			
					9113.00			36.900		24650			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #		TOTAL GAS PRODUCED		BOILER EFF. %		TOTAL GAS STEAM LIMITED		TOTAL GAS STEAM PRODUCED			
TOTAL GAS USED		BOILER #											

BOILER PLANT RECORD

PLANT NAME

Thomas

MAKE UP FEED WATER

WATER

SALT

CONV

TDS

TEMP

COND

TIME	STEAM PRESS	TEMP	GAS PRESS	BURNER DATA			COND. PUMPS			FUEL PUMPS			MAKE UP FEED WATER				WATER SH	SALT BAGS ADDED	CONV TONS	AIR C. TEMP. °F	TEMP. °F/100°
				OIL PRESS	OIL IN	OIL OUT	#1 PRESS	#2 PRESS	#1 DISCH PRESS	#2 DISCH PRESS	TANK PRESS	TANK TEMP.	SOFTEN R #1	GAL. USED	SOFTEN R #2	GAL. USED					
1200	3.5	350	1.5				X	12/30	18.3		2	172	0.55C				5	4	2600	165	75
1210	3.5	350	1.5				X	12/30	22.9		2	138					5	—	—	165	92
1220	3.5	350	1.5				X	12/30	27.9		2	104					5	81.50	—	165	90
1230	3.5	350	1.5				X	12/30	23.0		2	156					5	—	—	165	82
1240	3.5	350	1.5				X	12/30	23.4		2	170					5	—	—	165	86
1250	3.5	350	1.5				X	12/30	23.0		2	174					5	3500	—	165	85
1300	3.5	350	1.5				X	12/30	23.0		2	186					5	—	—	165	79
TOTAL																					

BURNER STEAMING HOURS

FUEL OIL RECEIVED

FUEL OIL SOURDINGS

BOILER NO	INQUIRY TYPE #	DATE - TIME OF CALL	TIME	TOWNS	SOUNDINGS		GALLONS RECEIVED	STATEMENT	ATTANK				#2 TANK							
					BEFORE	AFTER			DATE/TIME	LOCATION	DATE/TIME	LOCATION								
1	Car																			
2																				
3	/																			

FUEL OIL WATER	GALLONS USED	FUEL OIL SECTION	PLANT STEAM FLOW	CONV STEAM FLOW	NATURAL GAS CONV.	TOTAL CUBIC FOOT
1	1390.24		115.900	0.64	826.712	14140
2	1402.22		115.900	0.64	826.712	14140
3	1411.70		115.900	0.64	826.712	14140
	1423.22		115.900	0.64	826.712	14140
	1433.94		115.900	0.64	826.712	14140
	1445.50		115.900	0.64	826.712	14140
	1456.52		115.900	0.64	826.712	14140
	1468.57		115.900	0.64	826.712	14140
	1479.83		115.900	0.64	826.712	14140
TOTAL	107,800		107,800	107,800	107,800	107,800

STEAM PRODUCTION	BOILER #	STEAM PRESS	STACK TEMP	GAS PRESS	IN	OUT	COND. PUMPS	#1 PRESS	#2 PRESS	#1 DISCH PRESS	#2 DISCH PRESS	TANK PRESS	TANK TEMP	SOFTEN R #1	GAL USED	SOFTEN R #2	GAL USED	WATER SH	SALT BAGS ADDED	CONV TDS	TEMP	COND
1	107,800																					
2	107,800																					
3	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
TOTAL	107,800																					

STEAM PRODUCTION	BOILER #	STEAM PRESS	STACK TEMP	GAS PRESS	IN	OUT	COND. PUMPS	#1 PRESS	#2 PRESS	#1 DISCH PRESS	#2 DISCH PRESS	TANK PRESS	TANK TEMP	SOFTEN R #1	GAL USED	SOFTEN R #2	GAL USED	WATER SH	SALT BAGS ADDED	CONV TDS	TEMP	COND
1	107,800																					
2	107,800																					
3	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
TOTAL	107,800																					

STEAM PRODUCTION	BOILER #	STEAM PRESS	STACK TEMP	GAS PRESS	IN	OUT	COND. PUMPS	#1 PRESS	#2 PRESS	#1 DISCH PRESS	#2 DISCH PRESS	TANK PRESS	TANK TEMP	SOFTEN R #1	GAL USED	SOFTEN R #2	GAL USED	WATER SH	SALT BAGS ADDED	CONV TDS	TEMP	COND
1	107,800																					
2	107,800																					
3	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
	107,800																					
TOTAL	107,800																					

07.30 Releive
Seance

Notes: Add 20

DATE: 11/30/18

BY: [Signature]

BOILER PLANT RECORD

PLANT NAME *Thomas Plant*

DATE *9 24 90*

1530 *Adam on 1*

TIME	STEAM PRESS	STACK TEMP.	BURNER DATA				COND. PUMPS				FEED PUMPS				SOFTENR #1		SOFTENR #2		WATER S/H	SALT BAGS ADDED	CONV TDS.	COOR.		PRESS	TEMP OUTSIDE
			GAS PRESS	IN	OUT	MOZZ	#1	#2	INPUT	#1 DISCH PRESS	#2 DISCH PRESS	TANK PRESS	TANK TEMP.	GAL. USED	GAL. USED	GAL. USED	GAL. USED	+1				+2			
1530	34	54	68	44	17	1	11.5	230		0	170							5	3900	✓			120	71°	
1600	34	54	68	44	17	✓	0	234		5	140							5	3500	✓			120	70°	
1630	34	54	68	44	17	✓	11.5	228		0	210							5	3500	✓			120	68°	
1700	34	54	68	44	17	✓	0	232		5	214							5	3500	✓			120	67°	
1730	34	54	68	44	17	✓	0	232		5	214							5	3500	✓			120	66°	
1800	34	54	68	44	17	✓	12	230		5	218							5	3520	✓			120	66°	
1830	34	54	68	44	17	✓	12	231		5	220							5	3150	✓			120	66°	
1900	34	54	68	44	17	✓	12	231		5	220							5	2350	✓			120	65°	
TOTAL																									

[illegible]

APPENDIX E

CORRESPONDENCE REGARDING
EMISSION LIMITS FOR BOILER

RESOURCE MANAGEMENT AGENCY
county of ventura

Air Pollution
Control District

Richard H. Baldwin
Air Pollution Control Officer

July 26, 1990

B. Herrington, Director, Planning/Environmental Division
U.S. Naval Construction Battalion Center
Code 80, Public Works, Bldg 850
Port Hueneme, CA 93043-5000

RE: Application for Permit
to Operate #1012-101

Dear Mr. Herrington:

Your application for the referenced Ventura County Air Pollution Control District (APCD) Permit to Operate for a Cleaver Brooks Steam Boiler located at the Thomas Plant is incomplete. In order to make your application complete, you must provide the stack test report required by Condition #F.1. on the Authority to Construct for this project, dated July 29, 1987. Also note that this boiler is now subject to additional requirements, see District Rule 74.15. Please review this rule, note the carbon monoxide limits, the required test methods, new reporting requirements, and the bi-annual testing needs. Testing shall demonstrate compliance with the Authority to Construct conditions and District Rule 74.15. In case of conflict, the more stringent requirement shall apply. Two one hour tests shall be performed at 25, 50, 75, and 100% of rated load, or as close to these values as possible. If the test results vary widely, a third test will be required. The 180 day period, within which the approval or disapproval of your application is required by District Rule 25, will not begin until the test report is received.

Submit the test report by September 28, 1990. If additional time is required or you wish to schedule a mutually acceptable source test date, please contact the Bill Flynn at (805)654-2664.


A temporary permit to operate for the subject boiler is enclosed. This temporary operating permit is considered valid until such time as the Permit to Operate is issued or the application is denied. This temporary operating permit is issued based on the statement on the Permit to Operate application that all attachments previously submitted with the Authority to Construct application are valid and no changes have been made. Specifically, the steam boiler may only be operated if equipped with a low NOx burner, a flue gas recirculation system, and oxygen trim, or equivalent emission control methods. Please post this permit in accordance with District Rule 19.

Failure to submit complete or adequate information, within a reasonable period of time, may be grounds for the disapproval of



your application. If disapproval occurs, your temporary permit to operate would be rescinded and your project would then be considered only upon resubmittal of the application package, accompanied by the required test report and the appropriate fees (see District Regulation III).

Sincerely,

A handwritten signature in cursive script, appearing to read "Karl E. Krause", written over a horizontal line.

Karl E. Krause, Manager
Engineering Section

RESOURCE MANAGEMENT AGENCY
county of ventura

Air Pollution
Control District

Richard H. Baldwin
Air Pollution Control Officer

August 27, 1990

L.A. Sollenberger, Commander, Civil Engineers Corps
U.S. Navy
Public Works Officer
Naval Construction Battalion Center
Attention: J. Reichle, P.E., NEESA-111C1
Port Hueneme, CA 93043-5000


RE: P/O 1012-101

Dear Mr. Reichle;

As requested in your letter dated August 14, 1990, I have reviewed your test protocol for the Cleaver-Brooks Boiler located in Building 373 Steam Plant. The test plans, modified with the changes we discussed by telephone on August 27, 1990, are acceptable. The most important changes being the need to measure fuel flow during the tests and to use calibration gases that are close to the actual measured concentrations as required by test method CARB 1-100.

If you have further questions or wish to schedule mutually acceptable source test date(s) please call me at (805)654-2664.

Sincerely,


W.J. Flynn
Engineering Section



5090/88blh
September 13, 1990

Resource Management Agency
Air Pollution Control District
Attn: Mr. Allen Danzig
800 South Victoria Avenue
Ventura, CA, 93009

Dear Mr. Danzig

Confirming this morning's phone conversations with you and Bill Flynn, it is the understanding of our staff, that with respect to acceptance testing of our new boiler, APCD Rule 74.15 is the standard that the boiler manufacturer must meet. This standard provides that NOx emissions shall not exceed 40ppm and CO emissions shall not exceed 400ppm.

We currently anticipate acceptance of the boiler on the basis of achieving or exceeding the 40/400 criteria, by the end of this week. Source testing will then be performed at various load levels, in accordance with Authority to Construct #1012-1 and the transmittal letter, dated July 26 1990, for Permit to Operate #1012-101. This Source Testing, will be performed during the week of 17 September, possibly extending into the week of 24 September. Mr. Flynn will be kept apprised by phone, of testing progress so that he may attend any of the test sessions he wishes to observe.

Point of contact for further information is LT Cris Long, phone 982-3740

Sincerely,

L. A. SOLLENBERGER
Commander, Civil Engineer Corps
U. S. Navy
Public Works Officer
By direction of the Commanding Officer

Copy to: NEESA Code 111C

APPENDIX F

RESUMES OF EMISSION TEST PERSONNEL

RESUME

DREK A. NEWTON

Mechanical Engineer

1984

B.S. Mechanical Engineering
Cal Poly State University San Luis Obispo, CA

1984-1986

Research and Development Engineer
VETCO Offshore, Inc. Ventura, CA

1987-Present

Mechanical Engineer
Coal/Air Department
Naval Energy and Environmental Support Activity
Port Hueneme, CA

RESUME

JIM REICHLE, P.E.	Mechanical Engineer
1982	B.S. Mechanical Engineering University of Portland Portland, OR
1982-1983	Mechanical Engineer FPH Forest Grove, OR
1983-1985	Mechanical Engineer Fläkt Evaporator AB Jönköping, Sweden
1985-Present	Mechanical Engineer Naval Energy and Environmental Support Activity Port Hueneme, CA

RESUME

DAVID COOK

Environmental Engineer

1990

B.S. Environmental Engineering
Cal Poly State University San Luis Obispo, CA

1990-Present

Environmental Engineer
Coal/Air Department
Naval Energy and Environmental Support Activity
Port Hueneme, CA

RESUME

KEATON JEFFREY MCCALLISTER

Mechanical Engineer

1987

B.S. Mechanical Engineering
Kansas State University
Manhattan, Kansas

1988 to Present

Mechanical Engineer, PDC
Naval Facilities Engineering
Command on assignment to:
Coal/Air Department
Naval Energy and Environmental
Support Activity
from:
Mobile Utilities Support Equipment
Engineering Office
Naval Energy and Environmental
Support Activity
Port Hueneme, California