

GENESIS

ENVIRONMENTAL SERVICES COMPANY

KCAPCD

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

CHEVRON U.S.A. INC.
P.O. BOX 1392
BAKERSFIELD, CALIFORNIA 93302

Rec 7/25/91
NPH

CHEVRON U.S.A.
SECTION 26C STEAM PLANT
STEAM GENERATOR # 50-6 and 50-7

INITIAL COMPLIANCE TEST
JUNE 11, 1991

PREPARED BY:
GENESIS ENVIRONMENTAL SERVICES COMPANY
1145 WEST COLUMBUS AVENUE
BAKERSFIELD, CALIFORNIA 93301

KCAPCD PERMIT #'s 4008175 AND 4008176
REPORT #7777-0268

RECEIVED
JUL 25 1991

TEST CONDUCTED BY KEVIN ORTON
RESULTS VERIFIED BY MICHAEL L. BAKALOR
OPERATIONS MANAGER

KERN COUNTY AIR
POLLUTION CONTROL DISTRICT

SUMMARY OF SOURCE TEST RESULTS

Company: Chevron U.S.A.
Test Date: 6-11-91

APCD No. 4008176
Unit No. # 50-7

EMISSIONS

POLLUTANT	Concentration		PPMv	@3% O2	lb/hr	lb/MMBTU
	gr/scf	@12%				
Particulate						
Sulfate						
Sulfur						
NOx as NO2 (dry)			35.6	32.9	2.04	0.0416 lb/MMBTU
			37.5	34.8	2.15	
			37.9	35.1	2.17	
			37.0	34.3	2.12	
HC (as methane)			N/D		N/D	
			N/D		N/D	
			N/D		N/D	
			N/D*		N/D*	
CO*			5.2		0.18	
			2.5		0.09	
			5.2		0.01	
			4.3		0.09	

INITIAL 210.1, 424, 425, GAS F 62.5 W FGR

Comments: HC reported as non-detected.

NAH 8/9/91

SUMMARY OF SOURCE TEST RESULTS

Company: Chevron U.S.A.
Test Date: 6-11-91

APCD No. 4008175
Unit No. # 50-6

EMISSIONS

POLLUTANT	Concentration		PPMv	@3% O2	1b/hr	1b/MMBTU
	gr/scf	@12%				
Particulate						
Sulfate						
Sulfur						
NOx as NO2 (dry)			38.5	35.9	2.15	0.0435 1b/MMBTU
			37.9	35.3	2.12	
			39.0	36.3	2.18	
			38.4	35.8	2.15	
HC (as methane)			N/D		N/D	
			N/D		N/D	
			N/D		N/D	
			N/D*		N/D*	
CO*			0.1		0.00	
			2.7		0.09	
			0.1		0.07	
			1.0		0.05	

INITIAL 210.1, 424, 425.1 - GAS F62.5 W FGR

Comments: HC reported as non-detected.

RAN. 8/9/91

TABLE OF CONTENTS

		Page
Section 1.0	- Introduction	1
Section 2.0	- Continuous Emission Monitoring	3

APPENDIX

A-1	Fuel Analysis
A-2	Hydrocarbon Analysis
A-3	Raw Data
A-4	Calibrations and Certifications

INTRODUCTION

At the request of Mr. Stephen Miller of Chevron U.S.A. Inc., Genesis Environmental Services Company conducted an Initial Compliance Test on Steam Generator's #50-7 and #50-6, located at Chevron's 26C Steam Plant.

Steam Generator's # 50-7 and # 50-6 are manufactured by Struthers and are rated at 62.5 MMBTU/hr.

The purpose of these tests is to comply with Kern County Air Pollution Control District rules as required in KCAPCD Permit #'s 4008176 and 4008175.

The 1991 Initial Compliance Tests were conducted on June 11, 1991 by Mr. Kevin Orton of Genesis Environmental. Chevron representative, Mr. Stephen Miller was present during the tests.

Table 1-1 contains a summary of test results. Figure 1-1 contains the calculations used to determine the results. The following is a summary of tests performed on Steam Generator #'s 50-7 and 50-6.

Test Summary
Steam Generator #'s 50-7 and 50-6
June 11, 1991

<u>CONSTITUENT</u>	<u>METHOD</u>	<u>QUANTITY</u>
NOx	CARB 1-100 FOR NOx (TECO MODEL 10AR)	TRIPLICATE
CO	CARB 1-100 FOR CO (TECO MODEL 48)	TRIPLICATE
O ₂	CARB 1-100 FOR O ₂ (TELEDYNE MODEL 326RA)	TRIPLICATE
HYDROCARBON	EPA METHOD 18 (GAS CHROMATOGRAPH)	TRIPLICATE

As per KCAPCD requirements, a total of three forty minute tests were performed with an initial calibration at the start of run #1. A post calibration was performed after each 40 minutes of continuous measurement.

Figure 1-1

Calculation of Results

$$1. \quad Fd_{68} = \frac{[10^6 (3.64\%H + 1.53\%C + 0.57\%S + 0.14\%N - 0.46\%O)]}{GCV}$$

$$Fd_{60} = \frac{520}{528} Fd_{68} \quad \text{Note: } Fd_{68} \text{ for EPA}$$

$$Fd_{60} \text{ for KCAPCD}$$

$$2. \quad SDCFM = \left[\frac{(Fd) (GCV) (FR)}{1440} \right] \left[\frac{(20.9)}{(20.9 - O_2\%)} \right]$$

Where: GCV - 10₆ BTU/cu.ft.
FR - Fuel Rate (cu.ft./day)

$$3. \quad \text{Corrected to } 3\% O_2$$

$$\text{ppm @ } 3\% O_2 = \text{ppm} \left[\frac{(17.9)}{(20.9 - O_2\%)} \right]$$

$$4. \quad C_s = (\text{ppm}) (X)$$

Where: C_s = pollutant concentration (lbs/scf)

	<u>EPA</u>	<u>KCAPCD</u>
X = NOx	1.194x10 ⁻⁷	1.212x10 ⁻⁷
X = CO	7.268x10 ⁻⁸	7.378x10 ⁻⁸
X = HC	4.153x10 ⁻⁸	4.216x10 ⁻⁸

$$5. \quad E = (C_s) (Fd) \left[\frac{(20.9)}{(20.9 - O_2\%)} \right]$$

Where: E = emission rate (lbs/MMBTU)

$$6. \quad E = (C_s) (SDCFM) (60)$$

Where: E = emission rate (lbs/hr)

Section 2.0
Continuous Emission Monitoring

SECTION 2.0

CONTINUOUS EMISSION MONITORING: NO_x, CO & O₂

The analyzers utilized in the Genesis continuous monitor test trailer are presented in Table 2-2. Figure 2-1 is a schematic of the continuous monitoring systems. The protocol used to continuously monitor stack gases for NO_x, Oxygen and CO follow CARB Method 100 recommendations.

Stack gas is extracted from the stack using a 316 stainless steel probe. A stainless steel sintered filter (99 percent efficiency @ 0.6 micron particles) is attached to the inlet of the probe. From the sample probe, sample gas is transported through a heated Teflon sample line by a Teflon-lined diaphragm pump to a series of Greenburg-Smith knock-out impingers and condenser system. The clean, dry sample gas is then transported to the continuous analyzer system through a Teflon line. Prior to the analyzers another filter (Balston glass fiber filter, efficiency of 99% @ 0.3 microns) is installed. A series of flowmeters, valves, and a bypass regulator maintain constant flow through the system at a constant pressure.

At the onset of each test series, a leak-check is performed on the continuous monitor sampling system. The sample probe is removed from the stack and the inlet is sealed. A leak free system is verified when flow through rotameters to the individual analyzers all drop to zero. A mandatory leak-check is performed at the completion of each test series.

Analyzer calibrations are performed at the start of the test run by introducing zero and span gases for each analyzer and making the necessary adjustments. EPA Protocol 1 certified calibration gas values are recorded on the strip chart and field data sheet. A calibration check is also performed at the end of each one hour test run and recorded on the strip chart. If adjustments are necessary to the analyzers they are made after documentation has been made of any zero or calibration drift. At the conclusion of the test series, a system calibration (bias check) is performed of the sample system. This is accomplished by first removing the sample probe from the stack and allowing ambient air to purge the system. After the system has been purged to verify a zero reading, a system gas which has been named against the standard EPA protocol gas is introduced at the sample nozzle. System pressure and vacuum are maintained as in normal operation during this procedure. The system gas is then allowed to flow through the sample conditioning system to the analyzers. Once a stable reading has been achieved, it is recorded and used to calculate the system efficiency which has a tolerance of 5% of the system gas introduced.

Data is recorded in 10 minute averages for each sixty minute test run. Table 2-1 gives a summary of 10 minute averages and calculated emission factors.

TABLE 1-1

Continuous Monitor Data Summary
 Chevron, 26C Steam Plant
 June 11, 1991
 SG# 50-7

Time	% O2	CO ppm	NOx ppm	SDCFM	CO Lbs/hr	NOx Lbs/hr	NOx lb/MMBTU
1	1.55	5.23	35.6	7879	0.18	2.04	0.0399
2	1.62	2.50	37.5	7879	0.09	2.15	0.0422
3	1.59	0.20	37.9	7879	0.01	2.17	0.0426
AVG.	1.59	2.64	37.0	7879	0.09	2.12	0.0416

Continuous Monitor Data Summary
 Chevron, 26C Steam Plant
 June 11, 1991
 SG# 50-6

Time	% O2	CO ppm	NOx ppm	SDCFM	CO Lbs/hr	NOx Lbs/hr	NOx lb/MMBTU
1	1.72	0.10	38.5	7691	0.00	2.15	0.0435
2	1.71	2.65	37.9	7691	0.09	2.12	0.0429
3	1.71	2.08	39.0	7691	0.07	2.18	0.0441
AVG.	1.71	1.61	38.4	7691	0.05	2.15	0.0435

TABLE 2-1a

Continuous Monitor Data Summary
 Ten Minute Averages
 Test # 1
 SG# 50-7

Time	% O2	CO ppm	NOx ppm	SDCFM	CO Lbs/hr	NOx Lbs/hr
1055	1.62	7.0	34.5	7879	0.24	1.98
1105	1.55	5.5	35.7	7879	0.19	2.05
1115	1.53	4.5	35.7	7879	0.16	2.05
1125	1.49	3.9	36.4	7879	0.14	2.09
AVG.	1.55	5.2	35.6	7879	0.18	2.04

Calibration Data

	% O2	CO ppm	NOxppm
ZERO	0.00	0.0	-1.0
Span	3.80	18.5	74.7
Gas Value	4.00	18.0	76.0
Zero Factor	0	0	0
Span Factor	0	0	0

TABLE 2-1b

Continuous Monitor Data Summary
 Ten Minute Averages
 Test # 2
 SG# 50-7

Time	% O2	CO ppm	NOx ppm	SDCFM	CO Lbs/hr	NOx Lbs/hr
1141	1.63	3.0	37.5	7879	0.10	2.15
1151	1.63	2.8	37.6	7879	0.10	2.15
1201	1.58	2.4	37.0	7879	0.08	2.12
1211	1.63	1.8	37.8	7879	0.06	2.17
AVG.	1.62	2.5	37.5	7879	0.09	2.15

Calibration Data

	% O2	CO ppm	NOxppm
ZERO	0.00	0.0	-0.5
Span	4.00	18.5	77.3
Gas Value	4.00	18.0	76.0
Zero Factor	0	0	0
Span Factor	0	0	0

TABLE 2-1c

Continuous Monitor Data Summary
 Ten Minute Averages
 Test # 3
 SG# 50-7

Time	% O2	CO ppm	NOx ppm	SDCFM	CO Lbs/hr	NOx Lbs/hr
1240	1.58	0.2	37.7	7879	0.01	2.16
1250	1.60	0.2	37.9	7879	0.01	2.17
1300	1.58	0.2	38.0	7879	0.01	2.18
1310	1.60	0.2	37.8	7879	0.01	2.17
AVG.	1.59	0.2	37.9	7879	0.01	2.17

Calibration Data

	% O2	CO ppm	NOxppm
ZERO	0.00	-1.5	0.0
Span	3.98	16.8	76.0
Gas Value	4.00	18.03	76.02
Zero Factor	0	0	0
Span Factor	0	0	0

TABLE 2-1d

Continuous Monitor Data Summary
 Ten Minute Averages
 Test # 1
 SG# 50-6

Time	% O2	CO ppm	NOx ppm	SDCFM	CO Lbs/hr	NOx Lbs/hr
1340	1.73	0.1	38.2	7691	0.00	2.14
1350	1.68	0.1	38.5	7691	0.00	2.15
1410	1.72	0.1	38.3	7691	0.00	2.14
1125	1.73	0.1	38.8	7691	0.00	2.17
AVG.	1.72	0.1	38.5	7691	0.00	2.15

Calibration Data

	% O2	CO ppm	NOxppm
ZERO	0.00	-1.0	0.5
Span	3.98	17.0	76.9
Gas Value	4.00	18.03	76.02
Zero Factor	0	0	0
Span Factor	0	0	0

TABLE 2-1e

Continuous Monitor Data Summary
 Ten Minute Averages
 Test # 2
 SG# 50-6

Time	% O2	CO ppm	NOx ppm	SDCFM	CO Lbs/hr	NOx Lbs/hr
1430	1.70	0.2	38.6	7691	0.01	2.16
1440	1.70	0.1	38.5	7691	0.00	2.15
1450	1.73	0.5	38.3	7691	0.02	2.14
1500	1.70	9.8	36.0	7691	0.33	2.01
AVG.	1.71	2.7	37.9	7691	0.09	2.12

Calibration Data

	% O2	CO ppm	NOxppm
ZERO	0.00	0.0	-0.8
Span	4.01	18.0	75.7
Gas Value	4.00	18.03	76.02
Zero Factor	0	0	0
Span Factor	0	0	0

TABLE 2-1f

Continuous Monitor Data Summary
 Ten Minute Averages
 Test # 3
 SG# 50-6

Time	% O2	CO ppm	NOx ppm	SDCFM	CO Lbs/hr	NOx Lbs/hr
1520	1.70	3.8	38.5	7691	0.13	2.15
1530	1.70	2.5	38.8	7691	0.09	2.17
1540	1.72	1.5	39.0	7691	0.05	2.18
1550	1.73	0.5	39.5	7691	0.02	2.21
AVG.	1.71	2.1	39.0	7691	0.07	2.18

Calibration Data

	% O2	CO ppm	NOxppm
ZERO	0.00	-1.0	1.0
Span	3.98	16.8	78.6
Gas Value	4.00	18.03	76.02
Zero Factor	0	0	0
Span Factor	0	0	0

Table 2-2
Analyzer Specifications

NO_x CHEMILUMINESCENT ANALYZER -- THERMO ELECTRON MODEL 10AR

Response time	(0-90%)	1.5 sec-- NO mode 1.7 sec -- NO _x mode
Zero Drift		Negligible after 1/2 hour warmup
Linearity		less than 1% of full scale
Accuracy		Derived from the NO or NO _x calibration gas, 1% of full scale
Output		0.100 mV, 0-10 mV, 0-5 V, 0-10 V

O₂ ANALYZER, FUEL TYPE -- TELEDYNE MODEL 326RA

Response Time	(0-90%)	60 seconds
Accuracy		less than 1% of scale at constant temperatures; less than 1% of scale of less than 5% of reading, whichever is greater, over the operating temp. range 0-1 V


CO INFRARED ANALYZER -- TECO MODEL 48

Response Time	(0-90%)	1.2 seconds
Zero Drift		less than 1% / 24 hr full scale
Span Drift		less than 1% / 24 hr full scale
Linearity		1%
Repeatability		less than 0.5% of full scale
Output		0-1 V

STRIP CHART RECORDED (4 PEN) -- Linseis Model 7045


Response Time		less than 0.35 sec.
Span -- Full Scale		1 mV through 10 V
Zero Set		Electronically adjustable full scale with 1 full scale of zero suppression
Accuracy		Plus or minus 0.35 %
Linearity		Plus or minus 0.25 %

Figure 2-1



Appendix A-1

Fuel Analysis



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

GENESIS ENVIRONMENTAL
1145 W. Columbus Ave.
Bakersfield, CA 93301

Lab. No.: 027897_001
Received: Jun 20, 1991
Reported: Jun 21, 1991

Attention: Mike Bakalor

Sample Description: Chevron S6-50-6 Test #1 6/11/91

* CHROMATOGRAPHIC ANALYSIS (Z 1635) *

Components	Mole %	Wt %	CHONS	Wt %
Hydrogen	0.000	0.000	CARBON	63.07
Carbon Dioxide	6.711	14.488	HYDROGEN	18.60
Oxygen	1.260	1.978	OXYGEN	12.51
Nitrogen	4.225	5.806	NITROGEN	5.81
Carbon Monoxide	0.000	0.000	SULFUR	0.00
Hydrogen Sulfide	0.000	0.000		
Methane	78.824	62.033	Totals	99.99
Ethane	6.310	9.308	Total H/C	.29
Propane	2.007	4.341		
IsoButane	.177	.505		
N-Butane	.304	.868		
IsoPentane	.101	.357		
N-Pentane	.036	.128		
Hexanes+	.045	.188		
Totals =	100.000	100.000		

SPECIFIC GRAVITY (Air = 1) .7064
SPECIFIC VOLUME, cu.ft./lb * 18.55
GROSS CALORIFIC VALUE, BTU/cu.ft. * 969.19
GROSS CALORIFIC VALUE, BTU/cu.ft. ** 985.95
GROSS CALORIFIC VALUE, BTU/lb ** 18288.11
NET CALORIFIC VALUE, BTU/cu.ft. ** 890.88
NET CALORIFIC VALUE, BTU/lb ** 16524.75
DSCF EXHAUST PER SCF FUEL (0% Oxygen) 8.4840
COMPRESSIBILITY FACTOR 'Z' (60 F, 1 ATM) .9976
EPA 'F' Factor @ 68 F: 8708.563 DSCF / MM Btu.
KCAPCD 'F' Factor @ 60 F: 8577.935 DSCF / MM Btu.

* Water Saturated

** Dry Gas @ 60 F, 14.73 psia

Maryann W. Benoit

Maryann W. Benoit
Organics Supervisor

Richard L. Penner

Richard L. Penner
Laboratory Director

4309 Armour Avenue Bakersfield, California 93308

(805) 395-0539

FAX (805) 395-3069

RECEIVED JUN 21 1991



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

Genesis Environmental
1145 West Columbus
Bakersfield, CA 93305

Laboratory No: 27897-1
Date Received: 6-20-91
Date Reported: 6-25-91

Attention: Mike Bakalor

Sample: Fuel Gas

Sample Description: Chevron S6-50-6; Sampled on 6-11-91
Sampled by Mike Bakalor

Total Sulfur
(ASTM D 3246)


Results

As H₂S, ppm (vol.) < 1.0

As S, Grains/100 SCF* < 0.06

* Standard cubic feet (60 °F, 14.7 psia)

RLP/tds


Richard L. Penner
Laboratory Director

4309 Armour Avenue Bakersfield, California 93308

(805) 395-0539

FAX (805) 395-3069

100

Appendix A-2
Hydrocarbon Analysis

CHEVRON HC#1 5⁹-7
START



CHROMATOPAC CR601
SAMPLE NO 0
REPORT NO 706

FILE 1
METHOD 44
SAMPLE WT 100

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	6.092	640		2	4.5587	METHAN
TOTAL		640			4.5587	

CHEVRON 50-7 HC#2
START




CHROMATOPAC CR601
SAMPLE NO 9
REPORT NO 707

FILE 1
METHOD 44
SAMPLE WT 100

PKNO	TIME	AREA	PK	IDNO	CONC	NAME
1	6.132	271		2	1.9344	METHAN
TOTAL		271			1.9344	

CHEVRON ⁵ 40-7, HC#3
START



CHROMATOPAC CR601
SAMPLE NO 0
REPORT NO 731

FILE 1
METHOD 44
SAMPLE WT 100

PKNO	TIME	AREA	NK	IDNO	CONC	NAME
1	6.015	228		2	1.5761	METHAN
TOTAL		228			1.5761	

5
/CHEVRON 90-6 HC#1
START




CHROMATOPAC CR601
SAMPLE NO 0
REPORT NO 710

FILE 1
METHOD 44
SAMPLE WT 100

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	5.723	140		2	0.9943	METHAN
TOTAL		140			0.9943	

CHEVRON, HC#2
50-6
START



CHROMATOPAC CR601
SAMPLE NO 0
REPORT NO 733

FILE 1
METHOD 44
SAMPLE WT 100


PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	5.98	142		2	0.9847	METHAN
2	6.483	797		2	5.5096	METHAN
TOTAL		940			6.4942	

RENEW CHARTER RENEW CHARTER RENEW CHARTER RENEW CHARTER

CHEVRON, HC#3
58-6
START

STOP

WARNING NO PEAK
START




CHROMATOPAC CR601
SAMPLE NO 0
REPORT NO 734

FILE 1
METHOD 44
SAMPLE WT 100

PKNO	TIME	AREA	PK	IDNO	CONC	NAME
1	5.855	141		2	0.9715	METHAN
TOTAL		141			0.9715	

FW CHARTER NEW CHARTER NEW CHARTER NEW CHARTER

START



CHROMATOPAC CR601
SAMPLE NO 0
REPORT NO 722

FILE 1
METHOD 44
SAMPLE WT 100

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.027	167				
2	5.325	23482		1	28.474	HEXANE
3	5.967	2185	V	2	15.5753	METHAN
4	7.875	3688		3	14.4822	ETHANE
5	11.623	5460		4	14.6717	PROPAN
6	20.912	7460		5	14.7517	BUTANE
7	41.5	8906		6	14.7115	PENTAN
TOTAL		51347			102.6664	


PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.027	167				
2	5.325	23482		1		HEXANE
3	5.967	2185	V	2		METHAN
4	7.875	3688		3		ETHANE
5	11.623	5460		4		PROPAN
6	20.912	7460		5		BUTANE
7	41.5	8906		6		PENTAN
TOTAL		51347				

CALIBRATION MADE IN IDENTIFICATION FILE 1
MODE# 1 WINDOW 9

IDNO	NAME	TIME	FACTOR	CONC
1	HEXANE	5.32	0.00126481	29.7
2	METHAN	5.96	0.00690985	15.1
3	ETHANE	7.87	0.0040948	15.1
4	PROPAN	11.62	0.00280222	15.3
5	BUTANE	20.91	0.00201072	15
6	PENTAN	41.5	0.00168435	15

Appendix A-3

Raw Data



BLK - O2 0-10%

RED - CO 0-100

BLUE - NOX 0-100

CHART SPD @ 6.0"/HR

07:30 ON SITE

6-11-91 CHEVRON 26C SG 56.7

58.6

K. OKTON GENESIS

S. MILLER CHEVRON

NOX SPAN GAS = 76.02 ppm


CO " " = 17.03 ppm




O2 " " = 4.0%

ALM 12220


CE 60295

ALM 15888







SYSTEM CAL



START RUN #3 @ 15:20



START #2 @ 14:30



Company CHEVRONDate 6-11-91Station 26-C SG 50-6Test Run 1

Time	%O ₂	%CO ₂	ppm CO		ppm SO ₂		ppm NO _x	
			drift not corrected	drift corrected	drift not corrected	drift corrected	drift not corrected	drift corrected
13:40	1.73	N/A	-1.0		N/A	N/A	38.2	
13:50	1.68		-0.7				38.5	
14:00	1.72		-0.7				38.3	
14:10	1.73		-0.7				38.8	
Mean	1.72	✓	-0.78		✓	✓	38.45	

Calibration	%O ₂	%CO ₂	ppm CO	ppm SO ₂	ppm NO _x
zero reading	0.0	N/A	-1.0	N/A	0.5
span reading	3.98		17.0		76.9
span gas value	4.0% C4#ALM15818		18.03 C4#AL60243		76.02 C4#ALM12220
* span drift corr. factor					
* zero drift corr. factor		✓		✓	

*Apply drift correction factors to the mean value only, for each test run.
See calculations on next page.

Company CHEVRON
 Station 26-C SG 50-6

Date 6-11-91
 Test Run 2

Time	%O ₂	%CO ₂	ppm CO		ppm SO ₂		ppm NO _x	
			drift not corrected	drift corrected	drift not corrected	drift corrected	drift not corrected	drift corrected
14:30	1.70	N/A	0.2		N/A	N/A	38.6	
14:40	1.70		0.0				38.5	
14:50	1.73		0.5				38.3	
15:00	1.70		9.8				36.0	
Mean	1.71	✓	2.63		✓	✓	35.35	

Calibration	%O ₂	%CO ₂	ppm CO	ppm SO ₂	ppm NO _x
zero reading	0.0	N/A	0.0	N/A	-0.8
span reading	4.01		18.0		75.7
span gas value	4.0% CIL # ALM15818		18.03 CIL # PL60243		76.02 CIL # ALM12220
* span drift corr. factor					
* zero drift corr. factor		✓		✓	

*Apply drift correction factors to the mean value only, for each test run.
 See calculations on next page.

Company CHEVRON
 Station 26-C SG 50-6

Date 6-11-91
 Test Run 3

Time	%O ₂	%CO ₂	ppm CO		ppm SO ₂		ppm NO _x	
			drift not corrected	drift corrected	drift not corrected	drift corrected	drift not corrected	drift corrected
15:20	1.70	N/A	3.8		N/A	N/A	38.5	
15:30	1.70		2.5				38.8	
15:40	1.72		1.5				39.0	
15:50	1.73		0.5				39.5	
Mean	1.71	✓	2.18		✓	✓	38.95	

Calibration	%O ₂	%CO ₂	ppm CO	ppm SO ₂	ppm NO _x
zero reading	0.0	N/A	-1.0	N/A	1.0
span reading	3.98		16.8		78.6
span gas value	4.0% C4K*AM15818		18.03 C4K*AM15818		76.02 C4K*AM15818
* span drift corr. factor					
* zero drift corr. factor		✓		✓	

*Apply drift correction factors to the mean value only, for each test run.
 See calculations on next page.

Company CHEVRON.Date 6-11-91.Station 26-C SG 50-7Test Run 1

Time	%O ₂	%CO ₂	ppm CO		ppm SO ₂		ppm NO _x	
			drift not corrected	drift corrected	drift not corrected	drift corrected	drift not corrected	drift corrected
10:55	1.62	N A	7.0		N A	N A	34.5	
11:05	1.55		5.5				35.7	
11:15	1.53		4.5				35.7	
11:25	1.49		3.9				36.4	
Mean	1.55	✓	5.23		✓	✓	35.58	

Calibration	%O ₂	%CO ₂	ppm CO	ppm SO ₂	ppm NO _x
zero reading	0.0	N/A	0.0	N/A	-1.0
span reading	3.8		18.5		74.7
span gas value	4.0% CAL#ALM15818		18.03 CAL#CE60243		76.02 CAL#ALM12220
* span drift corr. factor					
* zero drift corr. factor		✓		✓	

*Apply drift correction factors to the mean value only, for each test run.
See calculations on next page.

Company CHEVRON.Date 6-11-91.Station 26-C SG. 50-7.Test Run 2

Time	%O ₂	%CO ₂	ppm CO		ppm SO ₂		ppm NO _x	
			drift not corrected	drift corrected	drift not corrected	drift corrected	drift not corrected	drift corrected
11:41	1.63	N A	3.0		N A	N A	37.5	
11:51	1.63		2.8				37.6	
12:01	1.58		2.4				37.0	
12:11	1.63		1.8				37.8	
Mean	1.62	✓	2.5		✓	✓	37.48	

Calibration	%O ₂	%CO ₂	ppm CO	ppm SO ₂	ppm NO _x
zero reading	0.0	N/A	0.0	N/A	-0.5
span reading	4.0		18.5		77.3
span gas value	4.0% M4*NM15818		18.03 M4*CE6024.3		76.02 M4*AL1112220
* span drift corr. factor					
* zero drift corr. factor		✓		✓	

*Apply drift correction factors to the mean value only, for each test run.
See calculations on next page.

Company CHEVRON.Date 6-11-91.Station 26-C SG 50-7.Test Run 3

Time	%O ₂	%CO ₂	ppm CO		ppm SO ₂		ppm NO _x	
			drift not corrected	drift corrected	drift not corrected	drift corrected	drift not corrected	drift corrected
12:40	1.58	N A	0.2		N A	N A	37.7	
12:50	1.60		-0.5				37.9	
13:00	1.58		-1.0				38.0	
13:10	1.60		-1.4				37.8	
Mean	1.59	✓	-0.6		✓	✓	37.85	

Calibration	%O ₂	%CO ₂	ppm CO	ppm SO ₂	ppm NO _x
zero reading	0.0	N/A	-1.5	N/A	-0.02
span reading	3.98		16.8		76.0
span gas value	4.0% MIL#NM15818		18.03 MIL#CC60243		76.02 MIL#ALM12220
* span drift corr. factor					
* zero drift corr. factor		✓		✓	

*Apply drift correction factors to the mean value only, for each test run.
See calculations on next page.

Appendix A-4
Calibrations and Certifications



Scott Specialty Gases, Inc.

2600 CAJON BLVD., SAN BERNARDINO, CA 92405

FAX: 714-887-0549
PHONE: 714-887-2571

Shipped From: Scott SAN BERNARDINO, CA
Date Shipped 7/19/90
Our Project No: 7758
Your PO No: 7113
Page 1 of 1
Expiration Date: 1/92

GENESIS ENVIRONMENTAL
1145 W. COLUMBUS AVE
BAKERSFIELD, CA 93301

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES

Certified Per Testability Protocol No. 1 Procedure No. GL Cylinder No. ALM-12220 Cylinder Pressure 1900 psig Certified Accuracy $\pm 1\%$ 1105 Traceable

REFERENCE STD

COMPONENTS	CERTIFIED CONC	SRV/CRM NO.	CYL. NO.	CONC.
NITRIC OXIDE	75.88 ppm	CRM1684B	AAL-6032	94.82 ppm
NOX	76.02 ppm			

GAS ANALYZER

MAKE/MODEL/SERIAL NO.	LAST CAL. DATE	ANALYTICAL PRINCIPLE
THERMO-ELECTRON 10 AR 14853-150	6/2/90	CHEMI-LUMINESCENT

BALANCE GAS NITROGEN

ANALYZER READINGS: Z = Zero Gas T = Test Gas R = Reference Gas

Component	NITRIC OXIDE	7/11/90	Units	ppm
First Analysis Date				
Z	0.00	R	94.75	T 75.58
R	94.74	Z	0.08	T 75.56
Z	0.08	T	75.60	R 94.78
Mean Test Assay				75.62 ppm
Second Analysis Date	7/18/90	Units	ppm	
Z	0.00	R	94.78	T 76.02
R	94.98	Z	0.02	T 75.88
Z	0.01	T	75.95	R 94.74
Mean Test Assay				75.88 ppm

Component	Units
Date	
Z	R
R	Z
Z	T
Mean Test Assay	
Date	
Z	R
R	Z
Z	T
Mean Test Assay	

Component	Units
Date	
Z	R
R	Z
Z	T
Mean Test Assay	
Date	
Z	R
R	Z
Z	T
Mean Test Assay	

Chronology: Date _____
Assay _____

Analyst L. OLDHAM

Approved By R. Steady

RECEIVED JUL 05 1991



Scott Specialty Gases, Inc.

2600 CAJON BLVD., SAN BERNARDINO, CA 92411-0000
PHONE: 714-887-2571 FAX: 714-887-0549

11/30/90

GENESIS ENVIRONMENTAL
1145 W. COLUMBUS AVENUE

PROJECT #: 02-10721
PO #: 7158

BAKERSFIELD

CA 93301-0000

CYLINDER #: ALM015818

ANALYTICAL ACCURACY: +/-2%

COMPONENT	REQUESTED CONCENTRATION	ANALYSIS 1 (MOLES) U/M
OXYGEN	4.0 PCT	4.00 PCT
NITROGEN	BALANCE	N/A

DATE OF ANALYSIS: 11/20/90

ANALYST: 
MAYNARD JOHNSON

APPROVED BY: 
ROBERT SHEALY



TO: GENEØ1

DATE : 03/06/90

Mike Bakalor
Genesis Environmental
1145 West Columbus
Bakersfield, CA 93301

CUSTOMER ORDER NUMBER: 8286

PAGE 1

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC60293	Carbon Monoxide Nitrogen	18.03 ± 0.18 ppm Balance	SRM 2613a

$$\text{ppm} = \text{umole/mole}$$

% = mole-%

The above analysis is traceable to the National Institute of Standards and Technology by intercomparison with the reference standard listed above. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

Analyst:

Approved:

J.W. Gay

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS