

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

APPLICATION NUMBER 1431370699 B005

Siemens Energy and Automation, Inc.

SOURCE DESCRIPTION (OR SCC CODE)

Natural Gas Boiler #2

CONTROL EQUIPMENT

Low NO<sub>x</sub> Burners

DATE(S) OF TEST

August 8, 1994

FINAL TEST REPORT RECEIVED ON

August 25, 1994

POLLUTANT(S) TESTED

NO<sub>x</sub>

TEST METHOD

U.S. EPA Reference Methods 1-4 and 7e

TEST FIRM

K & B Design, Inc.

EMISSION RATES\*:

ACTUAL

ALLOWABLE\*\*

0.13 lb./mmbtu

NO<sub>x</sub> 0.10 lb./mmbtu or 2.01 lbs./hr.

OPERATING RATES\*:

DURING TEST\*\*

20.5 mmbtu/hr.

MAXIMUM\*\*

24.5 mmbtu/hr.

EMISSION FACTOR\*\*\*

COMMENTS:

I HEREBY VERIFY THAT THE INFORMATION CONTAINED WITHIN THE STACK TEST REPORT HAS BEEN REVIEWED AND IT HAS BEEN DETERMINED THAT THE TEST PROCEDURES, ANALYSES AND CALCULATIONS ARE:

- ☒ AN ACCEPTABLE DEMONSTRATION OF CONFORMANCE WITH THE APPROVED TESTING METHODOLOGY.
- ☐ AN UNACCEPTABLE DEMONSTRATION OF CONFORMANCE WITH THE APPROVED TESTING METHODOLOGY.

March 14, 1994

DATE OF REVIEW

PREPARED BY

REVIEWED BY

- \* BASED ON- RUN AVERAGE
- \*\* SPECIFY APPLICABLE UNITS
- \*\*\* SPECIFY IN UNITS OF MASS/INPUT

(Filename: g:\wpwin\shared\forms\appendk.frm)  
(Filename: a:\appendk.frm - SAL's Diskette #9)

Observer's Report

Compliance Test For  
NO<sub>x</sub>

Conducted on: Siemens Energy and Automation

Source: Natural Gas Fired Boiler #2

Premise Number: 1431370699 B005

Test Firm: K & B Design, Inc.

Prepared by: Denise L. Bien, ETII

Date Prepared: August 26, 1994

Department of Environmental Services - Air Quality Management  
(D.O.E.S. - A.Q.M.)

**Siemens Energy & Automation**  
**1431370699 B005 and B004**

Testing for NO<sub>x</sub> emissions was conducted on boiler #2 at Siemens Energy & Automation (1431370699 B005) on, August 8, 1994. The boiler is a natural gas/#2 fuel oil fired boiler, B004 is an identical unit. The boiler is rated at 24.5 mmbtu/hr. heat input. The Ohio Administrative Code (OAC) Rules 3745-31-05, 3745-15-07, 3745-17-07, 3745-17-10, 3745-18-06 apply to the source and 40 CFR Part 60 Subpart Dc. These rules limit the source to emission rates of 0.13 lbs. NO<sub>x</sub>/ mmbtu for natural gas, and 0.17 lbs. NO<sub>x</sub>/mmbtu for #2 fuel oil. The source was tested to determine if it meets PTI requirements.

U.S. EPA Reference Methods 1-4 and 7e were utilized to sample the stack. Port location was in accord with Federal Register specifications.

The NO<sub>x</sub> emission rates (by f factor method) during testing were as follows:

| Run #1                        | Run 2#                        | Run #3                        | Average                        |
|-------------------------------|-------------------------------|-------------------------------|--------------------------------|
| 0.10 lbNO <sub>x</sub> /mmbtu | 0.10 lbNO <sub>x</sub> /mmbtu | 0.10 lbNO <sub>x</sub> /mmbtu | 0.10 lb NO <sub>x</sub> /mmbtu |

The NO<sub>x</sub> emissions averaged 0.11 lbs/mmbtu derived from natural gas usage calculations. These results are below the 0.13 lbs./mmbtu listed in the PTI. This also represents an average value of 39.8 ppm NO<sub>x</sub> and 2.0 lbs./hr. NO<sub>x</sub>.

Results from previous testing run on 3/17/94 were as follows:

| Run # 1                        | Run # 2                        | Run # 3                        | Average                        |
|--------------------------------|--------------------------------|--------------------------------|--------------------------------|
| 0.15 lb NO <sub>x</sub> /mmbtu | 0.15 lb NO <sub>x</sub> /mmbtu | 0.15 lb.NO <sub>x</sub> /mmbtu | 0.15 lb.NO <sub>x</sub> /mmbtu |

Stack parameters during this test were as follows:

**Siemens Energy & Automation**  
**1431370699 B005 and B004**

| Run Number | Velocity (fps) | Stack Temp - °F | Flow Rate (dscfm) | Moisture % | % CO <sub>2</sub> | % O <sub>2</sub> |
|------------|----------------|-----------------|-------------------|------------|-------------------|------------------|
| 1          | 13.2           | 230             | 6,712             | 10.6       | 4.2               | 12.0             |
| 2          | 13.9           | 231             | 7,001             | 11.3       | 4.2               | 11.3             |
| 3          | 13.9           | 233             | 7,009             | 10.9       | 4.3               | 11.9             |
| Average    | 13.7           | 231             | 6,907             | 10.9       | 4.2               | 11.7             |

Stack parameters from previous testing on 3/15/94 were as follows:

| Run Number | Velocity (fps) | Stack Temp. - °F | Flow Rate (dscfm) | Moisture % | % CO <sub>2</sub> | % O <sub>2</sub> |
|------------|----------------|------------------|-------------------|------------|-------------------|------------------|
| 1          | 7.3            | 159              | 4,126             | 9.8        | 4.4               | 11.9             |
| 2          | 7.9            | 171              | 4,421             | 9.0        | 4.3               | 12.0             |
| 3          | 7.5            | 160              | 4,391             | 6.8        | 4.2               | 12.0             |
| Average    | 7.6            | 163              | 4,313             | 8.5        | 4.3               | 12.0             |

The boiler was run in automatic mode. The load averaged 20.5 mmbtu/hr. by f factor and heat input by fuel meter was 17.6 mmbtu/hr. This is 83.7 % and 71.8 % respectively, of the 24.5 mmbtu/hr. rated capacity. There was not enough real load for the source to operate at maximum steam output.

Natural gas heat content was 1,025 btu/ft<sup>3</sup>.

Stack volumetric flow averaged 6,907 dscfm at 231 °F and 10.9 % moisture. Stack O<sub>2</sub> averaged 11.7 % and CO<sub>2</sub> averaged 4.2 %. The f<sub>o</sub>-factor was 2.19, which is 22% above the standard for natural gas of 1.79.

Quality assurance measures to assure precision and accuracy included calibration of all equipment used, leak checks before and after each test run, sample blanks and full documentation of all results, process data and calibrations. All calculations were checked and found to be accurate. Observer notes agreed with the data in the test report.

**Siemens Energy & Automation**  
**1431370699 B005 and B004**

In conclusion, based upon D.O.E.S.-A.Q.M. analysis of the test procedures and the final test report submitted by Siemens Energy & Automation and K & B Design, Inc., this boiler has a mass emission rate of 0.10 lb./mmbtu and visible emissions of near 0% while operating at 83.7 % of maximum load.

**Siemens Energy & Automation**  
**1431370699 B005 and B004**

In conclusion, based upon D.O.E.S.-A.Q.M. analysis of the test procedures and the final test report submitted by Siemens Energy & Automation and K & B Design, Inc., this boiler has a mass emission rate of 0.10 lb./mmbtu and visible emissions of near 0% while operating at 83.7 % of maximum load. Testing at permit renewal is indicated by Ohio EPA Engineering Guidance.

**DETERMINATION OF  
NO<sub>x</sub> EMISSION RATES  
BOILER 2  
SIEMENS ENERGY & AUTOMATION, INC.  
MOTORS & DRIVES DIVISION  
NORWOOD PLANT  
AUGUST 8, 1994**

**Mailing Address:  
4620 Forest Avenue  
Norwood, Ohio 45212-3396**

**Telephone #:  
513/841-3450**

**Performed by:  
K&B Design, Inc.**

  
**Thomas E. Bayer  
Project Manager**

**Job # F-810  
August 16, 1994**



**K&B Design, Inc.  
3131 Disney Street  
Cincinnati, OH 45209  
(513) 351-6200**



## **Table of Contents**

|                                        |     |
|----------------------------------------|-----|
| 1.0 EXECUTIVE SUMMARY                  | -1- |
| 2.0 INTRODUCTION                       | -2- |
| 3.0 SAMPLING AND ANALYTICAL PROCEDURES | -3- |
| 4.0 DESCRIPTION OF OPERATIONS          | -8- |
| 4.0 TEST RESULTS                       | -9- |

Appendix A-Quality Assurance Procedures and Results

Appendix B-Process Data

Appendix C-Field Data Sheets

Appendix D-Chart Recordings & Data Log Files

Appendix E-Emission Rate Calculations

### **1.0 EXECUTIVE SUMMARY**

K&B Design, Inc. was retained by Siemens Energy & Automation, Inc. to determine NO<sub>x</sub> emission rates from Boiler 2 ( Source No. B005 ) at the Norwood Plant. Continuous gas samples were analyzed from the outlet stack of the furnace using USEPA Reference Methods 1-4 and 7E for stationary source sampling.

The results of the tests are summarized below:

| RUN #/<br>FURNACE | NO <sub>x</sub><br>EMISSION RATE <sup>1</sup> |                            |
|-------------------|-----------------------------------------------|----------------------------|
|                   | ( lb/MM Btu ) <sup>2</sup>                    | ( lb/MM Btu ) <sup>3</sup> |
| 1                 | 0.11                                          | 0.10                       |
| 2                 | 0.11                                          | 0.10                       |
| 3                 | 0.11                                          | 0.10                       |
| Average           | 0.11                                          | 0.10                       |

<sup>1</sup>As nitrogen dioxide.

<sup>2</sup>Based on fuel integrator and fuel analysis.

<sup>3</sup>Based on published F-factor of 8,710 dscf/MM Btu.

## **2.0 INTRODUCTION**

K&B Design, Inc. was retained by Siemens Energy & Automation, Inc. to determine NO<sub>x</sub> emission rates from Boiler 2 at the Norwood Plant. Three test runs were conducted on Boiler 2 over a one day period. The tests were conducted on August 8, 1994. In addition to the NO<sub>x</sub> concentration, measurements were also made of the stack gas temperature, moisture content, velocity and volumetric flow rate, oxygen and carbon dioxide content.

Ms. Karen Notestine of Siemens provided process data and coordinated the sampling with production personnel. Mr. Tom Bayer, Mr. Brian Finn, and Mr. Rick Feller of K&B Design conducted the stack tests.

### **3.0 SAMPLING AND ANALYTICAL PROCEDURES**

The sampling and analytical procedures used in this survey conform with the USEPA Reference Methods for stationary source sampling. The following procedures were employed:

- ° ***Measurement Sites***

Location of measurement sites and the number of traverse points to be sampled were determined as specified in USEPA Reference Method 1, *"Sample and Velocity Traverses for Stationary Sources"*. A drawing of the sampling site is included in Figure 3.1.

- ° ***Velocity, Flow Rate, and Temperature***

The stack gas velocity and temperature were determined using USEPA Reference Method 2, *"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type "S" Pitot Tube)"*. The velocity pressure was measured with a Type "S" pitot tube and oil manometer. The stack temperature was measured with a calibrated Type "K" thermocouple.

- ° ***Analysis for Carbon Dioxide and Oxygen***

Carbon dioxide and oxygen were determined using USEPA Reference Method 3, *"Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight"*. An integrated sample was collected during each sample run. Analysis was performed with an Orsat analyzer.

- ° ***Stack Gas Moisture***

Stack gas moisture content was determined using USEPA Reference Method 4, *"Determination of Moisture Content in Stack Gases"*. The impingers were weighed to the nearest 0.5 g with a digital electronic balance before and after each test. A drawing of the sampling train is included in Figure 3.2.

- ° ***Nitrogen Oxide***

Nitrogen oxide emissions were determined using USEPA Reference Method 7E, *"Determination of Nitrogen Oxide Emissions From Stationary Sources - Instrumental Analyzer Procedure"*. A continuous sample of the stack gas was extracted and analyzed on a wet basis with a chemiluminescent analyzer. The instrument output was recorded on a chart recorder and instantaneously logged on a Macintosh computer equipped with a 12 bit A/D high resolution data acquisition board.

The analyzer was calibrated as specified in the Reference Method with zero, mid-level, and high-level mixtures of NO in nitrogen. The calibration standards were certified by USEPA Protocol 1 *"Traceability Protocol for Establishing True Concentrations of Gases Used for Calibration and Audits of Continuous Source Emission Monitors"*.





Figure 3.1 Sampling Site Detail



**Figure 3.2 USEPA Reference Method 4 sampling train**

Prior to the first test and each subsequent test, the analyzer calibration was established by introducing the high level span gas and zero gas upstream of the instrument and making the necessary adjustments. The mid-level calibration gas was then introduced in the same manor to check the calibration error. A measurement system pre-test bias check was performed. The zero and mid-level span gas were introduced to the analyzer through a 3-way calibration valve and a solenoid valve located at the sample probe. The system bias was checked by comparing the instrument response to the results obtained from the analyzer calibration check. The up-scale and down-scale measurement system response time was also determined at this time. After each test, the analyzer system response to zero air and the mid-level span gas was checked to determine the post test system bias and analyzer drift.

The analyzer interference response was checked prior to its initial use in the field. The check consists of introducing several different gaseous components to the analyzer and recording there response. The sum of the interference responses of the test gases must be less than 2 % of the span value. The test results for this check are included in the QA/QC section of the report. The analyzer will be rechecked if any changes are made in the instrumentation that could alter the interference response.

The analyzer NO<sub>2</sub> to NO conversion efficiency was not required. Previous test data shows NO<sub>2</sub> is less than 5% of the NO<sub>x</sub> concentration. A drawing of the sampling train is included in Figure 3.3.

° ***Emission Rates***

Since there was no isolated gas meter for this boiler, the heat input rate was determined from a published F-factor ( USEPA Reference Method 19 ), the NO<sub>x</sub> emission rates as a function of the heat input, were calculated from the measured concentration, the oxygen content of the stack gas and the F-factor. The fuel usage from a common plant gas meter was recorded as a back-up method and second check of the heat input rate.

° ***Quality Assurance***

The Quality Assurance procedures used in this survey include equipment calibration by USEPA and manufacturer's guidelines, use of standard published procedures for sample collection and analysis, and attention to the QA procedures included in the Reference Methods. The calibration procedures and results for the equipment used in this survey are included Appendix A.




Figure 3.3 USEPA Reference Method 7E measurement system



#### **4.0 DESCRIPTION OF OPERATIONS**

Boiler B004 and B005 are identical units. They were manufactured by Clayton Industries and are rated at 24.5 MMBtu/hr. The boilers are fired with natural gas but may be fired with #2 fuel oil. Boiler #2 (B005) was tested firing natural gas. The boiler was operated at 90% of capacity for the three tests.

The emission samples were collected in the main exhaust stack. The test site meets the criteria of Reference Method 1. The test ports are 3 diameters downstream and 5 diameters upstream of the nearest flow disturbance. The diameter of the stack is 48".

## **5.0 TEST RESULTS**

The stack gas flow rates, temperature, etc. are summarized in Table 5.1. The average flow rate was 10,312 acfm (6,915 dscfm) at 231°F and 10.9 % water vapor. The average O<sub>2</sub> concentration was 11.9 % and the average CO<sub>2</sub> concentration was 4.3 %.

Nitrogen oxide emissions are summarized in Table 5.2. A computer generated graphic representation of the NO<sub>x</sub> instrument response recorded for each run is included as Figures 5.1 through 5.3. The average NO<sub>x</sub> concentration for the three test runs was 39.8 ppm. The average NO<sub>x</sub> emission rate was 2.0 lb/hr. The emission rate based on heat input was calculated both by fuel usage, 0.11 lb/MM Btu and published F-factor 0.10 lb/MM Btu.

The Appendices to this report contain the QA/QC data, process data, copies of the field data forms, data log files with recorder charts, and emissions calculations for each run.

Table 5.1 Summary of stack gas conditions-Boiler 2

| RUN NO. | DATE 1994 | VELOCITY (fps) <sup>a</sup> | FLOW RATE (acfm) <sup>b</sup> | TEMP. (°F) | MOISTURE (%) | O2 (%) | CO2 (%) |
|---------|-----------|-----------------------------|-------------------------------|------------|--------------|--------|---------|
| 1       | 8/11      | 13.3                        | 10,005                        | 230        | 10.6         | 12.0   | 4.2     |
| 2       | 8/11      | 13.9                        | 10,465                        | 231        | 11.3         | 11.8   | 4.3     |
| 3       | 8/11      | 13.9                        | 10,465                        | 232        | 10.9         | 11.9   | 4.3     |
| Average |           | 13.7                        | 10,312                        | 231        | 10.9         | 11.9   | 4.3     |

<sup>a</sup>Feet per second at stack conditions.

<sup>b</sup>Actual cubic feet per minute at stack conditions.

<sup>c</sup>Dry standard cubic feet per minute at 68°F and 29.92" Hg.

Table 5.2 Summary of NO<sub>x</sub> emission rates-Boiler 2

| RUN<br>NO. | CONCENTRATION<br>(ppm) | MASS EMISSION RATE <sup>1</sup> |                                                   |
|------------|------------------------|---------------------------------|---------------------------------------------------|
|            |                        | (lb/hr)                         | (lb/MM Btu) <sup>2</sup> (lb/MM Btu) <sup>3</sup> |
| 1          | 39.5                   | 1.9                             | 0.11 0.10                                         |
| 2          | 39.7                   | 2.0                             | 0.11 0.10                                         |
| 3          | 40.2                   | 2.0                             | 0.11 0.10                                         |
| Average    | 39.8                   | 2.0                             | 0.11 0.10                                         |

<sup>1</sup> As nitrogen dioxide

<sup>2</sup> Based on fuel integrator and fuel analysis.

<sup>3</sup> Based on published F-factor of 8,710 dscf/MMBtu.




Figure 5.1 NOx Data Summary Run 1




Figure 5.2 NOx Data Summary Run 2




Figure 5.3 NOx Data Summary Run 3

## QUALITY ASSURANCE PROCEDURES AND RESULTS

The sampling and analytical equipment used in this survey has been calibrated and maintained as recommended in USEPA Reference Methods for Stationary Source Sampling, the Quality Assurance Handbook for Air Pollution Measurement Systems, and in the manufacturers owners manuals. The paragraphs below summarize the calibration procedures that will be employed.

- **Analytical Balance**

Gravimetric analysis is performed on a Sartorius Model B 120 S analytical balance that is readable to 0.1 mg. The analytical balance is permanently mounted in the laboratory. The balance is calibrated on each day of use with a series of standard weights. The results of the daily calibration are recorded in a logbook.

- **Nozzles**

Nozzles are regularly inspected in the field for obvious signs of damage and irregularities. If the nozzle shows signs of damage, it is not used until the damage is repaired. The nozzle diameter is determined in the field by measuring three different diameters with a precision micrometer. The three measurements are averaged to establish the nozzle diameter. The nozzle is acceptable if the difference between the high and low measurements is less than 0.004 in.

- **Pitot Tubes**

The 'S'-type pitot tubes are built to the design specifications cited in Reference Method 2 and are assigned a coefficient of 0.84. Standard pitot tubes have a coefficient of 0.99. The pitot tubes, connecting lines, and manometers are leak-checked in the field before and after each test run.

- **Thermocouples**

Thermocouples are calibrated on an annual basis. The thermocouples are calibrated against an NBS traceable mercury in glass thermometer. The thermocouples are calibrated at approximately 32°F, 70°F, 212°F, and 400°F.

- **Digital Readouts**

The digital readouts that display temperature are calibrated with a Omega Engineering thermocouple simulator which generates millivolt signals corresponding to temperatures from 0°F to 1000° F in 100° increments.

- **Orsat Analyzer**

The Orsat analyzer is calibrated in the field with a standard gas mixture of oxygen and carbon dioxide in nitrogen. The calibration standard is certified to  $\pm 1\%$  by the supplier. Analyzer reagents are changed when analysis indicates slow adsorption, lack of agreement between runs, or when the calibration standards cannot be accurately measured.

- **Fyrite Analyzers**

The Fyrite analyzers are routinely leak checked and reagents are changed as performance dictates.



## QUALITY ASSURANCE PROCEDURES AND RESULTS

---

### ° Control Consoles

The Method 5 control consoles are Nutech Model 2010 consoles with digital temperature controllers. The dry gas meter coefficient (Y-factor) and the orifice constant ( $\Delta H @$ ) are established by calibrating the control consoles at 5 flow rates. Five critical orifices serve as the reference standards. The Method 5 control consoles are calibrated after each test series to confirm the Y-factor has not changed more than plus or minus 5%.

The Method 6 and VOST control consoles are calibrated against a soap bubble meter at the flow rate used during the emission test. The consoles are calibrated before and after each test series.

### ° NO<sub>x</sub> Flasks

The NO<sub>x</sub> flasks and stopcocks are calibrated by filling the flask and matching stopcock with deionized water. The flask and stopcock are then weighed on a digital balance to the nearest 0.1 gram. The water is drained, the glass ware is dried and the weight is recorded. The difference between the tare weight and the gross weight is the flask volume in milliliters.

### ° Method 7E Calibration and Span Gas

The NO-NO<sub>2</sub>-NO<sub>x</sub> chemiluminescent analyzer is calibrated as specified in the Reference Method with zero air, mid-level, and high-level mixtures of nitrogen oxide in nitrogen. The calibration standards are certified by USEPA Protocol 1 *"Traceability Protocol for Establishing True Concentrations of Gases Used for Calibration and Audits of Continuous Source Emission Monitors"*.

The analyzer interference response was checked prior to its initial use in the field. The check consists of introducing CO, SO<sub>2</sub>, CO<sub>2</sub>, and O<sub>2</sub> to the analyzer and recording the response. The sum of the interference responses of the test gases must be less than 2% of the span value. The analyzer interference response is re-checked if any changes are made in the instrumentation that could alter the interference response.


The analyzer NO<sub>2</sub> to NO conversion efficiency is checked by introducing an NO<sub>2</sub> test gas to the analyzer. The NO<sub>x</sub> response will be recorded for 30 minutes. If the response remains within 2.0% of the highest value, the conversion efficiency is considered to be 100%.

### ° Method 10 Calibration and Span Gas

The carbon monoxide gas filter correlation NDIR analyzer is calibrated as specified in the Reference Method with nitrogen, low-level, mid-level, and high-level mixtures of carbon monoxide in nitrogen. The calibration standards are certified by the supplier to  $\pm 2\%$ . The analyzer was challenged with a 10.1% CO<sub>2</sub>/10.1% O<sub>2</sub> mixture to determine the interference of CO<sub>2</sub> in the detector. The results of this test indicated the response is negligible. The results of the test is summarized below:

## QUALITY ASSURANCE PROCEDURES AND RESULTS

---



- **Personal Sampling Pumps**

Personal sampling pumps are calibrated against a soap film bubble meter with representative sampling media in line to simulate actual sampling conditions. Triplicate calibration runs are made and the run values are averaged to arrive at the actual sampling rate.

- **Method 25 Trap and Tank Background Check**

Prior to field use, the condensate traps are baked at elevated temperature and then analyzed on the NMO analyzer to ensure there is <10 ppm-C<sub>1</sub> residual contamination. The tanks are also heated at elevated temperature, purged with zero air and then analyzed on the NMO analyzer to ensure there is <10 ppm-C<sub>1</sub> residual contamination

- **Method 25 Sample Tank Volume Determination**

The Method 25 sample tanks are calibrated prior to being placed into field service. The calibration procedure consists weighing the empty tank to nearest 1 gram on a calibrated digital balance. The tank is then filled with water and weighed again. The difference in the tare weight and the gross weight is the tank volume in milliliters.

- **Method 25 Sample Flow Controllers**

The Method 25 sample flow controllers are calibrated upon receipt from the manufacturer. They are calibrated with a soap bubble meter at two points to establish linearity.

- **Method 25 Sample Train Leak Checks**

The Method 25 sample train consists of a trap, a tank, a control console and a probe of varying length. The volume of the sample train must be known to leak check the probe, trap, and console in the field (The tank is leak checked separately in the lab or the field).

## QUALITY ASSURANCE PROCEDURES AND RESULTS

The trap body is constructed from 22" of 0.375" OD x 0.049" wall tubing and packed tightly with quartz glass wool (estimated blockage of 50%). The trap probe is constructed from 22" of 0.125" OD x 0.035" wall tubing for a total trap volume of 10.32 cm<sup>3</sup>.

The console has 82" of 0.250" OD x 0.035" wall tubing and 9" of 0.125" OD x 0.035" wall tubing for a tubing volume of 34.54 cm<sup>3</sup>. The filter holder has a volume of 8 cm<sup>3</sup> for a total console volume of 42.54 cm<sup>3</sup>. The total volume of the trap and console is therefore 52.86 cm<sup>3</sup>. This value is a constant.

The probe volume is a function of the length of the probe. The probes are constructed of 0.250" OD x 0.035" wall tubing and vary in length. The most common probe length is 4'. This length of probe has a volume of 20.02 cm<sup>3</sup> which results in a total train volume of 72.88 cm<sup>3</sup>.

The allowable leak rate is calculated using the following equation:

$$\Delta P = \frac{F P_b \emptyset}{V_t} \quad (0.01)$$

where:

$\Delta P$  = allowable pressure change, cm Hg

$F$  = sampling flow rate, cc/min (80 cc/min)

$P_b$  = barometric pressure, cm Hg

$\emptyset$  = leak check period, min (5 min)

$V_t$  = volume of sample train, cm<sup>3</sup>

For example, the allowable leak rate for a train with a 4' probe at a barometric pressure of 74.2 cm would be:

$$\Delta P = \frac{80 \times 74.2 \times 5}{72.88} \quad (0.01)$$

$$\Delta P = 4.07 \text{ cm (or 40.7 mm)}$$

### ° Method 25A Calibration and Span Gas

The flame ionization analyzers are calibrated as specified in the Reference Method with ultra zero air (< 0.1 ppm THC), low-level, mid-level, and high-level mixtures of propane in air. The calibration standards are certified by USEPA Protocol 1 "Traceability Protocol for Establishing True Concentrations of Gases Used for Calibration and Audits of Continuous Source Emission Monitors".

### ° Barometers

The aneroid field barometers are calibrated with a stationary mercury column barometer prior to each field use. The reference barometer is permanently mounted in the laboratory.

## QUALITY ASSURANCE PROCEDURES AND RESULTS


---

### ° Reagents

All reagents used for the preparation of sample trains, collection and recovery of samples, and analysis meet the requirements of the Reference Methods.

# THERMOCOUPLE CALIBRATION

Thermocouple ID 6B  
 Reference Thermometer 9N911  
 Date 2/25/94  
 Calibrated by D. THOMPSON



| Calibration Point          | Ice Water | Ambient | Boiling Water | Hot Oil |
|----------------------------|-----------|---------|---------------|---------|
| Reference Temperature (°F) | 32        | 66      | 212           | 430     |
| Thermocouple Temp., (°F)   | 32        | 66      | 210           | 433     |
| % Difference               | 0.00%     | 0.00%   | 0.30%         | 0.34%   |


**Note:**

$$\% \text{ Difference} = \frac{(\text{Ref. temp., } ^\circ\text{F} + 460) - (\text{Thermocouple temp., } ^\circ\text{F} + 460)}{(\text{Ref. temp., } ^\circ\text{F} + 460)} \times 100$$

The absolute value of the % Difference must be  $\leq 1.5\%$

# THERMOCOUPLE CALIBRATION

Thermocouple ID K-4 DGM INLET  
Reference Thermometer 9N911  
Date 3/10/94  
Calibrated by D. THOMPSON



| Calibration Point          | Ice Water | Ambient | Boiling Water | Hot Oil |
|----------------------------|-----------|---------|---------------|---------|
| Reference Temperature (°F) | 32        | 71      | 211           | NA      |
| Thermocouple Temp., (°F)   | 31        | 71      | 210           | NA      |
| % Difference               | 0.20%     | 0.00%   | 0.15%         | NA      |


## Note:

$$\% \text{ Difference} = \frac{(\text{Ref. temp., } ^\circ\text{F} + 460) - (\text{Thermocouple temp., } ^\circ\text{F} + 460)}{(\text{Ref. temp., } ^\circ\text{F} + 460)} \times 100$$

The absolute value of the % Difference must be  $\leq 1.5\%$

# THERMOCOUPLE CALIBRATION

Thermocouple ID I-2  
 Reference Thermometer 9N911  
 Date 2/25/94  
 Calibrated by D. THOMPSON




| Calibration Point          | Ice Water | Ambient | Boiling Water | Hot Oil |
|----------------------------|-----------|---------|---------------|---------|
| Reference Temperature (°F) | 32        | 66      | 211           | NA      |
| Thermocouple Temp., (°F)   | 32        | 66      | 210           | NA      |
| Difference                 | 0         | 0       | 1             | NA      |

## Note:

Thermocouple temperature must be  $\pm 2$  °F of reference temperature.

# THERMOCOUPLE CALIBRATION

Thermocouple ID I-5  
Reference Thermometer 9N911  
Date 2/25/94  
Calibrated by D. THOMPSON



| Calibration Point          | Ice Water | Ambient | Boiling Water | Hot Oil |
|----------------------------|-----------|---------|---------------|---------|
| Reference Temperature (°F) | 32        | 68      | 211           | NA      |
| Thermocouple Temp., (°F)   | 32        | 68      | 211           | NA      |
| Difference                 | 0         | 0       | 0             | NA      |


## Note:

Thermocouple temperature must be  $\pm 2$  °F of reference temperature.



# TEMPERATURE DISPLAY CALIBRATION

Temperature Display ID K-4  
 Reference Source Omega SN 102  
 Date 2-23-94  
 Calibrated by D. THOMPSON



| Calibration Point             | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    |
|-------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Reference Temperature (°F)    | 0     | 100   | 200   | 300   | 400   | 500   | 600   | 700   | 800   | 900   | 1000  |
| Temperature Display, K-4 (°F) | 4     | 103   | 206   | 309   | 409   | 510   | 613   | 714   | 815   | 916   | 1008  |
| % Difference                  | 0.87% | 0.54% | 0.91% | 1.18% | 1.05% | 1.04% | 1.23% | 1.21% | 1.19% | 1.18% | 0.55% |

## Note:

$$\% \text{ Difference} = \frac{(\text{Ref. temp., } ^\circ\text{F} + 460) - (\text{Thermocouple temp., } ^\circ\text{F} + 460)}{(\text{Ref. temp., } ^\circ\text{F} + 460)} \times 100$$

The absolute value of the % Difference must be  $\leq 1.5\%$

# Pre-Test Calibration

Calibration date: 2/15/94  
 Console Identification: K-4  
 Calibrated By: Dan Thompson

## Dry Gas Meter

|                             |            | 1       | 2       | 3       | 4       | 5            |
|-----------------------------|------------|---------|---------|---------|---------|--------------|
| Orifice number              |            | 0.2425  | 0.3122  | 0.4535  | 0.5504  | 0.6785       |
| Orifice coefficient         | K'         | 29.22   | 29.22   | 29.21   | 29.22   | 29.22        |
| Barometric pressure         | in. Hg     | 71      | 71      | 72      | 71      | 71           |
| Ambient temperature         | °F         | 19      | 19      | 19      | 19      | 19           |
| Vacuum                      | in. Hg     | 0.31    | 0.52    | 1.20    | 1.80    | 2.70         |
| Orifice ΔH                  | in. H2O    | 10.0    | 10.0    | 10.0    | 10.0    | 10.0         |
| Time                        | minutes    | 228.400 | 232.100 | 299.200 | 236.500 | 244.200      |
| Initail volume              | cubic feet | 231.571 | 236.209 | 305.300 | 243.800 | 253.384      |
| Final volume                | cubic feet | 3.171   | 4.109   | 6.100   | 7.300   | 9.184        |
| Volume metered              | cubic feet | 76      | 76      | 76      | 77      | 80           |
| Inlet initial temperature   | °F         | 74      | 74      | 76      | 75      | 76           |
| Outlet initial temperature  | °F         | 84      | 77      | 79      | 80      | 81           |
| Inlet final temperature     | °F         | 79      | 75      | 77      | 86      | 77           |
| Outlet final temperature    | °F         | 78      | 76      | 77      | 80      | 79           |
| Average temperature         | °F         | 3.039   | 3.960   | 5.871   | 7.006   | 8.850        |
| Volume metered std.         | dscf       | 3.075   | 3.959   | 5.743   | 6.979   | 8.604        |
| Volume through orifice std. | dscf       | 1.012   | 1.000   | 0.978   | 0.996   | 0.972        |
| DGM calibration factor      | Y          |         |         |         |         | <b>0.992</b> |
| <b>AVERAGE Y</b>            |            |         |         |         |         |              |
| DGM ΔH@                     | in. H2O    | 1.769   | 1.802   | 1.976   | 2.005   | 1.991        |
| <b>AVERAGE ΔH@</b>          |            |         |         |         |         | <b>1.909</b> |

DGM Calibration Factor's ( Y ) must be  $\pm 2.0$  % of the average Y. Maximum 1.011  
Minimum 0.972

DGM Orifice ΔH@'s must be  $\pm 0.2$  of the average ΔH@. Maximum 2.109  
Minimum 1.709

## Post Test Calibration Form

|                                                                            |            |         |              |
|----------------------------------------------------------------------------|------------|---------|--------------|
|                                                                            |            |         |              |
| Calibration date:                                                          | 8/15/94    |         |              |
| Console Identification:                                                    | K-4        |         |              |
| Calibrated By:                                                             | T. Bayer   |         |              |
| Job Number:                                                                | F-810      |         |              |
| Client:                                                                    | Siemens    |         |              |
| <b>Dry Gas Meter</b>                                                       |            |         |              |
| Run number / Low Load                                                      |            | 1       | 2            |
| Orifice number                                                             |            | 3       | 4            |
| Orifice coefficient                                                        | K'         | 0.4535  | 0.5504       |
| Barometric pressure                                                        | in. Hg     | 29.62   | 29.62        |
| Ambient temperature                                                        | °F         | 73      | 73           |
| Vacuum                                                                     | in. Hg     | 19      | 19           |
| Orifice ΔH                                                                 | in. H2O    | 1.2     | 1.8          |
| Time                                                                       | minutes    | 10.0    | 10.0         |
| Initail volume                                                             | cubic feet | 139.787 | 150.075      |
| Final volume                                                               | cubic feet | 145.915 | 157.51       |
| Volume metered                                                             | cubic feet | 6.128   | 7.435        |
| Inlet initial temperature                                                  | °F         | 77      | 80           |
| Outlet initial temperature                                                 | °F         | 76      | 78           |
| Inlet final temperature                                                    | °F         | 81      | 84           |
| Outlet final temperature                                                   | °F         | 77      | 79           |
| Average temperature                                                        | °F         | 78      | 80           |
| Volume metered std.                                                        | dscf       | 5.972   | 7.223        |
| Volume through orifice std.                                                | dscf       | 5.818   | 7.062        |
| DGM calibration factor                                                     | Y          | 0.974   | 0.978        |
| <b>AVERAGE Y</b>                                                           |            |         | <b>0.976</b> |
| Dry Gas Meter Calibration Factor's ( Y ) must be ± 2.0 % of the average Y. |            |         |              |
|                                                                            |            | Maximum | 0.996        |
|                                                                            |            | Minimum | 0.956        |

# Method 7E Instrument Interference Response Check

Date: June 6, 1993

Manufacturer: Thermo Environmental Instruments Inc.

Model: 42H NO-NO<sub>2</sub>-NO<sub>x</sub> Chemiluminescence Analyzer

SN: 42H-41303-265


By: Tom Bayer

| Test Gas        | Concentration | Analyzer Output Response<br>( ppm NO <sub>x</sub> ) | % of Span |
|-----------------|---------------|-----------------------------------------------------|-----------|
| O <sub>2</sub>  | 20.9 %        | 0.0                                                 | 0.0       |
| SO <sub>2</sub> | 221.1 ppm     | 2.0                                                 | 0.2       |
| CO <sub>2</sub> | 10.1 %        | 0.0                                                 | 0.0       |
| CO              | 301.0 ppm     | 0.0                                                 | 0.0       |

Total % = 0.2

$$\% \text{ of Span} = \frac{\text{Analyzer Output ( ppm NO}_x \text{ )}}{\text{Analyzer Span ( 1000 )}} \times 100 \quad \text{Total limit} = 2\%$$






| Span gas concentration (ppm) | Calibration response, ppm |     |                  |           | Calibration error (% of span) | System bias (% of span) |           | System drift (% of span) |
|------------------------------|---------------------------|-----|------------------|-----------|-------------------------------|-------------------------|-----------|--------------------------|
|                              | Analyzer                  |     | System injection |           |                               | Pre-test                | Post-test |                          |
|                              | Pre-test                  | 0   | Pre-test         | Post-test |                               |                         |           |                          |
|                              |                           |     |                  |           |                               |                         |           |                          |
| 0                            | 0                         | 151 | 0                | 151       | 1.7                           | 0.2                     | 0.2       | 0.0                      |
| 149                          | 152                       |     |                  |           |                               |                         |           |                          |
| 413                          | 413                       |     |                  |           |                               |                         |           |                          |
| Span value                   |                           |     |                  |           |                               |                         |           |                          |

|                  |     |
|------------------|-----|
| Span value (ppm) | 500 |
|------------------|-----|

| NO2 to NO Conversion efficiency |                           |         |              |
|---------------------------------|---------------------------|---------|--------------|
| Time                            | Conversion response (ppm) |         | Efficiency % |
| Start                           | Maximum                   | Minimum | NA           |
| Stop                            |                           |         |              |

|                              |                                                             |       |            |         |                                                                             |       |            |
|------------------------------|-------------------------------------------------------------|-------|------------|---------|-----------------------------------------------------------------------------|-------|------------|
| Analyzer Calibration error = | Span gas concentration - Analyzer calibration response      | x 100 | Limit = 2% | Drift = | Post test system calibration response - Pretest system calibration response | x 100 | Limit = 5% |
| System bias =                | System calibration response - Analyzer calibration response | Span  |            |         | Span                                                                        |       |            |
| Conversion efficiency =      | Max. conversion response - Min. conversion response         | x 100 | Limit = 5% |         | Max. conversion response                                                    | x 100 | Limit = 2% |




| Span gas<br>concentration<br>( ppm ) | Calibration response, ppm |                  |           |         | Calibration<br>error<br>( % of span ) | System bias<br>( % of span ) |           | System<br>drift<br>( % of span ) |
|--------------------------------------|---------------------------|------------------|-----------|---------|---------------------------------------|------------------------------|-----------|----------------------------------|
|                                      | Analyzer                  | System injection |           | Average |                                       | Pre-test                     | Post-test |                                  |
|                                      |                           | Pre-test         | Post-test |         |                                       |                              |           |                                  |
| 0                                    | 0                         | 0                | 1         | 1       |                                       | 0.2                          | 0.1       | 0.1                              |
| 149                                  | 151                       | 151              | 150       | 151     | 1.1                                   | 0.2                          | 0.1       | 0.1                              |
| 413                                  | 413                       |                  |           |         |                                       |                              |           |                                  |

|                  |
|------------------|
| Span value (ppm) |
| 500              |

| NO2 to NO Conversion efficiency |                           |         |            |
|---------------------------------|---------------------------|---------|------------|
| Time                            | Conversion response (ppm) |         | Efficiency |
| Start                           | Maximum                   | Minimum | %          |
| Stop                            |                           |         | NA         |

Analyzer Calibration error =  $\frac{\text{Span gas concentration} - \text{Analyzer calibration response}}{\text{Span}} \times 100$  Limit = 2% Drift =  $\frac{\text{Post test system calibration response} - \text{Pretest system calibration response}}{\text{Span}} \times 100$  Limit = 5%

System bias =  $\frac{\text{System calibration response} - \text{Analyzer calibration response}}{\text{Span}} \times 100$  Limit = 5% Conversion efficiency =  $\frac{\text{Max. conversion response} - \text{Min. conversion response}}{\text{Max. conversion response}} \times 100$  Limit = 2%



| Span gas concentration (ppm) | Calibration response, ppm |        |           | Calibration error (% of span) | System bias (% of span) |           | System drift (% of span) |
|------------------------------|---------------------------|--------|-----------|-------------------------------|-------------------------|-----------|--------------------------|
|                              | Analyzer                  | System | Injection |                               | Pre-test                | Post-test |                          |
| 0                            | 0                         | 0      | 0         | 0                             | 0.0                     | 0.0       | 0.0                      |
| 149                          | 152                       | 152    | 151       | 1.7                           | 0.2                     | 0.1       | 0.1                      |
| 413                          | 413                       |        |           |                               |                         |           |                          |

|                  |     |
|------------------|-----|
| Span value (ppm) | 500 |
|------------------|-----|

| NO2 to NO Conversion efficiency |                           |         |              |
|---------------------------------|---------------------------|---------|--------------|
| Time                            | Conversion response (ppm) |         | Efficiency % |
| Start                           | Stop                      | Maximum | Minimum      |
|                                 |                           |         | NA           |

Analyzer Calibration error =  $\frac{\text{Span gas concentration} - \text{Analyzer calibration response}}{\text{Span}} \times 100$  Limit = 2% Drift =  $\frac{\text{Post test system calibration response} - \text{Pretest system calibration response}}{\text{Span}} \times 100$  Limit = 5%

System bias =  $\frac{\text{System calibration response} - \text{Analyzer calibration response}}{\text{Span}}$

Conversion efficiency =  $\frac{\text{Max. conversion response} - \text{Min. conversion response}}{\text{Max. conversion response}} \times 100$  Limit = 2%



215-691-2474  
FAX# 215-758-8384

# LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION  
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

## CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER S/T CINCINNATI

P.O NUMBER

### REFERENCE STANDARD

COMPONENT  
NITRIC OXIDE

NIST SRM NO.

GMIS VS. 1685B

CYLINDER NO.

CLM-004735

CONCENTRATION

265.6 PPM

### ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT NITRIC OXIDE

ANALYTICAL PRINCIPLE

FIRST ANALYSIS DATE

Z 0.00 R 2.30

R 2.30 Z 0.00

Z 0.00 C 1.30

U/M VOLTS

ANALYZER MAKE-MODEL-S/N

CHEMILUMINESCENCE

02/07/94

C 1.30 CONC. 150.1

C 1.30 CONC. 150.1

R 2.30 CONC. 150.1

MEAN TEST ASSAY 150.1

THERMO ENVIRON. 14A 14A-35387-250

LAST CALIBRATION DATE

11/30/93

SECOND ANALYSIS DATE

02/14/94

Z 0.00 R 2.27 C 1.27 CONC. 148.6

R 2.27 Z 0.00 C 1.27 CONC. 148.6

Z 0.00 C 1.27 R 2.27 CONC. 148.6

U/M VOLTS MEAN TEST ASSAY 148.6

Received 3/3/94 *g*

THIS CYLINDER NO. SA 8079

HAS BEEN CERTIFIED ACCORDING TO SECTION  
OF TRACEABILITY PROTOCOL NO. 1

PROCEDURE G1

CERTIFIED ACCURACY  $\pm 1.0$  % NIST TRACEABLE

CYLINDER PRESSURE 2000 PSIG

CERTIFICATION DATE 02/14/94

EXPIRATION DATE 02/14/96

CERTIFIED CONCENTRATION

NITRIC OXIDE

149.4 PPM

NITROGEN

BALANCE

ANALYZED BY

*K. Brady*  
KEVIN BRADY

CERTIFIED BY

*Bob Hillard*  
BOB HILLARD





215-691-2474  
FAX# 215-758-8384

# LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION  
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

## CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER S/T CINCINNATI

P.O NUMBER

### REFERENCE STANDARD

COMPONENT  
NITRIC OXIDE

NIST SRM NO.  
GMIS VS. 1687B

CYLINDER NO.  
CLM-000650

CONCENTRATION  
770.1 PPM

### ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT NITRIC OXIDE

ANALYTICAL PRINCIPLE

FIRST ANALYSIS DATE

Z 0.00 R 7.43

R 7.42 Z 0.00

Z 0.00 C 4.00

U/M VOLTS

CHEMILUMINESCENCE

02/28/94

C 4.00 CONC.

C 4.00 CONC.

R 7.43 CONC.

MEAN TEST ASSAY

ANALYZER MAKE-MODEL-S/N

414.6 Z

415.1 R

414.6 Z

414.8 U/M

THERMO ENVIRON. 14A 14A-35387-250

LAST CALIBRATION DATE

02/24/94

SECOND ANALYSIS DATE

03/07/94

0.00 R 7.33 C 3.92 CONC.

7.33 Z 0.00 C 3.92 CONC.

0.00 C 3.93 R 7.35 CONC.

MEAN TEST ASSAY

411.8

411.8

411.8

411.8

THIS CYLINDER NO. SGAL 3426  
HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.4  
OF TRACEABILITY PROTOCOL NO. 1

PROCEDURE G1

CERTIFIED ACCURACY  $\pm 1.0$  % NIST TRACEABLE

CYLINDER PRESSURE 2000 PSIG

CERTIFICATION DATE 03/07/94

EXPIRATION DATE 03/07/96

CERTIFIED CONCENTRATION

NITRIC OXIDE

413.3 PPM

NITROGEN

BALANCE

ANALYZED BY

KEVIN BRADY

CERTIFIED BY

BOB HILLARD

# K & B Design, Inc.

Industrial Ventilation Engineering - Stack Testing

3131 Disney Street Cincinnati, OH 45209 (513) 351-6200

FAX (513) 351-4071

Dayton Regional Operations (513) 436-1811

Prepared By T. BAYER Date 8-11-94

|             |                          |           |                      |
|-------------|--------------------------|-----------|----------------------|
| Client      | <u>SIEMENS</u>           | Sheet     | <u>1</u> of <u>1</u> |
| Project     | <u>NOx Testing</u>       | Proj. No. | <u>F-810</u>         |
| Task        | <u>Boiler</u>            |           |                      |
| Sheet Title | <u>Natural Gas Usage</u> |           |                      |

## Process DATA

Boiler operated at % CAPACITY  
For ALL test RUNS.

Gas Meter DATA (reading  $\times 600 = \text{ft}^3$ )

|       |      |       |                 |                                  |
|-------|------|-------|-----------------|----------------------------------|
| RUN 1 | Time | 9:10  | Initial reading | <sup>10</sup> <del>677</del> 275 |
|       |      | 10:10 | Final reading   | <u>677 303</u>                   |

TOTAL 28.0

Gas Used 16,800  $\text{ft}^3$

|       |      |       |                 |               |
|-------|------|-------|-----------------|---------------|
| RUN 2 | Time | 10:30 | Initial Reading | 677313        |
|       |      | 11:30 | Final reading   | <u>677342</u> |

TOTAL 29.0

Gas Used 17,400  $\text{ft}^3$

|       |      |       |                 |               |
|-------|------|-------|-----------------|---------------|
| RUN 3 | Time | 11:50 | Initial Reading | 677352        |
|       |      | 12:50 | Final Reading   | <u>677381</u> |

TOTAL 29.0

Gas Used 17,400  $\text{ft}^3$

Linda Kottengrass  
287-3925  
CG & E

Requested Loc ID / Meter : 0058  
Requested Class : RTU  
Requested Effective Date : 08/01/94  
Requested Release Date : 03/01/94  
Requested Release Time : 16:53:31:03

YONG GAS TRANSMISSION CORPORATION  
GAS ANALYSIS SYSTEM  
RELEASED ANALYSIS REPORT

Printed By : MMS/AMG/S  
Printed Date : 03/01/94  
Printed Time : 14:53:13:03  
Page : 1

Sample Loc ID : 0058 LAMSON  
Source : WLD Type : COMP  
Chg Flag : A Comments :

Measure Point : 1307  
Sample Data : 02/27/94

Effective Date : 02/28/94  
Sample Origin : ACT

COMPONENTS

| Comp Code | Component Name | Press Base | Mole Percent | BTU Factor | BTU Value | SPG Factor | SPG Value | Max-Hydro | Mora |
|-----------|----------------|------------|--------------|------------|-----------|------------|-----------|-----------|------|
| 02        | ETHYLENE       |            | 0.416738     |            |           | 0.36723    | 0.00403   | F         | F    |
| 002       | ETHYLENE       |            | 1.048223     |            |           | 1.51865    | 0.01593   | F         | F    |
| 004       | ETHYLENE       |            | 95.832393    | 1012.00    | 969.82    | 0.55382    | 0.53883   | F         | F    |
| 006       | ETHYLENE       |            | 2.215690     | 1773.70    | 19.37     | 1.43824    | 0.00385   | F         | F    |
| 008       | ETHYLENE       |            | 0.291120     | 2522.10    | 7.09      | 1.32256    | 0.00428   | F         | F    |
| 010       | ETHYLENE       |            | 0.055782     | 3268.30    | 1.82      | 2.06584    | 0.00132   | F         | F    |
| 012       | ETHYLENE       |            | 0.057805     | 3270.10    | 1.80      | 2.06584    | 0.00132   | F         | F    |
| 014       | ETHYLENE       |            | 0.026484     | 4011.10    | 1.06      | 2.19415    | 0.00056   | F         | F    |
| 016       | ETHYLENE       |            | 0.017116     | 4018.30    | 0.69      | 2.19415    | 0.00043   | F         | F    |
| 018       | ETHYLENE       |            | 0.014732     | 5141.10    | 2.30      | 3.23762    | 0.00144   | F         | F    |
| 020       | ETHYLENE       |            | 0.040000     |            |           |            |           | F         | F    |
| 022       | ETHYLENE       |            | 0.583940     |            |           |            |           | F         | F    |
| 024       | ETHYLENE       |            | 0.997835     |            |           |            |           | F         | F    |
| 026       | ETHYLENE       |            | 1026.042926  |            |           |            |           | F         | F    |

| Comp Code | Press Base | BTU/ct Dry  | BTU/ct Sat  | BTU/ct Am Dml |
|-----------|------------|-------------|-------------|---------------|
| 002       | 14.738     | 1026.200000 | 1899.300000 |               |
| 004       | 15.076     | 1046.800000 | 1809.500000 |               |
| 006       | 16.554     | 1028.700000 | 1809.700000 |               |

X=1025 BTU/ct


EXCLUSIVE RIGHTS  
02/28/94 - 03/01/94

Release Date : 02/28/94 Release Time : 11:05:12:37

# METHOD 1-TRAVERSE POINT LOCATION FOR RECTANGULAR DUCTS

Client SIEMENS Job # F-810 Date 8-11-94  
 Source Boiler 2 Site Outlet Stack By TB

INSIDE DUCT DIMENSIONS 51.0"  
 NIPPLE DEPTH 3.0"  
 EQUIVALENT STACK DIAMETER 48  
 DISTANCE (A) UPSTREAM OF DISTURBANCE ~20'  
 STACK DIAMETERS >2.0  
 DISTANCE (B) DOWNSTREAM OF DISTURBANCE ~12.0'  
 STACK DIAMETERS 3  
 NUMBER OF TRAVERSE POINTS 16  
 MATRIX (8x8)



| TRAVERSE POINT NUMBER | INSIDE OF NEAR WALL TO TRAVERSE PT. | NIPPLE DEPTH | TRAVERSE POINT LOCATION | PORT NO. | DISTANCE FROM EDGE OF STACK |
|-----------------------|-------------------------------------|--------------|-------------------------|----------|-----------------------------|
| 1                     | 0.032                               | 48"          | 1.5                     | 3.0"     | 4.5                         |
| 2                     | 0.105                               |              | 5.0                     |          | 8.0                         |
| 3                     | 0.194                               |              | 9.3                     |          | 12.3                        |
| 4                     | 0.323                               |              | 15.5                    |          | 18.5                        |
| 5                     | 0.677                               |              | 32.5                    |          | 35.5                        |
| 6                     | 0.806                               |              | 38.7                    |          | 41.7                        |
| 7                     | 0.895                               |              | 43.0                    |          | 46.0                        |
| 8                     | 0.968                               |              | 46.5                    |          | 49.5                        |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |
|                       |                                     |              |                         |          |                             |

## METHOD 2-VELOCITY DATA

Client Siemens  
Job # F-810  
Date 8-11-94  
Source Boiler  
Site Outlet Stack  
Run 1  
Barometric Pressure (Pb) 29.50 in Hg  
Static Pressure (Pg) - 0.11 in H<sub>2</sub>O

Pitot Tube # 6B Cp 0.84  
Pre-Test leak check ✓ Post-test leak check ✓  
Thermocouple # 6B Duct Dimensions 48.0" Ø


**MOISTURE DATA**  
Wet Bulb TC# — Dry Bulb TC # —  
Temperature : Wet — Dry —

**FYRITE DATA**  
Oxygen (%) — Carbon Dioxide (%) —

[illegible]

## PRELIMINARY DATA

Bws: \_\_\_\_\_  
 $\Delta P$ : \_\_\_\_\_  
 $\sqrt{\Delta P}$ : 0.202  
Ts: 230  
Vs: 13.6 fps  
Qa: 10.239 acfm  
Qsd: 7.063 dscfm  
Qs: \_\_\_\_\_ scfm



|                  |      |
|------------------|------|
| % O <sub>2</sub> |      |
| 12.2             |      |
| <del>13.0</del>  |      |
| 11.8             |      |
| <hr/>            |      |
|                  | 12.0 |

Meter box # K-4 Sample box # 5/scr #1  
 Meter  $\Delta H$  @ 1.109 Meter Y factor 0.992  
 Filter #      Pitot # / Cp       
 Probe length/type 2' SS  
 Stack TC #      Oven TC #       
 Impinger TC # I-5  
 Duct dimensions 48.0" Ø  
 Operators DB, BF, RF

[illegible]

# METHOD 3-ORSAT DATA

Client Siemens Job # F-810 Date 8-11-94  
 Source Boiler Site Outlet STACK Run 1

|         |          | CO <sub>2</sub> | O <sub>2</sub> (1) | CO (2) | N <sub>2</sub> (3) |
|---------|----------|-----------------|--------------------|--------|--------------------|
| Run 1   | Actual % | 4.2             | 16.2               |        | 100.0              |
|         | Net %    | 4.2             | 12.0               | —      | 83.8               |
| Run 2   | Actual % | 4.2             | 16.2               |        | 100.0              |
|         | Net %    | 4.2             | 12.0               | —      | 83.8               |
| Run 3   | Actual % | 4.2             | 16.2               |        | 100.0              |
|         | Net %    | 4.2             | 12.0               | —      | 83.8               |
| Average |          | 4.2             | 12.0               | ND     | 83.8               |

- (1) Net is actual O<sub>2</sub> reading minus the actual CO<sub>2</sub> reading.  
 (2) Net is actual CO reading minus the actual O<sub>2</sub> reading.  
 (3) Net is 100 minus the actual CO reading.

| ACTUAL Fo:                                                                             | EXPECTED Fo:                                                                                                                                                                                                                                                                                          |
|----------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Orsat data                                                                             | Fuel type Fo range                                                                                                                                                                                                                                                                                    |
| $Fo = \frac{20.9\% - \%O_2}{\%CO_2}$ $Fo = \frac{20.9\% - (12.0)}{(4.2)}$ $Fo = 2.119$ | Coal:<br>Anthracite and lignite..... 1.016-1.130<br>Bituminous..... 1.083-1.230<br>Oil:<br>Distillate..... 1.260-1.413<br>Residual..... 1.210-1.370<br>Gas:<br>Natural..... 1.600-1.836<br>Propane..... 1.434-1.586<br>Butane..... 1.405-1.553<br>Wood..... 1.000-1.120<br>Wood bark..... 1.003-1.130 |
| Expected Fo Value = <u>1.600-1.836</u>                                                 |                                                                                                                                                                                                                                                                                                       |



# SAMPLE RECOVERY DATA

Client Siemens  
Source Boiler

Job # F-810  
Site Outlet

Date 8-11-94  
Run 1

Filter #     

Glassware set # 1

Sample box # 25

| Impinger #<br>Wt. | #1    | #2    | #3    | #4    | #5 | TOTAL |
|-------------------|-------|-------|-------|-------|----|-------|
| Final (g)         | 685.7 | 722.1 | 582.6 | 745.2 |    |       |
| Initial (g)       | 698.8 | 710.9 | 579.6 | 734.2 |    |       |
| Net (g)           | 86.9  | 11.2  | 3.0   | 11.0  |    | 112.1 |

## RECOVERED SAMPLE

DESCRIPTION OF PARTICULATE ON FILTER     

COLOR OF SILICA GEL 20% spent

COMMENTS none

## BALANCE CHECK EX 1200A S/N C0235207

|                                    |                         |
|------------------------------------|-------------------------|
| TEST WEIGHT<br>500 GM<br>#840500.4 | INITIAL WEIGHT<br>500.0 |
|                                    | FINAL WEIGHT<br>500.0   |

RECOVERED BY R. Felt





Client Siemens  
Job # F-810  
Date 8-11-94  
Source Boiler  
Site Outlet stack  
Run 2  
Barometric Pressure (Pb) 29.50 in Hg  
Static Pressure (Pg) -0.11 in H<sub>2</sub>O

Pitot Tube # 6B Cp 0.84  
Pre-Test leak check ✓ Post-test leak check ✓  
Thermocouple # 6B Duct Dimensions 48.0" Ø

**MOISTURE DATA**  
Wet Bulb TC# — Dry Bulb TC # —  
Temperature : Wet — Dry —


**FYRITE DATA**  
Oxygen (%) — Carbon Dioxide (%) —

Oxygen (%) \_\_\_\_\_

Carbon Dioxide (%) \_\_\_\_\_

[illegible]

Bws: \_\_\_\_\_  
 $\Delta P$ : \_\_\_\_\_  
 $\sqrt{\Delta P}$ : 0.211  
Ts: 231  
Vs: \_\_\_\_\_ fps  
Qa: \_\_\_\_\_ acfm  
Qsd: \_\_\_\_\_ dscfm  
Qs: \_\_\_\_\_ scfm



|      |      |      |      |      |
|------|------|------|------|------|
| 11.8 | 11.9 | 11.7 | 11.9 | 11.8 |
|------|------|------|------|------|

\*235.936



# METHOD 3-ORSAT DATA

Client Siemens Job # F-810 Date 8-11-94  
 Source Boiler Site Outlet Stack Run 2

|         |          | CO <sub>2</sub> | O <sub>2</sub> (1) | CO (2) | N <sub>2</sub> (3) |
|---------|----------|-----------------|--------------------|--------|--------------------|
| Run 1   | Actual % | 4.3             | 16.1               |        | 100.0              |
|         | Net %    | 4.3             | 11.8               | —      | 83.9               |
| Run 2   | Actual % | 4.3             | 16.1               |        | 100.0              |
|         | Net %    | 4.3             | 11.8               | —      | 83.9               |
| Run 3   | Actual % | 4.3             | 16.1               |        | 100.0              |
|         | Net %    | 4.3             | 11.8               | —      | 83.9               |
| Average |          | 4.3             | 11.8               | ND     | 83.9               |

- (1) Net is actual O<sub>2</sub> reading minus the actual CO<sub>2</sub> reading.  
 (2) Net is actual CO reading minus the actual O<sub>2</sub> reading.  
 (3) Net is 100 minus the actual CO reading.

| ACTUAL Fo:                                                                             | EXPECTED Fo:                |             |
|----------------------------------------------------------------------------------------|-----------------------------|-------------|
| Orsat data                                                                             | Fuel type                   | Fo range    |
| $Fo = \frac{20.9\% - \%O_2}{\%CO_2}$ $Fo = \frac{20.9\% - (11.8)}{(4.3)}$ $Fo = 2.116$ | Coal:                       |             |
|                                                                                        | Anthracite and lignite..... | 1.016-1.130 |
|                                                                                        | Bituminous.....             | 1.083-1.230 |
|                                                                                        | Oil:                        |             |
|                                                                                        | Distillate.....             | 1.260-1.413 |
|                                                                                        | Residual.....               | 1.210-1.370 |
|                                                                                        | Gas:                        |             |
|                                                                                        | Natural.....                | 1.600-1.836 |
|                                                                                        | Propane.....                | 1.434-1.586 |
|                                                                                        | Butane.....                 | 1.405-1.553 |
|                                                                                        | Wood.....                   | 1.000-1.120 |
|                                                                                        | Wood bark.....              | 1.003-1.130 |
| Expected Fo Value = <u>1.600-1.836</u>                                                 |                             |             |

# SAMPLE RECOVERY DATA

Client Siemens Job # F-810 Date 8-11-94  
 Source Boiler Site Outlet Run 2

Filter #      Glassware set # 2 Sample box # 2

| Impinger #<br>wt. | #1    | #2    | #3    | #4    | #5 | TOTAL |
|-------------------|-------|-------|-------|-------|----|-------|
| Final (g)         | 702.2 | 749.4 | 564.2 | 652.6 |    |       |
| Initial (g)       | 608.4 | 736.6 | 561.3 | 642.5 |    |       |
| Net (g)           | 93.8  | 12.8  | 2.9   | 10.1  |    | 119.6 |

## RECOVERED SAMPLE

DESCRIPTION OF PARTICULATE ON FILTER       
 COLOR OF SILICA GEL 50% Spent  
 COMMENTS NONE

## BALANCE CHECK EX 1200A S/N C0235207

|                                    |                         |
|------------------------------------|-------------------------|
| TEST WEIGHT<br>500 GM<br>#840500.4 | INITIAL WEIGHT<br>500.0 |
|                                    | FINAL WEIGHT<br>500.0   |

RECOVERED BY T. Bayler




Client Siemens  
Job # F-810  
Date 8-11-94  
Source Boiler  
Site Outlet Stack  
Run 3  
Barometric Pressure (Pb) 29.50 in Hg  
Static Pressure (Pg) -0.11 in H<sub>2</sub>O

Pitot Tube # 6B Cp 0.84  
Pre-Test leak check ✓ Post-test leak check ✓  
Thermocouple # 6B Duct Dimensions 48.0" Ø  
**MOISTURE DATA**  
Wet Bulb TC#      Dry Bulb TC #       
Temperature : Wet      Dry       
**FYRITE DATA**  
Oxygen (%)      Carbon Dioxide (%)     

[illegible]

## PRELIMINARY DATA

Bws: \_\_\_\_\_  
 ΔP: \_\_\_\_\_  
 ΔP: 0.211  
 Ts: 232  
 Vs: \_\_\_\_\_ fps  
 Qa: \_\_\_\_\_ acfm  
 Qsd: \_\_\_\_\_ dscfm  
 Qs: \_\_\_\_\_ scfm



Client Siemens Meter box # K-4 Sample box # 5/5CT #3 C factor — Reference  $\Delta P$  —

Job # F-810 Date 8-11-94 Meter  $\Delta H$  @ 1.909 Meter Y factor 0.993 Nozzle I.D. — — Avg. —

Source Boiler Filter # — Pitot # / Cp — Pretest leak rate 0.001 cfm @ 10 "Hg

Site Outlet Stack Probe length/type 2' SS Post-test leak rate 0.002 cfm @ 4 "Hg

Run # 3 Stack TC # — Oven TC # — Pitot tube leak check: Pre — Post —

Sample type M-4 Impinger TC # I-5 Orsat train leak check: Pre ✓ Post ✓

Barometric pressure (Pb), in Hg — Duct dimensions 48" Ø Record data every 10.0 Minutes

Static pressure (Pg), in H<sub>2</sub>O — Operators TB, RFE, BF Page 1 of 1

[illegible]

|    |      |      |      |      |
|----|------|------|------|------|
| %O | 11.8 | 11.7 | 11.9 | 11.8 |
|----|------|------|------|------|

# METHOD 3-ORSAT DATA

Client Siemens Job # E-810 Date 8-11-94  
 Source Boiler Site Outlet STACK Run 3

|         |          | CO <sub>2</sub> | O <sub>2</sub> (1) | CO (2) | N <sub>2</sub> (3) |
|---------|----------|-----------------|--------------------|--------|--------------------|
| Run 1   | Actual % | 4.3             | 16.2               |        | 100.0              |
|         | Net %    | 4.3             | 11.9               | —      | 83.8               |
| Run 2   | Actual % | 4.3             | 16.2               |        | 100.0              |
|         | Net %    | 4.3             | 11.9               | —      | 83.8               |
| Run 3   | Actual % | 4.3             | 16.2               |        | 100.0              |
|         | Net %    | 4.3             | 11.9               | —      | 83.8               |
| Average |          | 4.3             | 11.9               | ND     | 83.8               |

- (1) Net is actual O<sub>2</sub> reading minus the actual CO<sub>2</sub> reading.  
 (2) Net is actual CO reading minus the actual O<sub>2</sub> reading.  
 (3) Net is 100 minus the actual CO reading.

| ACTUAL Fo:                                                                                         | EXPECTED Fo:                                                                                                                                                                                                                                                                                          |
|----------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Orsat data                                                                                         | Fuel type Fo range                                                                                                                                                                                                                                                                                    |
| $Fo = \frac{20.9\% - \%O_2}{\%CO_2}$ $Fo = \frac{20.9\% - (11.9)}{(4.3)}$ $Fo = \underline{2.093}$ | Coal:<br>Anthracite and lignite..... 1.016-1.130<br>Bituminous..... 1.083-1.230<br>Oil:<br>Distillate..... 1.260-1.413<br>Residual..... 1.210-1.370<br>Gas:<br>Natural..... 1.600-1.836<br>Propane..... 1.434-1.586<br>Butane..... 1.405-1.553<br>Wood..... 1.000-1.120<br>Wood bark..... 1.003-1.130 |
| Expected Fo Value = <u>1.600-1.836</u>                                                             |                                                                                                                                                                                                                                                                                                       |

# SAMPLE RECOVERY DATA

Client Sewans Job # F-810 Date 8-11-94  
 Source Boiler Site Outlet Run 3

Filter # 1 Glassware set # 3 Sample box # 5

| Impinger #<br>wt. | #1    | #2    | #3    | #4    | #5 | TOTAL |
|-------------------|-------|-------|-------|-------|----|-------|
| Final (g)         | 777.6 | 732.1 | 585.3 | 754.6 |    |       |
| Initial (g)       | 685.7 | 722.1 | 582.6 | 745.2 |    |       |
| Net (g)           | 91.9  | 10.0  | 2.7   | 9.4   |    | 114.0 |

## RECOVERED SAMPLE

DESCRIPTION OF PARTICULATE ON FILTER \_\_\_\_\_  
 COLOR OF SILICA GEL 50% Spent  
 COMMENTS NONE

## BALANCE CHECK EX 1200A S/N C0235207

|                                    |                                |
|------------------------------------|--------------------------------|
| TEST WEIGHT<br>500 GM<br>#840500.4 | INITIAL WEIGHT<br><u>500.0</u> |
|                                    | FINAL WEIGHT<br><u>500.0</u>   |

RECOVERED BY T. Bajer





# METHOD 7E CALIBRATION DATA

Client Siemens Job # F-810 Date 8-11-94 Calibration Console #2  
 Source Boiler #2 Site Outlet Stack Analyzer NOX #1 Operator TB, BFE, RE

Span 0-500 ppm

Start time 9:10 AM Stop time 10:10 AM

Run# 1

| Span gas concentration (ppm) | Calibration response, ppm |        | Analyzer calibration error (% of span) | System bias (% of span) |           | Drift (% of span) |
|------------------------------|---------------------------|--------|----------------------------------------|-------------------------|-----------|-------------------|
|                              | Analyzer                  | System |                                        | Pre-test                | Post-test |                   |
| 0                            | 0                         | 0      |                                        |                         |           |                   |
| 149.4                        | 152                       | 151    |                                        |                         |           |                   |
| 413.3                        | 413                       | 151    |                                        |                         |           |                   |

Span 0-500 ppm

Start time 10:30 Stop time 11:30

Run# 2

| Span gas concentration (ppm) | Calibration response, ppm |        | Analyzer calibration error (% of span) | System bias (% of span) |           | Drift (% of span) |
|------------------------------|---------------------------|--------|----------------------------------------|-------------------------|-----------|-------------------|
|                              | Analyzer                  | System |                                        | Pre-test                | Post-test |                   |
| 0                            | 0                         | 0      |                                        |                         |           |                   |
| 149                          | 151                       | 151    |                                        |                         |           |                   |
| 413                          | 413                       | 150    |                                        |                         |           |                   |

Span 0-500 ppm

Start time 11:50 Stop time 12:50

Run# 3

| Span gas concentration (ppm) | Calibration response, ppm |        | Analyzer calibration error (% of span) | System bias (% of span) |           | Drift (% of span) |
|------------------------------|---------------------------|--------|----------------------------------------|-------------------------|-----------|-------------------|
|                              | Analyzer                  | System |                                        | Pre-test                | Post-test |                   |
| 0                            | 0                         | 0      |                                        |                         |           |                   |
| 149                          | 152                       | 152    |                                        |                         |           |                   |
| 413                          | 413                       | 151    |                                        |                         |           |                   |

| NO2 to NO Conversion efficiency |                           |         |              |
|---------------------------------|---------------------------|---------|--------------|
| Time                            | Conversion response (ppm) |         | Efficiency % |
|                                 | Maximum                   | Minimum |              |
| Start                           | —                         | —       | NA.          |
| Stop                            | —                         | —       |              |

☒ NO2 to NO conversion efficiency not required. Previous test data shows NO2 is less than 5% of the NOx concentration.

Response Time Up-scale 180 sec. Down-scale 150 sec.

|                              |                                                                             |   |     |            |
|------------------------------|-----------------------------------------------------------------------------|---|-----|------------|
| Analyzer Calibration error = | Span gas concentration - Analyzer calibration response                      | x | 100 | Limit = 2% |
| System bias =                | System calibration response - Analyzer calibration response                 | x | 100 | Limit = 5% |
| Drift =                      | Post test system calibration response - Pretest system calibration response | x | 100 | Limit = 5% |
| Conversion efficiency =      | Max. conversion response - Min. conversion response                         | x | 100 | Limit = 2% |

width 671

413 ppm

zero

# PRE-TEST CALIBRATION

Range 0-500

Chart Speed 20 cm/hr

8-11-94

Boiler # 2

90% of Rated Cap.

SIEMENS


F-810


099

KOKUSAI CHART

1000cm

②





START RUN 2 10:30 AM

system  
1419 ppm

1419 ppm

413 ppm

zero

RUN 2 Pre-Test Calibration

4

YOKOGAWA B931 AY 3045-15

KOKUSAI CHART

Chart Paper Jammed

11:09

NOX

(5)

RUN 3 Pre-Test Calibration

RUN 2 Post-Test CAL

END RUN 2 11:30 AM

system  
149 ppm

zero →


⑦

930


KOKUSAI CHART

940

YOKOGAWA B9531A 3045-15







YOKOGAWA ◆ B9511AY (3045-15)

YOKOGAWA CHART

890

5

4

3

2

1

0

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

101

102

103

104

105

106

107

108

109

110

111

112

113

114

115

116

117

118

119

120

121

122

123

124

125

126

127

128

129

130

131

132

133

134

135

136

137

138

139

140

141

142

143

144

145

146

147

148

149

150

151

152

153

154

155

156

157

158

159

160

161

162

163

164

165

166

167

168

169

170

171

172

173

174

175

176

177

178

179

180

181

182

183

184

185

186

187

188

189

190

191

192

193

194

195

196

197

198

199

200

201

202

203

204

205

206

207

208

209

210

211

212

213

214

215

216

217

218

219

220

221

222

223

224

225

226

227

228

229

230

231

232

233

234

235

236

237

238

239

240

241

242

243

244

245

246

247

248

249

250

251

252

253

254

255

256

257

258

259

260

261

262

263

264

265

266

267

268

269

270

271

272

273

274

275

276

277

278

279

280

281

282

283

284

285

286

287

288

289

290

291

292

293

294

295

296

297

298

299

300

301

302

303

304

305

306

307

308

309

310

311

312

313

314

315

316

317

318

319

320

321

322

323

324

325

326

327

328

329

330

331

332

333

334

335

336

337

338

339

340

341

342

343

344

345

346

347

348

349

350

351

352

353

354

355

356

357

358

359

360

361

362

363

364

365

366

367

368

# Run 1 Boiler 2 NOx Log

| Run 1<br>Date | Time    | NOx ppm | NO2 ppm | NO ppm |
|---------------|---------|---------|---------|--------|
|               |         | 41      | 0       | 40     |
| 11-Aug-94     | 9:10:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:10:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:10:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:11:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:11:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:11:52 | 41      | 0       | 40     |
| 11-Aug-94     | 9:12:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:12:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:12:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:13:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:13:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:13:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:14:12 | 41      | 0       | 41     |
| 11-Aug-94     | 9:14:32 | 41      | 0       | 41     |
| 11-Aug-94     | 9:14:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:15:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:15:32 | 41      | 0       | 40     |
| 11-Aug-94     | 9:15:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:16:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:16:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:16:52 | 39      | 0       | 39     |
| 11-Aug-94     | 9:17:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:17:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:17:52 | 39      | 0       | 39     |
| 11-Aug-94     | 9:18:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:18:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:18:52 | 39      | 0       | 39     |
| 11-Aug-94     | 9:19:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:19:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:19:52 | 39      | 0       | 39     |
| 11-Aug-94     | 9:20:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:20:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:20:52 | 39      | 0       | 39     |
| 11-Aug-94     | 9:21:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:21:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:21:52 | 39      | 0       | 39     |
| 11-Aug-94     | 9:22:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:22:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:22:52 | 39      | 0       | 39     |
| 11-Aug-94     | 9:23:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:23:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:23:52 | 39      | 0       | 40     |
| 11-Aug-94     | 9:24:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:24:32 |         |         |        |

# Run 1 Boiler 2 NOx Log

| Run 1     |         |         |         |        |
|-----------|---------|---------|---------|--------|
| Date      | Time    | NOx ppm | NO2 ppm | NO ppm |
| 11-Aug-94 | 9:24:52 | 39      | 0       | 40     |
| 11-Aug-94 | 9:25:12 | 40      | 0       | 40     |
| 11-Aug-94 | 9:25:32 | 40      | 0       | 40     |
| 11-Aug-94 | 9:25:52 | 40      | 0       | 40     |
| 11-Aug-94 | 9:26:12 | 40      | 0       | 40     |
| 11-Aug-94 | 9:26:32 | 40      | 0       | 40     |
| 11-Aug-94 | 9:26:52 | 40      | 0       | 40     |
| 11-Aug-94 | 9:27:12 | 40      | 0       | 40     |
| 11-Aug-94 | 9:27:32 | 40      | 0       | 40     |
| 11-Aug-94 | 9:27:52 | 40      | 0       | 40     |
| 11-Aug-94 | 9:28:12 | 39      | 0       | 40     |
| 11-Aug-94 | 9:28:32 | 40      | 0       | 39     |
| 11-Aug-94 | 9:28:52 | 40      | 0       | 40     |
| 11-Aug-94 | 9:29:12 | 39      | 0       | 39     |
| 11-Aug-94 | 9:29:32 | 39      | 0       | 39     |
| 11-Aug-94 | 9:29:52 | 39      | 0       | 39     |
| 11-Aug-94 | 9:30:12 | 39      | 0       | 39     |
| 11-Aug-94 | 9:30:32 | 39      | 0       | 39     |
| 11-Aug-94 | 9:30:52 | 39      | 0       | 39     |
| 11-Aug-94 | 9:31:12 | 39      | 0       | 39     |
| 11-Aug-94 | 9:31:32 | 39      | 0       | 39     |
| 11-Aug-94 | 9:31:52 | 39      | 0       | 39     |
| 11-Aug-94 | 9:32:12 | 39      | 0       | 39     |
| 11-Aug-94 | 9:32:32 | 39      | 0       | 39     |
| 11-Aug-94 | 9:32:52 | 39      | 0       | 39     |
| 11-Aug-94 | 9:33:12 | 39      | 0       | 39     |
| 11-Aug-94 | 9:33:32 | 39      | 0       | 39     |
| 11-Aug-94 | 9:33:52 | 39      | 0       | 39     |
| 11-Aug-94 | 9:34:12 | 39      | 0       | 39     |
| 11-Aug-94 | 9:34:32 | 39      | 0       | 39     |
| 11-Aug-94 | 9:35:08 | 39      | 0       | 39     |
| 11-Aug-94 | 9:35:12 | 39      | 0       | 39     |
| 11-Aug-94 | 9:35:32 | 40      | 0       | 40     |
| 11-Aug-94 | 9:35:52 | 40      | 0       | 40     |
| 11-Aug-94 | 9:36:12 | 40      | 0       | 40     |
| 11-Aug-94 | 9:36:32 | 40      | 0       | 40     |
| 11-Aug-94 | 9:36:52 | 40      | 0       | 40     |
| 11-Aug-94 | 9:37:12 | 40      | 0       | 40     |
| 11-Aug-94 | 9:37:32 | 40      | 0       | 40     |
| 11-Aug-94 | 9:37:52 | 41      | 0       | 40     |
| 11-Aug-94 | 9:38:12 | 41      | 0       | 40     |
| 11-Aug-94 | 9:38:32 | 40      | 0       | 40     |
| 11-Aug-94 | 9:38:52 | 40      | 0       | 40     |
| 11-Aug-94 | 9:39:12 | 40      | 0       | 40     |

# Run 1 Boiler 2 NOx Log

| Run 1<br>Date | Time    | NOx ppm | NO2 ppm | NO ppm |
|---------------|---------|---------|---------|--------|
|               |         | 40      | 0       | 40     |
| 11-Aug-94     | 9:39:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:39:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:40:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:40:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:40:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:41:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:41:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:41:52 | 41      | 0       | 41     |
| 11-Aug-94     | 9:42:12 | 41      | 0       | 41     |
| 11-Aug-94     | 9:42:32 | 41      | 0       | 41     |
| 11-Aug-94     | 9:42:52 | 41      | 0       | 41     |
| 11-Aug-94     | 9:43:12 | 41      | 0       | 40     |
| 11-Aug-94     | 9:43:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:43:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:44:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:44:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:44:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:45:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:45:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:45:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:46:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:46:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:46:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:47:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:47:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:47:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:48:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:48:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:48:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:49:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:49:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:49:52 | 41      | 0       | 41     |
| 11-Aug-94     | 9:50:12 | 41      | 0       | 41     |
| 11-Aug-94     | 9:50:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:50:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:51:12 | 39      | 0       | 39     |
| 11-Aug-94     | 9:51:32 | 39      | 0       | 39     |
| 11-Aug-94     | 9:51:52 | 39      | 0       | 40     |
| 11-Aug-94     | 9:52:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:52:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:52:52 | 40      | 0       | 40     |
| 11-Aug-94     | 9:53:12 | 40      | 0       | 40     |
| 11-Aug-94     | 9:53:32 | 40      | 0       | 40     |
| 11-Aug-94     | 9:53:52 | 40      | 0       | 40     |

# Run 1 Boiler 2 NOx Log

| Run 1<br>Date | Time     | NOx ppm | NO2 ppm | NO ppm |
|---------------|----------|---------|---------|--------|
|               |          | 40      | 0       | 40     |
| 11-Aug-94     | 9:54:12  | 40      | 0       | 40     |
| 11-Aug-94     | 9:54:32  | 40      | 0       | 40     |
| 11-Aug-94     | 9:54:52  | 40      | 0       | 40     |
| 11-Aug-94     | 9:55:12  | 40      | 0       | 40     |
| 11-Aug-94     | 9:55:32  | 40      | 0       | 40     |
| 11-Aug-94     | 9:55:52  | 40      | 0       | 40     |
| 11-Aug-94     | 9:56:12  | 41      | 0       | 41     |
| 11-Aug-94     | 9:56:32  | 41      | 0       | 41     |
| 11-Aug-94     | 9:56:52  | 41      | 0       | 41     |
| 11-Aug-94     | 9:57:12  | 41      | 0       | 41     |
| 11-Aug-94     | 9:57:32  | 41      | 0       | 41     |
| 11-Aug-94     | 9:57:52  | 40      | 0       | 40     |
| 11-Aug-94     | 9:58:12  | 40      | 0       | 40     |
| 11-Aug-94     | 9:58:32  | 40      | 0       | 40     |
| 11-Aug-94     | 9:58:52  | 40      | 0       | 40     |
| 11-Aug-94     | 9:59:12  | 40      | 0       | 40     |
| 11-Aug-94     | 9:59:32  | 40      | 0       | 40     |
| 11-Aug-94     | 9:59:52  | 40      | 0       | 40     |
| 11-Aug-94     | 10:00:12 | 40      | 0       | 40     |
| 11-Aug-94     | 10:00:32 | 40      | 0       | 40     |
| 11-Aug-94     | 10:00:52 | 40      | 0       | 40     |
| 11-Aug-94     | 10:01:12 | 40      | 0       | 40     |
| 11-Aug-94     | 10:01:32 | 40      | 0       | 40     |
| 11-Aug-94     | 10:01:52 | 40      | 0       | 40     |
| 11-Aug-94     | 10:02:12 | 40      | 0       | 40     |
| 11-Aug-94     | 10:02:32 | 40      | 0       | 40     |
| 11-Aug-94     | 10:02:52 | 40      | 0       | 40     |
| 11-Aug-94     | 10:03:12 | 40      | 0       | 40     |
| 11-Aug-94     | 10:03:32 | 41      | 0       | 41     |
| 11-Aug-94     | 10:03:52 | 41      | 0       | 41     |
| 11-Aug-94     | 10:04:12 | 41      | 0       | 41     |
| 11-Aug-94     | 10:04:32 | 41      | 0       | 41     |
| 11-Aug-94     | 10:04:52 | 41      | 0       | 41     |
| 11-Aug-94     | 10:05:12 | 41      | 0       | 41     |
| 11-Aug-94     | 10:05:32 | 41      | 0       | 41     |
| 11-Aug-94     | 10:05:52 | 41      | 0       | 41     |
| 11-Aug-94     | 10:06:12 | 41      | 0       | 41     |
| 11-Aug-94     | 10:06:32 | 41      | 0       | 41     |
| 11-Aug-94     | 10:06:52 | 41      | 0       | 41     |
| 11-Aug-94     | 10:07:12 | 41      | 0       | 40     |
| 11-Aug-94     | 10:07:32 | 40      | 0       | 40     |
| 11-Aug-94     | 10:07:52 | 40      | 0       | 40     |
| 11-Aug-94     | 10:08:12 | 40      | 0       | 40     |
| 11-Aug-94     | 10:08:32 | 40      | 0       | 40     |

# Run 1 Boiler 2 NOx Log

| Run 1     |          |         |         |        |
|-----------|----------|---------|---------|--------|
| Date      | Time     | NOx ppm | NO2 ppm | NO ppm |
| 11-Aug-94 | 10:08:52 | 40      | 0       | 40     |
| 11-Aug-94 | 10:09:12 | 40      | 0       | 40     |
| 11-Aug-94 | 10:09:32 | 40      | 0       | 40     |
| 11-Aug-94 | 10:09:52 | 40      | 0       | 40     |
| 11-Aug-94 | 10:10:12 | 40      | 0       | 40     |
| Run 1     | Average  | 40      |         |        |

# Run 2 Boiler 2 NOx Log

| Run 2     |          |         |         |        |
|-----------|----------|---------|---------|--------|
| Date      | Time     | NOx ppm | NO2 ppm | NO ppm |
| 11-Aug-94 | 10:30:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:30:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:30:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:31:16 | 42      | 0       | 42     |
| 11-Aug-94 | 10:31:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:31:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:32:15 | 42      | 0       | 41     |
| 11-Aug-94 | 10:32:35 | 42      | 0       | 41     |
| 11-Aug-94 | 10:32:55 | 42      | 0       | 41     |
| 11-Aug-94 | 10:33:15 | 42      | 0       | 41     |
| 11-Aug-94 | 10:33:35 | 42      | 0       | 41     |
| 11-Aug-94 | 10:33:55 | 42      | 0       | 41     |
| 11-Aug-94 | 10:34:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:34:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:34:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:35:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:35:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:35:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:36:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:36:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:36:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:37:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:37:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:37:55 | 42      | 0       | 41     |
| 11-Aug-94 | 10:38:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:38:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:38:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:39:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:39:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:39:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:40:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:40:35 | 43      | 0       | 42     |
| 11-Aug-94 | 10:40:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:41:15 | 42      | 0       | 42     |
| 11-Aug-94 | 10:41:35 | 42      | 0       | 42     |
| 11-Aug-94 | 10:41:55 | 42      | 0       | 42     |
| 11-Aug-94 | 10:42:15 | 42      | 0       | 41     |
| 11-Aug-94 | 10:42:35 | 42      | 0       | 41     |
| 11-Aug-94 | 10:42:55 | 42      | 0       | 41     |
| 11-Aug-94 | 10:43:15 | 42      | 0       | 41     |
| 11-Aug-94 | 10:43:35 | 42      | 0       | 41     |
| 11-Aug-94 | 10:43:55 | 42      | 0       | 41     |
| 11-Aug-94 | 10:44:15 | 42      | 0       | 41     |
| 11-Aug-94 | 10:44:35 | 42      | 0       | 42     |



# Run 2 Boiler 2 NOx Log

| Run 2<br>Date | Time     | NOx ppm | NO2 ppm | NO ppm |
|---------------|----------|---------|---------|--------|
| 11-Aug-94     | 10:44:55 | 42      | 0       | 42     |
| 11-Aug-94     | 10:45:15 | 42      | 0       | 42     |
| 11-Aug-94     | 10:45:35 | 42      | 0       | 42     |
| 11-Aug-94     | 10:45:55 | 42      | 0       | 42     |
| 11-Aug-94     | 10:46:15 | 42      | 0       | 42     |
| 11-Aug-94     | 10:46:35 | 42      | 0       | 42     |
| 11-Aug-94     | 10:46:55 | 42      | 0       | 42     |
| 11-Aug-94     | 10:47:15 | 42      | 0       | 42     |
| 11-Aug-94     | 10:47:35 | 42      | 0       | 42     |
| 11-Aug-94     | 10:47:55 | 42      | 0       | 42     |
| 11-Aug-94     | 10:48:15 | 42      | 0       | 42     |
| 11-Aug-94     | 10:48:35 | 42      | 0       | 42     |
| 11-Aug-94     | 10:48:55 | 42      | 0       | 42     |
| 11-Aug-94     | 10:49:15 | 42      | 0       | 42     |
| 11-Aug-94     | 10:49:35 | 42      | 0       | 42     |
| 11-Aug-94     | 10:49:55 | 42      | 0       | 42     |
| 11-Aug-94     | 10:50:15 | 42      | 0       | 41     |
| 11-Aug-94     | 10:50:35 | 42      | 0       | 41     |
| 11-Aug-94     | 10:50:55 | 42      | 0       | 41     |
| 11-Aug-94     | 10:51:15 | 42      | 0       | 41     |
| 11-Aug-94     | 10:51:35 | 42      | 0       | 41     |
| 11-Aug-94     | 10:51:55 | 41      | 0       | 41     |
| 11-Aug-94     | 10:52:15 | 41      | 0       | 41     |
| 11-Aug-94     | 10:52:35 | 41      | 0       | 41     |
| 11-Aug-94     | 10:52:55 | 41      | 0       | 41     |
| 11-Aug-94     | 10:53:15 | 41      | 0       | 41     |
| 11-Aug-94     | 10:53:35 | 41      | 0       | 41     |
| 11-Aug-94     | 10:53:55 | 41      | 0       | 41     |
| 11-Aug-94     | 10:54:15 | 41      | 0       | 41     |
| 11-Aug-94     | 10:54:35 | 42      | 0       | 41     |
| 11-Aug-94     | 10:54:55 | 42      | 0       | 41     |
| 11-Aug-94     | 10:55:15 | 42      | 0       | 41     |
| 11-Aug-94     | 10:55:35 | 42      | 0       | 41     |
| 11-Aug-94     | 10:55:55 | 42      | 0       | 41     |
| 11-Aug-94     | 10:56:15 | 42      | 0       | 41     |
| 11-Aug-94     | 10:56:35 | 42      | 0       | 41     |
| 11-Aug-94     | 10:56:55 | 42      | 0       | 41     |
| 11-Aug-94     | 10:57:15 | 42      | 0       | 41     |
| 11-Aug-94     | 10:57:35 | 42      | 0       | 41     |
| 11-Aug-94     | 10:57:55 | 42      | 0       | 41     |
| 11-Aug-94     | 10:58:15 | 42      | 0       | 41     |
| 11-Aug-94     | 10:58:35 | 42      | 0       | 41     |
| 11-Aug-94     | 10:58:55 | 42      | 0       | 41     |
| 11-Aug-94     | 10:59:15 | 42      | 0       | 41     |

# Run 2 Boiler 2 NOx Log

| Run 2<br>Date | Time     | NOx ppm | NO2 ppm | NO ppm |
|---------------|----------|---------|---------|--------|
| 11-Aug-94     | 10:59:35 | 42      | 0       | 41     |
| 11-Aug-94     | 10:59:55 | 41      | 0       | 41     |
| 11-Aug-94     | 11:00:15 | 41      | 0       | 41     |
| 11-Aug-94     | 11:00:35 | 41      | 0       | 41     |
| 11-Aug-94     | 11:00:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:01:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:01:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:01:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:02:15 | 41      | 0       | 41     |
| 11-Aug-94     | 11:02:35 | 41      | 0       | 41     |
| 11-Aug-94     | 11:02:55 | 41      | 0       | 41     |
| 11-Aug-94     | 11:03:15 | 41      | 0       | 41     |
| 11-Aug-94     | 11:03:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:03:55 | 41      | 0       | 40     |
| 11-Aug-94     | 11:04:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:04:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:04:55 | 41      | 0       | 40     |
| 11-Aug-94     | 11:05:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:05:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:05:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:06:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:06:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:06:55 | 41      | 0       | 40     |
| 11-Aug-94     | 11:07:15 | 41      | 1       | 41     |
| 11-Aug-94     | 11:07:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:07:55 | 41      | 0       | 40     |
| 11-Aug-94     | 11:08:15 | 41      | 1       | 40     |
| 11-Aug-94     | 11:08:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:08:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:09:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:09:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:09:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:10:15 | 41      | 1       | 40     |
| 11-Aug-94     | 11:10:35 | 41      | 0       | 41     |
| 11-Aug-94     | 11:10:55 | 41      | 0       | 41     |
| 11-Aug-94     | 11:11:15 | 41      | 0       | 41     |
| 11-Aug-94     | 11:11:35 | 41      | 0       | 41     |
| 11-Aug-94     | 11:11:55 | 41      | 0       | 40     |
| 11-Aug-94     | 11:12:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:12:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:12:55 | 41      | 0       | 40     |
| 11-Aug-94     | 11:13:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:13:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:13:55 | 41      | 0       | 40     |

## Run 2 Boiler 2 NOx Log

| Run 2<br>Date | Time     | NOx ppm | NO2 ppm | NO ppm |
|---------------|----------|---------|---------|--------|
| 11-Aug-94     | 11:14:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:14:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:14:55 | 41      | 0       | 40     |
| 11-Aug-94     | 11:15:15 | 41      | 1       | 40     |
| 11-Aug-94     | 11:15:35 | 41      | 0       | 40     |
| 11-Aug-94     | 11:15:55 | 41      | 0       | 41     |
| 11-Aug-94     | 11:16:15 | 41      | 0       | 41     |
| 11-Aug-94     | 11:16:35 | 42      | 1       | 41     |
| 11-Aug-94     | 11:16:55 | 42      | 1       | 41     |
| 11-Aug-94     | 11:17:15 | 42      | 0       | 41     |
| 11-Aug-94     | 11:17:35 | 42      | 1       | 41     |
| 11-Aug-94     | 11:17:55 | 42      | 1       | 41     |
| 11-Aug-94     | 11:18:15 | 42      | 0       | 41     |
| 11-Aug-94     | 11:18:35 | 42      | 1       | 41     |
| 11-Aug-94     | 11:18:55 | 42      | 1       | 41     |
| 11-Aug-94     | 11:19:15 | 42      | 1       | 41     |
| 11-Aug-94     | 11:19:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:19:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:20:15 | 41      | 1       | 41     |
| 11-Aug-94     | 11:20:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:20:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:21:15 | 41      | 1       | 40     |
| 11-Aug-94     | 11:21:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:21:55 | 41      | 0       | 40     |
| 11-Aug-94     | 11:22:15 | 41      | 1       | 40     |
| 11-Aug-94     | 11:22:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:22:55 | 42      | 1       | 41     |
| 11-Aug-94     | 11:23:15 | 42      | 1       | 41     |
| 11-Aug-94     | 11:23:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:23:55 | 42      | 2       | 40     |
| 11-Aug-94     | 11:24:15 | 41      | 0       | 40     |
| 11-Aug-94     | 11:24:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:24:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:25:15 | 41      | 1       | 40     |
| 11-Aug-94     | 11:25:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:25:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:26:15 | 41      | 1       | 40     |
| 11-Aug-94     | 11:26:35 | 41      | 1       | 40     |
| 11-Aug-94     | 11:26:55 | 41      | 1       | 40     |
| 11-Aug-94     | 11:27:15 | 41      | 2       | 39     |
| 11-Aug-94     | 11:27:35 | 40      | 1       | 39     |
| 11-Aug-94     | 11:27:55 | 40      | 1       | 39     |
| 11-Aug-94     | 11:28:15 | 40      | 1       | 39     |
| 11-Aug-94     | 11:28:35 | 40      | 1       | 39     |

# Run 2 Boiler 2 NOx Log

| Run 2<br>Date | Time     | NOx ppm | NO2 ppm | NO ppm |
|---------------|----------|---------|---------|--------|
| 11-Aug-94     | 11:28:55 | 40      | 1       | 39     |
| 11-Aug-94     | 11:29:15 | 40      | 0       | 39     |
| 11-Aug-94     | 11:29:35 | 40      | 1       | 39     |
| 11-Aug-94     | 11:29:55 | 40      | 1       | 39     |
| 11-Aug-94     | 11:30:15 | 40      | 1       | 39     |
| Run 2         | Average  | 41      |         |        |

# Run 3 Boiler 2 NOx Log

| Run 3     |          |         |         |        |
|-----------|----------|---------|---------|--------|
| Date      | Time     | NOx ppm | NO2 ppm | NO ppm |
| 1-Aug-94  | 11:50:12 | 42      | 0       | 41     |
| 11-Aug-94 | 11:50:32 | 42      | 0       | 41     |
| 11-Aug-94 | 11:50:54 | 41      | 0       | 41     |
| 11-Aug-94 | 11:51:12 | 41      | 0       | 41     |
| 11-Aug-94 | 11:51:32 | 41      | 0       | 41     |
| 11-Aug-94 | 11:51:52 | 41      | 0       | 41     |
| 11-Aug-94 | 11:52:12 | 41      | 0       | 41     |
| 11-Aug-94 | 11:52:32 | 41      | 0       | 41     |
| 11-Aug-94 | 11:52:52 | 41      | 0       | 40     |
| 11-Aug-94 | 11:53:12 | 41      | 0       | 40     |
| 11-Aug-94 | 11:53:32 | 41      | 0       | 40     |
| 11-Aug-94 | 11:53:52 | 41      | 0       | 41     |
| 11-Aug-94 | 11:54:12 | 41      | 0       | 41     |
| 11-Aug-94 | 11:54:32 | 42      | 0       | 41     |
| 11-Aug-94 | 11:54:52 | 42      | 0       | 42     |
| 11-Aug-94 | 11:55:12 | 42      | 0       | 41     |
| 11-Aug-94 | 11:55:32 | 42      | 0       | 41     |
| 11-Aug-94 | 11:55:52 | 42      | 0       | 41     |
| 11-Aug-94 | 11:56:12 | 42      | 0       | 41     |
| 11-Aug-94 | 11:56:32 | 42      | 0       | 41     |
| 11-Aug-94 | 11:56:52 | 42      | 0       | 41     |
| 11-Aug-94 | 11:57:12 | 42      | 0       | 41     |
| 11-Aug-94 | 11:57:32 | 41      | 0       | 41     |
| 11-Aug-94 | 11:57:52 | 41      | 0       | 41     |
| 11-Aug-94 | 11:58:12 | 41      | 0       | 41     |
| 11-Aug-94 | 11:58:32 | 41      | 0       | 40     |
| 11-Aug-94 | 11:58:52 | 41      | 0       | 41     |
| 11-Aug-94 | 11:59:12 | 41      | 0       | 41     |
| 11-Aug-94 | 11:59:32 | 41      | 0       | 41     |
| 11-Aug-94 | 11:59:52 | 41      | 0       | 41     |
| 11-Aug-94 | 12:00:12 | 41      | 0       | 41     |
| 11-Aug-94 | 12:00:32 | 41      | 0       | 41     |
| 11-Aug-94 | 12:00:52 | 41      | 0       | 41     |
| 11-Aug-94 | 12:01:12 | 41      | 0       | 41     |
| 11-Aug-94 | 12:01:32 | 41      | 0       | 41     |
| 11-Aug-94 | 12:01:52 | 41      | 0       | 41     |
| 11-Aug-94 | 12:02:12 | 41      | 0       | 41     |
| 11-Aug-94 | 12:02:32 | 41      | 0       | 41     |
| 11-Aug-94 | 12:02:52 | 41      | 0       | 41     |
| 11-Aug-94 | 12:03:12 | 41      | 0       | 40     |
| 11-Aug-94 | 12:03:32 | 41      | 0       | 40     |
| 11-Aug-94 | 12:03:52 | 40      | 0       | 40     |
| 11-Aug-94 | 12:04:12 | 40      | 0       | 40     |
| 11-Aug-94 | 12:04:32 | 41      | 1       | 40     |

# Run 3 Boiler 2 NOx Log

| Run 3<br>Date | Time     | NOx ppm | NO2 ppm | NO ppm |
|---------------|----------|---------|---------|--------|
| 11-Aug-94     | 12:04:52 | 41      | 0       | 40     |
| 11-Aug-94     | 12:05:12 | 41      | 0       | 41     |
| 11-Aug-94     | 12:05:32 | 42      | 0       | 41     |
| 11-Aug-94     | 12:05:52 | 42      | 0       | 41     |
| 11-Aug-94     | 12:06:12 | 42      | 1       | 41     |
| 11-Aug-94     | 12:06:32 | 41      | 0       | 41     |
| 11-Aug-94     | 12:06:52 | 41      | 0       | 41     |
| 11-Aug-94     | 12:07:12 | 41      | 0       | 41     |
| 11-Aug-94     | 12:07:32 | 41      | 0       | 41     |
| 11-Aug-94     | 12:07:52 | 41      | 1       | 40     |
| 11-Aug-94     | 12:08:12 | 41      | 0       | 41     |
| 11-Aug-94     | 12:08:32 | 41      | 0       | 41     |
| 11-Aug-94     | 12:08:52 | 42      | 1       | 41     |
| 11-Aug-94     | 12:09:12 | 42      | 0       | 41     |
| 11-Aug-94     | 12:09:32 | 42      | 1       | 41     |
| 11-Aug-94     | 12:09:52 | 42      | 1       | 41     |
| 11-Aug-94     | 12:10:12 | 41      | 0       | 41     |
| 11-Aug-94     | 12:10:32 | 41      | 1       | 40     |
| 11-Aug-94     | 12:10:52 | 41      | 0       | 41     |
| 11-Aug-94     | 12:11:12 | 41      | 0       | 41     |
| 11-Aug-94     | 12:11:32 | 41      | 0       | 41     |
| 11-Aug-94     | 12:11:52 | 41      | 0       | 41     |
| 11-Aug-94     | 12:12:12 | 41      | 0       | 41     |
| 11-Aug-94     | 12:12:32 | 41      | 0       | 41     |
| 11-Aug-94     | 12:12:52 | 41      | 0       | 41     |
| 11-Aug-94     | 12:13:12 | 41      | 0       | 41     |
| 11-Aug-94     | 12:13:32 | 41      | 0       | 41     |
| 11-Aug-94     | 12:13:52 | 41      | 1       | 40     |
| 11-Aug-94     | 12:14:12 | 41      | 1       | 40     |
| 11-Aug-94     | 12:14:32 | 41      | 0       | 40     |
| 11-Aug-94     | 12:14:52 | 41      | 1       | 40     |
| 11-Aug-94     | 12:15:12 | 41      | 0       | 40     |
| 11-Aug-94     | 12:15:32 | 41      | 0       | 40     |
| 11-Aug-94     | 12:15:52 | 41      | 0       | 40     |
| 11-Aug-94     | 12:16:12 | 41      | 0       | 40     |
| 11-Aug-94     | 12:16:32 | 41      | 0       | 40     |
| 11-Aug-94     | 12:16:52 | 41      | 0       | 40     |
| 11-Aug-94     | 12:17:12 | 41      | 1       | 40     |
| 11-Aug-94     | 12:17:32 | 41      | 1       | 40     |
| 11-Aug-94     | 12:17:52 | 41      | 1       | 40     |
| 11-Aug-94     | 12:18:12 | 41      | 0       | 40     |
| 11-Aug-94     | 12:18:32 | 41      | 1       | 40     |
| 11-Aug-94     | 12:18:52 | 41      | 1       | 40     |
| 11-Aug-94     | 12:19:12 | 41      | 0       | 40     |

# Run 3 Boiler 2 NOx Log

| Run 3     |          |         |         |        |
|-----------|----------|---------|---------|--------|
| Date      | Time     | NOx ppm | NO2 ppm | NO ppm |
| 11-Aug-94 | 12:19:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:19:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:20:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:20:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:20:52 | 41      | 0       | 40     |
| 11-Aug-94 | 12:21:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:21:32 | 41      | 0       | 41     |
| 11-Aug-94 | 12:21:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:22:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:22:32 | 41      | 0       | 40     |
| 11-Aug-94 | 12:22:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:23:12 | 41      | 0       | 40     |
| 11-Aug-94 | 12:23:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:23:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:24:12 | 41      | 0       | 40     |
| 11-Aug-94 | 12:24:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:24:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:25:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:25:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:25:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:26:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:26:32 | 41      | 0       | 40     |
| 11-Aug-94 | 12:26:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:27:12 | 41      | 0       | 40     |
| 11-Aug-94 | 12:27:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:27:52 | 41      | 0       | 40     |
| 11-Aug-94 | 12:28:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:28:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:28:52 | 41      | 0       | 40     |
| 11-Aug-94 | 12:29:12 | 41      | 0       | 41     |
| 11-Aug-94 | 12:29:32 | 42      | 1       | 41     |
| 11-Aug-94 | 12:29:52 | 41      | 0       | 40     |
| 11-Aug-94 | 12:30:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:30:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:30:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:31:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:31:32 | 42      | 2       | 40     |
| 11-Aug-94 | 12:31:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:32:12 | 41      | 0       | 40     |
| 11-Aug-94 | 12:32:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:32:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:33:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:33:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:33:52 | 41      | 1       | 40     |

# Run 3 Boiler 2 NOx Log

| Run 3     |          |         |         |        |
|-----------|----------|---------|---------|--------|
| Date      | Time     | NOx ppm | NO2 ppm | NO ppm |
|           |          | 41      | 1       | 40     |
| 11-Aug-94 | 12:34:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:34:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:34:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:35:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:35:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:35:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:36:12 | 41      | 0       | 40     |
| 11-Aug-94 | 12:36:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:36:52 | 42      | 1       | 40     |
| 11-Aug-94 | 12:37:12 | 42      | 1       | 40     |
| 11-Aug-94 | 12:37:32 | 42      | 2       | 40     |
| 11-Aug-94 | 12:37:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:38:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:38:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:38:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:39:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:39:32 | 41      | 0       | 40     |
| 11-Aug-94 | 12:39:52 | 42      | 1       | 41     |
| 11-Aug-94 | 12:40:12 | 42      | 0       | 41     |
| 11-Aug-94 | 12:40:32 | 42      | 1       | 41     |
| 11-Aug-94 | 12:40:52 | 42      | 0       | 41     |
| 11-Aug-94 | 12:41:12 | 42      | 1       | 40     |
| 11-Aug-94 | 12:41:32 | 42      | 1       | 40     |
| 11-Aug-94 | 12:41:52 | 41      | 0       | 40     |
| 11-Aug-94 | 12:42:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:42:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:42:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:43:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:43:32 | 41      | 0       | 40     |
| 11-Aug-94 | 12:43:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:44:12 | 41      | 2       | 40     |
| 11-Aug-94 | 12:44:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:44:52 | 41      | 2       | 39     |
| 11-Aug-94 | 12:45:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:45:32 | 41      | 2       | 40     |
| 11-Aug-94 | 12:45:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:46:12 | 41      | 1       | 40     |
| 11-Aug-94 | 12:46:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:46:52 | 41      | 1       | 40     |
| 11-Aug-94 | 12:47:12 | 41      | 2       | 40     |
| 11-Aug-94 | 12:47:32 | 41      | 1       | 40     |
| 11-Aug-94 | 12:47:52 | 41      | 2       | 40     |
| 11-Aug-94 | 12:48:12 | 41      | 0       | 40     |
| 11-Aug-94 | 12:48:32 | 41      |         |        |



# Run 3 Boiler 2 NOx Log

| Run 3<br>Date | Time     | NOx ppm | NO2 ppm | NO ppm |
|---------------|----------|---------|---------|--------|
| 11-Aug-94     | 12:48:52 | 41      | 1       | 40     |
| 11-Aug-94     | 12:49:12 | 41      | 1       | 40     |
| 11-Aug-94     | 12:49:32 | 41      | 2       | 40     |
| 11-Aug-94     | 12:49:52 | 41      | 1       | 40     |
| 11-Aug-94     | 12:50:12 | 42      | 1       | 40     |
| Run 3         | Average  | 41      |         |        |

**APPENDIX E**

**Emission Rate Calculations**

## **NOMENCLATURE**

- $A_n$ = area of sampling nozzle, ft<sup>2</sup>
- $B_{ws}$ = proportion by volume of water vapor in gas stream, dimensionless
- $C$ = average analyzer concentration, ppm
- $C_{ER1}$ = condensible particulate emission rate, lb/hr
- $C_{ER2}$ = condensible particulate emission rate, lb/MMBtu
- $C_{gas}$ = effluent gas concentration, ppm
- $C_m$ = average of initial and final system bias responses for upscale calibration gas, ppm
- $C_{ma}$ = actual concentration of the upscale calibration gas, ppm
- $C_{NOx}$ = gas concentration, lb/dscf
- $C_o$ = average of initial and final system bias responses for zero calibration gas, ppm
- $CC_{s1}$ = concentration of condensible particulate in stack gas, grains/dscf
- $CC_{s2}$ = concentration of condensible particulate in stack gas, lb/dscf
- $CO$ = percent carbon monoxide in stack gas by volume, dry basis, %
- $CO_2$ = percent carbon dioxide in stack gas by volume, dry basis, %
- $COER_1$ = CO emission rate, lb/hr
- $COER_2$ = CO emission rate, lb/MMBtu
- $C_p$ = pitot tube coefficient, dimensionless
- $C_{s1}$ = concentration of filterable particulate in stack gas, grains/dscf
- $C_{s2}$ = concentration of filterable particulate in stack gas, lb/dscf
- $dia$ = diameter of stack at measurement site, inches
- $D$ = Density of fuel oil, lb/gal
- $ER_1$ = filterable particulate emission rate, lb/hr
- $ER_2$ = filterable particulate emission rate, lb/MMBtu
- $GCV$ = Gross calorific value of fuel, Btu/lb for coal and oil or Btu/scf for natural gas
- $\Delta H$ = average pressure drop across orifice, inches H<sub>2</sub>O
- $\%I$ = percent isokinetic

### **NOMENCLATURE**

- $L$ = length of duct at sampling site cross section, in.
- $L_p$ = post test leak rate,  $\text{ft}^3$
- $M_d$ = molecular weight of stack gas, dry basis, lb/lb-mole
- $M_{nc}$ = weight of condensible particulate, mg
- $M_{nf}$ = weight of filterable particulate, mg
- $M_s$ = molecular weight of stack gas, wet basis, lb/lb-mole
- $N_2$ = percent nitrogen in stack gas by volume, dry basis, %
- $NGfr$ = Natural gas flow rate, scf/hr
- $NO_xER_1$ =  $NO_x$  emission rate, lb/hr
- $NO_xER_2$ =  $NO_x$  emission rate, lb/MMBtu
- $O_2$ = percent oxygen in stack gas by volume, dry basis, %
- $Ofr$ = Fuel oil flow rate, gal/hr
- $\Delta p$ = average velocity head of stack gas, inches  $H_2O$
- $\sqrt{\Delta p}$ = average square root of  $\Delta p$
- $P_b$ = barometric pressure, inches Hg
- $P_g$ = static pressure of stack, inches  $H_2O$
- $P_s$ = absolute stack gas pressure, inches Hg
- $Q_a$ = volumetric flow rate @ stack conditions, acfm
- $Q_{hf}$ = heat input rate by f-factor, MM Btu/hr
- $Q_{hcs}$ = heat input rate by coal scales, MM Btu/hr
- $Q_{hfm}$ = heat input rate by fuel meter, MM Btu/hr
- $Q_{sd}$ = volumetric flow rate of stack gas, dry standard conditions, dscfm
- $Q_s$ = volumetric flow rate of stack gas, standard conditions, scfm
- $\phi$ = elapsed time of test, minutes
- $T_m$ = average temperature of dry gas meter,  $^{\circ}F$

## ***NOMENCLATURE***

- $T_s$ = average stack temperature, °F
- $V_{lc}$ = weight of water collected in impingers, g
- $V_m$ = volume of gas sampled measured by dry gas meter, ft<sup>3</sup>
- $V_{mc}$ = volume of gas sampled corrected for leak rate, ft<sup>3</sup>
- $V_{mstd}$ = metered volume corrected to dry standard conditions, ft<sup>3</sup>
- $V_s$ = stack gas velocity, fps
- $V_{soln}$ = volume of liquid in impingers, ml
- $w$ = width of duct at sampling site cross section, in.
- $Y$ = dry gas meter calibration factor, dimensionless
- 0.84= S type pitot tube coefficient
- 85.49= pitot tube constant
- 18.0= molecular wt. water, lb/lb-mole
- 44.0= molecular wt. of CO<sub>2</sub>
- 28.0= molecular wt. of N<sub>2</sub> and CO
- 32.0= molecular wt. of O<sub>2</sub>
- 46.005= molecular wt. of NO<sub>2</sub>
- 0.264= ratio of O<sub>2</sub> to N<sub>2</sub> in air, v/v
- 17.64= conversion factor, °R/in. Hg
- 460= conversion factor, °F to °R
- 24.04= gas constant
- 6.24E-08= conversion factor, mg/m<sup>3</sup> to lb/scf
- 60= conversion factor, minutes to hours

## EXAMPLE EMISSION CALCULATIONS

Facility:  
Source/Site:  
Test Date:  
Run #:EXAMPLE

---

---

1. Volume metered, corrected for leakage, dcf

$$V_{mc} = V_m - (L_p - 0.02) (\emptyset)$$

$$V_{mc} = \text{dcf}$$

2. Volume metered, standard conditions, dscf

$$V_{m(\text{std})} = (17.64) (V_{mc}) (Y) \frac{(P_b) + (\Delta H \div 13.6)}{(T_m + 460)}$$

$$V_{m(\text{std})} = \text{dscf}$$

3. Volume of water vapor collected, scf

$$V_{w(\text{std})} = 0.04707 \times V_{lc}$$

$$V_{w(\text{std})} = \text{scf}$$

4. Moisture content, proportion by volume

$$B_{ws} = \frac{V_{w(\text{std})}}{V_{w(\text{std})} + V_{m(\text{std})}}$$

$$B_{ws} =$$

5. Molecular weight of stack gas, dry basis, lb/lb-mole

$$M_d = 0.440 (\text{CO}_2) + 0.320 (\text{O}_2) + 0.280 (\text{N}_2 + \text{CO})$$

$$M_d = \text{lb/lb-mole}$$

6. Molecular weight of stack gas, wet basis, lb/lb-mole

$$M_s = M_d (1 - B_{ws}) + 18.0 (B_{ws})$$

$$M_s = \text{lb/lb-mole}$$

## EXAMPLE EMISSION CALCULATIONS

Facility:  
Source/Site:  
Test Date:  
Run #:EXAMPLE

7. Excess air, %

$$\%EA = \left( \frac{O_2 - (0.5 \times CO)}{(0.264 \times (CO + N_2)) - (O_2 - (0.5 \times CO))} \right) \times 100$$

$\%EA = \%$

8. Average stack gas velocity, fps

$$v_s = 85.49 (C_p) (\sqrt{\Delta p}) \sqrt{\frac{(T_s + 460)}{(P_s) (M_s)}}$$

$v_s = \text{fps}$

9. Volumetric flow rate @ stack conditions, acfm

| ROUND                                |    | SQUARE                         |
|--------------------------------------|----|--------------------------------|
| $Q_a = 60 (v_s) (dia)^2 (5.454E-03)$ | or | $60 (v_s) (L) (W) (6.944E-03)$ |
| $Q_a = \text{acfm}$                  |    |                                |

10. Volumetric flow rate @ dry standard conditions, dscfm

$$Q_{sd} = 17.64 (Q_a) (1 - B_{ws}) \frac{(P_s)}{(T_s + 460)}$$

$Q_{sd} = \text{dscfm}$

11. F-factor, dscf/MMbtu

$$F_d = 10^6 \left( \frac{(3.64 \times \%H) + (1.53 \times \%C) + (0.57 \times \%S) + (0.14 \times \%N_2) - (0.46 \times \%O_2)}{GCV_{db}} \right)$$

$F_d = \text{dscf/MMbtu}$

## EXAMPLE EMISSION CALCULATIONS

Facility:  
Source/Site:  
Test Date:  
Run #:EXAMPLE

---

12. Heat input rate (f-factor), MMBtu/hr

$$Q_{hf} = \left( \frac{Q_{std}}{F\text{-factor}} \right) \times \left( \frac{20.9 - O_2}{20.9} \right) \times 60$$
$$Q_{hf} = \text{MMBtu/hr}$$

13. Heat input rate, Fuel meter, gas, MMBtu/hr

$$Q_{hfm} = \left( \frac{NG_{fr} \times GCV}{1.0 \text{ E}06} \right)$$
$$Q_{hfm} = \text{MMBtu/hr}$$

14. NOx concentration, ppm

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$
$$C_{gas} = \text{ppm}$$

15. NOx concentration, lb/dscf

$$C_{NOx} = C_{gas} \times \left( \frac{46.005}{24.04} \right) \times 6.24\text{E-}08$$
$$C_{NOx} = \text{lb/dscf}$$

16. NOx emission rate, lb/hr

$$NOxER_1 = C_{NOx} \times 60 \times Q_{sd}$$
$$NOxER_1 = \text{lb/hr}$$



## EXAMPLE EMISSION CALCULATIONS

Facility:  
Source/Site:  
Test Date:  
Run #:EXAMPLE

---

---

17. NOx emission rate (by Fuel meter), lb/MMBtu

$$\text{NOxER}_2 = \frac{\text{NOxER}_1}{Q_{\text{hfm}}}$$

$$\text{NOxER}_2 = \text{lb/MMBtu}$$

18. NOx emission rate (by f-factor), lb/MMBtu

$$\text{NOxER}_2 = (C_{\text{NOx}}) (\text{F-Factor}) \frac{(20.9)}{(20.9 - O_2)}$$

$$\text{NOxER}_2 = \text{lb/MMBtu}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 1

---

1. Volume metered, corrected for leakage, dcf

$$V_{mc} = 46.848 - (0.02 - 0.02) (60.0)$$

$$V_{mc} = 46.848 \text{ dcf}$$

2. Volume metered, standard conditions, dscf

$$V_{m(std)} = 17.64 (46.848) (0.992) \frac{(29.50) + (2.00 + 13.6)}{(86 + 460)}$$

$$V_{m(std)} = 44.513 \text{ dscf}$$

3. Volume of water vapor collected, scf

$$V_{w(std)} = 0.04707 \times 112.1$$

$$V_{w(std)} = 5.276 \text{ scf}$$

4. Moisture content, proportion by volume

$$B_{ws} = \frac{5.276}{5.276 + 44.513}$$

$$B_{ws} = 0.106$$

5. Molecular weight of stack gas, dry basis, lb/lb-mole

$$M_d = 0.440 (4.2) + 0.320 (12.0) + 0.280 (83.8)$$

$$M_d = 29.15 \text{ lb/lb-mole}$$

6. Molecular weight of stack gas, wet basis, lb/lb-mole

$$M_s = 29.15 (1 - 0.106) + 18.0 (0.106)$$

$$M_s = 27.97 \text{ lb/lb-mole}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 1

---

7. Excess air, %

$$\%EA = \left( \frac{12.0 - (0.5 \times 0.0)}{(0.264 \times 83.8) - (12.0 - (0.5 \times 0.0))} \right) \times 100$$
$$\%EA = 118.5 \%$$

8. Average stack gas velocity, fps

$$v_s = 85.49 (0.84) (0.202) \sqrt{\frac{(230 + 460)}{(27.97) (29.49)}}$$
$$v_s = 13.3 \text{ fps}$$

9. Volumetric flow rate @ stack conditions, acfm

$$Q_a = 60 (13.3) (48.0002) (5.454E-03)$$

$$Q_a = 10,005 \text{ acfm}$$

10. Volumetric flow rate @ dry standard conditions, dscfm

$$Q_{sd} = 17.64 (10,005) (1 - 0.106) \frac{(29.49)}{(230 + 460)}$$

$$Q_{sd} = 6,744 \text{ dscfm}$$

11. F-factor, dscf/MMbtu (published)

$$F_d = 8,710 \text{ dscf/MMbtu}$$

12. Heat input rate, MMBtu/hr (F-factor)

$$Q_{hf} = \left( \frac{6,744}{8,710} \right) \times \left( \frac{20.9 - 12.0}{20.9} \right) \times 60$$
$$Q_{hf} = 19.78 \text{ MMBtu/hr}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 1

---

13. Heat input rate, MMBtu/hr (Fuel Meter)

$$Q_{\text{hfm}} = \left( \frac{1,025 \times 16,800}{1.0 \text{ E}6} \right)$$
$$Q_{\text{hfm}} = 17.22 \text{ MMBtu/hr}$$

14. NOx concentration, ppm

$$C_{\text{gas}} = (40.0 - 0.0) \times \frac{149.0}{151.0 - 0.0}$$
$$C_{\text{gas}} = 39.5 \text{ ppm}$$

15. NOx concentration, lb/dscf

$$C_{\text{NOx}} = 39.5 \times \left( \frac{46.005}{24.04} \right) \times 6.24\text{E-}08$$
$$C_{\text{NOx}} = 4.72\text{E-}6 \text{ lb/dscf}$$

16. NOx emission rate, lb/hr

$$\text{NOxER}_1 = 4.72\text{E-}6 \times 60 \times 6,744$$
$$\text{NOxER}_1 = 1.9 \text{ lb/hr}$$

17. NOx emission rate, lb/MMBtu, (Fuel meter)

$$\text{NOxER}_2 = \frac{(1.9)}{(17.22)}$$
$$\text{NOxER}_2 = 0.11 \text{ lb/MMBtu}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 1

---

18. NOx emission rate, lb/MMBtu, (F-factor)

$$\text{NOxER}_2 = (4.72\text{E-}6) (8,710) \frac{(20.9)}{(20.9 - 12.0)}$$

$$\text{NOxER}_2 = 0.10 \text{ lb/MMBtu}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 2

---

1. Volume metered, corrected for leakage, dcf

$$V_{mc} = 47.361 - (0.02 - 0.02) (60.0)$$

$$V_{mc} = 47.361 \text{ dcf}$$

2. Volume metered, standard conditions, dscf

$$(29.50) + (2.00 + 13.6)$$

$$V_{m(std)} = 17.64 (47.361) (0.992) \quad (93 + 460)$$

$$V_{m(std)} = 44.431 \text{ dscf}$$

3. Volume of water vapor collected, scf

$$V_{w(std)} = 0.04707 \times 119.6$$

$$V_{w(std)} = 5.630 \text{ scf}$$

4. Moisture content, proportion by volume

$$\frac{5.630}{\quad}$$

$$B_{ws} = 5.630 + 44.431$$

$$B_{ws} = 0.113$$

5. Molecular weight of stack gas, dry basis, lb/lb-mole

$$M_d = 0.440 (4.3) + 0.320 (11.8) + 0.280 (83.9)$$

$$M_d = 29.16 \text{ lb/lb-mole}$$

6. Molecular weight of stack gas, wet basis, lb/lb-mole

$$M_s = 29.16 (1 - 0.113) + 18.0 (0.113)$$

$$M_s = 27.91 \text{ lb/lb-mole}$$

## EMISSION CALCULATIONS

Facility: Siemens  
Source/Site: Boiler 2-Outlet  
Test Date: Thursday, August 11, 1994  
Run #: 2

---

7. Excess air, %

$$\%EA = \left( \frac{11.8 - (0.5 \times 0.0)}{(0.264 \times 83.9) - (11.8 - (0.5 \times 0.0))} \right) \times 100$$
$$\%EA = 114.0 \%$$

8. Average stack gas velocity, fps

$$v_s = 85.49 (0.84) (0.211) \sqrt{\frac{(231 + 460)}{(27.91) (29.49)}}$$
$$v_s = 13.9 \text{ fps}$$

9. Volumetric flow rate @ stack conditions, acfm

$$Q_a = 60 (13.9) (48.0002) (5.454E-03)$$
$$Q_a = 10,465 \text{ acfm}$$

10. Volumetric flow rate @ dry standard conditions, dscfm

$$Q_{sd} = 17.64 (10,465) (1 - 0.113) \frac{(29.49)}{(231 + 460)}$$
$$Q_{sd} = 6,992 \text{ dscfm}$$

11. F-factor, dscf/MMBtu (published)

$$F_d = 8,710 \text{ dscf/MMBtu}$$

12. Heat input rate, MMBtu/hr (F-factor)

$$Q_{hf} = \left( \frac{6,992}{8,710} \right) \times \left( \frac{20.9 - 11.8}{20.9} \right) \times 60$$
$$Q_{hf} = 20.97 \text{ MMBtu/hr}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 2

---

13. Heat input rate, MMBtu/hr (Fuel Meter)

$$Q_{\text{hfm}} = \left( \frac{1,025 \times 17,400}{1.0 \text{ E6}} \right)$$

$$Q_{\text{hfm}} = 17.83 \text{ MMBtu/hr}$$

14. NOx concentration, ppm

$$C_{\text{gas}} = (41.0 - 1.0) \times \frac{149.0}{151.0 - 1.0}$$

$$C_{\text{gas}} = 39.7 \text{ ppm}$$

15. NOx concentration, lb/dscf

$$C_{\text{NOx}} = 39.7 \times \left( \frac{46.005}{24.04} \right) \times 6.24\text{E-}08$$

$$C_{\text{NOx}} = 4.75\text{E-}6 \text{ lb/dscf}$$

16. NOx emission rate, lb/hr

$$\text{NOxER}_1 = 4.75\text{E-}6 \times 60 \times 6,992$$

$$\text{NOxER}_1 = 2.0 \text{ lb/hr}$$

17. NOx emission rate, lb/MMBtu, (Fuel meter)

$$\text{NOxER}_2 = \frac{(2.0)}{(17.83)}$$

$$\text{NOxER}_2 = 0.11 \text{ lb/MMBtu}$$



## EMISSION CALCULATIONS

Facility: Siemens  
Source/Site: Boiler 2-Outlet  
Test Date: Thursday, August 11, 1994  
Run #: 2

---

18. NOx emission rate, lb/MMBtu, (F-factor)

$$\text{NOxER}_2 = (4.75\text{E-}6) (8,710) \frac{(20.9)}{(20.9 - 11.8)}$$
$$\text{NOxER}_2 = 0.10 \text{ lb/MMBtu}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 3

---

---

1. Volume metered, corrected for leakage, dcf

$$V_{mc} = 46.995 - (0.02 - 0.02) (60.0)$$

$$V_{mc} = 46.995 \text{ dcf}$$

2. Volume metered, standard conditions, dscf

$$(29.50) + (2.00 \div 13.6)$$

$$V_{m(std)} = 17.64 (46.995) (0.992) \quad (96 + 460)$$

$$V_{m(std)} = 43.850 \text{ dscf}$$

3. Volume of water vapor collected, scf

$$V_{w(std)} = 0.04707 \times 114.0$$

$$V_{w(std)} = 5.366 \text{ scf}$$

4. Moisture content, proportion by volume

$$\frac{5.366}{}$$

$$B_{ws} = 5.366 + 43.850$$

$$B_{ws} = 0.109$$

5. Molecular weight of stack gas, dry basis, lb/lb-mole

$$M_d = 0.440 (4.3) + 0.320 (11.9) + 0.280 (83.8)$$

$$M_d = 29.16 \text{ lb/lb-mole}$$

6. Molecular weight of stack gas, wet basis, lb/lb-mole

$$M_s = 29.16 (1 - 0.109) + 18.0 (0.109)$$

$$M_s = 27.95 \text{ lb/lb-mole}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 3

---

7. Excess air, %

$$\%EA = \left( \frac{11.9 - (0.5 \times 0.0)}{(0.264 \times 83.8) - (11.9 - (0.5 \times 0.0))} \right) \times 100$$
$$\%EA = 116.4 \%$$

8. Average stack gas velocity, fps

$$v_s = 85.49 (0.84) (0.211) \sqrt{\frac{(232 + 460)}{(27.95) (29.49)}}$$
$$v_s = 13.9 \text{ fps}$$

9. Volumetric flow rate @ stack conditions, acfm

$$Q_a = 60 (13.9) (48.0002) (5.454E-03)$$

$$Q_a = 10,465 \text{ acfm}$$

10. Volumetric flow rate @ dry standard conditions, dscfm

$$Q_{sd} = 17.64 (10,465) (1 - 0.109) \frac{(29.49)}{(232 + 460)}$$

$$Q_{sd} = 7,010 \text{ dscfm}$$

11. F-factor, dscf/MMBtu (published)

$$F_d = 8,710 \text{ dscf/MMBtu}$$

12. Heat input rate, MMBtu/hr (F-factor)

$$Q_{hf} = \left( \frac{7,010}{8,710} \right) \times \left( \frac{20.9 - 11.9}{20.9} \right) \times 60$$

$$Q_{hf} = 20.79 \text{ MMBtu/hr}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 3

---

13. Heat input rate, MMBtu/hr (Fuel Meter)

$$Q_{\text{hfm}} = \left( \frac{1,025 \times 17,400}{1.0 \text{ E6}} \right)$$

$$Q_{\text{hfm}} = 17.83 \text{ MMBtu/hr}$$

14. NOx concentration, ppm

$$C_{\text{gas}} = (41.0 - 0.0) \times \frac{149.0}{152.0 - 0.0}$$

$$C_{\text{gas}} = 40.2 \text{ ppm}$$

15. NOx concentration, lb/dscf

$$C_{\text{NOx}} = 40.2 \times \left( \frac{46.005}{24.04} \right) \times 6.24\text{E-}08$$

$$C_{\text{NOx}} = 4.81\text{E-}6 \text{ lb/dscf}$$

16. NOx emission rate, lb/hr

$$\text{NOxER}_1 = 4.81\text{E-}6 \times 60 \times 7,010$$

$$\text{NOxER}_1 = 2.0 \text{ lb/hr}$$

17. NOx emission rate, lb/MMBtu, (Fuel meter)

$$\text{NOxER}_2 = \frac{(2.0)}{(17.83)}$$

$$\text{NOxER}_2 = 0.11 \text{ lb/MMBtu}$$

## EMISSION CALCULATIONS

Facility: Siemens

Source/Site: Boiler 2-Outlet

Test Date: Thursday, August 11, 1994

Run #: 3

---

18. NO<sub>x</sub> emission rate, lb/MMBtu, (F-factor)

$$\text{NO}_x\text{ER}_2 = (4.81\text{E-}6) (8,710) \frac{(20.9)}{(20.9 - 11.9)}$$

$$\text{NO}_x\text{ER}_2 = 0.10 \text{ lb/MMBtu}$$