


The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.



SOURCE TEST REPORT Gibson Oil and Refining, Inc.

BC Analytical
September 18, 1990

RECEIVED
OCT 1 1990

BC Analytical

KERN COUNTY AIR
POLLUTION CONTROL DIST

Testing Information

54

Facility: Gibson Oil and Refining, Inc.
Type of Unit: Natural gas-fired Boiler
Purpose of Test: AB 2588 EIR Data
Test Procedure: Emissions testing for PAHs, dioxins, furans, chlorobenzenes, formaldehyde and acetaldehyde, hydrogen sulfide, NOX, CO, SO2, THC, volatile organics, and metals.
Test Date: May 14-17, 1990

Client Information

Company: Gibson Oil and Refining, Inc.
3300 Truxtun Avenue, Suite 200
Bakersfield, CA 93301
Contact: Mr. Sam I. Haywood

Testing Firm Information

Company: BC Analytical
2000 Powell Street
Suite 1240
Emeryville, California 94608
Contact: Tom Stucker, manager
Air Emissions and Toxics Program
(415) 658-9367

2000 Powell Street
Suite 1240
Emeryville, CA
94608
415/658-9367
Fax: 415/658-2724

GIBSON 5240
Source Test Report

Page 2

BC Analytical
2000 Powell Street
Suite 1240
Emeryville, California 94608

Project Number: 5240


Report Date: September 18, 1990

Report Prepared By:



Dan Duncan
Project Engineer

Report Reviewed By:



Tom Stucker, Manager
Air Emissions and Toxics Program

RECEIVED
OCT 1 1990

Volume I

KERN COUNTY AIR
POLLUTION CONTROL TEST

Introduction	.4
Test Summary	.5
Formaldehyde and Acetaldehyde Emissions	.11
Volatile Organic Emissions (VOST)	.14
Hydrogen Sulfide Emissions	.17
Continuous Emissions Monitoring.	.18
Dioxins and Furans Emissions.	.21
Other Semi-Volatiles and HCl Emissions	.27
Total and Hexavalent Chromium Emissions	.36
Multiple Metals Emissions	.45
Lead Emissions	.54
Operating Conditions	.63

APPENDIX - Volume II Bound Separately

- Laboratory Results
- Continuous Monitoring Strip Charts
- Field Data Sheets
- Methods Descriptions

From May 14 through May 17, 1990, a BC Analytical test team collected a series of samples for Gibson Oil and Refining, Inc. at their facility in Bakersfield, Ca. All of the samples were collected from the stack of Gibson's natural gas-fired boiler with the exception of two bag samples which were taken from the compressor downstream from a collection tank. This report contains all of the data and results of the sampling and analysis undertaken and descriptions of the methods employed in the study.

The purpose of the study is to provide air toxics emission rates for inclusion in Gibson Oil's AB2588 Emission Inventory Report (EIR). The following table lists the sampling methods, number of sample replicates, sample run duration and approximate sample volume for each determination.

Throughout this report the symbols NA, ND, UTD, and BL are used to denote "Not Analyzed", "Not Detected", "Unable To Determine" (due to sample tube damage), and "indistinguishable from BLank" respectively.

Sampling Determination	Sample Method	Sampling Replicate	Sample Duration	Sample Volume
Traverse Points*1	CARB 1			
Volume Flow Rate*1	CARB 2			
Fixed Gases*1	CARB 3			
Moisture*1	CARB 4			
Dioxins, Furans, PAHs and HCl	CARB 428	3+FB	180 min.	90 ft ³
Aldehydes	CARB 430	3+FB	60 min.	30 ft ³
NOx, SO ₂ , CO, THC, O ₂ , and CO ₂	CARB 1-100	3	60 min.	-----
Hydrogen Sulfide	EPA 11	3	30 min.	30 L
Volatile Organics	VOST	3+FB	20 min.	20 L
Chromium VI & Total	CARB 425	3+FB	120 min.	60 ft ³
Multiple Metals	EPA MM	3+FB	120 min.	60 ft ³
Lead	CARB 12	3+FB	120 min.	60 ft ³

*1) Determined concurrently with every isokinetic sample runBC Analytical

GIBSON 5240
DATA SUMMARY

Page 5

Parameter	RUN 2	RUN 3	RUN 4	AVERAGE
PAH - HCl - NH3 Sampling				
Stack Conditions				
Temperature, °F	272	272	276	273
Velocity, ft/sec	21.0	20.5	19.8	20.4
Volume Flow Rate				
ACFM	2231	2179	2100	2170
SDCFM	1486	1455	1395	1445
% H2O	4.8	4.6	4.7	4.7
Fixed Gases				
%O2 vol.dry	16.5	16.5	16.0	16.3
%CO2 vol. dry	2.2	2.2	2.2	2.2
%N2 vol.dry	81.3	81.3	81.8	81.5
Total PAH Emissions				
ng/NM ³ @ 12%CO2	7.3	670	1910	863
ng/sec	31.2	2820	7710	3520
lb/hr	2.47E-07	2.23E-05	6.09E-05	2.78E-05
Dioxins and Furans				
Total tetra-octa PCDD				
ng/Nm3 @ 12% CO2	ND	ND	ND	ND
ng/sec	ND	ND	ND	ND
Total tetra-octa PCDF				
ng/Nm3 @ 12% CO2	ND	ND	ND	ND
ng/sec	ND	ND	ND	ND
Total Toxic Equivalent (2,3,7,8-TCDD Equivalents) (Ca scenario iv)				
ng/Nm3 @ 12%CO2				< 1.984
Dichlorobenzenes				
ng/NM ³ @ 12%CO2	ND	ND	94.3	
ng/sec	ND	ND	10.8	
lb/hr	ND	ND	8.51E-08	
Other Chlorobenzenes				
ng/NM ³ @ 12%CO2	ND	ND	ND	ND
ng/sec	ND	ND	ND	ND
lb/hr	ND	ND	ND	ND

Parameter	RUN 2	RUN 3	RUN 4	AVERAGE
-----------	-------	-------	-------	---------

PAH - HCl - NH3 Sampling
(continued)

NH3 Emissions

ppm	NA	NA	NA	NA
lb/hr	NA	NA	NA	NA

HCl Emissions

ppm	0.0040	0.0032	0.0044	0.0039
lb/hr	3.40E-05	2.67E-05	3.56E-05	3.21E-05

Aldehyde Emissions

mg/L Formaldehyde	6.26E-03	1.24E-03	2.99E-04	2.60E-03
lb/hr Formaldehyde	3.33E-02	6.60E-03	1.59E-03	1.38E-02

mg/L Acetaldehyde	2.14E-03	1.27E-04	4.75E-05	7.72E-04
lb/hr Acetaldehyde	1.14E-03	6.77E-04	2.53E-04	6.90E-04

H2S Emissions

ppm	BL	BL	BL	BL
lb/hr	BL	BL	BL	BL

Parameter	RUN 1	RUN 2	RUN 3	AVERAGE
-----------	-------	-------	-------	---------

Continuous Emissions Monitoring

CO, ppm vol. dry:	189.8	189.6	191.7	190.4
CO, lb/hr:	1.19	1.19	1.20	1.19

CO2, % vol. dry:	2.50	2.50	2.50	2.50
------------------	------	------	------	------

NOx, ppm vol. dry:	24.0	21.6	21.3	22.3
NOx, lb/hr:	0.248	0.222	0.220	0.230

O2, % vol. dry:	16.9	16.4	16.6	16.6
-----------------	------	------	------	------

SO2, ppm vol. dry:	0.29	0.05	0.01	0.12
SO2, lb/hr:	0.004	0.0007	0.0001	0.0016

THC as C1,				
ppm vol. dry:	646	390	324	453
THC as C1, lb/hr:	1.74	1.05	0.88	1.22

Parameter

RUN 5 RUN 6 RUN 7 AVERAGE

Volatile Organic Compounds
Compound

Acetone ppb	UTD	NA	NA	NA
Acetone lb/hr	UTD	NA	NA	
Benzene ppb	UTD	315	629	522
Benzene lb/hr	UTD	0.0055	0.011	0.0083
Carbon tetrachloride ppb	UTD	BL	BL	BL
Carbon tetrachloride lb/hr	UTD	BL	BL	BL
1,1-Dichloroethene ppb	UTD	BL	BL	BL
1,1-Dichloroethene lb/hr	UTD	BL	BL	BL
cis-1,2-Dichloroethene ppb	UTD	BL	BL	BL
cis-1,2-Dichloroethene lb/hr	UTD	BL	BL	BL
trans-1,2-Dichloroethene ppb	UTD	BL	BL	BL
trans-1,2-Dichloroethene lb/hr	UTD	BL	BL	BL
Ethylene dibromide ppb	UTD	NA	NA	NA
Ethylene dibromide lb/hr	UTD	NA	NA	NA
Methylene chloride ppb	UTD	BL	BL	BL
Methylene chloride lb/hr	UTD	BL	BL	BL
Methyl ethyl ketone ppb	UTD	NA	NA	NA
Methyl ethyl ketone lb/hr	UTD	NA	NA	NA
Methyl isobutyl ketone ppb	UTD	NA	NA	NA
Methyl isobutyl ketone lb/hr	UTD	NA	NA	NA
Phenol ppb	UTD	NA	NA	NA
Phenol lb/hr	UTD	NA	NA	NA
Toluene ppb	UTD	401	667	534
Toluene lb/hr	UTD	0.0083	0.014	0.011
Total xylene ppb	UTD	BL	BL	BL
Total xylene lb/hr	UTD	BL	BL	BL
Vinyl chloride ppb	UTD	BL	BL	BL
Vinyl chloride lb/hr	UTD	BL	BL	BL

GIBSON 5240

Page 8
AVERAGE

Parameter	RUN 5	RUN 6	RUN 7	AVERAGE
Chromium Testing				
Stack Conditions				
Temperature, °F	272	279	272	274
Velocity, ft/sec	20.3	20.0	19.4	19.9
Volume Flow Rate				
ACFM	2147	2116	2052	2105
SDCFM	1427	1395	1365	1396
% H2O	5.2	5.1	5.1	5.1
Fixed Gases				
%O2 vol.dry	16.7	16.7	16.7	16.7
%CO2 vol. dry	2.3	2.3	2.3	2.3
%N2 vol.dry	81.0	81.0	81.0	81.0
Total Chromium Emissions				
gr/SDCF	ND	ND	ND	ND
gr/SDCF @ 12% CO2	ND	ND	ND	ND
lb/hr	ND	ND	ND	ND
Hexavalent Chromium Emissions				
gr/SDCF	BL	BL	BL	BL
gr/SDCF @ 12% CO2	BL	BL	BL	BL
lb/hr	BL	BL	BL	BL

Parameter	RUN 9	RUN 10	RUN 11	AVERAGE
Lead Testing				
Stack Conditions				
Temperature, °F	280	278	262	273
Velocity, ft/sec	20.6	19.4	20.1	20.0
Volume Flow Rate				
ACFM	2179	2052	2136	2122
SDCFM	1433	1354	1443	1410
% H2O	5.0	5.0	4.8	5.0
Fixed Gases				
%O2 vol.dry	16.7	16.7	16.2	16.5
%CO2 vol. dry	2.3	2.3	2.9	2.5
%N2 vol.dry	81.0	81.0	80.9	80.9
Lead Emissions				
gr/SDCF	2.26E-08	2.65E-07	1.81E-07	1.56E-07
gr/SDCF @ 12% CO2	5.22E-08	6.12E-07	2.39E-07	3.01E-07
lb/hr	3.84E-06	4.78E-05	3.03E-05	2.73E-05

Parameter	RUN 13	RUN 14	RUN 15	AVERAGE
Multiple Metals Testing				
Stack Conditions				
Temperature, °F	270	264	262	265
Velocity, ft/sec	20.2	18.4	21.3	20.0
Volume Flow Rate				
ACFM	2139	1951	2263	2118
SDCFM	1428	1312	1531	1424
% H2O	5.0	5.0	4.7	4.9
Fixed Gases				
%O2 vol.dry	16.7	16.7	16.2	16.5
%CO2 vol. dry	2.3	2.3	2.9	2.5
%N2 vol.dry	81.0	81.0	80.9	81.0
Arsenic Emissions				
gr/SDCF	BL	BL	BL	BL
gr/SDCF @ 12% CO2	BL	BL	BL	BL
lb/hr	BL	BL	BL	BL
Beryllium Emissions				
gr/SDCF	ND	ND	ND	ND
gr/SDCF @ 12% CO2	ND	ND	ND	ND
lb/hr	ND	ND	ND	ND
Cadmium Emissions				
gr/SDCF	BL	BL	5.72E-07	
gr/SDCF @ 12% CO2	BL	BL	2.37E-06	
lb/hr	BL	BL	7.52E-06	
Chromium (Total) Emissions				
gr/SDCF	4.38E-08	7.97E-07	5.53E-07	4.65E-07
gr/SDCF @ 12% CO2	2.28E-07	4.16E-06	2.29E-06	2.23E-06
lb/hr	5.35E-07	8.98E-06	7.26E-06	5.59E-06
Copper Emissions				
gr/SDCF	8.73E-08	2.05E-07	BL	1.46E-07
gr/SDCF @ 12% CO2	4.55E-07	1.07E-06	BL	7.63E-07
lb/hr	1.07E-06	2.31E-06	BL	1.69E-06

GIBSON 5240

Page 10

Parameter	RUN 1	RUN 2	RUN 3	AVERAGE
Lead Emissions				
gr/SDCF	2.18E-08	BL	1.97E-08	2.08E-08
gr/SDCF @ 12% CO2	1.14E-07	BL	8.17E-08	9.79E-08
lb/hr	2.67E-07	BL	2.59E-07	2.63E-07
Manganese Emissions				
gr/SDCF	ND	ND	ND	ND
gr/SDCF @ 12% CO2	ND	ND	ND	ND
lb/hr	ND	ND	ND	ND
Mercury Emissions				
gr/SDCF	BL	BL	5.92E-08	
gr/SDCF @ 12% CO2	BL	BL	2.45E-07	
lb/hr	BL	BL	7.78E-07	
Nickel Emissions				
gr/SDCF	5.02E-07	1.37E-07	1.18E-07	2.52E-07
gr/SDCF @ 12% CO2	2.62E-06	7.13E-07	4.90E-07	1.27E-06
lb/hr	6.15E-06	1.54E-06	1.56E-06	3.08E-06
Selenium Emissions				
gr/SDCF	ND	ND	ND	ND
gr/SDCF @ 12% CO2	ND	ND	ND	ND
lb/hr	ND	ND	ND	ND
Zinc Emissions				
gr/SDCF	BL	4.56E-06	BL	
gr/SDCF @ 12% CO2	BL	2.38E-05	BL	
lb/hr	BL	5.13E-05	BL	

Compressor Gas Testing

	Bag 1	Bag 2	Average
Methane, ppm	910	920	915
Ethane, ppm	56	56	56
Propane, ppm	16	16	16
n-Butane, ppm	140	140	140
Ethylene, ppm	< 2	< 2	< 2
Propylene, ppm	< 2	< 2	< 2
Isobutane, ppm	14	16	15

GIBSON 5240

FORMALDEHYDE AND ACETALDEHYDE

DATA AND RESULTS:

CLIENT:	Gibson Oil	RUN #:	ALD-1
DATE:	May 14, 1990	LOG #:	05-292-1
UNIT:	Boiler	FIELD BLANK:	05-292-4
SAMPLE:	Outlet	TRIP BLANK:	05-292-5

SAMPLING DATA:

Bar. Press. (in.Hg)	29.50	Meter	Meter	Std.Vol.	Std.Vol.
Standard Temp. (F)	60	Vol.,	Temp.,	Meter,	Meter,
Std Press. (in.Hg.)	29.92	Liters	deg. F	Liters	SDCF
SDCFM	1419				
		68.00	72.5	65.47	2.312

ANALYTICAL DATA:

ND = Not Detected

Compound Name	MW gm/mole	Total Sample mg	Conc. mg/L Vol.Dry	Emission Rate g/sec	Conc. ppm Vol.Dry	Emission Rate Lb/Hr	TOTAL MILLIGRAMS FIELD BLANK 05-292-4
Formaldehyde	30.03	0.410	6.26E-03	4.19E-03	4.94	3.33E-02	0.0014
Acetaldehyde	44.05	0.014	2.14E-04	1.43E-04	0.11	1.14E-03	0.0002

GIBSON 5240

FORMALDEHYDE AND ACETALDEHYDE

DATA AND RESULTS:

CLIENT:	Gibson Oil	RUN #:	ALD-2
DATE:	May 14, 1990	LOG #:	05-292-2
UNIT:	Boiler	FIELD BLANK:	05-292-4
SAMPLE:	Outlet	TRIP BLANK:	05-292-5

SAMPLING DATA:

Bar. Press. (in.Hg)	29.50	Meter	Meter	Std.Vol.	Std.Vol.
Standard Temp. (F)	60	Vol.,	Temp.,	Meter,	Meter,
Std Press. (in.Hg.)	29.92	Liters	deg. F	Liters	SDCF
SDCFM	1419				
		64.00	76.1	61.21	2.161

ANALYTICAL DATA:

ND = Not Detected

Compound Name	MW gm/mole	Total Sample mg	Conc. mg/L Vol.Dry	Emission Rate g/sec	Conc. ppm Vol.Dry	Emission Rate Lb/Hr	TOTAL MILLIGRAMS
							FIELD BLANK 05-292-4
Formaldehyde	30.03	0.0760	1.24E-03	8.32E-04	0.98	6.60E-03	0.0014
Acetaldehyde	44.05	0.0078	1.27E-04	8.54E-05	0.07	6.77E-04	0.0002

GIBSON 5240

FORMALDEHYDE AND ACETALDEHYDE

DATA AND RESULTS:

CLIENT:	Gibson Oil	RUN #:	ALD-3
DATE:	May 14, 1990	LOG #:	05-292-3
UNIT:	Boiler	FIELD BLANK:	05-292-4
SAMPLE:	Outlet	TRIP BLANK:	05-292-5

SAMPLING DATA:

Bar. Press. (in.Hg)	29.50	Meter	Meter	Std.Vol.	Std.Vol.
Standard Temp. (F)	60	Vol.,	Temp.,	Meter,	Meter,
Std Press. (in.Hg.)	29.92	Liters	deg. F	Liters	SDCF
SDCFM	1419				
		60.00	81.2	56.84	2.007

ANALYTICAL DATA:

ND = Not Detected

Compound Name	MW gm/mole	Total Sample mg	Conc. mg/L Vol.Dry	Emission Rate g/sec	Conc. ppm Vol.Dry	Emission Rate Lb/Hr	TOTAL MILLIGRAMS FIELD BLANK 05-292-4
Formaldehyde	30.03	0.0170	2.99E-04	2.00E-04	0.24	1.59E-03	0.0014
Acetaldehyde	44.05	0.0027	4.75E-05	3.18E-05	0.03	2.53E-04	0.0002

GIBSON 5240

Page 14

VOLATILE ORGANIC HYDROCARBON

DATA AND RESULTS:

CLIENT:	Gibson Oil	RUN #:	5 A&B
DATE:	May 14, 1990	TUBE #s:	05-293-1
UNIT:	Boiler	FIELD BLANK:	05-293-4
SAMPLE:	Outlet	TRIP BLANK:	05-293-5

SAMPLING DATA:

Bar. Press. (in.Hg)	30.04	Meter	Meter	Std.Vol.	Std.Vol.
Standard Temp. (F)	60	Vol.,	Temp.,	Meter,	Meter,
Std Press. (in.Hg.)	29.92	Liters	deg. F	Liters	SDCF
SDCFM	1419				
		20	79.7	19.347	0.683

ANALYTICAL DATA:		UTD = Unable to determine due to sample tube breakage					TOTAL MICROGRAMS	
ND = Not Detected		BL = Indistinguishable from Blank						
NA = Not Analyzed								
Compound	MW	Total Sample	Conc. ug/L	Emission Rate	Conc. ppb	Emission Rate	FIELD BLANK	TRIP BLANK
Name	gm/mole	ng	Vol.Dry	g/sec	Vol.Dry	Lb/Hr	05-293-4	05-293-5
=====								
Benzene	78.11	UTD	UTD	UTD	UTD	UTD	UTD	<5
Carbon tetrachloride	153.84	UTD	UTD	UTD	UTD	UTD	UTD	<5
1,1-Dichloroethene	96.95	UTD	UTD	UTD	UTD	UTD	UTD	<5
trans-1,2-Dichloroethene	96.95	UTD	UTD	UTD	UTD	UTD	UTD	<5
Methylene chloride	84.94	UTD	UTD	UTD	UTD	UTD	UTD	<5
Toluene	92.13	UTD	UTD	UTD	UTD	UTD	UTD	<5
Vinyl chloride	62.98	UTD	UTD	UTD	UTD	UTD	UTD	<5
Acetone	58.08	UTD	UTD	UTD	UTD	UTD	UTD	<5
Methyl ethyl ketone (MEK)	72.11	UTD	UTD	UTD	UTD	UTD	UTD	<5
Methyl isobutyl ketone	100.16	UTD	UTD	UTD	UTD	UTD	UTD	<5
Total xylene isomers	106.16	UTD	UTD	UTD	UTD	UTD	UTD	<25
cis-1,2-Dichloroethene	96.95	UTD	UTD	UTD	UTD	UTD	UTD	<5

VOLATILE ORGANIC HYDROCARBON

DATA AND RESULTS:

CLIENT:	Gibson Oil	RUN #:	6 A&B
DATE:	May 14, 1990	TUBE #s:	05-293-2
UNIT:	Boiler	FIELD BLANK:	05-293-4
SAMPLE:	Outlet	TRIP BLANK:	05-293-5

SAMPLING DATA:

Bar. Press. (in.Hg)	30.04	Meter	Meter	Std.Vol.	Std.Vol.
Standard Temp. (F)	60	Vol.,	Temp.,	Meter,	Meter,
Std Press. (in.Hg.)	29.92	Liters	deg. F	Liters	SDCF
SDCFM	1419				
		20	82.22	19.257	0.680

ANALYTICAL DATA:		UTD = Unable to determine due to sample tube breakage					TOTAL NANOGRAMS	
ND = Not Detected		BL = Indistinguishable from Blank						
NA = Not Analyzed								
Compound	MW	Total Sample	Conc. ug/L	Emission Rate	Conc. ppb	Emission Rate	FIELD BLANK	TRIP BLANK
Name	gm/mole	ng	Vol.Dry	g/sec	Vol.Dry	Lb/Hr	05-293-4	05-293-5
Benzene	78.11	20000	1.0386	7.00E-04	314.99	5.52E-03	UTD	<5000
Carbon tetrachloride	153.84	BL	BL	BL	BL	BL	UTD	<5000
1,1-Dichloroethene	96.95	BL	BL	BL	BL	BL	UTD	<5000
trans-1,2-Dichloroethene	96.95	BL	BL	BL	BL	BL	UTD	<5000
Methylene chloride	84.94	BL	BL	BL	BL	BL	UTD	<5000
Toluene	92.13	30000	1.5578	1.05E-03	400.58	8.28E-03	UTD	<5000
Vinyl chloride	62.98	BL	BL	BL	BL	BL	UTD	<5000
Acetone	58.08	NA	NA	NA	NA	NA	UTD	<5000
Methyl ethyl ketone (MEK)	72.11	NA	NA	NA	NA	NA	UTD	<5000
Methyl isobutyl ketone	100.16	NA	NA	NA	NA	NA	UTD	<5000
Total xylene isomers	106.16	BL	BL	BL	BL	BL	UTD	<25000
cis-1,2-Dichloroethene	96.95	BL	BL	BL	BL	BL	UTD	<5000

GIBSON 5240

Page 16

VOLATILE ORGANIC HYDROCARBON

DATA AND RESULTS:

CLIENT:	Gibson Oil	RUN #:	7 A&B
DATE:	May 14, 1990	TUBE #s:	05-293-3
UNIT:	Boiler	FIELD BLANK:	05-293-4
SAMPLE:	Outlet	TRIP BLANK:	05-293-5

SAMPLING DATA:

Bar. Press. (in.Hg)	30.04	Meter	Meter	Std.Vol.	Std.Vol.
Standard Temp. (F)	60	Vol.,	Temp.,	Meter,	Meter,
Std Press. (in.Hg.)	29.92	Liters	deg. F	Liters	SDCF
SDCFM	1419				
		20	81.68	19.277	0.681

ANALYTICAL DATA:		UTD = Unable to determine due to sample tube breakage					TOTAL NANOGRAMS	
ND = Not Detected		BL = Indistinguishable from Blank						
NA = Not Analyzed								
Compound	MW	Total Sample	Conc.	Emission	Conc.	Emission	FIELD	TRIP
Name	gm/mole	ng	ug/L	Rate	ppb	Rate	BLANK	BLANK
			Vol.Dry	g/sec	Vol.Dry	Lb/Hr	05-293-4	05-293-5
=====								
Benzene	78.11	40000	2.0751	1.40E-03	629.35	1.10E-02	UTD	<5000
Carbon tetrachloride	153.84	BL	BL	BL	BL	BL	UTD	<5000
1,1-Dichloroethene	96.95	BL	BL	BL	BL	BL	UTD	<5000
trans-1,2-Dichloroethene	96.95	BL	BL	BL	BL	BL	UTD	<5000
Methylene chloride	84.94	BL	BL	BL	BL	BL	UTD	<5000
Toluene	92.13	50000	2.5938	1.75E-03	666.97	1.38E-02	UTD	<5000
Vinyl chloride	62.98	BL	BL	BL	BL	BL	UTD	<5000
Acetone	58.08	NA	NA	NA	NA	NA	UTD	<5000
Methyl ethyl ketone (MEK)	72.11	NA	NA	NA	NA	NA	UTD	<5000
Methyl isobutyl ketone	100.16	NA	NA	NA	NA	NA	UTD	<5000
Total xylene isomers	106.16	BL	BL	BL	BL	BL	UTD	<25000
cis-1,2-Dichloroethene	96.95	BL	BL	BL	BL	BL	UTD	<5000

GIBSON 5240

Page 17

H2S DATA AND RESULTS

CLIENT:	Gibson Oil	Pbar (in.Hg)	29.87
DATE:	16-May-90	Pstd (in.Hg)	29.92
UNIT:	Boiler	Standard (F)	60
SAMPLE:	Outlet	N KI3	0.00974
SDCFM	1419	N Na2S2O3	0.00998

METER DATA	Run 1	Run 2	Run 3
Initial Meter	0.000	0.000	0.000
Final Meter	1.059	1.059	1.413
Meter Temp (F)	85	85	85
Delta H (in.H2O)	0.00	0.00	0.00
Vm std.	1.009	1.009	1.346

TITRATIONS	Run 1	Run 2	Run 3	Blank
Vol. KI3	50.00	50.00	50.00	50.00
Vol. Na2S2O3	50.70	49.35	48.90	47.95
Net Milli. Eqv.	-0.0192	-0.0057	-0.0012	0.0083

RESULTS	Run 1	Run 2	Run 3	Average
ppm	-11.4	-5.8	-2.9	-6.7
Lb/Hr	-2.55E-03	-1.30E-03	-6.60E-04	-1.50E-03

CONTINUOUS EMISSIONS MONITORING
Sample Run #1 of 3

Client: Gibson Oil and Refining

Date Start Time

Stop Time

Interval

5/16/90

12:34

13:34

5 Min.

Interval	O2 % vol. dry	NOx ppm	So2 ppm	CO ppm	CO2 % vol. dry	THC as C3 ppm
1	16.7	20.1	0.6	188.8	2.5	192.3
2	16.8	21.1	0.4	193.2	2.5	236.1
3	16.9	22.0	0.4	185.5	2.5	204.4
4	17.0	22.4	0.3	189.6	2.5	230.2
5	17.0	23.2	0.2	182.2	2.5	208.7
6	16.9	23.7	0.2	191.6	2.5	206.7
7	17.0	24.3	0.1	189.1	2.5	225.4
8	17.0	25.5	0.1	188.9	2.5	230.5
9	16.9	25.9	0.2	190.2	2.5	248.4
10	17.0	26.1	0.2	192.6	2.5	196.7
11	17.0	26.4	0.3	192.6	2.5	182.6
12	17.1	27.5	0.5	193.8	2.5	222.2

CONTINUOUS EMISSIONS MONITORING
Sample Run #2 of 3

Client: Gibson Oil and Refining

Date 5/16/90
Start Time 13:49

Stop Time 14:49

Interval
5 Min.

Interval	O2 % vol. dry	NOx ppm	So2 ppm	CO ppm	CO2 % vol. dry	THC as C3 ppm
1	16.7	21.1	0.5	182.3	2.5	142.2
2	16.5	21.6	0.1	192.4	2.5	124.6
3	16.4	21.2	0.0	193.1	2.5	126.0
4	16.4	21.0	0.0	198.1	2.5	134.9
5	16.4	21.4	0.0	184.7	2.5	128.4
6	16.5	20.7	0.0	170.6	2.4	104.5
7	16.3	21.7	0.0	187.4	2.5	140.3
8	16.3	21.8	0.0	194.5	2.5	143.9
9	16.3	21.6	0.0	190.5	2.5	114.8
10	16.3	21.8	0.0	189.4	2.5	114.5
11	16.3	22.2	0.0	192.6	2.5	134.5
12	16.3	22.5	0.0	200.0	2.5	149.5

CONTINUOUS EMISSIONS MONITORING
Sample Run #3 of 3

Client: Gibson Oil and Refining

Date Start Time

Stop Time

Interval

5/16/90

15:04

16:04

5 Min.

Interval	O2 % vol. dry	NOx ppm	So2 ppm	CO ppm	CO2 % vol. dry	THC as C3 ppm
1	16.6	19.3	0.1	186.0	2.5	114.2
2	16.6	20.1	0.0	188.0	2.5	109.6
3	16.6	20.4	0.0	195.4	2.5	123.4
4	16.7	21.2	0.0	192.7	2.5	112.1
5	16.7	21.5	0.0	194.7	2.5	115.9
6	16.6	22.1	0.0	190.4	2.5	100.2
7	16.7	22.2	0.0	190.5	2.5	98.7
8	16.7	22.2	0.0	191.3	2.5	122.9
9	16.6	22.2	0.0	190.4	2.5	103.9
10	16.6	21.5	0.0	196.8	2.5	112.2
11	16.7	21.4	0.0	193.0	2.5	94.2
12	16.5	21.8	0.0	191.1	2.6	93.8

GIBSON 5240

Page 21

CLIENT: Gibson Oil
 RESULTS: Tetra - Octa PCDDs and PCDFs
 DATE: 05-15-90
 TIME: 15:01
 RUN: 2

		@ 0' C		DRY	
		STACK	ME	%CO2	%O2
		NM3/S	NM3		
		0.663789	3.25	2.2	0
COMPOUND		ng	ng/NM3 @12% CO2	ng/s	lbs/hr
2378 TCDD	<	0.490	< 0.822	< 0.100	< 7.94E-10
TOTAL TCDD	<	1.300	< 2.181	< 0.265	< 2.11E-09
12378 PeCDD	<	0.500	< 0.839	< 0.102	< 8.10E-10
TOTAL PeCDD	<	0.500	< 0.839	< 0.102	< 8.10E-10
123478 HxCDD	<	0.640	< 1.074	< 0.131	< 1.04E-09
123678 HxCDD	<	0.620	< 1.040	< 0.127	< 1.00E-09
123789 HxCDD	<	0.640	< 1.074	< 0.131	< 1.04E-09
TOTAL HxCDD	<	0.640	< 1.074	< 0.131	< 1.04E-09
1234678 HpCDD	<	0.290	< 0.487	< 0.059	< 4.70E-10
TOTAL HpCDD	<	0.290	< 0.487	< 0.059	< 4.70E-10
TOTAL OCDD	<	0.087	< 0.146	< 0.018	< 1.41E-10
TOTAL PCDD	<	2.817	< 4.727	< 0.575	< 4.57E-09
2378 TCDF	<	0.780	< 1.309	< 0.159	< 1.26E-09
TOTAL TCDF	<	0.780	< 1.309	< 0.159	< 1.26E-09
12378 PeCDF	<	0.780	< 1.309	< 0.159	< 1.26E-09
23478 PeCDF	<	0.200	< 0.336	< 0.041	< 3.24E-10
TOTAL PeCDF	<	0.200	< 0.336	< 0.041	< 3.24E-10
123478 HxCDF	<	0.460	< 0.772	< 0.094	< 7.45E-10
123678 HxCDF	<	0.460	< 0.772	< 0.094	< 7.45E-10
234678 HxCDF	<	0.440	< 0.738	< 0.090	< 7.13E-10
123789 HxCDF	<	0.450	< 0.755	< 0.092	< 7.29E-10
TOTAL HxCDF	<	0.460	< 0.772	< 0.094	< 7.45E-10
1234678 HpCDF	<	0.330	< 0.554	< 0.067	< 5.35E-10
1234789 HpCDF	<	0.300	< 0.503	< 0.061	< 4.86E-10
TOTAL HpCDF	<	0.330	< 0.554	< 0.067	< 5.35E-10
TOTAL OCDF	<	0.080	< 0.134	< 0.016	< 1.30E-10
TOTAL PCDF	<	1.850	< 3.104	< 0.378	< 3.00E-09
TOTAL PCDD & PCDF	<	4.667	< 7.831	< 0.953	< 7.56E-09

MDLs: Minimum Detection Limits are used for Non-Detectable congeners.

GIBSON 5240

Page 22

CLIENT: Gibson Oil
 RESULTS: Tetra - Octa PCDDs and PCDFs
 DATE: 05-15-89
 TIME: 14:25
 RUN: 3

		@ 0' C		DRY	
		STACK NM3/S	METER NM3	%CO2	%O2
		0.649708	4.44719	2.2	0
COMPOUND	ng	ng/NM3 @12% CO2		ng/s	lbs/hr
2378 TCDD	< 0.140	< 0.172	<	0.020	< 1.62E-10
TOTAL TCDD	< 0.400	< 0.491	<	0.058	< 4.64E-10
12378 PeCDD	< 0.081	< 0.099	<	0.012	< 9.39E-11
TOTAL PeCDD	< 0.081	< 0.099	<	0.012	< 9.39E-11
123478 HxCDD	< 0.080	< 0.098	<	0.012	< 9.28E-11
123678 HxCDD	< 0.080	< 0.098	<	0.012	< 9.28E-11
123789 HxCDD	< 0.080	< 0.098	<	0.012	< 9.28E-11
TOTAL HxCDD	< 0.080	< 0.098	<	0.012	< 9.28E-11
1234678 HpCDD	< 0.074	< 0.091	<	0.011	< 8.58E-11
TOTAL HpCDD	< 0.083	< 0.102	<	0.012	< 9.62E-11
TOTAL OCDD	< 0.088	< 0.108	<	0.013	< 1.02E-10
TOTAL PCDD	< 0.732	< 0.898	<	0.107	< 8.49E-10
2378 TCDF	< 0.080	< 0.098	<	0.012	< 9.28E-11
TOTAL TCDF	< 0.083	< 0.102	<	0.012	< 9.62E-11
12378 PeCDF	< 0.052	< 0.064	<	0.008	< 6.03E-11
23478 PeCDF	< 0.054	< 0.066	<	0.008	< 6.26E-11
TOTAL PeCDF	< 0.054	< 0.066	<	0.008	< 6.26E-11
123478 HxCDF	< 0.054	< 0.066	<	0.008	< 6.26E-11
123678 HxCDF	< 0.053	< 0.065	<	0.008	< 6.15E-11
234678 HxCDF	< 0.052	< 0.064	<	0.008	< 6.03E-11
123789 HxCDF	< 0.052	< 0.064	<	0.008	< 6.03E-11
TOTAL HxCDF	< 0.054	< 0.066	<	0.008	< 6.26E-11
1234678 HpCDF	< 0.074	< 0.091	<	0.011	< 8.58E-11
1234789 HpCDF	< 0.076	< 0.093	<	0.011	< 8.81E-11
TOTAL HpCDF	< 0.079	< 0.097	<	0.012	< 9.16E-11
TOTAL OCDF	< 0.081	< 0.099	<	0.012	< 9.39E-11
TOTAL PCDF	< 0.351	< 0.431	<	0.051	< 4.07E-10
TOTAL PCDD & PCDF	< 1.083	< 1.328	<	0.158	< 1.26E-09

MDLs: Minimum Detection Limits are used for Non-Detectable congeners

GIBSON 5240

CLIENT: Gibson Oil
 RESULTS: Tetra - Octa PCDDs and PCDFs
 DATE: 05-16-90
 TIME: 08:44
 RUN: 4

		@ 0' C		DRY	
		STACK	MET	%CO2	%O2
		NM3/S	NM3		
		0.622911	2.776	2.2	0
COMPOUND	ng	ng/NM3 @12% CO2		ng/s	lbs/hr
2378 TCDD	< 0.080	< 0.157	<	0.018	< 1.42E-10
TOTAL TCDD	< 0.084	< 0.165	<	0.019	< 1.50E-10
12378 PeCDD	< 0.051	< 0.100	<	0.011	< 9.08E-11
TOTAL PeCDD	< 0.051	< 0.100	<	0.011	< 9.08E-11
123478 HxCDD	< 0.080	< 0.157	<	0.018	< 1.42E-10
123678 HxCDD	< 0.081	< 0.159	<	0.018	< 1.44E-10
123789 HxCDD	< 0.080	< 0.157	<	0.018	< 1.42E-10
TOTAL HxCDD	< 0.081	< 0.159	<	0.018	< 1.44E-10
1234678 HpCDD	< 0.083	< 0.163	<	0.019	< 1.48E-10
TOTAL HpCDD	< 0.083	< 0.163	<	0.019	< 1.48E-10
TOTAL OCDD	< 0.085	< 0.167	<	0.019	< 1.51E-10
TOTAL PCDD	< 0.384	< 0.754	<	0.086	< 6.84E-10
2378 TCDF	< 0.047	< 0.092	<	0.011	< 8.37E-11
TOTAL TCDF	< 0.047	< 0.092	<	0.011	< 8.37E-11
12378 PeCDF	< 0.049	< 0.096	<	0.011	< 8.72E-11
23478 PeCDF	< 0.046	< 0.090	<	0.010	< 8.19E-11
TOTAL PeCDF	< 0.049	< 0.096	<	0.011	< 8.72E-11
123478 HxCDF	< 0.063	< 0.124	<	0.014	< 1.12E-10
123678 HxCDF	< 0.061	< 0.120	<	0.014	< 1.09E-10
234678 HxCDF	< 0.061	< 0.120	<	0.014	< 1.09E-10
123789 HxCDF	< 0.063	< 0.124	<	0.014	< 1.12E-10
TOTAL HxCDF	< 0.063	< 0.124	<	0.014	< 1.12E-10
1234678 HpCDF	< 0.076	< 0.149	<	0.017	< 1.35E-10
1234789 HpCDF	< 0.083	< 0.163	<	0.019	< 1.48E-10
TOTAL HpCDF	< 0.076	< 0.149	<	0.017	< 1.35E-10
TOTAL OCDF	< 0.081	< 0.159	<	0.018	< 1.44E-10
TOTAL PCDF	< 0.316	< 0.621	<	0.071	< 5.63E-10
TOTAL PCDD & PCDF	< 0.700	< 1.375	<	0.157	< 1.25E-09

MDLs: Minimum Detection Limits are used for Non-Detectable congeners

GIBSON 5240

CLIENT: Gibson Oil
 RESULTS: Tetra - Octa PCDDs and PCDFs
 THREE RUN AVERAGE CONCENTRATION

		ng/Nm3 AT 12 % CO2						
COMPOUND		RUN 2		RUN 3		RUN 4		AVERAGE
2378 TCDD	<	0.822	<	0.172	<	0.157	<	0.384
TOTAL TCDD	<	2.181	<	0.491	<	0.165	<	0.946
12378 PeCDD	<	0.839	<	0.099	<	0.100	<	0.346
TOTAL PeCDD	<	0.839	<	0.099	<	0.100	<	0.346
123478 HxCDD	<	1.074	<	0.098	<	0.157	<	0.443
123678 HxCDD	<	1.040	<	0.098	<	0.159	<	0.433
123789 HxCDD	<	1.074	<	0.098	<	0.157	<	0.443
TOTAL HxCDD	<	1.074	<	0.098	<	0.159	<	0.444
1234678 HpCDD	<	0.487	<	0.091	<	0.163	<	0.247
TOTAL HpCDD	<	0.487	<	0.102	<	0.163	<	0.250
TOTAL OCDD	<	0.146	<	0.108	<	0.167	<	0.140
TOTAL PCDD	<	4.727	<	0.898	<	0.754	<	2.126
2378 TCDF	<	1.309	<	0.098	<	0.092	<	0.500
TOTAL TCDF	<	1.309	<	0.102	<	0.092	<	0.501
12378 PeCDF	<	1.309	<	0.064	<	0.096	<	0.490
23478 PeCDF	<	0.336	<	0.066	<	0.090	<	0.164
TOTAL PeCDF	<	0.336	<	0.066	<	0.096	<	0.166
123478 HxCDF	<	0.772	<	0.066	<	0.124	<	0.321
123678 HxCDF	<	0.772	<	0.065	<	0.120	<	0.319
234678 HxCDF	<	0.738	<	0.064	<	0.120	<	0.307
123789 HxCDF	<	0.755	<	0.064	<	0.124	<	0.314
TOTAL HxCDF	<	0.772	<	0.066	<	0.124	<	0.321
1234678 HpCDF	<	0.554	<	0.091	<	0.149	<	0.265
1234789 HpCDF	<	0.503	<	0.093	<	0.163	<	0.253
TOTAL HpCDF	<	0.554	<	0.097	<	0.149	<	0.267
TOTAL OCDF	<	0.134	<	0.099	<	0.159	<	0.131
TOTAL PCDF	<	3.104	<	0.431	<	0.621	<	1.385
TOTAL PCDD & PCDF	<	7.831	<	1.328	<	1.375	<	3.511

MDLs: Minimum Detection Limits are used for Non-Detectable congeners.

GIBSON 5240

Page 25

CLIENT: Gibson Oil

RESULTS: Tetra - Octa PCDDs and PCDFs

Average Toxic Equivalent Emissions
EPA Scenario (ng/Nm3 at 12 % CO2)

COMPOUND	Multiplying factor	Average		Toxic equivalent	
2378 TCDD	1.00000	<	0.384	<	0.384
Other TCDD	0.01000	<	0.562	<	0.006
12378 PeCDD	0.50000	<	0.346	<	0.173
Other PeCDD	0.00500	<	0.000	<	0.000
123478 HxCDD	0.04000	<	0.443	<	0.018
123678 HxCDD	0.04000	<	0.433	<	0.017
123789 HxCDD	0.04000	<	0.443	<	0.018
Other HxCDD	0.00040	<	-0.875	<	0.000
1234678 HpCDD	0.00100	<	0.247	<	0.000
Other HpCDD	0.00001	<	0.004	<	0.000
OCDD	0.00000	<	0.140	<	0.000
TOTAL PCDD		<	2.126	<	0.615
2378 TCDF	0.10000	<	0.500	<	0.050
Other TCDF	0.00100	<	0.001	<	0.000
12378 PeCDF	0.10000	<	0.490	<	0.049
23478 PeCDF	0.10000	<	0.164	<	0.016
Other PeCDF	0.00100	<	-0.488	<	0.000
123478 HxCDF	0.01000	<	0.321	<	0.003
123678 HxCDF	0.01000	<	0.319	<	0.003
234678 HxCDF	0.01000	<	0.307	<	0.003
123789 HxCDF	0.01000	<	0.314	<	0.003
Other HxCDF	0.00010	<	-0.940	<	0.000
1234678 HpCDF	0.00100	<	0.265	<	0.000
1234789 HpCDF	0.00100	<	0.253	<	0.000
Other HpCDF	0.00100	<	-0.251	<	0.000
OCDF	0.00000	<	0.131	<	0.000
TOTAL PCDF		<	1.385	<	0.128

Total Toxic Equivalent (2,3,7,8-TCDD Equivalents) 0.743

MDLs: Minimum Detection Limits are used for Non-Detectable congeners.

GIBSON 5240

Page 26

CLIENT: Gibson Oil

RESULTS: Tetra - Octa PCDDs and PCDFs

Average Toxic Equivalent Emissions
CA Scenario iv (ng/Nm3 at 12 % CO2)

COMPOUND	Multiplying factor		Average		Toxic Equivalent
2378 TCDD	1.00	<	0.384	<	0.384
Other TCDD	0.00	<	0.562	<	0.000
12378 PeCDD	1.00	<	0.346	<	0.346
Other PeCDD	0.00	<	0.000	<	0.000
123478 HxCDD	0.03	<	0.443	<	0.013
123678 HxCDD	0.03	<	0.433	<	0.013
123789 HxCDD	0.03	<	0.443	<	0.013
Other HxCDD	0.00	<	-0.875	<	0.000
1234678 HpCDD	0.03	<	0.247	<	0.007
Other HpCDD	0.00	<	0.004	<	0.000
OCDD	0.00	<	0.140	<	0.000
<u>TOTAL PCDD</u>		<	<u>2.126</u>	<	<u>0.777</u>
2378 TCDF	1.00	<	0.500	<	0.500
Other TCDF	0.00	<	0.001	<	0.000
12378 PeCDF	1.00	<	0.490	<	0.490
23478 PeCDF	1.00	<	0.164	<	0.164
Other PeCDF	0.00	<	-0.488	<	0.000
123478 HxCDF	0.03	<	0.321	<	0.010
123678 HxCDF	0.03	<	0.319	<	0.010
234678 HxCDF	0.03	<	0.307	<	0.009
123789 HxCDF	0.03	<	0.314	<	0.009
Other HxCDF	0.00	<	-0.940	<	0.000
1234678 HpCDF	0.03	<	0.265	<	0.008
1234789 HpCDF	0.03	<	0.253	<	0.008
Other HpCDF	0.00	<	-0.251	<	0.000
OCDF	0.00	<	0.131	<	0.000
<u>TOTAL PCDF</u>		<	<u>1.385</u>	<	<u>1.207</u>

Total Toxic Equivalent (2,3,7,8-TCDD Equivalents) < 1.984

MDLs: Minimum Detection Limits are used for Non-Detectable congeners.

GIBSON 5240

Page 27

SEMI-VOLATILE EMISSIONS TEST MONITOR DATA

DATE: May 15, 1990	Pbar(in. Hg): 29.49	Nozzle q90009	Diameter (mm): 9.680
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.48	LCD Meter	789 Cor.Fact.: 1.0319
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	2 Orifice Km: 0.60
RUN #: 2	Initial %H2O: 5.0	Probe Liner: SS	Filter Holder: SS

PORT NORTH				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	15	1	276	0.08	86	792.933		19.1	1.87	0.64	
2	3	16	38	276	0.06	86		7	16.5	1.46	0.55	
3	2	17	1	278	0.10	85			21.4	2.27	0.71	
4	1	17	23	280	0.13	86		12	24.4	2.88	0.81	
		17	46				853.611					

Sample Time =	90	278	0.09	86	62.614		20.3	2.12	103.6
---------------	----	-----	------	----	--------	--	------	------	-------

PORT WEST				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	18	0	244	0.12	82	853.611	11	22.9	2.78	0.79	
2	3	18	23	271	0.13	84			24.2	2.90	0.81	
3	2	18	45	279	0.09	84		8	20.3	2.06	0.67	
4	1	19	8	271	0.09	84			20.2	2.08	0.67	
		19	30				917.099					

Sample Time =	90	266	0.11	83	65.513		21.9	2.46	99.0
Post-Test Leak Rate	0.020 CFM	at	8 in. Hg.						

Test Summary

Sample Time =	180	272		84	128.127		21.1	2.29	101.2
					NET CU. FT.				

SEMI-VOLATILE EMISSIONS

Data and Results:

Date: May 15, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 2
 Time: 15:01
 Project DRD
 Project 5240

Liquid Analysis:

Gas Composition:

Selected Results:

Absorber Type	Contents	Final	Tare	Net			
Mod. Grnbg.	H2O	700.60	599.50	101.10	%CO2 volume	2.2	Wet MW 28.48
Lg. Grnbg.	H2O	595.50	598.60	-3.10	%O2 volume	16.5	Excess Air
Mod. Grnbg.	EMPTY	530.00	527.40	2.60	%CO volume	0.0	
Mod. Grnbg.	SILICA GEL	803.10	771.30	31.80	%N2 volume	81.3	Vm Standard 121.319
				0.00	%H2O volume	4.8	%Isokinetic 104.1
			Total	132.40			Standard T 60

PAH and Chlorobenzene Analysis

COMPOUND	ng	ng/NM3 @12% CO2	ng/s	lbs/hr
Naphthalene	BL	BL	BL	BL
Acenaphthylene	28	46.98	5.7	4.52E-08
Acenaphthene	57	95.64	11.6	9.19E-08
Fluorene	68	114.10	13.9	1.10E-07
Phenanthrene	BL	BL	BL	BL
Anthracene	BL	BL	BL	BL
Fluoranthene	BL	BL	BL	BL
Pyrene	BL	BL	BL	BL
Chrysene	BL	BL	BL	BL
Benz(a)anthracene	BL	BL	BL	BL
Benzo(b+k)fluoranthene	ND	ND	ND	ND
Benzo(a)pyrene	ND	ND	ND	ND
Indeno(1,2,3-cd)pyrene	ND	ND	ND	ND
Dibenzo(ah)anthracene	ND	ND	ND	ND
Benzo(ghi)perylene	ND	ND	ND	ND
Dichlorobenzenes	ND	ND	ND	ND
Trichlorobenzenes	ND	ND	ND	ND
Tetrachlorobenzenes	ND	ND	ND	ND
Pentachlorobenzenes	ND	ND	ND	ND
Hexachlorobenzenes	ND	ND	ND	ND

HCL Analysis

Total mg HCL

ppm HCL

lb/hr HCL

Sample
 Blank
 Net

0.09
 0.07
 0.02

0.0040

3.40E-05

GIBSON 5240

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 15, 1990

TIME: 15:01 -19:30

UNIT: Boiler

SAMPLE: Outlet

RUN #: 2

Duct Diameter (in.) 18.0
 Rectangular Duct 0.0
 Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.48
 Vol. Per Cent H₂O 4.83
 Molecular Wt. (wet) 28.48
 Standard Temp. (F) 60
 Std Press. (in.Hg) 29.92
 Pitot Coeff. 0.840

Pt.	In.	NORTH			WEST		
		From					
		Edge	Td	Dp	Vd	Td	Dp
1	1.2	276	0.08	19.0	244	0.12	22.8
2	4.5	276	0.06	16.5	271	0.13	24.2
3	13.5	278	0.10	21.3	279	0.09	20.2
4	16.8	280	0.13	24.3	271	0.09	20.1

RESULTS:

Avg. Vel. (Vd) 21.0 FPS @ 272 F and 29.5 in. Hg

Volume Flow Rate Qd 2231 ACFM
 Qstd (wet) 1562 SCFM
 Qstd (dry) 1486 SDCFM
 Qstd (dry) 0.66 Nm³ @ 0C

SEMI-VOLATILE EMISSIONS TEST MONITOR DATA

DATE: May 15, 1990	Pbar(in. Hg): 29.49	Nozzle q90011	Diameter (mm): 11.510
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.48	LCD Meter	1288 Cor.Fact.: 1.0255
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	1 Orifice Km: 0.60
RUN #: 3	Initial %H2O: 5.0		Probe Liner: SS
			Filter Holder: SS

PORT WEST				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	14	25	270	0.10	85	497.828	12	21.2	4.39	1.01	
2	3	14	56	279	0.11	87			22.4	4.80	1.05	
3	2	16	1	306	0.07	83		6	18.2	2.97	0.82	
4	1	16	24	257	0.09	87			20.0	4.04	0.97	
		16	46				583.253					

Sample Time =	90	278	0.09	85	87.603	20.5	4.05	101.2
---------------	----	-----	------	----	--------	------	------	-------

PORT NORTH				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	18	33	231	0.07	83	583.253	9	17.3	3.27	0.86	
2	3	18	56	275	0.08	83			19.1	3.50	0.89	
3	2	19	18	279	0.11	84			22.4	4.77	1.05	
4	1	19	41	279	0.13	83			24.4	5.66	1.14	
		20	3				667.876					

Sample Time =	90	266	0.10	83	86.781	20.8	4.30	97.9
Post-Test Leak Rate	0.018 CFM	at	16 in. Hg.					

Test Summary

Sample Time =	180	272	84	174.384	20.6	4.17	99.5
			NET CU. FT.				

SEMI-VOLATILE EMISSIONS

Data and Results:

Date: May 15, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 3
 Time: 14:25
 Project DRD
 Project 5240

Liquid Analysis:

Gas Composition:

Selected Results:

Absorber Type	Contents	Final	Tare	Net			
Mod. Grnbg.	H2O	748.70	612.10	136.60	%CO2 volume	2.2	Wet MW 28.51
Lg. Grnbg.	H2O	607.30	618.20	-10.90	%O2 volume	16.5	Excess Air
Mod. Grnbg.	EMPTY	504.30	503.70	0.60	%CO volume	0.0	
Mod. Grnbg.	SILICA GEL	790.30	745.00	45.30	%N2 volume	81.3	Vm Standard 165.967
				0.00	%H2O volume	4.6	%Isokinetic 102.2
			Total	171.60			Standard T 60

PAH and Chlorobenzene Analysis

COMPOUND	ng	ng/NM3 @12% CO2	ng/s	lbs/hr
Naphthalene	18000	22077.27	2629.7	2.08E-05
Acenaphthylene	130	159.45	19.0	1.50E-07
Acenaphthene	190	233.04	27.8	2.19E-07
Fluorene	290	355.69	42.4	3.35E-07
Phenanthrene	410	502.87	59.9	4.73E-07
Anthracene	BL	BL	BL	BL
Fluoranthene	80	98.12	11.7	9.23E-08
Pyrene	140	171.71	20.5	1.62E-07
Chrysene	BL	BL	BL	BL
Benz(a)anthracene	55	67.46	8.0	6.35E-08
Benzo(b+k)fluoranthene	ND	ND	ND	ND
Benzo(a)pyrene	ND	ND	ND	ND
Indeno(1,2,3-cd)pyrene	ND	ND	ND	ND
Dibenzo(ah)anthracene	ND	ND	ND	ND
Benzo(ghi)perylene	ND	ND	ND	ND
Dichlorobenzenes	ND	ND	ND	ND
Trichlorobenzenes	ND	ND	ND	ND
Tetrachlorobenzenes	ND	ND	ND	ND
Pentachlorobenzenes	ND	ND	ND	ND
Hexachlorobenzenes	ND	ND	ND	ND

HCL Analysis

	Total mg HCL	ppm HCL	lb/hr HCL
Sample	0.09		
Blank	0.07		
Net	0.02	0.0032	2.67E-05

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 15, 1990

TIME: 14:25 -20:03

UNIT: Boiler

SAMPLE: Outlet

RUN #: 3

Duct Diameter (in.) 18.0

Rectangular Duct 0.0

Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.48

Vol. Per Cent H2O 4.59

Molecular Wt. (wet) 28.51

Standard Temp. (F) 60

Std Press. (in.Hg) 29.92

Pitot Coeff. 0.840

Pt.	In.	WEST			NORTH		
	From						
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	270	0.10	21.2	231	0.07	17.2
2	4.5	279	0.11	22.3	275	0.08	19.0
3	13.5	306	0.07	18.1	279	0.11	22.3
4	16.8	257	0.09	19.9	279	0.13	24.3

RESULTS:

Avg. Vel. (Vd) 20.5 FPS @ 272 F and 29.5 in. Hg

Volume Flow Rate Qd 2179 ACFM
 Qstd (wet) 1525 SCFM
 Qstd (dry) 1455 SDCFM
 Qstd (dry) 0.65 Nm3 @ 0C

SEMI-VOLATILE EMISSIONS TEST MONITOR DATA

DATE: May 16, 1990	Pbar(in. Hg): 29.54	Nozzle q90011	Diameter (mm): 11.510
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.53	LCD Meter	789 Cor.Fact.: 1.0319
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	2 Orifice Km: 0.60
RUN #: 4	Initial %H2O: 5.0	Probe Liner: SS	Filter Holder: SS

PORT NORTH				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	8	44	289	0.13	66	919.472	17	24.0	5.18	1.07	
2	3	8	59	288	0.09	73			20.4	3.78	0.92	
3	2	9	14	285	0.05	80			15.2	2.23	0.70	
4	1	9	29	248	0.06	82		9	16.2	2.77	0.79	
		9	44				968.913					

Sample Time =	60	278	0.08	75	51.018	18.9	3.49	97.8
---------------	----	-----	------	----	--------	------	------	------

PORT WEST				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	10	5	280	0.11	84	968.913		22.4	4.76	1.05	
2	3	10	20	283	0.12	86		17	23.5	5.21	1.09	
3	2	10	35	287	0.08	87			18.6	3.26	0.86	
4	1	10	50	248	0.08	88		12	18.7	3.66	0.92	
		11	5				1024.199					

Sample Time =	60	275	0.10	86	57.050	20.8	4.22	97.0
Post-Test Leak Rate	0.020 CFM	at	17 in. Hg.					

Test Summary

Sample Time =	120	276	81	108.068	19.9	3.86	97.4
NET CU. FT.							

SEMI-VOLATILE EMISSIONS

Data and Results:

Date: May 16, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 4
 Time: 08:44
 Project DRD
 Project 5240

Liquid Analysis:

Gas Composition:

Selected Results:

Absorber Type	Contents	Final	Tare	Net			
Mod. Grnbg.	H2O	692.40	601.60	90.80	%CO2 volume	2.2	Wet MW 28.47
Lg. Grnbg.	H2O	587.60	600.70	-13.10	%O2 volume	16.0	Excess Air
Mod. Grnbg.	EMPTY	503.90	504.20	-0.30	%CO volume	0.0	
Mod. Grnbg.	SILICA GEL	785.40	751.80	33.60	%N2 volume	81.8	Vm Standard 103.634
				0.00	%H2O volume	4.7	%Isokinetic 100.5
			Total	111.00			Standard T 60

PAH and Chlorobenzene Analysis

COMPOUND	ng	ng/NM3 @12% CO2	ng/s	lbs/hr
Naphthalene	34000	66783.95	7626.8	6.03E-05
Acenaphthylene	56	110.00	12.6	9.92E-08
Acenaphthene	37	72.68	8.3	6.56E-08
Fluorene	ND	ND	ND	ND
Phenanthrene	160	314.28	35.9	2.84E-07
Anthracene	ND	ND	ND	ND
Fluoranthene	BL	BL	BL	BL
Pyrene	80	157.14	17.9	1.42E-07
Chrysene	3	5.89	0.7	5.32E-09
Benz(a)anthracene	17	33.39	3.8	3.01E-08
Benzo(b+k)fluoranthene	ND	ND	ND	ND
Benzo(a)pyrene	ND	ND	ND	ND
Indeno(1,2,3-cd)pyrene	ND	ND	ND	ND
Dibenzo(ah)anthracene	ND	ND	ND	ND
Benzo(ghi)perylene	ND	ND	ND	ND
Dichlorobenzenes	48	94.28	10.8	8.51E-08
Trichlorobenzenes	ND	ND	ND	ND
Tetrachlorobenzenes	ND	ND	ND	ND
Pentachlorobenzenes	ND	ND	ND	ND
Hexachlorobenzenes	ND	ND	ND	ND

HCL Analysis

Total mg HCL

ppm HCL

lb/hr HCL

Sample
 Blank
 Net

0.09
 0.07
 0.02

0.0044

3.56E-05

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 16, 1990

TIME: 08:44 -11:05

UNIT: Boiler

SAMPLE: Outlet

RUN #: 4

Duct Diameter (in.) 18.0

Rectangular Duct 0.0

Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.53

Vol. Per Cent H2O 4.74

Molecular Wt. (wet) 28.47

Standard Temp. (F) 60

Std Press. (in.Hg) 29.92

Pitot Coeff. 0.840

Pt.	In.	NORTH			WEST		
		From					
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	289	0.13	24.0	280	0.11	22.3
2	4.5	288	0.09	20.3	283	0.12	23.4
3	13.5	285	0.05	15.1	287	0.08	18.5
4	16.8	248	0.06	16.1	248	0.08	18.6

RESULTS:

Avg. Vel. (Vd) 19.8 FPS @ 276 F and 29.5 in. Hg

Volume Flow Rate Qd 2100 ACFM
 Qstd (wet) 1464 SCFM
 Qstd (dry) 1395 SDCFM
 Qstd (dry) 0.62 Nm³ @ 0C

CHROMIUM EMISSIONS TEST MONITOR DATA

DATE: May 16, 1990	Pbar(in. Hg): 29.54	Nozzle q90011	Diameter (mm): 11.510
CLIENT: Gibson Oil	Pstat(in. H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.53	LCD Meter	789 Cor.Fact.: 1.0319
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	1 Orifice Km: 0.60
RUN #: 5	Initial %H2O: 5.0		Probe Liner: SS
			Filter Holder: SS

PORT WEST				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	14	4	275	0.11	91	25.981		22.3	4.86	1.06	
2	3	14	13	289	0.12	89		5	23.3	5.06	1.08	
3	2	14	22	289	0.07	91			18.0	3.07	0.84	
4	1	14	31	250	0.08	92			18.6	3.63	0.92	
		14	40				59.184					

Sample Time =	36	276	0.09	91	34.262	20.5	4.15	97.5
---------------	----	-----	------	----	--------	------	------	------

PORT NORTH				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	14	49	277	0.14	89	59.184		25.2	6.23	1.19	
2	3	14	58	287	0.11	90			22.5	4.77	1.05	
3	2	15	7	280	0.06	92			16.6	2.70	0.78	
4	1	15	16	231	0.06	93			16.0	2.87	0.81	
		15	25				91.124					

Sample Time =	36	269	0.09	91	32.959	20.1	4.14	95.3
Post-Test Leak Rate	0.014 CFM	at			7 in. Hg.			

Test Summary

Sample Time =	72	272		91	67.221	20.3	4.15	96.5
					NET CU. FT.			

GIBSON 5240
CHROMIUM EMISSIONS

Page 37

Data and Results:

Date: May 16, 1990
Client: Gibson Oil
Unit: Boiler
Site: Outlet

Run #: 5
Time: 14:04
Project DRD
Project 5240

Liquid Analysis:

Absorber Type	Contents	Final	Tare	Net
Mod. Grnbg.	0.1 N NaOH	654.60	611.90	42.70
Lg. Grnbg.	0.1 N NaOH	628.50	619.60	8.90
Mod. Grnbg.	EMPTY	532.30	529.30	3.00
Mod. Grnbg.	SILICA GEL	733.90	714.60	19.30
				0.00
			Total	73.90

Gas Composition:

%CO2 volume	2.3
%O2 volume	16.7
%CO volume	0.0
%N2 volume	81.0
%H2O volume	5.1

Selected Results:

Wet MW	28.47
Excess Air	
Vm Standard	63.316
%Isokinetic	100.0
Standard T	60

Chromium Analysis

Filter Sample Type:

EPA GLASS FIBER MAT

Chromium Results:

Sample Fraction		mg Net	gr/SDCF
Hexavalent Cr	Less than	0.0010	2.43E-07
Hexavalent Blank	Less than	-0.0010	-2.43E-07
Net Hexavalent Chromium		0.0000	0.00E+00
Total Cr		0.0011	2.68E-07
Blank		-0.0020	-4.86E-07
Net Total Chromium		-0.0009	-2.19E-07

Concentration: grains/SDCF @ STP

Hexavalent Cr	0.00E+00
Total Cr	-2.19E-07

Emission Rate, lbs/hr

Hexavalent Cr	0.00E+00
Total Cr	-2.68E-06

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 16, 1990

TIME: 14:04 -15:25

UNIT: Boiler

SAMPLE: Outlet

RUN #: 5

Duct Diameter (in.) 18.0

Rectangular Duct 0.0

Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.53

Vol. Per Cent H2O 5.15

Molecular Wt. (wet) 28.47

Standard Temp. (F) 60

Std Press. (in.Hg) 29.92

Pitot Coeff. 0.840

Pt.	In.	WEST			NORTH		
	From						
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	275	0.11	22.3	277	0.14	25.2
2	4.5	289	0.12	23.2	287	0.11	22.5
3	13.5	289	0.07	17.9	280	0.06	16.5
4	16.8	250	0.08	18.6	231	0.06	15.9

RESULTS:

Avg. Vel. (Vd) 20.3 FPS @ 272 F and 29.5 in. Hg

Volume Flow Rate Qd 2147 ACFM
 Qstd (wet) 1505 SCFM
 Qstd (dry) 1427 SDCFM

CHROMIUM EMISSIONS TEST MONITOR DATA

DATE: May 16, 1990	Pbar(in. Hg): 29.54	Nozzle q90011	Diameter (mm): 11.510
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in. 36	Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.53	LCD Meter 789	Cor.Fact.: 1.0319
SITE: Outlet	Initial MW: 28.3	Impinger Bkt 1	Orifice Km: 0.60
RUN #: 6	Initial %H2O: 5.0	Probe Liner: SS	Filter Holder: SS

PORT NORTH				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	16	34	285	0.13	85	92.271		24.0	5.41	1.11	
2	3	16	43	288	0.11	87			22.5	4.74	1.05	
3	2	16	52	287	0.07	89			17.3	2.86	0.81	
4	1	17	1	254	0.06	88			15.6	2.56	0.76	
		17	10				124.359					

Sample Time =	36	279	0.09	87	33.112	19.8	3.89	98.7
---------------	----	-----	------	----	--------	------	------	------

PORT WEST				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	17	41	278	0.11	88	124.359		22.4	4.81	1.05	
2	3	17	50	281	0.11	87		7	22.4	4.79	1.05	
3	2	17	59	289	0.07	88			18.1	3.10	0.84	
4	1	18	8	266	0.07	89		5	17.8	3.19	0.86	
		18	17				157.096					

Sample Time =	36	279	0.09	88	33.781	20.2	3.97	98.7
Post-Test Leak Rate	0.016 CFM	at		7 in. Hg.				

Test Summary

Sample Time =	72	279		88	66.893	20.0	3.93	98.7
					NET CU. FT.			

CHROMIUM EMISSIONS

Data and Results:

Date: May 16, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 6
 Time: 16:34
 Project DRD
 Project 5240

Liquid Analysis:

Gas Composition:

Selected Results:

Absorber Type	Contents	Final	Tare	Net		
Mod. Grnbg.	0.1 N NaOH	649.60	604.70	44.90	%CO2 volume	2.3
Lg. Grnbg.	0.1 N NaOH	612.10	603.10	9.00	%O2 volume	16.7
Mod. Grnbg.	EMPTY	507.80	504.30	3.50	%CO volume	0.0
Mod. Grnbg.	SILICA GEL	762.80	746.60	16.20	%N2 volume	81.0
				0.00	%H2O volume	5.1
			Total	73.60		

Wet MW	28.47	
Excess Air		
Vm Standard	63.333	
%Isokinetic	102.4	
Standard T	60	

Chromium Analysis

Filter Sample Type:

EPA GLASS FIBER MAT

Chromium Results:

Sample Fraction		mg Net	gr/SDCF	
Hexavalent Cr	Less than	0.0010	2.43E-07	Concentration: grains/SDCF @ STP
Hexavalent Blank	Less than	-0.0010	-2.43E-07	
Net Hexavalent Chromium		0.0000	0.00E+00	Hexavalent Cr 0.00E+00
				Total Cr -1.46E-07
Total Cr		0.0014	3.40E-07	
Blank		-0.0020	-4.86E-07	
Net Total Chromium		-0.0006	-1.46E-07	

Emission Rate, lbs/hr

Hexavalent Cr 0.00E+00
 Total Cr -1.75E-06

CHROMIUM EMISSIONS TEST MONITOR DATA

DATE: May 16, 1990	Pbar(in. Hg): 29.54	Nozzle q90012	Diameter (mm): 12.140
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in. 36	Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.53	LCD Meter 1288	Cor.Fact.: 1.0255
SITE: Outlet	Initial MW: 28.3	Impinger Bkt 2	Orifice Km: 0.60
RUN #: 7	Initial %H2O: 5.0	Probe Liner: SS	Filter Holder: SS

PORT NORTH				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	17	52	221	0.06	86	669.070	5	15.9	3.52	0.90	
2	3	18	1	279	0.06	89			16.5	3.27	0.87	
3	2	18	10	287	0.10	90		6	20.9	5.11	1.09	
4	1	18	19	288	0.13	91			24.5	7.18	1.27	
		18	28				704.958					

Sample Time =	36	269	0.09	89	36.803	19.5	4.77	99.1
---------------	----	-----	------	----	--------	------	------	------

PORT WEST				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	18	39	281	0.10	86	704.958		21.4	5.40	1.11	
2	3	18	48	286	0.11	89			22.0	5.67	1.14	
3	2	18	57	287	0.06	89			16.6	3.24	0.86	
4	1	19	6	245	0.07	90			17.5	3.98	0.96	
		19	15				741.203					

Sample Time =	36	275	0.08	88	37.169	19.4	4.57	101.2
Post-Test Leak Rate	0.008 CFM at			10 in. Hg.				

Test Summary

Sample Time =	72	272	89	73.972	19.4	4.67	100.1
NET CU. FT.							

GIBSON 5240

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 16, 1990

TIME: 16:34 -18:17

UNIT: Boiler

RUN #: 6

Duct Diameter (in.) 18.0
 Rectangular Duct 0.0
 Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.53
 Vol. Per Cent H2O 5.13
 Molecular Wt. (wet) 28.47
 Standard Temp. (F) 60
 Std Press. (in.Hg) 29.92
 Pitot Coeff. 0.840

Pt.	In.	NORTH			WEST		
		From					
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	285	0.13	23.9	278	0.11	22.3
2	4.5	288	0.11	22.5	281	0.11	22.4
3	13.5	287	0.07	17.3	289	0.07	18.1
4	16.8	254	0.06	15.5	266	0.07	17.8

RESULTS:

Avg. Vel. (Vd) 20.0 FPS @ 279 F and 29.5 in. Hg

Volume Flow Rate Qd 2116 ACFM
 Qstd (wet) 1470 SCFM
 Qstd (dry) 1395 SDCFM

GIBSON 5240
CHROMIUM EMISSIONS

Page 43

Data and Results:

Date: May 16, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 7
 Time: 17:52
 Project DRD
 Project 5240

Liquid Analysis:

Absorber Type	Contents	Final	Tare	Net
Mod. Grnbg.	0.1 N NaOH	647.10	604.50	42.60
Lg. Grnbg.	0.1 N NaOH	635.80	621.90	13.90
Mod. Grnbg.	EMPTY	532.50	529.10	3.40
Mod. Grnbg.	SILICA GEL	729.60	707.90	21.70
				0.00
			Total	81.60

Gas Composition:

%CO2 volume	2.3
%O2 volume	16.7
%CO volume	0.0
%N2 volume	81.0
%H2O volume	5.1

Selected Results:

Wet MW	28.47
Excess Air	
Vm Standard	70.035
%Isokinetic	103.3
Standard T	60

Chromium Analysis

Filter Sample Type:

EPA GLASS FIBER MAT

Chromium Results:

Sample Fraction		mg Net	gr/SDCF
Hexavalent Cr	Less than	0.0010	2.20E-07
Hexavalent Blank	Less than	-0.0010	-2.20E-07
Net Hexavalent Chromium		0.0000	0.00E+00
Total Cr		0.0012	2.64E-07
Blank		-0.0020	-4.40E-07
Net Total Chromium		-0.0008	-1.76E-07

Concentration: grains/SDCF @ STP

Hexavalent Cr	0.00E+00
Total Cr	-1.76E-07

Emission Rate, lbs/hr

Hexavalent Cr	0.00E+00
Total Cr	-2.06E-06

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 16, 1990

TIME: 17:52 -19:15

UNIT: Boiler

SAMPLE: Outlet

RUN #: 7

Duct Diameter (in.) 18.0

Rectangular Duct 0.0

Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.53

Vol. Per Cent H2O 5.14

Molecular Wt. (wet) 28.47

Standard Temp. (F) 60

Std Press. (in.Hg) 29.92

Pitot Coeff. 0.840

Pt.	In.	NORTH			WEST		
	From						
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	221	0.06	15.8	281	0.10	21.3
2	4.5	279	0.06	16.5	286	0.11	21.9
3	13.5	287	0.10	20.9	287	0.06	16.6
4	16.8	288	0.13	24.4	245	0.07	17.4

RESULTS:

Avg. Vel. (Vd) 19.4 FPS @ 272 F and 29.5 in. Hg

Volume Flow Rate Qd 2052 ACFM
 Qstd (wet) 1439 SCFM
 Qstd (dry) 1365 SDCFM

METALS EMISSIONS

Data and Results:

Date: May 17, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 13
 Time: 09:52
 Project DRD
 Project 5240

Liquid Analysis:

Absorber Type	Contents	Final	Tare	Net
Mod. Grnbg.	HN03/H2O2	659.00	605.50	53.50
Lg. Grnbg.	HN03/H2O2	632.00	622.70	9.30
Mod. Grnbg.	EMPTY	525.40	523.30	2.10
Mod. Grnbg.	KMnO4	609.10	610.70	-1.60
Mod. Grnbg.	KMnO4	647.10	647.20	-0.10
Mod. Grnbg.	SILICA GEL	744.50	728.40	16.10
			Total	79.30

Gas Composition:

Selected Results:

%CO2 volume 2.3
 %O2 volume 16.7
 %CO volume 0.0
 %N2 volume 81.0
 %H2O volume 5.0

Wet MW 28.49
 Excess Air
 Vm Standard 70.561
 %Isokinetic 100.1
 Standard T 60

Metals Analysis

Metal	mg Sample	mg Blank	mg Net	gr/SDCF	gr/SDCF @ 12% CO2	lbs/hr
Arsenic	0.0018	0.0021	-0.0003	-6.55E-08	-3.42E-07	-8.02E-07
Beryllium	0.0050	0.0050	0.0000	0.00E+00	0.00E+00	0.00E+00
Cadmium	0.0010	0.0053	-0.0043	-9.38E-07	-4.90E-06	-1.15E-05
Chromium (Total)	0.0062	0.0060	0.0002	4.37E-08	2.28E-07	5.35E-07
Copper	0.0082	0.0078	0.0004	8.73E-08	4.55E-07	1.07E-06
Lead	0.0071	0.0070	0.0001	2.18E-08	1.14E-07	2.67E-07
Manganese	0.0500	0.0500	0.0000	0.00E+00	0.00E+00	0.00E+00
Mercury	0.0042	0.0060	-0.0018	-3.93E-07	-2.05E-06	-4.81E-06
Nickel	0.0110	0.0087	0.0023	5.02E-07	2.62E-06	6.15E-06
Selenium	0.0010	0.0010	0.0000	0.00E+00	0.00E+00	0.00E+00
Zinc	0.1400	0.1600	-0.0200	-4.37E-06	-2.28E-05	-5.35E-05

GIBSON 5240

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 17, 1990

TIME: 09:52 -11:32

UNIT: Boiler

RUN #: 13

Duct Diameter (in.) 18.0
 Rectangular Duct 0.0
 Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.49
 Vol. Per Cent H2O 4.97
 Molecular Wt. (wet) 28.49
 Standard Temp. (F) 60
 Std Press. (in.Hg) 29.92
 Pitot Coeff. 0.840

Pt.	In. From Edge	NORTH			WEST		
		Td	Dp	Vd	Td	Dp	Vd
1	1.2	240	0.08	18.4	238	0.09	19.6
2	4.5	280	0.07	17.2	282	0.07	17.9
3	13.5	281	0.10	21.3	278	0.11	22.3
4	16.8	282	0.12	23.4	275	0.10	21.2

RESULTS:

Avg. Vel. (Vd) 20.2 FPS @ 270 F and 29.5 in. Hg

Volume Flow Rate Qd 2139 ACFM
 Qstd (wet) 1502 SCFM
 Qstd (dry) 1428 SDCFM

GIBSON 5240

METALS EMISSIONS TEST MONITOR DATA

DATE: May 17, 1990	Pbar(in. Hg): 29.50	Nozzle q90012	Diameter (mm): 12.140
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.49	LCD Meter	789 Cor.Fact.: 1.0319
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	2 Orifice Km: 0.60
RUN #: 14	Initial %H2O: 5.0		Probe Liner: SS
			Filter Holder: SS

PORT NORTH				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	13	22	200	0.07	87	231.844		16.9	4.22	0.99	
2	3	13	31	280	0.06	87			16.6	3.26	0.86	
3	2	13	40	279	0.09	90			20.3	4.88	1.06	
4	1	13	49	281	0.12	90			22.9	6.32	1.20	
		13	58				267.912					
Sample Time = 36 260 0.08 88 37.219									19.2	4.67		100.4

PORT WEST				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	14	8	273	0.09	89	267.912		20.2	4.92	1.07	
2	3	14	17	278	0.09	90			20.3	4.90	1.07	
3	2	14	26	281	0.05	91			15.1	2.77	0.79	
4	1	14	35	238	0.06	92			15.4	3.20	0.86	
		14	44				301.298					
Sample Time = 36 268 0.07 91 34.451									17.7	3.95		101.0
Post-Test Leak Rate 0.010 CFM at 10 in. Hg.												

Test Summary

Sample Time = 72 264	89	71.670	18.5	4.31	100.7
NET CU. FT.					

GIBSON 5240

METALS EMISSIONS

Data and Results:

Date: May 17, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 14
 Time: 13:22
 Project DRD
 Project 5240

Liquid Analysis:

Gas Composition:

Selected Results:

Absorber Type	Contents	Final	Tare	Net	%CO2 volume	2.3	Wet MW	28.48
Mod. Grnbg.	HNO3/H2O2	655.30	601.40	53.90	%O2 volume	16.7	Excess Air	
Lg. Grnbg.	HNO3/H2O2	604.00	596.40	7.60	%CO volume	0.0		
Mod. Grnbg.	EMPTY	503.60	501.80	1.80	%N2 volume	81.0	Vm Standard	67.604
Mod. Grnbg.	KMnO4	622.40	623.30	-0.90	%H2O volume	5.0	%Isokinetic	104.4
Mod. Grnbg.	SILICA GEL	731.80	717.60	14.20			Standard T	60
			Total	76.60				

Metals Analysis

Metal	mg Sample	mg Blank	mg Net	gr/SDCF	gr/SDCF @ 12% CO2	lbs/hr
Arsenic	0.0021	0.0021	0.0000	0.00E+00	0.00E+00	0.00E+00
Beryllium	0.0050	0.0050	0.0000	0.00E+00	0.00E+00	-1.21E-05
Cadmium	0.0006	0.0053	-0.0047	-1.07E-06	-5.59E-06	8.98E-06
Chromium (Total)	0.0095	0.0060	0.0035	7.97E-07	4.16E-06	2.31E-06
Copper	0.0087	0.0078	0.0009	2.05E-07	1.07E-06	-5.13E-07
Lead	0.0068	0.0070	-0.0002	-4.56E-08	-2.38E-07	0.00E+00
Manganese	0.0500	0.0500	0.0000	0.00E+00	0.00E+00	-1.03E-06
Mercury	0.0056	0.0060	-0.0004	-9.11E-08	-4.75E-07	1.54E-06
Nickel	0.0093	0.0087	0.0006	1.37E-07	7.13E-07	-2.56E-07
Selenium	0.0009	0.0010	-0.0001	-2.28E-08	-1.19E-07	5.13E-05
Zinc	0.1800	0.1600	0.0200	4.56E-06	2.38E-05	

GIBSON 5240

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 17, 1990

TIME: 13:22 -14:44

UNIT: Boiler

RUN #: 14

SAMPLE: Outlet

Duct Diameter (in.) 18.0
 Rectangular Duct 0.0
 Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.49
 Vol. Per Cent H2O 5.00
 Molecular Wt. (wet) 28.48
 Standard Temp. (F) 60
 Std Press. (in.Hg) 29.92
 Pitot Coeff. 0.840

Pt.	In.	NORTH			WEST		
		From					
		Edge	Td	Dp	Vd	Td	Dp
1	1.2	200	0.07	16.8	273	0.09	20.1
2	4.5	280	0.06	16.5	278	0.09	20.2
3	13.5	279	0.09	20.2	281	0.05	15.1
4	16.8	281	0.12	22.9	238	0.06	15.4

RESULTS:

Avg. Vel. (Vd) 18.4 FPS @ 264 F and 29.5 in. Hg

Volume Flow Rate Qd 1951 ACFM
 Qstd (wet) 1381 SCFM
 Qstd (dry) 1312 SDCFM

GIBSON 5240

Page 51

METALS EMISSIONS TEST MONITOR DATA

DATE: May 17, 1990	Pbar(in. Hg): 29.50	Nozzle q90012	Diameter (mm): 12.140
CLIENT: Gibson Oil	Pstat(in. H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.49	LCD Meter	789 Cor.Fact.: 1.0319
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	2 Orifice Km: 0.60
RUN #: 15	Initial %H2O: 5.0		Probe Liner: SS
			Filter Holder: SS

PORT NORTH				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	17	21	279	0.14	87	301.533		25.3	7.84	1.32	
2	3	17	34	274	0.11	86			22.3	6.03	1.17	
3	2	17	43	271	0.06	86			16.5	3.29	0.87	
4	1	17	52	240	0.08	85			18.6	4.54	1.02	
		18	1				338.941					

Sample Time =	36	266	0.10	86	38.601		20.7	5.42		97.8
---------------	----	-----	------	----	--------	--	------	------	--	------

PORT WEST				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	18	28	223	0.11	82	338.941		21.5	6.47	1.21	
2	3	18	37	280	0.08	83			19.1	4.27	0.99	
3	2	18	46	267	0.13	83			24.2	7.28	1.27	
4	1	18	55	264	0.13	82			24.1	7.30	1.28	
		19	4				380.579					

Sample Time =	36	259	0.11	82	42.966		22.2	6.33		100.6
Post-Test Leak Rate	0.018 CFM	at		15 in. Hg.						

Test Summary

Sample Time =	72	262		84	81.568		21.5	5.88		99.3
					NET CU. FT.					

GIBSON 5240
METALS EMISSIONS

Page 52

Data and Results:

Date: May 17, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 15
 Time: 17:21
 Project DRD
 Project 5240

Liquid Analysis:

Gas Composition:

Selected Results:

Absorber Type	Contents	Final	Tare	Net			
Mod. Grnbg.	HNO3/H2O2	663.50	609.60	53.90	%CO2 volume	2.9	Wet MW 28.59
Lg. Grnbg.	HNO3/H2O2	640.20	631.80	8.40	%O2 volume	16.2	Excess Air
Mod. Grnbg.	EMPTY	526.20	523.90	2.30	%CO volume	0.0	
Mod. Grnbg.	KMnO4	606.50	612.90	-6.40	%N2 volume	80.9	Vm Standard 78.010
Mod. Grnbg.	SILICA GEL	754.10	729.80	24.30	%H2O volume	4.7	%Isokinetic 103.1
			Total	82.50			Standard T 60

Metals Analysis

Metal	mg Sample	mg Blank	mg Net	gr/SDCF	gr/SDCF @ 12% CO2	lbs/hr
Arsenic	0.0018	0.0021	-0.0003	-5.92E-08	-2.45E-07	-7.78E-07
Beryllium	0.0050	0.0050	0.0000	0.00E+00	0.00E+00	0.00E+00
Cadmium	0.0082	0.0053	0.0029	5.72E-07	2.37E-06	7.52E-06
Chromium (Total)	0.0088	0.0060	0.0028	5.53E-07	2.29E-06	7.26E-06
Copper	0.0077	0.0078	-0.0001	-1.97E-08	-8.17E-08	-2.59E-07
Lead	0.0071	0.0070	0.0001	1.97E-08	8.17E-08	2.59E-07
Manganese	0.0500	0.0500	0.0000	0.00E+00	0.00E+00	0.00E+00
Mercury	0.0063	0.0060	0.0003	5.92E-08	2.45E-07	7.78E-07
Nickel	0.0093	0.0087	0.0006	1.18E-07	4.90E-07	1.56E-06
Selenium	0.0010	0.0010	0.0000	0.00E+00	0.00E+00	0.00E+00
Zinc	0.1600	0.1600	0.0000	0.00E+00	0.00E+00	0.00E+00

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 17, 1990

TIME: 17:21 -19:04

UNIT: Boiler

SAMPLE: Outlet

RUN #: 15

Duct Diameter (in.) 18.0

Rectangular Duct 0.0

Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.49

Vol. Per Cent H2O 4.69

Molecular Wt. (wet) 28.59

Standard Temp. (F) 60

Std Press. (in.Hg) 29.92

Pitot Coeff. 0.840

Pt.	In.	NORTH			WEST		
	From						
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	279	0.14	25.2	223	0.11	21.4
2	4.5	274	0.11	22.2	280	0.08	19.0
3	13.5	271	0.06	16.4	267	0.13	24.0
4	16.8	240	0.08	18.5	264	0.13	24.0

RESULTS:

Avg. Vel. (Vd) 21.3 FPS @ 262 F and 29.5 in. Hg

Volume Flow Rate Qd 2263 ACFM
 Qstd (wet) 1606 SCFM
 Qstd (dry) 1531 SDCFM

GIBSON 5240

Page 54

LEAD EMISSIONS TEST MONITOR DATA

DATE: May 17, 1990	Pbar(in. Hg): 29.50	Nozzle q90011	Diameter (mm): 11.510
CLIENT: Gibson Oil	Pstat(in. H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.49	LCD Meter	1288 Cor.Fact.: 1.0255
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	1 Orifice Km: 0.60
RUN #: 9	Initial %H2O: 5.0		Probe Liner: SS
			Filter Holder: SS

PORT WEST				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	9	41	276	0.12	74	741.689	6	23.4	5.14	1.08	
2	3	9	50	279	0.11	77			22.6	4.79	1.04	
3	2	9	59	277	0.08	81		5	18.5	3.27	0.86	
4	1	10	8	278	0.09	83			19.7	3.69	0.92	
		10	17				774.817					

Sample Time =	36	278	0.10	79	33.973	21.0	4.22	96.8
---------------	----	-----	------	----	--------	------	------	------

PORT NORTH				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	10	46	284	0.13	84	774.817	7	24.4	5.64	1.13	
2	3	10	55	286	0.11	86			22.5	4.74	1.05	
3	2	11	4	282	0.06	88			16.6	2.67	0.78	
4	1	11	13	281	0.07	92			17.3	2.90	0.82	
		11	22				807.037					

Sample Time =	36	283	0.09	87	33.042	20.2	3.99	97.3
Post-Test Leak Rate	0.020 CFM	at		7 in. Hg.				

Test Summary

Sample Time =	72	280		83	67.014	20.6	4.11	97.0
					NET CU. FT.			

GIBSON 5240

Page 55

LEAD EMISSIONS

Data and Results:

Date: May 17, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 9
 Time: 09:41
 Project DRD
 Project 5240

Liquid Analysis:

Gas Composition:

Selected Results:

Absorber Type	Contents	Final	Tare	Net		
Mod. Grnbg.	0.1 N HNO3	637.10	590.00	47.10	%CO2 volume	2.3
Lg. Grnbg.	0.1 N HNO3	621.90	615.10	6.80	%O2 volume	16.7
Mod. Grnbg.	EMPTY	503.20	500.80	2.40	%CO volume	0.0
Mod. Grnbg.	SILICA GEL	744.10	727.50	16.60	%N2 volume	81.0
				0.00	%H2O volume	5.0
			Total	72.90		

Wet MW	28.48
Excess Air	
Vm Standard	63.930
%Isokinetic	100.0
Standard T	60

Lead Analysis

Filter Sample Type:

EPA GLASS FIBER MAT

Lead Results:

Sample Fraction	mg Net	gr/SDCF	Concentration:	grains/SDCF @ STP
Pb	0.0007	1.69E-07		
Pb Blank	-0.0016	-3.85E-07		
Net Pb	-0.0009	-2.17E-07	Pb	-2.17E-07

Emission Rate, lbs/hr

Pb -2.66E-06

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 17, 1990

TIME: 09:41 -11:22

UNIT: Boiler

SAMPLE: Outlet

RUN #: 9

Duct Diameter (in.) 18.0
 Rectangular Duct 0.0
 Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.49
 Vol. Per Cent H₂O 5.03
 Molecular Wt. (wet) 28.48
 Standard Temp. (F) 60
 Std Press. (in.Hg) 29.92
 Pitot Coeff. 0.840

Pt.	In.	WEST			NORTH		
		From					
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	276	0.12	23.3	284	0.13	24.4
2	4.5	279	0.11	22.5	286	0.11	22.4
3	13.5	277	0.08	18.4	282	0.06	16.5
4	16.8	278	0.09	19.6	281	0.07	17.2

RESULTS:

Avg. Vel. (Vd) 20.6 FPS @ 280 F and 29.5 in. Hg

Volume Flow Rate Qd 2179 ACFM
 Qstd (wet) 1508 SCFM
 Qstd (dry) 1433 SDCFM

GIBSON 5240

LEAD EMISSIONS TEST MONITOR DATA

DATE: May 17, 1990	Pbar(in. Hg): 29.50	Nozzle q90011	Diameter (mm): 11.510
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.49	LCD Meter	1288 Cor.Fact.: 1.0255
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	1 Orifice Km: 0.60
RUN #: 10	Initial %H2O: 5.0		Probe Liner: SS
			Filter Holder: SS

PORT WEST				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	13	12	277	0.10	88	807.432		21.7	4.51	1.02	
2	3	13	21	278	0.11	89			21.9	4.60	1.03	
3	2	13	30	284	0.07	92			17.3	2.89	0.81	
4	1	13	39	279	0.08	94			19.1	3.54	0.91	
		13	48				840.195					

Sample Time =	36	280	0.09	91	33.598		20.0	3.88	98.8
---------------	----	-----	------	----	--------	--	------	------	------

PORT NORTH				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	14	18	272	0.07	92	840.195		17.8	3.14	0.85	
2	3	14	27	277	0.05	93			15.1	2.30	0.72	
3	2	14	36	279	0.08	94			19.1	3.54	0.91	
4	1	14	45	279	0.12	96			23.4	5.34	1.12	
		14	54				870.759					

Sample Time =	36	277	0.08	94	31.343		18.9	3.58	96.8
Post-Test Leak Rate	0.015 CFM at				10 in. Hg.				

Test Summary

Sample Time =	72	278		92	64.942		19.4	3.73	97.8
					NET CU. FT.				

GIBSON 5240

LEAD EMISSIONS

Data and Results:

Date: May 17, 1990
 Client: Gibson Oil
 Unit: Boiler
 Site: Outlet

Run #: 10
 Time: 13:12
 Project DRD
 Project 5240

Liquid Analysis:

Absorber Type	Contents	Final	Tare	Net
Mod. Grnbg.	0.1 N HNO ₃	635.70	591.80	43.90
Lg. Grnbg.	0.1 N HNO ₃	632.80	626.70	6.10
Mod. Grnbg.	EMPTY	505.50	504.00	1.50
Mod. Grnbg.	SILICA GEL	791.90	774.50	17.40
				0.00
			Total	68.90

Gas Composition:

%CO ₂ volume	2.3
%O ₂ volume	16.7
%CO volume	0.0
%N ₂ volume	81.0
%H ₂ O volume	5.0

Selected Results:

Wet MW	28.48
Excess Air	
Vm Standard	60.873
%Isokinetic	100.7
Standard T	60

Lead Analysis

Filter Sample Type:

EPA GLASS FIBER MAT

Lead Results:

Sample Fraction	mg Net	gr/SDCF	Concentration:	grains/SDCF @ STP
Pb	0.0027	6.83E-07		
Pb Blank	-0.0016	-4.05E-07		
Net Pb	0.0011	2.78E-07	Pb	2.78E-07

Emission Rate, lbs/hr

Pb	3.23E-06
----	----------

GIBSON 5240

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 17, 1990

TIME: 13:12 -14:54

UNIT: Boiler

RUN #: 10

Duct Diameter (in.) 18.0
 Rectangular Duct 0.0
 Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.49
 Vol. Per Cent H2O 5.00
 Molecular Wt. (wet) 28.48
 Standard Temp. (F) 60
 Std Press. (in.Hg) 29.92
 Pitot Coeff. 0.840

Pt.	In.	WEST			NORTH		
		From					
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	277	0.10	21.6	272	0.07	17.7
2	4.5	278	0.11	21.8	277	0.05	15.0
3	13.5	284	0.07	17.2	279	0.08	19.1
4	16.8	279	0.08	19.1	279	0.12	23.3

RESULTS:

Avg. Vel. (Vd) 19.4 FPS @ 278 F and 29.5 in. Hg

Volume Flow Rate Qd 2052 ACFM
 Qstd (wet) 1425 SCFM
 Qstd (dry) 1354 SDCFM

GIBSON 5240

Page 60

LEAD EMISSIONS TEST MONITOR DATA

DATE: May 17, 1990	Pbar(in. Hg): 29.50	Nozzle q90011	Diameter (mm): 11.510
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in.	36 Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.49	LCD Meter	1288 Cor.Fact.: 1.0255
SITE: Outlet	Initial MW: 28.3	Impinger Bkt	1 Orifice Km: 0.60
RUN #: 11	Initial %H2O: 5.0		Probe Liner: SS
			Filter Holder: SS

PORT WEST				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	17	35	196	0.10	85	871.176		19.6	4.65	1.04	
2	3	17	44	266	0.07	86			17.7	3.14	0.85	
3	2	17	53	262	0.11	87			22.2	4.91	1.07	
4	1	18	2	294	0.12	87			23.6	5.14	1.09	
		18	11				905.529					

Sample Time =	36	255	0.10	86	35.229		20.8	4.46		97.0
---------------	----	-----	------	----	--------	--	------	------	--	------

PORT NORTH				DATA				CALCULATIONS				
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	18	18	270	0.13	85	905.529		24.0	5.67	1.14	
2	3	18	27	272	0.10	86			20.7	4.17	0.98	
3	2	18	36	271	0.06	86			16.3	2.66	0.77	
4	1	18	45	264	0.07	86			17.7	3.14	0.85	
		18	54				937.647					

Sample Time =	36	269	0.09	86	32.937		19.7	3.91		97.9
Post-Test Leak Rate	0.016 CFM	at			10 in. Hg.					

Test Summary

Sample Time =	72	262		86	68.166		20.2	4.18		97.4
					NET CU. FT.					

GIBSON 5240

Page 61

LEAD EMISSIONS

Data and Results:

Date: May 17, 1990
Client: Gibson Oil
Unit: Boiler
Site: Outlet

Run #: 11
Time: 17:35
Project DRD
Project 5240

Liquid Analysis:

Absorber Type	Contents	Final	Tare	Net
Mod. Grnbg.	0.1 N HNO3	637.50	592.00	45.50
Lg. Grnbg.	0.1 N HNO3	620.50	615.80	4.70
Mod. Grnbg.	EMPTY	504.80	502.40	2.40
Mod. Grnbg.	SILICA GEL	755.90	737.70	18.20
				0.00
			Total	70.80

Gas Composition:

%CO2 volume	2.9
%O2 volume	16.2
%CO volume	0.0
%N2 volume	80.9
%H2O volume	4.8

Selected Results:

Wet MW	28.57
Excess Air	
Vm Standard	64.691
%Isokinetic	100.3
Standard T	60

Lead Analysis

Filter Sample Type:

EPA GLASS FIBER MAT

Lead Results:

Sample Fraction	mg Net	gr/SDCF
Pb	0.0016	3.81E-07
Pb Blank	-0.0016	-3.81E-07
Net Pb	0.0000	0.00E+00

Concentration: grains/SDCF @ STP
Pb 0.00E+00

Emission Rate, lbs/hr

Pb 0.00E+00

VELOCITY TRAVERSE & VOLUME FLOW RATE

CLIENT: Gibson Oil

DATE: May 17, 1990

TIME: 17:35 -18:54

UNIT: Boiler

SAMPLE: Outlet

RUN #: 11

Duct Diameter (in.) 18.0

Rectangular Duct 0.0

Area (sq.ft.) 1.8

Duct Press. (in.Hg) 29.49

Vol. Per Cent H2O 4.84

Molecular Wt. (wet) 28.57

Standard Temp. (F) 60

Std Press. (in.Hg) 29.92

Pitot Coeff. 0.840

Pt.	In.	WEST			NORTH		
	From						
	Edge	Td	Dp	Vd	Td	Dp	Vd
1	1.2	196	0.10	19.5	270	0.13	23.9
2	4.5	266	0.07	17.6	272	0.10	20.6
3	13.5	262	0.11	22.0	271	0.06	16.2
4	16.8	294	0.12	23.5	264	0.07	17.6

RESULTS:

Avg. Vel. (Vd) 20.1 FPS @ 262 F and 29.5 in. Hg

Volume Flow Rate Qd 2136 ACFM
 Qstd (wet) 1516 SCFM
 Qstd (dry) 1443 SDCFM

OPERATING CONDITIONS

CLIENT: Gibson Oil
DATE: May 14, 1990
UNIT: Boiler

<u>Time</u>	<u>Gas Meter cubic feet</u>	<u>Gas Flow Rate ft3/min</u>	<u>Water Meter gal</u>	<u>Water Flow Rate gal/min</u>	<u>Steam Pressure psi</u>
826	23145811				
905			201680.35		30
909	23146367	12.930			
922			201723.55	2.541	
1008					35
1009			201843.15	2.545	
1013	23147206	13.109			
1041					35
1042			201932.74	2.715	
1045	23147622	13.000			
1114					37
1115			202021.23	2.682	
1118	23148055	13.121			
1148					37
1149			202115.85	2.783	
1152	23148499	13.059			
1224					38
1225			202215.40	2.765	
1228	23148966	12.972			
1254			202299.75	2.909	
1255					39
1258	23149358	13.067			
1333					37
1335			202392.79	2.269	
1338	23149888	13.250			
1409					37
1410			202481.50	2.535	
1412	23150331	13.029			
1800					37
1802			203310.00	3.571	
1805	23153465	13.451			

OPERATING CONDITIONS

CLIENT: Gibson Oil
DATE: May 15, 1990
UNIT: Boiler

<u>Time</u>	<u>Gas Meter cubic feet</u>	<u>Gas Flow Rate ft³/min</u>	<u>Water Meter gal</u>	<u>Water Flow Rate gal/min</u>	<u>Steam Pressure psi</u>
745			205322.90		20
749	23163795				
827	23164293	13.105			
830			205444.25	2.697	
913	23164870	12.543			
916			205550.30	2.305	20
1035	23165940	13.049			
1321			206185.40	2.592	20
1324	23168130	12.959			
1513	23169570	13.211			
1516			206478.60	2.550	20
1713	23171125	12.958			
1716			206682.50	1.699	20

OPERATING CONDITIONS

CLIENT: Gibson Oil
DATE: May 16, 1990
UNIT: Boiler

<u>Time</u>	<u>Gas Meter cubic feet</u>	<u>Gas Flow Rate ft3/min</u>	<u>Water Meter gal</u>	<u>Water Flow Rate gal/min</u>	<u>Steam Pressure psi</u>
852					20
853			209196.65		
855	23183132				
921					19
922			209275.15	2.707	
924	23183517	13.276			
1012			209407.20	2.641	20
1015	23184275	14.863			
1511			210192.00	2.625	20
1515	23188085	12.700			
1646			210454.80	2.766	20
1649	23189300	12.926			
1724			210562.40	2.832	21
1727	23189884	15.368			
1913	23191155	11.991			
1918			210871.50	2.711	21
2002			211093.50	5.045	20
2005	23191815	12.692			

GIBSON 5240

OPERATING CONDITIONS

CLIENT: Gibson Oil
DATE: May 17, 1990
UNIT: Boiler

<u>Time</u>	<u>Gas Meter cubic feet</u>	<u>Gas Flow Rate ft3/min</u>	<u>Water Meter gal</u>	<u>Water Flow Rate gal/min</u>	<u>Steam Pressure psi</u>
717			212840.50		21
720	23200370				
832	23201305	12.986			20
836			213057.40	2.746	
1203	23204040	12.962			
1249	23204639	13.022			19
1252			213717.05	2.577	
1355	23205495	12.970			20
1358			213901.70	2.798	20
1554			214220.95	2.752	
1557	23207090	13.074			19
1952			214825.70	2.541	
1956	23210208	13.046			

METALS EMISSIONS TEST MONITOR DATA

DATE: May 17, 1990	Pbar(in. Hg): 29.50	Nozzle q90012	Diameter (mm): 12.140
CLIENT: Gibson Oil	Pstat(in.H2O): -0.2	Probe Length, in. 36	Pitot Cp: 0.840
UNIT: Boiler	Pduct(in. Hg): 29.49	LCD Meter 789	Cor.Fact.: 1.0319
SITE: Outlet	Initial MW: 28.3	Impinger Bkt 2	Orifice Km: 0.60
RUN #: 13	Initial %H2O: 5.0	Probe Liner: SS	Filter Holder: SS

PORT NORTH				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	9	52	240	0.08	80	158.546	6	18.5	4.44	1.01	
2	3	10	1	280	0.07	79		5	17.2	3.47	0.89	
3	2	10	10	281	0.10	81			21.4	5.34	1.10	
4	1	10	19	282	0.12	82		9	23.5	6.50	1.21	
		10	28				193.459					

Sample Time =	36	271	0.09	80	36.027	20.1	4.94	95.2
---------------	----	-----	------	----	--------	------	------	------

PORT WEST				DATA					CALCULATIONS			
#	TP	Hour	Minute	Td	DP	Tm	Vm	Vacuum	Vd	DH	Qm	%ISO
1	4	10	56	238	0.09	84	193.459		19.7	5.12	1.08	
2	3	11	5	282	0.07	83			17.9	3.74	0.93	
3	2	11	14	278	0.11	85			22.4	5.99	1.17	
4	1	11	23	275	0.10	87			21.3	5.45	1.12	
		11	32				230.000					

Sample Time =	36	268	0.09	85	37.707	20.3	5.07	97.5
Post-Test Leak Rate	0.010 CFM	at	10 in. Hg.					

Test Summary

Sample Time =	72	270	82	73.733	20.2	5.01	96.3
NET CU. FT.							