

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Stella Cheese
P. O. Box 1379
Tulare, California 93274

Superior Mohawk Boiler

Prepared by:

Steiner Environmental, Inc.
4930 Boylan Street
Bakersfield, California 93308

RECEIVED

AUG 20 1993

SAN JOAQUIN VALLEY UNIFIED
APCD—SOUTHERN REGION

INITIAL COMPLIANCE TEST

July 30, 1993

8/20
Rac
A. J. F.

San Joaquin Valley Unified Air Pollution Control District
Permit Number S-0817-0001-00

Report PS-93-3186/Project 7378-93

Test Team Leader: Darryl Meloche

Approved by :



Jim Steiner, Project Manager
August 12, 1993

TABLE OF CONTENTS

Section		Page
1	INTRODUCTION	1-1
2	TEST MATRIX	2-1
3	TEST RESULTS	3-1
4	SAMPLING EQUIPMENT AND PROCEDURES	4-1
5	ANALYTICAL PROCEDURES	5-1
6	QUALITY ASSURANCE	6-1
	APPENDIX A - STEINER ENVIRONMENTAL RAW DATA . .	A-1
	APPENDIX B - BOILER OPERATING DATA	B-1

SECTION 1

INTRODUCTION

At the request of Stella Cheese, Steiner Environmental, Inc. undertook a series of emission tests on the effluent of a boiler located at their plant located in Tulare, California. The purpose of these tests was to determine compliance with San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) rules and regulations. These tests were conducted on July 30, 1993.

Stella Cheese has installed a Superior Mohawk Model 4-3753 natural gas fired boiler. This boiler is equipped with a low NO_x burner and flue gas recirculation (FGR) for NO_x control.

Triplicate tests for NO_x , CO, CO_2 and O_2 were conducted on the effluent of the boiler using CARB Method 1-100. Triplicate flowrate and moisture tests were performed using EPA Methods 2/4. A sample of the natural gas fired in the boiler was collected and analyzed for CHNOS, specific gravity, moisture and BTU using ASTM methods.

Messrs. Darryl Meloche and Scott Wine of Steiner Environmental, Inc. conducted these tests. Mr. Frank Miranda of Stella Cheese was present to oversee the operation of the boiler. Mr. Greg LeFlore of the SJVUAPCD was on site to observe the tests.

Section 2 of this report summarizes the test matrix for this program.

SECTION 2
TEST MATRIX

Table 2-1 summarizes the tests performed on this program. The boiler is rated at 31.5 MMBtu/hr and the heat input during these tests was 26 MMBtu/hr (82.5% of capacity).

Section 3 presents the test results.

TABLE 2-1. STELLA CHEESE SUPERIOR MOHAWK BOILER TEST MATRIX

Date	Test No.	Test Parameter	Test Time	Test Condition
07/30/93	1	NO _x /CO/CO ₂ /O ₂ Flowrate/H ₂ O	11:12 am - 12:12 pm 11:15 am - 12:06 pm	27 MMBtu/hr
	2	NO _x /CO/CO ₂ /O ₂ Flowrate/H ₂ O	12:22 pm - 1:22 pm 12:22 pm - 1:21 pm	25 MMBtu/hr
	3	NO _x /CO/CO ₂ /O ₂ Flowrate/H ₂ O	1:47 pm - 2:47 pm 1:50 pm - 2:41 pm	26 MMBtu/hr

SECTION 3

TEST RESULTS

Table 3-1 summarizes the results of the tests performed on the boiler. NO_x and CO emissions are limited to 0.037 lb/MMBtu and 0.035 lb/MMBtu, respectively. Measured NO_x and CO emissions averaged 0.034 lb/MMBtu and 0.004 lb/MMBtu, respectively.

TABLE 3-1. SUMMARY OF SOURCE TEST RESULTS

Company : STELLA CHEESE

Test Date: JULY 30, 1993

APCD No.: S-0817-0001-00

Unit No. :
SUPERIOR MOHAWK BOIL

POLLUTANT	INLET			OUTLET			Removal Percent	Emission Factor Outlet
	Concentration	Mass Flow Rate	Mass Flow Rate	Concentration	Mass Flow Rate	Mass Flow Rate		
	gr/scf @12% CO2	ppm(v)	lb/hr	gr/scf @12% CO2	ppm(v)	@O2 CORR*	lb/hr	
Particulate								
avg.								
Sulfate								lb/MMBtu
avg.								as Sulfur
SO2 (wet)								lb/MMBtu
avg.								as Sulfur
NOx as NO2 (dry)								0.0338
avg.								lb/MMBtu
HC (> C1)								
avg.								
CO								
avg.								0.0038
avg.								
Scrubber Liquor Analysis :				Chlorides -		Specific Gravity -		
				mg/l				
For Kern County Use Only								

Comments : 3.0 % O2 correction.

SECTION 4

SAMPLING EQUIPMENT AND PROCEDURES

This section of the report describes the equipment and procedures used to conduct the gaseous tests on this program.

4.1 PRELIMINARY MEASUREMENTS

Before conducting the stack tests a series of preliminary measurements were made to determine:

- The location of the sampling site and the number and location of the sampling points to be used (EPA Method 1)

4.2 PREPARATION OF THE MOISTURE/FLOWRATE SAMPLING TRAIN

All sampling train components were cleaned in the laboratory (soap and water, tap water rinse, distilled water rinse, and IPA rinse) to eliminate previous contamination. The sampling train components were EPA Method 2/4 equipment used to measure moisture and flowrate consisted of:

- A straight stainless steel nozzle for constant rate sampling
- A heated Pyrex glass sampling probe (6 feet long) equipped with an S-type pitot tube and a thermocouple to measure stack velocity, pressure and temperature
- A heated Pyrex glass filter holder containing an untared 100-mm Whatman 934 AH glass fiber filter

- A Pyrex glass impinger train in an icebath (impingers 1 and 2 contained 100-ml distilled water; bubbler 3 was dry; bubbler 4 contained a weighed amount of silica gel)
- An umbilical to connect the probe and sample box to the control module
- A control module containing a vacuum pump, a calibrated dry gas meter and a calibrated orifice meter to measure the pressure, temperature and flowrate throughout the train.

The sampling train was charged in the mobile lab using freshly prepared reagents. Each impinger and its contents was weighed to the nearest 0.1 gm on a calibrated electronic balance. The sampling point locations were marked on the probe using a high-temperature marker. The sampling train was completely assembled and lifted to the sampling site.

4.3 SAMPLING PROCEDURES FOR MOISTURE/FLOWRATE SAMPLING TRAIN

Prior to a test, the sampling train was heated and leak checked at 15-inches Mercury to insure leakage was less than 0.02 cfm or 4% of the average sampling rate. The S-type pitot tube was also leak checked. The sampling train was installed on the unirail and the probe was inserted into the stack at the farthest point. A constant sampling rate was calculated using an HP-41CV calculator for each sampling point on the traverse (8 points per traverse; 2 traverses at 90°). Each point was sampled for an equal period of time (1.875 minutes) and all pertinent data were recorded on the data sheet every 1.875 minutes for each point. The probe and sample box were maintained at 250°F throughout the traverse. The gases leaving the impinger train were maintained at <68°F. At the end of a traverse, the probe was withdrawn from the stack and the

entire sampling train was transferred intact to the next sampling port. Another traverse of the stack was completed and the sampling train was withdrawn for the final leak check. This leak check was performed at 15-inches Mercury or at the highest vacuum achieved during the test. The S-type pitot tube was also checked at this time. The impinger train was sealed with aluminum foil and lowered to the mobile lab for sample recovery.

4.4 SAMPLE RECOVERY PROCEDURES FOR MOISTURE/FLOWRATE SAMPLING TRAIN

Sample recovery for the impinger train occurred in the mobile lab. Each impinger was removed from the icebath, wiped dry and weighed to the nearest 0.1 gm. The contents of impingers 1 and 2 and bubblers 3 and 4 were discarded. The sampling train was then recharged in preparation for the next test.

4.5 SAMPLING PROCEDURES FOR CONTINUOUS MONITORING

The continuous monitors used in the Steiner Environmental Mobile Monitoring Lab are shown in Table 4-1. Figure 4-1 is a schematic of the continuous monitoring system. The procedures used to continuously monitor stack gases for NO_x , CO, CO_2 and O_2 strictly followed CARB Method 1-100.

Sample was taken from the stack (at a single point) using a 316 stainless steel probe. A heated Balston filter holder and fiberglass filter (99.9999 percent efficiency retention of 0.6 micron particles) was connected to the outlet of the probe. Sample gas was transported through heated Teflon sample line (maintained at $>250^\circ\text{F}$) by a Teflon-lined diaphragm pump to a 316 stainless steel refrigeration type conditioner (Hankison Model E-4G-SS). The sample gas was passed through the

TABLE 4-1. CONTINUOUS MONITORING LAB - TRAILER 3

NO_x CHEMILUMINESCENT ANALYZER – THERMO ELECTRON MODEL 10

Response Time (0-90%)	1.5 sec -- NO mode; 1.7 sec -- NO _x mode
Zero Drift	Negligible after 1/2 hour warmup
Linearity	±1% of full scale
Accuracy	Derived from the NO or NO ₂ calibration gas, ±1% of full scale
Output	0-10 V
Operating Ranges	0-2.5, 10, 25, 100, 250, 1000, 2500 and 10,000 ppm
Flowrate = 2 scfh	0-2.5

O₂ ANALYZER, FUEL TYPE – TELEDYNE MODEL 326

Response Time (0-90%)	60 seconds
Accuracy	±1% of scale at constant temperatures; ±1% of scale of ±5% of reading, whichever is greater, over the operating temperature range
Output	0-1 V
Operating Ranges	0-5%, 10%, 25% O ₂
Flowrate	2 scfh

CO₂/CO INFRARED ANALYZER – ANARAD MODEL AR-600

Response Time (0-90%)	5 seconds
Zero Drift	±1%
Span Drift	±1%
Linearity	1%
Resolution	Less than 1% of full scale
Output	0-1 V
Operating Ranges	0-20% CO ₂ /0-5% CO
Flowrate	1000 cc/min

CO GAS FILTER CORRELATION – THERMO ELECTRON MODEL 48

Response Time (0-95%)	1 minute
Zero Drift	±0.2 ppm CO
Span Drift	Less than 1% full scale in 24 hours
Linearity	±1% full scale, all ranges
Accuracy	±0.1 ppm CO
Output	0-10 V
Operating Ranges	1, 2, 5, 10, 20, 50, 100, 200, 500, 1000 ppm
Flowrate	.5 - 2 lpm

STRIP CHART RECORDERS (2) – LINSEIS 7025

Pen Response	0.35 seconds Full Scale
Input Spans	1, 2, 5, 10, 20, 50, 100 mV
Zero Set	Stable across entire chart-width ±100%
Accuracy	.35% of Span
Dead Band	.15% of Span
Linearity	.25% of Span
Chart Speed	1, 2, 5, 10, 20, 50, 100 cm/min; 1, 2, 5, 10, 20, 50 cm/hr; fast advance 100 cm/min; LED indicator; forward and reverse selector
Recording Pen	Fiber tip pen
Chart Width	250 mm

SCOTSMAN TRAILER

Fully Insulated	Air Conditioned -- 8 feet x 14 feet x 11 feet
-----------------	---

1. Filter 0.6 μ , 99.9999 percent efficient
2. Duct
3. 316 stainless steel probe
4. 3/8-inch, heated (250°F) Teflon
5. Four-pass conditioner-dryer, 316 stainless steel internals
6. 3/8-inch, unheated Teflon
7. Teflon-lined sample pump
8. 3/8-inch unheated Teflon
9. Rotameter
10. 1/4-inch Teflon tubing
11. Calibration gas manifold
12. Calibration gas selector valve
13. Calibration gas cylinders
14. Backpressure regulator
15. Auxiliary analysis port




FIGURE 4-1. SCHEMATIC OF CONTINUOUS MONITORING SYSTEM

conditioner two separate times under vacuum before entering the pump, then two additional times under pressure. The clean, dry sample gas ($\sim 35^{\circ}\text{F}$) was then transported to the continuous analyzer system through an unheated Teflon line. A series of flowmeters, valves, and regulators maintain constant flow through the system at a constant pressure.

Calibrations of the continuous analyzers were performed using EPA Protocol 1 calibration gases ($\pm 1\%$) for NO_x and NBS certified calibration gases ($\pm 1\%$) for CO , CO_2 and O_2 . Copies of the gas certifications are included in the appendix of this report. All pertinent data (date, time, test locations, analyzer range, cal gas value) were recorded on both the field data sheets and continuous analyzer strip charts in the field.

At the start of a test day, a leak check was performed. The sample probe was removed from the stack and the end was sealed. A leak check was successful only if pressure at the analyzer system and flow through the rotameters to the individual analyzers all dropped to zero. A mandatory leak check was performed at the completion of each test day.

An initial calibration was performed at the start of a test period by introducing zero and span gases for each analyzer and making the necessary adjustments. Calibration gas values were recorded on the continuous monitor strip charts and field data sheets. A calibration check was completed at the end of a test and adjustments (if necessary) to the analyzers were made in preparation for another test.

An external calibration of the sampling system was performed at the start of a test day. EPA Protocol 1 gas was flowed through the entire sampling system from the probe tip. The response of the analyzers had to be within $\pm 5\%$ of the certified tank value before testing could proceed. An external calibration was also performed at the end of each test day.

Test data were collected by recording 10-minute averages from the strip chart recordings onto the field data sheets. Data collected over the test period were averaged and reported. A fuel analysis was used to calculate the F-factor, dscf/MMBtu corrected to zero percent O₂ (standard conditions 60°F, 29.92 inches Mercury), as described in 40 CFR 60.45. The pollutant concentration and the F-factor were used to calculate an emission factor in lb/MMBtu.

SECTION 5

ANALYTICAL PROCEDURES

This section of the report describes the procedures used to analyze the samples collected during the test program.

5.1 FUEL

A sample of the fuel fired during this test program was collected and sent to Pacific Gas Technology for analysis. Analysis was performed by PGT in accordance with EPA Title 40 Section 60.45. The specific procedures are itemized in Table 5-1. The results appear at the end of this section.

TABLE 5-1. FUEL ANALYSIS METHODS
LABORATORY TEST PROCEDURES FOR FUEL OILS AND FUEL GASES

Reference: EPA Title 40, Section 60.45

FUEL OIL TESTS:

Sediment and Water, Vol. %	ASTM D4007-81
Gravity by Hydrometer (API)	ASTM D1298-80
API Gravity Corrected to 60°F	ASTM Table 5A
Gross Calorific Value (Btu/lb)	ASTM D2015-77
Ultimate Analysis (C, H, O, N, S, wt. %)	
Carbon, Hydrogen	ASTM D3178-73
Nitrogen (chemiluminescence detector)	ASTM D3431-80
Sulfur	ASTM D2622-82
Ash	ASTM D482
Oxygen	ASTM D3176-74

GASEOUS FUELS BY GAS-LIQUID CHROMATOGRAPHY:

Gas Analysis	ASTM D1945-81
Sulfur Analysis	CPA B16
Calculation of Gross Calorific Value	ASTM D3588-81
Component Weight %, F-factor calculations	EPA 40:60.45

PROCEDURES FOR SCRUBBER LIQUOR ANALYSIS:

Specific Gravity	ASTM D1429
Chlorides	ASTM D512-67

PACIFIC GAS TECHNOLOGY




2122 Q Street
Bakersfield, California 93301
805/324-1317
Fax: 805/324-2746

GAS ANALYSIS BY CHROMATOGRAPH

STEINER ENVIRONMENTAL, INC
4930 Boylan Street
Bakersfield, CA 93308

Attention: Jim Steiner



SAMPLED: 30-Jul-93

SUBMITTED: 2-Aug-93

REPORTED: 5-Aug-93

LAB No.: 6474-7

Sample ID : STELLA CHEESE
BOILER
NATURAL GAS

STEINER ID No. : 33914

ANALYZED GAS

	MOLE %	WT %	CHONS	WT %
OXYGEN	0.04	0.07	CARBON	73.25
NITROGEN	0.76	1.18	HYDROGEN	23.08
CARBON DIOXIDE	1.36	3.32	OXYGEN	2.49
HYDROGEN	ND	0.00	NITROGEN	1.18
CARBON MONOXIDE	ND	0.00	SULFUR	0.00
HYDROGEN SULFIDE	ND	0.00		
METHANE	89.45	79.61		
ETHANE	6.50	10.84		
PROPANE	1.53	3.74		
iso-BUTANE	0.12	0.39		
n-BUTANE	0.17	0.55		
iso-PENTANE	0.03	0.12		
n-PENTANE	0.02	0.08		
HEXANE +	0.02	0.10		
TOTAL:	100.00			

SPECIFIC GRAVITY * : 0.622

SPECIFIC
VOLUME : 21.13 cu ft/lb

TOTAL SULFUR as
Hydrogen Sulfide : ppm (GC/FPD)

TOTAL * DRY : 1069

NET * DRY : 965

BTU/cu ft WET : 1051

BTU/cu ft WET : 948

BTU/lb : 22596

BTU/lb : 20394

SECTION 6

QUALITY ASSURANCE

6.1 MOISTURE/FLOWRATE SAMPLING EQUIPMENT

A detailed record of repair and maintenance to each sampling train is kept. Preventative maintenance to each system is performed periodically to avoid complete component breakdown during a field test.

A detailed record of sampling system calibrations is also kept. Calibration data for the sampling nozzles, pitot tubes, dry gas meters and orifice meters are available for review. Results of the EPA Quality Assurance Branch biannual audits of the dry gas meter and orifice meter combinations are also logged and verify our in-house calibration data. The calibration data for the equipment used on this program can be found in the appendix.

A comparison of the volumetric stack gas flowrates measured by pitot tube and calculated from the fuel gas readings appears in Table 6-1. Good agreement was obtained.

6.2 LAB ANALYSIS

All field samples are assigned a label and an ID number. This ID is also affixed to a chain-of-custody log and to the field data sheet to eliminate any chance of sample mixup.

Prior to analysis, all glassware is thoroughly cleaned (soap and water, tap water rinse, distilled water rinse, IPA rinse) to eliminate

any contamination. The evaporating dishes used to evaporate the washings are treated the same as a sample (dried in an oven, desiccated and weighed repeatedly at 6-hour intervals until a constant weight is achieved). The glassware used to measure volumes and make transfers and dilutions are all NBS Class A to insure accurate measurements. All weighings are carried out on a Sartorius Research Model R160P electronic semi-micro balance supported by a marble table in a separate room from the main analytical laboratory. The balance is calibrated regularly against an NBS Class S-1 weight.

All reagents used in the field and in the laboratory are ACS reagent grade and blanks of these reagents are evaluated for every set of tests. Blanks are taken in the field from the squeeze bottles and not the original container. Records are kept on these blanks to insure consistent quality of the reagents.

6.3 CONTINUOUS MONITORS QUALITY ASSURANCE

The NO_x analyzer was calibrated before and after each test using an EPA Protocol 1 gas ($\pm 1\%$) traceable to NBS. The CO, CO₂ and O₂ analyzers are calibrated before and after each test using a NBS certified gas mixture ($\pm 1\%$). Copies of the calibration gas certificates appear in the appendix of this report.

A sampling system check was performed at the beginning and end of each test day. This was done by introducing an EPA Protocol 1 gas at the sampling probe and measuring the system response. The purpose of this was to check the system for leaks and sample loss.

Multi-point calibration linearity checks of the continuous analyzers were performed on May 5, 1991 through May 16, 1991. These

results were well within CARB limitations of $\pm 2\%$ of full scale. Tables 6-1 through 6-6 list the results of these checks.

TABLE 6-1. MEASURED VERSUS CALCULATED FLOWRATES

Test No.	Measured	Calculated	% Difference
1	4,221	4,371	-3.6
2	4,158	4,068	2.2
3	4,186	4,123	1.5

$$\% \text{ Difference} = \frac{\text{Measured} - \text{Calculated}}{\text{Measured}} \times 100$$

TABLE 6-2. NO_x CALIBRATION SUMMARY

Monitoring Trailer: 3		Calibrated by: JP 5/9/91	
Analyzer:	TECO	Calibrator Manufacturer:	Enviro-nics
Model:	10 AR	Model:	201-1520
Serial Number:	15311-154	Serial Number:	1122
NO _x Standard: CC7204, CC72048			
Concentration: 9760 ppm, 1039 ppm			
Cylinder Pressure: 2000 psi, 2000 psi			

NO_x CALIBRATION AND LINEARITY CHECKS

Range 0-2500 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	2944.8	0	0	0	0
80% URL	2332.9	603.8	2005	2005.0	0
1	2487.1	450.7	1497	1502.5	+ 0.22
2	2638.9	302.0	1002	1010.0	+ 0.32
3	2790.6	152.3	505	505.0	0

Range 0-1000 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	4919.8	0	0	0	0
80% URL	4515.9	402.0	798.0	798	0
1	4616.3	303.2	601.5	602	+ 0.05
2	4716.6	204.1	405.0	409	+ 0.40
3	4814.5	103.6	205.5	207	+ 0.15

TABLE 6-2. NO_x CALIBRATION AND LINEARITY CHECKS (Concluded)

TECO Model 10-AR/Trailer #3/May 9, 1991

Range 0-100 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9339.6	0	0	0	0
80% URL	9256.4	76.9	80.4	80.4	0
1	9278.4	56.9	59.5	60.1	+ 0.6
2	9298.0	38.2	39.9	39.8	+ 0.1
3	9320.1	19.5	20.3	19.9	- 0.4

Range 0-25 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	4916.6	0	0	0	0
80% URL	4821.9	94.7	20.00	20.00	0
1	4846.3	70.1	14.80	15.02	+ 0.88
2	4865.4	46.9	9.90	10.00	+ 0.40
3	4890.4	23.8	5.03	5.03	0

Range 0-10 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	NO _x out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9335.3	0	0	0	0
80% URL	9263.8	72.3	8.04	8.04	0
1	9283.3	53.4	5.95	5.92	- 0.3
2	9298.0	35.8	3.99	3.93	- 0.6
3	9320.0	18.3	2.03	2.02	- 0.1

TABLE 6-3. CO CALIBRATION SUMMARY

Monitoring Trailer:	3	Calibrated by:	JP 5/13/91
Analyzer:	ANARAD	Calibrator Manufacturer:	Enviro-nics
Model:	AR 602	Model:	201-1520
Serial Number:	2340	Serial Number:	1122
CO Standard:	ALM17548, ALM15154		
Concentration:	42490 ppm, 22560 ppm, 10430 ppm		
Cylinder Pressure:	2000 psi, 2000 psi, 2000 psi		

CO CALIBRATION AND LINEARITY CHECKS

Range 0-50,000 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	* NA	* NA	0	0	0
80% URL	* NA	* NA	42490	42490	0
1	* NA	* NA	22560	22600	+ 0.08
2	* NA	* NA	10430	10100	- 0.66

* Used Concentrated Gas Cylinders

TABLE 6-4. CO CALIBRATION SUMMARY

Monitoring Trailer: 3		Calibrated by: JP 5/10/91	
Analyzer:	TECO	Calibrator Manufacturer:	EnviroNics
Model:	48	Model:	201-1520
Serial Number:	25149-219	Serial Number:	1122
CO Standard:	CC81181, CC345		
Concentration:	10430 ppm, 1001 ppm		
Cylinder Pressure:	2000 psi, 2000 psi		

CO CALIBRATION AND LINEARITY CHECKS

Range 0-1000 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	7368.0	0	0	0	0
80% URL	6809.1	558.9	791.2	791.2	0
1	6948.6	420.3	594.5	598.0	+ 0.35
2	7090.5	281.1	397.7	411.0	+ 1.30
3	9160.9	179.4	200.3	211.0	+ 1.10

Range 0-500 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	7371.6	0	0	0	0
80% URL	7090.5	281.1	397.7	397.7	0
1	7161.5	211.8	299.6	307.5	+ 1.58
2	2890.9	56.0	198.3	201.0	+ 0.54
3	2917.8	28.3	100.2	100.5	+ 0.06

TABLE 6-4. CO CALIBRATION AND LINEARITY CHECKS (Concluded)

TECO Model 48/Trailer #3/May 10, 1991

Range 0-100 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	8838.0	0	0	0	0
80% URL	8140.4	697.6	79.0	79.0	0
1	8319.1	524.1	59.3	59.1	- 0.2
2	8492.9	350.9	39.7	39.8	+ 0.1
3	8671.5	177.2	20.0	20.3	+ 0.3

Range 0-20 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	4917.8	0	0	0	0
80% URL	4838.9	78.9	16.05	16.05	0
1	4858.6	58.3	11.90	12.08	+ 0.9
2	4878.2	39.1	7.96	8.02	+ 0.3
3	4897.7	19.9	4.04	4.14	+ 0.5

Range 0-10 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO out ppm	Chart ppm	% Difference +2% Full Scale
Zero	8845.5	0	0	0	0
80% URL	8774.3	71.2	8.04	8.04	0
1	8796.3	52.6	5.94	6.05	+ 1.1
2	8813.5	35.3	3.99	4.15	+ 1.6
3	9711.6	19.7	2.02	2.10	+ 0.8

TABLE 6-5. CO₂ CALIBRATION SUMMARY

Monitoring Trailer: 3		Calibrated by: JP 5/16/91	
Analyzer: ANARAD		Calibrator Manufacturer: Environics	
Model: AR 602		Model: 201-1520	
Serial Number: 2340		Serial Number: 1122	
CO ₂ Standard: CC86353			
Concentration: 41.2%			
Cylinder Pressure: 1000 psi			

CO₂ CALIBRATION AND LINEARITY CHECKS

Range 0-20 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	CO ₂ out %	Chart %	% Difference +2% Full Scale
Zero	1998.0	--	0	0	0
80% URL	1278.1	719.9	16.21	16.21	0
1	1451.9	531.0	12.05	12.30	+ 1.25
2	1628.1	355.2	8.06	8.20	+ 0.70
3	1801.9	179.3	4.07	4.16	+ 0.45

TABLE 6-6. O₂ CALIBRATION SUMMARY

Monitoring Trailer: 3		Calibrated by: JP 5/14/91	
Analyzer:	Teledyne	Calibrator Manufacturer:	Enviro-nics
Model:	326A	Model:	201-1520
Serial Number:	44535	Serial Number:	1122
O ₂ Standard:	A14722		
Concentration:	45%		
Cylinder Pressure:	1750 psi		

O₂ CALIBRATION AND LINEARITY CHECKS

Range 0-25 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	O ₂ out %	Chart %	% Difference +2% Full Scale
Zero	1991.8	--	0	0	0
80% URL	1094.6	897.2	20.2	20.20	0
1	1836.1	943.5	15.3	15.25	- 0.20
2	2139.6	618.9	10.1	10.38	+ 1.10
3	2445.5	311.0	5.08	5.30	+ 0.88

Range 0-10 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	O ₂ out %	Chart %	% Difference +2% Full Scale
Zero	4441.1	--	0	0	0
80% URL	3632.5	808.6	8.19	8.19	0
1	3828.2	596.8	6.07	6.11	+ 0.3
2	4024.0	398.8	4.06	4.20	+ 1.4
3	4219.8	201.2	2.05	2.21	+ 1.6

TABLE 6-6. O₂ CALIBRATION AND LINEARITY CHECKS (Concluded)

Teledyne Model 326A/Trailer #3/May 14, 1991


Range 0-5 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	O ₂ out %	Chart %	% Difference +2% Full Scale
Zero	7885.8	--	0	0	0
80% URL	7166.4	719.4	4.10	4.10	0
1	7340.2	530.6	3.03	3.08	+ 1.0
2	7513.9	354.7	2.03	2.10	+ 1.4
3	7687.7	179.3	1.03	1.11	+ 1.6

APPENDIX A
STEINER ENVIRONMENTAL RAW DATA

SAMPLING POINT LOCATION DATA SHEET

Plant STELLA CHEESE
 Date 7-30-93
 Test Location HRSG-out
 Upstream Dist./Dia. 52.0" / 2.0 ϕ
 Downstream Dist./Dia. 180" / 6.9 ϕ
 No. of Sampling Points 16
 Stack Dimension 26.0"
 Coupling Length 3.0"



4-inch MPI/FPT/Flange
HAS HOOKS 3' PROBE & RAILS
50 ROPE 100' POWER
 XEQ PNT * MAY WANT TO BRING TRANSFORMER

Sample Point	Dist	Sample Point	Dist	Sample Point	Dist	Sample Point	Dist
1	3.8						
2	5.7						
3	8.0						
4	11.4						
5	20.6						
6	24.0						
7	26.3						
8	28.2						

SAMPLING POINT RELOCATION:

VELOCITY TRAVERSE DATA SHEET

Plant STELLA CHEESE

Date 7-30-93

Test Location HRSG - OUT

Static Pressure (in. wg) 0.19

Barometric Pressure 30.20

Probe Type/Length GL / 6'

Pitot Coefficient 0.84

Stack Dimension 26.0"

Run # 1

Time: 1150 Time: 1158 Time: Time:

Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s
A-1	0.23	336	B-1	0.26	329						
2	0.265	342	2	0.27	332						
3	0.26	343	3	0.28	339						
4	0.26	345	4	0.28	342						
5	0.27	345	5	0.25	343						
6	0.27	343	6	0.25	345						
7	0.24	338	7	0.22	341						
8	0.24	334	8	0.23	340						

SAMPLING POINT RELOCATION

Pitot ☒ O.K.

Avg. $\sqrt{\Delta P}$ = 0.5044

Avg. ΔP = 0.2547

Avg. T_s = 339.81

VelTrav.Frm (1/91)

VELOCITY TRAVERSE DATA SHEET

Plant STELLA CHEESE

Date 7-30-93

Test Location HRSG - OUT

Static Pressure (in. wg) 0.15

Barometric Pressure 30.18

Probe Type/Length GL/6'

Pitot Coefficient 0.84

Stack Dimension 26.0"

Run # 2

Time: 1305 Time: 1313 Time: Time:

Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s
A-1	0.23	329	B-1	0.25	325						
2	0.25	339	2	0.27	336						
3	0.26	341	3	0.29	340						
4	0.26	342	4	0.28	342						
5	0.25	344	5	0.24	343						
6	0.265	345	6	0.225	345						
7	0.24	340	7	0.21	339						
8	0.23	336	8	0.23	335						

SAMPLING POINT RELOCATION

Pitot $\checkmark$ O.K.

Avg. $\sqrt{\Delta P}$ = 0.4983

Avg. ΔP = 0.2488

Avg. T_s = 338.81

VelTrav.Frm (1/91)

VELOCITY TRAVERSE DATA SHEET

Plant STELLA CHEESE

Date 7-30-93

Test Location HRS6 - OUT

Static Pressure (in. wg) 0.16

Barometric Pressure 30.21

Probe Type/Length GL/6'

Pitot Coefficient 0.84

Stack Dimension 26.0"

Run # 3

Time: 1427 Time: 1434 Time: Time:

Smpl Pt.	ΔP	T_s	Smpl Pt.	ΔP	T_s	Smpl Pt.	ΔP	T_s	Smpl Pt.	ΔP	T_s
A-1	0.23	328	B-1	0.25	330						
2	0.26	334	2	0.27	334						
3	0.26	339	3	0.27	336						
4	0.27	343	4	0.29	341						
5	0.25	345	5	0.26	343						
6	0.26	346	6	0.245	345						
7	0.23	340	7	0.23	338						
8	0.23	338	8	0.22	332						

SAMPLING POINT RELOCATION

Pitot $\checkmark$ O.K.

Avg. $\sqrt{\Delta P} = \underline{0.5012}$

Avg. $\Delta P = \underline{0.2516}$

Avg. $T_s = \underline{338.25}$

VelTrav.Frm (1/91)

Date 7-30-93 Barometric Pressure 30.20
 Test Location HRS6-OUT Static in.wg. 0.19
 Run Number #1 Probe Type/Length GL/6'
 Stack Diameter 26.0" Pitot Coefficient 0.84
 Operator SWD Meter Box No./Y #21314/1.0053
 Filter No. N/A Nozzle No./Size STRAIGHT

IMPINGER				VOLUMES/WEIGHTS				GAS COMPOSITION			
Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO	Leakrate	cfm	"Hg	
DI	638.3	533.3	105.0								
DI	629.4	620.9	8.5								
DRY	455.0	453.7	1.3								
S.G.	738.2	731.1	7.1					Initial	0.003	15"	
		TOTAL	121.9					Final	0.002	5"	

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F						Pump Vacuum in.Hg	√ΔP	Comments
					Stack	Probe	Oven	Imp.	Gas Meter				
									In	Out			
1	1115		3.0	100.000	*	N/A	N/A	76	97	98	4.5	*	* Avg. Taken
				104.467				70	95	96			From Velocity
	10			108.964				69	95	95			TRAVERSE
				113.435				70	94	94			
	20			117.891				70	93	93			
				122.325				70	93	93			
END TEST	1145			126.808									
T/A	30 ¹¹¹⁵		3.0	26.808	339.81							0.5044	

Date 7-30-93 Barometric Pressure 30.18
 Test Location H2SG-04T Static in.wg. 0.15
 Run Number #2 Probe Type/Length GL/6'
 Stack Diameter 26.0" Pitot Coefficient 0.84
 Operator SWD Meter Box No./Y # 21314/1.0053
 Filter No. 12/A Nozzle No./Size STRAIGHT

IMPIGNER			VOLUMES/WEIGHTS		GAS COMPOSITION			
Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO	
DI	633.2	530.2	103.0					
DI	552.0	541.0	11.0					
DRY	443.2	441.3	1.9					
				Leakrate	cfm		"Hg	
S.G.	703.3	695.5	7.8	Initial	0.004		15"	
		TOTAL	123.7	Final	0.002		5"	

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F						Pump Vacuum in.Hg	$\sqrt{\Delta P}$	Comments
					Stack	Probe	Oven	Imp.	Gas Meter				
									In	Out			
1	1222		3.0	127.400	*	N/A	N/A	77	96	96	5.0	*	* AUG. TAKEN FROM VELOCITY TRAVERSE
	10			131.876				67	96	96			
				136.318				67	98	97			
				140.761				65	98	97			
	20			145.249				68	100	97			
END TEST				149.724				64	101	98			
				154.218									
T/A 30 min			3.0	26.818	338.81					97.50		0.4983	

STELLA CHEESE

Barometric Pressure 30.21

IMPINGER VOLUMES/WEIGHTS			
Contents	Final	Initial	Net
DI	644.9	541.7	103.2
DI	639.7	629.4	10.3
DRY	456.8	455.0	1.8
S.G.	745.6	738.2	7.4
		TOTAL	122.7

[illegible]

CONTINUOUS MONITOR DATA SHEET

Plant STELLA CheeseDate 7-30-93 Run No. 1+2Test Location BulkOperator DMFuel Type Natural Gas Trailer No. 3APCD Witness/Number Greg LaForeClient Rep Frank Miranda

Generator Type _____

Burner Type _____

O₂ Controller Type _____


Dry Uncorrected

Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	Comments	Miscellaneous Information
		8.55	15.82	175.8			86.2	Span Gas Value	CALIBRATION GASES
		0.0	0.0	0.0			0.0	Zero	NO _x <u>CC28647</u>
		8.40	15.64	174.5			86.1	Bias Span	SO ₂ _____
		0.05	0.0	0.0			0.0	Bias Zero	CO <u>CC42657</u>
		0.04						QA ✓ back	CO/CO ₂ /O ₂ <u>CC40344 CC50006</u>
								Fire alarm CO 0-100ppm	
				87.5				Span value (CO only)	Wet Bulb: _____ Dry Bulb: _____
				0.0				Zero	Barometric Press: _____
1112		2.64	10.20	3.0			28.8	Run #1	RESPONSE TIME
1122		2.68	10.18	2.4			28.7	33914	Upscale: _____ Downscale: _____
1132		2.60	10.26	4.0			28.8	N.G. All	Upscale: _____ Downscale: _____
1142		2.60	10.18	4.7			29.1		Upscale: _____ Downscale: _____
1152		2.46	10.04	36			28.9		
1202		2.40	10.08	7.4			29.7		PROCESS DATA
									Fuel Flow: _____
		0.0	0.0	0.0			0.0	Zero	Steam Flow: _____
		8.47	15.42	87.5			87.8	Span	Rating: _____
								ADJUST	
1222		2.60	10.26	3.3			28.3	Run #2	CONVERTER GAS
1232		2.43	10.40	3.6			28.9		Cal Gas Values Actual Values
1242		2.50	10.42	2.9			28.6		NO _____
1252		2.30	10.54	8.0			28.0		NO ₂ _____
1302		2.52	10.40	3.6			26.7		Conv. Efficiency: _____
1312		2.38	10.40	5.2			26.5		

APCD Witness/Number Greg LaBare
 Client Rep Frank Mirana
 Generator Type _____
 Burner Type _____
 O₂ Controller Type _____


Plant STELLA Cheese
Date 7-30-93 Run No. 2 + 3
Test Location Bowler
Operator DM
Fuel Type Natural Gas Trailer No. 3

Time	Sample Point	Dry Uncorrected						Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm		
		8.55	15.82	87.5			86.2	Span Gas Value	CALIBRATION GASES
		0.0	0.0	0.0			-1.0	Zero	NO _x _____
		8.50	16.04	87.5			86.2	Span	SO ₂ _____
								ADJUST	CO _____
									CO/CO ₂ /O ₂ _____
1347		2.44	10.46	8.2			29.5	Run #3	Wet Bulb: _____ Dry Bulb: _____
1357		2.52	10.40	6.3			29.3		Barometric Press: _____
1407		2.46	10.48	7.7			30.3		
1417		2.60	10.50	6.4			30.7		
1427		2.39	10.76	7.7			31.7		RESPONSE TIME
1437		2.40	11.04	9.0			31.8		Upscale: _____ Downscale: _____
									Upscale: _____ Downscale: _____
									Upscale: _____ Downscale: _____
		0.02	0.0	0.0			1.6	Zero	
		8.55	16.08	87.0			87.9	Span	PROCESS DATA
		0.04	0.0	0.0			1.4	Bias Zero	Fuel Flow: _____
		8.30	16.82	87.0			87.7	Bias Span	Steam Flow: _____
		0.07						QAV Leak ✓	Rating: _____
									CONVERTER GAS
									Cal Gas Values Actual Values
									NO _____ _____
									NO ₂ _____ _____
									Conv. Efficiency: _____




(8207)


$O_2 = 0-10\%$
 $NOx = 0-100ppm$
Ext. $O_2 = 0.04\%$
Ext. $NOx = 1.4ppm$
830%
Ext. $NOx = 87.7ppm$
 $O_2 = 0-10\%$
Ext. $O_2 = 0.03\%$
 $NOx = 0-100ppm$
Ext. $NOx = 1.6ppm$
- $O_2 = 8.55\%$
- $NOx = 87.9ppm$




$NOx = 0-100ppm$
 $O_2 = 0-10\%$
- $NOx = 86.2ppm$
- $O_2 = 8.55\%$
ADJUST
 $O_2 = 0-10\%$
 $NOx = 0-100ppm$
- $NOx = 86.2ppm$
- $O_2 = 8.50\%$
Ext. $NOx = 1.0ppm$




$O_2 = 0-10\%$
 $NOx = 0-100ppm$
- $O_2 = 8.55\%$
- $O_2 = 8.47\%$
- $NOx = 86.2ppm$
- $NOx = 87.8ppm$
 $NOx = 0-100ppm$
 $O_2 = 0-10\%$



5cm/hr
STELLA Chase
7-30-93 DM
Run #1
Boiler





A. CALIBRATION AND CORRECTION DATA

Company :

STELLA CHEESE

Date : 7/30/93

Station :

SUPERIOR MOHAWK BOILER

Test Run : 1

Test Condition: GAS 100%

Concentration : Drift Uncorrected (A) / Corrected (B)										
Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	2.64	2.64	10.20	10.22	3.00				28.80	28.76
2	2.68	2.69	10.18	10.24	2.40				28.70	28.57
3	2.60	2.61	10.26	10.37	4.00				28.80	28.58
4	2.60	2.61	10.18	10.33	4.70				29.10	28.79
5	2.46	2.48	10.04	10.23	3.60				28.90	28.50
6	2.40	2.42	10.08	10.32	7.40				29.70	29.20
MEAN		2.58		10.29		4.18				28.73

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.00		0.00		0.00				0.00
Span Check		8.47		15.42		87.50				87.80
Cal. Gas		8.55		15.82		87.50				86.20
Scf		-0.00156		-0.00421						0.00309
Zcf		0.00000		0.00000						0.00000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : STELLA CHEESE
 Station : SUPERIOR MOHAWK BOILER
 Date : 7/30/93
 Test Run : 2
 Test Condition: GAS 100%

Concentration : Drift Uncorrected (A) / Corrected (B)											
Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx		
	A	B	A	B	A	B	A	B	A	B	
1	2.60	2.60	10.26	10.25	3.30				28.30	28.36	
2	2.43	2.43	10.40	10.36	3.50				28.90	29.07	
3	2.50	2.51	10.42	10.36	2.90				28.60	28.88	
4	2.30	2.31	10.54	10.46	8.00				28.00	28.39	
5	2.52	2.53	10.40	10.29	3.60				26.70	27.21	
6	2.38	2.39	10.40	10.27	5.20				26.50	27.13	
MEAN		2.46		10.33		4.42					28.17

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.00		0.00		0.00				-1.00
Span Check		8.50		16.04		87.50				86.20
Cal. Gas		8.55		15.82		87.50				86.20
Scf		-0.00097		0.00232					0.00193	
Zcf		0.00000		0.00000					-0.16667	

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : STELLA CHEESE
 Station : SUPERIOR MOHAWK BOILER
 Date : 7/30/93
 Test Run : 3
 Test Condition: GAS 100%

Concentration : Drift Uncorrected (A) / Corrected (B)											
Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx		
	A	B	A	B	A	B	A	B	A	B	
1	2.44	2.44	10.46	10.45	8.20	8.20			29.50	29.36	
2	2.52	2.52	10.40	10.36	6.30	6.31			29.30	28.89	
3	2.46	2.45	10.48	10.41	7.70	7.72			30.30	29.62	
4	2.60	2.59	10.50	10.40	6.40	6.42			30.70	29.75	
5	2.39	2.38	10.76	10.63	7.70	7.73			31.70	30.47	
6	2.40	2.39	11.04	10.88	9.00	9.05			31.80	30.30	
MEAN		2.46		10.52		7.57					29.73

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.02		0.00		0.00				1.60
Span Check		8.55		16.08		87.00				87.90
Cal. Gas		8.55		15.82		87.50				86.20
Scf	-0.00039		0.00274		-0.00095				0.00019	
Zcf	0.00333		0.00000		0.00000				0.26667	

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

B. ZERO AND SPAN DRIFT PERCENT CALCULATIONS

Company : STELLA CHEESE

Date : 7/30/93

Station : SUPERIOR MOHAWK BOILER

Run 1	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	8.55	15.82	87.50		86.20
Measured Span	8.47	15.42	87.50		87.80
Zero Drift	0.00	0.00	0.00		0.00
Final, Actual Span	8.47	15.42	87.50		87.80
Percent Drift	-0.9	-2.5	0.0		1.9
*****	*****	*****	*****	*****	*****
Run 2	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	8.55	15.82	87.50		86.20
Measured Span	8.50	16.04	87.50		86.20
Zero Drift	0.00	0.00	0.00		-1.00
Final, Actual Span	8.50	16.04	87.50		87.20
Percent Drift	-0.6	1.4	0.0		1.2
*****	*****	*****	*****	*****	*****
Run 3	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	8.55	15.82	87.50		86.20
Measured Span	8.55	16.08	87.00		87.90
Zero Drift	0.02	0.00	0.00		1.60
Final, Actual Span	8.53	16.08	87.00		86.30
Percent Drift	-0.2	1.6	-0.6		0.1

Final, Actual Span = Measured Span - Zero Drift

Percent Drift = (Final, Actual Span - Initial Span) / Initial Span x 100

SOURCE TEST CALCULATIONS

PLANT : STELLA CHEESE
SUPERIOR MOHAWK BOILER

RUN NO.: 1
DATE : JULY 30, 1993

STANDARD TEMP.: 60 DEG. F

METER TEMP.	=	94.67 DEG. F	STATIC PRESS.	=	0.19 in. H2O
STACK TEMP.	=	339.81 DEG. F	Cp	=	0.840
SQ. RT. dP	=	0.5044 in. H2O	STACK I.D.	=	26.00 inch
METER ORIFICE	=	3.00 in. H2O	DUCT LENGTH	=	inch
METER VOLUME	=	26.808 Cu.Ft.	DUCT WIDTH	=	inch
METER Y	=	1.0053	STACK AREA	=	3.687 Sq.Ft.
BAR. PRESSURE	=	30.20 in.Hg	TEST TIME	=	30.00 min.
COND. (Vlc)	=	121.9 ml	NOZZLE DIA.	=	inch
GAS ANALYSIS	=	2.58 % O2			
		10.29 % CO2			
			0.00 % CO		
			87.13 % N2		

Sq Ft.

$$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots = 25.688 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic = 5.651 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots = 0.180 \text{ | Lower Bws value used.}$$

$$Bws @ \text{ Saturated Conditions} = \text{Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)} \dots = 1.000$$

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 12.63$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.75$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots = 27.63$$

$$P(stack) = Pbar + [Pstatic / 13.6] \dots = 30.21 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots = 35.45 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots = 7.843 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots = 4,221 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92)] \times 100 / (Time \times Ps \times An \times vs \times 60) = \%$$

SOURCE TEST CALCULATIONS

PLANT : STELLA CHEESE
SUPERIOR MOHAWK BOILER

RUN NO.: 2
DATE : JULY 30, 1993

STANDARD TEMP.: 60 DEG. F

METER TEMP.	=	97.5 DEG. F		STATIC PRESS.	=	0.15 in. H2O
STACK TEMP.	=	338.81 DEG. F		Cp	=	0.840
SQ. RT. dP	=	0.4983 in. H2O		STACK I.D.	=	26.00 inch
METER ORIFICE	=	3.00 in. H2O		DUCT LENGTH	=	inch
METER VOLUME	=	26.818 Cu.Ft.		DUCT WIDTH	=	inch
METER Y	=	1.0053		STACK AREA	=	3.687 Sq.Ft.
BAR. PRESSURE	=	30.18 in.Hg		TEST TIME	=	30.00 min.
COND. (Vlc)	=	123.7 ml		NOZZLE DIA.	=	inch

GAS ANALYSIS	:	2.46 % O2		0.00 % CO
		10.33 % CO2		87.21 % N2

Sq.Ft.

$$Vm(std) = \left[\frac{T(std) + 460}{29.92} \right] \times Vm \times Y \times \frac{(Pb + (dH / 13.6))}{(Tm + 460)} \dots\dots = 25.551 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic = 5.734 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots = 0.183 \text{ | Lower Bws value used.}$$

Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 11.96$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.75$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots = 27.60$$

$$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots = 30.19 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots\dots\dots = 35.04 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots\dots\dots = 7,751 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots\dots\dots = 4,158 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) = *$$

SOURCE TEST CALCULATIONS

PLANT : STELLA CHEESE
SUPERIOR MOHAWK BOILER

RUN NO.: 3
DATE : JULY 30, 1993

STANDARD TEMP.: 60 DEG. F

METER TEMP.	=	101.18 DEG. F		STATIC PRESS.=	0.16 in. H2O
STACK TEMP.	=	338.25 DEG. F		Cp	= 0.840
SQ.RT. dP	=	0.5012 in. H2O		STACK I.D.	= 26.00 inch
METER ORIFICE	=	3.00 in. H2O		DUCT LENGTH	= inch
METER VOLUME	=	26.826 Cu.Ft.		DUCT WIDTH	= inch
METER Y	=	1.0053		STACK AREA	= 3.687 Sq.Ft.
BAR. PRESSURE	=	30.21 in.Hg		TEST TIME	= 30.00 min.
COND. (Vlc)	=	122.7 ml		NOZZLE DIA.	= inch

GAS ANALYSIS :	2.46 % O2	0.00 % CO
	10.52 % CO2	87.02 % N2

Sq.Ft.

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots\dots = 25.416 \text{ dscf}$

$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic = 5.688 \text{ scf}$

$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots = 0.183$ | Lower

Bws @ Saturated Conditions = Vapor Press. of H2O | Bws
@ Dew Point Temp. / (Ps, in.Hg.) | value
= 1.000 | used.

$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 11.99$

$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.78$

$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots = 27.63$

$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots = 30.22 \text{ in. Hg}$

$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots\dots\dots = 35.19 \text{ ft/sec}$

$Qs = vs \times As \times 60 \dots\dots\dots = 7.785 \text{ acf/min}$

$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots\dots\dots = 4,186 \text{ dscf/min}$

$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) = \%$

FUEL / FLOWRATE CALCULATIONS

PLANT STELLA CHEESE
 SOURCE SUPERIOR MOHAWK BOILER
 DATE JULY 30, 1993
 Temp. Std.: 60
 Press. Std: 29.92

FUEL FLOWRATE DATA :

	RUN 1	RUN 2	RUN 3
Barometric Press., in.Hg..	29.92	29.92	29.92
Brake Horsepower			
Fuel Flow, scfh			
Oxygen, %	2.58	2.46	2.46
Fuel Flow, acfh	26631.00	25006.00	25400.00
Fuel Press, psig	0.00	0.00	0.00
" " psia	14.70	14.70	14.70
Fuel Temp, dF	87.40	88.80	90.00

FUEL ANALYSIS DATA :

	RUN 1	RUN 2	RUN 3
Btu/scf, Gross Cal. Value:	1069.00	1069.00	1069.00
Btu/lb, Gross Cal. Value :	22596.00	22596.00	22596.00
Hydrogen, Wt.% :	23.08	23.08	23.08
Carbon, Wt.% :	73.25	73.25	73.25
Sulfur, Wt.% :	0.00	0.00	0.00
Nitrogen, Wt.% :	1.18	1.18	1.18
Oxygen, Wt.% :	2.49	2.49	2.49

CALCULATIONS :

	RUN 1	RUN 2	RUN 3	AVERAGE
F-Factor, dscf/MMBtu :	8,503.60	8,503.60	8,503.60	8,503.60
Fuel Rate, scfh :	25291.10	23687.28	24008.01	24328.80
Heat Rate, MMBtu/hr :	27.036	25.322	25.665	26.007
Flue gas flowrate, dscfm :	4371.37	4067.52	4122.60	4187.16

$$* \text{ F-Factor} = 10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(T_{std} + 460) / 528]$$

$$* \text{ scfh} = \text{fuel acfh} \times [P_b + (P, \text{psig} \times 2.036 \text{ in.Hg/psi}) / (T_{\text{fuel}} + 460)] \times [(T_{std} + 460) / P_{std}]$$

where: psig = psia - 14.7

$$* \text{ MMBtu/hr} = \text{scfh} \times (\text{Btu/scf}) / 10E6$$

$$* \text{ dscfm} = \text{MMBtu/hr} \times \text{dscf/MMBtu} \times (1\text{hr}/60\text{min}) \times [20.9 / (20.9 - \%O_2)]$$

EMISSION RATE CALCULATIONS

PLANT : STELLA CHEESE
SOURCE : SUPERIOR MOHAWK BOILER

Temp. Std. : 60 dF
Press. Std.: 29.92 in. Hg. 3 % O2 Correction

Run No.	1	2	3	AVERAGE
Date	7/30/93	7/30/93	7/30/93	
Oxygen (%)	2.58	2.46	2.46	2.50
Qs(std), dscfm	4,221	4,158	4,186	4,188
NOx, ppm	28.73	28.17	29.73	28.88
SO2, ppm				
CO, ppm	4.18	4.42	7.57	5.39
HC, ppm				
F-Factor	8503.60	8503.60	8503.60	8503.60

NOx, MW = 46.005				
NOx, lb/hr	0.88	0.85	0.91	0.88
NOx, ppm @ O2	28.07	27.35	28.86	28.09
NOx, lb/MMBtu	0.0338	0.0329	0.0348	0.0338

SO2, MW = 64.058
SO2, lb/hr
SO2, ppm @ O2
SO2, lb/MMBtu

CO, MW = 28.010				
CO, lb/hr	0.08	0.08	0.14	0.10
CO, ppm @ O2	4.09	4.29	7.35	5.24
CO, lb/MMBtu	0.0030	0.0031	0.0054	0.0038

HC, MW = 16.043
HC, lb/hr
HC, ppm @ O2
HC, lb/MMBtu

$$* \text{ lb/hr} = 8.223\text{E-}5 \times \text{Qs(std)} \times \text{MW} \times \text{ppm} / (\text{Tstd} + 460)$$

$$* \text{ ppm @ O2} = \text{ppm measured} \times [(\text{20.9} - \text{O2\% correction}) / (\text{20.9} - \text{\%O2 measured})]$$

$$* \text{ lb/MMBtu} = \text{F-Factor} \times \text{MW} \times [1.3711\text{E-}6 / (\text{Tstd} + 460)] \times [\text{20.9} / (\text{20.9} - \text{O2\%})] \times \text{ppm}$$

$$* \text{ lb/Bbl} = (\text{lb/MMBtu}) \times (\text{MMBtu/Bbl})$$

DRY GAS METER / ORIFICE METER CALIBRATION DATA

DateMAY 10, 1993

Bar. Press, in.Hg 28.00

Meter Box No. 21314

Dry Gas Meter No. 658977

Standard Test Meter # 2409881

Operator JM

STANDARD TEST METER			DRY TEST METER				Time t (min)
Press. dHs (in. H2O)	Temp. Ts (dF)	Volume Vs (ft3)	Press. dH (in. H2O)	Temp. Tdi (dF)	Temp. Tdo (dF)	Volume Vd (ft3)	
-1.0	76.0	974.337	0.5	81	80	895.138	56.0
	77.0	951.976		80	76	872.900	
Avg/Net :	76.5	22.361			79	22.238	
-1.5	77.0	951.842	1.0	80	76	872.763	51.0
	72.0	924.178		72	72	845.421	
Avg/Net :	74.5	27.664			75	27.342	
-2.0	74.0	923.744	1.5	77	76	845.009	42.0
	73.0	895.830		78	75	817.256	
Avg/Net :	73.5	27.914			77	27.753	
-2.9	74.0	895.640	2.0	77	75	817.088	32.0
	71.0	871.492		77	76	793.200	
Avg/Net :	72.5	24.148			76	23.888	
-3.4	74.0	871.100	3.0	78	76	792.800	25.0
	72.0	848.087		78	75	770.161	
Avg/Net :	73.0	23.013			77	22.639	

$$y = V_s \times (P_{bar} + (dH_s / 13.6)) \times (Avg. T_d + 460) / [V_d \times (P_{bar} + (dH / 13.6)) \times (T_s + 460)]$$

$$K_o = [(V_s/t) \times [(T_{do} + 460) / (T_s + 460)] \times [(P_{bar} + (dH_s/13.6)) / (P_{bar} + (dH/13.6))] / [((T_{do} + 460) \times dH) / (P_{bar} + (dH/13.6))] \times (Mm)]^{0.5}$$

dH :	0.5	1.0	1.5	2.0	3.0	Avg.	Std.Dev.
y :	1.0067	1.0061	1.0022	1.0050	1.0067	1.0053	0.0017
Ko :	0.6929	0.6643	0.6654	0.6536	0.6487	0.6650	0.0153
y :	0.17 % Relative Std. Dev.						
Ko :	2.31 % Relative Std. Dev.						



6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (714) 653-6780 • FAX (714) 653-2430

REPORT OF ANALYSIS
EPA PROTOCOL GAS MIXTURES

STEIØ1

TO:

SUE POWERS
STEINER ENVIRONMENTAL
4930 BOYLAN ST
BAKERSFIELD, CA 93308-

DATE : 03/30/93

CUSTOMER ORDER NUMBER: SP-2750-90REL92

PAGE 1

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA	
CYLINDER NO.: CC28647						
Nitric Oxide	86.2 ± 0.9 ppm	GMIS	Monitor Labs Model 8440 S/N 136	03/29/95	03/19/93	03/29/93
NOx	86.2 ppm	Cylinder #	Continuous		85.2 ppm	86.3 ppm
Nitrogen, O2-Free Balance		CC106651	Chemiluminescence		86.3 ppm	86.0 ppm
Cylinder Pressure: 2000 psig		@ 98.9 ppm	Last Cal Date: 01/12/93		86.3 ppm	86.1 ppm
					Mean: 86.3 ppm	86.0 ppm
CYLINDER NO.: CC104180						
Nitric Oxide	85.6 ± 0.9 ppm	GMIS	Monitor Labs Model 8440 S/N 136	03/29/95	03/19/93	03/29/93
NOx	85.6 ppm	Cylinder #	Continuous		85.5 ppm	85.8 ppm
Nitrogen, O2-Free Balance		CC106651	Chemiluminescence		85.2 ppm	85.8 ppm
Cylinder Pressure: 2000 psig		@ 98.9 ppm	Last Cal Date: 01/12/93		85.2 ppm	85.7 ppm
					Mean: 85.3 ppm	85.8 ppm

$$\text{ppm} = \text{umole/mole}$$

3 = mole-3

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.

Analyst:

S. B. Kozy

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

A-25
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

REPORT OF ANALYSIS
EPA PROTOCOL GAS MIXTURES

STEIØ1

TO:

Sue Powers
Steiner Environmental Services
4930 Boylan Street
Bakersfield, CA 93308-

DATE : 01/26/93

CUSTOMER ORDER NUMBER: SP-2750-90REL83

PAGE 1

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA	
CYLINDER NO.:	CC42657					
Carbon Monoxide	87.5 ± 0.9 ppm	GMIS	Carle Insts Model 8800 S/N 8249	01/25/96	01/18/93 87.4 ppm	01/25/93 87.3 ppm
Nitrogen	Balance	Cylinder #	Methanation/FID		87.8 ppm	87.2 ppm
Cylinder Pressure:	2000 psig	CC81223	Gas Chromatography		87.7 ppm	87.3 ppm
		@ 100.5 ppm	Last Cal Date: 11/27/92		Mean: 87.5 ppm	87.3 ppm

CYLINDER NO.: CC81148					
Carbon Monoxide	86.2 ± 0.9 ppm	GMIS	Carle Insts Model 3000	01/19/93	01/25/93
			S/N 8249	01/25/96	86.1 ppm
Nitrogen	Balance	Cylinder #	Methanation/FID		85.9 ppm
Cylinder Pressure: 2000 psig		CC81223	Gas Chromatography		86.2 ppm
		@ 100.5 ppm	Last Cal Date: 11/27/92	Mean: 86.1 ppm	86.3 ppm

CYLINDER NO.: CC60194					
Carbon Monoxide	5.22 ± 0.10 ppm	GMIS	Carle Insts Model 8000	01/13/93	01/20/93
			S/N 8249	01/20/96	5.18 ppm
Nitrogen	Balance	Cylinder #	Methanation/FID		5.19 ppm
		CC163	Gas Chromatography		5.24 ppm
Cylinder Pressure: 2000 psig		@ 9.82 ppm	Last Cal Date: 11/27/92	Mean: 5.20 ppm	5.24 ppm

ppm = umole/mole % = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.

Analyst: Mark Monson
M.J. Monson

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

A-26
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS


REPORT OF ANALYSIS
NIST TRACEABLE GAS MIXTURES

STEIØ1

TO:

SUE POWERS
STEINER ENVIRONMENTAL INC
4930 BOYLAN ST
BAKERSFIELD, CA 93308-

DATE: 06/03/93



CUSTOMER ORDER NUMBER: SP-2750-90 R.94 / Reanalysis

PAGE 1

[illegible]

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC7472	Nitrogen Dioxide	38.3 ± 0.8 ppm	SRM 2627
	Nitrogen	Balance	
	Cylinder Pressure:	1000 psig	
CC40344	Carbon Monoxide	48.1 ± 0.5 ppm	SRM 2614a
	Carbon Dioxide	10.27 ± 0.10 %	SRM 1675b
	Oxygen	8.55 ± 0.09 %	SRM 2658a
	Nitrogen	Balance	
	Cylinder Pressure:	1700 psig	

$$\text{ppm} = \text{umole/mole}$$

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above.

Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

alyst:

M.S. Calhoun

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.



6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (714) 653-6780 • FAX (714) 653-2430

REPORT OF ANALYSIS
NIST TRACEABLE GAS MIXTURES

STEIØ1

TO:

SUE POWERS
STEINER ENVIRONMENTAL
4930 BOYLAN ST
BAKERSFIELD, CA 93308-

DATE: 03/30/93

CUSTOMER ORDER NUMBER: SP 2750 90 R.86

PAGE 1

XX

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC114765	Carbon Dioxide	$8.39 \pm 0.08 \%$	SRM 1674b
	Oxygen	$2.591 \pm 0.026 \%$	SRM 2657
	Nitrogen	Balance	
CC50645	Carbon Dioxide	$8.15 \pm 0.08 \%$	SRM 1674b
	Oxygen	$10.73 \pm 0.11 \%$	SRM 2658a
	Nitrogen	Balance	
CC50006	Carbon Dioxide	$15.82 \pm 0.16 \%$	SRM 1675b
	Oxygen	$4.06 \pm 0.04 \%$	SRM 2658a
	Nitrogen	Balance	

$$\text{ppm} = \text{umole/mole}$$

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

analyst:

M.S. Calhoun

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

A-28
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

APPENDIX B
BOILER OPERATING DATA

Steiner Environmental, Inc.

UNIT OPERATING DATA	
Company Name: <u>STELLA Cheese</u>	Date: <u>7-30-93</u>
Unit Tested: <u>Boiler</u>	Barometric Pressure ("Hg): <u>30.20</u>
Manufacturer & Model No.: <u>Low Max Superior Mohawk Boiler</u>	Dry Bulb Temp (°F): <u>83 89 92</u>
Type of Pollution Control Device: <u>4-3753 FGR</u>	Wet Bulb Temp (°F): <u>69 70 70</u>

BOILER/HEATER DATA	RATED	ACTUAL		
		Run #1	Run #2	Run #3
Steam Flow (lb/hr)				
Steam Pressure (psi)	<u>Venting</u>	<u>50</u>	<u>45</u>	<u>45</u>
Heat Input (MMBtu/hr)	<u>31.5</u>			
Product Throughput (barrels/day)				

INTERNAL COMBUSTION ENGINE DATA	RATED	ACTUAL		
		Run #1	Run #2	Run #3
Brake Horsepower (BHP)				
Kilowatts (KW)				
Revolutions Per Minute (RPM)				

GAS TURBINE DATA	RATED	ACTUAL		
		Run #1	Run #2	Run #3
Megawatts (MW)				
Water/Fuel Ratio				
Combustor Inlet Pressure (psi)				

BATCH PLANT DATA	RATED	ACTUAL		
		Run #1	Run #2	Run #3
Charge/Process Rate				
Pull Rate				

FUEL DATA		ACTUAL		
		Run #1	Run #2	Run #3
Fuel Usage	<u>CFH (corrected)</u>	<u>26631</u>	<u>25006</u>	<u>25400</u>
Fuel Temperature *	<u>°F</u>	<u>87.4</u>	<u>88.8</u>	<u>90.0</u>
Fuel Pressure *	<u>PSIG</u>	<u>32</u>	<u>32</u>	<u>33</u>

* Not required if fuel usage is at standard conditions.

Forms 1A: UNIT-OP.DAT

Note: the gas meter reading in CFH (corrected) the "corrected" refers to pressure only