

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

E. & J. GALLO WINERY

Modesto, California

October 2, 1992

**Mr. Simeon Bugay
San Joaquin Valley Unified APCD
1999 Tuolumne St., Suite 200
Fresno, CA 93721**

Dear Mr. Bugay,


We have completed the burner retrofit project at Gallo Winery, Fresno that is described in Authority To Construct #3030140101, #3030140104, #3030140105, and #3030140106. Source tests have been conducted and were observed by Jovencio Refuerzo, a representative of the SJVUAPCD. Results of those source tests are enclosed.

Please arrange for a final inspection of the project in order that we may obtain a Permit to Operate.

If you need anything further, please contact me at (209) 579-4217.

Sincerely,

E. & J. Gallo Winery


**Dave Wolf
Project Manager**

**cc: B. Slayton
J. Stout
J. Fraga**

GALLO WINERY

**Fresno Plant
Boilers #1, #2, #3. & #4
Emissions Compliance Testing
Test Dates: April 30,
May 18 & 19, 1992**

*Source Tests results
for the retrofit of
the above Boilers.
E.J. Gallo, requests
that their PtoD's be
issued.*

BEST ENVIRONMENTAL, INC.

15890 Foothill Boulevard
San Leandro, California 94578

(510) 278-4011 FAX (510) 278-4018

June 3, 1992

Gallo Winery
P.O. Box 1130
Modesto, CA 95353

To: Mr. Dave Wolf

Subject: Compliance Emissions Testing on boilers #1, #2, #3 & #4

Test Date: April 30, May 18 & 19, 1992.

Sampling Location: Outlet stacks of boilers #1, #2, #3 & #4 located at the Gallo Winery facility in Fresno, CA.

Sampling Personnel: Sherman Smith, Tracy Prevo and Dan Ashlin of BEST ENVIRONMENTAL.

Observing Personnel: Jovencio Refuerzo of the Fresno County Air Pollution Control District.

Test Program: Boiler emissions were continuously monitored for CO, O₂, CO₂, Total Hydrocarbons (THC), Total Non-Methane Hydrocarbons (TNMHC) and NO_x concentration for three 40 minute periods with calibrations done before and after each test. Volumetric flowrate was calculated using fuel rate information provided by the plant gas meter. Traverses were performed only on boiler #2 to validate the flowrate calculated by fuel usage. Traverses were not performed on the other boilers due to poor access and/or inadequate port distance from upstream disturbances.

Sampling Methods: The following Source Test Methods of the US Environmental Protection Agency (EPA) and California Air Resources Board (CARB) were used:

EPA Method 19 Flowrate Determination By Fuelrate

Method 1-100 NO_x, O₂, CO₂, THC, and CO

Method 1-4 Volumetric Flowrate Determination

New Address!!!!!!

BEST ENVIRONMENTAL

15890 Foothill Boulevard

San Leandro, CA 94578

(510) 278-4011 Fax (510) 278-4018

Date: 10/7/92

Job: _____

From: Canig ThiryTo: Gary MartinCompany: SJV UAPCDFax #: (209) 233-2057

Comments: I just talked with Sherman Smith.
The traverse that was completed on boiler
#2 was done approximately 6" above the
economizer. It is not hard to get a 20°
variation when the sampling location that
is available does not even meet the minimum
criteria for traverse location. This is why we
believe the flourate from fuelvate was the most
accurate data we collected.

DISREGARD THE REST, GO WITH BEST!!!!Total # pages = 1 (including cover sheet)Original Being Mailed Yes No ☒

STACK VOLUMETRIC FLOWRATE DETERMINATION

Date 4-30-92 client Gallo (Fresno) Operators SS/DA
 Time 12:30 Barometric (Pb) _____ Static _____
 Location Boiler #2 O-kt Pressure 29.34 Pressure -.04
 Pitot Factor .84 Stack/Duct dimen. 58.5" ID. _____
 CO2% 10.1 Stack Area (As) 28.66
 O2% 2.3 Round duct = $\pi r^2 \times 144$ (radius in inches)
 H2O% 16.2

Velocity Traverse Data

Remarks _____

Port ID & Pnt#	Inches f.wall w/port	Time	Delta P	Stack Temp	sqrt. "P
1	4.17		.24	330°	.583
2	4.4		.45		.648
3	10.4		.56		.632
4	12.7		.39		.583
5	14.1		.27		.520
6	24.3		.19		.436
7	46.8		.18		.416
8	47.8		.10		.316
9	51.6		.12		.346
10	53.1		.17		.412
11	58.1		.17		.412
12	60.8		.15		.387
1			.43	332°	.656
2			.45		.671
3			.47		.686
4			.38		.616
5			.33		.574
6			.28		.529
7			.15		.387
8			.11		.300
9			.33		.574
10			.38		.616
11			.40		.632
12			.42		.648
Averages					.523

Stack Gas Velocity
 @ Stack conditions
 (foot per second)

$$V_s = 85.49 \times (C_p) \times \sqrt{p_{avg.}} \times \sqrt{[T_{savg} \times 460 / P_{savg} \times M_w]}$$

Where,

Vs-velocity stack
 Cp-pitot factor
 Ts-Stack Temperature
 Ps-Stack pressure
 Mw=Molecular Wt.gas

where,

$$M_w = M_{wd} \times (1 - B_{wo}) + 18(B_{wo})$$

$$M_{wd} = .44(\%CO_2) + .32(\%O_2) + .28(\%CO + \%N_2)$$

$$B_{wo} = \%moisture / 100$$

$$P_s = static / 13.6 + P_b$$

Stack Gas Volume at
 Standard Conditions
 Qs = SDCFM

$$Q_s = 60(1 - B_{wo}) \times V_{savg} \times A_n \times (528 / T_{savg} \times 460) \times (P_s / 29.92)$$

MW=

Vs= 36 761

Qs= 22,811.6

19,182.5 by fuel rate

Notes/Comments Does not meet 8/2 criteria

New Address!!!!!!

BEST ENVIRONMENTAL

15890 Foothill Boulevard

San Leandro, CA 94578

(510) 278-4011 Fax (510) 278-4018

Date: 10/7/92

Job: _____

From: Craig ThiryTo: Gary MartinCompany: STVUAPCPFax #: (209) 233-2057Comments: Traverse sheet follows in fileOur normal operating procedure is to include all data in the appendix. This should have been included.I have contacted Eric Bettemann at M. W. Malmgren who was on site at this testing site. You will probably be hearing from him.Please keep me informed of your decision on the sampling program.**DISREGARD THE REST, GO WITH BEST!!!!**Total # pages = 2 (including cover sheet)Original Being Mailed Yes _____ No ✓

Instrumentation:

Horiba Model PIR-2000 CO2 Analyzer

Thermal Electron Model 48 CO Analyzer

Thermal Electron Model 10 NOx Analyzer

Combustion Eng. Model 8214TM Total Hydrocarbon Analyzer


Teledyne Model 326RA O2 Analyzer

Test Results: Tables 1 thru 4 presents the results of the compliance emissions testing. The summary table presents the results of all boilers and also includes the heat input of each boiler during the test period. The comparison of the pitot traverse and the volumetric flowrate calculated by fuel usage showed a variance of 18.9%. The difference can be attributed to significant flow variations observed during each point during the traverse. The fuel rate was deemed the most accurate and was used to calculate stack volumetric flowrate and pounds per hour for each boiler.

Field data sheets, calculations, strip chart recordings and calibration gas certifications are appended to this report.

If there are any questions concerning this report, please contact Craig Thiry or myself at (510)278-4011.

Submitted by,


Sherman Smith
Project Manager

Reviewed by,


Craig Thiry
Operations Manager

Table 1

Gallo Winery - Fresno**Unit #1****Emissions Test Results**

TEST	1	2	3	AVERAGE
TEST LOCATION	OUTLET	OUTLET	OUTLET	
TEST DATE	5/19/92	5/19/92	5/19/92	
TEST TIME	1122-1202	1238-1318	1328-1408	
FLOWRATE, SDCFM	9920.3	9999.6	9963.0	9961.0
O ₂ , %	2.8	2.9	2.8	2.8
CO ₂ , %	10.65	10.2	10.25	10.4
H ₂ O, %	16.6	16.5	16.5	16.5
NO _x , ppm	21.0	21.4	21.6	21.3
NO _x , ppm (@3% O ₂)	20.8	21.3	21.4	21.1
NO _x , lbs/mmBTU	0.025	0.026	0.026	0.026
NO _x , lbs/hr	1.495	1.536	1.544	1.525
CO, ppm	154.0	149.4	165.0	156.1
CO, ppm (@3% O ₂)	152.3	148.6	163.2	154.7
CO, lbs/mmBTU	0.113	0.110	0.121	0.114
CO, lbs/hr	6.673	6.526	7.181	6.793
THC, ppm	53.5	18.4	22.4	31.4
TNMHC, ppm	5.0	<1.0	<1.0	<2.3
TNMHC, lbs/mmBTU	0.0021	<0.0004	<0.0004	<0.0010
TNMHC, lbs/hr	0.124	<0.025	<0.025	<0.058

WHERE,NO_x = Oxides of NitrogenCO₂ = Carbon Dioxide

CO = Carbon Monoxide

TNMHC = Total Non-methane Hydrocarbon

lbs/mmBtu = Pounds per Million Btu

ppm = Parts Per Million Concentration

lbs/hr = Pound Per Hour Emission Rate

F = 8740 (EPA F Factor for Natural Gas)

CALCULATIONS,3% correction = $(17.9/(20.9 - O_2\%)) \times \text{ppm of pollutant}$ lbs/hr = $1.56e-7 \times \text{SDCFM} \times \text{ppm} \times \text{Molecular Wgt. of pollutant}$ lbs/mmBtu = $F \times \text{Molecular Wgt.} \times \text{ppm} \times 2.59e-9 \times (20.9/(20.9 - \%O_2))$

Table 2

Gallo Winery - Fresno**Unit #2****Emissions Test Results**

TEST	1	2	3	AVERAGE
TEST LOCATION	OUTLET	OUTLET	OUTLET	
TEST DATE	4/30/92	4/30/92	4/30/92	
TEST TIME	1110-1150	1203-1243	1317-1357	
FLOWRATE, SDCFM	19182.5	19182.5	19182.5	19182.5
O ₂ , %	3.3	3.3	3.3	3.3
CO ₂ , %	10.1	10.2	10.1	10.1
H ₂ O, %	16.2	16.2	16.2	16.2
NO _x , ppm	26.9	25.0	25.6	25.8
NO _x , ppm (@3% O ₂)	27.4	25.4	26.0	26.3
NO _x , lbs/mmBTU	0.033	0.031	0.032	0.032
NO _x , lbs/hr	3.703	3.441	3.524	3.556
CO, ppm	140.3	133.0	115.8	129.7
CO, ppm (@3% O ₂)	142.7	135.3	117.8	131.9
CO, lbs/mmBTU	0.106	0.100	0.087	0.098
CO, lbs/hr	11.756	11.144	9.703	10.867
THC, ppm	4.0	6.0	3.0	4.3
TNMHC, ppm	1.0	2.0	1.0	1.3
TNMHC, lbs/mmBTU	0.0004	0.0009	0.0004	0.001
TNMHC, lbs/hr	0.048	0.096	0.048	0.064

WHERE,NO_x = Oxides of NitrogenCO₂ = Carbon Dioxide

CO = Carbon Monoxide

TNMHC = Total Non-methane Hydrocarbon

lbs/mmBtu = Pounds per Million Btu

ppm = Parts Per Million Concentration

lbs/hr = Pound Per Hour Emission Rate

F = 8740 (EPA F Factor for Natural Gas)

CALCULATIONS,3% correction = $(17.9/(20.9 - O_2\%)) \times \text{ppm of pollutant}$ lbs/hr = $1.56e-7 \times \text{SDCFM} \times \text{ppm} \times \text{Molecular Wgt. of pollutant}$ lbs/mmBtu = $F \times \text{Molecular Wgt.} \times \text{ppm} \times 2.59e-9 \times (20.9/(20.9 - \%O_2))$

Table 3
Gallo Winery - Fresno
Unit #3
Emissions Test Results

TEST	1	2	3	AVERAGE
TEST LOCATION	OUTLET	OUTLET	OUTLET	
TEST DATE	5/18/92	5/18/92	5/18/92	
TEST TIME	1205-1245	1257-1337	1410-1450	
FLOWRATE, SDCFM	12477.3	12400.7	12300.0	12392.7
O2, %	3.8	3.8	3.9	3.8
CO2, %	9.3	9.3	9.6	9.4
H2O, %	15.7	15.7	15.7	15.7
NOx, ppm	24.0	24.0	24.0	24.0
NOx, ppm (@3% O2)	25.1	25.1	25.3	25.2
NOx, lbs/mmBTU	0.031	0.031	0.031	0.031
NOx, lbs/hr	2.149	2.136	2.118	2.134
CO, ppm	163.0	165.8	117.5	148.8
CO, ppm (@3% O2)	170.6	173.6	123.7	156.0
CO, lbs/mmBTU	0.126	0.128	0.092	0.115
CO, lbs/hr	8.884	8.981	6.313	8.059
THC, ppm	53.6	55.3	56.5	55.1
TNMHC, ppm	<1.0	<1.0	<1.0	<1.0
TNMHC, lbs/mmBTU	<0.0004	<0.0004	<0.0004	<0.0004
TNMHC, lbs/hr	<0.031	<0.031	<0.031	<0.031

WHERE,

NOx = Oxides of Nitrogen
CO2 = Carbon Dioxide
CO = Carbon Monoxide
TNMHC = Total Non-methane Hydrocarbon
lbs/mmBtu = Pounds per Million Btu
ppm = Parts Per Million Concentration
lbs/hr = Pound Per Hour Emission Rate
F = 8740 (EPA F Factor for Natural Gas)

CALCULATIONS,

3% correction = $(17.9/(20.9 - O_2\%)) \times \text{ppm of pollutant}$
lbs/hr = $1.56e-7 \times \text{SDCFM} \times \text{ppm} \times \text{Molecular Wgt. of pollutant}$
lbs/mmBtu = $F \times \text{Molecular Wgt.} \times \text{ppm} \times 2.59e-9 \times (20.9/(20.9 - \%O_2))$

Table 4

Gallo Winery - Fresno**Unit #4****Emissions Test Results**

TEST	1	2	3	AVERAGE
TEST LOCATION	OUTLET	OUTLET	OUTLET	
TEST DATE	5/18/92	5/18/92	5/18/92	
TEST TIME	1605-1655	1705-1745	1753-1833	
FLOWRATE, SDCFM	11875.6	11890.7	11912.6	11893.0
O2, %	3.6	3.6	3.6	3.6
CO2, %	9.5	9.45	9.4	9.5
H2O, %	15.9	15.9	15.9	15.9
NOx, ppm	20.0	19.9	20.0	20.0
NOx, ppm (@3% O2)	20.7	20.6	20.7	20.7
NOx, lbs/mmBTU	0.025	0.025	0.025	0.025
NOx, lbs/hr	1.704	1.698	1.710	1.704
CO, ppm	169.0	152.7	154.0	158.6
CO, ppm (@3% O2)	174.9	158.0	159.3	164.1
CO, lbs/mmBTU	0.129	0.117	0.118	0.121
CO, lbs/hr	8.766	7.931	8.013	8.237
THC, ppm	88.6	19.8	21.3	43.2
TNMHC, ppm	<1.0	1.5	<1.0	<1.2
TNMHC, lbs/mmBTU	<0.0004	0.0007	<0.0004	<0.0005
TNMHC, lbs/hr	<0.030	0.045	<0.030	<0.035

WHERE,

NOx = Oxides of Nitrogen

CO2 = Carbon Dioxide

CO = Carbon Monoxide

TNMHC = Total Non-methane Hydrocarbon

lbs/mmBtu = Pounds per Million Btu

ppm = Parts Per Million Concentration

lbs/hr = Pound Per Hour Emission Rate

F = 8740 (EPA F Factor for Natural Gas)

CALCULATIONS,3 % correction = $(17.9/(20.9 - O_2\%)) \times \text{ppm of pollutant}$ lbs/hr = $1.56e-7 \times \text{SDCFM} \times \text{ppm} \times \text{Molecular Wgt. of pollutant}$ lbs/mmBtu = $F \times \text{Molecular Wgt.} \times \text{ppm} \times 2.59e-9 \times (20.9/(20.9 - \%O_2))$

Summary Table
Gallo Winery - Fresno
Units 1, 2, 3, & 4
Emissions Test Results

Boiler #	1	2	3	4
TEST LOCATION	OUTLET	OUTLET	OUTLET	OUTLET
TEST DATE	5/19/92	4/30/92	5/18/92	5/18/92
HEAT INPUT, mmBtu/hr	59.1	110.9	69.9	67.5
FLOWRATE, SDCFM	9961.0	19182.5	12392.7	11893.0
O2, %	2.8	3.3	3.8	3.6
CO2, %	10.4	10.1	9.4	9.5
H2O, %	16.5	16.2	15.7	15.9
NOx, ppm	21.3	25.8	24.0	20.0
NOx, ppm (@3% O2)	21.1	26.2	25.1	20.7
NOx, lbs/mmBTU	0.026	0.032	0.031	0.025
NOx, lbs/hr	1.523	3.551	2.134	1.707
CO, ppm	156.1	129.7	148.8	158.6
CO, ppm (@3% O2)	154.4	131.9	155.8	164.1
CO, lbs/mmBTU	0.114	0.098	0.115	0.121
CO, lbs/hr	6.792	10.867	8.055	8.239
THC, ppm	31.4	4.3	5.1	43.2
TNMHC, ppm	<2.3	1.3	<1.0	<1.2
TNMHC, lbs/mmBTU	<0.0010	0.0006	<0.0004	<0.0005
TNMHC, lbs/hr	<0.057	0.062	<0.031	<0.036

WHERE,

NOx = Oxides of Nitrogen, MW = 46
CO2 = Carbon Dioxide
CO = Carbon Monoxide, MW = 28
TNMHC = Total Non-methane Hydrocarbon, measured as CH4, MW = 16
lbs/mmBtu = Pounds per Million Btu
ppm = Parts Per Million Concentration
lbs/hr = Pound Per Hour Emission Rate
F = 8740 (EPA F Factor for Natural Gas)

CALCULATIONS,

3% correction = $(17.9 / (20.9 - O_2\%)) \times \text{ppm of pollutant}$
lbs/hr = $1.56e-7 \times \text{SDCFM} \times \text{ppm} \times \text{Molecular Wgt. of pollutant}$
lbs/mmBtu = $F \times \text{Molecular Wgt.} \times \text{ppm} \times 2.59e-9 \times (20.9 / (20.9 - \%O_2))$

APPENDIX

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

GALLO - Fresno Unit #1

Run 1

Date: 5/19/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	19.67 seconds
Gas Line Pressure(PSIG)	30.1 pounds per square inch
Gas Line Pressure(PSIA)	44.8 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	2.8 %
Gas F-Factor	8740 SDCF/MMBtu
Gas Temperature (degrees F)	50.99 degrees

Realtime Fuel Rate(CFM)	305.0 CFM
Corrected Fuel Rate(SCFM)	945.2 SCFM
Million Btu per minute	0.983 MMBtu/min
Stack Gas Flowrate(SDCFM)	9,920.3 SDCFM
Heat Input (MMBtu/hour)	59.0 MMBtu/HR
Fuel Flowrate (SCFH)	56,710 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBTU/min} \times 60$$

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

**GALLO - Fresno Unit #1
Run 2**

Date: 5/19/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	19.56 seconds
Gas Line Pressure(PSIG)	30.0 pounds per square inch
Gas Line Pressure(PSIA)	44.7 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	2.9 %
Gas F-Factor	8740 SDCF/MMBtu
Gas Temperature (degrees F)	51.93 degrees
Realtime Fuel Rate(CFM)	306.7 CFM
Corrected Fuel Rate(SCFM)	947.5 SCFM
Million Btu per minute	0.985 MMBtu/min
Stack Gas Flowrate(SDCFM)	9,999.6 SDCFM
Heat Input (MMBtu/hour)	59.1 MMBtu/HR
Fuel Flowrate (SCFH)	56,848 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBTU/min} \times 60$$

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

GALLO - Fresno Unit #1

Run 3

Date: 5/19/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	19.5 seconds
Gas Line Pressure(PSIG)	30.0 pounds per square inch
Gas Line Pressure(PSIA)	44.7 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	2.8 %
Gas F-Factor	8740 SDCF/MMBtu
Gas Temperature (degrees F)	52.43 degrees
Realtime Fuel Rate(CFM)	307.7 CFM
Corrected Fuel Rate(SCFM)	949.2 SCFM
Million Btu per minute	0.987 MMBtu/min
Stack Gas Flowrate(SDCFM)	9,963.0 SDCFM
Heat Input (MMBtu/hour)	59.2 MMBtu/HR
Fuel Flowrate (SCFH)	56,955 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBTU/min} \times 60$$

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

GALLO - Fresno Unit #2

Date: 4/30/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	10.57 seconds
Gas Line Pressure(PSIG)	29.8 pounds per square inch
Gas Line Pressure(PSIA)	44.5 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	3.3 %
Gas F-Factor	8740 SDCF/MMBtu
Gas Temperature (degrees F)	42.8 degrees

Realtime Fuel Rate(CFM)	567.6 CFM
Corrected Fuel Rate(SCFM)	1777.2 SCFM
Million Btu per minute	1.848 MMBtu/min
Stack Gas Flowrate(SDCFM)	19,182.5 SDCFM
Heat Input (MMBtu/hour)	110.9 MMBtu/HR
Fuel Flowrate (SCFH)	106,630 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBtu/min} \times 60$$

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

GALLO - Fresno Unit #3

Run 1

Date: 5/18/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	16.47 seconds
Gas Line Pressure(PSIG)	29.9 pounds per square inch
Gas Line Pressure(PSIA)	44.6 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	3.8 %
Gas F-Factor	8740 SDCF/MMBtu
Gas Temperature (degrees F)	51.63 degrees
Realtime Fuel Rate(CFM)	364.3 CFM
Corrected Fuel Rate(SCFM)	1124.1 SCFM
Million Btu per minute	1.169 MMBtu/min
Stack Gas Flowrate(SDCFM)	12,488.5 SDCFM
Heat Input (MMBtu/hour)	70.1 MMBtu/HR
Fuel Flowrate (SCFH)	67,447 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBTu/min} \times 60$$

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

GALLO - Fresno Unit #3

Run 2

Date: 5/18/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	16.61 seconds
Gas Line Pressure(PSIG)	30.0 pounds per square inch
Gas Line Pressure(Psia)	44.7 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	3.8 %
Gas F-Factor	8740 SDCf/MMBtu
Gas Temperature (degrees F)	51.71 degrees

Realtime Fuel Rate(CFM)	361.2 CFM
Corrected Fuel Rate(SCFM)	1116.2 SCFM
Million Btu per minute	1.161 MMBtu/min
Stack Gas Flowrate(SDCFM)	12,400.7 SDCFM
Heat Input (MMBtu/hour)	69.7 MMBtu/HR
Fuel Flowrate (SCFH)	66,973 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBTU/min} \times 60$$

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

GALLO - Fresno Unit #4 Run 1

Date: 5/18/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	17.07 seconds
Gas Line Pressure(PSIG)	29.9 pounds per square inch
Gas Line Pressure(PSIA)	44.6 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	3.6 %
Gas F-Factor	8740 SDCF/MMBtu
Gas Temperature (degrees F)	52.43 degrees

Realtime Fuel Rate(CFM)	351.5 CFM
Corrected Fuel Rate(SCFM)	1081.5 SCFM
Million Btu per minute	1.125 MMBtu/min
Stack Gas Flowrate(SDCFM)	11,875.6 SDCFM
Heat Input (MMBtu/hour)	67.5 MMBtu/HR
Fuel Flowrate (SCFH)	64,888 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBTu/min} \times 60$$

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

GALLO - Fresno Unit #4

Run 2

Date: 5/18/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	17.075 seconds
Gas Line Pressure(PSIG)	29.9 pounds per square inch
Gas Line Pressure(PSIA)	44.6 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	3.6 %
Gas F-Factor	8740 SDCF/MMBtu
Gas Temperature (degrees F)	51.63 degrees

Realtime Fuel Rate(CFM)	351.4 CFM
Corrected Fuel Rate(SCFM)	1082.8 SCFM
Million Btu per minute	1.126 MMBtu/min
Stack Gas Flowrate(SDCFM)	11,890.7 SDCFM
Heat Input (MMBtu/hour)	67.6 MMBtu/HR
Fuel Flowrate (SCFH)	64,970 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBTU/min} \times 60$$

VOLUMETRIC FLOWRATE BY FUEL RATE CALCULATIONS

**GALLO - Fresno Unit #4
Run 3**

Date: 5/18/92

# cubic feet/rev	100 cubic feet
# of seconds/rev	17.074 seconds
Gas Line Pressure(PSIG)	29.9 pounds per square inch
Gas Line Pressure(PSIA)	44.6 pounds per square inch
Gross Calorific Value	1040 Btu / cubic foot
Stack Oxygen	3.6 %
Gas F-Factor	8740 SDCF/MMBtu
Gas Temperature (degrees F)	50.95 degrees

Realtime Fuel Rate(CFM)	351.4 CFM
Corrected Fuel Rate(SCFM)	1084.8 SCFM
Million Btu per minute	1.128 MMBtu/min
Stack Gas Flowrate(SDCFM)	11,912.6 SDCFM
Heat Input (MMBtu/hour)	67.7 MMBtu/HR
Fuel Flowrate (SCFH)	65,090 SCFH

Calculations,

$$\text{SCFM} = (\text{cfm} \times \text{gas line pressure} + 14.7) / 14.7$$

$$\text{MMBTU/MIN} = (\text{SCFM} \times \text{BTU/ft}^3) / 1,000,000$$

$$\text{SDCFM} = \text{Gas F-Factor} \times \text{MMBTU/Minute} \times (20.9 / 20.9 - \text{stack O}_2)$$

$$\text{SCFH} = \text{SCFM} \times 60$$

$$\text{Heat Input} = \text{MMBTu/min} \times 60$$

**BEST ENVIRONMENTAL
CONTINUOUS MONITOR DATA SHEET**

Plant Cello - Friesno
 Date 4-30-92
 Test Location Unit # 2 Stack
 Run Number 1203
 Operator SSP/BA
 Ambient Temperature _____
 Barometric Pressure 29.64
 Static Pressure Duct _____
 Fuel NG Gas
 Number _____

Time	Sample Point	Fuel Flow	Dry Uncorrected						3% O2 Dry		Hydrocarbons			CO2 ppm	VOC ppm	Comments
			O2 %	CO2 %	CO ppm	SO2 ppm	NO ppm	NOx ppm	ppm	NOx ppm	THC	CH4	Non CH4			
1110	end		7.8	12.2	78.2			88.7			88.6					443 ASIA
1115			3.3	10.1	146			26			4.0					
1120			3.3	10.1	112			26.5			4.0					
1123			3.3	10.1	140			26.5			4.0					
1130			3.3	10.1	128			27			4.0	3.0	1.0			
1135			3.3	10.1	156			27			4.0					
1140			3.3	10.1	154			27.0			4.0					100F 10.56
1145			3.3	10.1	150			27.5			4.0					10.60 sec.
1150			3.3	10.1	136			28.0			4.0					10.55
	AUH		3.3	10.1	146.3			26.9			4.0	3.0	1.0			10.56 sec.
	3sec		0	15	0			3.5			.02					14,182.5 sec
	5sec		8.1	12.2	77.6			91.0			91.0					
1203	cell		7.8	10.2	78.2			88.7			86.6					
1208			3.2	10.2	150			25				4.0				
1213			3.2	10.2	124			25				4.0				
1218			3.2	10.2	140			25				4.0				
1223			3.3	10.2	134			25				4.0				
1228			3.3	10.2	122			25				4.0				
1233			3.1	10.2	140			25				4.0				
1238			3.2	10.2	138			25				4.0				
1243			3.3	10.2	118			25			6.0	4.0	2.0			
	AUH		3.3	10.2	133			25.0			6.0	4.0	2.0			
	3sec		0.05	10.1	0			1.0			0					
	5sec		7.8	12.3	78.1			88.0			86.6					

STACK VOLUMETRIC FLOWRATE DETERMINATION

Date 4-30-92 client Gallo (Fresno) Operators SS/DA
 Time 1220 Barometric (Pb) Static
 Location Boiler #2 O-kt Pressure 29.34 Pressure -.04
 Pitot Factor .84 Stack/Duct dimen. 58.5" ID.
 CO2% 10.1 Stack Area (As) 18.665
 O2% 3.3 Round duct = $\pi r^2 \div 144$ (radius in inches)
 H2O% 16.2

Velocity Traverse Data

Remarks

Port ID & Pnt#	Inches f.wall w/port	Time	Delta P	Stack Temp	sqrt. P
1	4.7		.34	330°	.583
2	7.4		.42		.648
3	10.4		.46		.632
4	13.7		.34		.583
5	18.1		.27		.520
6	24.3		.19		.436
7	41.3		.10		.316
8	47.9		.10		.316
9	51.6		.12		.346
10	55.1		.17		.412
11	58.1		.17		.412
12	60.8		.15		.387
1			.43	332°	.656
2			.45		.671
3			.43		.656
4			.38		.616
5			.33		.574
6			.28		.529
7			.15		.387
8			.16		.400
9			.33		.574
10			.38		.616
11			.40		.632
12			.42		.648
Averages					.523

Stack Gas Velocity
 @ Stack conditions
 (feet per second)

$$V_s = 85.49 \times (C_p) \times \sqrt{P} \text{ avg. } \times \sqrt{Ts \text{ avg} \times 460 / Ps \times MWs}$$

Where,

Vs=velocity stack
 Cp=pitot factor
 Ts=Stack Temperature
 Ps=Stack pressure
 MWs=Molecular Wt. gas

where,

$$MWs = MWd \times (1 - Bwo) + 18(Bwo)$$

$$MWd = .44(\%CO_2) + .32(\%O_2) + .28(\%CO + \%N_2)$$

$$Bwo = \%moisture / 100$$

$$Ps = static / 13.6 + Pb$$

Stack Gas Volume at
 Standard Conditions
 $Q_s = SDCFM$

$$Q_s = 60(1 - Bwo) \times V_{s \text{ avg}} \times A_s \times (528 / Ts \text{ avg} + 460) \times (Ps / 29.92)$$

MW=

Vs= 36.761

Qs= 22,811.6

19,182.5 by fuel rate

Notes/Comments

Does not meet 8/2 criteria

**BEST ENVIRONMENTAL
CONTINUOUS MONITOR DATA SHEET**

Plant Callo from Ambient Temperature 78°
 Date 5/19/92 Barometric Pressure _____
 Test Location 884-1 outld Static Pressure Duct _____
 Run Number 1 Fuel _____
 Operator TP, PA Number _____

200 ft fuel in 638 sec = fuel out

Time	Sample Point	Fuel Flow	Dry Uncorrected					3% O ₂ Dry		Hydrocarbons			TOC ppm	CO ₂ ppm	VOC ppm	Comments
			O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	ppm	THC	CH ₄	Non CH ₄				
1115	CAL		8.0	12.12	82.5			58.8		34						
1122			2.8	10.7	140			21.1		36	35	1				
1127			2.7	10.7	137			21.1		36						
1132			2.7	10.7	163			20.8		50						
1137			2.7	10.7	172			20.5		70						
1142			2.7	10.7	170			20.5		72						
1147			3.0	10.6	165			21.0		69	60	9				
1152			2.9	10.6	165			21.0		66						
1157			2.9	10.5	120			22.5		89						
1202			(2.8/10.6/151.0)					(21.0)		(53.5)						
	AVG		3	6	3			8		-1.0						
	CHL		8.0	12.1	82.1			87		84						
	ADY			12.2	82.6			87.6								

**BEST ENVIRONMENTAL
CONTINUOUS MONITOR DATA SHEET**

Plant Gallo Lagoon Ambient Temperature _____
 Date 5/19/92 Barometric Pressure _____
 Test Location Blk #1 out Static Pressure Duct _____
 Run Number 2 Fuel _____
 Operator TP, DA Number _____

Time	Sample Point	Fuel Flow	Dry Uncorrected						3% O2 Dry			Hydrocarbons			TOC ppm	CO2 ppm	VOC ppm	Comments
			O2 %	CO2 %	CO ppm	SO2 ppm	NO ppm	NOx ppm	ppm	ppm	NOx ppm	THC	CH4	Non CH4				
1205	CAL		8.0	12.2	82.6			88.6				87						
1238			2.8	12.2	155			21.2				19						
1243			2.8	10.2	165			21.0				24						
1248			2.9	10.2	155			21.0				23	23	<1				
1253			2.9	10.2	150			21.0				23						
1258			3.0	10.2	125			28.0				22						
1303			2.8	10.2	145	NS		22.0				11						
1308			2.8	10.2	145			21.8				12						
1313			3.0	10.2	155			21.0				13						
1318			2.9	10.2	149.47			21.47				28.47						
	AVG		2.9	10.2	149.47			21.47				28.47						
	2010		2.8	10.2	149.47			21.47				28.47						
	CAL		8.0	12.2	81.6			87				82						
	2010		8.0	12.2	81.6			87				82						
	2010		8.0	12.2	81.6			87				82						

Plant Calla Lemo
Date 5/19/92
Test Location Bldg #1 out
Run Number 3
Operator P. Ch

Ambient Temperature _____
Barometric Pressure _____
Static Pressure Duct _____
Fuel _____
Number _____

[illegible]

Env page 544-7625 #111

BEST ENVIRONMENTAL
CONTINUOUS MONITOR DATA SHEET

Plant Gallo - Fresno Ambient Temperature _____
Date 5/18/92 Barometric Pressure _____
Test Location Unit #3 Stack Static Pressure Duct _____
Run Number 1, 2 Fuel Natl Gas
Operator TP, DA Number Horiba CO

Time	Sample Point	Fuel Flow	Dry Uncorrected					3% O2 Dry			Hydrocarbons			TOC ppm	CO2 ppm	VOC ppm	Comments
			O2 %	CO2 %	CO ppm	SO2 ppm	NO ppm	NOx ppm	ppm	ppm	THC	CH4	Non CH4				
1200	CAL		3.7	12.8	401			88			85						
1205			3.9	9.3	169			240			54						
1210			3.8	9.3	157			238			54	54	<1				
1215			3.8	9.3	164			239			54						
1220			3.7	9.7	165			240			55						
1225			3.9	9.3	140			238			55	55	<1				
1230			3.8	7.3	168			240			54						
1235			3.9	7.3	154			241			52						
1240			3.8	9.3	170			240			51	51	<1				
1245	Avg		3.87	9.37	1637			244.7			53.67						
1250	Std		3.9	9.3	145			24			54						
1255			3.9	9.3	161.1			24			52						
1300			3.9	9.3	156.4			24			53						
1305			3.8	9.3	167			24			55						
1312			3.7	9.3	167			24			56	56	<1				
1317			3.7	9.3	172.8			24			55						
1322			3.8	9.3	172.8			24			57						
1327			3.8	9.3	172			24			58						
1332			3.8	9.3	170			24			58						
1337	Avg		3.87	9.37	165.87			241.7			55.37						
	Std							24			1.0						
	Cal							88			82						

Ambient Temperature _____
Barometric Pressure _____
Static Pressure Duct Not Used
Fuel _____
Number TF0000

Time	Sample Point	Fuel Flow	Dry Uncorrected						3% O ₂ Dry		Hydrocarbons			TOC ppm	CO ₂ ppm	VOC ppm	Comments
			O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	ppm	ppm	THC	CH ₄	Non CH ₄				
1400	CAL		7.9	12.12	82.7				88			84					
1410			8.9	9.6	9.18				24			59					
1415			8.9	9.6	118				24			54					
1420			8.9	9.6	120				24			56					
1425			8.9	9.6	112				24			54					
1430			8.9	9.6	122				24			56	<1				
1435			8.9	9.6	120				24			56					
1440			8.9	9.6	118				24			57					
1445			8.9	9.6	115				24			56					
1450	Avg		(8.9)	(9.6)	(117.5)				(84.0)			(51.5)					
ZERO			9	9	9				0			-05					
CAL			8.0	12.2	80.7				88.4			86					

Plant Gallo Fresno
Date 5/18/92
Test Location Unit # 4, Shop
Run Number 1, 2
Operator TP, PA

Ambient Temperature _____
 Barometric Pressure _____
 Static Pressure Duct _____
 Fuel _____
 Number _____

[illegible]

BEST ENVIRONMENTAL
CONTINUOUS (ITOR) DATA SHEET

Plant Cello Trumo Ambient Temperature _____

Date 5/18/92 Barometric Pressure _____

Test Location Unit #4 Outlet Static Pressure Duct _____

Run Number 2 Fuel _____

Operator TP, DA Number _____

0.914 m/min

Time	Sample Point	Fuel Flow	Dry Uncorrected					3% O2 Dry		Hydrocarbons			TOC ppm	CO2 ppm	VOC ppm	Comments
			O2 %	CO2 %	CO ppm	SO2 ppm	NO ppm	NOx ppm	ppm	ppm	THC	CH4	Non CH4			
1700	CAL		8.0	12.12	82.6			29.3			86					
1705			3.6	9.5	150.8			20			20					
1710			3.5	9.5	155.1			20			20					
1715			3.6	9.5	153.6			20			20					
1720			3.6	9.5	155.4			20			20	18.5	1.5			
1725			2.5	9.4	155.4			20			19					
1730			3.6	9.4	150.8			19.8			19					
1735			3.6	9.4	149.0			19.8			20					
1740			3.6	9.4	150.9			19.8			20					
1745			3.6	9.4	152.7			19.9			19.8					
	AVG		3.6	9.4	152.7			19.9			19.8					
	Zero		0	0	0			0			-1.0					
	Cal		8.0	12.1	82.6			27			22					
	Adj							88			84					

Ambient Temperature _____
Barometric Pressure _____
Static Pressure Duct _____
Fuel _____
Number _____

0.91974

[illegible]

Run 1

1130

1120

1110

110

80

70


60

50


78.7 ppm CO

Blue - CO 8/200 mag
Red - O₂ 8/100 to mag

Galileo - Extern
4-30-92
Unit #2



78.7 ppm CO



12.820.02

12.78.00 CO

12.38

12.33

12.23

12.13

12.03 cont v2

12.02.02

12.01.02

12.01

12.32

12.23

12.13

12.03

12.02.02

12.01.02

12.01

7.8800

7.7800

1317

1352

1347

1337

1327

78.2400


SWAT #3

1317

Run 3

Barter #4

Not tested



8/7/92
TMC

Run 1

See TMC 0/100 m/s

Collo. Fresno

4-30-92

Unit 2

1110

300

2011
7/12

7-21-11
9/11/11

Page 2

-1203

FHK

10/11/11

1-81.5 gpm
1/100

1-81.5 gpm
1/100




1-81.5 gpm
1/100

Run 3



1-1517 2/15/17

1-1517 2/15/17

100
100
100
100



Run



3-12-2002
11:22:00

3000

3000 CO2


Unit #2

Blue - 100% O2
Red - CO2 O/15%


Gold - Frasco Unit #2


4-30-92





Boiler #4
not
good








MADE IN CANADA

CHART NO. 59001

ESTERLINE ANGUS INDIANAPOLIS, IND., U.S.A.





✓
B.D. #1

✓
B.D. #3
Xtra

Call B.D. #1 for


1595

4765 0-10047

No. 1210
Start Run 1210
1205

Boiler #3

THC 0-300 scale





THC 0-100 scale
1125

THC 0-300 scale



THC 0-100 scale
1125
0-100

Gallo Winery 5/1/12



Start of
8:00 PM

Normal
8:00 PM


Start
8:00 PM

10:00 PM

11:00 PM

12:00 AM

1:00 AM



1755

1735

1725

1715

1705

1705

TR 0-100 ft

Start Run 2

10

10

1700

1650

1600

1600
1550
1500
1450
1400
1350
1300
1250
1200
1150
1100
1050
1000
950
900
850
800
750
700
650
600
550
500
450
400
350
300
250
200
150
100
50
0

1700

Cells Winery Station Building

519 92

716-01 8500
- 1000



5181


4000


0181

1900
1900
1900


1900
1900
1900










Calla Winery 5/18/92








1813



1753

1813



1734

1785

1715

020040

Start pin 2

020040

020040

Cp 0-500 uab

1736

1715

1715

1705

020040

020040


Siddhanta Sanyal
Sanyal

Calla Winery 5/19/92 Biler #1

Coast 92.2

22.4
20.7.9.6

Plus
Coast 0-50V Start Clock 18:42



Start Run 2

Biller 001

0221

0121

001-0 125000

25-0011

2411


1821

Start Run 1

1122

5.18
4.50
0.00

0.00
0.00
0.00



1: 312 18h

(Boiler # 3

FEED WATER TANK -

START @ 13:03 - 20.5'

FINISH @ 13:29 17.0'

26 min

DA. TANK -

PRESSURE 8.5 PSIG / 8.0

TEMP - 235°F / 232

FEED WATER PUMP PRESSURE -

SUCTION 12.5 PSIG / 12

DISCHARGE 210 PSIG / 215

BOILER STEAM PRESSURE - 146 PSIG / 144

STACK TEMP. - 420°F

ECON. WATER OUT TEMP - 292°F / 286

FEEDWATER TANK TEMP - 70°F

GAS METER -

START - 258530

FINISH - 258540 10 x 10 = 100 REV. 27m - 26.69 sec.

CORR. - 799161

UNCORR. - 258540

GAS PRESS - 44.46

GAS TEMP - 51.63

ATM PRESS - 14.53

SP. GR GAS - .583

% N₂ - .630

0.0000 CF

76.49 x 10⁶

82.6%

T + 46.0

46.0

FEED WATER TANK -

START @ 14:14:20 - 21.5'

FINISH @ 14:45 17.5'

30 min

DA. TANK -

PRESSURE 8.5 / 8.5

TEMP - 235 / 235

FEED WATER PUMP PRESSURE -

SUCTION 12.5 / 12.5

DISCHARGE - 215 / 212

BOILER STEAM PRESSURE - 146 / 148

STACK TEMP - 420°F

ECON. WATER OUT TEMP - 288 / 292

FEEDWATER TANK TEMP - 70°F

GAS METER -

START - 258557

FINISH - 258568 10 x 10 = 100 REV. 30m 27.21 sec

CORR. - 799248

UNCORR. - 258568

GAS PRESS - 44.44

GAS TEMP - 51.71

ATM PRESS - 14.53

SP. GR GAS - .585

% N₂ - .585

75.53 x 10⁶

81.1%

63.728 PPH

5/19/92

(BOILER # 4

1 REC : 100 cu ft.

4/13/92

1st TEST

2nd TEST

FEED WATER TANK -

START @ 16:07:30 23.0'

@ 16:35:30 19.5'

FINISH @ 16:10:00 3.5 ft

DA. TANK -

PRESSURE 9.0 / 8.5

TEMP 235°F / 232

FEED WATER PUMP PRESSURE -

SUCTION 12.5 / 12.0

DISCHARGE 215 / 220

BOILER STEAM PRESSURE - 149 psig / 148

STACK TEMP - 450°F /

ECON - WATER OUT TEMP - 290°F / 285

FEEDWATER TANK TEMP - 70°F

GAS METER - 10 x 10 = 100

START - 258598

FINISH - 258608 m 28m, 27 sec.

CORR - 799371

UNCORR - 258608

GAS PRESS - 44.40

GAS TEMP - 52.43

ATM PRESS - 14.53

SP GR GAS - .583

% N₂ - .630

FEED WATER TANK -

START @ 17:08 22.0'

FINISH @ 17:15 17.5

DA. TANK -

PRESSURE 9.5 / 8.5

TEMP 236 / 233

FEED WATER PUMP PRESSURE -

SUCTION 130 / 12.5

DISCHARGE 215 / 205

BOILER STEAM PRESSURE - 142 / 140

STACK TEMP - 445 / 445

ECON - WATER OUT - 284 / 283

FEEDWATER TANK TEMP - 70°F

GAS METER - 12 x 10 = 120

START - 258620

FINISH - 258632 m 34 m 9 sec.

CORR - 799444

UNCORR - 258632

GAS PRESS - 44.40

GAS TEMP - 51.63

ATM PRESS - 14.53

SP GR GAS - .583

% N₂ - .630

BOILER # 4

4/18/02

3rd TEST

FEED WATER TANK -

START @ 18:09:30 - 18.0'

18.37-02 - 14.5

FINISH

27:30 - 3.5'

D.A. TANK -

PRESSURE 8.5/22

TEMP 235/232

FEED WATER PUMP PRESSURE -

SUCTION 14.2/12.5

DISCHARGE 210/215

BOILER STEAM PRESSURE - 137/134

STACK TEMP - 443/300

ECOM WATER OUT TEMP - 281/279

FEEDWATER TANK TEMP - 70°

GAS METER - 10 x 10 = 100

START - 258639

FINISH - 258649 in 28m 27,37 sec

CORR - 799497

UNCORR - 258644

GAS PRESS - 40.02

GAS TEMP - 50.95

ATM PRESS - 14.53

SP. GR. GAS - 1.683

% N₂ - 1.630

FEED WATER TANK -

START

FINISH

D.A. TANK -

PRESSURE

TEMP

FEED WATER PUMP PRESSURE -

SUCTION

DISCHARGE

BOILER STEAM PRESSURE -

FEEDWATER TANK TEMP -

(BULLE #1

1st TEST

FEED WATER TANK -

START @ 11:30 17.5'
12:00 14.5'
FINISH 23m 3 ft.

DA. TANK -

PRESSURE 7.5 / 8.0
TEMP 230° / 233

FEED WATER PUMP PRESSURE -

SUCTION 11 / 12.5
DISCHARGE 22.5 ✓

BOILER STEAM PRESSURE -

142 / 147
STACK TEMP - 540 / 545 ✓
ECON. WATER OUT TEMP - > 300°F ✓
FEEDWATER TANK TEMP - 69 ✓

GAS METER -

START - 259249
FINISH - 259257

8 x 10 = 80 RPM
in 26m 13.36 sec.

CORE - 801394
UNCORE - 259257
GAS PRESS - 44.59
GAS TEMP - 50.99
ATM PRESS - 14.53
SP. GR. GAS - .583
% N₂ - .630
% CO₂ - 1.190

5/11/72

2nd TEST

FEED WATER TANK -

START 12:43:30 15.5'
13:14:30 12.5
FINISH 37 min 3

DA. TANK -

PRESSURE 7.5 / 7.0
TEMP 232

FEED WATER PUMP PRESSURE -

SUCTION 12 / 11
DISCHARGE 22.0 / 21.5

BOILER STEAM PRESSURE -

145 / 147
STACK TEMP - 545 ✓
ECON. WATER OUT TEMP - 296 / > 300
FEEDWATER TANK TEMP - 69

GAS METER -

START - 259272
FINISH 259280

CORE - 801466
UNCORE - 259280
GAS PRESS - 44.53
GAS TEMP - 51.93
SP. GR. GAS - .583
% N₂ - .630
% CO₂ - 1.190
ATM. PRESS - 14.53
8 x 10 = 80
26m 4.63 sec.

BOILER #1

5/9/92

3rd TEST

FEED WATER TANK -

START 13:32 17.5'

14:09 14.0'

FINISH 37 min 3.5H.

DA. TANK -

PRESSURE 7.5 ✓

TEMP 230

FEED WATER PUMP PRESSURE -

SUCTION 12 / 11

DISCHARGE 215 / 210

BOILER STEAM PRESSURE - 145 / 102

STACK TEMP - 545 / 540

ECON. WATER OUT TEMP - > 300°F / 249

FEEDWATER TANK TEMP - 69.5°F

GAS METER -

START - 259287

FINISH - 259297

32 ~ 30:14

CORE - 80 1517

UNCOR - 259297

GAS PRESS - 44.52

GAS TEMP - 52.43

ATM PRESS - 14.53

SP. GR. GAS - 0.933

% N₂ - 1630

% CO₂ - 1190

10 XID = 100 RW.

FOR FAN
INLET TEMP. 298°F

FEED WATER TANK -

START

FINISH

DA. TANK -

PRESSURE

TEMP

FEED WATER PUMP PRESSURE -

SUCTION

DISCHARGE

BOILER STEAM PRESSURE -

STACK TEMP -

ECON. WATER OUT TEMP -

FEEDWATER TANK TEMP -

GAS METER -

START -

FINISH

CORE -

UNCOR -

GAS PRESS -

GAS TEMP -

SP. GR. GAS -

% N₂ -

% CO₂ -

SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (714) 653-6780 • FAX (714) 653-2430

REPORT OF ANALYSIS
NIST TRACEABLE GAS MIXTURES

BEST01

DATE: 04/27/92

TO:

**CRAIG THIRY
BEST ENVIRONMENTAL
15890 FOOTHILL BLVD
SAN LEANDRO, CA 94578-2101**

CUSTOMER ORDER NUMBER: 8418

PAGE 1

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC56492	Propane	19.79 ± 0.20 ppm	SRM 1667b
	Methane	25.22 ± 0.25 ppm	L2293
	Ultrapur Air	Balance	
CC56495	Propane	19.25 ± 0.19 ppm	SRM 1667b
	Methane	25.25 ± 0.25 ppm	L2293
	Ultrapur Air	Balance	

ppm = umole/mole

*** = mole-%**

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

Analyst:

Mark Moran

M. J. Monson

Approved:

Alvaro

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

**BEST01**

DATE: 05/10/91

TO:

REGAN BEST
BEST ENVIRONMENTAL
27343 INDUSTRIAL BLVD.#E
HAYWARD, CA 94545

PAGE 1

CUSTOMER ORDER NUMBER: 8271

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC28696	Nitric Oxide Nitrogen, O2-Free	88.1 ± 0.9 ppm Balance	SRM 1684b
CC293	Nitric Oxide Nitrogen, O2-Free	88.7 ± 0.9 ppm Balance	SRM 1684b

ppm = umole/mole

t = mole-t

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above.

Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202/91.

Analyst:

Approved:

B.E. Gross

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
TELEPHONE (714) 784-1240

REPORT OF ANALYSIS
NIST TRACEABLE GAS MIXTURES

BEST01

TO:

**CRAIG THIRY
BEST ENVIRONMENTAL
15890 FOOTHILL BLVD.
SAN LEANDRO, CA 94578-**

DATE: 01/10/92

CUSTOMER ORDER NUMBER: 8370

PAGE 1

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC12250	Carbon Dioxide	12.12 + 0.12 %	SRM 1675b
	Oxygen	7.89 + 0.08 %	SRM 2658a
	Carbon Monoxide	82.6 + 0.8 ppm	SRM 1679c
	Nitrogen	Balance	
CC12706	Sulfur Dioxide	194.3 + 1.9 ppm	SRM 1661
	Nitrogen	Balance	

ppm = umole/mole

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

Analyst:

Mark Monson

M.J. Monson

Approved:

Amor

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (714) 653-6780 • FAX (714) 653-2430

REPORT OF ANALYSIS NIST TRACEABLE GAS MIXTURES

BEST01

TO:

CRAIG THIRY
BEST ENVIRONMENTAL
15890 FOOTHILL BLVD.
SAN LEANDRO, CA 94578-

DATE: 03/31/92

CUSTOMER ORDER NUMBER: 8398

PAGE 1

XX			
CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC97819	Propane Ultrapure Air	3.08 ± 0.03 ppm Balance	SRM 1667b
CC60419	Carbon Monoxide Carbon Dioxide Oxygen Nitrogen	78.2 ± 0.8 ppm 12.20 ± 0.12 % 7.81 ± 0.08 % Balance	SRM 1679c SRM 1675b SRM 2658a
CC292	Carbon Monoxide Carbon Dioxide Oxygen Nitrogen	401 ± 4 ppm 12.79 ± 0.13 % 3.91 ± 0.04 % Balance	SRM 1680b SRM 1675b SRM 2658a

ppm = umole/mole

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/207491.

Analyst:

M.S. Calhoun

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS