

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 ~~31~~#9
Section 1.4
(B10 Ch. 2)

15

**UREA PERMIT
COMPLIANCE TESTING AT ALAMITOS
GENERATING STATION UNIT 2**

Prepared For:

**Southern California Edison Company
Rosemead, California**

For Submittal To:

South Coast Air Quality Management District

Prepared By:

Edward J. Filadelfia

**CARNOT
Tustin, California**

NOVEMBER 1992

REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and documented in this report were carried out under my direction and supervision.

Edward J. Filadelfia

Date 11/24/92

Edward J. Filadelfia
Senior Engineer

I have reviewed, technically and editorially, details, calculations, results, conclusions and other appropriate written material contained herein, and hereby certify that the presented material is authentic and accurate.

Carmela J. Rossi

Date 11/24/92

Carmela J. Rossi, P.E.
Senior Engineer



SECTION 1.0

INTRODUCTION

Carnot was contracted to conduct a series of emissions tests on Unit 2 at the Alamitos Generating Station for Southern California Edison (SCE). Carnot conducted testing to comply with South Coast Air Quality Management District (SCAQMD) Permit A/N 248230.

A test program was conducted to quantify the effect of urea injection on various stack emissions as stated in the permit to construct. Emissions tests were performed on Alamitos Unit 2 for the following:

- NO_x, CO, and O₂
- ROG as non-methane hydrocarbons
- Particulates
- NH₃ (urea on only)

Emissions testing was conducted by Edward J. Filadelfia, Craig H. Fry, Jim Mulligan and Robert Madrigal of Carnot, on October 6, 7, and 8, 1992. Mr. Barry Novodvorsky and Mike Escarcega of SCE coordinated the testing.

TABLE 1-1
EMISSIONS TEST RESULTS SUMMARY
ALAMITOS UNIT 2
October, 1992

Parameter	<u>NET LOAD 165 MW</u>		<u>NET LOAD 138 MW</u>		<u>NET LOAD 40 MW</u>	
	Urea Off	Urea On	Urea Off	Urea On	Urea Off	Urea On
NO _x ppm ⁽¹⁾	144.9	106.5	83.2	71.3	108.2	91.0
NO _x PPM @ 3% O ₂ ⁽¹⁾	141.9	103.1	85.8	73.7	142.9	120.5
CO ppm ⁽¹⁾	1.4	4.6	0.6	1.2	0.31	0.6
ppm @ 3% O ₂ ⁽¹⁾	1.3	4.5	0.6	1.2	0.4	0.8
Methane, ppm	ND < 1.0	< 1.4	< 1.1	ND < 1.0	ND < 1.0	ND < 1.0
TNMHC as CH ₄ , ppm	15.7	18.7	14.1	13.4	12.6	11.2
Particulate, lb/hr	1.30	1.23	0.44	1.36	0.24	1.01
Grain loading, gr/dscf	0.0008	0.0007	0.0003	0.0009	0.0003	0.0013
Total urea flow	0.0	1.2	0.0	0.7	0.0	0.25
NH ₃ Slip						
ppm	-	7.8	-	5.4	-	3.3
ppm @ 3% O ₂ ⁽²⁾	-	10.3	-	7.4	-	6.3

(1) Carnot CEM Data.

(2) Oxygen for correction from portable O₂ meter.

Notes: ND < indicates that this species was not detected.
 < indicated that this species was detected in at least one but not all samples.

SECTION 2.0

BOILER DESCRIPTION

1750 MW/AC

Alamitos Unit 2 is a gas- or oil-fired steam-electric unit with a nameplate rating of 175 MW. The boiler is similar to five other units designed and built by B&W for SCE in 1956, and has a steam capacity of 1,140,000 lb/hr at design conditions of 1990 psig, 1000°F superheat, and 1000°F reheat steam temperature.

The furnace is fired with 16 combination gas/oil B&W burners arranged in a four-by-four matrix on the front wall. During gas fuel operation, the oil guns and diffusers are retracted to the back of the windbox. Gas is introduced radially inward through an external manifold spud burner. Combustion air enters each burner through adjustable vane-type air registers. The draft system is comprised of forced and induced draft fans, and the furnace is operated with slightly negative pressure.

The boilers are equipped with flue gas recirculation (GR) to the furnace hopper which is intended for steam temperature control. The flue gas is extracted from the boiler exhaust upstream of both air preheaters, and introduced into the furnace through slots between the waterwall tubes located in the rear wall immediately above the hopper. Spray attenuation for the superheaters and reheaters is also provided for steam temperature control.

SECTION 3.0

TEST DESCRIPTION

3.1 TEST CONDITIONS

The demonstration tests were conducted at two conditions and at three loads. Condition one was with urea off and condition two was with optimum urea injection. Duplicate tests were performed at each of the following net loads: 40, 138 and 165 MW. All testing were performed with the boiler fired on natural gas fuel. The test matrix and unit operating data are outlined in Tables 3-1 and 3-2. Test conditions were established by SCE personnel, and unit data was collected by Carnot and SCE personnel.

3.2 SAMPLE LOCATIONS

The particulate sampling was performed in two exhaust ducts located between the air preheater (APH) and the stack. Samples were drawn from two ports with seven points each on both the east and west ducts. This resulted in a total of 14 points per duct as shown in Figure 3-1.

Ammonia and hydrocarbon sampling was performed at the same locations as the particulates.

All gaseous testing (NO_x , CO and O_2) was performed on the hot (inlet) side of the APH, as shown in Figure 3-2, with an 8-point sampling grid on both the east and west ducts (16-point total).

3.3 TEST PROCEDURES

The test procedures used for this program are in Table 3-3. Descriptions of standard procedures are included in Appendix A. Additional information and modifications to standard procedures are presented in the following section.

TABLE 3-1
TEST MATRIX SCE ALAMITOS UNIT 2
October, 1992

Test	Date	Time	Type of Test	Load MW	Urea Injection Status	Comments
1-2-PM	10/6/92	0900/1027	Particulate	165	off	
1-2-HC	10/6/92	1012/1032	Hydrocarbon	165	off	
1-2-CEM	10/6/92	1012/1042	NO _x , CO & O ₂	165	off	
2-2-PM	10/6/92	1115/1157	Particulate	165	off	Isokinetics out of range.
3-2-PM	10/6/92	1305/1449	Particulate	165	off	
3-2-HC	10/6/92	1316/1336	Hydrocarbon	165	off	
3-2-CEM	10/6/92	1315/1350	NO _x , CO & O ₂	165	off	
4-2-PM	10/6/92	1530/1700	Particulate	165	on	
4-2-HC	10/6/92	1410/1430	Hydrocarbon	165	on	
4-2-CEM	10/6/92	1615/1645	NO _x , CO & O ₂	165	on	
4-2-NH ₃	10/6/92	1610/1641	Ammonia	165	on	
5-2-PM	10/6/92	1740/1907	Particulate	165	on	
5-2-HC	10/6/92	1810/1830	Hydrocarbon	165	on	
5-2-CEM	10/6/92	1815/1845	NO _x , CO & O ₂	165	on	
5-2-NH ₃	10/6/92	1810/1841	Ammonia	165	on	
6-2-PM	10/7/92	0830/1012	Particulate	138	off	
6-2-HC	10/7/92	0917/0937	Hydrocarbon	138	off	
6-2-CEM	10/7/92	0910/0955	NO _x , CO & O ₂	138	off	
7-2-PM	10/7/92	1056/1222	Particulate	138	off	
7-2-HC	10/7/92	1126/1146	Hydrocarbon	138	off	
7-2-CEM	10/7/92	1130/1225	NO _x , CO & O ₂	138	off	

(Continued)

TABLE 3-1 (Cont'd)
TEST MATRIX SCE ALAMITOS UNIT 2
October, 1992

Test	Date	Time	Type of Test	Load MW	Urea Injection Status	Comments
8-2-PM	10/7/92	1327/1457	Particulate	138	on	
8-2-HC	10/7/92	1400/1420	Hydrocarbon	138	on	
8-2-CEM	10/7/92	1400/1445	NO _x , CO & O ₂	138	off	
8-2-NH ₃	10/7/92	1400/1431	Ammonia	138	on	
9-2-PM	10/7/92	1535/1704	Particulate	138	on	
9-2-HC	10/7/92	1615/1635	Hydrocarbon	138	on	
9-2-CEM	10/7/92	1620/1650	NO _x , CO & O ₂	138	on	
9-2-NH ₃	10/7/92	1615/1646	Ammonia	138	on	
10-2-PM	10/8/92	0835/1012	Particulate	40	on	
10-2-HC	10/8/92	0909/0929	Hydrocarbon	40	on	
10-2-CEM	10/8/92	0905/0935	NO _x , CO & O ₂	40	on	
10-2-NH ₃	10/8/92	0900/0131	Ammonia	40	on	
11-2-PM	10/8/92	1105/1233	Particulate	40	on	
11-2-HC	10/8/92	1117/1137	Hydrocarbon	40	on	
11-2-CEM	10/8/92	1115/1145	NO _x , CO & O ₂	40	on	
11-2-NH ₃	10/8/92	1116/1147	Ammonia	40	on	
12-2-PM	10/8/92	1215/1441	Particulate	40	off	
12-2-HC	10/8/92	1345/1405	Hydrocarbon	40	off	
12-2-CEM	10/8/92	1345/1415	NO _x , CO & O ₂	40	off	
13-2-PM	10/8/92	1515/1641	Particulate	40	off	
13-2-HC	10/8/92	1525/1545	Hydrocarbon	40	off	
13-2-CEM	10/8/92	1525/1555	NO _x , CO & O ₂	40	off	

TABLE 3-2
UNIT OPERATING DATA SCE ALAMITOS UNIT 2
October, 1992

Test No.	Date	Load MW	Urea Status	Total Urea Flow gpm
1-2	10/6/92	166	off	0.0
2-2	10/6/92	166	off	0.0
3-2	10/6/92	166	off	0.0
4-2	10/6/92	166	on	1.2
5-2	10/6/92	166	on	1.2
6-2	10/7/92	137	off	0.0
7-2	10/7/92	138	off	0.0
8-2	10/7/92	137	on	0.7
9-2	10/7/92	138	on	0.7
10-2	10/8/92	39	off	0.25
11-2	10/8/92	39	off	0.25
12-2	10/8/92	39	off	0.0
13-2	10/8/92	39	off	0.0

⁽¹⁾ Burners Out Of Service.

TABLE 3-3
EMISSIONS TEST PROCEDURES SCE ALAMITOS UNIT 2
October, 1992

Parameter	Number of Replicates	Duration of Test (Minutes)	Measurement Principle	Reference Method	Method Detection Limit
NO _x	2	30	Chemiluminescent	SCAQMD 100.1	Below 2% of instrument full scale
CO	2	30	NDIR/Gas filter correlation	SCAQMD 100.1	Below 2% of instrument full scale
O ₂	2	30	Electrochemical cell	SCAQMD 100.1 EPA 3A	Below 2% of instrument full scale
ROG as Hydrocarbons	2	20	Gas chromatography/FID	SCAQMD 25.2	0.1 ppm
Particulate	2	86	In-stack filtration	SCAQMD 5.3	0.002 gr/dscf
Ammonia	2	30	Colorimetry Spectrophotometry	SCAQMD Draft 207.1	0.1 ppm

3.3.1 Gaseous Emissions

Gaseous species (NO_x , CO and O_2) were measured using Carnot's Continuous Emissions Monitor (CEM) described in Appendix A. This system meets SCAQMD, CARB and EPA requirements for gaseous species. Two thirty minute gaseous emissions test runs were done for each test condition and load. Leak checks were done at the beginning and end of the test program on all points of the grid. Carnot connected one of the probes to a heated line and knockout to perform a system bias. NO_2 was measured once at each test condition. The results can be found in Appendix D.2. On the cold side of the APH, O_2 was measured at each point during all isokinetic tests with a portable Teledyne O_2 analyzer. Linearity of the portable O_2 analyzer was established before and after each test day. The results from these calibrations are presented in Appendix C. For molecular weight and dilution calculations on the cold side of the APH, CO_2 was determined by stoichiometric calculation.

3.3.2 Particulate Matter

Particulate was measured according to SCAQMD Method 5.3 (in-stack filtration). A total of two separate runs were used for each load condition. Each test run was 84 minutes in duration. Emissions were calculated in lb/hr and lb/MMBtu.

During particulate sampling, a gas sample was drawn through a stainless steel nozzle into a **Gelman** in stack filter housing with a tared 45 mm fiberglass filter. The filter collected existing particulate at actual exhaust temperature. The gas sample was then drawn through two **Smith Greenburg** impingers containing 100 ml of distilled water, an empty impinger as a knock-out, a fourth impinger containing silica gel. The impingers collected any condensible particulate species.

3.3.3 Reactive Organic Gases (ROG) as Hydrocarbons

Hydrocarbon samples were collected in new tedlar bags and analyzed according to SCAQMD method 25.2. The samples were analyzed within 72 hours of collection by Atmosphere Assessments in Chatsworth, California.

3.3.4 Ammonia

Ammonia samples were collected non-isokinetically, with NH_3 being absorbed in two impingers containing 0.1 N H_2SO_4 . The ammonia was analyzed by SCAQMD NH_3 Draft Method in Carnot's Tustin Laboratory.

3.3.5 Velocity and Moisture

Stack gas velocity and moisture were determined by SCAQMD methods 2 and 4 in conjunction with every isokinetic test.




Figure 3-1. Alamitos Unit 2 Air Preheater Outlet Ducts Test Location




Figure 3-2. Alamitos Unit 2 Air Preheater Inlet Sample Test Location for NO_x, CO and O₂ Sampling

SECTION 4.0

RESULTS

Emissions test results are presented in Tables 4-1 to 4-6. Measurement procedures are detailed in Appendix A. Quality assurance and equipment calibrations are in Appendix B. All raw data sheets from Carnot's testing and from unit operation are included in Appendix C. Appendix D contains general and specific emissions calculations. Appendix E contains laboratory reports. Carnot's instrument strip charts are in Appendix F. Chain of Custody information is included in Appendix G.

TABLE 4-1
EMISSION TEST RESULTS AT 165 MW
UREA OFF
ALAMITOS UNIT 2
October 6, 1992

Parameter	Test No. 1-2	Test No. 3-2	Test Averages
NO _x , ppm ⁽¹⁾	147.3	142.4	144.9
ppm @ 3% O ₂ ⁽¹⁾	145.8	137.9	141.9
CO, ppm ⁽¹⁾	0.8	1.9	1.4
ppm @ 3% O ₂ ⁽¹⁾	0.8	1.8	1.3
O ₂ % ⁽¹⁾	2.8	2.4	2.6
Methane, ppm			
Total non-methane hydrocarbon as methane, ppm	ND < 1.0 13.8	ND < 1.0 17.5	ND < 1.0 15.7
Particulate analysis:			
Flow dscfm	187,400	199,700	193,600
Stack temperature °F	314.5	329.0	321.8
Moisture %	14.0	15.1	14.6
O ₂ % ⁽²⁾	7.7	7.4	7.6
lb/hr	1.61	0.98	1.30
Grain loading, gr/dscf	0.0013	0.0008	0.0010

(1) Carnot CEM Data.

(2) Oxygen for correction from portable O₂ meter.

Notes: ND < indicates that this species was not detected.
< indicated that this species was detected in at least one but not all samples.

TABLE 4-2
EMISSIONS TEST RESULTS AT 165 MW
UREA ON
ALAMITOS UNIT 2
October 6, 1992

Parameter	Test No. 4-2	Test No. 5-2	Test Averages
NO _x , ppm ⁽¹⁾	109.3	103.6	106.5
ppm @ 3% O ₂ ⁽¹⁾	105.9	100.3	103.1
CO, ppm ⁽¹⁾	3.3	5.9	4.6
ppm @ 3% O ₂ ⁽¹⁾	3.2	5.7	4.5
O ₂ % ⁽¹⁾	2.4	2.4	2.4
Methane, ppm			
Total non-methane hydrocarbon as methane, ppm	1.7 18.0	ND < 1.0 19.4	< 1.4 18.7
NH ₃ , ppm	4.0	11.5	7.8
ppm @ 3% O ₂ ⁽²⁾	5.3	15.3	10.3
Particulate analysis:			
Flow dscfm	216,600	192,500	204,600
Stack temperature °F	310.4	319.6	315.0
Moisture %	16.1	15.2	15.6
O ₂ % ⁽²⁾	7.4	7.4	7.4
lb/hr	1.17	1.29	1.23
Grain loading, gr/dscf	0.0006	0.0008	0.0007

(1) Carnot CEM Data.

(2) Oxygen for correction from portable O₂ meter.

Notes: ND < indicates that this species was not detected.
< indicated that this species was detected in at least one but not all samples.

TABLE 4-3
EMISSION TEST RESULTS AT 138 MW
UREA OFF
ALAMITOS UNIT 2
October 7, 1992

Parameter	Test No. 6-2	Test No. 7-2	Test Averages
NO _x , ppm ⁽¹⁾	82.9	83.5	83.2
ppm @ 3% O ₂ ⁽¹⁾	84.8	86.7	85.8
CO, ppm ⁽¹⁾	0.7	0.5	0.6
ppm @ 3% O ₂ ⁽¹⁾	0.7	0.5	0.6
O ₂ % ⁽¹⁾	3.4	3.7	3.6
Methane, ppm			
Total non-methane hydrocarbon	1.2	ND < 1.0	< 1.1
as methane, ppm	14.6	13.6	14.1
Particulate analysis:			
Flow dscfm	156,600	193,500	175,100
Stack temperature °F	300.2	339.6	319.9
Moisture %	13.9	14.2	14.1
O ₂ % ⁽²⁾	8.5	8.1	8.3
lb/hr	0.24	0.64	0.44
Grain loading, gr/dscf	0.0002	0.0004	0.0003

(1) Carnot CEM Data.

(2) Oxygen for correction from portable O₂ meter.

Notes: ND < indicates that this species was not detected.
 < indicated that this species was detected in at least one but not all samples.

TABLE 4-4
EMISSION TEST RESULTS AT 138 MW
UREA ON
ALAMITOS UNIT 2
October 7, 1992

Parameter	Test No. 8-2	Test No. 9-2	Test Averages
NO _x , ppm ⁽¹⁾	70.7	71.9	71.3
ppm @ 3% O ₂ ⁽¹⁾	72.9	74.4	73.7
CO, ppm ⁽¹⁾	1.3	1.0	1.2
ppm @ 3% O ₂ ⁽¹⁾	1.4	1.0	1.2
O ₂ % ⁽¹⁾	3.5	3.6	3.6
Methane, ppm			
Total non-methane hydrocarbon as methane, ppm	ND < 1.0 13.6	ND < 1.0 13.1	ND < 1.0 13.4
NH ₃ , ppm	3.3	7.5	5.4
ppm @ 3% O ₂ ⁽²⁾	4.6	10.2	7.4
Particulate analysis:			
Flow dscfm	177,600	156,000	166,800
Stack temperature °F	342.3	298.5	320.4
Moisture %	14.7	14.0	14.3
O ₂ % ⁽²⁾	8.2	7.8	8.0
lb/hr	1.80	0.91	1.36
Grain loading, gr/dscf	0.0012	0.0007	0.0009

(1) Carnot CEM Data.

(2) Oxygen for correction from portable O₂ meter.

Notes: ND < indicates that this species was not detected.

< indicated that this species was detected in at least one but not all samples.

TABLE 4-5
EMISSION TEST RESULTS AT 40 MW
UREA OFF
ALAMITOS UNIT 2
October 8, 1992

15.0

Parameter	Test No. 12-2	Test No. 13-2	Test Averages
NO _x , ppm ⁽¹⁾	108.6	107.7	108.2
ppm @ 3% O ₂ ⁽¹⁾	143.4	142.4	142.9
CO, ppm ⁽¹⁾	0.32	0.30	0.31
ppm @ 3% O ₂ ⁽¹⁾	0.4	0.4	0.4
O ₂ % ⁽¹⁾	7.3	7.3	7.3
Methane, ppm			
Total non-methane hydrocarbon as methane, ppm	ND < 1.0 10.3	ND < 1.0 14.8	ND < 1.0 12.6
Particulate analysis:			
Flow dscfm	76,800	113,800	95,300
Stack temperature °F	337.6	284.1	310.9
Moisture %	11.6	11.9	11.8
O ₂ % ⁽²⁾	12.2	11.1	11.7
lb/hr	0.22	0.26	0.24
Grain loading, gr/dscf	0.0003	0.0023	0.0013

(1) Carnot CEM Data.

(2) Oxygen for correction from portable O₂ meter.

Notes: ND < indicates that this species was not detected.
< indicated that this species was detected in at least one but not all samples.

TABLE 4-6
EMISSION TEST RESULTS AT 40 MW
UREA On
ALAMITOS UNIT 2
October 8, 1992

15.7

Parameter	Test No. 10-2	Test No. 11-2	Test Averages
NO _x , ppm ⁽¹⁾	89.3	92.7	91.0
ppm @ 3 % O ₂ ⁽¹⁾	117.8	123.1	120.5
CO, ppm ⁽¹⁾	0.5	0.7	0.6
ppm @ 3 % O ₂ ⁽¹⁾	0.7	0.9	0.8
O ₂ % ⁽¹⁾	7.3	7.4	7.4
Methane, ppm			
Total non-methane hydrocarbon as methane, ppm	ND < 1.0 11.1	ND < 1.0 11.3	ND < 1.0 11.2
NH ₃ , ppm	4.1	2.5	3.3
ppm @ 3 % O ₂ ⁽²⁾	7.8	4.8	6.3
Particulate analysis:			
Flow dscfm	104,100	88,200	96,200
Stack temperature °F	282.2	335.4	308.8
Moisture %	13.4	11.8	12.6
O ₂ % ⁽²⁾	11.6	11.5	11.6
lb/hr	0.3	1.72	1.01
Grain loading, gr/dscf	0.0003	0.0003	0.0003

(1) Carnot CEM Data.

(2) Oxygen for correction from portable O2 meter.

Notes: ND < indicates that this species was not detected.

< indicated that this species was detected in at least one but not all samples.

APPENDIX A
MEASUREMENT PROCEDURES

Continuous Emissions Monitoring System

Oxygen (O₂) by Continuous Analyzer

NO/NO_x by Continuous Analyzer

Carbon Monoxide (CO) by NDIR/Gas Filter Correlation

Total Particulate by SCAQMD Method 5.3 w/Condensible Analysis

Hydrocarbons by SCAQMD Micro TCA Method

Ammonia

Continuous Emissions Monitoring System

O₂, CO, CO₂, NO, NO_x and SO₂ are measured using an extractive continuous emissions monitoring (CEM) package, shown in the following figure. This package is comprised of three basic subsystems. They are: (1) the sample acquisition and conditioning system, (2) the calibration gas system, and (3) the analyzers themselves. This section presents a description of the sampling and calibration systems. Descriptions of the analyzers used in this program and the corresponding reference test methods follow. Information regarding quality assurance information on the system, including calibration routines and system performance data follows.

The sample acquisition and conditioning system contains components to extract a representative sample from the stack or flue, transport the sample to the analyzers, and remove moisture and particulate material from the sample. In addition to performing the tasks above, the system must preserve the measured species and deliver the sample for analysis intact. The sample acquisition system extracts the sample through a stainless steel probe. The probe is insulated or heated as necessary to avoid condensation. If the particulate loading in the stack is high, a sintered stainless steel filter is used on the end of the probe.


Where water soluble NO₂ and/or SO₂ are to be measured, the sample is drawn from the probe through a heated teflon sample line into an on-stack cooled (approximately 35-40°F) water removal trap. The trap consists of stainless steel flasks in a bath of ice and water. This design removes the water vapor by condensation. The contact between the sample and liquid water is minimized and the soluble NO₂ and SO₂ are conserved. This system meets the requirements of EPA Method 20. The sample is then drawn through a teflon transport line, particulate filter, secondary water removal and into the sample pump. The pump is a dual head, diaphragm pump. All sample-wetted components of the pump are stainless steel or teflon. The pressurized sample leaving the pump flows through a third condensate trap in a refrigerated water bath (≈38°F) for final moisture removal. A drain line and valve are provided to constantly expel any condensed moisture from the dryer at this point. After the dryer, the sample is directed into a distribution manifold. Excess sample is vented through a back-pressure regulator, maintaining a constant pressure of 5-6 psig to the analyzer rotameters.

The calibration system is comprised of two parts: the analyzer calibration, and the system bias check (dynamic calibration). The analyzer calibration equipment includes pressurized cylinders of certified span gas. The gases used are, as a minimum, certified to 1% by the manufacturer. Where necessary to comply with reference method requirements EPA Protocol 1 gases are used. The cylinders are equipped with pressure regulators which supply the calibration gas to the analyzers at the same pressure and flow rate as the sample. The selection of zero, span, or sample gas directed to each analyzer is accomplished by operation of the sample/calibration selector fittings.

The system bias check is accomplished by transporting the same gases used to zero and span the analyzers to the sample system as close as practical to the probe inlet. This is done either by attaching the calibration gas supply line to the probe top with flexible tubing or by actuation of a solenoid valve located at the sample conditioner inlet (probe exit). The span gas is exposed to the same elements as the sample and the system response is documented. The analyzer indications for the system calibration check must agree within 5% of the analyzer calibration. Values are adjusted and changes/repairs are made to the system to compensate for any difference in analyzer readings. Specific information on the analytical equipment and test methods used is provided in the following pages.

Method:	Oxygen (O ₂) by Continuous Analyzer
Applicable Reference Methods:	EPA 3A, EPA 20, ARB 100, BA ST-14, SCAQMD 100.1
Principle:	A sample is continuously drawn from the flue gas stream, conditioned, and conveyed to the instrument for direct readout of O ₂ concentration.
Analyzer:	Teledyne Model 326A
Measurement Principle:	Electrochemical cell
Ranges:	0-5, 0-10, 0-25% O ₂
Accuracy:	1% of full scale
Output:	0-100 mV, linear
Interferences:	Halogens and halogenated compounds will cause a positive interference. Acid gases will consume the fuel cell and cause a slow calibration drift.
Response Time:	90% <7 seconds
Sampling Procedure:	A representative flue gas sample is collected and conditioned using the CEM system described previously. If Method 20 is used, that method's specific procedures for selecting sample points are used. Otherwise, stratification checks are performed at the start of a test program to select single or multiple-point sample locations.
Analytical Procedure:	An electrochemical cell is used to measure O ₂ concentration. Oxygen in the flue gas diffuses through a Teflon membrane and is reduced on the surface of the cathode. A corresponding oxidation occurs at the anode internally, and an electric current is produced that is proportional to the concentration of oxygen. This current is measured and conditioned by the instrument's electronic circuitry to give an output in percent O ₂ by volume.
Special Calibration Procedure:	The measurement cells used with the O ₂ instrument have to be replaced on a regular basis. After extended use, the cell tend to produce a nonlinear response. Therefore, a three-point calibration is performed at the start of each test day to check for linearity. If the response is not linear ($\pm$ 2% of scale), the cell is replaced.

Method:	Carbon Monoxide (CO) by NDIR/Gas Filter Correlation
Applicable Reference Methods:	EPA 10; ARB 1-100; BA ST-6, SCAQMD 100.1
Principle:	A sample is continuously drawn from the flue gas stream, conditioned, and conveyed to the instrument for direct readout of CO concentration.
Analyzer:	TECO, Model 48
Measurement Principle:	NDIR/Gas Filter Correlation
Precision:	0.1 % ppm
Ranges:	0-5, 0-10, 0-25, 0-50, 0-100, 0-250, 0-500, 0-1000, 0-5000 ppm
Output:	0-100 mV
Interferences:	Negligible interference from water and CO ₂
Rise/Fall Times (0-95 %)	1 minute @ 1 lpm flow, 30 second integration time
Sampling Procedure:	A representative flue gas sample is collected and conditioned using the CEM system described previously. Sample point selection has been described previously.
Analytical Procedure:	Radiation from an infrared source is chopped and then passed through a gas filter which alternates between CO and N ₂ due to rotation of a filter wheel. The radiation then passes through a narrow band-pass filter and a multiple optical pass sample cell where absorption by the sample gas occurs. The IR radiation exits the sample cell and falls on a solid state IR detector.



Sample Train for Determination of Particulate by
SCAQMD Method 5.3

Method: Hydrocarbons by SCAQMD Micro Total Carbon Analysis (TCA/FID) Method

Reference: SCAQMD Method 25.2 (draft Source Test Manual)

Principle: A Tedlar bag is filled with flue gas at a constant rate. The bag contents are analyzed by gas chromatography/flame ionization detection for CO, CO₂, methane and total gaseous non-methane hydrocarbons.

Sampling Procedure: Samples are collected using a lung-type sampling system shown in the attached figure. In this system, a bag is placed in a sealed container and the container is evacuated. Flue gas enters the bag as it expands to fill the container. Sampling rate is monitored by a rotameter on the container exhaust. This system allows sample collection without exposing the sample to pumps, flowmeters, oils, etc.

Analytical Procedure: In the analytical phase, gaseous carbon compounds from the tank are fractionated on a chromatographic column, eluting in the order: carbon monoxide, methane, carbon dioxide, non-methane hydrocarbons. All resulting vapors are passed through oxidizers where they are combusted to carbon dioxide, then converted to methane and measured by flame ionization detection. CO₂, CO, CH₄, and total gaseous non-methane hydrocarbons are reported separately.

This method provides lower detection limits than the standard TCA procedure, which uses GC/NDIR. Since this method does not use a steel condensate trap, it eliminates positive interferences that have been associated with carbon dioxide dissolved in water frozen in the condensate trap and released during analysis.

The TCA/FID method is appropriate for combustion sources and ambient sampling where low concentrations of hydrocarbons are expected.

Carnot subcontracts TCA analysis to qualified local laboratories experienced in the analytical procedures.


Method:	Ammonia
Principle:	Ammonia emissions are determined by collecting a dry, metered volume of flue gas containing ammonia vapor in dilute sulfuric acid solution. The ammonia concentration of the sample is then determined by ion selective electrode or colorimetric spectrophotometry.
Sampling Procedure:	The ammonia sampling probe/train arrangement used during the test program is shown schematically in the following figure. A sample is extracted through a glass probe fitted with a quartz wool plug or filter used to remove particulate matter. The plug is located and/or heated to avoid condensation of moisture at the plug. The sample is then passed through four impingers. The first two impingers are filled with 100 ml of 0.1 N sulfuric acid (H₂SO₄), the third is empty, and the fourth is filled with silica gel. After each sample run, the quartz wool plug is removed and placed in a sample bottle. If a filter is used, it is generally saved but not analyzed. The impingers, glass probe, and sampling train glassware are washed with dilute H₂SO₄ into a separate sample bottle. The sample bottles containing the impinger wash solution and the quartz wool plug or filter are returned to the laboratory for analysis.
Analytical Procedure:	Ammonia in source test samples is analyzed by ion selective electrode or colorimetrically. Source test samples are generally at low levels and titrations for ammonia are not applicable. The following sections discuss the two applicable analytical techniques.

Ion Selective Electrode

The ammonia samples are analyzed using an Orion Research Model 940 Microprocessor Ionanalyzer equipped with an ammonia ion selective electrode. The ammonia electrode is a glass electrode and reference electrode mounted behind a gas permeable membrane that separates the sample solution from the internal filling solution. After the addition of sodium hydroxide, ammonia in the sample diffuses across the electrode membrane. The measured pH change in the internal electrode solution is proportional to the concentration of ammonia in the sample solution.

The ammonia concentrations of the sample solutions are measured in units of ppm NH₃ by weight with the specific ion analyzer. By using the NH₃ concentration in ppm by weight, measuring the liquid volume of the sample solution, and obtaining the volume of the flue gas sample, the stack flue gas NH₃ concentration in ppm by volume is calculated using the equation:

$$\text{NH}_3 \text{ ppmV} = 0.049 \frac{(\text{ppm wt NH}_3 \text{ soln}) (\text{liq. vol., ml})}{\text{DSCF (at 60}^\circ\text{F) of sampled flue gas}}$$



Ammonia sampling probe/train arrangement.

APPENDIX B
QUALITY ASSURANCE

Appendix B.1
Quality Assurance Program Summary

QUALITY ASSURANCE PROGRAM SUMMARY AND ARB CERTIFICATION

Carnot ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA Officer and encompasses seven major areas:

1. Development and use of an internal QA manual.
2. QA reviews of reports, laboratory work, and field testing.
3. Equipment calibration and maintenance.
4. Chain of custody.
5. Training.
6. Knowledge of current test methods.
7. Agency certification.

Each of these areas is discussed individually below.

Quality Assurance Manual. Carnot has prepared a QA Manual according to EPA guidelines. The manual serves to document and formalize all of Carnot's QA efforts. The manual is constantly updated, and each member of the Source Test Division is required to read and understand its contents. The manual includes details on the other six QA areas discussed below.

QA Reviews. Carnot's review procedure includes review of each source test report by the QA Officer, and spot check reviews of laboratory and field work.

The most important review is the one that takes place before a test program begins. The QA Officer works closely with Source Test Division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of any interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance. The equipment used to conduct the emissions measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the California Air Resources Board (CARB). The schedule for maintenance and calibrations are given in Tables B-1 and B-2. Quality control checks are also conducted in the field for each test program. The following is a partial list of checks made as part of each CEM system test series.

- Sample acquisition and conditioning system leak check.
- 2-point analyzer calibrations (all analyzers)
- 3-point analyzer calibrations (analyzers with potential for linearity errors).
- Complete system calibration check ("dynamic calibration" through entire sample system).

- Periodic analyzer calibration checks (once per hour) are conducted at the start and end of each test run. Any change between pre- and post-test readings are recorded.
- All calibrations are conducted using gases certified by the manufacturer to be + 1 % of label value (NBS traceable).

Calibration and CEM performance data are fully documented, and are included in each source test report.

Chain of Custody. Carnot maintains full chain of custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Carnot documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.).

Samples are stored in a locked area to which only Source Test Division personnel have access. Neither other Carnot employees nor cleaning crews have keys to this area.

Data sheets are copied immediately upon return from the field, and this first generation copy is placed in locked storage. Any notes made on original sheets are initialed and dated.

Training. Personnel training is essential to ensure quality testing. Carnot has formal and informal training programs which include:

1. Attendance at EPA-sponsored training courses.
2. Enrollment in EPA correspondence courses.
3. A requirement for all technicians to read and understand Carnot's QA Manual.
4. In-house training and QA meetings on a regular basis.
5. Maintenance of training records.

Knowledge of Current Test Methods. With the constant updating of standard test methods and the wide variety of emerging test methods, it is essential that any qualified source tester keep abreast of new developments. Carnot subscribes to services which provide updates on EPA and CARB reference methods, and on EPA, CARB and SCAQMD rules and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Carnot personnel maintain membership in the Air Pollution Control Association, the Source Evaluation Society, and the ASME Environmental Control Division.

AGENCY CERTIFICATION

Carnot is certified by the CARB as an independent source test contractor for gaseous and particulate measurements. Carnot also participates in EPA QA audit programs for Methods 5, 6 and 7.

TABLE B-1
SAMPLING INSTRUMENTS AND EQUIPMENT CALIBRATION SCHEDULE
As Specified by the CARB

Instrument Type	Frequency of Calibration	Standard of Comparison or Method of Calibration	Acceptance Limits
Orifice Meter (large)	12 months	Calibrated dry test meter	$\pm 2\%$ of volume measured
Dry Gas Meter	12 months or when repaired	Calibrated dry test meter	$\pm 2\%$ of volume measured
S-Type Pitot (for use with EPA-type sampling train)	6 months	EPA Method 2	Cp constant (+5%) over working range; difference between average Cp for each leg must be less than 2%
Vacuum Gauges Pressure Gauges	6 months	Manometer	$\pm 3\%$
Field Barometer	6 months	Mercury barometer	$\pm 0.2''$ Hg
Temperature Measurement	6 months	NBS mercury thermometer or NBS calibrated platinum RTD	$\pm 4^{\circ}\text{F}$ for $< 400^{\circ}\text{F}$ $\pm 1.5\%$ for $> 400^{\circ}\text{F}$
Temperature Readout Devices	6 months	Precision potentiometer	$\pm 2\%$ full scale reading
Analytical Balance	12 months (check prior to each use)	Should be performed by manufacturer or qualified laboratory	± 0.3 mg of stated weight
Probe Nozzles	12 Months	Nozzle diameter check micrometer	Range $< \pm 0.10$ mm for three measurements
Continuous Analyzers	Depends upon use, frequency and performance	As specified by manufacturers operating manuals, EPA NBS gases and/or reference methods	Satisfy all limits specified in operating specifications

TABLE B-2
EQUIPMENT MAINTENANCE SCHEDULE
Based on Manufacturer's Specifications and Carnot Experience

Equipment	Performance Requirement	Maintenance Interval	Corrective Action
Pumps	1. Absence of leaks 2. Ability to draw manufacturer required vacuum and flow	Every 500 hours of operation or 6 months, whichever is less	1. Visual inspection 2. Clean 3. Replace worn parts 4. Leak check
Flow Measuring Device	1. Free mechanical movement 2. Absence of malfunction	Every 500 hours of operation or 6 months, whichever is less After each test, if used in H ₂ S sampling or other corrosive atmospheres	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero, span gas	As required by the manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobile Van Sampling Systems	Absence of leaks	Depends on nature of use	1. Change filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling Lines	Sample degradation less than 2%	After each test or test series	Blow filtered air through line until dry

Appendix B.2
ARB Certification

State of California
AIR RESOURCES BOARD

Executive Order G-767

Approval to Carnot
To Conduct Testing as an Independent Contractor

WHEREAS, the Air Resources Board ("Board"), pursuant to Section 41512 of the California Health and Safety Code, has established the procedures contained in Section 91200-91220, Title 17, California Code of Regulations, to allow the use of independent testers for compliance tests required by the Board; and


WHEREAS, pursuant to Sections 91200-91220, Title 17, California Code of Regulations, the Executive Officer has determined that Carnot meets the requirements of the Board for conducting ARB Test Methods 1, 2, 3, 4, 5, 6, 8, 10, and 100 (NOx, O2) when the following conditions are met:

1. Carnot conducts ARB Test Method 100 for O2 using a Teledyne 326 analyzer with either a A5 or a B1 sensor, or a paramagnetic analyzer.

NOW, THEREFORE, BE IT ORDERED that Carnot is granted an approval, from the date of execution of this order, until June 30, 1993 to conduct the tests listed above, subject to compliance with Section 91200-91220, Title 17, California Code of Regulations.

BE IT FURTHER ORDERED that during the approved period the Executive Officer or his or her authorized representative may field audit one or more tests conducted pursuant to this order for each type of testing listed above.

Executed this 10TH day of August 1992, at Sacramento, California.



James J. Morgester, Chief
Compliance Division


State of California
Air Resources Board
Approved Independent Contractor

Carnot

This is to certify that the company listed above has been approved
by the Air Resources Board to conduct compliance testing,
pursuant to Section 91207, Title 17, California Code of Regulations,
until June 30, 1993, for those test methods listed below:

ARB Source Test Methods:

1, 2, 3, 4, 5, 6, 8, 10, 100 (NOx, O2),


James J. Morgester, Chief
Compliance Division


for H. Roye Jackson, Manager
Field Evaluation Section

Appendix B.3
Calibration Data

CARNOT SPAN GAS RECORD

CLIENT/LOCATION: SCE / Unit 2 DATE: 12-6-92
BY: CHF

GAS	SPAN CYLINDER		AUX. SPAN CYLINDER	
	CYLINDER NO.	CONCENTRATION	CYLINDER NO.	CONCENTRATION
ZERO	ALM009761	99.998		
NOx	IL2595	90.52 / 100.2	ALM22747	222.4 / 222.4
O ₂	AAL12047	4.990	ALM12263	7.926
CO	IL2958	55.84	ALM12604	90.79
CO ₂	AAL12047	15.00	ALM12263	22.15 88.6
SO ₂				

CARNOT INSTRUMENT LINEARITY

	ANALYZER				
	O ₂	CO ₂	CO	NOx	SO₂ CO
ANALYZER RANGE	0-10%	0-25%	0-100	0-250 ppm	0-500 ppm
SET TO HIGH STD (80-90% OF RANGE)	7.926	22.15	90.79	222.4	
ACTUAL VALUE OF LOW STD	4.990	15.00	55.84	90.52	
AS-FOUND LOW STD (50-60% OF RANGE)	4.999	15.1	55.0	90.00	
DIFFERENCE IN % OF FULL SCALE					

% ERROR CALCULATION:

$$\frac{(\text{AS FOUND} - \text{ACTUAL VALUE OF SPAN})}{\text{RANGE}} \times 100$$

ALLOWABLE DEVIATION IS 2% OF FULL SCALE (2 SQUARES ON STRIP CHART).

CARNOT SPAN GAS RECORD

CLIENT/LOCATION: SCE DATE: 10-7-92

BY: CHF

New O₂ Bottle

GAS	SPAN CYLINDER		AUX. SPAN CYLINDER	
	CYLINDER NO.	CONCENTRATION	CYLINDER NO.	CONCENTRATION
ZERO				
NOx				
O ₂	ALM02680	4.973	ALM12263	7.926
CO				
CO ₂	ALM02680	14.98		22.15
SO ₂				

CARNOT INSTRUMENT LINEARITY

	ANALYZER				
	O ₂	CO ₂	CO	NOx	SO ₂
ANALYZER RANGE	0-10%	0-25%			
SET TO HIGH STD (80-90% OF RANGE)	7.926	22.15			
ACTUAL VALUE OF LOW STD	4.973	14.98			
AS-FOUND LOW STD (50-60% OF RANGE)	5.02	15.10			
DIFFERENCE IN % OF FULL SCALE					

% ERROR CALCULATION:

$$\frac{(\text{AS FOUND} - \text{ACTUAL VALUE OF SPAN})}{\text{RANGE}} \times 100$$

ALLOWABLE DEVIATION IS 2% OF FULL SCALE (2 SQUARES ON STRIP CHART).

CARNOT SPAN GAS RECORD

CLIENT/LOCATION: SCE / Alamitos 2 DATE: 10-8-92
BY: CHF

GAS	SPAN CYLINDER		AUX. SPAN CYLINDER	
	CYLINDER NO.	CONCENTRATION	CYLINDER NO.	CONCENTRATION
ZERO				
NOx	ALM02020	49.20	IL2595	90.52
O ₂				
CO				
CO ₂				
SO ₂				

CARNOT INSTRUMENT LINEARITY

	ANALYZER				
	O ₂	CO ₂	CO	NOx	SO ₂
ANALYZER RANGE				0-100 ppm	
SET TO HIGH STD (80-90% OF RANGE)				90.52	
ACTUAL VALUE OF LOW STD				49.86	
AS-FOUND LOW STD (50-60% OF RANGE)				50.4	
DIFFERENCE IN % OF FULL SCALE					

% ERROR CALCULATION:

$$\frac{(\text{AS FOUND} - \text{ACTUAL VALUE OF SPAN})}{\text{RANGE}} \times 100$$

ALLOWABLE DEVIATION IS 2% OF FULL SCALE (2 SQUARES ON STRIP CHART).

CARNOT

SUBJECT Portable OL Linearity JOB NO. 1259

SHEET NO. of

COMPUTED BY EF DATE 10/6/92 CHECKED BY DATE
Run 259

10/6/92

ALM 015786 12.66

ALM 026660 9.973

Set 20.9

AS FOUND

12.7

0.02%

AS FOUND

5.0

0.11%

ZERO

0.1

0.4%

10/6/92

Set

20.9

AS FOUND

12.7

0.2%

AS FOUND

5.1

0.5%

ZERO

0.1

0.4%

CARNOT

SUBJECT Portable O₂ Linearity JOB NO. 1259V

SHEET NO. of

COMPUTED BY EF DATE 10/7/92 CHECKED BY DATE
Range 25%

10/7/92

ALM 015788 12.66

Set 20.9

ALM 026680 4.973

As found 12.8

0.6 %

As found 5.2

0.9 %

Zero 0.1

0.4 %

10/7/92

Set 20.9

As found 12.7

0.2 %

As found 5.1

0.5 %

Zero 0.1

0.4 %

CARNOT

SUBJECT Portabk O₂ Linearity JOB NO. 1259

SHEET NO. of

COMPUTED BY EF DATE 10/8/92 CHECKED BY DATE
Pres. 25%

10/8/92

Set 20.9

25 form 12.7

Pres 5748

12.6 0.3%

25 form 5.1

Pres 02000

1.9 0.3%

25 form 0.1

0.4%

10/8/92

Set 20.9

25 form 12.7

0.4%

25 form 5.1

0.5%

25 form 0.1

0.4%



FAX 714-887-0549
PHONE: 714-887-2571

Shipped From: Scott SAN BERNARDINO, CA
Date Shipped 05/27/92
Our Project No: 19572
Your P.O. No: 7477-C
Page 1 of 1
Expiration Date: 11/93

2600 CAJON BLVD., SAN BERNARDINO, CA 92411

CARNOT

JIM MULLIGAN

15991 RED HILL AVE

SUITE 110

TUSTIN

CA 92680

Certified Per Traceability Protocol No. 1 Procedure No. G1
 Cylinder No. 1L2595 Cylinder Pressure 2000 PSIC
 Certified Accuracy +1% % NIST Traceable

CERTIFICATE OF ANALYSIS -- EPA PROTOCOL GASES

REFERENCE STD

[illegible]

BALANCE GAS NITROGEN

ANALYZER READINGS: Z = Zero Gas T = Test Gas R = Reference Gas

NITRIC OXIDE		
Component	05/13/92	Units
First Analysis Date		
Z 0.00	R 94.70	T 85.92
R 94.84	Z 0.11	T 85.72
Z 0.08	T 85.78	R 94.80
Mean Test Assay		
Second Analysis Date	05/20/92	Units
Z 0.00	R 95.48	T 86.38
R 95.52	Z 0.00	T 86.49
Z 0.00	T 86.45	R 95.56
Mean Test Assay		
		86.20 PPM

Component	Date	Units	mv
Z	_____	R	T
R	_____	Z	T
Z	_____	T	R
Mean Test Assay			
Date	_____	Units	mv
Z	_____	R	T
R	_____	Z	T
Z	_____	T	R
Mean Test Assay			

Component	Date	Units	mv
Z	_____	R _____	T _____
R	_____	Z _____	T _____
Z	_____	T _____	R _____
Mean Test Assay			
Date	_____	Units	mv
Z	_____	R _____	T _____
R	_____	Z _____	T _____
Z	_____	T _____	R _____
Mean Test Assay			

Chronology: Date _____
Assay _____

Analyst C. KING

Approved By: 
A.F. LANGE, Ph.D., MANAGER, QA



Scott Specialty Gases, Inc.

FAX 714-887-0549
PHONE: 714-887-2571

2600 CAJON BLVD., SAN BERNARDINO, CA 92411

CARNOT

ATTN: RICH MADRIGAL
15991 RED HILL AVE
SUITE 110
TUSTIN

CA 92680

Shipped From: Scott SAN BERNARDINO, CA
Date Shipped 07/27/92
Our Project No: 20636
Your P.O. No: 8641
Page 1 of 1
Expiration Date: 1/94

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES

Cylinder No. ALM026583 Cylinder Pressure 2050 PSIG Certified Accuracy $\pm 1\%$ % NIST Traceable

REFERENCE STD

CERTIFIED
CONC

48.73 PPM

49.86 PPM

SRM/CRM NO.

GMIS TRACEABLE

TO CRM1684B

CYL. NO.

ALM003664

CONC.

97.73 PPM

MAKE/MODEL/SERIAL NO.

THERMO-ELFECTION

10AR 14853-150

ANALYTICAL
PRINCIPLE

CHLOR-LUMINESCENT

GAS ANALYZER

LAST CAL
DATE

04/23/92

ALANCE GAS

NITROGEN

ANALYZER READINGS: Z = Zero Gas T = Test Gas R = Reference Gas

NITRIC OXIDE

Component	Date	Units	mv
Analysis Date	07/14/92		
0.00	R	96.97	T 48.29
96.95	Z	-0.35	T 48.48
-0.27	T	48.28	R 96.95
Mean Test Assay			
07/21/92			
Analysis Date			
0.00	R	96.40	T 47.72
96.33	Z	-0.20	T 47.93
-0.04	T	48.02	R 96.28
Mean Test Assay			
48.62 PPM			

Chronology: Date

Assay

Analyst G. KING

Approved By:

A.F. LANGE, Ph.D., MANAGER, QA



Shipped From: Scott SAN BERNARDINO, CA
 Date Shipped 07/27/92
 Our Project No: 20636
 Your P.O. No: 8641
 Page 1 of 1
 Expiration Date: 1/94

CARNOT

ATTN: RICH MADRIGAL
15991 RED HILL AVE
SUITE 110
TUSTIN

CA 92680

CERTIFICATE OF ANALYSIS – EPA PROTOCOL GASES

Certified Per Traceability Protocol No. 1 Procedure No. G1 Cylinder No. ALM012609 Cylinder Pressure 2000 PSIG
 Certified Accuracy ± 1% % NIST Traceable

REFERENCE STD

COMPONENTS	CERTIFIED CONC.	REFERENCE STD		GAS ANALYZER			ANALYTICAL PRINCIPLE
		SRM/CRM NO.	CYL. NO.	CONC.	MAKE/MODEL/SERIAL NO.	LAST CAL. DATE	

GAS ANALYZER

COMPONENTS	CERTIFIED CONC	SRM/CRM NO.	CYL. NO.	CONC.	MAKE/MODEL/SERIAL NO.	LAST CAL. DATE	ANALYTICAL PRINCIPLE
BON MONOXIDE	90.79 PPM	GMIS TRACEABLE	AAL657	252.0 PPM	HORIBA AIA-24	06/03/92	INFRA-RED
		TO SRM2636			4564403		

LAST CAL. DATE	ANALYTICAL PRINCIPLE
-------------------	-------------------------

BALANCE GAS

ANALYZER READINGS: Z = Zero Gas T = Test Gas R = Reference Gas

CARBON MONOXIDE

Component	Component
CARBON MONOXIDE	

First Analysis Date 07/15/92 Units mv

Z	<u>00.00</u>	R	<u>95.0</u>	T	<u>37.1</u>
R	<u>95.0</u>	Z	<u>00.04</u>	T	<u>37.1</u>
Z	<u>00.06</u>	T	<u>37.1</u>	R	<u>95.0</u>

Mean Test Assay 91.05 PPM

Mean Test Assay		91.05 PPM
Second Analysis Date	07/22/92	Units
Z	00.00	R
R	95.0	T
Z	-00.02	T
Mean Test Assay		90.53 PPM

Component	Date	Units	mv
Z	_____	R	T
R	_____	Z	T
Z	_____	T	R

Mean Test Area

Date		Mean Test Assay	
		Units	mv
Z	R		T
R	Z		T
Z	T		R

Component	Date	Units	mv
Z	_____	R	_____
R	_____	Z	_____
Z	_____	T	_____
Mean Test Assay			
		Units	mv
Z	_____	R	_____
R	_____	Z	_____
Z	_____	T	_____
Mean Test Assay			

Chronology: Date _____
Assay _____

Analyst M. JOHNSON

Approved By: A.F. LANGE, Ph.D., MANAGER, QA



Scott Specialty Gases, Inc.

2600 CAJON BLVD., SAN BERNARDINO, CA 92411

CARNOT

JIM MULLIGAN

15991 RED HILL AVE

SUITE 110

TUSTIN

CA 92680

Cylinder No. 1 Procedure No. G1

CERTIFICATE OF ANALYSIS - EPA PROTOCOL GASES

Cylinder No. 1L2958

Cylinder Pressure 2000 PSIG

Certified Accuracy $\pm 1\%$ % NIST Traceable

Certified Per Traceability Protocol No. 1

REFERENCE STD

CERTIFIED CONC

SRM/CRM NO.

CYL. NO.

CONC.

96.67 PPM

ALM010524

96.67 PPM

COMPONENTS

55.84 PPM

GMIS TRACEABLE

TO CRM1679

GAS ANALYZER

LAST CAL DATE

MAKE/MODEL/SERIAL NO.

HORIBA AIA-24

4564403

ANALYTICAL PRINCIPLE

INFRA-RED

NITROGEN

BALANCE GAS

R = Reference Gas

ANALYZER READINGS: Z = Zero Gas

T = Test Gas

CARBON MONOXIDE

mv

Units

Date

R

T

mv

Units

Date

R

T

mv

First Analysis Date 01/09/92

Units

T 23.7

Z 00.00

R 40.2

T 23.7

T 23.7

R 40.2

Z 00.01

T 23.7

R 40.2

T 23.7

Mean Test Assay 55.87 PPM

mv

Units

Date

R

T

mv

Units

Date

R

T

mv

Second Analysis Date 05/05/92

Units

T 23.7

Z 00.00

R 40.2

T 23.7

T 23.7

R 40.2

Z 00.01

T 23.7

R 40.2

T 23.7

Mean Test Assay 55.81 PPM

mv

Units

Date

R

T

mv

Units

Date

R

T

mv

Chronology: Date

Assay

Analyst M. JOHNSON

Approved By: A.F. LANGE, Ph.D., MANAGER, QA



Scott Specialty Gases, Inc.

Shipped From: 2600 CAJON BLVD.
SAN BERNARDINO CA 92411
Phone: 714-887-2571 Fax: 714-887-0549

CERTIFICATE OF ANALYSIS

CARNOT
ATTN: RICK MADRIGAL
15991 RED HILL AVE
SUITE 110
TUSTIN

CA 92680

PROJECT #: 02-21908
PO#: 8957
ITEM #: 020203000701AL
DATE: 10/02/92

CYLINDER #: ALM026680
FILL PRESSURE: 2000 PSIG

ANALYTICAL ACCURACY: +/-1%

COMPONENT	REQUESTED GAS		ANALYSIS	
	CONC	MOLES	(MOLES)	
CARBON DIOXIDE	15.	PCT	14.98	PCT
OXYGEN	5.	PCT	4.973	PCT
NITROGEN		BAL		BAL

CARNOT 10/1 TONNIO
CERTIFIED TO HAVE BEEN BLENDED
AND VERIFIED TO BE CORRECT BY
ANALYSIS.

GRAVIMETRIC MASTER GAS -
AGAINST NIST CERTIFIED WEIGHTS
INDEPENDENT LABORATORY

ANALYST:

JOSEPH DE LA TORRE

APPROVED BY:

DR ARNOLD LANGE PH D



Scott Specialty Gases, Inc.

ipped 2600 CAJON BLVD. SAN BERNARDINO CA 92411-0000
From: Phone: 714-887-2571 Fax: 714-887-0549

CERTIFICATE OF ANALYSIS

CARNOT
MIKE SCHMITT
15991 RED HILL AVE
SUITE 110
TUSTIN

CA 92680

PROJECT #: 02-17313
PO#: 7477
ITEM #: 0202C3000701AL
DATE: 12/16/91

CYLINDER #: ALM015788

ANALYTICAL ACCURACY: +/-1%

COMPONENT	REQUESTED GAS	ANALYSIS
	CONC MOLES	(MOLES)
CARBON DIOXIDE	15. PCT	15.23 PCT
OXYGEN	12.5 PCT	12.66 PCT
NITROGEN	BAL	BAL

CYLINDER PRESSURE 1915 PSI
CERTIFIED TO HAVE BEEN BLENDED
AND VERIFIED TO BE CORRECT BY
ANALYSIS.

GRAVIMETRIC MASTER GAS -
AGAINST NIST CERTIFIED WEIGHTS
INDEPENDENT LABORATORY

ANALYST:

MAYNARD JOHNSON

APPROVED BY:

DR ARMAND LANGE, PHD



Scott Specialty Gases, Inc.

Shipped
From:

2600 CAJON BLVD.

SAN BERNARDINO

CA 92411

Phone: 714-887-2571

Fax: 714-887-0549

CERTIFICATE OF ANALYSIS

CARNOT

ATTN: RICH MADRIGAL

15991 RED HILL AVE

SUITE 110

TUSTIN

CA 92680

PROJECT #: 02-20636

PO#: 8641

ITEM #: 0202C3013601AL

DATE: 7/15/92

CYLINDER #: ALM012263

FILL PRESSURE: 1900 PSIG

ANALYTICAL ACCURACY: +/-1%

COMPONENT

CARBON DIOXIDE

OXYGEN

NITROGEN

REQUESTED GAS

CONC MOLES

22.5 PCT

8. PCT

BAL

ANALYSIS

(MOLES)

22.15 PCT

7.926 PCT

BAL

CARNOT 7/16 BIN 1
CERTIFIED TO HAVE BEEN BLENDED
AND VERIFIED TO BE CORRECT BY
ANALYSIS.

GRAVIMETRIC MASTER GAS -
AGAINST NIST CERTIFIED WEIGHTS
INDEPENDENT LABORATORY

ANALYST:

M.J.

MAYNARD JOHNSON

APPROVED BY:

O. Lange

DR ARMAND LANGE PHD



Scott Specialty Gases, Inc.

Shipped 2600 CAJON BLVD. SAN BERNARDINO CA 92411-0000
om: Phone: 714-887-2571 Fax: 714-887-0549

CERTIFICATE OF ANALYSIS

CARNOT
JIM MULLIGAN
15991 RED HILL AVE
SUITE 110
TUSTIN

CA 92680

PROJECT #: 02-18807
PO#: 7477-B #1
ITEM #: 0202C3000701AL
DATE: 3/18/92

CYLINDER #: AAL12047

ANALYTICAL ACCURACY: +/-1%

COMPONENT	REQUESTED GAS		ANALYSIS	
	CONC	MOLES	(MOLES)	
CARBON DIOXIDE	15.	PCT	15.00	PCT
OXYGEN	5.	PCT	4.990	PCT
NITROGEN		BAL		BAL

CYLINDER PRESSURE 1900 PSI
CERTIFIED TO HAVE BEEN BLENDED
AND VERIFIED TO BE CORRECT BY
ANALYSIS.

GRAVIMETRIC MASTER GAS -
AGAINST NIST CERTIFIED WEIGHTS
INDEPENDENT LABORATORY

ANALYST:

MAYNARD JOHNSON

APPROVED BY:

DR ARMAND LANGE PHD

DRY GAS METER CALIBRATION

BAROMETRIC PRESSURE 29.98

FIELD METER			TEST METER				RESULTS				
VOLUME cu.ft.	TEMP. a 'F	DELTA H "H2O	TIME min.	VOLUME cu.ft.	TEMP. 'F	PRESS. "H2O	Q cfm	Y	Hq	AVE. Y	AVG. Hq
6.189	82.0	0.50	15	6.254	76.0	0.15	0.413	1.022	1.61	1.0281	1.60
6.218	90.0	0.50	15	6.251	76.0	0.15	0.415	1.032	1.59		
6.208	91.0	0.50	15	6.223	76.0	0.15	0.414	1.031	1.60		
6.163	80.0	0.80	12	6.285	76.0	0.25	0.514	1.027	1.64	1.0399	1.64
6.094	87.0	0.80	12	6.247	76.0	0.25	0.508	1.046	1.63		
6.113	90.0	0.80	12	6.243	76.0	0.25	0.509	1.047	1.63		
5.601	91.0	1.00	10	5.725	76.0	0.30	0.560	1.050	1.68	1.0497	1.68
5.612	92.0	1.00	10	5.729	76.0	0.30	0.561	1.050	1.67		
5.637	94.0	1.00	10	5.728	76.0	0.30	0.564	1.049	1.67		
5.570	87.0	2.00	7	5.671	76.0	0.55	0.796	1.035	1.69	1.0338	1.73
5.481	90.0	2.00	7	5.532	76.0	0.55	0.783	1.032	1.76		
5.539	92.0	2.00	7	5.580	76.0	0.55	0.791	1.034	1.73		
5.801	93.0	3.00	6	5.828	76.0	0.75	0.967	1.030	1.74	1.0336	1.74
5.789	95.0	3.00	6	5.824	76.0	0.75	0.965	1.036	1.74		
5.803	95.0	3.00	6	5.835	76.0	0.75	0.967	1.035	1.73		
AVERAGE Yd = 1.0370											1.68

DRY GAS METER CALIBRATION DATA

TEST METER ID. ES-12

TEST METER Y.

DATE LAST CALIB.

TE 9-4-92 BY ABM

LD DRY GAS METER ID ES-19

BAROMETRIC PRESSURE (P_B) (IN. Hg)

METER LEAK CHECK VAC. 2.4" H₂O INIT.

ROMETRIC PRESSURE (P ₂) — (IN. H ₂ O)															TEST METER														
ΔH	FIELD DRY GAS METER										TEMPERATURES, °F																		
	FINAL VOLUME	INITIAL VOLUME	VOLUME (V ₂ -V ₁)	INLET		OUTLET		AVERAGE	TIME (Ø) MIN.	FINAL VOLUME	INITIAL VOLUME	VOLUME (V ₂ -V ₁)	INLET		OUTLET		AVERAGE	PRESSURE IN. H ₂ O											
				BEG.	END	BEG.	END						BEG.	END	BEG.	END													
0.50	508.825	502.636	6.189	79	91	78	81	82	15:12:31	006.254	0.00	6.254	76	76	76	76	76	.15											
	515.043	508.825	6.218	94	96	83	85	90	15:12:47	012.505	006.254	6.251	76	76	76	76	76	.15											
	521.251	515.043	6.208	93	97	86	88	91	15:13:03	018.728	012.505	6.223	76	76	76	76	76	.15											
0.80	527.788	521.625	6.163	76	90	75	78	80	14:20	006.285	0.00	6.285	76	76	76	76	76	.25											
	533.802	527.788	6.014	90	96	79	83	87	14:33	012.532	006.285	6.247	76	76	76	76	76	.75											
	539.995	533.802	6.113	92	99	83	86	90	12:14:45	018.775	012.532	6.243	76	76	76	76	76	.25											
1.00	546.601	540.400	5.601	91	100	86	88	91	15:01	005.725	0.00	5.725	76	76	76	76	76	.30											
	551.613	546.001	5.612	91	101	86	89	92	15:12	011.454	005.725	5.729	76	76	76	76	76	.30											
	557.250	551.613	5.637	96	102	89	90	94	10:15:33	017.182	011.454	5.728	76	76	76	76	76	.30											
2.00	563.421	557.851	5.570	84	94	84	84	87	15:51	005.671	0.00	5.671	76	76	76	76	76	.55											
	568.902	563.421	5.481	92	98	84	85	90	07:15:58	011.203	005.671	5.532	76	76	76	76	76	.55											
	574.441	568.902	5.539	95	100	86	87	92	15:59	016.783	011.203	5.580	76	76	76	76	76	.55											
3.00	580.896	575.095	5.801	96	102	87	88	93	07:16:07	005.828	0.00	5.828	76	76	76	76	76	.75											
	586.685	580.896	5.789	98	103	88	89	95	16:16	011.652	005.828	5.824	76	76	76	76	76	.75											
	592.488	586.685	5.803	99	103	89	90	95	16:23	017.487	011.652	5.835	76	76	76	76	76	.75											

CARNOT

CARNOT
 CALIBRATED BY DE
 DATE 10/09/92
 FIELD GAS METER I.D. 71-4
 INITIAL Yd 1.004
 INITIAL H@ 1.881

POST TEST DRY GAS METER CALIBRATION CHECK
 DATA ENTRY BY DE
 BAROMETRIC PRESSURE 29.91
 TEST MEETER ES-13
 TEST METER Y (Yt) 1.0014
 TEST METER LAST CAL. 12/16/91

FIELD METERR					TEST METER			RESULTS	
VOLUME cu.ft.	TEMP.a IN	TEMP OUT	DELTA "H2O	TIME min.	VOLUME cu.ft.	TEMP. 'F	Q cfm	Y	H@
5.367	72.0	71.0	1.00	10	5.444	71.0	0.537	1.013	1.89
5.376	79.5	74.0	1.00	10	5.432	73.0	0.538	1.015	1.91
5.479	81.5	76.5	1.00	10	5.416	74.0	0.548	0.995	1.92

AVERAGES 1.008 1.91

PASS - INDIVIDUAL Yd VALUES ACCEPTABLE
 PASS - INDIVIDUAL DELTA H@ VALUES ACCEPTABLE
 PASS - POST TEST Yd WITHIN LIMITS

CARNOT
 CALIBRATED BY DE
 DATE 10/09/92
 FIELD GAS METER I.D. 71-5
 INITIAL Yd 1.004
 INITIAL H@ 1.881

POST TEST DRY GAS METER CALIBRATION CHECK
 DATA ENTRY BY DE
 BAROMETRIC PRESSURE 29.91
 TEST MEETER ES-13
 TEST METER Y (Yt) 1.0014
 TEST METER LAST CAL. 12/16/91

FIELD METERR					TEST METER			RESULTS	
VOLUME cu.ft.	TEMP.a IN	TEMP OUT	DELTA "H2O	TIME min.	VOLUME cu.ft.	TEMP. 'F	Q cfm	Y	H@
5.698	70.5	70.0	1.00	10	5.832	76.0	0.570	1.010	1.68
5.700	73.5	70.5	1.00	10	5.831	76.5	0.570	1.012	1.69
5.684	76.5	73.0	1.00	10	5.786	77.5	0.568	1.010	1.71
AVERAGES								1.011	1.70

PASS - INDIVIDUAL Yd VALUES ACCEPTABLE
 PASS - INDIVIDUAL DELTA H@ VALUES ACCEPTABLE
 PASS - POST TEST Yd WITHIN LIMITS

CARNOT

DRY GAS METER CALIBRATION

FIELD GAS METER I.D. SCE N.OUTLET TEST METER ES-13
 DATE 9/16/92 TEST METER LAST CAL. 12/16/91 1.0014 = Yt
 BAROMETRIC PRESSURE 29.96

FIELD METER		TEST METER					RESULTS				
VOLUME	TEMP. a	DELTA H	TIME	VOLUME	TEMP.	PRESS.	Q	Y	H0	AVE. Y	AVG. H0
cu.ft.	'F	"H2O	min.	cu.ft.	'F	"H2O	cfm				
5.391	92.0	0.50	15	5.131	74.0	0.10	0.359	0.984	2.33	0.9894	2.34
5.360	96.0	0.50	15	5.107	74.0	0.10	0.357	0.992	2.34		
5.376	97.0	0.50	15	5.112	74.0	0.10	0.358	0.992	2.33		
7.624	96.0	0.80	12	7.129	74.0	0.30	0.635	0.973	1.23	0.9750	1.48
7.262	100.0	0.80	12	6.784	75.0	0.30	0.605	0.977	1.35		
6.224	99.0	0.80	12	5.809	75.0	0.30	0.519	0.975	1.84		
7.759	100.0	1.00	10	7.213	75.0	0.50	0.776	0.972	1.03	0.9702	1.04
7.800	100.0	1.00	10	7.231	76.0	0.50	0.780	0.968	1.03		
7.789	101.0	1.00	10	7.234	76.0	0.50	0.779	0.971	1.03		
8.820	92.0	2.00	7	8.293	76.0	1.00	1.260	0.965	0.78	0.9697	0.78
8.849	99.0	2.00	7	8.270	76.0	1.00	1.264	0.971	0.77		
8.836	100.0	2.00	7	8.257	76.0	1.00	1.262	0.973	0.78		
9.690	101.0	3.00	6	9.033	76.0	1.60	1.615	0.970	0.71	0.9700	0.72
9.699	103.0	3.00	6	9.146	77.0	1.60	1.617	0.983	0.69		
9.724	102.0	3.00	6	8.949	77.0	1.60	1.621	0.957	0.73		
AVERAGE Yd =										0.9748	1.27
										*****	*****

::

DRY GAS METER CALIBRATION DATA

DATE 9-16-92 BY Lab M. TEST METER ID. ES-13

FIELD DRY GAS METER ID SCC/North Outlet TEST METER Y, _____

BAROMETRIC PRESSURE (P_b) 29.92 (IN. Hg) METER LEAK CHECK VAC. 10" INIT. Rm DATE LAST CALIB. _____

ΔH	FIELD DRY GAS METER										TIME (MIN.)	TEST METER									
	FINAL VOLUME	INITIAL VOLUME	VOLUME (V ₁)"I"	TEMPERATURES, °F						FINAL VOLUME		INITIAL VOLUME	VOLUME (V ₂)"I"	TEMPERATURES, °F							
				INLET BEG.	INLET END	OUTLET BEG.	OUTLET END	AVERAGE	INLET BEG.					INLET END	OUTLET BEG.	OUTLET END	AVERAGE				
0.50	831.332	825.441	5.891	101	113	76	92	005.131	0.00	5.131	74	74	74	74	74	74	1.0				
	836.692	831.332	5.36	111	117	77	96	010.238	005.131	5.107	74	74	74	74	74	74	1.0				
	842.068	836.692	5.376	115	119	77	97	015.350	010.238	5.112	74	74	74	74	74	74	1.0				
0.80	850.042	842.468	7.624	110	119	78	96	007.129	0.00	7.129	74	74	74	74	74	74	1.30				
	857.354	850.042	7.262	119	125	78	100	013.913	007.129	6.784	75	75	74	74	74	75	1.30				
	863.578	857.354	6.224	121	122	77	99	019.722	013.913	5.809	75	76	74	74	74	75	1.30				
1.00	871.883	864.164	7.759	121	126	76	100	007.213	0.00	7.213	76	76	74	75	75	75	1.50				
	879.663	871.883	7.80	122	124	76	100	014.444	007.213	7.231	76	76	75	75	75	76	1.50				
	887.452	879.663	7.789	121	128	76	101	021.678	014.444	7.234	76	76	75	75	75	76	1.50				
2.00	917.458	908.638	8.82	98	116	78	92	008.293	0.00	8.293	76	76	75	75	75	76	1.0				
	926.307	917.458	8.849	116	124	78	99	016.563	008.293	8.27	76	76	75	75	75	76	1.0				
	935.143	926.307	8.836	120	127	78	100	024.820	016.563	8.257	76	76	75	75	75	76	1.0				
3.00	945.312	935.852	9.690	125	128	76	101	009.033	0.00	9.033	76	77	75	76	76	76	1.60				
	955.241	945.542	9.699	127	132	76	103	018.179	009.033	9.146	77	77	76	76	77	77	1.60				
	964.965	955.241	9.724	127	133	75	102	027.128	018.179	8.949	77	77	76	76	77	77	1.60				

CARNOT

APPENDIX C
DATA SHEETS

Appendix C.1
Sample Locations

PLANT: SCE/Alamitos DATA BY: Rob M.
DATE: 10-7-92
TEST LOCATION: Units #1 & 2

[illegible]

7
7
7
7
7
7
7
7
7

Appendix C.2
Unit Data

UNIT DATA

 Client: _____
 Unit: _____

 Location: _____
 Data by: _____

TEST #	1-2	1-2	2-2	3-2
DATE	10/5/92	10/6/92	10/6/92	10/6/92
TIME		1040	1225	1310
LOAD MW		1.6		1.6
AUX. LOAD		7.4		8.5
UREA ON/OFF		OFF		OFF
UREA MODE		5		2
UREA FLOW GPM				
UREA H ₂ O FLOW GPM				
UREA H ₂ O PRES. PSI				4.5/7.5
UREA HEADER PRES. PSI				235.0
TANK		161.5		2147.9
O ₂ % EAST		1.3		1.2
O ₂ % WEST		1.2		1.5
STM. PRES PSI		1774		1842
FUEL FLOW 10 ⁶ SCFH	1.7	1.7	1.7	1.7
FUEL				
WP/FURN dP				
ID FAN EAST (AMPS)				
FD FAN EAST (AMPS)				
ID FAN WEST (AMPS)				
FD FAN WEST (AMPS)				

* INCORRECT RECORDING OF FUEL FLOW AT 10/6/92 1040
 READING 1.7 SCFH

FGR (AMPS)	216	070	242	270
BOOS	15-14	15-14	15-12	14-15
APH OUT EAST °F	332.2		334.1	335
APH OUT WEST °F	345.4		343.6	345
TBCT # 1234	W-57E74 14			

NOTES:

UNIT DATA

Client: 521
 Unit: ALPHA TOS #2

Location: _____
 Data by: WDE/EE

TEST #	3-2	4-2	4-2	5-2
DATE	10/6/92	10/6/92	10/6/92	10/6/92
TIME	1437	1545	1705	1745
LOAD MW	16.5	16.6	16.6	16.5
AUX. LOAD	2.2	2.3	2.3	2.3
UREA ON/OFF	OFF	ON	ON	ON
UREA MODE	—	4	4	4
UREA FLOW GPM	0.1/1.1	0.1/0.1/0.1	0.1/0.1/0.1	0.1/0.1/0.1
UREA H ₂ O FLOW GPM	1.1	1.78/1.8	1.7/1.8	1.7/1.8
UREA H ₂ O PRES. PSI	3.1/3.1/3.1	3.1/30.0/30.0	3.1/30.0/30.0	3.1/30.0/30.0
UREA HEADER PRES. PSI	25.8	26.4	27.5	27.5
TANK / LEVEL	105/47.7	102/42.3	102/32.6	102/29.5
O ₂ % EAST	1.6	1.6	1.5	1.6
O ₂ % WEST	1.4	1.4	1.4	1.4
STM. PRES PSI	1845	1846	1847	1846
FUEL FLOW 10 ⁶ SCF	1.70	1.71	1.70	1.71
FUEL	NATURAL GAS	NATURAL GAS	NATURAL GAS	NATURAL GAS
WP/FURN dP	6.2	6.2	6.2	6.2
ID FAN EAST (AMPS)	132	138	138	132
FD FAN EAST (AMPS)	71	71	71	71
ID FAN WEST (AMPS)	135	135	136	135
FD FAN WEST (AMPS)	72	72	72	72

FGR (AMPS)	270	270	270	
BOOS	14-15	14-15	14-15	14+5
APH OUT EAST °F 8	337	341	340	340
APH OUT WEST °F 7	347	348	349	348
TEST #				

NOTES:

UNIT DATA

Client: SCS
 Unit: ALAN - OS #2

Location:
 Data by: MDE/EF

TEST #	5-2			
DATE	10/6/92			
TIME	1900			
LOAD MW	18.3			
AUX. LOAD	8.3			
UREA ON/OFF	ON			
UREA MODE	4			
UREA FLOW GPM	0/1.59/1.5			
UREA H ₂ O FLOW GPM	17.2/15.2			
UREA H ₂ O PRES. PSI	3.2/2.2/2.2			
UREA HEADER PRES. PSI	27.5			
TANK	12.2/12.2			
O ₂ % EAST	10.5			
O ₂ % WEST	10.4			
STM. PRES PSI	17.44			
FUEL FLOW 10 ⁶ SCF	1.70			
FUEL	145.24			
WP/FURN dP	3.2			
ID FAN EAST (AMPS)	50			
FD FAN EAST (AMPS)	71			
ID FAN WEST (AMPS)	136			
FD FAN WEST (AMPS)	71			

FGR (AMPS)	270			
BOOS	14-15			
APH OUT EAST °F 8	340			
APH OUT WEST °F 7	347			
TEST#				

NOTES:

UNIT DATA

 Client: Su
 Unit: 2

 Location: 11/14/92
 Data by:

TEST #	6-2	6-2	7-2	7-2
DATE	10/7/92	10/7/92	10/7/92	10/7/92
TIME	8:55	9:10	11:10	12:15
LOAD MW	137	137	138	138
AUX. LOAD	7.5	7.5	7.5	7.5
UREA ON/OFF	OFF	OFF	OFF	
UREA MODE	0	1	0	0
UREA FLOW GPM	0.0/0.0/0.0		0.0/0.0	0.0/0.0/0.0
UREA H ₂ O FLOW GPM			1.0/1.0	0.0/0.0/0.0
UREA H ₂ O PRES. PSI		1.1/1.1/1.1	3.2/7.5/13.0	3.3/7.6/14.0
UREA HEADER PRES. PSI			142.1	144.5
TANK / LEVEL IN.	102/50.8	102/50.8	102/50.8	102/50.8
O ₂ % EAST	2.2	2.5	2.2	2.5
O ₂ % WEST	2.2	2.5	2.5	2.5
STM. PRES PSI	1840	1840	1840	1841
FUEL FLOW 10 ⁶ SCF	1.35	1.35	1.35	1.35
FUEL	0.0/0.0	0.0/0.0	0.0/0.0	0.0/0.0
WP/FURN dP	-4.7	-4.7	-4.7	+4.7
ID FAN EAST (AMPS)	115	115	115	115
FD FAN EAST (AMPS)	65	65	65	69
ID FAN WEST (AMPS)	120	120	120	120
FD FAN WEST (AMPS)	67	67	67	67

FGR (AMPS)	250	255	255	255
BOOS	13,14,15,16	13,14,15,16	13,14,15,16	13,14,15,16
APH OUT EAST °F	305.9	303.5	303	303.1
APH OUT WEST °F	350.6	351.1	351	350.9
TEST #				

NOTES:

UNIT DATA

Client: SCSUnit: ALANITJS #2Location: ALANITJSData by: MDE/EF

TEST #	8-2	8-2	9-2	9-2
DATE	10/7/92	10/7/92	10/7/92	10/7/92
TIME	1335	1500	1540	1705
LOAD MW	137	137	132	138
AUX. LOAD	7.6	7.6	7.6	7.6
UREA ON/OFF	ON	ON	ON	ON
UREA MODE	3	3	3	3
UREA FLOW GPM	304/3.7/3.0	304/3.7/3.0	304/3.7/3.0	304/3.7/3.0
UREA H ₂ O FLOW GPM	2/7.8/2	2/7.8/2	2/7.8/2	2/7.8/2
UREA H ₂ O PRES. PSI	3.1/30.1/13.1	3.2/30.1/13.1	3.4/30.1/13.1	3.4/30.1/13.1
UREA HEADER PRES. PSI	95.3	96.6	96.9	97.3
TANK / LEV. IN.	102/48.4	106/43.9	102/41.3	102/36.2
O ₂ % EAST	2.1	2.0	2.2	2.2
O ₂ % WEST	2.4	2.5	2.5	2.4
STM. PRES PSI	1841	1843	1847	1845
FUEL FLOW 10 ⁶ SCFH	1.35	1.35	1.35	1.35
FUEL	177.345	177.345	177.345	177.345
WP/FURN dP	4.8	4.8	4.8	4.7
ID FAN EAST (AMPS)	116	116	116	116
FD FAN EAST (AMPS)	59	59	59	59
ID FAN WEST (AMPS)	160	120	125	150
FD FAN WEST (AMPS)	67	67	66	67

FGR (AMPS)	255	255	250	255
BOOS	13-16	13-16	1314/1515	13-16
APH OUT EAST °F 8	308	309	310.9	313
APH OUT WEST °F 7	353	355	356.1	356
TEST #				

NOTES:

UNIT DATA

 Client: _____
 Unit: _____

 Location: _____
 Data by: _____

TEST #	10-2	10-2	11-2	11-2
DATE	10/14/92	10/18/92	10/18/92	11/1/92
TIME	1:05	1:10	1:05	1:10
LOAD MW	2.0	2.0	2.4	2.4
AUX. LOAD	1.2	1.2	1.2	1.2
UREA ON/OFF	ON	ON	ON	ON
UREA MODE	1		1	
UREA FLOW GPM	1000	1000	1000	1000
UREA H ₂ O FLOW GPM	1000	1000	1000	1000
UREA H ₂ O PRES. PSI	100	100	100	100
UREA HEADER PRES. PSI	100	100	100	100
TANK	100	100	100	100
O ₂ % EAST	100	100	100	100
O ₂ % WEST	100	100	100	100
STM. PRES PSI	100	100	100	100
FUEL FLOW 10 ⁵ SCF	1.0	1.0	1.0	1.0
FUEL	100	100	100	100
WP/FURN dP	100	100	100	100
ID FAN EAST (AMPS)	100	100	100	100
FD FAN EAST (AMPS)	100	100	100	100
ID FAN WEST (AMPS)	100	100	100	100
FD FAN WEST (AMPS)	100	100	100	100

FGR (AMPS)	32.1	32.1	32.2	32.0
BOOS	14, 515/12	14, 515/12	13, 115/14	13, 131/11
APH OUT EAST °F	277.6	277.2	270.1	270.8
APH OUT WEST °F	277.2	277.1	273.9	275.2
TEST #				

NOTES:

UNIT DATA

Client: _____
Unit: _____

Location: _____
Data by: _____

TEST #	10-2	10-2	10-2	10-2
DATE	10-2	10-2	10-2	10-2
TIME	10-2	10-2	10-2	10-2
LOAD MW	10-2	10-2	10-2	10-2
AUX. LOAD	10-2	10-2	10-2	10-2
UREA ON/OFF	10-2	10-2	10-2	10-2
UREA MODE	10-2	10-2	10-2	10-2
UREA FLOW GPM	10-2	10-2	10-2	10-2
UREA H ₂ O FLOW GPM	10-2	10-2	10-2	10-2
UREA H ₂ O PRES. PSI	10-2	10-2	10-2	10-2
UREA HEADER PRES. PSI	10-2	10-2	10-2	10-2
TANK	10-2	10-2	10-2	10-2
O ₂ % EAST	10-2	10-2	10-2	10-2
O ₂ % WEST	10-2	10-2	10-2	10-2
STM. PRES PSI	10-2	10-2	10-2	10-2
FUEL FLOW 10 ⁶ SCF	10-2	10-2	10-2	10-2
FUEL	10-2	10-2	10-2	10-2
WP/FURN dP	10-2	10-2	10-2	10-2
ID FAN EAST (AMPS)	10-2	10-2	10-2	10-2
FD FAN EAST (AMPS)	10-2	10-2	10-2	10-2
ID FAN WEST (AMPS)	10-2	10-2	10-2	10-2
FD FAN WEST (AMPS)	10-2	10-2	10-2	10-2

FGR (AMPS)	352.1	332	332	332
BOOS	317.5	310.1	310.1	310.1
APH OUT EAST °F	289.0	290.1	290.0	272.9
APH OUT WEST °F	341.3	336.3	347.0	341.3
TEST #				

NOTES:

Appendix C.3
CEM Data

CARNOT

PAGE 1 OF 1

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCE Unit 2CONDITION: 165 MW No UreaDATE: 10-6-97OPERATOR: CHFTEST NUMBER: 1-2-CFMTEST LOCATION: Exhaust

TEST NO.	TIME		SAMPLE POINT/ CONDITION	DRY, UNCORRECTED						CORRECTED TO % DRY		
				O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx
SPAN GAS CONCENTRATION												
			AS FOUND ANAL SPAN	4.99	15.00	55.84	90.52					
	958		SYSTEM ZERO	.05	0.0	0.0	0.5					
			SYSTEM SPAN	4.93	14.35	56.0	87.2					
	BEGIN	1012	Start									
	END	1017	All Probe	2.64	10.15	0.9	139.3					
	BEGIN	1017										
	END	1022		2.74	10.24	0.7	139.5					
	BEGIN	1022										
	END	1027		2.86	10.00	.8	142.5					
	BEGIN	1027										
	END	1032		2.88	10.00	.8	143.8					
	BEGIN	1032										
	END	1037		2.90	10.00	.7	144.5					
	BEGIN	1037	NOx Probe									
	END	1042	/NO				107	101.3	5.75			
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
			SYSTEM ZERO	.06	.03	0.0	1.75					
			SYSTEM SPAN	4.94	14.58	55.4	87.5					
RAW AVERAGE				2.804	10.03	0.70	141.12					
CORRECTED AVERAGE												
COMMENTS:												

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCE Unit 2CONDITION: 165 MW No UreaDATE: 10-1-11OPERATOR: CHFTEST NUMBER: 2-2-CEMTEST LOCATION: Exhaust

TEST NO.	TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO ____%____, DRY		
			O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION												
		AS FOUND ANAL SPAN										
	1113	SYSTEM ZERO	.03	0.0	0.0	.75						
		SYSTEM SPAN	49.8	14.8	55.84	87.5						
	BEGIN 1130 END 1135	Star. All H ₂ O	2.64	10.3	1.0	136.0						
	BEGIN 1135 END 1140		2.62	10.3	0.9	136.0						
	BEGIN 1140 END 1145		2.60	10.3	0.8	136.3						
	BEGIN 1145 END 1150		2.60	10.3	0.8	135.8						
	BEGIN 1150 END 1155		2.60	10.3	0.9	135.5						
	BEGIN 1155 END 1200	End	2.54	10.3	0.8	135.5						
	BEGIN 1200 END 1205	NOx Precon				105	96.3	8.75				
	BEGIN END											
	BEGIN END											
	BEGIN END											
	BEGIN END											
	BEGIN END											
		SYSTEM ZERO	0.02	0.0	0.0	1.0						
		SYSTEM SPAN	4.96	14.8	55.8	88.0						
RAW AVERAGE												
CORRECTED AVERAGE												
COMMENTS:												

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCE Unit 2CONDITION: 10:10 AM 11, JanDATE: 10-6-92OPERATOR: CHPTEST NUMBER: 2-2-CEMTEST LOCATION: Exhaust

TEST NO.	TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO ____%____ DRY		
			O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION												
		AS FOUND ANAL SPAN	7.926	22.15								
	1241	SYSTEM ZERO	0.2	0.0	0.0	0.5						
		SYSTEM SPAN	7.80	21.68	55.84	90.0						
	BEGIN 1315 END 1320	Start All Pumps	2.45	10.4	1.5	143.8						
	BEGIN 1320 END 1325		2.42	10.4	1.6	142.8						
	BEGIN 1325 END 1330		2.40	10.4	1.9	141.0						
	BEGIN 1330 END 1335		2.40	10.4	1.9	141.0						
	BEGIN 1335 END 1340		2.37	10.4	2.0	140.2						
	BEGIN 1340 END 1345		2.39	10.4	2.5	140.0						
	BEGIN 1345 END 1350	NOx Probe Notched				106.8	98	8.8				
	BEGIN END											
	BEGIN END											
	BEGIN END											
	BEGIN END											
	BEGIN END											
		SYSTEM ZERO	0.03	0.0	0.0	0.5						
		SYSTEM SPAN	7.90	21.6	55.8	91.6						
RAW AVERAGE												
CORRECTED AVERAGE												
COMMENTS:												

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCECONDITION: 165MW Urea ONDATE: 10-6-97OPERATOR: CHFTEST NUMBER: 4-2-CFM

TEST LOCATION: _____

TEST NO.	TIME.		SAMPLE POINT/ CONDITION	DRY, UNCORRECTED						CORRECTED TO ____% ____, DRY			
				O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION													
			AS FOUND ANAL. SPAN	7.93	22.15	55.84	90.52						
	1605		SYSTEM ZERO	.05	0.0	0.0	1.25						
			SYSTEM SPAN	7.83	22.0	56	88.5						
	BEGIN 1615			2.4	10.5	3.8	104.8						
	END 1620												
	BEGIN 1620			2.4	10.5	3.2	105.0						
	END 1625												
	BEGIN 1625			2.4	10.5	3.8	105.2						
	END 1630												
	BEGIN 1630			2.42	10.5	3.5	105.8						
	END 1635												
	BEGIN 1635			2.42	10.5	3.7	106.5						
	END 1640												
	BEGIN 1640			2.41	10.45	3.1	107						
	END 1645												
	BEGIN		NOx V. NOx				81.3	76.0	5.3				
	END		NOx V. NOx										
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												
	END												
	BEGIN												

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCECONDITION: 165 MW Urea ONVDATE: 10-6-92OPERATOR: CHFTEST NUMBER: 5-2-CFM

TEST LOCATION: _____

TEST NO.	TIME.	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO ____%____, DRY		
			O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION												
		AS FOUND ANAL. SPAN										
	1805	SYSTEM ZERO	.02	0.0	0.1	.75						
		SYSTEM SPAN	7.85	22.05	55.7	89.5						
	BEGIN 1815 END 1820	Start A.I.P. probe	2.45	10.5	5.8	103.6						
	BEGIN 1820 END 1825		2.41	10.5	5.4	103.3						
	BEGIN 1825 END 1830		2.41	10.5	6.2	102.8						
	BEGIN 1830 END 1835		2.4	10.5	5.8	102.5						
	BEGIN 1835 END 1840		2.4	10.5	6.5	102.5						
	BEGIN 1840 END 1845		2.4	10.5	6.0	101.8						
	BEGIN END											
	BEGIN 1955 END	NOx/NO				78.3	73.0	5.3				
	BEGIN END											
	BEGIN END											
	BEGIN END											
	BEGIN END											
	1847	SYSTEM ZERO	.02	0.0	0.1	.50						
		SYSTEM SPAN	7.90	21.98	55.84	90.75						
RAW AVERAGE												
CORRECTED AVERAGE												
COMMENTS:												

CARNOT

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCF AlumCONDITION: 140 MW Urea OffDATE: 10-7-92OPERATOR: CHFTEST NUMBER: 6-2-CFM

TEST LOCATION: _____

TEST NO.	TIME.		SAMPLE POINT/ CONDITION	DRY, UNCORRECTED						CORRECTED TO ____%____, DRY		
				O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx
SPAN GAS CONCENTRATION												
			AS FOUND ANAL. SPAN	4.97	14.98	55.6	88.25					
		900	SYSTEM ZERO	.03	0.0	.3	.75					
			SYSTEM SPAN	4.97	14.75	55.84	88.25					
	BEGIN	910	Start									
	END	915	Alf. Probe	3.39	9.83	1.0	80.0					
	BEGIN	915										
	END	920		3.35	9.8	1.0	80.0					
	BEGIN	920										
	END	925		3.35	9.8	1.0	80.8					
	BEGIN	925										
	END	930		3.37	9.8	1.0	81.25					
	BEGIN	930										
	END	935		3.38	9.8	1.0	81.25					
	BEGIN	935										
	END	940		3.38	9.8	1.0	80.8					
	BEGIN	---										
	END	---										
	BEGIN	955	NOx									
	END	---	Probe				47.0	43.8	3.2			
	BEGIN	---										
	END	---										
	BEGIN	---										
	END	---										
	BEGIN	---										
	END	---										
	BEGIN	---										
	END	---										
			SYSTEM ZERO	.02	0.0	.3	.75					
			SYSTEM SPAN	4.97	14.7	55.9	88.3					
RAW AVERAGE				3.37	9.8	1.0	80.8					
CORRECTED AVERAGE												
COMMENTS:												

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCE AlamitosCONDITION: 140mw Upn OFFDATE: 10-7-97OPERATOR: CHFTEST NUMBER: 7-2-CEM

TEST LOCATION: _____

TEST NO.	TIME		SAMPLE POINT/ CONDITION	DRY, UNCORRECTED						CORRECTED TO ____%____, DRY		
				O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx
SPAN GAS CONCENTRATION												
			AS FOUND ANAL. SPAN									
			SYSTEM ZERO	.02	0.0	.2	.50					
			SYSTEM SPAN	4.92	14.75	55.5	50.0					
	BEGIN	1130										
	END	1135		3.62	9.68	0.2	80.8					
	BEGIN	1135										
	END	1140		3.62	9.68	0.7	80.7					
	BEGIN	1140										
	END	1145		3.61	9.68	0.7	80.8					
	BEGIN	1145										
	END	1150		3.61	9.70	0.7	80.8					
	BEGIN	1150										
	END	1155		3.61	9.7	.7	80.8					
	BEGIN	1155										
	END	1200		3.61	9.7	.7	80.8					
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
	BEGIN	1220	NOx Ppt				46.2	44.5	1.8			
	END	1225	NOx Ppt									
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
			SYSTEM ZERO	.02	.05	.2	.50					
			SYSTEM SPAN	4.91	14.70	55.94	87.5					
RAW AVERAGE												
CORRECTED AVERAGE												
COMMENTS:												

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCIE / AL 2CONDITION: 140 mm Urea ONDATE: 10-7-92OPERATOR: CHFTEST NUMBER: 2-2-CFM

TEST LOCATION: _____

TEST NO.	TIME		SAMPLE POINT/ CONDITION	DRY, UNCORRECTED						CORRECTED TO ____%____, DRY		
				O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx
SPAN GAS CONCENTRATION												
			AS FOUND ANAL. SPAN									
		1345	SYSTEM ZERO	.02	.00	.23	.25					
			SYSTEM SPAN	4.88	14.75	55.84	89.25					
	BEGIN	1400	5 min for 1000	3.48	9.75	1.7	68.8					
	END	1405										
	BEGIN	1405		3.46	9.75	1.5	69.5					
	END	1410										
	BEGIN	1410		3.48	9.75	1.5	69.5					
	END	1415										
	BEGIN	1415		3.4	9.75	1.5	69.8					
	END	1420										
	BEGIN	1420		3.47	9.75	1.5	70.0					
	END	1425										
	BEGIN	1425	5 min	3.46	9.75	1.4	70.0					
	END	1430										
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
	BEGIN	1445	NO ₂ proc				37.5	36.25	1.25			
	END	----										
	BEGIN	----										
	END	----										
	BEGIN	----										
	END	----										
		1432	SYSTEM ZERO	.02	.00	.2	.75					
			SYSTEM SPAN	4.87	14.75	55.84	89.25					
RAW AVERAGE				✓								
CORRECTED AVERAGE												
COMMENTS:												

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCF / 1112CONDITION: INDIAN VILLAGEDATE: 10-7-92OPERATOR: CHFTEST NUMBER: 9.2-CEM

TEST LOCATION: _____

TEST NO.	TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO _____% ____ DRY		
			O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION												
		AS FOUND ANAL. SPAN										
	1609	SYSTEM ZERO	.01	0.0	.2	.5						
		SYSTEM SPAN	4.96	14.8	55.83	90.52						
	BEGIN 1620 END 1625	CHF 111222	3.60	9.75	1.2	71.3						
	BEGIN 1625 END 1630		3.58	9.75	1.1	71.3						
	BEGIN 1630 END 1635		3.6	9.75	1.1	71.3						
	BEGIN 1635 END 1640		3.56	9.75	1.1	72.0						
	BEGIN 1640 END 1645		3.54	9.75	1.2	72.2						
	BEGIN 1645 END 1650	CHF	3.52	9.75	1.3	72.2						
	BEGIN END											
	BEGIN END	NOx Probe				38.75	37.5	1.3				
	BEGIN END											
	BEGIN END											
	BEGIN END											
	BEGIN END											
		SYSTEM ZERO	.02	0.0	.2	.5						
		SYSTEM SPAN	4.95	14.83	55.84	90.25						
RAW AVERAGE												
CORRECTED AVERAGE												
COMMENTS:												

CARNOT

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCE/AlamogordoCONDITION: HD MW Urea ONDATE: 10-8-92OPERATOR: CHFTEST NUMBER: 10-2-CFM

TEST LOCATION: _____

TEST NO.	TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO _____%____, DRY		
			O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION												
		AS FOUND ANAL. SPAN										
		SYSTEM ZERO	.02	0.0	0.3	.3						
		SYSTEM SPAN	497	14.93	55.84	48.5						
	BEGIN 905 END 910	Start Air Flow	7.3	7.28	0.9	86.5						
	BEGIN 910 END 915		7.3	7.65	0.9	86.5						
	BEGIN 915 END 920		7.25	7.65	0.9	85.5						
	BEGIN 920 END 925		7.28	7.65	0.9	85.5						
	BEGIN 925 END 930		7.30	7.65	0.9	86.5						
	BEGIN 930 END 935	End	7.29	7.65	0.9	88.0						
	BEGIN END											
	BEGIN END											
	BEGIN END	NOx P. 6				54.5	SI	3.5				
	BEGIN END											
	BEGIN END											
	BEGIN END											
	BEGIN END											
		SYSTEM ZERO	.03	0.0	0.5	.25						
		SYSTEM SPAN	497	14.85	55.84	48.5						
RAW AVERAGE			✓									
CORRECTED AVERAGE												
COMMENTS:												

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCE A14 2CONDITION: 40 MW Urea ONDATE: 10-8-92OPERATOR: CHFTEST NUMBER: 142-CFM

TEST LOCATION: _____

TEST NO.	TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO % DRY		
			O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION												
		AS FOUND ANAL. SPAN				49.86						
	10416	SYSTEM ZERO	.03	0.0	.1	.3						
		SYSTEM SPAN	4.98	14.8	55.84	48.5						
	BEGIN 1115 END 1120	Start # A11 P-10	7.42	7.55	0.8	90.5						
	BEGIN 1120 END 1125		7.40	7.55	0.8	91.0						
	BEGIN 1125 END 1130		7.42	7.55	0.8	90.5						
	BEGIN 1130 END 1135		7.42	7.55	0.8	89.5						
	BEGIN 1135 END 1140		7.4	7.55	.8	90.0						
	BEGIN 1140 END 1145	End	7.4	7.55	.8	90.0						
	BEGIN END											
	BEGIN END											
	BEGIN 1210 END	NOx A11 P-10				55	52	3.0				
	BEGIN END											
	BEGIN END											
	BEGIN END											
		SYSTEM ZERO	.02	0.0	0.1	1.7						
		SYSTEM SPAN	5.02	14.9	56.6	49.5						
RAW AVERAGE				7.55	0.8							
CORRECTED AVERAGE												
COMMENTS:												

CARNOT

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCE / AL 2CONDITION: 40mm View OffDATE: 10-8-92OPERATOR: CHFTEST NUMBER: 12-2-CEMTEST LOCATION: HSAPH

TEST NO.	TIME	SAMPLE POINT/ CONDITION	250 Range DRY, UNCORRECTED							CORRECTED TO % ____ DRY		
			O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION												
		AS FOUND ANAL. SPAN				90.52						
	1335	SYSTEM ZERO	.03	0.0	0.0	0.25						
		SYSTEM SPAN	4.99	14.8	5584	87.0						
	BEGIN 1345 END 1350	Start All Probes	732	7.53	.3	104.0						
	BEGIN 1350 END 1355		730	7.55	0.3	103.0						
	BEGIN 1355 END 1400		730	7.55	0.4	103.8						
	BEGIN 1400 END 1405		732	7.55	.3	103.8						
	BEGIN 1405 END 1410		730	7.55	.3	103.5						
	BEGIN 1410 END 1415	End	724	7.55	.3	103.8						
	BEGIN 1415 END 1420											
	BEGIN END											
	BEGIN END											
	BEGIN END											
	BEGIN END											
	1430	SYSTEM ZERO	.02	0.0	0.0	.25						
		SYSTEM SPAN	4.97	14.8	557	85.6						
RAW AVERAGE												
CORRECTED AVERAGE												
COMMENTS:												

362

CARNOT

PAGE ____ OF ____

REFERENCE METHOD GASEOUS MEASUREMENTS

CLIENT/LOCATION: SCF A1a 2CONDITION: 40 in w Valve offDATE: 10-3-77OPERATOR: CHHTEST NUMBER: 13-2-CEMTEST LOCATION: HSAPH

TEST NO.	TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO ____%____, DRY		
			O ₂	CO ₂	CO	NOx	NO	NO ₂	SO ₂	CO	NOx	SO ₂
SPAN GAS CONCENTRATION												
		AS FOUND ANAL. SPAN										
	1514	SYSTEM ZERO	.03	0.0	.1	0.0						
		SYSTEM SPAN	4.99	14.75	55.84	86.25						
	BEGIN 1525 END 1530	Star	7.36	7.5	.4	105						
	BEGIN 1530 END 1535		7.40	7.5	.4	104						
	BEGIN 1535 END 1540		7.35	7.5	.4	104						
	BEGIN 1540 END 1545		7.32	7.5	.4	102.5						
	BEGIN 1545 END 1550		7.30	7.5	.4	103.0						
	BEGIN 1550 END 1555	End	7.31	7.5	.4	103.3						
	BEGIN END											
	BEGIN END											
	BEGIN END	NOx Probe				68.3	66.3	2.0				
	BEGIN END											
	BEGIN END											
	BEGIN END											
		SYSTEM ZERO	.02	0.0	.1	.50						
		SYSTEM SPAN	5.00	14.7	55.84	87.5						
RAW AVERAGE			7.32	7.5	.4	103.0						
CORRECTED AVERAGE												
COMMENTS:												

Appendix C.4

Particulate

SAMPLE TRAIN TEST DATA

CLIENT 356/A/Am205 UNIT 2 TEST NO. 1-2-PM METHOD 5.3 PAGE 1 OF 1
 SAMPLE LOCATION Field Acoustic TEST CONDITION AMB. TEMP., °F PROJECT # 12598
 OPERATOR/ASSISTANT J.M. METER VOL. (START/END) 432.223 / 476.585 DATE 10/16/97

PRE-TEST DATA:
 Barometric Press., in. Hg. 30.01
 Assumed Stack Press. 1.07
 Assumed Moisture 2.5
 Assumed Molecular Wt. 28.9
 Assumed ΔP 1.07
 Assumed ΔH 1.07
 Stack Diameter, in. 8.4
 Sample Time: Total 14 per point
 Total of Traverse Points 78
 $\Delta H = .78 \times \Delta P$

EQUIPMENT INFO:
 Motor No. 71-Y
 Motor, Yd. 11.544
 CFM @ $\Delta H = 1.0$ 3.51
 Pilot ID, Cp 1.54
 O₂/CO₂ Method Acoustic
 Teflon Connecting 3.21
 Line (Y/N) Y
 Probe: Mat'l 3.21 Length 3.21
 Nozzle: Mat'l 3.21 Diam. 0.185
 Filter: No. 45-167 Mat'l 45-167

POST TEST INFO:
 Filter Appearance Clean
 Impinger Appearance Clean
 Silica Gel Spent (Y/N) No

TEMPERATURES, °F

IMPG.	Mat'l	WL(End)	WL(Start)	WL(g)	METER		OVEN	IMP. OUT	O ₂	VAC.	STATIC PRESS. Impg	CHAIN OF CUSTODY INFORMATION
					IN	OUT						
#1	H ₂	70.3	71.9	134.4	79	72		56	4.5	15		Impingers Loaded <u>CHF</u>
#2	H ₂	56.1	54.1	-2.0	81	77		54	4.8	10		Impingers Recovered <u>CHF</u>
#3	O	52.4	51.7	3.5	82	77		55	7.5	10		Filter Loaded <u>CHF</u>
#4	CO	76.1	74.8	14.8	82	72		55	7.8	10		Filter Recovered <u>CHF</u>
#5					84	77		60	7.5	15		Probe Wash <u>CHF</u>
Total					86	77		64	6.1	16		TEST SUMMARY
					87	78		65	8.6	17		Calculated by: <u>JM</u>
												Checked by: <u>EB</u>
												Sample Vol., c.f. <u>44.316</u>
												Stack Press., Impg <u>7.55</u>
												ΔH , Impg <u>1.57</u>
												ΔP , Impg <u>1.57</u>
												Meter Temp., °F <u>7.5</u>
												Stack Temp., °F <u>3.145</u>
												Water Collected, g <u>1.1</u>
												O ₂ /CO ₂ <u>7.7</u>
												Comments:

SAMPLE POINT	TIME	METER CONDITIONS				TEMPERATURES, °F				STATIC PRESS. Impg	CHAIN OF CUSTODY INFORMATION
		ΔP	ΔH	METER READING	STACK	PROBE	METER IN	METER OUT	OVEN		
7	7:00	1.04	1.07	432.223	321		79	72			
6	7:06	1.07	1.09	435.521	322		81	77			
5	7:12	1.05	1.07	438.721	316		82	77			
4	7:18	1.00	1.02	441.415	310		82	72			
3	7:24	0.93	1.04	444.438	307		84	77			
2	7:30	0.92	1.07	448.351	305		86	77			
1	7:36	0.80	1.00	451.550	308		87	78			
stop	7:42			456.357							
7	7:45	1.04	1.10	456.347	324		83	76			
6	7:51	0.90	1.01	460.024	324		86	78			
5	7:57	0.91	1.07	462.618	320		88	79			
4	8:03	0.94	1.03	464.588	312		88	79			
3	8:09	1.00	1.09	467.371	308		89	80			
2	8:15	0.98	1.04	470.420	308		91	82			
1	8:21	1.00	1.08	473.535	308		93	83			
stop	8:27			476.585							

CARNOT

CLIENT SCC / ALAMITOS
SAMPLE LOCATION CSAPH
OPERATOR/ASSISTANT _____

SAMPLE TRAIN TEST DATA

UNIT 2 TEST NO. 2-2-PM METHOD S.3 PAGE 1 OF 2
TEST CONDITION UR EA OFF AMB. TEMP., °F _____ PROJECT # 12598
METER VOL. (START/END) 476.821 DATE _____

PRE-TEST DATA:
Barometric Press., in. Hg. 30.01
Assumed Stack Press. +4.2
Assumed Moisture 15
Assumed Molecular Wt. 23
Assumed ΔP 1.3
Assumed ΔH 1.00
Stack Diameter, in. 66.3
Sample Time: Total 84
per point 6
Total of Traverse Points 14

$\Delta H = .56 \times \Delta P$

EQUIPMENT INFO:
Meter No. _____
Meter, Yd. _____
CFM @ $\Delta H = 1.0$ _____
Pilot ID, Cp _____
O₂/CO₂ Method _____
Teflon Connecting _____
Line (Y/N) _____
Probe: _____
Nozzle: _____
Filter: _____

Imp. 21-4
#1 470
#2 _____
#3 _____
#4 _____
#5 _____
Total 587
POST TEST INFO:
Filter Appearance 13-166
Impinger Appearance 13-166
Silica Gel Spent (Y/N) 13-166

Imp. 470 WL(Start) 56.2.6 WL(End) _____ Wt(L) _____
#1 _____
#2 _____
#3 _____
#4 _____
#5 _____
Total _____

SAMPLE TRAIN LEAK CHECK:
CEM Vac. _____ Pilot Inlet _____
Pre-Test 0.04 18
Post-Test _____

PRE-TEST CALIBRATION CHECK:
Meter Reading _____ Meter Temp. _____
Time ΔH _____ In _____ Out _____

SAMPLE POINT	TIME	METER CONDITIONS			TEMPERATURES, °F				STATIC PRESS. iw/g	CHAIN OF CUSTODY INFORMATION		
		ΔP	ΔH	METER READING	PROBE	METER IN	METER OUT	OVEN		O ₂	VAC.	
7	1115	1.0	.86	476.821	337	92	91				4	Impingers Loaded <u>EG</u>
6	1121	1.80	1.54	478.612	338	94	92			6.5	15	Impingers Recovered
5	1127	1.9	1.63	481.02	336	95	92			6.5	25	Filter Loaded
4	1133	1.8	1.44	485.157	336	94	93			6.7	24	Filter Recovered
3	1139	2.6	1.4	488.871	337	95	93			7.1	23	Probe Wash
2	1145	3.4	1.4	473.750	334	97	94			7.6	23	TEST SUMMARY
1	1151	2.5	1.4	496.87	321	96	92			8.2	23	Calculated by:
STOP	1157			501.409								Checked by:
												Sample Vol., c.f.
												Stack Press., iw/g
												ΔH , iw/g
												ΔP , iw/g
												Meter Temp., °F
												Stack Temp., °F
												Water Collected, g
												O ₂ /CO ₂
												Comments:

CARNOT

CLIENT See / Harris

SAMPLE TRAIN TEST DATA

UNIT 2 TEST NO. 3-2-8m METHOD 5 PAGE 1 OF 1
SAMPLE LOCATION 1000 PROJECT # 101815
OPERATOR/ASSISTANT g.c. DATE 10/8/15

PRE-TEST DATA: Barometric Press., in. Hg. 29.94
Assumed Stack Press. 0.00
Assumed Moisture 0.00
Assumed Molecular Wt. 0.00
Assumed ΔP 0.00
Assumed ΔH 0.00
Stack Diameter, in. 0.00
Sample Time: Total 0.00 per point 0.00
Total of Traverse Points 0.00
 $\Delta H = 72 \times \Delta P$

EQUIPMENT INFO: Meter No. 1000
Meter, Yd. 1000
CFM @ $\Delta H = 1.0$ 0.00
Pilot ID, Cp 0.00
O₂/CO₂ Method 0.00
Teflon Connecting Line (Y/N) 0.00
Probe: 0.00
Nozzle: 0.00
Filter: 0.00

IMP. #1 1000 #2 1000 #3 1000 #4 1000 #5 1000
WL(End) 1000 WL(Start) 1000 WL(alt) 1000
Pre-Test 0.00 Post-Test 0.00
Cem 0.00 Vac. 0.00 Pilot 0.00 Init. 0.00

SAMPLE TRAIN LEAK CHECK: CEM 0.00 Vac. 0.00 Pilot 0.00 Init. 0.00
Pre-Test 0.00 Post-Test 0.00
PRE-TEST CALIBRATION CHECK: Meter Reading 0.00 Meter Temp. 0.00
Time ΔH 0.00 In 0.00 Out 0.00

SAMPLE POINT	TIME	METER CONDITIONS			TEMPERATURES, °F				STATIC PRESS. lwg	CHAIN OF CUSTODY INFORMATION		
		ΔP	ΔH	METER READING	PROBE	METER IN	METER OUT	OVEN		IMP. OUT	O ₂	VAC.
7	1308	1.5	1.6	506.021	336	55	52			2.00	8.0	7
6	1312	1.0	1.1	509.408	340	54	53			4.4		8
5	1319	1.40	1.00	512.425	335	58	57			6.4		7
4	1324	2.1	1.57	516.625	324	55	53			6.4	7.4	10
3	1330	3.4	2.44	518.432	324	105	55			6.4		12
2	1332	2.05	1.50	525.618	318	103	55			6.4	7.4	5
1	1358	1.1	1.15	531.351	316	104	54			6.3	7.2	7
Stop	1404			535.125								
7	1407	1.75	1.0	535.128	330	55	54			6.1	7.2	4
6	1413	1.94	1.07	537.641	336	100	95			6.5	7.0	4
5	1415	2.3	1.65	540.112	334	100	95			6.3	7.2	8
4	1425	1.22	1.58	541.410	328	105	96			6.3	7.0	5
3	1434	1.0	1.2	545.610	323	105	96			6.4	7.4	6
2	1437	1.3	1.1	551.531	325	104	96			6.4	7.4	6
1	1443	1.10	1.12	554.081	328	104	96			6.4	7.4	6
Stop	1451			557.485								

CARNOT

CLIENT SEC, Alamos
 SAMPLE LOCATION SAH
 OPERATOR/ASSISTANT

SAMPLE TRAIN TEST DATA

UNIT 2 TEST NO. A-2-AM METHOD 5.3 PAGE 1 OF 1
 TEST CONDITION ULTRA DRY AMB. TEMP., °F 55.7 PROJECT # 12598
 METER VOL. (START/END) 55.7/10.1 DATE

PRE-TEST DATA:

Barometric Press., in. Hg. 30.05
 Assumed Stack Press. 15.0
 Assumed Moisture 15
 Assumed Molecular Wt. 28
 Assumed ΔP 0.3
 Assumed ΔH 84
 Stack Diameter, in. 6
 Sample Time: Total per point
 Total of Traverse Points 14

$$\Delta H = \frac{72}{x} \times \Delta P$$

EQUIPMENT INFO:

Meter No. 714
 Meter, Yd. 100
 CFM @ $\Delta H = 1.0$ 0.56
 Pilot ID, Cp 0.56
 O₂/CO₂ Method 100
 Teflon Connecting Line (Y/N) 100
 Probe: Marti Length Marti
 Nozzle: Marti Diam. No. Marti
 Filter: Marti

IMP. Marti WL(End) WL(Start) WL(Q)
 #1 DF 40 791.7 616.5 175.2
 #2 DF 160 623.0 599.0 14.0
 #3 — 528.9 520.5 3.4
 #4 50 647.6 227.2 20.4
 #5 — — — —
 Total 55
 POST TEST INFO:
 Filter Appearance 0.185
 Impinger Appearance 45-199
 Silica Gel Spent (Y/N)

SAMPLE TRAIN LEAK CHECK:

CEM Vac. Pilot Inlet
 Pre-Test 0.02 18 94 57
 Post-Test 0.00 10 — —

PRE-TEST CALIBRATION CHECK:

Meter Meter Meter Temp.
 Time ΔH Reading In Out
 Init. — — — — —
 Final — — — — —

SAMPLE POINT	TIME	METER CONDITIONS				TEMPERATURES, °F				STATIC PRESS. lwg	CHAIN OF CUSTODY INFORMATION	
		ΔP	ΔH	METER READING	STACK	METER		PROBE	OVEN	IMP. OUT	O ₂	VAC.
						IN	OUT					
7	1530	1.65	1.45	557.7710	390	99	94	340	—	64	8.4	4
6	1536	1.78	1.52	550.31	310	100	94	341	—	64	8.0	4
5	1542	2.1	2.22	562.45	287	102	99	342	—	64	7.4	8
4	1548	4.1	2.55	567.17	286	105	100	341	—	63	7.0	8
3	1554	3.4	2.44	573.121	277	103	102	339	—	63	7.6	11
2	1600	1.8	1.27	575.218	286	116	102	336	—	63	7.4	11
1	1606	0.0	1.7	584.38	256	116	104	34	—	62	—	—
stop	1612	—	—	585.55	—	—	—	—	—	—	—	—
7	1618	1.54	1.54	588.55	340	109	105	—	—	62	6.7	9
6	1624	1.05	1.75	591.724	341	111	106	—	—	62	6.6	9
5	1630	2.5	1.80	594.678	331	111	106	—	—	62	7.0	8
4	1636	1.10	1.0	595.652	327	115	106	—	—	62	7.5	8
3	1642	5.0	1.44	603.450	330	115	108	—	—	62	7.2	7
2	1648	1.5	1.0	606.448	328	115	108	—	—	63	7.4	7
1	1654	1.3	0.93	609.512	326	114	108	—	—	63	7.4	7
stop	1700	—	—	613.251	—	—	—	—	—	—	—	—
TEST SUMMARY											Calculated by: <u>55.7/10.1</u>	
Checked by: <u>55.7/10.1</u>											Sample Vol., c.f. <u>55.840</u>	
Stack Press., lwg											ΔH , lwg <u>1.369</u>	
ΔH , lwg											ΔP , lwg <u>1.78</u>	
Meter Temp., °F											Meter Temp., °F <u>106.82</u>	
Stack Temp., °F											Stack Temp., °F <u>337-310.3</u>	
Water Collected, g											Water Collected, g <u>213.0</u>	
O ₂ /CO ₂											O ₂ /CO ₂ <u>7.4</u>	
Comments:												

CARNOT

CLIENT SEI Alameda
SAMPLE LOCATION CSAPP
OPERATOR/ASSISTANT Michael G. G. G.

SAMPLE TRAIN TEST DATA

UNIT 2 TEST NO. 6-2-PH METHOD S.3 PAGE 1 OF 1
TEST CONDITION Wet off AMB. TEMP., °F 63 PROJECT # 12558
METER VOL. (START/END) 642.55 1 637.504 DATE 12/7/75

PRE-TEST DATA:
Barometric Press., in. Hg. 30.01
Assumed Stack Press. +5.00
Assumed Moisture 15
Assumed Molecular Wt. 28
Assumed ΔP 1.35
Assumed ΔH 0.75
Stack Diameter, in. 6.4
Sample Time: Total 6.4
per point 14
Total of Traverse Points 14

EQUIPMENT INFO:
Meter No. 71-4
Meter, Yd. 1.5004
CFM @ ΔH = 1.0 0.004
Pilot ID, Cp 0.34
O₂/CO₂ Method 700
Teflon Connecting Line (Y/N) 700
Probe: Length 14.50
Mater: 8.5
Nozzle: Mater 8.5
Diam. 47-448
Filter: No. 47-448
Mater

IMD.	Mater	Wt(End)	Wt(Start)	Wt(Gr)
#1	H ₂ O	674.7	677	10.100
#2	H ₂ O	525.3	525.0	1.3
#3	Ø	525.3	524.7	0.6
#4	SC	703.7	695.8	7.9
#5				
Total				116.7

POST TEST INFO:
Filter Appearance _____
Impinger Appearance _____
Silica Gel Spent (Y/N) _____

SAMPLE TRAIN LEAK CHECK:
CEM Vac. Pilot Inlet
Pre-Test 600 17 21 11
Post-Test 600 11 21 11
PRE-TEST CALIBRATION CHECK:
Time ΔH Meter Meter Temp.
Inlet _____ Inlet _____
Final _____

SAMPLE POINT	TIME	METER CONDITIONS			TEMPERATURES, °F					STATIC PRESS. InHg	CHAIN OF CUSTODY INFORMATION			
		ΔP	ΔH	METER READING	STACK	PROBE	METER		OVEN			IMP. OUT	O ₂	VAC.
							IN	OUT						
7	8:30	1.84	5.8	62.559	352		73	71		65	77	3	Impingers Loaded	CH
6	8:36	1.61	4.2	61.515	301		72	72		60		3	Impingers Recovered	CH
5	8:42	1.1	3.1	61.135	308		74	73		53	75	3	Filter Loaded	CH
4	8:48	1.04	5.1	62.0152	304		81	74		52	61	4	Filter Recovered	CH
3	8:54	1.02	5.4	63.512	308		83	75		54	60	4	Probe Wash	
2	9:00	1.99	6.5	67.6142	302		84	76		55	67	4	TEST SUMMARY	
1	9:06	1.13	5.1	67.220	300		85	77		57	62	4	Calculated by: J.M.	
STOP	9:12			68.1512									Checked by:	
7	9:30	1.3	5.1	68.1872	297		84	60		55	5	4	Sample Vol., cl. 35.305	
6	9:36	1.3	5.1	68.166	298		86	61		53	7.9	4	Stack Press., InHg 7.8	
5	9:42	1.35	3.5	68.415	294		89	62		50	8.2	4	ΔP, InHg 8.2	
4	9:48	1.67	4.6	68.360	292		90	62		53	8.3	3	Meter Temp., °F 81.5	
3	9:54	1.52	3.6	69.1125	290		92	64		55	8.4	3	Stack Temp., °F 300.2	
2	10:00	1.41	4.2	69.3412	285		93	64		60	8.7	3	Water Collected, g	
1	10:06	1.65	5.5	69.5301	285		93	64		58	8.8	3	O ₂ /CO ₂ 6.4	
Stop	10:12			69.7004									Comments:	



SAMPLE TRAIN TEST DATA

CLIENT UNIT TEST NO. 5-2-PM METHOD DATE 1 OF 1
SAMPLE LOCATION TEST CONDITION AMB. TEMP., °F PROJECT # 1
OPERATOR/ASSISTANT METER VOL. (START/END) 618.655 1 662.646 DATE 1

PRE-TEST DATA:
Barometric Press., in. Hg. _____
Assumed Stack Press. _____
Assumed Moisture _____
Assumed Molecular Wt. _____
Assumed ΔP _____
Assumed ΔH _____
Stack Diameter, in. _____
Sample Time: Total _____
per point _____
Total of Traverse Points _____

EQUIPMENT INFO:
Meter No. _____
Meter Yd. _____
CFM @ $\Delta H = 1.0$ _____
Pilot ID, Cp _____
O₂/CO₂ Method _____
Teflon Connecting _____
Line (Y/N) _____
Probe: _____
Length _____
Nozzle: _____
Diam. _____
Filter: _____
No. _____
Matl _____

POST TEST INFO:
Total _____
Filter Appearance _____
Impinger Appearance _____
Silica Gel Spent (Y/N) _____

SAMPLE TRAIN LEAK CHECK:
CEM Vac. Pilot Init.
Pre-Test 4.005 15 24 E
Post-Test 4.002 8 24 E

PRE-TEST CALIBRATION CHECK:
Time ΔH Meter Meter Temp.
Bleeding In Out
Init. _____
Final _____

SAMPLE POINT	TIME	METER CONDITIONS				TEMPERATURES, °F					O ₂	VAC.	STATIC PRESS. INWG	CHAIN OF CUSTODY INFORMATION
		ΔP	ΔH	METER READING	STACK	PROBE	METER		OVEN	IMP. OUT				
							IN	OUT						
7	1743	.51	.65	613.635	325	✓	100	93		66	74	4		Impingers Loaded
6	1746	.55	.44	616.634	330		100	94		68	64	3		Impingers Recovered
5	1752	.14	.65	618.706	322		101	93		60	70	5	65	Filter Loaded
4	1758	.15	.57	623.046	316		102	94		60	76	7		Filter Recovered
3	1804	.16	.62	626.647	310		104	97		61	78	6		Probe Wash
2	1810	.11	.87	630.531	314		103	97		61	80	4		TEST SUMMARY
1	1816	.50	.70	633.485	318		102	97		61		4		
stop	1822			636.518										Calculated by:
														Checked by:
7	1835	.11	.65	636.543	322		95	95		62	64	4		Sample Vol., cl. 48.781
6	1831	.16	.20	640.987	325		94	93		66	70	6		Stack Press., inwg
5	1837	.15	.12	644.135	320		98	93		60	72	5		ΔH, inwg 1418
4	1843	.13	.71	647.18	324		98	92		61		5		ΔP, inwg 1418
3	1849	.15	.35	651.323	301		97	91		61	70	6		Meter Temp., °F 97.36
2	1853	.14	.65	655.871	314		97	90		64	82	6		Stack Temp., °F 247.0
1	1901	.12	.65	658.686	310		97	89				6		Water Collected, g 73.0
stop	1907			662.646										O ₂ /CO ₂ 7.2 7.4
														Comments:

CARNOT

SAMPLE TRAIN TEST DATA

CLIENT CGE / Alcantara UNIT 2 TEST NO. 7-2-DN METHOD 5.2 PAGE 1 OF 1
SAMPLE LOCATION CGE / Alcantara TEST CONDITION 2 AMB. TEMP., °F 74.7 PROJECT # 10/2/52
OPERATOR/ASSISTANT J. Mulligan METER VOL. (START/END) 158.285 1 744.768 DATE 10/2/52

PRE-TEST DATA:
Barometric Press., in. Hg. _____
Assumed Stack Press. _____
Assumed Moisture _____
Assumed Molecular Wt. _____
Assumed ΔP _____
Assumed ΔH _____
Stack Diameter, in. _____
Sample Time: Total _____
por point _____
Total of Traverse Points _____

EQUIPMENT INFO:
Motor No. 714
Meter, Yd. 16046
CFM @ ΔH = 1.0 5.28
Pilot ID, Cp _____
O₂/CO₂ Method _____
Teflon Connecting _____
Line (Y/N) _____
Probe: Mart _____
Length _____
Nozzle: Mart _____
Diam. _____
Filter: No. _____
Mart _____

POST TEST INFO:
Total _____
Filter Appearance _____
Impinger Appearance _____
Silica Gel Spent (Y/N) _____

SAMPLE TRAIN LEAK CHECK:
Pre-Test 158.285 15 02 158.285
Post-Test 158.285 15 02 158.285

PRE-TEST CALIBRATION CHECK:
Time ΔH Meter Meter Temp.
Beading In Out

ΔH = 71 x ΔP

SAMPLE POINT	TIME	METER CONDITIONS			TEMPERATURES, °F						CHAIN OF CUSTODY INFORMATION					
		ΔP	ΔH	METER READING	STACK	PROBE	METER		OVEN	IMP. OUT	O ₂	VAC.	STATIC PRESS. iwg			
							IN	OUT								
7	11:06	45	68	698.005	346		32	51		700			4		Impingers Loaded	6147
6	11:07	51	57	700.350	348		32	50		64			4		Impingers Recovered	
5	11:08	2.7	1.56	702.712	348		35	32		66			6		Filter Loaded	
4	11:14	3.0	2.2	706.5	341		101	51		55			8		Filter Recovered	
3	11:20	3.7	2.6	708.654	340		103	54		55			11		Probe Wash	
2	11:26	2.5	1.85	717.130	333		105	45		60			5		TEST SUMMARY	
1	11:32	1.9	1.4	721.764	332		105	56		62			8		Calculated by: CG	
50g	11:38			726.040											Checked by:	
7	11:40	48	57	726.070	341		106	45		66			3		Sample Vol., c.i. 46503	
6	11:46	63	53	728.136	342		57	34		62			7		Stack Press., iwg	
5	11:52	84	62	731.641	342		57	34		62			3		ΔH, iwg 1.134	
4	11:58	2.0	1.48	733.142	337		56	34		63			2		ΔP, iwg 1.4204	
3	12:04	1.1	.81	736.861	334		57	34		63			4	5.8	Meter Temp., °F 239.9	
2	12:10	.88	.65	737.871	332		55	34		64			4		Stack Temp., °F 15.4	
1	12:40	75	55	742.618	332		58	44		65			4		Water Collected, g 8.00	
50g	12:42			744.768											O ₂ /CO ₂	
															Comments:	

SAMPLE TRAIN TEST DATA

CLIENT CEC / Alcantara UNIT 7-2-DM TEST NO. 5.2 METHOD 744.168 PAGE 1 OF 1
 SAMPLE LOCATION CEC AMB. TEMP., °F 74.1 PROJECT # 1072152
 OPERATOR/ASSISTANT J. Blalock METER VOL. (START/END) 65.8-25.1 DATE 10/2/52

E-TEST DATA:
 Isometric Press., in. Hg. 0.0
 Summed Stack Press. 0.0
 Summed Moisture 0.0
 Summed Molecular Wt. 0.0
 Summed ΔP 0.0
 Summed ΔH 0.0
 Stack Diameter, in. 0.0
 Sample Time: Total 0.0 per point 0.0
 Total of Traverse Points 0.0
 ΔH = 71 x ΔP

EQUIPMENT INFO:
 Meter No. 714
 Meter, Yd. 11.0
 CFM @ ΔH = 1.0 5.77
 Pilot ID, Cp 5.77
 O₂/CO₂ Method 5.77
 Teflon Connecting Line (Y/N) 5.77
 Probe: Mat'l 5.77 Length 5.77
 Nozzle: Mat'l 5.77 Diam. 5.77
 Filter: No. 5.77 Mat'l 5.77

POST TEST INFO:
 Filter Appearance 5.77
 Impinger Appearance 5.77
 Silica Gel Spent (Y/N) 5.77

TEMPERATURES, °F

Imp.	Mat'l	WL(End)	WL(Start)	WL(Δ)	METER		OVEN	IMP. OUT
					IN	OUT		
#1	11.0	715.2	575.7	140.1	92	91		92
#2	11.0	575.7	577.0	3.9	92	90		64
#3	11.0	576.6	577.0	1.6	95	92		66
#4	11.0	746.6	735.8	10.8	101	91		55
#5	11.0				103	94		55
Total					105	95		60

STATIC PRESS. Iwg

Imp.	Mat'l	WL(End)	WL(Start)	WL(Δ)	OVEN	IMP. OUT	O ₂	VAC.

CHAIN OF CUSTODY INFORMATION

Impingers Loaded	Impingers Recovered	Filter Loaded	Filter Recovered	Probe Wash	TEST SUMMARY	Calculated by:	Checked by:	Sample Vol., c.i.	Stack Press., iwg	ΔH, iwg	ΔP, iwg	Meter Temp., °F	Stack Temp., °F	Water Collected, g	O ₂ /CO ₂	Comments:
6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6

SAMPLE TRAIN TEST DATA

CLIENT SE / Alamos UNIT 2 TEST NO. 002-PM METHOD 5.23 PAGE 1 OF 1
 SAMPLE LOCATION 0024 TEST CONDITION 0024 AMB. TEMP., °F 75.1 PROJECT # 10-7-72
 OPERATOR/ASSISTANT W METER VOL. (START/END) 746.1/75.1 DATE 10-7-72

PRE-TEST DATA:
 Barometric Press., in. Hg. 30.05
 Assumed Stack Press. 7.2
 Assumed Moisture 14
 Assumed Molecular Wt. 2.8
 Assumed ΔP 1.0
 Assumed ΔH 1.15
 Stack Diameter, in. 4.4
 Sample Time: Total 14 per point
 Total of Traverse Points 14
 $\Delta H = 74.5 \times \Delta P$

EQUIPMENT INFO:
 Motor No. 71-4
 Motor, Yd. 1.004
 CFM @ $\Delta H = 1.0$ 0.58
 Pilot ID, Cp 0.84
 O₂/CO₂ Method 7.0
 Teflon Connecting Line (Y/N) 7.0
 Probe: Mat'l 7.0
 Length 7.0
 Nozzle: Diam. 7.0
 No. 7.0
 Filter: Mat'l 7.0

POST TEST INFO:
 Filter Appearance 7.0
 Impinger Appearance 7.0
 Silica Gel Spent (Y/N) 7.0

SAMPLE TRAIN LEAK CHECK:
 Pre-Test CEM Vac. 0.04 Pilot Init. 0.04
 Post-Test CEM Vac. 0.04 Pilot Init. 0.04

PRE-TEST CALIBRATION CHECK:
 Time ΔH Meter Reading Meter Temp. In Out
 Init. 157.2
 Final 157.2

SAMPLE POINT	METER CONDITIONS				TEMPERATURES, °F				STATIC PRESS. lwg	CHAIN OF CUSTODY INFORMATION	
	TIME	ΔP	ΔH	METER READING	PROBE	METER IN	METER OUT	OVEN			
7	13.17	56	41	744.757	343	83	94			Impingers Loaded	0.1.1
6	13.33	66	44	777.218	345	85	95			Impingers Recovered	0.1.1
5	13.35	78	57	749.028	344	97	95			Filter Loaded	0.1.2
4	13.45	18	133	751.820	339	100	96			Filter Recovered	0.1.2
3	13.51	13	96	756.481	339	105	96			Probe Wash	0.1.2
2	13.57	76	57	760.028	334	107	95			TEST SUMMARY	
1	14.03	77	57	762.150	336	106	98				
Stop	14.09			764.670						Calculated by:	
										Checked by:	
7	14.15	184	161	764.478	350	101	101			Sample Vol., c.l.	4/6.085
6	14.21	158	144	767.601	350	106	101			Stack Press., lwg	
5	14.27	1.1	84	769.924	349	108	102			ΔH , lwg	1.02+61.0543
4	14.33	2.8	2.15	772.710	346	109	104			ΔP , lwg	1.2-14
3	14.39	3.7	2.84	777.741	342	113	104			Meter Temp., °F	102.4
2	14.45	3.5	1.72	783.216	338	115	106			Stack Temp., °F	341.58
1	14.51	78	8.06	787.912	337	116	106			Water Collected, g	159.2
Stop	14.57			771.036						O ₂ /CO ₂	8.15
										Comments:	



SAMPLE TRAIN TEST DATA

CLIENT SE/Aluminitas UNIT 2 TEST NO. 9-2-PM METHOD 5.3 PAGE 1 OF 1
SAMPLE LOCATION SEPH TEST CONDITION DECA ON AMB. TEMP., °F 108.0 PROJECT # 12598
OPERATOR/ASSISTANT Jan METER VOL. (START/END) 791.261 / 830.452 DATE 10-7-82

PRE-TEST DATA:
Barometric Press., in. Hg. 29.99
Assumed Stack Press. 0
Assumed Moisture 18
Assumed Molecular Wt. 28
Assumed ΔP 1.0
Assumed ΔH 1.77
Stack Diameter, in. 6.37
Sample Time: Total 44 per point 6
Total of Traverse Points 14
 $\Delta H = 81 \times \Delta P$

EQUIPMENT INFO:
Meter No. 71-4
Meter, Yd. 1.000
CFM @ $\Delta H = 1.0$ 0.54
Pilot ID, Cp 0.34
O₂/CO₂ Method YES
Teflon Connecting Line (Y/N) YES
Probe: Matl 18/102
Nozzle: Matl 85
Filter: No. 47-451

POST TEST INFO:
Filter Appearance 35
Impinger Appearance 0.185
Silica Gel Spent (Y/N) 47-451

SAMPLE TRAIN LEAK CHECK:
Pre-Test CEM Vac. 0.02 Pilot Init YES
Post-Test CEM Vac. 0.02 Pilot Init YES

PRE-TEST CALIBRATION CHECK:
Time ΔH Meter Meter Temp.
Init. 126.3 108.0 In Out
Final 126.3 108.0 In Out

SAMPLE POINT	TIME	METER CONDITIONS				TEMPERATURES, °F						O ₂	VAC.	STATIC PRESS. lwg	CHAIN OF CUSTODY INFORMATION
		ΔP	ΔH	METER READING	STACK	PROBE	METER		OVEN	IMP. OUT					
							IN	OUT							
7	1735	1.5	79	775.206	305	1	103	100		100		4			Impingers Loaded CH-
6	1541	1.4	76	773.361	304		106	102		102		4		7.8	Impingers Recovered CH-
5	1547	1.5	65	756.218	304		109	103		103		78	4		Filter Loaded CH-
6	1753	1.1	69	779.005	302		114	105		105		74	4		Filter Recovered CH-
3	1800		111	802.432	294		116	106		106		80	4		Probe Wash CH-
2	1806	1.8	85	826.541	284		118	107		107			4		TEST SUMMARY
1	1812	5.1	73	809.646	284		130	108		108		83	4		
Stop	1818			813.000											Calculated by:
															Checked by:
7	1826	1.5	52	817.000	303		118	110		110		80	4		Sample Vol., c.f. 39.244
6	1838	1.4	43	814.300	303		118	111		111		80	4		Stack Press., lwg 1.8
5	1834	1.4	51	816.550	298		117	112		112		78	4		ΔH, lwg 0.716
4	1840	1.0	66	815.050	296		115	112		112		78	4		ΔP, lwg 0.872
3	1841	0.5	57	821.674	284		120	112		112		80	4		Meter Temp., °F
2	1850	1.5	59	824.841	264		110	112		112		84	4		Stack Temp., °F
1	1858	1.1	51	827.418	254		121	113		113		84	4		Water Collected, g
Stop	1924			830.450									4		O ₂ /CO ₂
															Comments: 10206

SAMPLE TRAIN TEST DATA

CLIENT SCC/ Alamitos UNIT 2 TEST NO. 11-2-PM METHOD 5.3 PAGE 1 OF 1
 SAMPLE LOCATION CSA/H TEST CONDITION 0.09 0.0 AMB. TEMP., °F 74 PROJECT # 12590
 OPERATOR/ASSISTANT J. Mulligan METER VOL. (START/END) 548.020 1 DATE 10-8-92

PRE-TEST DATA:
 Barometric Press., in. Hg. 29.98
 Assumed Stack Press. 0.00
 Assumed Moisture 1.25
 Assumed Molecular Wt. 2.5
 Assumed ΔP 0.00
 Assumed ΔH 6.00
 Stack Diameter, in. 4.00
 Sample Time: Total 3.4
 per point 6
 Total of Traverse Points 14
 $\Delta H = 2.6$ x ΔP 2.3

EQUIPMENT INFO:
 Meter No. 125
 Meter, Yd. 0.375
 CFM @ $\Delta H = 1.0$ 0.375
 Pilot ID, Cp 0.84
 O₂/CO₂ Method 100
 Teflon Connecting 7-8220
 Line (Y/N) 8
 Probe: Mat'l 55
 Length 0.232
 Nozzle: Mat'l 47-453
 Diam. 55
 No. 55
 Filter: Mat'l 55

POST TEST INFO:
 Filter Appearance 55
 Impinger Appearance 55
 Silica Gel Spent (Y/N) 55

TEMPERATURES, °F

METER	METER		PROBE	STACK	IMP.	OVEN	IMP.	O ₂	VAC.	STATIC PRESS. twg	CHAIN OF CUSTODY INFORMATION
	IN	OUT									
1	90	84		336	64		64	11.3	2	8.0	Impingers Loaded <u>CF</u>
2	95	88		335	60		60	11.6	2		Impingers Recovered <u>CF</u>
3	98	90		335	58		58	11.5	2		Filter Loaded <u>CF</u>
4	99	90		335	58		58	11.4	2		Filter Recovered <u>CF</u>
5	99	91		335	60		60	11.5	2		Probe Wash <u>JM</u>
6	99	91		335	61		61	11.5	2		TEST SUMMARY
7	100	91		331	61		61	11.5	2		Calculated by: <u>JM</u>
8											Checked by:
9	55	91		336	65		65	11.4	5		Sample Vol., c.f. <u>35.735</u>
10	104	92		336	58		58	11.7	3		Stack Press., twg <u>49.0</u>
11	100	92		336	62		62	11.7	3		ΔH , twg <u>0.707</u>
12	100	92		336	63		63	11.7	3		ΔP , twg <u>0.318</u>
13	98	92		337	64		64	11.5	2		Meter Temp., °F <u>94.75</u>
14	97	92		337	67		67	11.5	4		Stack Temp., °F <u>335.4</u>
15	103	92		336	62		62	11.7	4		Water Collected, g <u>11.5</u>
16											O ₂ /CO ₂ <u>11.5 / 5.5</u>
17	588	405									Comments:

CLIENT SOC / H / Am. Gas

SAMPLE LOCATION

OPERATOR/ASSISTANT J. M. L. J. J.

SAMPLE TRAIN TEST DATA

UNIT 2TEST NO. 12-7-7mMETHOD 5.3PAGE 1 OF 1TEST CONDITION 40 mV / 100 kPaAMB. TEMP., °F 69

PROJECT #

METER VOL. (START/END) 588.855DATE 10-8-92

DATE

PRE-TEST DATA:

Barometric Press., in. Hg.

Assumed Stack Press.

Assumed Moisture

Assumed Molecular Wt.

Assumed ΔP Assumed ΔH

Stack Diameter, in.

Sample Time: Total

per point

Total of Traverse Points

 $\Delta H = 2.23$ x ΔP 2.23

EQUIPMENT INFO:

Meter No.

Meter, Yd.

CFM @ $\Delta H = 1.0$

Pilot ID, Cp

O₂/CO₂ Method

Teflon Connecting

Line (Y/N)

Probe: Mat'l

Length

Mat'l

Diam.

No.

Filter: Mat'l

IMPROVEMENT INFO:

Imp.

#1

#2

#3

#4

#5

Total

POST TEST INFO:

Filter Appearance

Impinger Appearance

Silica Gel Spent (Y/N)

SAMPLE TRAIN LEAK CHECK:

CEM

Vac.

Elot

Init.

Pre-Test

Post-Test

PRE-TEST CALIBRATION CHECK:

Time

 ΔH

Meter Reading

In

Out

Meter Temp.

SAMPLE TRAIN LEAK CHECK:

CEM

Vac.

Elot

Init.

Pre-Test

Post-Test

PRE-TEST CALIBRATION CHECK:

Time

 ΔH

Meter Reading

In

Out

Meter Temp.

SAMPLE TRAIN LEAK CHECK:

CEM

Vac.

Elot

Init.

Pre-Test

Post-Test

PRE-TEST CALIBRATION CHECK:

Time

 ΔH

Meter Reading

In

Out

Meter Temp.

SAMPLE TRAIN LEAK CHECK:

CEM

Vac.

Elot

Init.

Pre-Test

Post-Test

PRE-TEST CALIBRATION CHECK:

Time

 ΔH

Meter Reading

In

Out

Meter Temp.

SAMPLE TRAIN LEAK CHECK:

CEM

Vac.

Elot

Init.

Pre-Test

Post-Test

PRE-TEST CALIBRATION CHECK:

Time

 ΔH

Meter Reading

In

Out

Meter Temp.

SAMPLE POINT	TIME	METER CONDITIONS				TEMPERATURES, °F				STATIC PRESS. lwg	CHAIN OF CUSTODY INFORMATION			
		ΔP	ΔH	METER READING	STACK	PROBE	METER IN	METER OUT	OVEN	IMP. OUT	O ₂	VAC.	Impingers Loaded	Impingers Recovered
7	1215	1.49	1.12	568.855	337	1	104	93		200	12.0	5		
6	1321	1.35	1.03	572.471	338		108	94		65	12.0	3		
5	1327	1.17	1.40	595.468	338		105	94		66	12.4	2		
4	1333	1.11	1.26	598.025	338		102	95		64	12.5	2		
3	1339	1.17	1.40	599.871	338		100	94		63	12.4	2		
2	1345	1.15	1.35	602.276	338		101	95		64	12.1	5		
1	1357	1.61	1.45	604.165	338		99	94						
stop	1357			608.689										
7	1359	1.14	1.33	608.689	338		95	93		68	12.0	2		
6	1405	1.11	1.25	610.340	338		97	93		65	12.1	2		
5	1411	1.18	1.41	612.476	338		95	92		64	12.1	2		
4	1417	1.13	1.29	614.752	337		96	91		62	12.0	2		
3	1423	1.17	1.38	616.745	337		95	90		64	12.2	2		
2	1429	1.14	1.32	619.015	337		96	90		63	12.0	2		
1	1435	1.27	1.61	620.850	337		94	90		63	12.1	2		
stop	1441			623.548										

SAMPLE TRAIN TEST DATA

CLIENT COE/Plasma Tech UNIT 2 TEST NO. 13-2-PM METHOD S-3 PAGE 1 OF 1
 SAMPLE LOCATION COE/Plasma Tech TEST CONDITION COE/Plasma Tech AMB. TEMP., °F 74 PROJECT # 1000-5-52
 OPERATOR/ASSISTANT Paul Miller METER VOL. (START/END) 623.732 DATE 10-5-52

PRE-TEST DATA:		EQUIPMENT INFO:		METER CONDITIONS		TEMPERATURES, °F				STATIC PRESS. iwg		CHAIN OF CUSTODY INFORMATION			
Barometric Press., in. Hg.	Meter No.	Meter, Yd.	CFM @ ΔH = 1.0	Pilot ID, Cp	O ₂ /CO ₂ Method	Teflon Connecting	Line (Y/N)	Probe:	Nozzle:	Filter:	ΔP	ΔH	METER READING	TIME	SAMPLE POINT
29.5	58-19	1.00	286.4	572.2	11.0	11.0	90	107	107	107	11.5	11.5	623.732	15:55	7
Assumed Stack Press.	575	575	613.2	613.2	11.0	11.0	92	110	110	110	11.5	11.5	623.732	15:57	8
Assumed Moisture	1.5	1.5	504.0	504.0	9	9	94	105	105	105	11.5	11.5	623.732	15:59	9
Assumed ΔP	1.5	1.5	800.8	800.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	10
Assumed ΔH	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	11
Stack Diameter, in.	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	12
Sample Time: Total	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	13
per point	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	14
Total of Traverse Points	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	15

PRE-TEST DATA:		EQUIPMENT INFO:		METER CONDITIONS		TEMPERATURES, °F				STATIC PRESS. iwg		CHAIN OF CUSTODY INFORMATION			
Barometric Press., in. Hg.	Meter No.	Meter, Yd.	CFM @ ΔH = 1.0	Pilot ID, Cp	O ₂ /CO ₂ Method	Teflon Connecting	Line (Y/N)	Probe:	Nozzle:	Filter:	ΔP	ΔH	METER READING	TIME	SAMPLE POINT
29.5	58-19	1.00	286.4	572.2	11.0	11.0	90	107	107	107	11.5	11.5	623.732	15:55	7
Assumed Stack Press.	575	575	613.2	613.2	11.0	11.0	92	110	110	110	11.5	11.5	623.732	15:57	8
Assumed Moisture	1.5	1.5	504.0	504.0	9	9	94	105	105	105	11.5	11.5	623.732	15:59	9
Assumed ΔP	1.5	1.5	800.8	800.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	10
Assumed ΔH	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	11
Stack Diameter, in.	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	12
Sample Time: Total	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	13
per point	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	14
Total of Traverse Points	1.5	1.5	790.8	790.8	56	56	95	110	110	110	11.5	11.5	623.732	15:59	15

Appendix C.5
Hydrocarbon

CARNOT
TEDLAR BAG SAMPLE DATA

CLIENT/PROJECT: SCE/Alamitos

DATE: 10-6-92 UNIT: #2 BY: Rob M.

	BAG ID <u>1-2-NH3</u>	BAG ID <u>2-2</u>	BAG ID <u>3-2-NH3</u>
TEST NO.	<u>1-2</u>	<u>2-2</u>	<u>3-2-NH3</u>
SAMPLE RATE			
START TIME	<u>1012</u>	<u>1130</u>	<u>1316</u>
STOP TIME	<u>1032</u>	<u>1150</u>	<u>1336</u>
SAMPLE LOCATION	<u>W-CSAPH</u>	<u>E-CSAPH</u>	<u>E-CSAPH</u>

DATE: 10-6-92 UNIT: #2 BY: Rob M.

	BAG ID <u>4-2-NH3</u>	BAG ID <u>5-2-NH3</u>	BAG ID <u> </u>
TEST NO.	<u>4-2-NH3</u>	<u>5-2-NH3</u>	
SAMPLE RATE			
START TIME	<u>1410</u>	<u>1810</u>	
STOP TIME	<u>1430</u>	<u>1830</u>	
SAMPLE LOCATION	<u>E-CSAPH</u>	<u>W-CSAPH</u>	

NOTES:

CARNOT
TEDLAR BAG SAMPLE DATA

*12598

CLIENT/PROJECT: SCE/Alamitos

DATE: 10-7-92 UNIT: #2 BY: Rob M.

	BAG ID <u>6-2</u>	BAG ID <u>7-2</u>	BAG ID <u>8-2-NH₃</u>
TEST NO.	<u>6-2</u>	<u>7-2</u>	<u>8-2-NH₃</u>
SAMPLE RATE			
START TIME	<u>0917</u>	<u>1126</u>	<u>1400</u>
STOP TIME	<u>0937</u>	<u>1146</u>	<u>1420</u>
SAMPLE LOCATION	<u>W-CSAPH</u>	<u>E-CSAPH</u>	<u>E-CSAPH</u>

DATE: 10-7-92 UNIT: #2 BY: Rob M.

	BAG ID <u>9-2-NH₃</u>	BAG ID _____	BAG ID _____
TEST NO.	<u>9-2-NH₃</u>		
SAMPLE RATE			
START TIME	<u>1615</u>		
STOP TIME	<u>1635</u>		
SAMPLE LOCATION	<u>W-CSAPH</u>		

NOTES:

CARNOT TEDLAR BAG SAMPLE DATA

CLIENT/PROJECT: SCE/Alamitos

DATE: 10-8-92 UNIT: #2 BY: Rob. M.

	BAG ID <u>10-2-NH₂</u>	BAG ID <u>11-2-NH₂</u>	BAG ID <u>12-2</u>
TEST NO.	<u>10-2-NH₂</u>	<u>11-2-NH₂</u>	<u>12-2-NH₂</u>
SAMPLE RATE			
START TIME	<u>0909</u>	<u>1117</u>	<u>1345</u>
STOP TIME	<u>0929</u>	<u>1137</u>	<u>1405</u>
SAMPLE LOCATION	<u>W-CSAPH</u>	<u>E-CSAPH</u>	<u>-CSAPH</u>

DATE: 10-8-92 UNIT: #2 BY: Rob. M.

	BAG ID <u>13-2-HC</u>	BAG ID _____	BAG ID _____
TEST NO.	<u>13-2-HC</u>		
SAMPLE RATE			
START TIME	<u>1525</u>		
STOP TIME	<u>1545</u>		
SAMPLE LOCATION	<u>-CSAPH</u>	<u>-CSAPH</u>	

NOTES:

Appendix C.6
Ammonia

(West-5101)

CARNOT

SAMPLE TRAIN TEST DATA

CLIENT SCE/Alamitos UNIT 82 TEST NO. 5-2-NH3 METHOD NH3 Draft PAGE 1 OF 1
SAMPLE LOCATION C.S. APH TEST CONDITION Over On AMB. TEMP., °F 1 PROJECT # 12588
OPERATOR/ASSISTANT RM METER VOL. (START/END) 1 DATE 10-8-92

PRE-TEST DATA:
Barometric Press., in. Hg. _____
Assumed Stack Press. _____
Assumed Moisture _____
Assumed Molecular Wt. _____
Assumed ΔP _____
Assumed ΔH _____
Stack Diameter, in. 30
Sample Time: Total _____ per point
Total of Traverse Points 5
 $\Delta H =$ _____ x ΔP _____

EQUIPMENT INFO:
Meter No. _____
Meter, Yd. _____
CFM @ $\Delta H = 1.0$ _____
Pilot ID, Cp _____
O₂/CO₂ Method _____
Teflon Connecting _____
Line (Y/N) _____
Probe: Mar'l _____
Length _____
Nozzle: Mar'l _____
Diam. _____
No. _____
Filter: Mar'l _____

POST TEST INFO:
Filter Appearance _____
Impinger Appearance _____
Silica Gel Spent (Y/N) _____

Imp. Mtd. WL(End) WL(Start) WL(g)
#1 1.114 94 619.2 538.7 91.5
#2 1.114 84 536.9 575.4 61.5
#3 _____ 514.7 514.8 514.8 0.0
#4 56 655.8 646.6 9.2 9.2
#5 _____
Total _____

SAMPLE TRAIN LEAK CHECK:
SEM Vac. _____ Init. _____
Pre-Test 0.002 15 RM
Post-Test 0.002 7 RM

PRE-TEST CALIBRATION CHECK:
Meter Meter Meter
Time ΔH Reading In Out
Init. _____
Final _____

SAMPLE POINT	TIME	METER CONDITIONS				TEMPERATURES, °F						STATIC PRESS. iwg	CHAIN OF CUSTODY INFORMATION
		ΔP	ΔH	METER READING	STACK	PROBE	METER		OVEN	IMP. OUT			
							IN	OUT					
W-6	1810	(	1.5	867.078	/	/	86	86	/	ICE	/	Impingers Loaded RM	
5	1815	(	"	872.09	/	/	104	86	/	"	/	Impingers Recovered C H F	
4	1820	(	"	877.1	/	/	112	86	/	"	/	Filter Loaded	
3	1825	(	"	882.124	/	/	119	86	/	"	/	Filter Recovered	
2	1831	(	"	887.15	/	/	118	87	/	"	/	Probe Wash RM	
1	1836	(	"	892.1	/	/	120	87	/	"	/	TEST SUMMARY	
STOP	1841	(		897.117	/	/			/		/	Calculated by: 4	
		(			/	/			/		/	Checked by: 4	
		(			/	/			/		/	Sample Vol., c.f. 20.039	
		(			/	/			/		/	Stack Press., iwg	
		(			/	/			/		/	ΔH, iwg 1.5	
		(			/	/			/		/	ΔP, iwg	
		(			/	/			/		/	Meter Temp., °F 98.1	
		(			/	/			/		/	Stack Temp., °F	
		(			/	/			/		/	Water Collected, g 106.5	
		(			/	/			/		/	O ₂ /CO ₂ 7.5	
		(			/	/			/		/	Comments:	

SAMPLE TRAIN TEST DATA

CLIENT SCE/Alamogordo UNIT 2 TEST NO. 82-NH2 METHOD 1 OF 1
 SAMPLE LOCATION E-C5APH AMB. TEMP., °F 89.7, 314 PROJECT # 12598
 OPERATOR/ASSISTANT RM METER VOL. (START/END) 897.314 DATE 10-7-92

PRE-TEST DATA:
 Barometric Press., in. Hg. 30.05
 Assumed Stack Press. _____
 Assumed Moisture _____
 Assumed Molecular Wt. _____
 Assumed ΔP _____
 Assumed ΔH _____
 Stack Diameter, in. 30
 Sample Time: Total _____ per point
 Total of Traverse Points _____

EQUIPMENT INFO:
 Meter No. _____
 Meter, Yd. _____
 CFM @ $\Delta H = 1.0$ _____
 Pilot ID, Cp _____
 O₂/CO₂ Method _____
 Teflon Connecting _____
 Line (Y/N) _____
 Probe: Mat'l _____ Length _____
 Nozzle: Mat'l _____ Diam. _____
 Filter: No. _____ Mat'l _____

POST TEST INFO:
 Filter Appearance _____
 Impinger Appearance _____
 Silica Gel Spent (Y/N) _____

TEMPERATURES, °F

IMP.	Mat'l	METER		OVEN	IMP. OUT	O ₂	VAC.	STATIC PRESS. iwg	CHAIN OF CUSTODY INFORMATION
		IN	OUT						
#1	1.504	89.7	314		ICF		8.0		Impingers Loaded
#2	1.504	89.7	314		"		8.0		Impingers Recovered
#3	1.504	89.7	314		"		8.0		Filter Loaded
#4	1.504	89.7	314		"		8.0		Filter Recovered
#5	1.504	89.7	314		"		8.0		Probe Wash
Total									TEST SUMMARY

PRE-TEST CALIBRATION CHECK:
 Meter Reading _____
 Meter Temp. In _____ Out _____
 Imp. ΔH _____
 Final _____

SAMPLE TRAIN LEAK CHECK:
 CEM Vac. _____ Pilot _____
 Pre-Test 0.00 13" RM
 Post-Test 0.00 9" RM

SAMPLE POINT	TIME	METER CONDITIONS			TEMPERATURES, °F				STATIC PRESS. iwg	CHAIN OF CUSTODY INFORMATION
		ΔP	ΔH	METER READING	STACK	PROBE	METER IN	METER OUT		
E-6	1400	1.5		897.314			84	76		Impingers Loaded
5	1405	"		902.5			95	78		Impingers Recovered
4	1410	"		907.56			102	78		Filter Loaded
3	1415	"		912.641			106	78		Filter Recovered
2	1421	"		917.71			105	80		Probe Wash
1	1426	"		922.715			109	79		TEST SUMMARY
STOP	1431			927.769						Calculated by: _____
										Checked by: _____
										Sample Vol., c.f. <u>50.4</u>
										Stack Press., iwg
										ΔH , iwg
										ΔP , iwg
										Meter Temp., °F
										Stack Temp., °F
										Water Collected, g
										O ₂ /CO ₂ <u>92</u>
										Comments:

SAMPLE TRAIN TEST DATA

CLIENT SCE/Alameda UNIT 2 TEST NO. 9-2-1143 METHOD 1 OF 1
 SAMPLE LOCATION W-C5 APH TEST CONDITION AMB. TEMP. °F PROJECT # 12588
 OPERATOR/ASSISTANT RM METER VOL. (START/END) 928.075 958.171 DATE 10-7-92

PRE-TEST DATA:
 Barometric Press., in. Hg. 29.97
 Assumed Stack Press. 1.006
 Assumed Moisture 1.006
 Assumed Molecular Wt. CEM
 Assumed ΔP 30
 Assumed ΔH 3
 Stack Diameter, in. 30
 Sample Time: Total 3 per point 6
 Total of Traverse Points 6

EQUIPMENT INFO:
 Meter No. 1006
 Meter, Yd. 1.006
 CFM @ $\Delta H = 1.0$ 1.006
 Pilot ID, Cp 1.006
 O₂/CO₂ Method CEM
 Teflon Connecting Y
 Line (Y/N) Y
 Probe: 30
 Length 3
 Mat'l 3
 Nozzle: 3
 Diam. 3
 No. 3
 Filter: 3
 Mat'l 3

POST TEST INFO:
 Filter Appearance 1006
 Impinger Appearance 1006
 Silica Gel Spent (Y/N) 1006

SAMPLE TRAIN LEAK CHECK:
 CEM Vac. 1006 Pilot 1006 Init. 1006
 Pre-Test 1006 Post-Test 1006
 PRE-TEST CALIBRATION CHECK:
 Meter Reading 1006 In Out 1006
 Time ΔH 1006

SAMPLE POINT	TIME	METER CONDITIONS				TEMPERATURES, °F					STATIC PRESS. lwg	CHAIN OF CUSTODY INFORMATION		
		ΔP	ΔH	METER READING	STACK	PROBE	METER		OVEN	IMP. OUT			O ₂	VAC.
							IN	OUT						
W-6	1615	1	1.5	928.075	1	1	103	93	1	ICE	1	7.0	Impingers Loaded	
5	1620	1	"	933.03	1	1	115	93	1	"	1	7.0	Impingers Recovered	
4	1625	1	"	938.05	1	1	122	93	1	"	1	7.0	Filter Loaded	
3	1630 1631	1	"	943.062	1	1	128	94	1	"	1	7.0	Filter Recovered	
2	1636	1	"	948.12	1	1	126	95	1	"	1	7.0	Probe Wash	
1	1641	1	"	953.19	1	1	133	95	1	"	1	7.0	TEST SUMMARY	
STOP	1646	1		958.171	1	1			1				Calculated by: <u>1006</u>	
		1			1	1			1				Checked by: <u>1006</u>	
		1			1	1			1				Sample Vol., c.f. <u>1006</u>	
		1			1	1			1				Stack Press., lwg <u>1006</u>	
		1			1	1			1				ΔH, lwg <u>1006</u>	
		1			1	1			1				ΔP, lwg <u>1006</u>	
		1			1	1			1				Meter Temp., °F <u>1006</u>	
		1			1	1			1				Stack Temp., °F <u>1006</u>	
		1			1	1			1				Water Collected, g <u>1006</u>	
		1			1	1			1				O ₂ /CO ₂ <u>1006</u>	
		1			1	1			1				Comments:	

SAMPLE TRAIN TEST DATA

UNIT # 2 TEST NO. 10-2-2115 METHOD 2021 PAGE 1 OF 1
 TEST CONDITION AMB. TEMP. °F PROJECT # 12598
 METER VOL (START/END) 958.515 1889.459 DATE 10-8-92

EVENT INFO:

Imp. North WL(Start) 581.3 WL(End) 582.4 WL(g) 63.2

#1 0.0014 582.4 581.3 = 63.2

#2 0.0014 582.3 584.0 = 5.3

#3 0.0014 584.5 520.7 = 2.2

#4 0.0014 520.7 246.1 = 9.0

#5 0.0014 246.1 79.7 = 79.7

Total 79.7

POST TEST INFO:

Filter Appearance

Impinger Appearance

Silica Gel Spent (Y/N)

SAMPLE TRAIN LEAK CHECK:

Pre-Test 0.002 14 RM

Post-Test 0.002 9 RM

PRE-TEST CALIBRATION CHECK:

Time Meter Reading Meter Temp.

Init. In Out

Final

METER READING	TEMPERATURES, °F				O ₂	VAC.	STATIC PRESS. iwg	CHAIN OF CUSTODY INFORMATION
	STACK	PROBE	METER IN	METER OUT				
28.515	✓	✓	88	80	✓	8.0	✓	Impingers Loaded <u>CF</u>
31.66	✓	✓	94	80	✓	8.0	✓	Impingers Recovered <u>RM</u>
31.79	✓	✓	103	80	✓	8.0	✓	Filter Loaded <u> </u>
33.94	✓	✓	102	81	✓	8.0	✓	Filter Recovered <u> </u>
34.18	✓	✓	105	80	✓	8.0	✓	Probe Wash <u>RM</u>
34.31	✓	✓	108	80	✓	8.0	✓	TEST SUMMARY
39.459	✓	✓			✓		✓	Calculated by: <u>CF</u>
							✓	Checked by: <u> </u>
							✓	Sample Vol., c.f. <u>30.944</u>
							✓	Stack Press., iwg <u> </u>
							✓	Δ H, iwg <u>1.5</u>
							✓	Δ P, iwg <u> </u>
							✓	Meter Temp., °F <u>70.1</u>
							✓	Stack Temp., °F <u> </u>
							✓	Water Collected, g <u>79.7</u>
							✓	O ₂ /CO ₂ <u>11.6</u>
							✓	Comments: <u> </u>

Appendix D.1
General Emissions Calculations

EMISSION CALCULATIONS

1. Sample Volume and Isokinetics

- a. Sample gas volume, dscf

$$V_{m\ std} = 0.03342 V_m \left(P_{bar} + \frac{H}{13.6} \right) \left(\frac{T_{ref}}{T_m} \right) (Y)$$

- b. Water vapor volume, scf

$$V_{w\ std} = 0.0472 V_k \left(\frac{T_{ref}}{528\ ^\circ R} \right)$$

- c. Moisture content, nondimensional

$$B_{wo} = \frac{V_{w\ std}}{V_{m\ std} + V_{w\ std}}$$

- d. Stack gas molecular weight, lb/lb mole

$$MW_{dry} = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2)$$

$$MW_{wet} = MW_{dry} (1 - B_{wo}) + 18 (B_{wo})$$

- e. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

- f. Stack velocity, ft/sec

$$V_s = 2.90 C_p \sqrt{\Delta PT_s} \sqrt{\left(\frac{29.92}{P_s} \right) \left(\frac{28.95}{MW_{wet}} \right)}$$

- g. Actual stack flow rate, wacfm

$$Q = (V_s)(A_s)(60)$$

- h. Standard stack gas flow rate, dscfm

$$Q_{std} = Q (1 - B_{wo}) \left(\frac{T_{ref}}{T_s} \right) \left(\frac{P_s}{29.92} \right)$$

- i. Percent isokinetic

$$I = \left(\frac{17.32(T_s)(V_{m\ std})}{(1 - B_{wo})(\Theta)(V_s)(P_s)(D_n^2)} \right) \left(\frac{528\ ^\circ R}{T_{ref}} \right)$$

2. Particulate Emissions

- a. Grain loading, gr/dscf

$$C = 0.01543 \left(\frac{M_n}{V_{m, std}} \right)$$

- b. Grain loading at 12% CO
- ₂
- , gr/dscf

$$C_{12\% CO_2} = C \left(\frac{12}{\% CO_2} \right)$$

- c. Mass emissions, lb/hr

$$M = C(Q_{sd}) \frac{(60 \text{ min/hr})}{(7000 \text{ gr/lb})}$$

3. Gaseous Emissions, lb/hr

$$M = (ppm)(10^{-6}) \left(\frac{MW_i \text{ lb/lb mole}}{SV} \right) (Q_{sd})(60 \text{ min/hr})$$

where,

SV = specific molar volume of an ideal gas:

$$SV = 385.3 \text{ ft}^3/\text{lb mole} \quad \text{for } T_{ref} = 528^\circ R$$

$$SV = 379.5 \text{ ft}^3/\text{lb mole} \quad \text{for } T_{ref} = 520^\circ R$$

4. Emissions Rates, lb/10⁶ Btu

- a. Fuel factor at 68 °F, dscf/10
- ⁶
- Btu at 0% O
- ₂

$$F_{68} = \frac{10^6 [3.64(\%H) + 1.53(\%C) + 0.14(\%N) + 0.57(\%S) - 0.46(\%O_{2, fuel})]}{HHV, \text{ Btu/lb}}$$

- b. Fuel factor at 60 °F

$$F_{60} = F_{68} \left(\frac{520^\circ R}{528^\circ R} \right)$$

- c. Gaseous Emissions factor

$$\left(\frac{\text{lb}}{10^6 \text{ Btu}} \right)_i = (ppm)_i (10^{-6}) \left(\frac{MW_i \text{ lb}}{\text{lb mole}} \right) \left(\frac{1}{SV} \right) (F) \left(\frac{20.9}{20.9 - \%O_2} \right)$$

- d. Particulate emission factor

$$\left(\frac{\text{lb}}{10^6 \text{ Btu}} \right) = C \left(\frac{1 \text{ lb}}{7000 \text{ gr}} \right) (F) \left(\frac{20.9}{20.9 - \%O_2} \right)$$

Nomenclature:

A_s	=	stack area, ft ²
B_{wo}	=	flue gas moisture content
$C_{12\% CO_2}$	=	particulate grain loading, gr/dscf corrected to 12% CO ₂
C	=	particulate grain loading, gr/dscf
C_p	=	pitot calibration factor, dimensionless
D_n	=	nozzle diameter, in.
F	=	fuel F factor, dscf/10 ⁶ Btu at 0% O ₂
H	=	orifice pressure differential, iwg
I	=	% isokinetics
M_n	=	mass of collected particulate, mg
M_i	=	mass emissions of species i, lb/hr
MW	=	molecular weight of flue gas
MW_i	=	molecular weight of species i:
		NO _x : 46
		CO : 28
		SO _x : 64
		HC : 16
θ	=	sample time, min.
ΔP	=	average velocity head, iwg = $(\sqrt{\Delta P})^2$
P_{bar}	=	barometric pressure, in.Hg
P_s	=	stack absolute pressure, in.Hg
P_{sg}	=	stack static pressure, iwg

Nomenclature (Continued):

Q	=	wet stack gas flow rate at actual conditions, wacfm
Q_{sd}	=	dry stack gas flow rate at standard conditions, dscfm
SV	=	specific molar volume of an ideal gas at standard conditions, ft ³ /lb mole
T_m	=	meter temperature, °R
T_{ref}	=	reference temperature, °R
T_s	=	stack temperature, °R
V_s	=	stack velocity, ft/sec
V_k	=	volume of liquid collected in impingers, ml
V_m	=	dry meter volume uncorrected, dcf
$V_{m\ sd}$	=	dry meter volume at standard conditions, dscf
$V_{w\ sd}$	=	volume of water vapor at standard conditions, scf
Y	=	meter calibration coefficient

Appendix D.2
Specific Emissions Calculations

CARNOT EMISSIONS TRAILER **CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: SCE Alamitos

Condition: Urea On

Unit: #2

Load: 165 MW

Location: HSAPH

	O2%	CO2%	CO ppm	NOx ppm	
Analyzer Range:	10	25	100	250	
Span Value:	7.93	22.15	55.84	90.79	
Test #: 4-2-CEM	Date: 10/6/92				
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.05	0.00	0.00	1.25	
System Span	7.83	22.00	56.00	88.50	
Raw Average	2.41	10.49	3.52	105.72	
System Zero	0.05	0.00	0.40	1.25	
System Span	7.80	21.93	55.84	87.50	
Corrected Average	2.41	10.58	3.33	109.34	
System Bias Check					
Zero Pre-test	0.50%	0.00%	0.00%	0.50%	
Zero Post-test	0.50%	0.00%	0.40%	0.50%	
Span Pre-test	-0.96%	-0.60%	0.16%	-0.92%	
Span Post-test	-1.26%	-0.88%	0.00%	-1.32%	
Test #: 5-2-CEM	Date: 10/6/92				
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.02	0.00	0.10	0.75	
System Span	7.85	22.05	55.70	89.50	
Raw Average	2.41	10.50	5.95	102.75	
System Zero	0.02	0.00	0.10	0.50	
System Span	7.90	21.98	55.84	90.75	
Corrected Average	2.41	10.56	5.87	103.60	
System Bias Check					
Zero Pre-test	0.20%	0.00%	0.10%	0.30%	
Zero Post-test	0.20%	0.00%	0.10%	0.20%	
Span Pre-test	-0.76%	-0.40%	-0.14%	-0.52%	
Span Post-test	-0.26%	-0.68%	0.00%	-0.02%	
Test Average	2.41	10.57	4.60	106.47	

CARNOT EMISSIONS TRAILER **CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: SCE Alamitos
Unit: #2
Location: HSAPH

Condition: Urea Off
Load: 138 MW

	O2%	CO2%	CO ppm	NOx ppm	
Analyzer Range:	10	25	100	250	
Span Value:	4.99	15.00	55.84	90.79	
Test #:	6-2-CEM			Date:	10/7/92
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.03	0.00	0.30	0.75	
System Span	4.97	14.75	55.84	88.25	
Raw Average	3.37	9.82	1.00	80.68	
System Zero	0.02	0.00	0.30	0.75	
System Span	4.93	14.70	55.90	88.30	
Corrected Average	3.39	10.00	0.70	82.91	
System Bias Check					
Zero Pre-test	0.30%	0.00%	0.30%	0.30%	
Zero Post-test	0.20%	0.00%	0.30%	0.30%	
Span Pre-test	-0.20%	-1.00%	0.00%	-1.02%	
Span Post-test	-0.60%	-1.20%	0.06%	-1.00%	
Test #:	7-2-CEM			Date:	10/7/92
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.02	0.00	0.20	0.50	
System Span	4.92	14.75	55.50	88.00	
Raw Average	3.61	9.69	0.72	80.78	
System Zero	0.02	0.05	0.20	0.50	
System Span	4.91	14.70	55.84	87.50	
Corrected Average	3.66	9.86	0.52	83.54	
System Bias Check					
Zero Pre-test	0.20%	0.00%	0.20%	0.20%	
Zero Post-test	0.20%	0.20%	0.20%	0.20%	
Span Pre-test	-0.70%	-1.00%	-0.34%	-1.12%	
Span Post-test	-0.80%	-1.20%	0.00%	-1.32%	
Test Average	3.52	9.93	0.61	83.22	

CARNOT EMISSIONS TRAILER **CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: SCE Alamitos
Unit: #2
Location: HSAPH

Condition: Urea Off
Load: 165 MW

	O2%	CO2%	CO ppm	NOx ppm	
Analyzer Range:	10	25	100	250	
Span Value:	4.99	15.00	55.84	90.79	
Test #:	1-2-CEM		Date: 10/6/92		
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.05	0.00	0.00	0.50	
System Span	4.93	14.75	56.00	87.30	
Raw Average	2.80	10.03	0.80	141.12	
System Zero	0.06	0.03	0.00	1.75	
System Span	4.94	14.58	55.90	87.50	
Corrected Average	2.81	14.58	0.80	147.32	
System Bias Check					
Zero Pre-test	0.50%	0.00%	0.00%	0.20%	
Zero Post-test	0.60%	0.12%	0.00%	0.70%	
Span Pre-test	-0.60%	-1.00%	0.16%	-1.40%	
Span Post-test	-0.50%	-1.68%	0.06%	-1.32%	
Test #:			Date:		
	O2%	CO2%	CO ppm	NOx ppm	
System Zero					
System Span					
Raw Average					
System Zero					
System Span					
Corrected Average					
System Bias Check					
Zero Pre-test					
Zero Post-test					
Span Pre-test					
Span Post-test					
Test Average					

CARNOT EMISSIONS TRAILER **CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: SCE Alamitos
Unit: #2
Location: HSAPH

Condition: Urea Off
Load: 165 MW

	O2%	CO2%	CO ppm	NOx ppm	
Analyzer Range:	10	25	100	250	
Span Value:	7.93	22.15	55.84	90.79	
Test #:	3-2-CEM		Date: 10/6/92		
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.02	0.00	0.00	0.50	
System Span	7.80	21.68	55.84	90.00	
Raw Average	2.41	10.40	1.90	141.52	
System Zero	0.03	0.00	0.00	2.50	
System Span	7.90	21.60	55.80	91.60	
Corrected Average	2.42	14.58	1.90	142.36	
System Bias Check					
Zero Pre-test	0.20%	0.00%	0.00%	0.20%	
Zero Post-test	0.30%	0.00%	0.00%	1.00%	
Span Pre-test	-1.26%	-1.88%	0.00%	-0.32%	
Span Post-test	-0.26%	-2.20%	-0.04%	0.32%	
Test #:			Date:		
	O2%	CO2%	CO ppm	NOx ppm	
System Zero					
System Span					
Raw Average					
System Zero					
System Span					
Corrected Average					
System Bias Check					
Zero Pre-test					
Zero Post-test					
Span Pre-test					
Span Post-test					
Test Average					

CARNOT EMISSIONS TRAILER **CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: SCE Alamitos
Unit: #2
Location: HSAPH

Condition: Urea On
Load: 165 MW

	O2%	CO2%	CO ppm	NOx ppm	
Analyzer Range:	10	25	100	250	
Span Value:	7.93	22.15	55.84	90.79	
Test #: 4-2-CEM	Date: 10/6/92				
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.05	0.00	0.00	1.25	
System Span	7.83	22.00	56.00	88.50	
Raw Average	2.41	10.49	3.52	105.72	
System Zero	0.05	0.00	0.40	1.25	
System Span	7.80	21.93	55.84	87.50	
Corrected Average	2.41	10.58	3.33	109.34	
System Bias Check					
Zero Pre-test	0.50%	0.00%	0.00%	0.50%	
Zero Post-test	0.50%	0.00%	0.40%	0.50%	
Span Pre-test	-0.96%	-0.60%	0.16%	-0.92%	
Span Post-test	-1.26%	-0.88%	0.00%	-1.32%	
Test #: 5-2-CEM	Date: 10/6/92				
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.02	0.00	0.10	0.75	
System Span	7.85	22.05	55.70	89.50	
Raw Average	2.41	10.50	5.95	102.75	
System Zero	0.02	0.00	0.10	0.50	
System Span	7.90	21.98	55.84	90.75	
Corrected Average	2.41	10.56	5.87	103.60	
System Bias Check					
Zero Pre-test	0.20%	0.00%	0.10%	0.30%	
Zero Post-test	0.20%	0.00%	0.10%	0.20%	
Span Pre-test	-0.76%	-0.40%	-0.14%	-0.52%	
Span Post-test	-0.26%	-0.68%	0.00%	-0.02%	
Test Average	2.41	10.57	4.60	106.47	

CARNOT EMISSIONS TRAILER **CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: SCE Alamitos
Unit: #2
Location: HSAPH

Condition: Urea Off
Load: 138 MW

	O2%	CO2%	CO ppm	NOx ppm	
Analyzer Range:	10	25	100	250	
Span Value:	4.99	15.00	55.84	90.79	
Test #:	6-2-CEM		Date:	10/7/92	
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.03	0.00	0.30	0.75	
System Span	4.97	14.75	55.84	88.25	
Raw Average	3.37	9.82	1.00	80.68	
System Zero	0.02	0.00	0.30	0.75	
System Span	4.93	14.70	55.90	88.30	
Corrected Average	3.39	10.00	0.70	82.91	
System Bias Check					
Zero Pre-test	0.30%	0.00%	0.30%	0.30%	
Zero Post-test	0.20%	0.00%	0.30%	0.30%	
Span Pre-test	-0.20%	-1.00%	0.00%	-1.02%	
Span Post-test	-0.60%	-1.20%	0.06%	-1.00%	
Test #:	7-2-CEM		Date:	10/7/92	
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.02	0.00	0.20	0.50	
System Span	4.92	14.75	55.50	88.00	
Raw Average	3.61	9.69	0.72	80.78	
System Zero	0.02	0.05	0.20	0.50	
System Span	4.91	14.70	55.84	87.50	
Corrected Average	3.66	9.86	0.52	83.54	
System Bias Check					
Zero Pre-test	0.20%	0.00%	0.20%	0.20%	
Zero Post-test	0.20%	0.20%	0.20%	0.20%	
Span Pre-test	-0.70%	-1.00%	-0.34%	-1.12%	
Span Post-test	-0.80%	-1.20%	0.00%	-1.32%	
Test Average	3.52	9.93	0.61	83.22	

CARNOT EMISSIONS TRAILER **CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: SCE Alamitos
Unit: #2
Location: HSAPH

Condition: Urea On
Load: 138 MW

	O2%	CO2%	CO ppm	NOx ppm	
Analyzer Range:	10	25	100	250	
Span Value:	4.99	15.00	55.84	90.79	
Test #: 8-2-CEM	Date: 10/7/92				
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.02	0.00	0.23	0.25	
System Span	4.88	14.75	55.84	89.25	
Raw Average	3.47	9.75	1.52	69.60	
System Zero	0.03	0.00	0.20	0.75	
System Span	4.87	14.70	55.84	89.25	
Corrected Average	3.54	9.93	1.31	70.69	
System Bias Check					
Zero Pre-test	0.20%	0.00%	0.23%	0.10%	
Zero Post-test	0.30%	0.00%	0.20%	0.30%	
Span Pre-test	-1.10%	-1.00%	0.00%	-0.62%	
Span Post-test	-1.20%	-1.20%	0.00%	-0.62%	
Test #: 9-2-CEM	Date: 10/7/92				
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.01	0.00	0.20	0.50	
System Span	4.96	14.80	55.84	90.52	
Raw Average	3.57	9.75	1.17	71.72	
System Zero	0.02	0.00	0.20	0.50	
System Span	4.95	14.83	55.84	90.25	
Corrected Average	3.59	9.87	0.97	71.94	
System Bias Check					
Zero Pre-test	0.10%	0.00%	0.20%	0.20%	
Zero Post-test	0.20%	0.00%	0.20%	0.20%	
Span Pre-test	-0.30%	-0.80%	0.00%	-0.11%	
Span Post-test	-0.40%	-0.68%	0.00%	-0.22%	
Test Average	3.57	9.90	1.14	71.31	

CARNOT EMISSIONS TRAILER **CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: SCE Alamitos
Unit: #2
Location: HSAPH

Condition: Urea On
Load: 40 MW

	O2%	CO2%	CO ppm	NOx ppm	
Analyzer Range:	10	25	100	250	
Span Value:	4.99	15.00	55.84	49.86	
Test #: 10-2-CEM	Date: 10/8/92				
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.02	0.00	0.30	0.30	
System Span	4.97	14.93	55.84	48.50	
Raw Average	7.29	7.66	0.90	86.42	
System Zero	0.03	0.00	0.50	-0.25	
System Span	4.97	14.85	55.84	48.00	
Corrected Average	7.33	7.72	0.50	89.32	
System Bias Check					
Zero Pre-test	0.20%	0.00%	0.30%	0.12%	
Zero Post-test	0.30%	0.00%	0.50%	-0.10%	
Span Pre-test	-0.20%	-0.28%	0.00%	-0.54%	
Span Post-test	-0.20%	-0.60%	0.00%	-0.74%	
Test #: 11-2-CEM	Date: 10/8/92				
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.03	0.00	0.10	0.30	
System Span	4.98	14.80	55.84	48.50	
Raw Average	7.41	7.55	0.80	90.25	
System Zero	0.02	0.00	0.10	1.70	
System Span	5.00	14.90	55.84	49.50	
Corrected Average	7.42	7.63	0.70	92.71	
System Bias Check					
Zero Pre-test	0.30%	0.00%	0.10%	0.12%	
Zero Post-test	0.20%	0.00%	0.10%	0.68%	
Span Pre-test	-0.10%	-0.80%	0.00%	-0.54%	
Span Post-test	0.10%	-0.40%	0.00%	-0.14%	
Test Average	7.38	7.67	0.60	91.02	

CARNOT EMISSIONS TRAILER					
CONTINUOUS GASEOUS MEASUREMENTS SUMMARY					
Client:	SCE Alamitos		Condition:	Urea Off	
Unit:	#2		Load:	40 MW	
Location:	HSAPH				
		O2%	CO2%	CO ppm	NOx ppm
Analyzer Range:	10	25	100	250	
Span Value:	4.99	15.00	55.84	90.52	
Test #:	12-2-CEM		Date:	10/8/92	
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.03	0.00	0.00	0.25	
System Span	4.99	14.80	55.84	87.00	
Raw Average	7.31	7.55	0.32	103.48	
System Zero	0.02	0.00	0.00	0.25	
System Span	4.97	14.80	55.70	85.60	
Corrected Average	7.34	7.65	0.32	108.59	
System Bias Check					
Zero Pre-test	0.30%	0.00%	0.00%	0.10%	
Zero Post-test	0.20%	0.00%	0.00%	0.10%	
Span Pre-test	0.00%	-0.80%	0.00%	-1.41%	
Span Post-test	-0.20%	-0.80%	-0.14%	-1.97%	
Test #:	13-2CEM		Date:	10/8/92	
	O2%	CO2%	CO ppm	NOx ppm	
System Zero	0.03	0.00	0.10	0.00	
System Span	4.99	14.75	55.84	86.25	
Raw Average	7.34	7.50	0.40	103.30	
System Zero	0.02	0.00	0.10	0.50	
System Span	5.00	14.70	55.84	87.50	
Corrected Average	7.34	7.64	0.30	107.68	
System Bias Check					
Zero Pre-test	0.30%	0.00%	0.10%	0.00%	
Zero Post-test	0.20%	0.00%	0.10%	0.20%	
Span Pre-test	0.00%	-1.00%	0.00%	-1.71%	
Span Post-test	0.10%	-1.20%	0.00%	-1.21%	
Test Average	7.34	7.65	0.31	108.14	

CARNOT

11/24/92

Particulate

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	Urea Off
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	1-2-PM	3-2-PM	Average
Reference Temperature, F.....	60	60	
Test Date.....	10/6/92	10/6/92	
Test Method.....	SCAQMD 5.3	SCAQMD 5.3	SCAQMD 5.3
Sample Train.....	71-4	71-4	-
Pitot Factor	0.840	0.840	-
Meter Calibration Factor.....	1.004	1.004	-
Stack Area (sq ft).....	68.43	68.43	-
Sample Time (Min).....	84	84	84
Barometric Pressure (in Hg).....	30.08	29.94	30.08
Nozzle Diam (in).....	0.185	0.194	-
Start/Stop Time.....	900/1027	1305/1449	-
Stack Pressure (iwg).....	5.90	7.10	6.50
Stack Temperature (F).....	314.5	329.0	321.8
Delta P (iwg).....	1.2868	1.5245	1.4057
Meter Volume (acf).....	44.316	51.468	47.892
Meter Temperature (F).....	82.0	97.8	89.9
Meter Pressure (iwg).....	1.157	1.152	1.155
Liquid Volume (ml).....	150.7	185.6	168.2
Stack O2 (%).....	7.7	7.4	7.6
Stack CO2 (%).....	7.8	7.9	7.9
Standard Sample Volume (SCF)	43.034	48.341	45.688
Moisture Fraction.....	0.140	0.151	0.146
Molecular Weight. (wet).....	27.94	27.81	27.87
Stack Gas Velocity (ft/sec).....	77.53	85.44	81.48
Stack Flow Rate (wacfm).....	318,307	350,796	334,551
Stack Flow Rate (dscfm).....	187,400	199,694	193,547
Isokinetic Ratio (%).....	100.18	96.04	98.11
Particulate Catch, mg.....	2.80	1.80	2.30
Grain Loading gr/dscf.....	0.0010	0.0006	0.0008
Grain Loading @ 12% CO2.....	0.0015	0.0009	0.0012
Part emission lb/hr.....	1.61	0.98	1.30

CARNOT

11/24/92

Particulate

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	Urea On
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	4-2-PM	5-2-PM	Average
Reference Temperature, F.....	60	60	SCAQMD 5.3
Test Date.....	10/6/92	10/6/92	
Test Method.....	SCAQMD 5.3	SCAQMD 5.3	
Sample Train.....	71-4	71-4	
Pitot Factor	0.840	0.840	
Meter Calibration Factor.....	1.004	1.004	
Stack Area (sq ft).....	68.43	68.43	
Sample Time (Min).....	84	84	
Barometric Pressure (in Hg).....	30.05	29.92	30.05
Nozzle Diam (in).....	0.185	0.185	-
Start/Stop Time.....	1530/1700	1740/1907	-
Stack Pressure (iwg).....	6.80	6.50	6.65
Stack Temperature (F).....	310.4	319.6	315.0
Delta P (iwg).....	1.7800	1.4044	1.5922
Meter Volume (acf).....	55.541	48.381	51.961
Meter Temperature (F).....	106.8	97.4	102.1
Meter Pressure (iwg).....	1.369	1.081	1.225
Liquid Volume (ml).....	213.0	175.0	194.0
Stack O2 (%).....	7.4	7.4	7.4
Stack CO2 (%).....	7.9	7.9	7.9
Standard Sample Volume (SCF)	51.548	45.436	48.492
Moisture Fraction.....	0.161	0.152	0.156
Molecular Weight. (wet).....	27.70	27.80	27.75
Stack Gas Velocity (ft/sec).....	91.28	81.61	86.44
Stack Flow Rate (wacfm).....	374,765	335,064	354,915
Stack Flow Rate (dscfm).....	216,630	192,539	204,585
Isokinetic Ratio (%).....	103.81	102.95	103.38
Particulate Catch, mg.....	2.10	2.30	2.20
Grain Loading gr/dscf.....	0.0006	0.0008	0.0007
Grain Loading @ 12% CO2.....	0.0010	0.0012	0.0011
Part emission lb/hr.....	1.17	1.29	1.23

CARNOT

11/24/92

Particulate

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	Urea Off
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	6-2-PM	7-2-PM	Average
Reference Temperature, F.....	60	60	
Test Date.....	10/7/92	10/7/92	
Test Method.....	SCAQMD 5.3	SCAQMD 5.3	SCAQMD 5.3
Sample Train.....	71-4	71-4	-
Pitot Factor	0.840	0.840	-
Meter Calibration Factor.....	1.004	1.004	-
Stack Area (sq ft).....	68.43	68.43	-
Sample Time (Min).....	84	84	84
Barometric Pressure (in Hg).....	30.01	30.05	30.01
Nozzle Diam (in).....	0.185	0.185	-
Start/Stop Time.....	0830/1012	1056/1222	-
Stack Pressure (iwg).....	7.80	5.80	6.80
Stack Temperature (F).....	300.2	339.6	319.9
Delta P (iwg).....	0.8762	1.4204	1.1483
Meter Volume (acf).....	35.308	46.503	40.906
Meter Temperature (F).....	81.5	96.1	88.8
Meter Pressure (iwg).....	0.628	1.113	0.871
Liquid Volume (ml).....	118.8	156.4	137.6
Stack O2 (%).....	8.5	8.1	8.3
Stack CO2 (%).....	7.2	7.4	7.3
Standard Sample Volume (SCF)	34.194	43.966	39.080
Moisture Fraction.....	0.139	0.142	0.140
Molecular Weight. (wet).....	27.89	27.87	27.88
Stack Gas Velocity (ft/sec).....	63.36	82.91	73.13
Stack Flow Rate (wacfm).....	260,131	340,393	300,262
Stack Flow Rate (dscfm).....	156,560	193,454	175,007
Isokinetic Ratio (%).....	95.28	99.15	97.22
Particulate Catch, mg.....	0.40	1.10	0.75
Grain Loading gr/dscf.....	0.0002	0.0004	0.0003
Grain Loading @ 12% CO2.....	0.0003	0.0006	0.0005
Part emission lb/hr.....	0.24	0.64	0.44

CARNOT

11/24/92

Particulate

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	Urea On
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	8-2-PM	9-2-PM	Average
Reference Temperature, F.....	60	60	
Test Date.....	10/7/92	10/7/92	
Test Method.....	SCAQMD 5.3	SCAQMD 5.3	SCAQMD 5.3
Sample Train.....	71-4	71-4	-
Pitot Factor	0.840	0.840	-
Meter Calibration Factor.....	1.004	1.004	-
Stack Area (sq ft).....	68.43	68.43	-
Sample Time (Min).....	84	84	84
Barometric Pressure (in Hg).....	30.05	30.08	30.05
Nozzle Diam (in).....	0.185	0.185	-
Start/Stop Time.....	1327/1457	1535/1704	-
Stack Pressure (iwg).....	5.20	7.80	6.50
Stack Temperature (F).....	342.3	298.5	320.4
Delta P (iwg).....	1.2140	0.8672	1.0406
Meter Volume (acf).....	46.085	39.244	42.665
Meter Temperature (F).....	102.4	111.9	107.2
Meter Pressure (iwg).....	1.054	0.716	0.885
Liquid Volume (ml).....	159.2	126.3	142.8
Stack O2 (%).....	8.2	7.8	8.0
Stack CO2 (%).....	7.3	7.5	7.4
Standard Sample Volume (SCF)	43.075	36.075	39.575
Moisture Fraction.....	0.147	0.140	0.143
Molecular Weight. (wet).....	27.81	27.90	27.86
Stack Gas Velocity (ft/sec).....	76.92	62.88	69.90
Stack Flow Rate (wacfm).....	315,813	258,176	286,995
Stack Flow Rate (dscfm).....	177,634	155,921	166,778
Isokinetic Ratio (%).....	105.79	100.94	103.36
Particulate Catch, mg.....	3.30	1.60	2.45
Grain Loading gr/dscf.....	0.0012	0.0007	0.0009
Grain Loading @ 12% CO2.....	0.0019	0.0011	0.0015
Part emission lb/hr.....	1.80	0.91	1.36

CARNOT

11/9/92

Particulate

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	Urea On
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	10-2-PM	11-2-PM	Average
Reference Temperature, F.....	60	60	
Test Date.....	10/8/92	10/8/92	
Test Method.....	SCAQMD 5.3	SCAQMD 5.3	SCAQMD 5.3
Sample Train.....	71-4	ES-19	-
Pitot Factor	0.840	0.840	-
Meter Calibration Factor.....	1.004	1.000	-
Stack Area (sq ft).....	68.43	68.43	-
Sample Time (Min).....	84	84	84
Barometric Pressure (in Hg).....	30.05	29.98	30.05
Nozzle Diam (in).....	0.220	0.250	-
Start/Stop Time.....	835/1012	1105/1233	-
Stack Pressure (iwg).....	10.00	9.00	9.50
Stack Temperature (F).....	282.2	335.4	308.8
Delta P (iwg).....	0.3706	0.2780	0.3243
Meter Volume (acf).....	33.493	39.735	36.614
Meter Temperature (F).....	86.5	94.8	90.6
Meter Pressure (iwg).....	0.732	0.707	0.720
Liquid Volume (ml).....	107.5	108.0	107.8
Stack O2 (%).....	11.6	11.5	11.6
Stack CO2 (%).....	5.4	5.5	5.5
Standard Sample Volume (SCF)	32.193	37.383	34.788
Moisture Fraction.....	0.134	0.118	0.126
Molecular Weight. (wet).....	27.81	28.00	27.90
Stack Gas Velocity (ft/sec).....	40.64	36.40	38.52
Stack Flow Rate (wacfm).....	166,878	149,461	158,170
Stack Flow Rate (dscfm).....	104,113	88,202	96,157
Isokinetic Ratio (%).....	95.39	101.25	98.32
Particulate Catch, mg.....	0.70	5.50	3.10
Grain Loading gr/dscf.....	0.0003	0.0023	0.0013
Grain Loading @ 12% CO2.....	0.0007	0.0050	0.0028
Part emission lb/hr.....	0.30	1.72	1.01

CARNOT

11/9/92

Particulate

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	Urea Off
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	12-2-PM	13-2-PM	Average
Reference Temperature, F.....	60	60	
Test Date.....	10/8/92	10/8/92	
Test Method.....	SCAQMD 5.3	SCAQMD 5.3	SCAQMD 5.3
Sample Train.....	ES-19	ES-19	-
Pitot Factor	0.840	0.840	-
Meter Calibration Factor.....	1.000	1.000	-
Stack Area (sq ft).....	68.43	68.43	-
Sample Time (Min).....	84	84	84
Barometric Pressure (in Hg).....	30.00	30.00	30.00
Nozzle Diam (in).....	0.250	0.250	-
Start/Stop Time.....	1215/1441	1515/1641	-
Stack Pressure (iwg).....	9.10	10.10	9.60
Stack Temperature (F).....	337.6	284.1	310.9
Delta P (iwg).....	0.2098	0.4322	0.3210
Meter Volume (acf).....	34.689	50.145	42.417
Meter Temperature (F).....	96.0	104.7	100.3
Meter Pressure (iwg).....	0.529	1.152	0.841
Liquid Volume (ml).....	91.8	134.3	113.1
Stack O2 (%).....	12.2	11.1	11.6
Stack CO2 (%).....	5.1	5.8	5.5
Standard Sample Volume (SCF)	32.572	46.428	39.500
Moisture Fraction.....	0.116	0.119	0.117
Molecular Weight. (wet).....	27.99	28.03	28.01
Stack Gas Velocity (ft/sec).....	31.66	43.81	37.73
Stack Flow Rate (wacfm).....	129,975	179,862	154,919
Stack Flow Rate (dscfm).....	76,778	113,817	95,297
Isokinetic Ratio (%).....	101.35	97.45	99.40
Particulate Catch, mg.....	0.70	0.80	0.75
Grain Loading gr/dscf.....	0.0003	0.0003	0.0003
Grain Loading @ 12% CO2.....	0.0008	0.0006	0.0007
Part emission lb/hr.....	0.22	0.26	0.24

CARNOT

11/9/92

Ammonia

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	165 MW
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	4-2-NH3	5-2-NH3	Average
Reference Temperature, F.....	60	60	
Test Date.....	10/6/92	10/6/92	
Test Method.....	NH3 Draft	NH3 Draft	NH3 Draft
Sample Train.....	North Outlet	North Outlet	-
Meter Calibration Factor.....	0.975	0.975	-
Sample Time (Min).....	30	30	30
Barometric Pressure (in Hg).....	30.05	29.92	30.05
Start/Stop Time.....	1610/1641	1810/1841	-
Meter Volume (acf).....	30.346	30.039	30.193
Meter Temperature (F).....	95.4	98.1	96.8
Meter Pressure (iwg).....	1.500	1.500	1.500
Liquid Volume (ml).....	107.4	106.3	106.9
Stack O2 (%).....	7.4	7.4	7.4
Stack CO2 (%).....	7.9	7.9	7.9
Standard Sample Volume (SCF)	27.916	27.382	27.649
Moisture Fraction.....	0.152	0.153	0.152
Molecular Weight. (wet).....	27.81	27.79	27.80
AMMONIA ANALYSIS			
NH3 ppm wt in solution.....	3.61	10.05	6.83
Sample volume (ml).....	630	640	635
NH3 ppmV in flue gas.....	4.0	11.5	7.8
NH3 ppmV @ 3%O2.....	5.3	15.3	10.3

CARNOT

11/9/92

Ammonia

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	138 MW
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	8-2-NH3	9-2-NH3	Average
Reference Temperature, F.....	60	60	
Test Date.....	10/7/92	10/7/92	
Test Method.....	NH3 Draft	NH3 Draft	NH3 Draft
Sample Train.....	North Outlet	North Outlet	-
Meter Calibration Factor.....	0.975	0.975	-
Sample Time (Min).....	30	30	30
Barometric Pressure (in Hg).....	30.05	29.99	30.05
Start/Stop Time.....	1400/1431	1615/1646	-
Meter Volume (acf).....	30.455	30.096	30.276
Meter Temperature (F).....	89.0	107.4	98.2
Meter Pressure (iwg).....	1.500	1.500	1.500
Liquid Volume (ml).....	98.5	106.3	102.4
Stack O2 (%).....	8.2	7.8	8.0
Stack CO2 (%).....	7.3	7.5	7.4
Standard Sample Volume (SCF)	28.343	27.047	27.695
Moisture Fraction.....	0.139	0.154	0.147
Molecular Weight. (wet).....	27.90	27.73	27.82
AMMONIA ANALYSIS			
NH3 ppm wt in solution.....	3.25	7.37	5.31
Sample volume (ml).....	580	560	570
NH3 ppmV in flue gas.....	3.3	7.5	5.4
NH3 ppmV @ 3%O2.....	4.6	10.2	7.4

CARNOT

11/9/92

Ammonia

SOURCE TEST DATA SUMMARY WORKSHEET

Client/Location.....	SCE	Parameter.....	40 MW
Unit.....	2	Fuel.....	Natural Gas
Sample Location.....	CSAPH	Data By.....	EF
Test Number.....	10-2-NH3	11-2-NH3	Average
Reference Temperature, F.....	60	60	NH3 Draft
Test Date.....	10/8/92	10/8/92	
Test Method.....	NH3 Draft	NH3 Draft	
Sample Train.....	North Outlet	North Outlet	
Meter Calibration Factor.....	0.975	0.975	
Sample Time (Min).....	30	30	
Barometric Pressure (in Hg).....	30.05	30.05	
Start/Stop Time.....	0900/0931	1116/1147	-
Meter Volume (acf).....	30.944	31.837	31.391
Meter Temperature (F).....	90.1	91.9	91.0
Meter Pressure (iwg).....	1.500	1.500	1.500
Liquid Volume (ml).....	79.7	85.3	82.5
Stack O2 (%).....	11.6	11.5	11.6
Stack CO2 (%).....	5.4	5.5	5.5
Standard Sample Volume (SCF)	28.741	29.474	29.107
Moisture Fraction.....	0.114	0.119	0.116
Molecular Weight. (wet).....	28.03	28.00	28.01
AMMONIA ANALYSIS			
NH3 ppm wt in solution.....	4.01	3.18	3.60
Sample volume (ml).....	595	475	535
NH3 ppmV in flue gas.....	4.1	2.5	3.3
NH3 ppmV @ 3%O2.....	7.8	4.8	6.3

CARNOT

SUBJECT NO_x / NO Concentration JOB NO. 12598

SHEET NO. of

COMPUTED BY LS DATE CHECKED BY DATE

<u>TEST #</u>	<u>NO_x</u>	<u>NO</u>
1-2	107.0	101.3
2-2	105.0	96.3
3-2	106.8	98.0
4-2	81.3	76.0
5-2	78.3	73.0
6-3	47.0	43.8
9-3	46.3	44.5
8-2	37.5	36.3
7-2	38.8	37.5
10-2	54.5	51.0
11-2	53.0	52.0
13-2	68.3	66.3

APPENDIX E
LABORATORY REPORTS

PARTICULATE **SCAQMD 5.3, IN STACK FILTER**

PROJECT # 12598

WATER BLANK mg/ml 0.0020 Front 1/2
0.0040 Back 1/2

CLIENT/LOCATION SCE Alamitos 2

MeCl₂ BLANK mg/ml 0.0013

SAMPLE DATE 10/16/92

SAMPLE LOCATION CSAPH

DATA ANALYSIS DATE 10/16/92

TEST # 1-2-PM

ANALYST INITIALS JRW

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	45-167	0.1020	0.1027	-0.7	—	/	0.5 -0.7
2. PROBE AND NOZZLE WASH	5099	28.68355	28.68245	1.1	0.2 ✓	100/100	0.9 ✓
3. IMPINGER							
a. WATER FRACTION	5120	28.8604	28.85835	2.05 ✓	1.24 ✓	620/310	1.6 ✓
b. ORGANIC EXTRACTION 125 ml MeCl ₂	5108	28.9748	28.9745	0.3	0.17 ✓	620/310	0.3 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 2.8 mg

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3, IN STACK FILTER

PROJECT # 12598
 CLIENT/LOCATION SCE Alamitos 2
 SAMPLE LOCATION CSAPH
 TEST # 3-2-PM

WATER BLANK mg/ml 0.0020 Front 1/2
0.0040 Back 1/2
 MeCl₂ BLANK mg/ml 0.0013

SAMPLE DATE 10/16/92
 DATA ANALYSIS DATE 10/19/92
 ANALYST INITIALS JRH

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQUT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	4516 5A	0.10515	0.10515	0.0	-	/	0.0
	45-2008	0.1044	0.1042	0.2		/	0.2
2. PROBE AND NOZZLE WASH	5100	28.54365	28.5425	1.15 ✓	0.16 ✓	78/78	1.0 ✓
3. IMPINGER							
a. WATER FRACTION	5121	28.3984	28.39665	1.75 ✓	1.48 ✓	740/370	0.5 ✓
b. ORGANIC EXTRACTION							
<u>125 ml MeCl₂</u>	5109	28.79395	28.7937	0.25 ✓	0.17 ✓	740/370	0.2 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 1.8 mg

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3, IN STACK FILTER

PROJECT # 12598 WATER BLANK mg/ml 0.0020 Front 1/2
 CLIENT/LOCATION SCE Alamitos 2 MeCl₂ BLANK mg/ml 0.0040 BACK 1/2 SAMPLE DATE 10/16/92
 SAMPLE LOCATION CSAPH DATA ANALYSIS DATE 10/19/92
 TEST # 4-2-PM ANALYST INITIALS JRH

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALQUOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	45-199	0.1048	0.10425	0.55 ✓	—	/	0.6 ✓
2. PROBE AND NOZZLE WASH	5101	28.56295	28.5616	1.35 ✓	0.24 ✓	$\frac{120}{790} \times \frac{120}{390}$	1.1 ✓
3. IMPINGER							
a. WATER FRACTION	5122	28.55965	28.55825	1.40 ✓	1.56 ✓	$\frac{790}{390}$	-0.0 ✓
b. ORGANIC EXTRACTION <u>125 ml MeCl₂</u>	5110	27.9675	27.9668	0.35 ✓	0.17 ✓	$\frac{790}{390}$	0.4 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 2.1 mg ✓

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3, IN STACK FILTER

PROJECT # 12598 WATER BLANK mg/ml 0.0020 Front 1/2
 CLIENT/LOCATION SCE Alamitos 2 MeCl₂ BLANK mg/ml 0.0040 Back 1/2 SAMPLE DATE 10, 6, 92
 SAMPLE LOCATION CSAPH DATA ANALYSIS DATE 10/19/92
 TEST # 5-2-PM ANALYST INITIALS JRH

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQUOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	45-178	0.1058	0.1053	0.5	—	/	0.5
2. PROBE AND NOZZLE WASH	5102	28.4959	28.4952	0.75 ✓	0.12 ✓	60/60	0.6 ✓
3. IMPINGER							
a. WATER FRACTION	5127	28.66175	28.6602	1.55 ✓	1.12 ✓	510/280	0.9 ✓
b. ORGANIC EXTRACTION 125 ml MeCl ₂	5123	28.2809	28.2806	0.3 ✓	0.17 ✓	510/280	0.3 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 2.3 mg ✓

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3, IN STACK FILTER

PROJECT # 12598
 CLIENT/LOCATION SCE Alamitos 2
 SAMPLE LOCATION CSAPH
 TEST # 6-2-PM

WATER BLANK mg/ml 0.0020 Front 1/2
0.0040 Back 1/2
 MeCl₂ BLANK mg/ml 0.0013

SAMPLE DATE 10, 7, 92
 DATA ANALYSIS DATE 10, 19, 92
 ANALYST INITIALS JRH

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	47-448	0.1104	0.1104	0.0 ✓	—	/	0.0 ✓
2. PROBE AND NOZZLE WASH	5111	28.4579	28.45745	0.45 ✓	0.34 ✓	168 / 168	0.1 ✓
3. IMPINGER							
a. WATER FRACTION	5128	27.5152	27.5142	1.0 ✓	128 ✓	640 / 320	-0.0 ✓
b. ORGANIC EXTRACTION 125 ml MeCl ₂	5124	30.2839	30.28355	0.35 ✓	0.17 ✓	640 / 320	0.4 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 0.4 mg

METHOD OF SAMPLE PREP/NOTES

PARTICULATE **SCAQMD 5.3, IN STACK FILTER**

PROJECT # 12598 WATER BLANK mg/ml 0.0020 Front
 CLIENT/LOCATION SCE Alamitos 2 MeCl₂ BLANK mg/ml 0.0040 Back SAMPLE DATE 10, 17, 92
 SAMPLE LOCATION CSAPH DATA ANALYSIS DATE 10, 19, 92
 TEST # 7-2-PM ANALYST INITIALS JRN

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	47-449	0.1107	0.1106	0.1 ✓	—	/	0.1 ✓
2. PROBE AND NOZZLE WASH	5112	27.58345	27.58265	0.8 ✓	0.24 ✓	120/120	0.6 ✓
3. IMPINGER							
a. WATER FRACTION	5129	28.17895	28.17785	1.1 ✓	1.2 ✓	610/300	0.0 ✓
b. ORGANIC EXTRACTION 125 ml MeCl ₂	5125	28.33765	28.3373	0.35 ✓	0.17 ✓	610/300	0.4 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 1.1 mg ✓

METHOD OF SAMPLE PREP/NOTES

PARTICULATE **SCAQMD 5.3, IN STACK FILTER**

PROJECT # 12598
 CLIENT/LOCATION SCE Alamitos
 SAMPLE LOCATION CSAPH
 TEST # 8-2-PM

WATER BLANK mg/ml 0.0020 Front
0.0040 Back
 MeCl₂ BLANK mg/ml 0.0013

SAMPLE DATE 10, 7, 92
 DATA ANALYSIS DATE 10, 19, 92
 ANALYST INITIALS JRW

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	47450	0.1112	0.11045	0.75	—	1/	0.8
2. PROBE AND NOZZLE WASH	5113	29.82045	29.81895	1.5	0.3	150/150	1.2
3. IMPINGER							
a. WATER FRACTION	5140	29.0521	29.0503	1.8	1.16	590/290	1.3
b. ORGANIC EXTRACTION							
<u>125 ml MeCl₂</u>	5139	28.5349	28.53485	0.05	0.17	590/290	-0.0
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 3.3 mg

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3, IN STACK FILTER

PROJECT # 12598 WATER BLANK mg/ml 0.0020 Front
 CLIENT/LOCATION SCE Alamitos 2 0.0040 Back
 SAMPLE LOCATION CSAPH MeCl₂ BLANK mg/ml 0.0013 SAMPLE DATE 10.17.92
 TEST # 9-2-PM DATA ANALYSIS DATE 10.19.92
 ANALYST INITIALS JRH

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQUOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	47-451	0.1106	0.10995	0.65 ✓	—	/	0.7 ✓
2. PROBE AND NOZZLE WASH	5114	27.70235	27.70155	0.8 ✓	0.2 ✓	98/98	0.6 ✓
3. IMPINGER							
a. WATER FRACTION	5130	27.7438	27.74255	1.25 ✓	1.28 ✓	640/320	-0.04 ✓
b. ORGANIC EXTRACTION (25 ml MeCl ₂)	5126	28.2293	28.2290	0.3 ✓	0.17 ✓	640/320	0.5 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 1.6 mg

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3, IN STACK FILTER

PROJECT # 12598

WATER BLANK mg/ml 0.0020 Front 1/2
0.0040 Back 1/2

CLIENT/LOCATION SCE Alamitos 2

MeCl₂ BLANK mg/ml 0.0013

SAMPLE DATE 10.8.92

SAMPLE LOCATION CSAPH

DATA ANALYSIS DATE 10.19.92

TEST # 10-2-PM

ANALYST INITIALS JRL

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	47-452	0.11075	0.1107	✓ 10.05	—	/	+0.1
2. PROBE AND NOZZLE WASH	5115	29.0833	29.0827	✓ 0.6	✓ 0.2	98/98	✓ 0.4
3. IMPINGER							
a. WATER FRACTION	5135	28.50915	28.50795	✓ 1.20	✓ 1.28	640/320	✓ -0.0
b. ORGANIC EXTRACTION <u>125 ml MeCl₂</u>	5131	28.93725	28.9370	✓ 0.25	✓ 0.17	640/320	✓ 0.2
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 0.743 mg

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3. IN STACK FILTER

PROJECT # 12598 WATER BLANK mg/ml 0.0020 Front 1/2
 CLIENT/LOCATION SCE Alamitos 2 MeCl₂ BLANK mg/ml 0.0040 Back 1/2 SAMPLE DATE 10.8.92
 SAMPLE LOCATION CSAPH DATA ANALYSIS DATE 10.19.92
 TEST # 11-2-PM ANALYST INITIALS JRH

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQUOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	47-453	0.11145	0.1107	0.75 ✓	—	/	0.8
2. PROBE AND NOZZLE WASH	5116	31.44665	31.4465	0.5 ✓	0.12 ✓	62/62	0.4 ✓
3. IMPINGER							
a. WATER FRACTION	5136	27.75935	27.7561	3.25 ✓	1.08 ✓	540/270	2.0 4.3 ✓
b. ORGANIC EXTRACTION 125 ml MeCl ₂	5132	29.8063	29.80615	0.15 ✓	0.17 ✓	540/270	0.0
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 5.5 mg ✓

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3, IN STACK FILTER

PROJECT # 12598
 CLIENT/LOCATION SCE Alamitos 2
 SAMPLE LOCATION CSAPH
 TEST # 12-2-PM

WATER BLANK mg/ml 0.0020 Front 1/2
0.0040 Back 1/2
 MeCl₂ BLANK mg/ml 0.0013

SAMPLE DATE 10, 8, 92
 DATA ANALYSIS DATE 10, 20, 92
 ANALYST INITIALS JRH

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	47454	0.10985	0.1095	0.35 ✓	—	/	0.4 ✓
2. PROBE AND NOZZLE WASH	5117	29.0564	29.05595	0.45 ✓	0.3 ✓	150/150	0.2 ✓
3. IMPINGER							
a. WATER FRACTION	5137	28.9379	28.9389	1.0 ✓	1.12 ✓	560/280	0.0
b. ORGANIC EXTRACTION							
<u>125 ml MeCl₂</u>	5133	29.66535	29.66515	0.2 ✓	0.17 ✓	560/280	0.1 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = 0.7 mg

METHOD OF SAMPLE PREP/NOTES

PARTICULATE SCAQMD 5.3. IN STACK FILTER

PROJECT # 12598

WATER BLANK mg/ml 0.0020 Front 1/2
2.0040 Back 1/2

CLIENT/LOCATION SCE Alamosa 2

MeCl₂ BLANK mg/ml _____

SAMPLE DATE 10, 8, 92

SAMPLE LOCATION CSAPH

DATA ANALYSIS DATE 10, 19, 92

TEST # 13-2-PM

ANALYST INITIALS JRH

ITEM	NUMBER	FINAL WEIGHT (g)	TARE WEIGHT (g)	GAIN WEIGHT (mg)	BLANK CORRECTION (mg)	ALIQOT CORRECTION (ml/ml)	NET GAIN (mg/SAMPLE)
1. GLASS FIBER FILTER	47-455	0.1090	0.1093	-0.2 ✓	—	/	-0.2
2. PROBE AND NOZZLE WASH	5118	28.9840	28.9834	0.6 ✓	0.12 ✓	61/61	0.5 ✓
3. IMPINGER							
a. WATER FRACTION	5138	27.83755	27.83635	1.2 ✓	1.08 ✓	540/270	0.2 ✓
b. ORGANIC EXTRACTION 125 ml MeCl ₂	5134	28.9801	28.9799	0.2 ✓	0.17 ✓	540/270	0.1 ✓
				.		/	.
				.		/	.
				.		/	.

TOTAL PARTICULATE = .8 mg ✓ (9)

METHOD OF SAMPLE PREP/NOTES



AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services

October 14, 1992

RECEIVED
OCT 19 1992

LTR/400/92
4037

Kelly Borkenhagen
CARNOT
15991 Red Hill Ave., Suite 110
Tustin, CA 92680

CARNOT

re: 12598

Dear Kelly:

Please find enclosed the laboratory analysis reports, quality assurance summaries, and the original chain of custody forms for nine Tedlar bag samples received on October 7, & 8, 1992.

The samples were analyzed for methane and total gaseous non-methane organics.

Sincerely,

AtmAA, Inc.

Michael L. Porter
Laboratory Director

Encl.
MLP/krp



AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services

LABORATORY ANALYSIS REPORT

Methane & Total Gaseous Non-Methane Organics (TGNMO) Analysis in Tedlar Bag Samples

Report Date: October 13, 1992
Client: CARNOT
P.O. No.: 9018
Project No.: 12598
Date Received: October 7, 1992
Date Analyzed: October 7, 1992

ANALYSIS DESCRIPTION

Methane and total gaseous non-methane organics were measured by flame ionization detection/total combustion analysis portion (FID/TCA).

AtmAA Lab No.:	92812-2	92812-3	92812-4	92812-5	92812-6
Sample I.D.:	1-2-HC	2-2-HC	3-2-HC	4-2-HC	5-2-HC
Components:	(Concentration in ppm, v/v)				
Methane	<1	1.27	<1	1.65	<1
TGNMO	13.8	15.2	17.5	18.0	19.4

TGNMO is total gaseous non-methane organics measured and reported as ppm methane.


Michael L. Porter
Laboratory Director

QUALITY ASSURANCE SUMMARY
(Repeat Analysis)

Project No.: 12598

	Sample ID	Repeat	Analysis	Mean Conc.	% Diff. From Mean
		Run #1	Run #2		
<u>Component:</u>		(Concentration in ppm, v/v)			
Methane	3-2-HC	< 1	< 1	---	---
TGNMO	3-2-HC	16.3	18.7	17.5	6.9

A set of 6 Tedlar bag samples laboratory numbers, 92812-(2-6) was analyzed for methane and TGNMO. Agreement between repeat analyses is a measure of precision and is shown above in the column "% Difference from Mean." Repeat analyses are an important part of AtmAA's quality assurance program. The average % Difference from Mean for 1 repeat measurement from the sample set of 5 Tedlar bag samples is 6.9%.





AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services

LABORATORY ANALYSIS REPORT

Methane & Total Gaseous Non-Methane Organics (TGNMO) Analysis in Tedlar Bag Samples

Report Date: October 14, 1992
Client: CARNOT
P.O. No.: 9022
Project No.: 12598
Date Received: October 8, 1992
Date Analyzed: October 8, 1992

ANALYSIS DESCRIPTION

Methane and total gaseous non-methane organics were measured by flame ionization detection/total combustion analysis portion (FID/TCA).

AtmAA Lab No.:	92822-1	92822-2	92822-3	92822-4
Sample I.D.:	6-2-HC	7-2-HC	8-2-HC	9-2-HC
Components:	(Concentration in ppm, v/v)			
Methane	1.21	<1	<1	<1
TGNMO	14.6	13.6	13.6	13.1

TGNMO is total gaseous non-methane organics measured and reported as ppm methane.


Michael L. Porter
Laboratory Director

QUALITY ASSURANCE SUMMARY
(Repeat Analysis)

Project No.: 12598

	Sample ID	Repeat	Analysis	Mean	% Diff.
		Run #1	Run #2	Conc.	From Mean
<u>Component:</u>	(Concentration in ppm, v/v)				
Methane	6-2-HC	1.18	1.24	1.21	2.5
TGNMO	6-2-HC	14.7	14.6	14.6	0.34

A set of 4 Tedlar bag samples laboratory numbers, 92822-(1-4) was analyzed for methane and TGNMO. Agreement between repeat analyses is a measure of precision and is shown above in the column "% Difference from Mean." Repeat analyses are an important part of AtmAA's quality assurance program. The average % Difference from Mean for 2 repeat measurements from the sample set of 4 Tedlar bag samples is 1.4%.





AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services

RECEIVED

OCT 21 1992

CARNOT

October 16, 1992

LTR/406/92
4037

Kelly Borkenhagen
CARNOT
15991 Red Hill Ave., Suite 110
Tustin, CA 92680

re: 12599

Dear Kelly:

Please find enclosed the laboratory analysis report, quality assurance summary, and the original chain of custody form for four Tedlar bag samples received on October 9, 1992.

The samples were analyzed for methane and total gaseous non-methane organics.

Sincerely,

AtmAA, Inc.

Michael L. Porter
Laboratory Director

Encl.
MLP/krp



AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services

LABORATORY ANALYSIS REPORT

Methane & Total Gaseous Non-Methane Organics (TGNMO) Analysis in Tedlar Bag Samples


Report Date: October 16, 1992
Client: CARNOT
P.O. No.: 9023
Project No.: 12599
Date Received: October 9, 1992
Date Analyzed: October 9, 1992

ANALYSIS DESCRIPTION

Methane and total gaseous non-methane organics were measured by flame ionization detection/total combustion analysis portion (FID/TCA).

AtmAA Lab No.:	92832-22	92832-23	92832-24	92832-25
Sample I.D.:	10-2-HC	11-2-HC	12-2-HC	13-2-HC
Components:	(Concentration in ppm, v/v)			
Methane	<1	<1	<1	<1
TGNMO	11.1	11.3	10.3	14.8

TGNMO is total gaseous non-methane organics measured and reported as ppm methane.


Michael L. Porter
Laboratory Director

QUALITY ASSURANCE SUMMARY
(Repeat Analysis)

Project No.: 12599

Component:	Sample ID	Repeat	Analysis	Mean	% Diff.
		Run #1	Run #2	Conc.	From Mean
(Concentration in ppm, v/v)					
Methane	10-2-HC	< 1	< 1	---	---
TGNMO	10-2-HC	10.6	11.6	11.1	4.5
	13-2-HC	14.6	14.9	14.8	1.0

A set of 4 Tedlar bag samples laboratory numbers, 92832-(22-25) was analyzed for methane and TGNMO. Agreement between repeat analyses is a measure of precision and is shown above in the column "% Difference from Mean." Repeat analyses are an important part of AtmAA's quality assurance program. The average % Difference from Mean for 2 repeat measurements from the sample set of 4 Tedlar bag samples is 2.8%.



**AMMONIA BY NESSLERIZATION
SCAQMD DRAFT METHOD**

CLIENT :	SCE	STORAGE DISK:	LOTUS DATA
LOCATION:	ALAMITOS #2	ANALYST:	JRH
PROJECT :	12598	CALIBRATION DATE:	10/8/92

SAMPLE ANALYSIS:

SAMPLE ID	SAMPLE DATE	ANALYSIS DATE	ALIQOT FACTOR	ABSORBANCE (OD)	CONC. (ug/ml)	TOTAL VOLUME (ml)
4-2-NH3	10/6/92	10/8/92	8.33	0.021	3.61	630
4-2-NH3SPK(2)	10/6/92	10/8/92	10.00	0.033	5.03	---
5-2-NH3	10/6/92	10/8/92	25.0	0.015	10.0	640
5-2-NH3	10/6/92	10/8/92	25.0	0.016	10.1	640
8-2-NH3	10/7/92	10/8/92	6.25	0.036	3.25	580
9-2-NH3	10/7/92	10/8/92	12.5	0.048	7.37	560
10-2-NH3	10/8/92	10/8/92	6.25	0.057	4.01	595
11-2-NH3	10/8/92	10/8/92	6.25	0.034	3.18	475


NOTES:

- (1) A 0.48 ug/ml Ricca standard was analyzed periodically during sample analysis.
Range of recovery was 100 to 101 percent. Average recovery was 101 percent.
- (2) 1 ml of 12.1 ug/ml Ricca standard and 4 ml of sample were diluted to 50 ml.
Recovery = (conc. spike - conc. sample)/ conc. std * 100 = 88.43%

AMMONIA CALIBRATION CURVE

Calibration Date: 10/8/92

Analyst: JRH



**AMMONIA BY NESSLERIZATION
SCAQMD DRAFT METHOD**

CLIENT :	SCE	STORAGE DISK:	LOTUS DATA
LOCATION:	ALAMITOS #2	ANALYST:	JRH
PROJECT :	12598	CAL DATE:	10/8/92

STANDARDS:

EXPECTED CONC. (ug/ml)	ABSORBANCE (OD)	ACTUAL CONC. (ug/ml)	RESPONSE FACTOR (mg/OD)
0.00	0.000	0.31	
0.32	0.002	0.32	8.0000
0.40	0.015	0.40	1.3333
0.48	0.031	0.49	0.7742
0.56	0.041	0.55	0.6829
0.64	0.054	0.62	0.5926
0.72	0.073	0.73	0.4932
		AVG	2.2766

Y-Int. = -0.0535
Slope = 0.1721
Corr. = 0.9937

LIMIT OF DETECTION:

SAMPLES	ABSORBANCE (OD)	CONC (ug/ml)
1	0.004	0.33
2	0.006	0.35
3	0.007	0.35
4	0.007	0.35
5	0.008	0.36
6	0.006	0.35
7	0.008	0.36

TRUE VALUE = 0.32
MEAN = 0.3490
STD DEV = 0.0081
MDL = 0.03
REPORTING LIMIT = 0.26

NOTES:


MDL = (3.143*STD DEV OF 7 REPLICATES OF 0.32 ug/ml STD)
RL = (MDL*10)


DUPLICATES:


ANALYSIS DATE	SAMPLE	RESULT 1	RESULT 2	DIFFERENCE (%)
10/8/92	5-2-NH3	10.0	10.1	-1.4%


7

APPENDIX F
INSTRUMENT STRIP CHARTS










SOLTEC CHART 1.0 ZOI-01-25-20M

SOL



4.94/11.11

CHART NO. ZD1-01-25-2014

20257

SOLTEC CHART NO. ZD1-01-25-20M

2023

10-25-20M

90.0/90.52/NOX

5524/5584 50

2165

$$7.89 / 7.72 = 0$$

25

System 1281
744

-55.84 / 55.84 CO

14.8 / 15.00 CVL

4.98 / 4.950

1. ΔG Mode
 2. N_{OX} Probe
 3. R_{OO} End


5517

1150

SCITEC CHART NO. ZDI-01-25-20M

25237

SCITEC CHART NO.



877111127100110000

1635

1630

1625

1620

1615 Start Test 4.2-CEM
All Passed

Urca ON

SC.0/SS.PV

Zero


System Span 1605

22. 2/20

7.83 / 7.9260

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13</																																																																																							

0606/NSU/25771/1.9



2/9/50

770 / 7.23 U

REF ID: A66666

1840

11113	11114	11115	11116	11117	11118	11119	11120	11121	11122	11123	11124	11125	11126	11127	11128	11129	11130	11131	11132	11133	11134	11135	11136	11137	11138	11139	11140	11141	11142	11143	11144	11145	11146	11147	11148	11149	11150	11151	11152	11153	11154	11155	11156	11157	11158	11159	11160	11161	11162	11163	11164	11165	11166	11167	11168	11169	11170	11171	11172	11173	11174	11175	11176	11177	11178	11179	11180	11181	11182	11183	11184	11185	11186	11187	11188	11189	11190	11191	11192	11193	11194	11195	11196	11197	11198	11199	11200	11201	11202	11203	11204	11205	11206	11207	11208	11209	11210	11211	11212	11213	11214	11215	11216	11217	11218	11219	11220	11221	11222	11223	11224	11225	11226	11227	11228	11229	11230	11231	11232	11233	11234	11235	11236	11237	11238	11239	11240	11241	11242	11243	11244	11245	11246	11247	11248	11249	11250	11251	11252	11253	11254	11255	11256	11257	11258	11259	11260	11261	11262	11263	11264	11265	11266	11267	11268	11269	11270	11271	11272	11273	11274	11275	11276	11277	11278	11279	11280	11281	11282	11283	11284	11285	11286	11287	11288	11289	11290	11291	11292	11293	11294	11295	11296	11297	11298	11299	11300	11301	11302	11303	11304	11305	11306	11307	11308	11309	11310	11311	11312	11313	11314	11315	11316	11317	11318	11319	11320	11321	11322	11323	11324	11325	11326	11327	11328	11329	11330	11331	11332	11333	11334	11335	11336	11337	11338	11339	11340	11341	11342	11343	11344	11345	11346	11347	11348	11349	11350	11351	11352	11353	11354	11355	11356	11357	11358	11359	11360	11361	11362	11363	11364	11365	11366	11367	11368	11369	11370	11371	11372	11373	11374	11375	11376	11377	11378	11379	11380	11381	11382	11383	11384	11385	11386	11387	11388	11389	11390	11391	11392	11393	11394	11395	11396	11397	11398	11399	11400	11401	11402	11403	11404	11405	11406	11407	11408	11409	11410	11411	11412	11413	11414	11415	11416	11417	11418	11419	11420	11421	11422	11423	11424	11425	11426	11427	11428	11429	11430	11431	11432	11433	11434	11435	11436	11437	11438	11439	11440	11441	11442	11443	11444	11445	11446	11447	11448	11449	11450	11451	11452	11453	11454	11455	11456	11457	11458	11459	11460	11461	11462	11463	11464	11465	11466	11467	11468	11469	11470	11471	11472	11473	11474	11475	11476	11477	11478	11479	11480	11481	11482	11483	1148
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

1944

1955-2015

1830

1825

1820

1815 Start Test SZ-CEM

89.5/90.32 NOX

1-55.7/55.84 CO

O_2 7.85

220

System spec - 1905

721

SCOTT: CHAOTIC? NO. NO. NO.

7010 / Span

SCE Alantus Unit 2

15.1 / 19.98 CO₂
5.02 / 4.973 O₂
7.41
7.926 O₂
22.15

Set L

New O₂ Cylinder Linearity

10-7-92

NO mode

NOX

NOX / NO mode

90.75 / 90.52 NOX

System Span 1847

55.84 / 55.84 CO₂

21.98 CO₂

7.90 / 7.93 O₂

1845

1840

88.25/10.52 NOx

55.84/55.84 CO

44.73/44.73 O₂

14.75/14.78 CO₂

System Spar 900

849 East side

846 West side

CHAS NO 812-55-40L

Zero / Spar

SCE Alameda Unit 2

06/15/2017 17:31

06/15/2017 17:31

06-NM5053717.81

NO Mode
95.5 NOx Mode

88.25/90.62 NOx

55.82/55.87 CO

14.12/14.98 CO₂

41.93/41.77 O₂

940
940.00-940.10M

935

930

925

920

915

910 Start Test G-2 CEM
All Probes

88.25/90.52 NOx

55.84/55.87 CO

49.77/49.75 O₂

14.75/14.98 CO₂

9.42 CO

06-NM5053717.81

114. Proles

88.0 hours NO_x

SS.8589⁴ CO
14.75 / 14.98 CO₂
Span Span

568.24 / 4.97 O₂

02045023717.81

02045023717.81

NO
NO

NOx P-03 1223

87.5 / 90.52

System Span

55.84 / 55.84 CO

14.70 / 14.98 CO₂

4.91 / 4.97 O₂

1200

1155

1150

1145

1140

1135

1130 Start Test 7-2-CEM
All Probes

88.0 / 90.52 NOx

55.84 / 55.84 CO

14.75 / 14.98 CO₂


System Span

4.92 / 4.97 O₂


1348

UREA ON 1300

NO
NO



10-8-92 SCE A lamitos CHF
CHART NO. 21 11-20-20N



40 mm Area ON

NO_x 0-100 ppm

Linearity

50.4 / 49.86 ppm

Set at 90.52 ppm


DL-8-92 SEE A/Amigos

CHF

CHART NO. ZU11-01-25-20M

NO_x

MM





972

1.4.97. 0.2

1145

1148

7/13/5

1430

1125

1120

11/15 Start
11-2-1 End

40 mW Urea ON

48.5 / 49.86 NOx

55.84/55.74 Co

14.8 / 14.88 Co.

4.98	1492	0.2
------	------	-----

System	3 Jan	1046
--------	-------	------

0806/NB0:27/1119

—

68-47

NO_x 0.750 ppm Range

Mode

NO
NO_x

1216

49.5 / 49.96 NO_x

55.84 / 55.84 CO


14.7 / 14.90 CO₂

5.00 / 9.97 O₂

1145

1140

1138



4.97/4.97 O₂
System Span
1514

85.5/90.52 NOx

55.7/55.84 CO

14.8/14.98 CO₂

4.97/4.97 O₂

System Cal 1420

1415


1410

1405

1400

1355

12



NG Mode
NOx 0.2 0.25%

87.5/90.52 NOx

55.84/55.84 CO

14.7/14.98 CO₂

5.00/4.97
O₂

1550

1545

1540

1535

1530

1525 Start
13-2-CEN

86.25/90.52 NOx


55.84/55.84 CO

14.75/14.98 CO

4.97/4.97 O₂
System Span
1514

0803-140237177 81

0803-140237177 81



APPENDIX G
CHAIN OF CUSTODY

CHAIN OF CUSTODY

PROJECT # 10540 OUTSIDE LAB REQUIRED (Y/N) NO SAMPLE DATE 10-18-19
 CLIENT/LOCATION SEE COMMENTS PROJECT MANAGER EF
 SAMPLE LOCATION CSAPH METHOD(S) SCAM 513 TECHNICIAN CF
 COMPLIANCE TEST (Y/N) Yes DATE DUE ASAP

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
10/18	:	10-18-19	Front 1/2			
1	:	10-18-19	Back 1/2			
1	:	10-18-19	Q5mm filter 45-167			
1	:	10-18-19	Front 1/2			
1	:	10-18-19	Back 1/2			
1	:	10-18-19	Q5mm filter 45-167			
1	:	10-18-19	Front 1/2			
1	:	10-18-19	Back 1/2			
1	:	10-18-19	Q5mm filter 45-167			
1	:	10-18-19	Front 1/2			
1	:	10-18-19	Back 1/2			
1	:	10-18-19	Q5mm filter 45-167			
1	:	10-18-19	Front 1/2			
1	:	10-18-19	Back 1/2			
1	:	10-18-19	Q5mm filter 45-167			
1	:	10-18-19	Front 1/2			
1	:	10-18-19	Back 1/2			
1	:	10-18-19	Q5mm filter 45-167			
1	:	10-18-19	Front 1/2			
1	:	10-18-19	Back 1/2			
1	:	10-18-19	Q5mm filter 45-167			

CHAIN OF CUSTODY

PROJECT # 12598 OUTSIDE LAB REQUIRED (Y/N) NO SAMPLE DATE 10-16-19
 CLIENT/LOCATION SEE/Alamitos #2 PROJECT MANAGER EF
 SAMPLE LOCATION CSAPH METHOD(S) SEE COMMENTS TECHNICIAN CF
 COMPLIANCE TEST (Y/N) Yes DATE DUE ASAP

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
✓ 10/16	:	1-2-PM	Front 1/2	1		SCAM 513
✓ 10/16	:	1-2-PM	Back 1/2	1		
✓ 10/16	:	1-2-PM	Q5mm filter 45-167	1		
10/16	:	1-2-PM	Front 1/2	1		

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAIN-ERS	SAMPLER	COMMENTS
10/16	1-2-PM		front 1/2	1		SCAND 53
10/15	1-2-PM		Back 1/2	1		
10/16	1-2-PM		ASPH 1/2	1		

PROJECT # 12598
 CLIENT/LOCATION SCE/Alameda #2
 SAMPLE LOCATION CSAPH
 COMPLIANCE TEST (Y/N) Yes
 OUTSIDE LAB REQUIRED (Y/N) NO
 SAMPLE DATE 10/16/98
 PROJECT MANAGER CF
 TECHNICIAN CF
 DATE DUE 10/16/98

CHAIN OF CUSTODY

1	:	4-2-HC	↓	1		
1	:	5-2-HC		1		
1	:					
1	:					
1	:					
1	:					
1	:					
1	:					
1	:					
1	:					
1	:					
1	:					
1	:					

TRANSFER OF SAMPLES FROM FIELD SAMPLE CUSTODIAN (FSC):

RELEASED BY (FSC)	DATE AND TIME	RECEIVED BY	DATE AND TIME
[Signature]	10/16/98	[Signature]	10/17/98 05:00
	1/1/98		1/1/98
	1/1/98		1/1/98

ANALYSIS REQUIRED:

Analyze for CH₄ & TMMHC By SCAND
 Method 25.2. Report in PPM

CERTIFICATION OF SAMPLE RECEIPT

PROJECT # 12598 OUTSIDE LAB# Atm AA SAMPLE DATE 10/6/92
SAMPLE LOCATION CSAPH METHOD(S) SEAAMP 25.2 PROJECT MANAGER EF
COMPLIANCE TEST (Y/N) YES TECHNICIAN CF/RM DATE DUE _____

$$\begin{array}{r} 2.2 \\ -3 \\ -4 \\ -5 \\ -6 \end{array}$$

CHAIN OF CUSTODY PRIOR TO SHIPMENT:

RELEASED BY	DATE	TIME	RECEIVED BY	DATE	TIME
Kelly Borkenhagen	10 7 192	10:00		/ /	:
	/ /	:		/ /	:
	/ /	:		/ /	:

OUTSIDE LAB INFORMATION

SAMPLES SHIPPED TO ATM AA
21354 NOROFF STREET; Suite 113
CHASWORTH, CA 91311
PHONE: (818) 718-6070

CARNOT SHIPPER Ritz-O-Way
DATE 10 17 192
CARRIER # AKG 5069
AIR BILL # NA

RECIPIENT Kenneth P. Porter
COMPANY ATM AA
DATE 10/7/92

CARNOT

CHAIN OF CUSTODY

PROJECT # 12598 OUTSIDE LAB REQUIRED (Y/N) Yes SAMPLE DATE 10/17/11
 CLIENT/LOCATION SEA/Alameda PROJECT MANAGER EF
 SAMPLE LOCATION CSAPM METHOD(S) SC96MD 25.2 TECHNICIAN CF
 COMPLIANCE TEST (Y/N) Yes DATE DUE _____

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
10/17	:	6-2-11	Tracker Bay	1		
/	:	7-2-11		1		
/	:	8-2-11		1		
/	:	9-2-11		1		
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					

TRANSFER OF SAMPLES FROM FIELD SAMPLE CUSTODIAN (FSC):

RELEASED BY (FSC)	DATE AND TIME	RECEIVED BY	DATE AND TIME
<u>[Signature]</u>	<u>10/17/11</u> :	<u>[Signature]</u>	<u>10/18/11</u> :
	<u>1 1</u> :		<u>1 1</u> :
	<u>1 1</u> :		<u>1 1</u> :

ANALYSIS REQUIRED: Analyze for CH₄ + TMMHC
using 25.2 Report in PPM

CERTIFICATION OF SAMPLE RECEIPT

PROJECT # 12598 OUTSIDE LAB# Atm AA SAMPLE DATE 10/7/92
 SAMPLE LOCATION CSAPM METHOD(S) SCAQMD 25.1 PROJECT MANAGER EF
 COMPLIANCE TEST (Y/N) YES TECHNICIAN CF DATE DUE 10/10/92

TEST #	COMPLETE DESCRIPTION
822-1 6-2-HC	Jedlar bag for CH ₄ + TNMHC analysis by SCAQMD 25.1
-2 7-2-HC	↓
-3 8-2-HC	↓
-4 9-2-HC	↓
	Please report in ppm.
	Please return these samples to Carnot.

PO# 9022

CHAIN OF CUSTODY PRIOR TO SHIPMENT:

RELEASED BY	DATE	TIME	RECEIVED BY	DATE	TIME
Kelly Borker	10/8/92	6:00a		/ /	:
	/ /	:		/ /	:
	/ /	:		/ /	:

OUTSIDE LAB INFORMATION

SAMPLES SHIPPED TO Atm AA
21354 Nordhoff Street; Suite 113
Chatsworth, CA 91311
 PHONE: (818) 718-6070

CARNOT SHIPPER KB
 DATE 10/8/92
 CARRIER # Rite-O-Way
 AIR BILL # ACT# 5009

RECIPIENT Karen D. Roteau
 COMPANY Atm AA, Inc.
 DATE 10/8/92

CHAIN OF CUSTODY

PROJECT # 12098 OUTSIDE LAB REQUIRED (Y/N) YES SAMPLE DATE 10/18/91
 CLIENT/LOCATION SEA / HAWAII #2 PROJECT MANAGER CEP
 SAMPLE LOCATION COPIER METHOD(S) PS 2 TECHNICIAN CEP
 COMPLIANCE TEST (Y/N) YES DATE DUE _____

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
10/18	:	1024	Debris	1		
10/18	:	1025				
10/18	:	1026				
10/18	:	1027				
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					

TRANSFER OF SAMPLES FROM FIELD SAMPLE CUSTODIAN (FSC):

RELEASED BY (FSC)	DATE AND TIME	RECEIVED BY	DATE AND TIME
<i>[Signature]</i>	10/19/92 X	<i>[Signature]</i>	10/19/92 X
	/ / :		/ / :
	/ / :		/ / :

ANALYSIS REQUIRED: _____

15991 Red Hill Ave., Suite 110, Tustin, California 92680-7388 (714) 259-9520 - FAX (714) 259-0372

CERTIFICATION OF SAMPLE RECEIPT

PROJECT # 1259.9 OUTSIDE LAB# Arm AA SAMPLE DATE 10 18 92
SAMPLE LOCATION _____ METHOD(S) SCAMD 25.1 PROJECT MANAGER EF
COMPLIANCE TEST (Y/N) YES for Qty 1 IN/MLC TECHNICIAN CF
DATE DUE 10/10/92

[illegible]

CHAIN OF CUSTODY PRIOR TO SHIPMENT:

RELEASED BY	DATE	TIME	RECEIVED BY	DATE	TIME
Kelly Bakerley	10/19/92	8:00	DAVE WATZ	10/19/92	9:30
DAVE WATZ	10/19/92	9:30		1 1	:
	1 1	:		1 1	:

OUTSIDE LAB INFORMATION

SAMPLES SHIPPED TO John Arr
21354 Norcross, Suite 113
Chattanooga, CA 91311
PHONE: (818) 718 - 6070

CARNOT SHIPPER 1
DATE 10 19 1992
CARRIER # RITE-O-WAY
AIR BILL # ACCT # 5009

RECIPIENT Xerox-Pater
COMPANY Almaa, Inc.
DATE 10/9/92

CHAIN OF CUSTODY

PROJECT # 12598 OUTSIDE LAB REQUIRED (Y/N) NO SAMPLE DATE 10/17/11
 CLIENT/LOCATION SE/Alameda PROJECT MANAGER EF
 SAMPLE LOCATION CSAPK1 METHOD(S) Drift 207.1 TECHNICIAN CF
 COMPLIANCE TEST (Y/N) YES DATE DUE ASAP

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
10/17	:	82-M	Probe → impinge	1		
10/17	:	9-2-M	Probe → impinge	1		
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					

TRANSFER OF SAMPLES FROM FIELD SAMPLE CUSTODIAN (FSC):

RELEASED BY (FSC)	DATE AND TIME	RECEIVED BY	DATE AND TIME
<u>[Signature]</u>	<u>10/17/11</u> :	<u>Andy R. Hoke</u>	<u>10/18/11 29:00</u>
	<u>1 1</u> :		<u>1 1</u> :
	<u>1 1</u> :		<u>1 1</u> :

ANALYSIS REQUIRED:

Analyse for NH₃ using Drift SCAMD 207.1
(report total volume and NH₃ in ppm)

CHAIN OF CUSTODY

PROJECT # 12578 OUTSIDE LAB REQUIRED (Y/N) NO SAMPLE DATE 10/18/92
 CLIENT/LOCATION SCE / Alameda #2 PROJECT MANAGER EF
 SAMPLE LOCATION _____ METHOD(S) SLAGM DRAFT 207 TECHNICIAN CF
 COMPLIANCE TEST (Y/N) YES DATE DUE 10/6/92

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
10/8	:	10-2-14	Probe → IMPROVE	1		
10/8	:	11-2-10-3	↓	1		
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					
/	:					

TRANSFER OF SAMPLES FROM FIELD SAMPLE CUSTODIAN (FSC):

RELEASED BY (FSC)	DATE AND TIME	RECEIVED BY	DATE AND TIME
<u>[Signature]</u>	<u>10/18/92</u>	<u>Jody R. Hone</u>	<u>10/18/92 13:10</u>
	1 1 :		1 1 :
	1 1 :		1 1 :

ANALYSIS REQUIRED: Analyze for NH₃ using Nessler reagents.
Report in P.P.m

Background Report Reference

AP-42 Section Number: 1.4

Background Chapter: 2

Reference Number: 9

Title: Urea Permit Compliance Testing at
Alamitos Generation Station Unit 2

Carnot

Carnot

November 1992

