

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Energy Systems Associates A CORPORATION

November 26, 1984
ESA 17700-144

AP42 Section 1.4
4/93

Reference 16

Mr. Florian Wisinski
Engineering Manager
Cleaver-Brooks
3707 No. Richards St
Milwaukee, WI 53212

Dear Mr. Wisinski:

SUBJECT: Results from Performance Tests
California Milk Producers Boiler No. 5
October 30-31, 1984

This letter presents the results of the emissions performance tests conducted for Cleaver-Brooks on California Milk Producers Boiler No. 5 in Artesia, California. The performance tests were conducted on October 30-31, 1984. Included in addition to the results are a brief unit and sampling site description, and a description of the test conditions, test procedures, and sampling equipment.

UNIT DESCRIPTION

California Milk Producers Boiler 5 is a Cleaver-Brooks package boiler. It has a rated full load capacity of 47,000 lb/hr steam (600 °F, 150 psi). The boiler has the capability of firing both natural gas and #2 fuel oil. It is equipped with a Cleaver-Brooks designed flue gas recirculation (FGR) system and an oxygen trim system.

The FGR system extracts a portion of the combustion products from the boiler exit duct and delivers the gas to be mixed with the combustion air at the burner. FGR recirculation rate is controlled by a butterfly valve in the duct between the FGR fan and the burner.

SAMPLING SITE DESCRIPTION

The sampling for NO_x, O₂, and CO was conducted from the boiler stack upstream of a finned-tube economizer. Two sample ports were installed on the 42 in. diameter stack (90 deg apart). The sample ports were installed upstream of the economizer due to the economizer position relative to the stack exit. In addition to the gaseous sampling, flue gas velocity and temperature measurements were also taken using these sample ports.

Two sampling ports were also installed on the 12 in. diameter FGR duct eight diameters downstream and two diameters upstream of any flow disturbances. These sample ports were used to measure gas velocity and temperature in the FGR duct.



TEST CONDITIONS

Table 1 presents the array of conditions at which the tests were performed. NO_x, O₂, and CO concentrations were measured at each of the conditions shown in the table according to methodology approved by the SCAQMD. FGR and stack flow rates were measured at all except the 0% FGR conditions. The maximum percent FGR was determined by fan limitation and flame appearance.

TABLE 1.
TEXT MATRIX CONDITIONS

Fuel	Load	Test Conditions (Percent FGR)		
Natural Gas	60%	0	10	20 (or max.)
	100%	0	10 (or max.)	
Oil	60%	0	10	20 (or max.)
	100%	0	10 (or max.)	

TEST PROCEDURES

Energy Systems Associates (ESA) utilized a continuous emissions monitoring system with analyzers for NO_x, O₂, and CO. The analyzers are the types (or equivalent) suggested by the California Air Resources Board. Table 2 below provides detailed information on the analyzers which were used in testing.

TABLE 2.
TEST PROGRAM ON CEM ANALYZERS

Species	Manufacturer	Measurement Principle	Accuracy
NO _x	Thermo Electron	Chemiluminescent	+ 1% full scale
O ₂	Teledyne	Micro Fuel Cell	+ 1% full scale
CO	Horiba	Nondispersive Infrared	+ 1% full scale

The above analyzers, used in conjunction with sample extraction and conditioning components and the calibration gas system, make up the continuous emissions monitor package. The sample extraction and conditioning system draws a sample from the stack, dries it, removes any particulate matter, and

Mr. Wisinski
Cleaver-Brooks



November 26, 1984
ESA 17700-144 - Page 3

delivers the clean, dry sample to the analyzers. The calibration system delivers gases of known concentration to the analyzers to set the instrument's zero and span outputs. ESA uses gases which are certified accurate to $\pm 1\%$. The NOx calibration gases are NBS-traceable.

The sampling system was set up and operated as outlined by Bay Area Air Quality Management District ST9 13A and 14, for CO, NOx, and O₂. A preliminary traverse of the stack was made to determine the level of stratification in flue gas. Based on the results of this test, all subsequent gas samples were extracted from a single point. The data from the stratification test can be found in the appendix. The test duration at each condition was 20-30 minutes. This time period was chosen in consideration of boiler operating criteria, boiler stability at a condition, and conversation with cognizant SCAQMD personnel. Where appropriate, stack gas and FGR flow rates were measured using EPA method 1 procedures during the same interval as the measurement of the gaseous constituents. The relation of these flow rates yielded the percent FGR. All calculations were performed according to appropriate reference method procedures or their equivalents. These calculations are included in the appendix.

RESULTS

The results of the performance test are presented in Table 3. The continuous measurement values presented are average values for the test period. The NOx and CO concentrations have been corrected to a reference condition of 3% O₂. Copies of the field data sheets and strip charts are included in the appendix. If you have any questions, please call.

Sincerely,

ENERGY SYSTEMS ASSOCIATES

Robert A. Finken
Manager, Testing Services

RAF:rs

Attachment/Enclosures: As Noted



TABLE 3.
TEST RESULTS

Test No.	Time	Fuel	% Load	Steam Flow (Avg, lb/hr)	% FGR	O ₂ , %	NO _x , ppm at 3% O ₂	CO, ppm
4	1210-1235	Natural gas	60	29,400	0	3.62	64.4	182
6	1427-1457	Natural gas	60	29,800	9.7	3.45	29.7	47
7	1515-1545	Natural gas	60	30,250	15.98	3.05	22.0	85
3	1130-1155	Natural gas	100	49,000	0	3.54	81.7	455
5	1345-1415	Natural gas	100	48,000	9.63*	3.09	33.9	386
9	1020-1045	#2 fuel oil	60	29,500	0	3.64	136	21
14	1605-1630	#2 fuel oil	60	28,500	10.69	3.59	115	24
15	1635-1700	#2 fuel oil	60	27,300	18.45	3.53	104	24
8	0910-0938	#2 fuel oil	100	49,300	0	3.49	144	20
13	1525-1555	#2 fuel oil	100	47,250	10.47*	3.38	118	24

*Maximum operating percent FGR at this load.

A sample of the fuel oil was analyzed for sulfur and API gravity. The results are as follows:

Sulfur (% wt) = 0.06%

API Gravity = 31.9

$$\begin{aligned} \text{NG } \frac{24.7}{64.4} &= 54\% \text{ red} \\ \frac{22}{64} &= 66\% \text{ red} \\ \frac{33.9}{81.7} &= 59\% \text{ red} \end{aligned}$$

ESA 17700-144

$$\begin{aligned} \text{\#2 oil } \frac{115}{136} &= 15\% \text{ red} \\ \frac{104}{136} &= 24\% \text{ red} \quad \frac{118}{144} = 18\% \end{aligned}$$

116
2/2

SOURCE CATEGORY: Natural Gas
EXCLUSION CRITERIA CHECKLIST

REFERENCE California Pilt Production - 10.5
Exxon Systems Associates, 10.5

CRITERIA	YES	NO
1. Test series averages are reported in units that can be converted to the selected reporting units?	✓	
2. Test series represent compatible test methods?	✓	
3. In tests in which emission control devices were used, the control devices are fully specified?	✓	
4. Is it clear whether or not the emissions were controlled (or not controlled)?	✓	

Form filled out by J.P.C. [Signature]

Date 3/6/90

INDICATE WHETHER ANSWER IS YES OR NO WITH AN "X" IN APPROPRIATE BOX.

IF ALL ANSWERS ARE "YES" PROCEED TO METHODOLOGY/DETAIL CRITERIA CHECKLIST.

SOURCE CATEGORY Paints & Co.
 METHODOLOGY/DETAIL CRITERIA CHECKLIST

REFERENCE Johna Hillk Products

CRITERIA	YES	NO	COMMENTS
1. Is the manner in which the source was operated well documented in the report?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Basic info re. loaded 1/17/82
Was the source operating within typical parameters during the test?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Did sampling procedures deviate from standard methods?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
If so, were the deviations well documented?	<input type="checkbox"/>	<input type="checkbox"/>	
Were the deviations appropriate?	<input type="checkbox"/>	<input type="checkbox"/>	
Comment on how any alterations in sampling procedure may have influenced the results.	<input type="checkbox"/>	<input type="checkbox"/>	
3. Were there wide variations in the results?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
If yes, can the variations be adequately explained by information in the report?	<input type="checkbox"/>	<input type="checkbox"/>	1/18
If the variations are not well explained, should the data be considered of poor quality?	<input type="checkbox"/>	<input type="checkbox"/>	1/18
4. Do the test reports contain the raw data sheets?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Are the nomenclature and equations used equivalent to those specified by the EPA?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Comment on the consistency and completeness of the results.	<input type="checkbox"/>	<input type="checkbox"/>	Consistent and complete

Form filled out by Johna Hillk

Date 1/18/82

INDICATE YES OR NO WITH AN "X" IN THE APPROPRIATE BOX. FILL IN COMMENTS.

IF, BASED ON ABOVE ANSWERS, THE SOURCE REPORT PROVIDES ADEQUATE DETAIL AND DEMONSTRATES SOUND METHODOLOGY, PROCEED TO RATING THE DATA IN THE RATING CRITERIA CHECKLIST.

SOURCE CATEGORY Natural Gas
 RATING CRITERIA CHECKLIST

Reference California Milk Producers

RATING CRITERIA	YES	NO
A Tests performed by a sound methodology and reported in enough detail for adequate validation?		
B Tests were performed by a generally sound methodology, but not enough detail for adequate validation?	<u>three</u> ✓	
C Were tests based on untested or new methodology that lacks significant amount of background data?		
D Were tests based on generally unacceptable methods, but may provide order-of-magnitude values for the source?		

COMMENTS
<p><i>From previous to 1981, seemed to be a lack of sufficient data for the state.</i></p> <p><i>Information from 1981 to 1982, seemed to be a lack of sufficient data for the state.</i></p>

Form filled out by J. J. 2
 Date 1/2/82

BASED ON ANSWERS AND COMMENTS ABOVE, ASSIGN A RANK TO THIS LITERATURE SOURCE:

B 1101.22

RANK ASSIGNED TO EMISSION SOURCE DATA

ESA/California Milk Producers

Natural gas combustion

Without flue gas recirculation

Test No.	Load, % of Max	Emissions, ppm				Emissions @ 0% O2						
		CO	NOx	CO2	% O2	CO	NOx	CO2	CO EF, lb/MM ft3	NOx EF, lb/MM ft3	CO2 EF, lb/MM ft3	NOx Red'n, %
4	60	182	64.4	-	3.62	220	75	ERR	150	84	ERR	60
3	100	455	81.7	-	3.54	548	95	ERR	374	107	ERR	100
Averages												

With flue gas recirculation

Test No.	Load, % of Max	Emissions, ppm				Emissions @ 0% O2						
		CO	NOx	CO2	% O2	CO	NOx	CO2	CO EF, lb/MM ft3	NOx EF, lb/MM ft3	CO2 EF, lb/MM ft3	NOx Red'n, %
6	60	47	29.7	-	3.45	56	35	ERR	38	39	ERR	53.9
7	60	85	22	-	3.05	100	26	ERR	68	29	ERR	65.8
5	100	386	33.9	-	3.09	453	40	ERR	309	44	ERR	58.5
Averages												

Note: FGR rates were 9.7, 16.0, and 9.6 % of total flue gas flow for Tests 6, 7, and 5, respectively.

File: CAMilk.wk1

10/1/84
 10/1/84

Colony in Milk Producer Center
 Long Island Sound, 1984

cont.

1/1/84 • Farrier: Clean tanks for large
 feeding, 100000 white, per hour
 at 100000 psi.

Temperature of tank, both water, oil
 and #3 distillate oil

1/1/84 • CO₂ control: Clean & wash
 the system 100 psi and oxygen
 control system

• All 100000 psi collected
 in #1 tank.

• See 100000 spread sheet for
 division factor

• Clean 3/4 inch

Steel H 100000 psi = 100000 psi

water H 100000 psi = 100000 psi

$\Delta = 100000$

Heat output 100000 psi x 100000 psi = 60 MM Btu/hr

Heat input 100000 psi = 70 MM Btu/hr