

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section 1-4

4/93

Reference 17

Source Test for Measurement of
Nitrogen Oxides and Carbon Monoxide Emissions from
Boiler Exhaust at

GAF BUILDING MATERIALS
11800 Industry Ave.
Fontana, CA 92335

Prepared By
Pacific Environmental Services, Inc.
13100 Brooks Drive
Baldwin Park, CA 91706
(818) 856-1400

PES Job Number: 4450
5/16/91

TABLE OF CONTENTS

	<u>Page</u>
Introduction and Process Description.....	1
Testing Methodology	2
Results	7
Quality Assurance/Quality Control	10

FIGURES

Figure 1: Boiler Equipment and Test Locations

Figure 2: Continuous Monitoring Schematic

APPENDICES

Appendix A: Permit to Construct for Boiler

Appendix B: Field Data and Calculations

Appendix C: Calibrations Data

INTRODUCTION and PROCESS DESCRIPTION

Pacific Environmental Services (PES) was retained by Southern California Boiler Company to measure CO and NOx emissions from a 16.8 MMBTU boiler located at GAF Building Materials in Fontana, CA. The tests were conducted to determine compliance with SCAQMD method 1146.

The object of the source test was to determine NOx and CO emissions under minimal, normal, and maximum load conditions with the boiler operating on number 2 fuel oil and natural gas. Instruments were used to determine the concentrations of oxides of nitrogen, oxygen, and carbon dioxide on a continuous basis. A velocity traverse was conducted to determine the volumetric stack gas flow rate for each fuel. PES conducted the test on May 13, 1991. The test was performed by Steve Hernandez and Siya Mokh of PES. Mr M. Dean High, Senior Vice President of PES, provided guidance and supervision for planning and supervision purposes.

The existing water tube boiler was retrofitted with an Industrial Combustion Model LNDG-210P burner assembly rated at 16.8 MMBTU/hr for natural gas and No. 2 fuel oil. The boiler is equipped with a flue gas recirculation (FGR) system and a oxygen trim system (see Figure 1). The permit to Construct for this equipment can be found in Appendix A.

TEST METHODOLOGY

For each test condition, SCAQMD method 100.1 was used to determine the oxides of nitrogen (NO_x), carbon monoxide (CO), carbon dioxide (CO₂), and oxygen (O₂) levels in the effluent gas from the boiler. The concentrations were measured by using a Continuous Emissions Monitoring System (CEMS) installed in a PES mobil monitoring van. A schematic of this system is shown in Figure 2.

A Horiba model PIR 2000 non-dispersive infrared analyzer was used to determine the carbon monoxide concentration, a Beckman Industrial Model 880 Nondispersive Infrared Analyzer was used to determine the CO₂ concentration, a Beckman Industrial Model 755 Paramagnetic Analyzer was used to determine the oxygen concentration, and a Thermo Electron Model 10 Chemiluminescent Analyzer was used to determine the NO_x concentration. Specifications for each analyzer are shown in Table 1. The output of the analyzers was linearized by the manufacturers.

The monitoring train consisted of a 3/8-inch stainless steel sampling probe, a 3/8-inch heated Teflon sampling line, a sample refrigeration system (operated at 40°F), a glass fiber filter in a 47 mm stainless steel holder, a diaphragm vacuum pump, and a sample distribution manifold. The distribution manifold was equipped with a series of 3-way valves with flow meters (rotometer style). One flow meter acted as a bypass, and the others were connected to the individual analyzers. The output of each analyzer was logged 60 times per minute with a Yokogawa Model 2400 multi-channel strip chart recorder. The recorder monitored the output of each individual analyzer on a separate channel scaled specifically for that component.

Prior to the source tests, the suction side of the monitoring system was leak-checked at 20" vacuum, and the sampling bias of the system was determined by introducing a CO, CO₂, O₂ span gas blend at the tip of the sampling line. A comparison of the analyzer responses was made between the span gas introduced at the sample line tip and the span gas introduced directly to the analyzers to ensure a differential of less than 5%. Since all analyzers were left on line during this procedure, a cross interference check was accomplished at the same time. The analyzers were spanned at a point between 20% and 80% of full scale before and after each source test with NBS traceable calibration gases, and with zero nitrogen. Table 2 lists all the gases used.

Table No. 1 Continuous Monitor Specifications**NO_x Chemiluminiscent Analyzer - Thermo-Electron Model 10A**

Response Time	1.5 sec - NO 1.7 sec - NO _x
Zero Drift	± 0.5% after warm up (30 min)
Linearity	± 1% of full scale
Accuracy	Derived from the calibration NO/NO _x ± 1% gas was used.
Output	NO 0-10 Vdc NO _x 0-1 Vdc (Scaled 0-100 ppm on stripchart)

O₂ Paramagnetic Analyzer - Beckman Model 755R

Response Time	2 Sec
Zero Drift	± 1% of full scale
Linearity	± 1% of full scale
Accuracy	Derived from the calibration O ₂ ± 1% gas was used.
Output	0-1 Vdc (Scaled 0-25.0% on stripchart)

CO/CO₂ Infrared Analyzers - Horiba model PIR 2000, Beckman 880

Response Time	2 sec.
Zero Drift	± 1% of full scale
Span Drift	± 1% of full scale
Linearity	± 1% of full scale
Accuracy	Derived from the calibration CO ± 1% gas was used.
Output	0-1 Vdc (Scaled 0-500ppm on strip chart)

Table No. 2 Calibration Gases

Gas Composition	Use:	Cylinder Ser. No.	Certified Accuracy	Analysis Date
Nitrogen	Zero Gas	AAL2931	Zero Grade	N/A
19.9% O ₂ 400 ppm CO 4.0% CO ₂ Bal N ₂	Span Gas	ALMO 13973	± 1%	2-12-91
4.0% O ₂ 2000 ppm CO 8.0% CO ₂ Bal N ₂	Span Gas	ALMO 12743	± 1%	3-21-91
NO 92.57 ppm NO _x 92.82 ppm Bal N ₂	Span Gas	AAL 2284	± 1% Exp 11-92	5-6-91




Figure 2

TEST RESULTS

The first three tests were conducted with the boiler using number 2 fuel oil. Test 1 was conducted at a minimum firing rate of 3.5 MMBTU/hr, test 2 was conducted at a normal firing rate of 8.12 MMBTU/hr, and test 3 was conducted at a maximum firing rate of 16.1 MMBTU/hr. The second three tests were run with the boiler using natural gas. Test 4 was conducted at a minimum firing rate of 3.26 MMBTU/hr, test 5 was conducted at a normal firing rate of 9.5 MMBTU/hr, and test 6 was conducted at a maximum firing rate of 16 MMBTU/hr.

Since no steam was produced with this type of boiler, loads were determined by the fuel consumption during the test period.

The results of each test are presented with all relative data and the monitored and corrected concentrations. Table 3 details the results for No. 2 fuel oil, and Table 4 the results for natural gas.

Table No. 3 Fuel Oil *

RUN 1:

Condition: 25% of load capacity 3.5 MMBTU/hr
Fuel: No. 2 Fuel oil 25 gal/hr

RESULTS						
Pollutant	Units	Measured	Corr to 3%	Allowed	SCAQMD	Rule
NO _x	ppm	21.4	22.6	40	1146	
**CO	ppm	80.4	85.2	400	1146	

RUN 2:

Condition: 50% of load capacity 8.12 MMBTU/hr
Fuel: No. 2 Fuel Oil 58 gal/hr

RESULTS						
Pollutant	Units	Measured	Corr to 3%	Allowed	SCAQMD	Rule
NO _x	ppm	29.6	28.8	40	1146	
CO	ppm	121.2	118.0	400	1146	

RUN 3:

Condition: 100% of capacity . 16.1 MMBTU/hr
Fuel: No. 2 Fuel Oil 115 gal/hr

RESULTS						
Pollutant	Units	Measured	Corr to 3%	Allowed	SCAQMD	Rule
NO _x	ppm	29.0	27.9	40	1146	
CO	ppm	192.9	185.6	400	1146	

* Special Low NOx Oil referred to as "Low Sulfur #2 Fuel Oil" by SCAQMD
** High CO due to abnormally low O₂ (< 3%) during test run

Table No. 4 Natural Gas

RUN 4:

Condition: 25% of capacity 3.3 MMBTU/hr
Fuel: Natural Gas 3,102 cu ft/hr

RESULTS						
Pollutant	Units	Measured	Corr to 3%	Allowed	SCAOMD	Rule
NO _x	ppm	21.8	28.2	40	1146	
* CO	ppm	48.2	62.5	400	1146	

RUN 5:

Condition: 50% of load capacity 9.5 MMBTU/hr
Fuel: Natural Gas 9,069 cu ft/hr

RESULTS						
Pollutant	Units	Measured	Corr to 3%	Allowed	SCAQMD	Rule
NO _x	ppm	21.0	26.9	40	1146	
CO	ppm	84.8	108.4	400	1146	

RUN 6:

Condition: 100% of load capacity 16.0 MMBTU/hr
Fuel: Natural Gas 15,275 cu ft/hr

RESULTS					
Pollutant	Units	Measured	Corr to 3%	Allowed	SCAQMD Rule
NO _x	ppm	19.0	22.6	40	1146
CO	ppm	103.7	123.8	400	1146

* High CO due to abnormally high Flue Gas Recirculation during test run (>20%)

SOURCE CATEGORY: Natural Gas
EXCLUSION CRITERIA CHECKLIST

REFERENCE Refined Natural Gas

CRITERIA	YES	NO
1. Test series averages are reported in units that can be converted to the selected reporting units?	<input type="checkbox"/>	
2. Test series represent compatible test methods?	<input checked="" type="checkbox"/>	
3. In tests in which emission control devices were used, the control devices are fully specified?	<input type="checkbox"/>	
4. Is it clear whether or not the emissions were controlled (or not controlled)?	<input type="checkbox"/>	

Form filled out by T. J. Schaeffer

Date 1/1/82

INDICATE WHETHER ANSWER IS YES OR NO WITH AN "X" IN APPROPRIATE BOX.

IF ALL ANSWERS ARE "YES" PROCEED TO METHODOLOGY/DETAIL CRITERIA CHECKLIST.

SOURCE CATEGORY Industrial
 METHODOLOGY/DETAIL CRITERIA CHECKLIST

REFERENCE 710-100-0001

CRITERIA	YES	NO	COMMENTS
1. Is the manner in which the source was operated well documented in the report?	✓		
Was the source operating within typical parameters during the test?	✓		
2. Did sampling procedures deviate from standard methods?		✓	
If so, were the deviations well documented?			
Were the deviations appropriate?			
Comment on how any alterations in sampling procedure may have influenced the results.			
3. Were there wide variations in the results?		✓	
If yes, can the variations be adequately explained by information in the report?			NY
If the variations are not well explained, should the data be considered of poor quality?			NY
4. Do the test reports contain the raw data sheets?		✓	
Are the nomenclature and equations used equivalent to those specified by the EPA?			
Comment on the consistency and completeness of the results.			Test data not complete

Form filled out by John B. Brown

Date 2/19/92

INDICATE YES OR NO WITH AN "X" IN THE APPROPRIATE BOX. FILL IN COMMENTS.

IF, BASED ON ABOVE ANSWERS, THE SOURCE REPORT PROVIDES ADEQUATE DETAIL AND DEMONSTRATES SOUND METHODOLOGY, PROCEED TO RATING THE DATA IN THE RATING CRITERIA CHECKLIST.

SOURCE CATEGORY Potential for
RATING CRITERIA CHECKLIST

Reference the 3rd historical site

RATING CRITERIA	YES	NO
A Tests performed by a sound methodology and reported in enough detail for adequate validation?		
B Tests were performed by a generally sound methodology, but not enough detail for adequate validation?		
C Were tests based on untested or new methodology that lacks significant amount of background data?		
D Were tests based on generally unacceptable methods, but may provide order-of-magnitude values for the source?		

COMMENTS
<p>From a literature source, and a look at a similar site, the methodology is sound and adequate.</p> <p>Only the methodology is sound and adequate, but the data is not enough to validate.</p>

Form filled out by DR. J. G. D. J. G.
Date 18/10/02

BASED ON ANSWERS AND COMMENTS ABOVE, ASSIGN A RANK TO THIS LITERATURE SOURCE:

<u>B</u>

DR. J. G. D. J. G.

RANK ASSIGNED TO EMISSION SOURCE DATA

380-42

Self-Extinguishing

Source: Test in Measurement of

Flame Retardant and Carbon Black Additives

for Polymers in a 2000°C Furnace.

The British Standard Test, etc.

• The average 10.0 million BTU per hour
flame temperature

• Self-Extinguishing

IMDG-300 ft. square


Rated at 16.0 MW per hr.

• The test is based on the following procedure:
the test specimen is heated to 2000°C
by gas or electric heating.

• See notes especially for
furnace.

PES/GAF Building Materials

Natural gas combustion

With flue gas recirculation 

Emissions, ppm

Test No.	Load, % of Max at 3% O ₂	Emissions, ppm			Emissions at 0% O ₂			CO EF, lb/MM ft ³			NOX EF, lb/MM ft ³			CO ₂ EF, lb/MM ft ³		
		CO	NOX	CO ₂	% O ₂	CO	NOX	CO ₂	CO	NOX	CO ₂	CO	NOX	CO ₂		
4	25	62.5	28.2	-	NA	73	33	ERR	52	39	ERR	52	39	ERR		
5	50	108.4	26.9	-	NA	127	31	ERR	91	37	ERR	91	37	ERR		
6	100	123.8	22.6	-	NA	145	26	ERR	104	31	ERR	104	31	ERR		
Averages						82.5	35.7	ERR								

File: GAF-PES.wk1