

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Natural Gas Combustion

AP-42 Section 1.4
Reference Number

4

SYSTEMATIC FIELD STUDY OF NO_x EMISSION CONTROL METHODS FOR UTILITY BOILERS

AP42 Section 1.4
4/93

Reference 7

by
William Bartok
Allen R. Crawford
Gregory J. Piegari

prepared under Contract No. CPA 70-90
December 31, 1971

for the
Office of Air Programs
ENVIRONMENTAL PROTECTION AGENCY
Research Triangle Park, North Carolina

GRU.4GNOS.71

ESSO RESEARCH AND ENGINEERING COMPANY
Government Research Laboratory
Linden, New Jersey

TABLE 2-12

EMISSION FACTORS FOR GAS FIRED BOILERS

Boiler			Emission Factor					
Code	Size and Load(1) MW	Type of Firing(2)	NO _x			CO		
			ppm, at 3% O ₂ , Dry Basis	lb/10 ⁶ BTU (3)	gm/10 ⁶ cal. (3)	ppm, at 3% O ₂ , Dry Basis	lb/10 ⁶ BTU	gm/10 ⁶ cal.
B I	Small 80F 66F	FW V	497	0.65	1.16	52	0.043	0.074
			155	0.20	0.36	12	0.010	0.017
A C C G	Medium 180F 315F 220F	FW FW AW	390	0.51	0.92	14	0.011	0.020
			992	1.29	2.32	(6)	(6)	(6)
			675	0.88	1.58	14	0.012	0.020
H D	320F 355F	T HO	340	0.44	0.79	175	0.145	0.249
			946	1.23	2.21	86 (67) (4)	0.068	0.122
E F	Large 480F 600F	HO HO	736 (140) (5)	0.96	1.73	20-400	0.016-0.33	0.028-0.57
			570	0.74	1.33	8	0.006	0.011

- (1) Load: F = Full Load, R = Reduced Load
 (2) Type of Firing: FW = Front Wall
 V = Vertical
 AW = All Wall
 T = Tangential
 HO = Horizontally Opposed

- (3) Expressed as equivalent NO₂
 (4) Using "NO-ports"
 (5) Using staged combustion
 (6) Not available

AP 42 Section 1.4

4/93

Reference 8

1.4 NATURAL GAS COMBUSTION

1.4.1 General¹⁻²

Natural gas is one of the major fuels used throughout the country. It is used mainly for power generation, for industrial process steam and heat production, and for domestic and commercial space heating. The primary component of natural gas is methane, although varying amounts of ethane and smaller amounts of nitrogen, helium and carbon dioxide are also present. Gas processing plants are required for recovery of liquefiable constituents and removal of hydrogen sulfide (H₂S) before the gas is used (see Natural Gas Processing, Section 9.2). The average gross heating value of natural gas is approximately 9350 kilocalories per standard cubic meter (1050 British thermal units/standard cubic foot), usually varying from 8900 to 9800 kcal/scm (1000 to 1100 Btu/scf).

1.4.2 Emission And Controls³⁻²⁶

Even though natural gas is considered to be a relatively clean fuel, some emissions can occur from the combustion reaction. For example, improper operating conditions, including poor mixing, insufficient air, etc., may cause large amounts of smoke, carbon monoxide and hydrocarbons. Moreover, because a sulfur containing mercaptan is added to natural gas to permit detection, small amounts of sulfur oxides will also be produced in the combustion process.

Nitrogen oxides are the major pollutants of concern when burning natural gas. Nitrogen oxide emissions are functions of combustion chamber temperature and combustion product cooling rate. Emission levels vary considerably with the type and size of unit and with operating conditions.

In some large boilers, several operating modifications may be used for NO_x control. Staged combustion, for example, including off-stoichiometric firing and/or two stage combustion, can reduce emissions by 5 to 50 percent. (26) In off-stoichiometric firing, also called "biased firing", some burners are operated fuel rich, some fuel lean, and others may supply air only. In two stage combustion, the burners are operated fuel rich (by introducing only 70 to 90 percent stoichiometric air), with combustion being completed by air injected above the flame zone through second stage "NO ports". In staged combustion, NO_x emissions are reduced because the bulk of combustion occurs under fuel rich conditions.

Other NO_x reducing modifications include low excess air firing and flue gas recirculation. In low excess air firing, excess air levels are kept as low as possible without producing unacceptable levels of unburned combustibles (carbon monoxide, volatile organic compounds and smoke) and/or other operating problems. This technique can reduce NO_x emissions 5 to 35 percent, primarily because of lack of oxygen during combustion. Flue gas recirculation into the primary combustion zone, because the flue gas is relatively cool and oxygen deficient, can also lower NO_x emissions 4 to 85 percent, depending on the amount of gas recirculated. Flue gas recirculation is best suited for new boilers. Retrofit application would require extensive burner modifications.

TABLE 1.4-1. UNCONTROLLED EMISSION FACTORS FOR NATURAL GAS COMBUSTION^a

Furnace size & type (10 ⁶ Btu/hr heat input)	Particulate ^b		Sulfur dioxide ^c		Nitrogen oxides ^d		Carbon monoxide ^e				Volatile organics			
							Methane		Nonmethane		Methane		Nonmethane	
	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³
Utility boilers (> 100)	16 - 80	1 - 5	9.6	0.6	8800 ^h	550 ^h	640	40	23	1.4	4.8	0.3		
Industrial boilers (10 - 100)	16 - 80	1 - 5	9.6	0.6	2240	140	560	35	44	2.8	48	3		
Domestic and commercial boilers (< 10)	16 - 80	1 - 5	9.6	0.6	1600	100	320	20	84	5.3	43	2.7		

^aExpressed as weight/volume fuel fired.^bReferences 15-18.^cBased on avg. sulfur content of natural gas, 4600 g/10⁶ m³ (2000 gr/10⁶ scf).^dReferences 4-5, 7-8, 11, 14, 18-19, 21.^eExpressed as NO_x. Tests indicate about 95 weight % NO_x is NO₂.^fReferences 4, 7-8, 16, 22-23.^gMay increase 10 - 100 times with improper operation or maintenance.^hReferences 16, 18. At reduced loads, multiplyfactor by load reduction coefficient in Figure 1.4-1. For potential NO_x reductions bycombustion modification, see text. Note that NO_x reduction from these modifications will

also occur at reduced load conditions.

NO_x

4.31-32

521

742

8.1-17.1-22

11.35-40

14.1-18.1-22

18.1-22

21.1-22

25.1-22

29.1-22

33.1-22

37.1-22

41.1-22

45.1-22

49.1-22

53.1-22

57.1-22

61.1-22

65.1-22

69.1-22

73.1-22

77.1-22

81.1-22

85.1-22

89.1-22

93.1-22

97.1-22

101.1-22

105.1-22

109.1-22

113.1-22

117.1-22

121.1-22

125.1-22

129.1-22

133.1-22

137.1-22

Studies indicate that low NO_x burners (20 to 50 percent reduction) and ammonia injection (40 to 70 percent reduction) also offer NO_x emission reductions.

Combinations of the above combustion modifications may also be employed to reduce NO_x emissions further. In some boilers, for instance, NO_x reductions as high as 70 to 90 percent have been produced by employing several of these techniques simultaneously. In general, however, because the net effect of any of these combinations varies greatly, it is difficult to predict what the reductions will be in individual applications.

Although not measured, all particulate has been estimated to be less than 1 micrometer in size. ^{g. have} Emission factors for natural gas combustion are presented in Table 1.4-1, and factor ratings in Table 1.4-2.

*particulate
statement
27.4-262*

TABLE 1.4-2. FACTOR RATINGS FOR NATURAL GAS COMBUSTION

Furnace type	Particulate	Sulfur oxides	Nitrogen oxides	Carbon monoxide	Volatile organics	
					Nonmethane	Methane
Utility boiler	B	A	A	A	C	C
Industrial boiler	B	A	A	A	C	C
Commercial boiler	B	A	A	A	D	D
Residential furnace	B	A	A	A	D	D




Figure 1.4-1. Load reduction coefficient as function of boiler load.
(Used to determine NO_x reductions at reduced loads in large boilers.)

References for Section 1.4

1. D. M. Hugh, et al., Exhaust Gases from Combustion and Industrial Processes, EPA Contract No. EHSD 71-36, Engineering Science, Inc., Washington, DC, October 2, 1971.
2. J. H. Perry (ed.), Chemical Engineer's Handbook, 4th Edition, McGraw-Hill, New York, NY, 1963. *only pages used are on 10 files*
3. H. H. Hovey, et al., The Development of Air Contaminant Emission Tables for Non-process Emissions, New York State Department of Health, Albany, NY, 1965.
4. W. Bartok, et al., Systematic Field Study of NO_x Emission Control Methods for Utility Boilers, APTD-1163, U. S. Environmental Protection Agency, Research Triangle Park, NC, December 1971. *only 2 tables*

5. F. A. Bagwell, et al., "Oxides of Nitrogen Emission Reduction Program for Oil and Gas Fired Utility Boilers", Proceedings of the American Power Conference, 14:683-693, April 1970.
6. R. L. Chass and R. E. George, "Contaminant Emissions from the Combustion of Fuels", Journal of the Air Pollution Control Association, 10:34-43, February 1980. *no page #s, short document (4 pages)*
7. H. E. Dietzmann, A Study of Power Plant Boiler Emissions, Final Report No. AR-837, Southwest Research Institute, San Antonio, TX, August 1972.
8. R. E. Barrett, et al., Field Investigation of Emissions from Combustion Equipment for Space Heating, EPA-R2-73-084, U. S. Environmental Protection Agency, Research Triangle Park, NC, June 1973.
9. Confidential information, American Gas Association Laboratories, Cleveland, OH, May 1970.
10. Unpublished data on domestic gas fired units, U. S. Environmental Protection Agency, Cincinnati, OH, 1970.
11. C. E. Blakeslee and H. E. Burbock, "Controlling NO_x Emissions from Steam Generators", Journal of the Air Pollution Control Association, 23:37-42, January 1979.
12. L. K. Jain, et al., "State of the Art" for Controlling NO_x Emissions: Part 1, Utility Boilers, EPA-Contract No. 68-02-0241, Catalytic, Inc., Charlotte, NC, September 1972.
13. J. W. Bradstreet and R. J. Fortman, "Status of Control Techniques for Achieving Compliance with Air Pollution Regulations by the Electric Utility Industry", Presented at the 3rd Annual Industrial Air Pollution Control Conference, Knoxville, TN, March 1973.
14. *see* Study of Emissions of NO_x from Natural Gas Fired Steam Electric Power Plants in Texas, Phase II, Volume II, Radian Corporation, Austin, TX, May 8, 1972.
15. N. F. Suprenant, et al., Emissions Assessment of Conventional Stationary Combustion Systems, Volume I: Gas and Oil Fired Residential Heating Sources, EPA-600/7-79-029b, U. S. Environmental Protection Agency, Washington, DC, May 1979. *just pertinent section on file*
16. C. C. Shih, et al., Emissions Assessment of Conventional Stationary Combustion Systems, Volume III: External Combustion Sources for Electricity Generation, EPA Contract No. 68-02-2197, TRW, Inc., Redondo Beach, CA, November 1980. *partial ref in file*
17. N. F. Suprenant, et al., Emissions Assessment of Conventional Stationary Combustion Sources, Volume IV: Commercial Institutional Combustion Sources, EPA Contract No. 68-02-2197, GCA Corporation, Bedford, MA, October 1980. *partial ref in file*

18. N. F. Suprenant, et al., Emissions Assessment of Conventional Stationary Combustion Systems, Volume V: Industrial Combustion Sources, EPA Contract No. 68-02-2197, GCA Corporation, Bedford, MA, October 1980. *partial report*
19. R. J. Milligan, et al., Review of NO_x Emission Factors for Stationary Fossil Fuel Combustion Sources, EPA-450/4-79-021, U. S. Environmental Protection Agency, Research Triangle Park, NC, September 1979.
20. W. H. Thrasher and D. W. Dewerth, Evaluation of the Pollutant Emissions from Gas Fired Water Heaters, Research Report No. 1507, American Gas Association, Cleveland, OH, April 1977.
21. W. H. Thrasher and D. W. Dewerth, Evaluation of the Pollutant Emissions from Gas Fired Forced Air Furnaces, Research Report No. 1503, American Gas Association, Cleveland, OH, May 1975.
22. G. A. Cato, et al., Field Testing: Application of Combustion Modification To Control Pollutant Emissions from Industrial Boilers, Phase I, EPA-650/2-74-078a, U. S. Environmental Protection Agency, Washington, DC, October 1974.
23. G. A. Cato, et al., Field Testing: Application of Combustion Modification To Control Pollutant Emissions from Industrial Boilers, Phase II, EPA-600/2-76-086a, U. S. Environmental Protection Agency, Washington, DC, April 1976. *only TCC*
24. W. A. Carter and H. J. Buening, Thirty-day Field Tests of Industrial Boilers - Site 5, EPA Contract No. 68-02-2645, KVB Engineering, Inc., Irvine, CA, May 1981. *Preliminary Report*
25. W. A. Carter and H. J. Buening, Thirty-day Field Tests of Industrial Boilers - Site 6, EPA Contract No. 68-02-2645, KVB Engineering, Inc., Irvine, CA, May 1981. *Preliminary Report*
26. K. J. Lim, et al., Technology Assessment Report for Industrial Boiler Applications: NO_x Combustion Modification, EPA Contract No. 68-02-3101, Acurex Corporation, Mountain View, CA, December 1979. *only 2 tables*
27. H. J. Taback, et al., Fine Particle Emissions From Stationary and Miscellaneous Sources in the South Coast Air Basin, California Air Resources Board Contract No. A6-191-30, KVB, Inc., Tustin, CA, February 1979.

TABLE 1.4-1. UNCONTROLLED EMISSION FACTORS FOR NATURAL GAS COMBUSTION^a

FURNACE SIZE & TYPE										COMBUSTION			
Furnace Size & Type (10 ⁶ Btu/hr heat input)		Particulates ^b kg/10 ⁶ m ³ lb/10 ⁶ ft ³	Sulfur ^c Dioxide kg/10 ⁶ m ³ lb/10 ⁶ ft ³	Nitrogen ^{d,e} Oxide kg/10 ⁶ m ³ lb/10 ⁶ ft ³	Carbon ^{f,g} Monoxide kg/10 ⁶ m ³ lb/10 ⁶ ft ³	Nonmethane Hydrocarbons ^h kg/10 ⁶ m ³ lb/10 ⁶ ft ³	Volatile Organic Compounds ⁱ kg/10 ⁶ m ³ lb/10 ⁶ ft ³	Methane ^j kg/10 ⁶ m ³ lb/10 ⁶ ft ³					
Utility boilers (>100)	16-80	1-5	9.6	0.6	8800 ^h	550 ^h	640	40	23	1.4	4.8	0.3	
Industrial boilers (10 - 100)	16-80	1-5	9.6	0.6	2240	140	560	35	44	2.8	48	3	
Domestic and commercial boilers (<10)	16-80	1-5	9.6	0.6	1600	100	320	20	84	5.3	43	2.7	

^a All emission factors are expressed as weight per volume fuel fired.

^b References 15-18.

^c Reference 4 (based on an average sulfur content of natural gas of 4600 g/10⁶ Nm³ (2000 gr/10⁶ scf)).

^d References 4-5, 7-8, 11, 14, 18-19, 21.

^e Expressed as NO₂. Test results indicate that about 95 weight % of NO_x is NO.

^f References 4, 7-8, 16, 18, 22-25.

^g References 16 and 18.

^h Use 4400 kg/10⁶ m³ (275 lb/10⁶ ft³) for tangentially fired units. At reduced loads, multiply this factor by the load reduction coefficient given in Figure 1.4-1. See text for potential NO_x reductions by combustion modifications. Note that the NO_x reduction from these modifications will also occur at reduced load conditions.

ⁱ May increase 10 to 100 times with improper operation or maintenance.

^j See text for potential NO_x reductions by combustion modifications. Note that the NO_x reduction from these modifications will also occur at reduced load conditions.

Old section
1.4 Table

TABLE 1.4-1. UNCONTROLLED EMISSION FACTORS FOR NATURAL GAS COMBUSTION^a

Furnace size & type (10 ⁶ Btu/hr heat input)	Particulate ^b		Sulfur dioxide ^c		Nitrogen oxide ^{d,e}		Carbon monoxide ^{f,g}		Volatile Organics		Methane lb/10 ⁶ ft ³	
	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	kg/10 ⁶ m ³	lb/10 ⁶ ft ³		
Utility Boilers (> 100)	16 - 80	1 - 5	9.6	0.6	8800 ^h	550 ^h	640	40	23	1.4	4.8	0.3
Industrial Boilers (10 - 100)	16 - 80	1 - 5	9.6	0.6	2240	140	560	35	44	2.8	48	3
Commercial Boilers and Furnaces (0.5 - 10)	16 - 80	1 - 5	9.6	0.6	1600	100	320	20	84	5.3	43	2.7
Residential Boilers and Furnaces (< 0.5)	16 - 80	1 - 5	9.6	0.6	1600	100	320	20	84	5.3	43	2.7

^a Expressed as weight/volume fuel fired.^b References 15-18.^c Reference 4. Based on avg. sulfur content of natural gas, 4600 g/10⁶ Nm³ (2000 gr/10⁶ scf).^d References 4-5, 7-8, 11, 14, 18-19, 21.^e Expressed as NO₂. Tests indicate about 95 weight % NO_x is NO.^f References 4, 7-8, 16, 18, 22-25.^g References 16, 18. May increase 10 - 100 times with improper operation or maintenance.^h For tangentially fired units, use 4400 kg/10⁶ m³ (275 lb/10⁶ ft³). At reduced loads, multiply factor by load reduction coefficient in Figure 1.4-1. For potential NO_x reductions by combustion modification, see text. Note that NO_x reduction from these modifications will also occur at reduced load conditions.