

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

**AP-42 Section Number:** 1.8


**Reference Number:** 20

**Title:** Source Test Report Number 4 Boiler  
Impingement Wet Scrubber Particulate  
Emissions: Sugar Cane Growers  
Cooperative of Florida

December 1990

Ref 7 A.J.

# Sugar Cane Growers Cooperative of Florida



POST OFFICE BOX 666

BELLE GLADE, FLORIDA

January 22, 1991

RECEIVED

JAN 24 1991

Division of Environmental Engineering  
PALM BEACH COUNTY  
HEALTH DEPARTMENT

Department of Environmental Regulation  
South Florida District  
2269 Bay Street  
Fort Myers, FL 33901

Attention: Mr. David Knowles      Re: Compliance Testing on  
Boiler No. 4 - A050-115039

Gentlemen:

Pursuant to fulfilling the provisions of the operating permit referred to above, we are enclosing two compliance test reports on Boiler No. 4.

Also enclosed is a certificate of calibration of the flowmeter installed in this boiler.

Sincerely,

E. R. Arias  
Executive Vice President

ERA:jm

Enclosure

cc: Mr. Ajaya K. Satyal, HRS/Palm Beach County  
Public Health Unit (with copy of report)

GLADES SUGAR HOUSE

*Sugar Cane Growers*



*Cooperative of Florida*

POST OFFICE BOX 666

BELLE GLADE, FLORIDA

January 22, 1991

TO WHOM IT MAY CONCERN:

I hereby certify that the steam flowmeter of Boiler No. 4 was calibrated, on August 27, 1990, using manufacturer's recommended procedures.


Romilio Alvarez  
Chief  
Instrumentation Department

SOURCE TEST REPORT  
NUMBER 4 BOILER  
IMPINGEMENT WET SCRUBBER  
PARTICULATE EMISSIONS  
SUGAR CANE GROWERS COOPERATIVE OF FLORIDA  
BELLE GLADE, FLORIDA

DECEMBER 11, 1990

PREPARED FOR:  
SUGAR CANE GROWERS COOPERATIVE OF FLORIDA  
BELLE GLADE, FLORIDA

PREPARED BY:  
AIR CONSULTING and ENGINEERING, INC.  
2106 N.W. 67th PLACE  
SUITE 4  
GAINESVILLE, FLORIDA  
32607  
14642 FLAMINGO DRIVE  
WEST PALM BEACH, FLORIDA  
33470



REPORT CERTIFICATION

To the best of my knowledge, all applicable field and analytical procedures comply with Florida Department of Environmental Regulation requirements and all test data and plant operating data are true and correct.

Stephen L. Neck  
Stephen L. Neck, P.E.

State of Florida  
Registration No. 20020

January 6, 1991  
Date

SEAL

## TABLE OF CONTENTS

| SECTION                                    | PAGE |
|--------------------------------------------|------|
| 1.0 INTRODUCTION.....                      | 1    |
| 2.0 SUMMARY AND DISCUSSION OF RESULTS..... | 2    |
| 3.0 PROCESS DESCRIPTION AND OPERATION..... | 4    |
| 4.0 SAMPLING POINT LOCATION.....           | 5    |
| 5.0 FIELD AND ANALYTICAL PROCEDURES.....   | 7    |

### APPENDICES

APPENDIX A--COMPLETE EMISSION DATA AND  
SAMPLE CALCULATIONS

APPENDIX B--FIELD DATA SHEETS

APPENDIX C--LABORATORY ANALYSES

APPENDIX D--QUALITY ASSURANCE AND  
CHAIN OF CUSTODY

APPENDIX E--PRODUCTION RATE CERTIFICATION

APPENDIX F--PROJECT PARTICIPANTS

## LIST OF TABLES

### TABLE

|   |                                              |   |
|---|----------------------------------------------|---|
| 1 | SUMMARY OF PARTICULATE MATTER EMISSIONS..... | 3 |
|---|----------------------------------------------|---|

## LIST OF FIGURES

### FIGURE

|   |                              |   |
|---|------------------------------|---|
| 1 | SAMPLING POINT LOCATION..... | 6 |
| 2 | EPA 5 SAMPLING TRAIN.....    | 8 |

## 1.0 INTRODUCTION

Personnel from Air Consulting and Engineering, INC. (ACEI) performed annual source emission compliance testing for the Sugar Cane Growers Cooperative of Florida (SCGCOF) on December 11, 1990. Testing was performed at the Number 4 Boiler wet scrubber outlet.

Testing was designed to fulfill "specific conditions" of the current Florida Department of Environmental Regulation (FDER) operating permit.

Three United States Environmental Protection Agency (USEPA) Method 5 particulate matter (PM) test runs were conducted while the plant was documented to be operating within 10% of permitted production.

Mr. Blas Marin of SCGCOF served as test coordinator and certified production rates.

Mr. Ken Tucker of the Florida Department of Environmental Regulation witnessed most of the testing.

## 2.0 SUMMARY and DISCUSSION of RESULTS

Results of the emission testing are provided in Table 1. Complete emission data are located in the report appendices.

The source was found to be operating within full compliance of permit conditions. Stack emissions averaged 63.44 pounds per hour (LB/HR) and 0.158 pounds per million btu(LB/MMBTU) heat input against a "process rate" basis allowable emission of 0.190 LB/MMBTU. Permit conditions limit emissions to 0.10 LB/MMBTU from oil and 0.20 LB/MMBTU from residue firing.

Production rate summaries are provided in Appendix A. These data were taken from control room recordings of steam flow, temperature, and pressure as well as feedwater temperature and pressure(Appendix E). Residue integrator and oil meter readings were recorded at the beginning and end of each particulate test run by ACEI personnel.

TABLE 1  
EMISSION SUMMARY  
SUGAR GROWERS COOPERATIVE OF FLORIDA  
NUMBER 4 BOILER  
DECEMBER 11, 1990

| RUN NUMBER | TIME         | ACTUAL EMISSIONS |          | ALLOWABLE EMISSIONS |          |
|------------|--------------|------------------|----------|---------------------|----------|
|            |              | LB/HR            | LB/MMBTU | LB/HR               | LB/MMBTU |
| 1          | 0915-1019 64 | 61.02            | 0.152    | 76.57               | 0.190    |
| 2          | 1105-1208 63 | 64.03            | 0.159    | 76.50               | 0.190    |
| 3          | 1244-1348 64 | 65.27            | 0.164    | 75.65               | 0.190    |
| AVERAGES   | -----        | 63.44            | 0.158    | 76.24               | 0.190    |

### 3.0 PROCESS DESCRIPTION AND OPERATION


The Number 4 Boiler at Sugar Cane Growers Cooperative is a spreader stoker design used primarily for residue fuel firing. Supplemental oil firing was also utilized for the emission test. The boiler averaged 235,511 pounds per hour steam production over the three run test period.


Oil meters, steam integrators, and other production monitoring devices were rigorously calibrated prior to the production season.

#### 4.0 SAMPLING POINT LOCATION

The sampling point location is a single scrubber outlet stack, 113.5" in diameter. The stack has four sample ports 90 degrees apart. The ports are located 300" from an upstream disturbance and 84" from the outlet.

Twenty-four test points were sampled for each test run. The traverse were located as shown in Figure 1. The stack configuration is such that there is no reason to evaluate the presence of cyclonic flow.



|  |                          |
|-------------------------------------------------------------------------------------|--------------------------|
| TRAVERSE POINT NUMBER                                                               | INCHES INSIDE STACK WALL |
| 1                                                                                   | 2.4                      |
| 2                                                                                   | 7.6                      |
| 3                                                                                   | 13.4                     |
| 4                                                                                   | 20.1                     |
| 5                                                                                   | 28.4                     |
| 6                                                                                   | 40.4                     |

NOTE: NOT TO SCALE

FIGURE I.  
SAMPLING POINT LOCATION  
BOILER NO. 4  
SUGARCANE GROWERS COOP. OF FLORIDA

AIR CONSULTING  
and  
ENGINEERING

## 5.0 FIELD and ANALYTICAL PROCEDURES- USEPA METHOD 5

Particulate matter samples were collected by the emission measurement method specified by the United States Environmental Protection Agency. A schematic diagram of the sampling train used is provided in Figure 2. All particulate matter captured from the nozzle to and including the filter was included in the calculation of the emission rate of particulate matter.

### PREPARATION OF EQUIPMENT

1. FILTERS- Gelman type "A" glass fiber filters were placed in a drying oven for two hours at 105 degrees C, removed and placed in a standard desiccator containing indicating silica gel, allowed to cool for two hours, and weighed to the nearest 0.1 mg. The filters were then re-desiccated for a minimum of six hours and weighed to a constant weight (less than 0.5 mg change from previous weighing). The average of the two constant weights was used as the tare value.
2. NOZZLE, FILTER HOLDER, AND SAMPLING PROBE - The nozzle, filter holder, and sampling probe were washed vigorously with soapy water and brushes, rinsed with distilled water and acetone, and dried prior to the test program. All openings on the equipment were sealed while in transit to the test site.
3. IMPINGERS - The Greenburg-Smith impingers were cleaned, rinsed, and dried as in 2. The impingers were also sealed during transit.

### TEST PROCEDURE

Prior to performing the actual particulate matter sample runs, certain stack and stack gas parameters were measured. These preliminary measurements included the average gas temperature, the stack gas velocity head, the stack gas moisture content, and the dimensions at the point where the tests were to be performed. The stack temperature was determined using a bi-metallic thermocouple and calibrated




FIGURE 2  
EPA METHOD 5 SAMPLING TRAIN

pyrometer. Velocity head measurements were made with a calibrated type "s" pitot tube and an inclined manometer. Velocity head measurements of 0.05 inches H<sub>2</sub>O or less were measured using a micromonometer.

The sampling traverse points were selected so that a representative sample could be extracted from the gas stream. The traverse points were located in the center of equal areas, the number of which were dependent upon the distance upstream or downstream from flow disturbances. USEPA Methods 1 and 2 were utilized for this task.

Each particulate matter test run consisted of sampling for a specific amount of time at each point. The type "s" pitot tube was connected to the sampling probe so that an instantaneous velocity head measurement could be made at each traverse point while conducting the test run. The stack gas temperature was also measured at each traverse point. Together with assumed moisture and orsat knowledge as well as known nozzle area, calculations of "isokinetic" (equal energy or velocity) were quickly made and effected for each traverse point during the test run.

The gases sampled passed through the following components: a stainless steel nozzle and glass probe; a glass fiber filter; two impingers charged with 100 ml of distilled water each; one dry impinger; one impinger with 200 grams of silica gel desiccant; a flexible length of tubing; a leak free pump; a calibrated dry gas meter; and, finally, a calibrated flow orifice.

Sample recovery was accomplished in the following manner:

1. The pre-tared filter was removed from its holder and placed in Container 1 and sealed. (This is usually performed in the lab).
2. All sample-exposed surfaces prior to the filter were washed with acetone and placed in Container 2. The container was then sealed and the liquid level marked.
3. The volume of water from the first three impingers was measured for the purpose of calculating the moisture content of the stack gases, then discarded.
4. The silica gel from the fourth impinger was transferred to the original tared container and sealed.

#### LABORATORY ANALYSIS

The three sample containers from each sampler run were analyzed according to the following procedures:

1. The filter was either dried for two hours at 105 degrees C or desiccated for 24 hours at ambient temperature. Following desiccation, the filter was weighed to the nearest 0.1 mg. A minimum of two such weighings six hours apart were made with a variance of less than 0.5 mg.
2. The acetone from Container 2 was transferred to a tared beaker, evaporated to dryness, and weighed in the same manner as above.
3. The used silica gel in its tared container was weighed to the nearest 0.1 gram.

The total sample weight included the weight gains from Sample Containers 1 and 2.

#### DATA

All relevant field and lab data sheets as well as emission calculations are provided in the report appendices.

APPENDIX A  
COMPLETE EMISSION DATA  
AND  
SAMPLE CALCULATIONS

APPENDIX A  
COMPLETE EMISSION DATA  
AND  
SAMPLE CALCULATIONS

AIR CONSULTING & ENGINEERING, INC.  
Complete Emission Data

-----  
PLANT: SUGAR GROWERS COOPERATIVE OF FL. DATE: 12-11-90  
LOCATION: BELLE GLADE, FLORIDA RUN NUMBER 1  
SOURCE: NUMBER 4 SCRUBBER OUTLET TIME: 0912-1023  
-----

TIME INTERVAL----- 71 MINUTES

OIL:

FINAL OIL----- 24210  
BEGIN OIL 23900  
FACTOR----- 1

STEAM:

FINAL STEAM----- 6761  
BEGIN STEAM 6681  
FACTOR----- 3500  
TEMPERATURE 580 DEGREES F  
PRESSURE----- 425 PSIG  
440 PSIA

FEEDWATER:

TEMPERATURE----- 260 DEGREES F  
PRESSURE 600 PSIG  
615 PSIA

HEAT INPUT:

STEAM----- 1291.7 BTU/LB  
FEEDWATER 228.6 BTU/LB  
NET STEAM----- 1063.1 BTU/LB  
STEAM RATE 236620 LB/HR  
BOILER EFFICIENCY----- 62.5 %  
TOTAL FUEL HEAT INPUT 402.48 MMBTUH  
STEAM INTEGRATOR FACTOR----- 1.00

OIL----- 261.97 GPH  
OIL 150000 BTU/GAL

TOTAL HEAT INPUT (OIL)----- 39.30 MMBTUH  
TOTAL HEAT INPUT (NON-OIL) 363.18 MMBTUH

ALLOWABLES:

ALLOWABLE EMISSION (OIL)----- .10 LB/MMBTU  
ALLOWABLE EMISSION (NON-OIL) .20 LB/MMBTU

TOTAL ALLOWABLE EMISSION----- 76.57 LB/HR  
TOTAL ACTUAL EMISSION 61.02 LB/HR

TOTAL ALLOWABLE EMISSION----- 0.190 LB/MMBTU  
TOTAL ACTUAL EMISSION 0.152 LB/MMBTU

AIR CONSULTING & ENGINEERING, INC.  
Complete Emission Data

-----  
PLANT: SUGAR GROWERS COOPERATIVE OF FL. DATE: 12-11-90  
LOCATION: BELLE GLADE, FLORIDA RUN NUMBER 2  
SOURCE: NUMBER 4 SCRUBBER OUTLET TIME: 1100-1212  
-----

TIME INTERVAL----- 72 MINUTES

OIL:

FINAL OIL----- 24680  
BEGIN OIL----- 24370  
FACTOR----- 1

STEAM:

FINAL STEAM----- 6882  
BEGIN STEAM----- 6801  
FACTOR----- 3500  
TEMPERATURE----- 580 DEGREES F  
PRESSURE----- 425 PSIG  
440 PSIA

FEEDWATER:

TEMPERATURE----- 260 DEGREES F  
PRESSURE----- 600 PSIG  
615 PSIA

HEAT INPUT:

STEAM----- 1291.7 BTU/LB  
FEEDWATER----- 228.6 BTU/LB  
NET STEAM----- 1063.1 BTU/LB  
STEAM RATE----- 236250 LB/HR  
BOILER EFFICIENCY----- 62.5 %  
TOTAL FUEL HEAT INPUT----- 401.85 MMBTUH  
STEAM INTEGRATOR FACTOR----- 1.00

OIL----- 258.33 GPH  
OIL----- 150000 BTU/GAL

TOTAL HEAT INPUT (OIL)----- 38.75 MMBTUH  
TOTAL HEAT INPUT (NON-OIL)----- 363.10 MMBTUH

ALLOWABLES:

ALLOWABLE EMISSION (OIL)----- .10 LB/MMBTU  
ALLOWABLE EMISSION (NON-OIL)----- .20 LB/MMBTU

TOTAL ALLOWABLE EMISSION----- 76.50 LB/HR  
TOTAL ACTUAL EMISSION----- 64.03 LB/HR

TOTAL ALLOWABLE EMISSION----- 0.190 LB/MMBTU  
TOTAL ACTUAL EMISSION----- 0.159 LB/MMBTU

AIR CONSULTING & ENGINEERING, INC.  
Complete Emission Data

-----  
PLANT: SUGAR GROWERS COOPERATIVE OF FL. DATE: 12-11-90  
LOCATION: BELLE GLADE, FLORIDA RUN NUMBER 3  
SOURCE: NUMBER 4 SCRUBBER OUTLET TIME: 1240-1351  
-----

TIME INTERVAL----- 71 MINUTES

OIL:

FINAL OIL----- 25100  
BEGIN OIL 24800  
FACTOR----- 1

STEAM:

FINAL STEAM----- 6992  
BEGIN STEAM 6913  
FACTOR----- 3500  
TEMPERATURE 580 DEGREES F  
PRESSURE----- 430 PSIG  
445 PSIA

FEEDWATER:

TEMPERATURE----- 260 DEGREES F  
PRESSURE 600 PSIG  
615 PSIA

HEAT INPUT:

STEAM----- 1291.2 BTU/LB  
FEEDWATER 228.6 BTU/LB  
NET STEAM----- 1062.6 BTU/LB  
STEAM RATE 233662 LB/HR  
BOILER EFFICIENCY----- 62.5 %  
TOTAL FUEL HEAT INPUT 397.26 MMBTUH  
STEAM INTEGRATOR FACTOR----- 1.00

OIL----- 253.52 GPH  
OIL 150000 BTU/GAL

TOTAL HEAT INPUT (OIL)----- 38.03 MMBTUH  
TOTAL HEAT INPUT (NON-OIL) 359.23 MMBTUH

ALLOWABLES:

ALLOWABLE EMISSION (OIL)----- .10 LB/MMBTU  
ALLOWABLE EMISSION (NON-OIL) .20 LB/MMBTU

TOTAL ALLOWABLE EMISSION----- 75.65 LB/HR  
TOTAL ACTUAL EMISSION 65.27 LB/HR

TOTAL ALLOWABLE EMISSION----- 0.190 LB/MMBTU  
TOTAL ACTUAL EMISSION 0.164 LB/MMBTU

# AIR CONSULTING AND ENGINEERING, INC.

## Complete Emission Results

|           |                               |       |                  |
|-----------|-------------------------------|-------|------------------|
| Plant:    | SUGAR CANE GROWEERS CO-OP FL. | Date: | 12-11-90         |
| Location: | BELLE GLADE, FLORIDA          | Run 1 | From 0915 - 1019 |
| Stack:    | NUMBER 4 BOILER               |       |                  |

|                      |                           |                     |                           |
|----------------------|---------------------------|---------------------|---------------------------|
| Y Factor             | 0.994                     | Nozzle Diameter     | 0.300 In                  |
| Total Time           | 60.00 Min                 | Nozzle Area         | 0.000491 Ft <sup>2</sup>  |
| Stack Area           | 70.260 Ft <sup>2</sup>    | Barometric Pressure | 30.20 In Hg               |
| Stack Temperature    | 144.5 -F                  | Meter Temperature   | 67.8 -F                   |
| Stack Pressure       | 30.20 In Hg               | Meter Orifice Diff  | 1.981 In H <sub>2</sub> O |
| Stack Avg - Vel Head | 0.591 In H <sub>2</sub> O | Meter Volume        | 41.783 CF                 |
|                      |                           | Condensate Vol      | 241.30 ml                 |

|                                               |          |        |
|-----------------------------------------------|----------|--------|
| 1. Volume Water Vapor Sampled                 | 11.358   | SCF    |
| 2. Volume Standard Dry Gas Sampled            | 42.122   | SCF    |
| 3. Total Standard Sample Volume               | 53.480   | SCF    |
| 4. Percent Moisture                           | 21.200   |        |
| 5. Percent Dry Air                            | 78.800   |        |
| 6. Molecular Weight of Dry Flue Gas           | 30.030   |        |
| 7. Molecular Weight of Wet Flue Gas           | 27.480   |        |
| 8. Specific Gravity Flue Gas                  | 0.95     |        |
| 9. Percent Oxygen [O <sub>2</sub> ]           | 9.75     |        |
| 10. Percent Carbon Dioxide [CO <sub>2</sub> ] | 10.25    |        |
| 11. Percent Excess Air                        | 85.752   |        |
| 12. Velocity of Flue Gas                      | 36.222   | FPS    |
| 13. Actual Volumetric Flow Rate               | 152696.0 | ACFM   |
| 14. Dry Volumetric Flow Rate                  | 120324.5 | ACFMD  |
| 15. Standard Volumetric Flow Rate             | 106073.5 | SCFMD  |
| 16. Emission Concentration                    | 0.0671   | gr/SCF |
| 17. Emission Concentration                    | 0.0466   | gr/ACF |
| 18. Emission Rate                             | 61.02    | lbs/Hr |
| 19. Percent Isokinetic                        | 94.8     |        |

|                   |       |    |
|-------------------|-------|----|
| Probe/Nozzle Wash | 17.0  | mg |
| Filter            | 166.2 | mg |
| Total             | 183.2 | mg |

# AIR CONSULTING AND ENGINEERING, INC.

## Complete Emission Results

|           |                              |       |             |
|-----------|------------------------------|-------|-------------|
| Plant:    | SUGAR CANE GROWERS CO-OP FL. | Date: | 12-11-90    |
| Location: | BELLE GLADE, FLORIDA         | Run   | 2           |
| Stack:    | NUMBER 4 BOILER              | From  | 1105 - 1208 |

|                      |                           |                     |                           |
|----------------------|---------------------------|---------------------|---------------------------|
| Y Factor             | 0.994                     | Nozzle Diameter     | 0.300 In                  |
| Total Time           | 60.00 Min                 | Nozzle Area         | 0.000491 Ft <sup>2</sup>  |
| Stack Area           | 70.260 Ft <sup>2</sup>    | Barometric Pressure | 30.20 In Hg               |
| Stack Temperature    | 144.8 -F                  | Meter Temperature   | 79.3 -F                   |
| Stack Pressure       | 30.20 In Hg               | Meter Orifice Diff  | 2.213 In H <sub>2</sub> O |
| Stack Avg - Vel Head | 0.591 In H <sub>2</sub> O | Meter Volume        | 44.061 CF                 |
|                      |                           | Condensate Vol      | 258.40 ml                 |

|                                               |          |        |
|-----------------------------------------------|----------|--------|
| 1. Volume Water Vapor Sampled                 | 12.163   | SCF    |
| 2. Volume Standard Dry Gas Sampled            | 43.496   | SCF    |
| 3. Total Standard Sample Volume               | 55.659   | SCF    |
| 4. Percent Moisture                           | 21.900   |        |
| 5. Percent Dry Air                            | 78.100   |        |
| 6. Molecular Weight of Dry Flue Gas           | 30.060   |        |
| 7. Molecular Weight of Wet Flue Gas           | 27.419   |        |
| 8. Specific Gravity Flue Gas                  | 0.95     |        |
| 9. Percent Oxygen [O <sub>2</sub> ]           | 9.50     |        |
| 10. Percent Carbon Dioxide [CO <sub>2</sub> ] | 10.50    |        |
| 11. Percent Excess Air                        | 81.756   |        |
| 12. Velocity of Flue Gas                      | 36.271   | FPS    |
| 13. Actual Volumetric Flow Rate               | 152903.7 | ACFM   |
| 14. Dry Volumetric Flow Rate                  | 119417.8 | ACFMD  |
| 15. Standard Volumetric Flow Rate             | 105238.0 | SCFMD  |
| 16. Emission Concentration                    | 0.0710   | gr/SCF |
| 17. Emission Concentration                    | 0.0489   | gr/ACF |
| 18. Emission Rate                             | 64.03    | lbs/Hr |
| 19. Percent Isokinetic                        | 98.6     |        |

|                   |       |    |
|-------------------|-------|----|
| Probe/Nozzle Wash | 16.9  | mg |
| Filter            | 183.2 | mg |
| Total             | 200.1 | mg |

# AIR CONSULTING AND ENGINEERING, INC.

## Complete Emission Results

Plant: SUGAR CANE GROWEERS CO-OP FL. Date: 12-11-90  
 Location: BELLE GLADE, FLORIDA Run 3 From 1244 - 1348  
 Stack: NUMBER 4 BOILER

|                      |                           |                     |                           |
|----------------------|---------------------------|---------------------|---------------------------|
| Y Factor             | 0.994                     | Nozzle Diameter     | 0.300 In                  |
| Total Time           | 60.00 Min                 | Nozzle Area         | 0.000491 Ft <sup>2</sup>  |
| Stack Area           | 70.260 Ft <sup>2</sup>    | Barometric Pressure | 30.20 In Hg               |
| Stack Temperature    | 144.8 -F                  | Meter Temperature   | 85.9 -F                   |
| Stack Pressure       | 30.20 In Hg               | Meter Orifice Diff  | 2.123 In H <sub>2</sub> O |
| Stack Avg - Vel Head | 0.579 In H <sub>2</sub> O | Meter Volume        | 44.032 CF                 |
|                      |                           | Condensate Vol      | 245.60 ml                 |

|                                               |          |        |
|-----------------------------------------------|----------|--------|
| 1. Volume Water Vapor Sampled                 | 11.560   | SCF    |
| 2. Volume Standard Dry Gas Sampled            | 42.933   | SCF    |
| 3. Total Standard Sample Volume               | 54.493   | SCF    |
| 4. Percent Moisture                           | 21.200   |        |
| 5. Percent Dry Air                            | 78.800   |        |
| 6. Molecular Weight of Dry Flue Gas           | 30.060   |        |
| 7. Molecular Weight of Wet Flue Gas           | 27.503   |        |
| 8. Specific Gravity Flue Gas                  | 0.95     |        |
| 9. Percent Oxygen [O <sub>2</sub> ]           | 9.50     |        |
| 10. Percent Carbon Dioxide [CO <sub>2</sub> ] | 10.50    |        |
| 11. Percent Excess Air                        | 81.756   |        |
| 12. Velocity of Flue Gas                      | 35.480   | FPS    |
| 13. Actual Volumetric Flow Rate               | 149570.1 | ACFM   |
| 14. Dry Volumetric Flow Rate                  | 117861.3 | ACFMD  |
| 15. Standard Volumetric Flow Rate             | 103866.3 | SCFMD  |
| 16. Emission Concentration                    | 0.0733   | gr/SCF |
| 17. Emission Concentration                    | 0.0509   | gr/ACF |
| 18. Emission Rate                             | 65.27    | lbs/Hr |
| 19. Percent Isokinetic                        | 98.7     |        |

|                   |       |    |
|-------------------|-------|----|
| Probe/Nozzle Wash | 16.9  | mg |
| Filter            | 187.1 | mg |
| Total             | 204.0 | mg |

Avg O<sub>2</sub> = 9.6  
 Temp = 145  
 Flow = 105,059  
 Oil input = 38.7 mmBtu/hr  
 non-oil = 362 mmBtu/hr  
 258 gal/hr

Plant: SUGAR CANE GROWERS CO-OP FL.  
Date: 12-11-90  
Stack: NUMBER 4 BOILER  
Run Number: 1

Average SQR Velocity Head = 0.591

Velocity Head Inputs:

|        |        |        |        |        |        |        |
|--------|--------|--------|--------|--------|--------|--------|
| 0.3400 | 0.3600 | 0.3600 | 0.4100 | 0.3700 | 0.3100 | 0.2900 |
| 0.3200 | 0.3700 | 0.4000 | 0.4000 | 0.3500 | 0.2700 | 0.3500 |
| 0.4000 | 0.4000 | 0.3600 | 0.3200 | 0.2600 | 0.3100 | 0.3700 |
| 0.3700 | 0.3700 | 0.3500 |        |        |        |        |

Average Orifice Pressure = 1.981

Orifice Pressure Inputs:

|        |        |        |        |        |        |        |
|--------|--------|--------|--------|--------|--------|--------|
| 1.9000 | 2.0000 | 2.0000 | 2.3500 | 2.0000 | 1.8000 | 1.6500 |
| 1.8000 | 2.1000 | 2.3000 | 2.3000 | 2.0000 | 1.5000 | 2.0000 |
| 2.3000 | 2.3000 | 2.0000 | 1.8000 | 1.4000 | 1.7500 | 2.1000 |
| 2.1000 | 2.1000 | 2.0000 |        |        |        |        |

Average Stack Temperature = 144.5

Stack Temperature Inputs:

|     |     |     |     |     |     |     |
|-----|-----|-----|-----|-----|-----|-----|
| 145 | 143 | 144 | 144 | 146 | 145 | 147 |
| 143 | 144 | 145 | 146 | 144 | 144 | 144 |
| 141 | 146 | 144 | 144 | 145 | 145 | 145 |
| 144 | 146 | 145 |     |     |     |     |

Average Meter Temperature = 67.8

Meter Temperature Inputs:

|    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|
| 60 | 60 | 61 | 62 | 62 | 63 | 64 |
| 65 | 65 | 66 | 67 | 68 | 69 | 69 |
| 70 | 70 | 71 | 72 | 73 | 73 | 73 |
| 74 | 75 | 75 |    |    |    |    |

Plant: SUGAR CANE GROWEERS CO-OP FL.  
 Date: 12-11-90  
 Stack: NUMBER 4 BOILER

Vwv Volume Water Vapor Sampled

$$Vwv = 0.04707 \times 241.3 = 11.358 \text{ SCF}$$

VMstd Volume Standard Dry Gas Sampled

$$VMstd = 17.64 \times 41.783 \times 0.994 \times [30.20 + (1.981 / 13.6)] / (67.8 + 460) = 42.122 \text{ SCF}$$

Vt Total Standard Sample Volume

$$Vt = 11.358 + 42.122 = 53.480 \text{ SCF}$$

$$W \text{ Percent Water} = (11.358 / 53.480) \times 100 = 21.2 \%$$

$$FDA \text{ Percent Dry Air} = (1 - 0.212) \times 100 = 78.8 \%$$

Md Molecular Weight of Dry Stack Gas

$$Md = (0.44 \times 10.25 \%CO_2) + (0.32 \times 9.75 \%O_2) + [0.28 \times (80.00 \%N_2 + 0.00 \%CO)] = 30.030$$

Ms Molecular Weight of Wet Stack Gas

$$Ms = (30.030 \times 0.788) + (18 \times 0.212) = 27.480$$

SG Specific Gravity Stack Gas

$$SG = 27.480 / 28.84 = 0.95$$

Ea Percent Excess Air

$$Ea = \frac{((9.75 \%O_2) - (0 \%CO / 2)) \times 100}{[(.264 \times (80 \%N_2)) - (9.75 \%O_2) - (0 \%CO / 2)]}$$

$$Ea = \frac{85.752}{85.752}$$

Vs Velocity of Stack

$$Vs = (85.49 \times 0.84 \times 0.591) \times -[(144.5 + 460) / (30.20 \times 27.480)]$$

$$Vs = 36.222$$

Qa Actual Volumetric Flow

$$Qa = (70.260 \times 36.222 \times 60) = 152696.0 \text{ ACFM}$$

Qd Dry Volumetric Flow

$$Qd = (152696.0 \times 0.788) = 120324.5 \text{ ACFMD}$$

Qsd Standard Volumetric Flow

$$Qsd = 152696.0 \times 0.788 \times [528 / (144.5 + 460)] \times (30.20 / 29.92) = 106073.5 \text{ SCFMD}$$

## Sample Calculations Run 1

Page 2

Plant: SUGAR CANE GROWEERS CO-OP FL.  
Date: 12-11-90  
Stack: NUMBER 4 BOILER

## ESTP Emission Rate

$$\text{gr/SCF} = [0.01543 \times (17.0 + 166.2)] / (42.122)$$
$$\text{gr/SCF} = 0.0671$$

Lbs/Hr Emission Rate

$$\text{Lbs/Hr} = 0.0671 / 7000 \times 106073.5 \times 60 = 61.02$$

I Percent Isokinetic

$$I = 100 \times \left( \frac{144.5 + 460}{67.8 + 460} \right) \times \left[ \frac{(0.002669 \times 241.3) + (41.783 \times 0.994)}{(30.20 + (1.981 / 13.6))} \right] /$$
$$(60 \times 60 \times 36.222 \times 30.20 \times 0.000491)$$
$$I = 94.8 \%$$

Plant: SUGAR CANE GROWERS CO-OP FL.  
Date: 12-11-90  
Stack: NUMBER 4 BOILER  
Run Number: 2

Average SQR Velocity Head = 0.591

Velocity Head Inputs:

|        |        |        |        |        |        |        |
|--------|--------|--------|--------|--------|--------|--------|
| 0.3200 | 0.3700 | 0.4200 | 0.4200 | 0.3800 | 0.3400 | 0.2500 |
| 0.2800 | 0.3600 | 0.4100 | 0.4300 | 0.3600 | 0.3000 | 0.3000 |
| 0.3800 | 0.3800 | 0.3500 | 0.3100 | 0.2700 | 0.3100 | 0.3600 |
| 0.3700 | 0.4000 | 0.3500 |        |        |        |        |

Average Orifice Pressure = 2.213

Orifice Pressure Inputs:

|        |        |        |        |        |        |        |
|--------|--------|--------|--------|--------|--------|--------|
| 2.0000 | 2.3000 | 2.6500 | 2.6500 | 2.4000 | 2.1500 | 1.6000 |
| 1.7500 | 2.3000 | 2.6000 | 2.7000 | 2.3000 | 1.9000 | 1.9000 |
| 2.4000 | 2.4000 | 2.2000 | 1.9500 | 1.7000 | 1.9500 | 2.3000 |
| 2.3000 | 2.5000 | 2.2000 |        |        |        |        |

Average Stack Temperature = 144.8

Stack Temperature Inputs:

|     |     |     |     |     |     |     |
|-----|-----|-----|-----|-----|-----|-----|
| 144 | 143 | 145 | 143 | 146 | 145 | 145 |
| 142 | 146 | 145 | 145 | 145 | 144 | 143 |
| 146 | 146 | 145 | 146 | 146 | 145 | 145 |
| 145 | 144 | 145 |     |     |     |     |

Average Meter Temperature = 79.3

Meter Temperature Inputs:

|    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|
| 75 | 75 | 75 | 75 | 76 | 76 | 77 |
| 77 | 78 | 78 | 79 | 79 | 80 | 80 |
| 80 | 81 | 82 | 82 | 82 | 83 | 83 |
| 83 | 84 | 84 |    |    |    |    |

Plant: SUGAR CANE GROWERS CO-OP FL.  
 Date: 12-11-90  
 Stack: NUMBER 4 BOILER  
 Run Number: 3

Average SQR Velocity Head = 0.579

Velocity Head Inputs:

|        |        |        |        |        |        |        |
|--------|--------|--------|--------|--------|--------|--------|
| 0.2700 | 0.2700 | 0.4100 | 0.4100 | 0.3600 | 0.3000 | 0.2500 |
| 0.3000 | 0.3400 | 0.4000 | 0.4200 | 0.3600 | 0.2800 | 0.3000 |
| 0.4000 | 0.3600 | 0.3300 | 0.3100 | 0.2600 | 0.3000 | 0.3500 |
| 0.3800 | 0.3800 | 0.3600 |        |        |        |        |

Average Orifice Pressure = 2.123

Orifice Pressure Inputs:

|        |        |        |        |        |        |        |
|--------|--------|--------|--------|--------|--------|--------|
| 1.7000 | 1.7000 | 2.6000 | 2.6000 | 2.3000 | 1.9000 | 1.6000 |
| 1.9000 | 2.1000 | 2.5000 | 2.6500 | 2.3000 | 1.7000 | 1.9000 |
| 2.5000 | 2.3000 | 1.9000 | 2.0000 | 1.6000 | 1.9000 | 2.2000 |
| 2.4000 | 2.4000 | 2.3000 |        |        |        |        |

Average Stack Temperature = 144.8

Stack Temperature Inputs:

|     |     |     |     |     |     |     |
|-----|-----|-----|-----|-----|-----|-----|
| 142 | 143 | 142 | 144 | 142 | 145 | 143 |
| 145 | 144 | 146 | 145 | 145 | 145 | 145 |
| 145 | 146 | 146 | 145 | 146 | 145 | 146 |
| 146 | 147 | 146 |     |     |     |     |

Average Meter Temperature = 85.9

Meter Temperature Inputs:

|    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|
| 82 | 82 | 82 | 82 | 83 | 83 | 84 |
| 84 | 85 | 85 | 85 | 86 | 87 | 87 |
| 87 | 87 | 88 | 88 | 89 | 89 | 89 |
| 89 | 89 | 90 |    |    |    |    |

AIR CONSULTING & ENGINEERING, INC.  
COMPLETE EMISSION DATA

PLANT: SUGAR GROWERS COOPERTIVE OF FLA. DATE 12-11-90  
LOCATION: BELLE GLADE, FLORIDA RUN NUMBER 1  
SOURCE: NUMBER 4 BOILER SCRUBBER OUTLET TIME 0912-1031

|                      |                |
|----------------------|----------------|
| TIME INTERVAL        | 71 min.        |
| FINAL OIL            | 24210          |
| BEGIN OIL            | 23900          |
| FACTOR               | 1              |
| FINAL STM            | 956761         |
| BEGIN STM            | 956681         |
| FACTOR               | 3500           |
| TEMP.                | 580            |
| PRESSURE             | 425            |
| FEEDWATER:           |                |
| TEMP.                | 260            |
| PRESS.               | 600            |
| STEAM BTU/LB         | 1293.0         |
| FEEDWATER BTU/#      | 228.6          |
| NET BTU/LB STM       | 1064.4         |
| LB/HR STEAM          | 236620         |
| BOILER EFFICIEN      | 62.50          |
| TOTAL BTU INPUT      | 402.97 MMBTUH  |
| OIL GPH              | 261.97         |
| OIL BTU/GAL.         | 150000         |
| OIL BTU INPUT        | 39.30 MMBTUH   |
| NON OIL BTU IN       | 363.68 MMBTUH  |
| ALLOWED NON OIL      | .20 LB/MMBTU   |
| ALLOWED OIL          | .10 LB/MMBTU   |
| TOTAL ALLOWED EMISS. | 76.66 LB/HR    |
| TOTAL ALLOWED EMISS. | 0.190 LB/MMBTU |
| TOTAL ACTUAL EMISS.  | 60.85 LB/HR    |
| TOTAL ACTUAL EMISS.  | 0.151 LB/MMBTU |

AIR CONSULTING & ENGINEERING, INC.  
COMPLETE EMISSION DATA

PLANT: SUGAR GROWERS COOPERTIVE OF FLA. DATE 12-7-90  
LOCATION: BELLE GLADE, FLORIDA RUN NUMBER 2  
SOURCE: NUMBER 4 BOILER SCRUBBER OUTLET TIME 1100-1212

|                      |                |
|----------------------|----------------|
| TIME INTERVAL        | 72 min.        |
| FINAL OIL            | 24680          |
| BEGIN OIL            | 24370          |
| FACTOR               | 1              |
| FINAL STM            | 956882         |
| BEGIN STM            | 956801         |
| FACTOR               | 3500           |
| TEMP.                | 580            |
| PRESSURE             | 425            |
| FEEDWATER:           |                |
| TEMP.                | 260            |
| PRESS.               | 600            |
| STEAM BTU/LB         | 1293.0         |
| FEEDWATER BTU/#      | 228.6          |
| NET BTU/LB STM       | 1064.4         |
| LB/HR STEAM          | 236250         |
| BOILER EFFICIEN      | 62.50          |
| TOTAL BTU INPUT      | 402.34 MMBTUH  |
| OIL GPH              | 258.33         |
| OIL BTU/GAL.         | 150000         |
| OIL BTU INPUT        | 38.75 MMBTUH   |
| NON OIL BTU IN       | 363.59 MMBTUH  |
| ALLOWED NON OIL      | .20 LB/MMBTU   |
| ALLOWED OIL          | .10 LB/MMBTU   |
| TOTAL ALLOWED EMISS. | 76.59 LB/HR    |
| TOTAL ALLOWED EMISS. | 0.190 LB/MMBTU |
| TOTAL ACTUAL EMISS.  | 64.89 LB/HR    |
| TOTAL ACTUAL EMISS.  | 0.161 LB/MMBTU |

AIR CONSULTING & ENGINEERING, INC.  
COMPLETE EMISSION DATA

PLANT: SUGAR GROWERS COOPERATIVE OF FL. DATE 12-11-90  
LOCATION: BELLE GLADE, FLORIDA RUN NUMBER 3  
SOURCE: NUMBER 4 BOILER SCRUBBER OUTLET TIME 1240-1351

|                      |                |
|----------------------|----------------|
| TIME INTERVAL        | 71 min.        |
| FINAL OIL            | 25100          |
| BEGIN OIL            | 24800          |
| FACTOR               | 1              |
| FINAL STM            | 956992         |
| BEGIN STM            | 956913         |
| FACTOR               | 3500           |
| TEMP.                | 580            |
| PRESSURE             | 425            |
| FEEDWATER:           |                |
| TEMP.                | 260            |
| PRESS.               | 600            |
| STEAM BTU/LB         | 1293.0         |
| FEEDWATER BTU/#      | 228.6          |
| NET BTU/LB STM       | 1064.4         |
| LB/HR STEAM          | 233662         |
| BOILER EFFICIEN      | 62.50          |
| TOTAL BTU INPUT      | 397.94 MMBTUH  |
| OIL GPH              | 253.52         |
| OIL BTU/GAL.         | 150000         |
| OIL BTU INPUT        | 38.03 MMBTUH   |
| NON OIL BTU IN       | 359.91 MMBTUH  |
| ALLOWED NON OIL      | .20 LB/MMBTU   |
| ALLOWED OIL          | .10 LB/MMBTU   |
| TOTAL ALLOWED EMISS. | 75.78 LB/HR    |
| TOTAL ALLOWED EMISS. | 0.190 LB/MMBTU |
| TOTAL ACTUAL EMISS.  | 65.95 LB/HR    |
| TOTAL ACTUAL EMISS.  | 0.166 LB/MMBTU |

APPENDIX B  
FIELD DATA SHEETS

# STACK SAMPLING FIELD DATA SHEET

PLANT SECC, at Florida  
 SOURCE N. 4002 of Bolea  
 PLANT LOCATION Belle Glade, FL  
 TYPE OF SAMPLING TRAIN EPAS

TYPE OF SAMPLES P.M.  
 DATE 12-11-90 RUN NO. 1  
 TIME START 0915 TIME END 1019

SAMPLE TIME 24.25 (min/pt) = 60 Total min  
 ASSUMED MOISTURE 25 % FDA

NOMOGRAPH C, 5.7 PITOT CORR. .84  
 P<sub>b</sub> 30.20 "Hg P<sub>s</sub> 30.20 "Hg

WEATHER clear TEMP 30.20 °F  
 METER BOX NO. 1 H<sub>2</sub>O 0.994

NOZZLE CAL. 1300 1299 1300 = 1300  
 STACK DIMENSIONS 113.5

STACK AREA 10.20 ft<sup>2</sup> EFFECTIVE 113.5 ft<sup>2</sup>  
 STACK HEIGHT 113.5 ft

STACK DIAMETER: UPSTRM. 113.5 DNSTRM. 113.5  
 PORT SIZE 113.5 in. NIPPLE LENGTH 113.5 in.

U CORD LENGTH 113.5  
 REMARKS: 113.5

ACE  
 AIR CONSULTING  
 & ENGINEERING, INC.  
 2106 N.W. 67th PLACE, Suite 9810  
 GAINESVILLE, FLORIDA 32606

2421 1023  
 2370 0912  
 9576761  
 9576681

60.85

15711  
 14050  
 17601  
 164  
 182.7

TEST ID                       
 PAGE                      OF                     

MAT'L PROCESSING RATE                       
 GAS METER READINGS: FINAL 344.203 ft<sup>3</sup>  
 INITIAL 307.420 ft<sup>3</sup>

NET                      ft<sup>3</sup>  
 FILTER NO. 2901 IMP. VOL. GAIN 235 ml.  
 SIL GEL NO. 2 WT. GAIN 613 ml.

TOTAL CONDENSATE 244.3 ml.  
 ORSAT                     

|                   | 1 | 2 | 3 | 4 | AVG.  |
|-------------------|---|---|---|---|-------|
| % CO <sub>2</sub> |   |   |   |   | 10.25 |
| % O <sub>2</sub>  |   |   |   |   | 9.75  |
| % CO              |   |   |   |   |       |
| % N <sub>2</sub>  |   |   |   |   |       |

F<sub>0</sub> =                      F<sub>0</sub> RANGE =                     

LEAK CHECKS                       
 ORSAT ANALYZER                     

PRE D<sub>02</sub> cfm 28 "Hg POST 0.00 cfm 23 "Hg  
 METER BOX/PUMP                      GAS SAMPLE SYST.                     

ORSAT BAG                       
 PITOT TUBE NO. 53 PRE-TEST 0.15

POST-TEST(+) 4.3 / 15 H<sub>2</sub>O/Sec  
 POST-TEST(-) 2.9 / 15 H<sub>2</sub>O/Sec

PYROMETER NO. 1  
 BOX OPERATOR Nick PROBE HOLDER Gerard

| PORT AND TRAVERSE POINT NUMBER | DISTANCE FROM INSIDE STACK WALL / COMMENTS | CLOCK TIME | GAS METER READING (FT <sup>3</sup> ) | STACK VELOCITY HEAD | METER ORIFICE PRESS. DIFF. ("H <sub>2</sub> O") | STACK GAS TEMP (°F) | SAMPLE BOX TEMP (°F) | LAST IMPINGER TEMP (°F) | DRY GAS METER TEMP (°F) | VACUUM ON SAMPLE TRAIL ("Hg) |
|--------------------------------|--------------------------------------------|------------|--------------------------------------|---------------------|-------------------------------------------------|---------------------|----------------------|-------------------------|-------------------------|------------------------------|
| 1-1                            |                                            |            | 309.18                               | .34                 | 1.9                                             | 145                 | 225                  | 42                      | 60                      | 9.5                          |
| 2                              |                                            | 0920       | 310.90                               | .36                 | 2.                                              | 143                 | 230                  | 42                      | 60                      | 10                           |
| 3                              |                                            |            | 312.63                               | .36                 | 2.                                              | 144                 | 227                  | 41                      | 61                      | 10                           |
| 4                              |                                            | 0925       | 314.5                                | .41                 | 2.35                                            | 144                 | 235                  | 43                      | 62                      | 12                           |
| 5                              |                                            |            | 316.28                               | .37                 | 2                                               | 146                 | 231                  | 40                      | 62                      | 11                           |
| 6                              |                                            | 0930       | 317.95                               | .31                 | 1.8                                             | 145                 | 231                  | 40                      | 63                      | 10                           |



# STACK SAMPLING FIELD DATA SHEET



2106 N. W. 67th PLACE, Suites 9 & 10  
GAINESVILLE, FLORIDA 32606

TEST ID \_\_\_\_\_  
PAGE \_\_\_\_\_ OF \_\_\_\_\_

PLANT SCG-C of FLORIDA  
SOURCE Number 4 Boiler  
PLANT LOCATION \_\_\_\_\_  
TYPE OF SAMPLING TRAIN \_\_\_\_\_  
TYPE OF SAMPLES \_\_\_\_\_  
DATE 12-11-90 RUN NO. 2  
TIME START 1105 TIME END 1208  
SAMPLE TIME 241.25 (min/pt) = 60 Total min  
ASSUMED MOISTURE \_\_\_\_\_ % FDA  
NOMOGRAPH  $G_1$  6.3 PITOT CORR. 1.84  
 $P_b$  30.2 "Hg  $P_s$  30.2 "Hg  
WEATHER CLEAR TEMP \_\_\_\_\_ °F  
METER BOX NO. 1 H 2.05 Y 0.994  
NOZZLE CAL. \_\_\_\_\_ = 1.300

STACK DIMENSIONS \_\_\_\_\_  
STACK AREA 70.26 ft<sup>2</sup> EFFECTIVE \_\_\_\_\_ ft<sup>2</sup>  
STACK HEIGHT \_\_\_\_\_ ft.  
STACK DIAMETER: UPSTRM. \_\_\_\_\_ DNSTRM. \_\_\_\_\_  
PORT SIZE \_\_\_\_\_ in. NIPPLE LENGTH \_\_\_\_\_ in.  
U CORD LENGTH 125 + 75  
REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

956882  
956801 1100  
24680  
24370 1212  
  
15913  
4069  
1844

MAT'L PROCESSING RATE \_\_\_\_\_  
GAS METER READINGS: FINAL 393.602 ft<sup>3</sup>  
INITIAL 349.547 ft<sup>3</sup>  
NET \_\_\_\_\_ ft<sup>3</sup>  
FILTER NO. 2902 IMP. VOL. GAIN 250 ml.  
SIL GEL NO. 25 WT. GAIN 8.4 ml.  
TOTAL CONDENSATE \_\_\_\_\_ ml.

ORSAT

|                   | 1 | 2 | 3 | 4 | AVG.        |
|-------------------|---|---|---|---|-------------|
| % CO <sub>2</sub> |   |   |   |   | <u>90.5</u> |
| % O <sub>2</sub>  |   |   |   |   | <u>9.5</u>  |
| % CO              |   |   |   |   |             |
| % N <sub>2</sub>  |   |   |   |   |             |

F<sub>0</sub> = \_\_\_\_\_ F<sub>0</sub> RANGE = \_\_\_\_\_  
ORSAT ANALYZER \_\_\_\_\_


LEAK CHECKS \_\_\_\_\_  
PRE 0.005 cm 2.3 "Hg POST 0.000 cm 2.6 "Hg  
METER BOX/PUMP \_\_\_\_\_ GAS SAMPLE SYST. \_\_\_\_\_

ORSAT BAG \_\_\_\_\_  
PITOT TUBE NO. 53 PRE-TEST 0.15  
POST-TEST (+) 3.4 / 15 H<sub>2</sub>O/Sec  
POST-TEST (-) 3.4 / 15 H<sub>2</sub>O/Sec  
PYROMETER NO. 1  
BOX OPERATOR NECK PROBE HOLDER C-90420

| PORT AND TRAVERSE POINT NUMBER | DISTANCE FROM INSIDE STACK WALL / COMMENTS | CLOCK TIME | GAS METER READING (FT <sup>3</sup> ) | STACK VELOCITY HEAD | METER ORIFICE PRESS. DIFF. ("H <sub>2</sub> O") |       | STACK GAS TEMP (°F) | SAMPLE BOX TEMP (°F) | LAST IMPINGER TEMP (°F) | DRY GAS METER TEMP (°F) | VACUUM ON SAMPLE TRAN ("Hg) |
|--------------------------------|--------------------------------------------|------------|--------------------------------------|---------------------|-------------------------------------------------|-------|---------------------|----------------------|-------------------------|-------------------------|-----------------------------|
| 1-1                            |                                            |            | 351.32                               | 32                  | 1.820                                           | 1.820 | 174                 | 221                  | 45                      | 75                      | 10                          |
| 2                              |                                            | 1110       | 353.18                               | 37                  | 2.3                                             | 2.3   | 143                 | 254                  | 47                      | 75                      | 11                          |
| 3                              |                                            |            | 355.20                               | 42                  | 2.65                                            | 2.65  | 145                 | 257                  | 43                      | 75                      | 13                          |
| 4                              |                                            | 1115       | 357.18                               | 42                  | 2.65                                            | 2.65  | 143                 | 254                  | 46                      | 75                      | 13.5                        |
| 5                              |                                            |            | 359.15                               | 38                  | 2.4                                             | 2.4   | 146                 | 257                  | 48                      | 76                      | 13.5                        |
| 6                              |                                            | 1120       | 360.00                               | 34                  | 2.15                                            | 2.15  | 145                 | 261                  | 49                      | 76                      | 12.5                        |

[illegible]

# STACK SAMPLING FIELD DATA SHEET



2106 N. W. 67th PLACE - SUITES 9 & 10  
GAINESVILLE, FLORIDA 32606

PLANT SCG of Florida  
SOURCE No. 4 Boiler  
PLANT LOCATION Buckley, Halsey, FL  
TYPE OF SAMPLING TRAIN CPA-5  
TYPE OF SAMPLES PM  
DATE 12-11-90 RUN NO. 3  
TIME START 1244 TIME END 1348  
SAMPLE TIME 24125 (min/pt) = 60 Total min  
ASSUMED MOISTURE 20 % FDA 18  
NOMOGRAPH C<sub>d</sub> 6.3 PITOT CORR. 84  
P<sub>b</sub> 30.2 "Hg P<sub>s</sub> 30.2 "Hg  
WEATHER CLEAR TEMP 99.4 °F  
METER BOX NO. 1 H 205 Y 99.4  
NOZZLE CAL. 1300

STACK DIMENSIONS 1135  
STACK AREA 70.26 ft<sup>2</sup> EFFECTIVE ft<sup>2</sup>  
STACK HEIGHT ft  
STACK DIAMETER: UPSTRM. DNSTRM.  
PORT SIZE in. NIPPLE LENGTH in.  
U CORD LENGTH ft  
REMARKS:

25100  
24800 1240  
956992  
956913  
  
5930  
4056  
1874  
18.7

TEST ID \_\_\_\_\_  
PAGE \_\_\_\_\_ OF \_\_\_\_\_

MAT'L PROCESSING RATE  
GAS METER READINGS: FINAL 438.032 ft<sup>3</sup>  
INITIAL 394.00 ft<sup>3</sup>  
NET ft<sup>3</sup>  
FILTER NO. 2903 IMP. VOL. GAIN 240 ml.  
SIL GEL NO. 14 WT. GAIN 516 ml.  
TOTAL CONDENSATE 245.6 ml.

ORSAT

|                   | 1 | 2 | 3 | 4 | AVG. |
|-------------------|---|---|---|---|------|
| % CO <sub>2</sub> |   |   |   |   | 10.5 |
| % O <sub>2</sub>  |   |   |   |   | 9.5  |
| % CO              |   |   |   |   |      |
| % N <sub>2</sub>  |   |   |   |   |      |

F<sub>0</sub> = \_\_\_\_\_ F<sub>0</sub> RANGE = \_\_\_\_\_

ORSAT ANALYZER \_\_\_\_\_

LEAK CHECKS  
PRE 0.00 cfm 23 "Hg POST 0.00 cfm 27 "Hg  
METER BOX/PUMP \_\_\_\_\_ GAS SAMPLE SYST. \_\_\_\_\_  
ORSAT BAG \_\_\_\_\_ PRE-TEST 0.15  
PITOT TUBE NO. 53 H<sub>2</sub>O/Sec 15  
POST-TEST(+) 3.5 H<sub>2</sub>O/Sec 15  
POST-TEST(-) 3 H<sub>2</sub>O/Sec 15  
PYROMETER NO. \_\_\_\_\_  
BOX OPERATOR \_\_\_\_\_ PROBE HOLDER \_\_\_\_\_

| PORT AND TRAVERSE POINT NUMBER | DISTANCE FROM INSIDE STACK WALL / COMMENTS | CLOCK TIME | GAS METER READING (FT <sup>3</sup> ) | STACK VELOCITY HEAD | METER ORIFICE PRESS. DIFF. ("H <sub>2</sub> O") | STACK GAS TEMP (°F) | SAMPLE BOX TEMP (°F) | LAST IMPINGER TEMP (°F) | DRY GAS METER TEMP (°F) | VACUUM ON SAMPLE TRAIN ("Hg) |
|--------------------------------|--------------------------------------------|------------|--------------------------------------|---------------------|-------------------------------------------------|---------------------|----------------------|-------------------------|-------------------------|------------------------------|
| 1-1                            |                                            |            | 397.4                                | 1.27                | CALC. 1.7 ACTUAL 1.7                            | 142                 | 247                  | 54                      | 82                      | 8.5                          |
| 2                              |                                            | 1249       | 399.3                                | 1.27                | 1.7                                             | 143                 | 249                  | 42                      | 82                      | 9.0                          |
| 3                              |                                            |            | 401.3                                | 1.41                | 2.6                                             | 142                 | 258                  | 43                      | 82                      | 13                           |
| 4                              |                                            | 1254       | 403.22                               | 1.41                | 2.6                                             | 144                 | 257                  | 44                      | 82                      | 13                           |
| 5                              |                                            |            | 405.04                               | 1.30                | 2.3                                             | 142                 | 264                  | 44                      | 83                      | 12.5                         |
| 0                              |                                            | 1259       |                                      | 1.23                | 1.9                                             | 145                 | 262                  | 45                      | 83                      | 11.5                         |

[illegible]

APPENDIX C  
LABORATORY ANALYSES

# AIR CONSULTING & ENGINEERING, inc.

## PARTICULATE LAB DATA

SOURCE SUGAR CANE GROWERS - No. 4 BOILER

| PROBE RINSE              | RUN <u>1</u>    | RUN <u>2</u>    | RUN <u>3</u>    | BLANK           |                                |
|--------------------------|-----------------|-----------------|-----------------|-----------------|--------------------------------|
| CONTAINER NUMBER         | <u>S-1</u>      | <u>S-13</u>     | <u>S-22</u>     | <u>S-23</u>     | LIQUID LEVEL <u>12</u>         |
| TOTAL VOLUME (ml)        |                 |                 |                 |                 |                                |
| 1st GROSS WEIGHT (g)     | <u>106.6193</u> | <u>103.5724</u> | <u>103.6482</u> | <u>103.0980</u> | DATE & TIME: <u>12-14/0938</u> |
| 2nd GROSS WEIGHT (g)     | <u>106.6197</u> | <u>103.5720</u> | <u>103.6482</u> | <u>103.0935</u> | DATE & TIME: <u>12-19/1455</u> |
| AVERAGE GROSS WEIGHT (g) | <u>106.6195</u> | <u>103.5722</u> | <u>103.6482</u> | <u>103.0933</u> |                                |
| TARE WEIGHT (g)          | <u>106.6022</u> | <u>103.5604</u> | <u>103.6313</u> | <u>103.0892</u> |                                |
| SUB NET WEIGHT (g)       | <u>0.0173</u>   | <u>0.0118</u>   | <u>0.0169</u>   | <u>0.0041</u>   |                                |
| ACETONE BLANK (g)        | <u>---</u>      | <u>---</u>      | <u>---</u>      | <u>---</u>      |                                |
| TOTAL NET WEIGHT (mg)    | <u>17.3</u>     | <u>11.8</u>     | <u>16.9</u>     | <u>4.1</u>      |                                |

NOTE: In no case should a blank residue > 0.01 mg/g or 0.001% of the weight of acetone used be subtracted from the sample weight.

| FILTER                   | RUN <u>1</u>  | RUN <u>---</u> | RUN <u>---</u> | BLANK         |                                |
|--------------------------|---------------|----------------|----------------|---------------|--------------------------------|
| FILTER NUMBER            | <u>2901</u>   | <u>2902</u>    | <u>2903</u>    | <u>2877</u>   |                                |
| 1st GROSS WEIGHT (g)     | <u>0.5714</u> | <u>0.5703</u>  | <u>0.5929</u>  | <u>0.3993</u> | DATE & TIME: <u>12-14/0938</u> |
| 2nd GROSS WEIGHT (g)     | <u>0.5710</u> | <u>0.5878</u>  | <u>0.5925</u>  | <u>0.3993</u> | DATE & TIME: <u>12-19/1455</u> |
| AVERAGE GROSS WEIGHT (g) | <u>0.5712</u> | <u>0.5901</u>  | <u>0.5927</u>  | <u>0.3993</u> |                                |
| TARE WEIGHT (g)          | <u>0.4050</u> | <u>0.4069</u>  | <u>0.4056</u>  | <u>0.3993</u> |                                |
| SUB NET WEIGHT (g)       | <u>0.1662</u> | <u>0.1832</u>  | <u>0.1871</u>  | <u>0.0000</u> |                                |
| TOTAL NET WEIGHT (mg)    | <u>166.2</u>  | <u>183.2</u>   | <u>187.1</u>   | <u>0</u>      |                                |

TARE  
BALANCE CHECK

SEE LAB BOOK

1st GROSS WEIGHT  
BALANCE CHECK

0 0.0000 1685 12-14-90  
0.5 g 0.5000 100.0g 100.0000  
% RH 47 DATE 12-14-90  
Signature S. J. Duck

2nd GROSS WEIGHT  
BALANCE CHECK

0 0.0000 100.0g ---  
0.5 g 0.5000 100.0g 100.0000  
% RH 50 DATE 12-19-90  
Signature S. J. Duck

APPENDIX D  
QUALITY ASSURANCE  
AND  
CHAIN OF CUSTODY

AIR CONSULTING AND ENGINEERING, Inc.

## SAMPLE RECOVERY AND CHAIN OF CUSTODY

PLANT NAME SUGAR GROWERS COOP TEST DATE 12-11-90  
SOURCE NAME NUMBER 4 BOILER SAMPLE RECOVERED BY SJN  
TYPE OF SAMPLE P.M. PARTICULATE ANALYSES BY SJN

## SAMPLE RECOVERY

| RUN NO.                           | CONTAINER<br>NO. | LIQUID LEVEL<br>MARKED | COLOR | COMMENTS |
|-----------------------------------|------------------|------------------------|-------|----------|
| 1                                 | FILTER 2901      |                        |       |          |
| 1                                 | S-1              |                        |       |          |
| 2                                 | FIL. 2902        |                        |       |          |
| 2                                 | S-13             |                        |       |          |
| 3                                 | FIL. 2903        |                        |       |          |
| 3                                 | S-22             |                        |       |          |
|                                   |                  |                        |       |          |
|                                   |                  |                        |       |          |
|                                   |                  |                        |       |          |
|                                   |                  |                        |       |          |
|                                   |                  |                        |       |          |
|                                   |                  |                        |       |          |
|                                   |                  |                        |       |          |
|                                   |                  |                        |       |          |
| (CIRCLE)<br>ACETONE / WATER BLANK | S-23             |                        |       |          |
| FILTER BLANK                      | 2899             |                        |       |          |

**SILICA GEL**

| RUN NO. | CONTAINER NO. | FINAL WT. (g) | INIT. WT. (g) | NET WT. (g) | COLOR |
|---------|---------------|---------------|---------------|-------------|-------|
| 1       | 2             | 206.3         | 200.0         | 6.3         | OK    |
| 2       | 25            | 208.4         | 200.0         | 8.4         | "     |
| 3       | 14            | 205.6         | 200.0         | 5.6         | "     |
|         |               |               | 200.0         |             |       |
|         |               |               | 200.0         |             |       |
|         |               |               | 200.0         |             |       |
|         |               |               | 200.0         |             |       |
|         |               |               | 200.0         |             |       |

## STANDARD METER CALIBRATION

Air Consulting and Engineering, Inc. (ACE) uses a dry gas meter for the calibration standard. This meter has been calibrated against a wet test meter in triplicate. This data was used to generate a standard meter calibration curve (see next page). Field meter calibrations are corrected to this curve using the following formula:

$$Y_m \times Y_s = Y$$

$Y_m$  = actual ratio of field meter to standard meter

$Y_s$  = ratio of standard meter to wet test meter  
at a given flow rate (from Calibration Curve)

$Y$  = corrected ratio of field meter

The dry standard meter was calibrated on April 26, 1990, and is checked and/or recalibrated at least annually.

# AIR CONSULTING & ENGINEERING

# STANDARD METER CALIBRATION

DATE 11-23-90

LEAK CHECK 0.000 CFM at 12 in. Hg.

METER SERIAL NUMBER 1040616(Savt)

BAROMETRIC PRESSURE 30.07 in. Hg.


STD GAS METER TEMPERATURE 67 °F/ASTM GLASS THERMOMETER TEMPERATURE 69 °F

| WET<br>ΔH | STD<br>ΔH | GAS VOLUME, WET TEST METER |        |                           | GAS VOLUME, STD GAS METER |         |                           | TEMP<br>WET TEST<br>METER<br>(°F) | TEMP<br>OF STD.<br>METER<br>(°F) | TIME<br>(Minutes) |
|-----------|-----------|----------------------------|--------|---------------------------|---------------------------|---------|---------------------------|-----------------------------------|----------------------------------|-------------------|
|           |           | INITIAL                    | FINAL  | ACTUAL<br>ft <sup>3</sup> | INITIAL                   | FINAL   | ACTUAL<br>ft <sup>3</sup> |                                   |                                  |                   |
| -0.1      | -1.1      | 0.000                      | 5.333  | 5.333                     | 272.003                   | 277.309 | 5.306                     | 70                                | 67                               | 12                |
| -0.1      | -1.1      | 5.333                      | 10.664 | 5.331                     | 277.309                   | 282.600 | 5.291                     | 70                                | 67                               | 12                |
| -0.1      | -1.1      | 10.664                     | 15.982 | 5.318                     | 282.600                   | 287.877 | 5.277                     | 70                                | 67                               | 12                |
| -0.3      | -1.9      | 0.000                      | 5.490  | 5.490                     | 288.149                   | 293.623 | 5.474                     | 70                                | 67                               | 9                 |
| -0.3      | -1.9      | 5.490                      | 12.799 | 7.309                     | 293.623                   | 300.898 | 7.275                     | 70                                | 67                               | 12                |
| -0.3      | -1.9      | 12.799                     | 18.278 | 5.479                     | 300.898                   | 306.359 | 5.461                     | 70                                | 67                               | 9                 |
| -0.4      | -2.5      | 0.000                      | 5.160  | 5.160                     | 306.712                   | 311.863 | 5.151                     | 70                                | 67                               | 7                 |
| -0.4      | -2.5      | 5.160                      | 10.321 | 5.161                     | 311.863                   | 317.017 | 5.154                     | 70                                | 67                               | 7                 |
| -0.4      | -2.5      | 10.321                     | 15.488 | 5.167                     | 317.017                   | 322.173 | 5.156                     | 70                                | 67                               | 7                 |
| -0.5      | -3.7      | 0.000                      | 7.481  | 7.481                     | 322.562                   | 330.068 | 7.506                     | 70                                | 67                               | 8                 |
| -0.5      | -3.7      | 7.481                      | 14.039 | 6.558                     | 330.068                   | 336.655 | 6.587                     | 70                                | 67                               | 7                 |
| -0.5      | -3.7      | 14.039                     | 19.649 | 5.610                     | 336.655                   | 342.278 | 5.623                     | 70                                | 67                               | 6                 |
| -0.7      | -5.3      | 0.000                      | 5.639  | 5.639                     | 342.648                   | 348.279 | 5.631                     | 70                                | 67                               | 5                 |
| -0.7      | -5.3      | 5.639                      | 11.268 | 5.629                     | 348.279                   | 353.889 | 5.610                     | 70                                | 67                               | 5                 |
| -0.7      | -5.3      | 11.268                     | 16.889 | 5.621                     | 353.889                   | 359.498 | 5.609                     | 70                                | 67                               | 5                 |


CALIBRATED BY: A. F. Habel

| Y       | SCFM  | Y     | SCFM  | Y     | SCFM  | Y     | SCFM  |
|---------|-------|-------|-------|-------|-------|-------|-------|
| Run 1   | 1.002 | 0.445 | 1.002 | 0.611 | 1.002 | 0.738 | 1.000 |
| Run 2   | 1.005 | 0.445 | 1.004 | 0.610 | 1.002 | 0.738 | 0.999 |
| Run 3   | 1.005 | 0.444 | 1.002 | 0.610 | 1.003 | 0.739 | 1.001 |
| Average | 1.004 | 0.444 | 1.003 | 0.610 | 1.002 | 0.738 | 1.000 |

| Y     | SCFM  | Y     | SCFM  |
|-------|-------|-------|-------|
| 1.009 | 0.986 | 1.010 | 0.986 |
| 1.129 | 1.127 | 1.126 | 1.127 |



air  
consulting  
and  
engineering



STANDARD METER CALIBRATION CURVE  
METER SERIAL NO. 1040616 (SOUTH)  
NOVEMBER 23, 1990

AIR CONSULTING  
and  
ENGINEERING

## AIR CONSULTING &amp; ENGINEERING

## ANNUAL METER CALIBRATION

DATE 6-7-90LEAK CHECK 0.000 CFM at 12 in. Hg.METER BOX NUMBER 1BAROMETRIC PRESSURE 30.02 in. Hg.DRY GAS METER TEMPERATURE 89 °F/ASTM GLASS THERMOMETER TEMPERATURE 90 °F

| ΔHS   | AVERAGE<br>ΔHD | GAS VOLUME, STANDARD METER |         |                           | GAS VOLUME, DRY GAS METER |         |                           | TEMP<br>STD.<br>METER | TEMP<br>OF DRY<br>METER | TIME<br>(Minutes) | TIMER |
|-------|----------------|----------------------------|---------|---------------------------|---------------------------|---------|---------------------------|-----------------------|-------------------------|-------------------|-------|
|       |                | INITIAL                    | FINAL   | ACTUAL<br>ft <sup>3</sup> | INITIAL                   | FINAL   | ACTUAL<br>ft <sup>3</sup> |                       |                         |                   |       |
| -0.07 | 0.5            | 206.539                    | 214.496 | 7.957                     | 719.311                   | 727.244 | 7.933                     | 85                    | 85                      | 21                | 21    |
| -1.15 | 1.25           | 215.308                    | 224.239 | 5.931                     | 728.042                   | 733.952 | 5.910                     | 85                    | 86                      | 10                |       |
| -1.22 | 2.0            | 221.610                    | 227.578 | 5.968                     | 734.320                   | 740.265 | 5.945                     | 85                    | 87                      | 8                 |       |
| -3.32 | 2.75           | 228.029                    | 233.291 | 5.262                     | 740.708                   | 745.940 | 5.232                     | 86                    | 88                      | 6                 |       |
| -4.0  | 3.5            | 233.668                    | 239.592 | 5.924                     | 746.315                   | 752.205 | 5.890                     | 87                    | 90                      | 6                 |       |
| -5.0  | 4.25           | 240.117                    | 245.527 | 5.410                     | 752.724                   | 758.112 | 5.388                     | 87                    | 91                      | 5                 |       |

| DELTA H | Y <sub>a</sub> | SCFM  | Y <sub>s</sub> | Y     |
|---------|----------------|-------|----------------|-------|
| 2.004   | 1.002          | 0.368 | 1.004          | 1.006 |
| 2.041   | 1.002          | 0.577 | 0.998          | 1.000 |
| 2.061   | 1.003          | 0.725 | 0.993          | 0.996 |
| 2.054   | 1.003          | 0.851 | 0.989          | 0.992 |
| 2.063   | 1.003          | 0.956 | 0.985          | 0.988 |
| 2.082   | 1.001          | 1.048 | 0.983          | 0.984 |
| MEAN:   | 2.051          | 1.002 | 0.992          | 0.994 |

CALIBRATED BY:

H. F. Gabel

# AIR CONSULTING & ENGINEERING, inc.

## POST TEST CALIBRATION

DATE 12-22-90 METER BOX NUMBER 1 LEAK CHECK 0.00 CFM at 22 in. Hg.  
 CLIENT ATLANTIC SUGAR + S.C. Co-op SOURCE VARIOUS THERMOCOUPLE NUMBER 1601 PYROMETER NUMBER 1  
 FLIGHT SERVICE Pb 30.10 in. Hg. ACE BAROMETER Pb 30.11 in. Hg.  
 ASTM GLASS THERMOMETER 149 °F / THERMOCOUPLE 150 °F of ASTM GLASS THERMOMETER 68 °F / METER TEMP 68 °F

| ΔHS | AVERAGE ΔHD | GAS VOLUME, STANDARD METER |         |                        | GAS VOLUME, DRY GAS METER |         |                        | TEMP STANDARD METER | TEMP OF DRY METER | TIME (Minutes) | MAX. VACUUM in. Hg. |
|-----|-------------|----------------------------|---------|------------------------|---------------------------|---------|------------------------|---------------------|-------------------|----------------|---------------------|
|     |             | INITIAL                    | FINAL   | ACTUAL ft <sup>3</sup> | INITIAL                   | FINAL   | ACTUAL ft <sup>3</sup> |                     |                   |                |                     |
| 126 | 2.1         | 452.500                    | 493.960 | 41.46                  | 290.053                   | 331.598 | 41.545                 | 71<br>73            | 69<br>76          | 55             | 21                  |
| 119 | 1.5         | 493.960                    | 509.942 | 15.982                 | 331.598                   | 347.654 | 16.056                 | 73<br>75            | 76<br>78          | 25             | 22                  |
| 132 | 2.7         | 509.942                    | 569.500 | 59.558                 | 347.654                   | 406.800 | 59.226                 | 75<br>76            | 78<br>82          | 101            | 20                  |

DELTA H  
 2.068  
 2.052  
 4.341

Y<sub>a</sub>  
 0.994  
 0.997  
 1.007

SCFM  
 0.753  
 0.636  
 0.585

Y<sub>s</sub>  
 0.993  
 0.995  
 0.998

Y  
 0.987  
 0.992  
 1.005

CALIBRATED BY: S. H. Dick

MEAN:

0.995 0.995

 air consulting and engineering

# AIR CONSULTING & ENGINEERING, INC.

## PITOT TUBE CALIBRATION

DATE CALIBRATED 9-25-90

PITOT TUBE 1601

IS PITOT TUBE ASSEMBLY LEVEL YES

ARE PITOT TUBE OPENINGS DAMAGED NO

$\alpha_1 = 0^\circ (< 10^\circ)$ ,  $\alpha_2 = 1.5^\circ (< 10^\circ)$ ,  $\beta_1 = 1^\circ (< 5^\circ)$ ,  $\beta_2 = 2^\circ (< 5^\circ)$

$\gamma = 1.5^\circ$ ,  $\theta = 1^\circ$ ,  $A = 1.179 \text{ in.} = (P_a + P_b)$

$z = A \sin \gamma = 0.031 \text{ in.} < 0.32 / < 1/8 \text{ in.}$

$\phi = A \sin \theta = 0.021 \text{ in.} < 0.08 / < 1/32 \text{ in.}$

$P_a 0.5895 \text{ in.}$   $P_b 0.5895 \text{ in.}$   $D_t 0.375$

WAS CALIBRATION REQUIRED NO

## THERMOCOUPLE CALIBRATION

| SOURCE (SPECIFY) | ASTM GLASS THERMOMETER WITH MERCURY ( $^\circ\text{F}$ ) | PYROMETER ( $^\circ\text{F}$ ) | DEGREE DIFFERENCE | PERCENT DIFFERENCE |
|------------------|----------------------------------------------------------|--------------------------------|-------------------|--------------------|
|------------------|----------------------------------------------------------|--------------------------------|-------------------|--------------------|

ICE BATH

AMBIENT

HOT OVEN

CALIBRATED BY: \_\_\_\_\_

FDER - MAXIMUM 5° DIFFERENCE

EPA  $\left[ \frac{(\text{REF. TEMP. } ^\circ\text{F} + 460^\circ) - (\text{PYROMETER TEMP. } ^\circ\text{F} + 460^\circ)}{\text{REF. TEMP. } ^\circ\text{F} + 460^\circ} \right] 100 \leq 1.5\%$

# AIR CONSULTING & ENGINEERING, INC. PYROMETER CALIBRATION

DATE 7-10-90






PYROMETER NUMBER METER BOX #1

| SOURCE<br>(SPECIFY) | GLASS THERMOMETER<br>WITH NBS MERCURY (°F) | PYROMETER<br>(°F) | DEGREE<br>DIFFERENCE | PERCENT<br>DIFFERENCE |
|---------------------|--------------------------------------------|-------------------|----------------------|-----------------------|
| ICE BATH            | <u>32°</u>                                 | <u>33°</u>        | <u>1</u>             | <u>.2%</u>            |
| AMBIENT             | <u>94°</u>                                 | <u>96°</u>        | <u>2</u>             | <u>.4%</u>            |
| HOT OVEN            | <u>800°</u>                                | <u>800°</u>       | <u>0</u>             | <u>0</u>              |

FDER - MAXIMUM 5° DIFFERENCE

EPA 
$$\left[ \frac{(\text{REF. TEMP. } ^\circ\text{F} + 460^\circ) - (\text{PYROMETER TEMP. } ^\circ\text{F} + 460^\circ)}{\text{REF. TEMP. } ^\circ\text{F} + 460^\circ} \right] 100 \leq 1.5\%$$

CALIBRATED BY: 



NOTE: Flow rate held constant at 0.75; 50% change in flow rate has little effect on probe temperature.

Probe temperatures.

APPENDIX E  
PRODUCTION RATE  
CERTIFICATION

10

SC 1  
7.5 7.5

OIL METER FACTOR \_\_\_\_\_

SCRUBBER(S) PRESS DROP\_\_\_\_,\_\_\_\_

SCRUBBER(S) GPM \_\_\_\_\_, \_\_\_\_\_

SCRUBBER(S) H2O LEVEL\_\_\_\_\_, \_\_\_\_

Ph(if applicable) \_\_\_\_\_, \_\_\_\_\_

FINAL INTEGRATOR 95676

[illegible]

10  
11  
12

BOILER NUMBER 4

OIL METER FACTOR \_\_\_\_\_ /

SCRUBBER(S) PRESS.DROP\_\_\_\_,\_\_\_\_

SCRUBBER(S) GPM \_\_\_\_\_, \_\_\_\_\_

SCRUBBER(S) H2O LEVEL\_\_\_\_\_, \_\_\_\_\_

Ph(if applicable) \_\_\_\_\_, \_\_\_\_\_

FINAL INTEGRATOR\_\_\_\_\_

[illegible]

1. 1. 1.

BOILER NUMBER 4OIL METER FACTOR 1

SCRUBBER(S) PRESS DROP\_\_\_\_\_,\_\_\_\_


SCRUBBER(S) GPM \_\_\_\_\_, \_\_\_\_\_

SCRUBBER(S) H2O LEVEL\_\_\_\_\_, \_\_\_\_\_

Ph(if applicable) \_\_\_\_\_, \_\_\_\_\_

FINAL INTEGRATOR 956992

[illegible]



APPENDIX F  
PROJECT PARTICIPANTS

PROJECT PARTICIPANTS

ACEI:

-----  
STEPHEN L. NECK, P.E.

FIELD TESTING  
REPORT PREPARATION

GERARD GAUTHREUX

FIELD TESTING

SCGCOF:

-----  
JOSE ALVEREZ

PROJECT COORDINATOR

BLAS MARIN

TEST COORDINATOR

FL. DEPT. OF ENVIRONMENTAL REGULATION

-----  
KEN TUCKER

TEST OBSERVER