

STAPPA/ALAPCO

12/17/86

2.5

73 0082 <sup>2.2</sup>  
#6 <sup>4.0</sup>

## INCINERATOR COMPLIANCE TEST

at

THE WILLIMANTIC

SEWAGE TREATMENT PLANT

in

WILLIMANTIC, CONNECTICUT

for

MSI INDUSTRIES, INC.  
DENVER, COLORADO

Prepared By

YORK RESEARCH CORPORATION  
ONE RESEARCH DRIVE  
STAMFORD, CONNECTICUT 06906

TABLE OF CONTENTS

- I. ABSTRACT
- II. SUMMARY OF RESULTS
- III. GENERAL TEST METHODS
- IV. APPENDIX

- Particulate Calculations
- Particulate Field Data
- Gas Calculations
- Gas Field Data
- Intent to Test Acceptance Letter
- Equipment Calibration Data

**I. ABSTRACT**

On January 23rd and 24th, 1974, York Research, an independent consulting firm in the environmental field, began a series of emission sampling tests at the Willimantic Sewage Treatment Plant in Willimantic, Connecticut.

The purpose of these tests was to determine compliance with Connecticut State Regulations for particulate emissions from an incinerator.  $NO_x$ ,  $SO_x$ , hydrocarbons and CO were also tested per a State request.

The Connecticut State Regulations as specified in "Administrative Regulations", Department of Environmental Protection, Abatement of Air Pollution, May 23, 1972, Page 14B, Section 19-508-18 "Control of Particulate Emissions" subsection (C) (3) (i) "Emission Standards. Particulates" states:

No person shall construct, install, use or cause to be used any new (constructed or modified after June 1, 1972) incinerator which will result in particulate matter in the effluent in excess of 0.08 gr/SCF (0.18 gm/NM<sup>3</sup>) corrected to 12%  $CO_2$ , maximum 2 hour average. No person shall use or cause to be used any existing incinerator which will emit more than 0.4 lb. particulate/1000 lbs. of flue gases adjusted to 50% excess air.

The following Table gives the results of the scrubber outlet sampling in terms as used in the Connecticut State Regulations.

Particulate Test	gr/SCF (12% $CO_2$ )	lbs./1000 lbs. (Flue Gas @ 50% excess air)
1	.137	.155
2	.208	.198
3	.264	.252
Average	.203	.202
State Limitations	.08 gr/SCF (12% $CO_2$ )	.4 lbs/1000 lbs. (Flue Gas @ 50% Excess Air)

II. SUMMARY OF RESULTSPARTICULATE

Test	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
Date	1/23/74	1/24/74	1/24/74	-
Time	1450-1650	1137-1323	1520-1721	-
% Moisture (Gas)	11.10	11.12	11.31	11.18
% CO <sub>2</sub>	3.8	2.8	2.8	3.13
% O <sub>2</sub>	14.4	14.8	14.8	14.7
% CO	0.2	0.4	0.4	0.33
% N <sub>2</sub>	81.6	82.0	82.0	81.9
Stack Temp. (°F)	143	128	136	136
Stack Velocity (FPM)	2273	2150	2384	2269
Stack Volume (SCFMD)	5568	5473	5978	5673
gr/SCF	.0435	.0485	.0616	.0512
gr/ACF	.0339	.0393	.0491	.0408
Lb./Hr.	2.08	2.27	3.16	2.50
*gr/SCF @ 12% CO <sub>2</sub>	.137	.208	.264	.203
**Lb./1000 Lb. Flue Gas @ 50% ex.air	.155	.198	.262	.202
% Excess Air	203	247	247	232.3
***Feed Rate Tons/Hr.	1.93	1.82	3.10	2.28

\*The State limit for new incinerators is .08 gr/SCF @ 12% CO<sub>2</sub>

\*\*The State limit for existing incinerators is .40 Lb./1000 Lb. Flue Gas @ 50% Excess Air

\*\*\*These readings are questionable due to problems encountered with the scale.

Test	<u>OXIDES OF NITROGEN</u>			<u>OXIDES OF SULFUR</u>		
	<u>1a</u>	<u>1b</u>	<u>1c</u>	<u>2a</u>	<u>2b</u>	<u>2c</u>
Date	1/23/74	1/23/74	1/23/74	1/24/74	1/24/74	1/24/74
Time	1611	1645	1703	1149	1224	1257
*NO <sub>2</sub> (ppm)	51.5	13.3	30.5	27.2	33.5	46.5
Lb/Hr	2.05	.528	1.21	1.06	1.31	1.82

\*State Limit is 700 ppm NO<sub>2</sub>

Test	<u>HYDROCARBONS</u>			<u>OXIDES OF SULFUR</u>		
	<u>1</u>	<u>2a</u>	<u>2b</u>	<u>3a</u>	<u>3b</u>	<u>3c</u>
Date	1/23/74	1/24/74	1/24/74	1/24/74	1/24/74	1/24/74
Time	1502	1205	1300	1545	1607	1658
ppm*	10.3	3.9	32.7	2.0	1.1	1.2

\*No specific State Limit

\*Based on C<sub>6</sub> H<sub>14</sub>

Test	<u>OXIDES OF NITROGEN</u>			<u>OXIDES OF SULFUR</u>		
	<u>1a</u>	<u>1b</u>	<u>1c</u>	<u>2a</u>	<u>2b</u>	<u>2c</u>
Date	1/23/74	1/23/74	1/23/74	1/24/74	1/24/74	1/24/74
Time	1404-	1529-	1101-	1341-	1518-	1638-
	1425	1550	1130	1414	1551	1705
*SO <sub>2</sub> (ppm)	34.4	79.6	48.1	53.5	47.5	31.2
Lb/hr	1.90	4.41	2.62	2.91	2.83	1.86
SO <sub>3</sub> (ppm)	23.2	21.5	11.3	8.6	15.4	24.6
Lb/hr	1.60	1.49	.765	.581	1.14	1.82

\*The State limit is 500 ppm SO<sub>2</sub>

PROXIMATE  
SLUDGE ANALYSIS

Test	<u>1</u>	<u>1</u>	<u>2 &amp; 3</u>	<u>2 &amp; 3</u>
Drying Temperature	100°F	105°C	100°F	105°C
Date	1/23/74	1/23/74	1/24/74	1/24/74
Moisture (%)	79.72	80.66	81.51	83.41
Volatiles (%) @ 600°C	14.00	13.66	12.30	10.93
Ash (%)	5.12	4.62	5.06	4.60
Fe (%)	0.89	0.83	0.88	0.83
Ca (%)	0.27	0.23	0.25	0.23
BTU/Lb. (Dry)	8126	8058	7933	7675

ULTIMATE  
SLUDGE ANALYSIS

Test	<u>1</u>	<u>2-3</u>
% Carbon (Dry)	37.33	38.29
% Hydrogen (Dry)	5.57	5.36
% Nitrogen (Dry)	3.09	2.17
% Oxygen (Dry)	21.91	19.49
% Sulfur (Dry)	.717	.713
% Sulfur (As received)	.099	.107
% Combustibles (Dry)	68.61	61.63
% Combustibles (as received)	10.10	9.71
% Hexane Extraction (Dry)	87.59	87.79
% Hexane Extraction (As received)	12.12	13.71

ASH ANALYSIS

<u>Test</u>	<u>1-2-3</u>
Date	1-23, 24-74
Moisture (%)	0.07
Volatiles (%)	0.62

SCRUBBER WATER ANALYSIS

<u>Test</u>	<u>1-2-3</u>
Date	1-23, 24-74
pH	7.01
Suspended Solids	21.95 mg/liter

III. GENERAL TEST METHODS




DESCRIPTION OF OPERATIONS

The incinerator is a multiple-hearth furnace with six (6) hearths. The temperatures in the furnace are regulated by burners located on hearths 2, 4 and 6. The furnace is designed to burn 8000 lb./hr. of a mixture of primary and secondary sludge.

As the sludge is burned, a relatively large amount of gases are produced. What remains after combustion is a sterile ash which is transported to another location by some suitable means. Along with the combustion gases produced by the sludge and auxiliary fuel (if any) is particulate matter. This particulate matter is passed through a pre-cooling chamber and a scrubbing system which removes the dust particles.

The scrubber is an impingement type using 300 GPM total water for adequate scrubbing of gases. The scrubber has an outlet volume of 7160 ACFM (maximum) @ 120°F with a differential pressure of 6.5 W.C. at the designed scrubber outlet volume with a design outlet dust loading of approximately .03 gr./ standard dry cubic foot exhaust gas.


The exhaust gases are moved through the entire system by an induced draft fan located between the scrubber outlet and the stack, and designed to move 8000 CFM at 120°F (See Figure #1).



## LEGEND

- SLUDGE
- ASH
- FLUE GASES
- SCRUBBED GASES
- COOLING-AIR


FIGURE 1



SAMPLING LOCATIONS - PORTS

Particulate sampling ports at the outlet were located in accordance with EPA guidelines. The sampling ports were located so that the distance to nearest interferences upstream (6 duct diameters) and downstream (1.5 diameters) were far enough away as not to cause any undue turbulence in the gas flow (Figure #2).

FIGURE #2



SAMPLING LOCATION - TEST POINTS

The round 23 1/2" ID outlet stack had two ports at right angles (90°) for twenty test points (ten at each traverse).

The test points were sampled for five minutes each. The location of each test point was determined from EPA specifications (Figure #3).




FIGURE #3  
OUTLET  
SAMPLING POINT LOCATIONS


### III. GENERAL TEST METHODS

#### Particulate Sampling Train - EPA Method 5

The sampling apparatus consisted of a five (5) foot probe, cyclone bypass, filter, four impingers, dry gas meter, vacuum pump and flow meter (See Figure 4). The stainless steel, button-hook type probe tip (1) was connected by a stainless steel coupling (2) with asbestos packing to the probe. The probe (3) consisted of 5/8 inch outside diameter medium wall Pyrex glass tube with a ground balljoint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 300°F in the probe. The wire wound tube was wrapped with fiberglass tape and encased in a 1-inch-OD stainless steel casing for protection. The end of the steel probe casing does not have the balljoint protruding but has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a cyclone bypass (4). The cyclone bypass connects to a very coarse fritted glass filter holder (5), which holds a tared glass fiber filter. The cyclone, flask, and filter were contained in an electrically heated enclosed box (6) which is thermostatically maintained at a minimum temperature of 300°F to prevent water condensation. Attached to the heated box was an ice bath (7) containing four impingers connected in series with glass balljoints. The first impinger (8) receives the gas stream from the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a 1/2 inch ID glass tube extending to 0.5 inches from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is of the Greenburg-Smith design and like the first was initially filled with 100 milliliters of distilled water. The third impinger (10), which was left dry, is a Greenburg-Smith impinger modified like the first. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained dry silica gel.

From the fourth impinger (11) the effluent stream flows through a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a needle valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous flow rates. The three thermometers (12) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from 1 to 10 inches.

## PARTICULATE SAMPLING TRAIN



## FIGURE #4

Readings Taken

During each run the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head ( $\Delta P$  in inches water)
5. Desired pressure drop across orifice ( $\Delta H$  in inches of water)
6. Actual pressure drop across orifice ( $\Delta H$  in inches of water)
7. Dry gas temperature ( $^{\circ}$ F) gas meter inlet
8. Dry gas temperature ( $^{\circ}$ F) gas meter outlet
9. Vacuum pump gauge reading (in. Hg)
10. Filter box temperature ( $^{\circ}$ F)
11. Dry gas temperature ( $^{\circ}$ F) at the discharge of last impinger
12. Stack temperature ( $^{\circ}$ F)
13. Stack pressure (inches water)

The relationship of  $\Delta P$  reading with the  $\Delta H$  reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between  $\Delta P$  and  $\Delta H$  could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

ANALYTICAL PROCEDURE - PARTICULATES

The filter discs were previously tare-weighed and the weights recorded at York Research's Laboratory. Upon return they were dried, cooled in a dessicator, then weighed on an analytical balance. The amount of particulate collected is the difference in the weights. The probe and nozzle water and acetone wash solutions are placed into respective tared beakers, evaporated with an infra-red lamp and the beakers weighed again. The difference in the weights is the weight of the particulate in the washes. These are combined with the filter catch as the total weight of the sample.



### PARTICULATE CALCULATIONS

The following are the basic equations used in calculating final data as found in the final summary.

1. Volume of dry gas sampled at standard conditions - 70°F, 29.92" Hg, ft.<sup>3</sup>

$$V_{m_{std}} = \frac{17.7 \times V_m \left( \frac{P_b + P_m}{13.6} \right)}{(T_m + 460)} \text{ ft.}^3$$

2. Volume of water vapor at 70°F and 29.92" Hg, Ft.<sup>3</sup>

$$V_{w_{gas}} = 0.0474 \times V_w = \text{Ft.}^3$$

3. % Moisture in stack gas

$$\%M = \frac{100 \times V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}} = \%$$

4. Mole fraction of dry gas

$$M_d = \frac{100 - \%M}{100}$$

5. Average molecular weight of dry stack gas

$$M\ W_d = (\%CO_2 \times \frac{44}{100}) + (\%O_2 \times \frac{32}{100}) + (\%N_2 \times \frac{28}{100})$$

6. Molecular weight of stack gas

$$M\ W = M\ W_d \times M_d + 18 (1 - M_d)$$



## 7. Stack velocity at stack conditions, fpm

$$V_s = 4350 \times \sqrt{\Delta P_s \times (T_s + 460)} \left( \frac{1}{P_s \times M_w} \right)^{1/2} = \text{fpm}$$

## 8. Stack gas volume at standard conditions, SCFM

$$Q_s = \frac{0.123 \times V_s \times A_s \times M_d \times P_s}{(T_s + 460)} = \text{SCFM}$$

## 9. Percent isokinetic

$$\%I = \frac{1032 \times (T_s + 460) \times V_{m \text{ std}}}{V_s \times T_t \times P_s \times M_d \times (D_n)^2} = \%$$

## 10. Particulate - probe, cyclone and filter, gr/SCF

$$C_{an} = 0.0154 \times \frac{M_f}{V_{m \text{ std}}} = \text{gr/SCF}$$

## 11. Particulate total, gr/SCF

$$C_{ao} = 0.0154 \times \frac{M_t}{V_{m \text{ std}}} = \text{gr/SCF}$$

## 12. Particulate - probe, cyclone and filter, gr/CF at stack conditions

$$C_{at} = \frac{17.7 \times C_{an} \times P_s \times M_d}{(T_s + 460)} = \text{gr/CF}$$

## 13. Particulate - total, gr/CF at stack conditions

$$C_{au} = \frac{17.7 \times C_{ao} \times P_s \times M_d}{(T_s + 460)} = \text{gr/CF}$$



14. Particulate - probe, cyclone and filter, lb/hr.

$$C_{aw} = 0.00857 \times C_{an} \times Q_s = \text{lb/hr.}$$

15. Particulate - total, lb/hr.

$$C_{ax} = 0.00857 \times C_{ao} \times Q_s = \text{lb/hr.}$$

16. % Excess air at sampling point

$$\% EA = \frac{(\% O_2) - 0.5 (\% CO)}{0.264 (\% N_2) - (\% O_2) + 0.5 (\% CO)} \times 100$$

17. PARTICULATE EMISSIONS IN GRAINS PER STANDARD CUBIC FOOT DRY ADJUSTED TO 12% CO<sub>2</sub>

$$GR/SCFD @ 12\% CO_2 = C_{an} \times \frac{12.0}{\text{measured \% CO}_2}$$

18. PARTICULATE EMISSIONS IN POUNDS EMISSION PER 1000 POUNDS OF FLUE GAS ADJUSTED TO 50% EXCESS AIR

$$LB/1000 @ 50\% E.A. = 1000 \times \frac{C_{aw}}{60} \times \frac{100 + \% EA}{150} \times \frac{387}{mw} \times \frac{M_d}{Q_s}$$

VELOCITY DETERMINATION

To determine the gas velocity an "S" type pitot tube, manometer, thermocouple, and a pyrometer were employed (See Figure #5).

The probe tip was placed at each point shown in Figure #3 and the " $\Delta P$ " (differential pressure), across the front and back face of the pitot tube, is indicated by the manometer in inches of  $H_2O$ .

The probe is turned at right angles to the gas flow and one connection to the manometer is opened to atmospheric pressure. The reading in inches of water ( $H_2O$ ) is noted as the static pressure and recorded on the Data Sheet.

The thermocouple junction reacts to the surrounding temperature by producing a voltage differential. This voltage is read out directly by a potentiometer in degrees fahrenheit ( $^{\circ}F$ ).

## VELOCITY DETERMINATION




FIGURE #5

HYDROCARBON SAMPLING

The hydrocarbon sampling train consists of (1) a heated glass probe, (2) a 3 inch coupling, (3) an aluminum box, (4) three 250 Ml hydrocarbon sampling flasks. The flasks are connected to a manifold with 12/5 ball and socket joints, (5) two 350 watt strip heaters (one on the bottom of the box, the other inside the top cover), (6) a thermometer, (7) the exhaust from the box to the pump inlet. (See Figure #6.)

A sample is drawn through one flask at a time, for a minute or two. The valve on the pump end of the flask is closed first, then the valve on the probe end.

HYDROCARBONS ANALYSIS

The method used to measure the hydrocarbon sample is with a Perkin-Elmer 881 gas chromatograph with flame ionization detectors. A 1/8" blank stainless steel column at 200°C with a Perkin-Elmer lcc gas sampling loop is used to inject the sample into the detector.

The samples are heated and displaced from the flask with mercury. Standards are made up from calibrated gases using a ppm Hexane in N<sub>2</sub> standards.

HYDROCARBON SAMPLING  
FIGURE # 6

1. HEATED GLASS PROBE

2. 3 INCH COUPLING


3. ALUMINUM BOX

4. 250ML FLASKS

5. 350WATT HEATER

6. THERMOMETER

7. EXHAUST LINE



OXIDES OF NITROGEN SAMPLING (EPA Method No. 7)

A grab sample is collected in an evacuated flask containing a dilute sulfuric acid - hydrogen peroxide absorbing solution.

The sampling procedure consists of pipetting 25 ml of  $H_2SO_4$  -  $H_2O_2$  absorbing solution into a 2 liter sampling flask. The flask is then evacuated to at least 3 in. Hg. absolute pressure. The next step is to evacuate the probe prior to sampling. The sample is then taken over a period of 15 seconds. After the sample has been collected, the flask is shaken for approximately 5 minutes. After this period the flask must be left with the sample for a minimum of 16 hours. After the 16 hours, the flask is reshaken for a period of two minutes. After this the final pressure of the flask is recorded and the sample is transferred to the lab for analysis. The sampling apparatus used to collect oxide of nitrogen samples is shown in Figure #7.)


NO<sub>2</sub> ANALYSIS

The amount of nitrogen dioxide in the sample is determined by the phenoldisulphonic method. This method is as follows:

The sample is placed in a beaker and NaOH is slowly added until the solution is neutral or slightly basic by Litmus paper indication. This solution is then evaporated in the beaker used for neutralization. To the dry residue, two (2) milliliters of phenoldisulphonic acid are added and mixed to dampen all the precipitate. Then add two (2) milliliters of distilled water and mix thoroughly; add twenty (20) more milliliters of distilled water and mix. Add concentrated  $NH_4OH$  to this solution in excess of neutralization. Filter solution if necessary and transfer to a volumetric flask. Using a spectrophotometer at 420 Mu, compare results with a standard curve based on standard concentrations, and read milligrams of nitrogen in the sample.

**NO<sub>x</sub> SAMPLING TRAIN**

FIGURE 2.7.



OXIDES OF SULFUR SAMPLING (EPA Method No. 6)

The sulfur oxides sampling train consists of the following components arranged and illustrated schematically (See Figure #8): (1) glass wool filter, (2) an electrically heated glass probe, (3) variac, (4,5,6,7) four midget impingers, (8) ice bath, (9) drying tube containing silica gel, (10) vacuum gauge, (11) control valve, (12) vacuum pump, (13) dry gas meter, and (14) thermometer.

The probe is made of an 18" length of medium wall Pyrex tubing wound with 26 gauge nichrome heating wire. The front end of the probe includes a two-inch long area for insertion of glass wool to be used as a filtering device. The wire is connected to a variable transformer which allows the voltage and hence the heat input to be controlled. The wire is covered with a fiberglass insulation tape.

The probe connects to a coarse frit midget bubbler containing 15 ml of 80% isopropanol, and three midget impingers, the first two of which contained 15 ml of 3%  $H_2O_2$  each with the third left dry, connected in series. The chamber near the bubbler outlet is stuffed with fine glass wool. An ice bath is provided for the bubbler and impingers. Attached to the outlet of the third impinger is a drying tube filled with silica gel of the indicator type. A bypass valve is provided for the leakless pump and a vacuum gauge and needle valve were installed at the inlet of the pump. The dry gas meter has a sensitivity of 0.001 cubic foot and is fitted with thermometers on the meter inlet and outlet.

SO<sub>2</sub>, SO<sub>3</sub> ANALYSIS

The amount of sulfur dioxide and sulfur trioxide are measured as follows:

Dilute solution used for sampling to 50 ml. Pipette 10 ml. of this solution into a 125 ml. Erlenmeyer flask. Add 40 ml. of isopropanol and two to four drops of thorin indicator. Titrate to a pink endpoint using 0.01 N barium perchlorate. Run a blank with each series of samples.


SO<sub>x</sub> SAMPLING TRAIN

FIGURE #8

GASEOUS EMISSIONS CALCULATIONSGENERAL EQUATIONSA. Parts Per Million (ppm) by Volume Dry:

$$\text{ppm} = \frac{(48.15) (\text{mg}_{\text{comp}}) (T_m + 460)}{(\text{MW}) (V_m) (P_m)}$$

$$\text{ppm @ } X \% \text{ EA} = \text{ppm measured} \times \frac{(\text{Total Air @ meas'd. EA})}{(\text{Total Air @ } X \% \text{ EA})}$$

Where: Total Air = 100 + EA (For O<sub>2</sub>, equivalent Excess Air Used)

B. Pounds Per Hour (Lb./Hr.):

$$\text{Lb./Hr.} = \frac{(7.467 \times 10^{-6}) (\text{mg}_{\text{comp}}) (Q_s) (T_m + 460)}{(V_m) (P_m)}$$

Where: mg<sub>comp</sub> = weight of component sampled (mg)

T<sub>m</sub> = Temperature of Meter (°F)

MW = Molecular weight of Component

V<sub>m</sub> = Metered gas volume (ACF)

P<sub>m</sub> = Meter pressure (in. Hg absolute)

Q<sub>s</sub> = Stack gas flow (SCFMD)

SPECIFIC EQUATIONSSO<sub>2</sub>, Sulfur Dioxide (MW=64.1)

$$\text{ppm} = \frac{(.7512) (\text{mg SO}_2) (T_m + 460)}{(P_m) (V_m)}$$

F<sup>-</sup>, Fluoride (MW=19.0)

$$\text{ppm} = \frac{(2.534) (\text{mg F}^-) (T_m + 460)}{(P_m) (V_m)}$$

SO<sub>3</sub>, Sulfur Trioxide (MW=80.1)

$$\text{ppm} = \frac{(.6011) (\text{mg SO}_3) (T_m + 460)}{(P_m) (V_m)}$$

Cl<sup>-</sup>, Chloride (MW=35.5)

$$\text{ppm} = \frac{(1.356) (\text{mg Cl}^-) (T_m + 460)}{(P_m) (V_m)}$$

Hg, Mercury (MW=200.6)

$$\text{ppm} = \frac{(.2400) (\text{mg Hg}) (T_m + 460)}{(P_m) (V_m)}$$

HCl, Hydrogen Chloride (MW=36.5)

$$\text{ppm} = \frac{(1.319) (\text{mg HCl}) (T_m + 460)}{(P_m) (V_m)}$$

NO<sub>x</sub>, Oxides of Nitrogen as NO<sub>2</sub> (MW=46.0)

$$\text{ppm} = \frac{(1.047) (\text{mg NO}_2) (T_F + 460)}{(P_i - P_f) (V_F, CF)}$$

F denotes Flask  
i denotes initial  
f denotes final  
V<sub>F</sub>, CF = liters/28.32

ES 056-1/74



### CO<sub>2</sub>, O<sub>2</sub> and CO SAMPLING AND ANALYSIS

Samples were collected by traverse through a sampling tube attached to the particulate sampling probe and aspirated into leveling bottles as illustrated in Figure #9. The gas collected was immediately tested with an Orsat apparatus for CO<sub>2</sub>, O<sub>2</sub> and CO concentration.

STACK




FLUE GAS COLLECTION BY  
LEVELING BOTTLEORSAT SAMPLE ANALYSIS

FIGURE # 9

TEST TEAM


Robert S. Epstein  
Raymond Bennetts  
John J. Jasko  
Karl Boldt  
James Federici

Prepared By:




John J. Jasko  
Test Engineer

Reviewed By:



Robert S. Epstein  
Project Director

Approved By:



Roy S. Agdall  
Engineering Manager-Field Operations

IV. APPENDIX



## SOURCE TESTING CALCULATION FORMS

Test No. Y-8300WNo. Runs 3Name of Firm MSILocation of Plant WILLIMANTIC, CTType of Plant SLUDGE INCINERATORControl Equipment SCRUBBERSampling Point Locations OUTLETPollutants Sampled PARTICULATE

## Time of Particulate Test:

Run No. <u>1</u>	Date <u>1/23/74</u>	Begin <u>1450</u>	End <u>1650</u>
Run No. <u>2</u>	Date <u>1/24/74</u>	Begin <u>1137</u>	End <u>1323</u>
Run No. <u>3</u>	Date <u>1/24/74</u>	Begin <u>1420</u>	End <u>1721</u>

PARTICULATE EMISSION DATA

Run No.	1	2	3
Pb barometric pressure, "Hg Absolute	29.87	30.27	30.28
Pm orifice pressure drop, "H <sub>2</sub> O	1.20	2.77	3.27
Vm volume of dry gas sampled @ meter conditions, ft. <sup>3</sup>	61.221	62.626	45.341
Tm Average Gas Meter Temperature, °F	70.5	70.1	70.7
V <sub>m</sub> Volume of Dry Gas Sampled @ Standard std. conditions, ft. <sup>3</sup>	51.123	90.087	47.01
V <sub>w</sub> Total H <sub>2</sub> O collected, ml., Impingers & Silica Gel.	161.2	237.7	261.2
V <sub>w</sub> Volume of Water Vapor Collected gas ft. <sup>3</sup> @ Standard Conditions*	11.64	11.27	12.33

\* 70°F, 29.92" Hg.



## PARTICULATE EMISSION DATA (cont'd)

Run No.	1	2	3
%M - % Moisture in the stack gas by volume	11.1	11.12	11.31
M <sub>d</sub> - Mole fraction of dry gas	.889	.889	.887
% CO <sub>2</sub>	3.8	2.8	2.8
% O <sub>2</sub>	14.4	14.8	14.8
CO	.2	.4	..
% N <sub>2</sub>	81.6	82.0	82.0
M W <sub>d</sub> - Molecular weight of dry stack gas	29.18	29.04	29.04
M W - Molecular weight of stack gas	27.94	27.82	27.79
Δ P <sub>s</sub> - Velocity Head of stack gas, in. H <sub>2</sub> O	—	—	—
T <sub>s</sub> - Stack Temperature, °F	125	280	255
√Δ P <sub>s</sub> X(T <sub>s</sub> +460)	5.11	4.58	5.2
P <sub>s</sub> - Stack Pressure, "Hg. Absolute	14.6	10.6	11.1
V <sub>s</sub> - Stack Velocity @ stack conditions, fpm	2273	2150	2224
A <sub>s</sub> - Stack Area, in. <sup>2</sup>	452.4	452.4	452.4
Q <sub>s</sub> - Stack Gas Volume @ Standard Conditions, *SCFM	5568	5473	5478
T <sub>t</sub> - Net Time of Test, min.	100	100	100
D <sub>n</sub> - Sampling Nozzle Diameter, in.	.250	.3125	.3125
%I - Percent isokinetic	100.9	96.8	95
m <sub>f</sub> - Particulate - probe, cyclone and filter, mg.	172.8	284.0	305.2
m <sub>t</sub> - Particulate - total, mg.	—	—	—
C <sub>an</sub> - Particulate - probe, cyclone, and filter, gr/SCF	.0435	.0485	.0616
C <sub>ao</sub> - Particulate - total, gr/SCF	—	—	—
C <sub>at</sub> - Particulate - probe, cyclone, and filter gr/cf @ stack conditions	.0337	.0293	.0461

## PARTICULATE EMISSION DATA (cont'd)

Run No.	1	2	3	
C <sub>au</sub> - Particulate, total, gr/cf @ stack cond.	—	—	—	
C <sub>aw</sub> - Particulate, probe, cyclone, and filter, lb/hr.	2.08	2.27	3.16	
C <sub>ax</sub> - Particulate - total, lb/hr.	—	—	—	
%EA - % Excess air @ sampling point	203	247	247	

\* 70°F. 29.92" Hg.

STATE  
LIMITgr/SCF @ 12% CO<sub>2</sub> .137 .208 .264 .08100% FLUE GAS .155 .198 .252 .40  
(50% Excess air)FEED RATE  
Tons/hr. .175 1.82 3.10

Y-8300 W

## FIELD DATA



PLANT MSI  
 DATE 1/23/74  
 SAMPLING LOCATION SCRUBBER OUTLET  
 SAMPLE TYPE PART  
 RUN NUMBER 1  
 OPERATOR RSE JJ  
 AMBIENT TEMPERATURE 50  
 BAROMETRIC PRESSURE 29.81  
 STATIC PRESSURE, (P<sub>3</sub>) -2.20  
 FILTER NUMBER (S) FL 521

H<sub>2</sub>O FINAL 344  
INITIAL 200  
144  
S/L/17.2 GEL 17.2  
161.2

SCHEMATIC OF TRAVERSE POINT LAYOUT

READ AND RECORD ALL DATA EVERY 5 MINUTES

PROBE LENGTH AND TYPE 5' GLASS  
 NOZZLE I.D. 1/4" .250  
 ASSUMED MOISTURE, % 15  
 SAMPLE BOX NUMBER A  
 METER BOX NUMBER C-102  
 METER ΔH<sub>0</sub> 1.81  
 C FACTOR .86  
 PROBE HEATER SETTING 250-300  
 HEATER BOX SETTING 250-300  
 REFERENCE ΔP -60

TRAVERSE POINT NUMBER	CLOCK TIME (24-HR CLOCK)	GAS METER READING (Nm <sup>3</sup> , ft <sup>3</sup> )	VELOCITY HEAD (ΔP <sub>3</sub> ), in. H <sub>2</sub> O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H <sub>2</sub> O	STACK TEMPERATURE (T <sub>s</sub> ), °F		DRY GAS METER TEMPERATURE (T <sub>m</sub> in), °F	INLET OUTLET (T <sub>m</sub> out), °F	PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
					DESIRED	ACTUAL					
START C	1450	791.650									
1 5	1453	790.89	.43	1.35	140	63	63	<2	275	70	
2 0	1500	794.13	.43	1.35	140	67	63				
3 5	1505	797.37	.45	1.40	140	70	64				
4 0	1510	800.66	.45	1.40	140	72	65				
5 5	1515	803.96	.46	1.45	140	72	67				
6 0	1520	807.22	.44	1.35	140	76	67				
7 5	1525	810.56	.34	1.25	140	75	67				
8 0	1530	813.67	.35	1.10	140	75	67				
9 5	1535	816.60	.33	1.05	145	78	68				
10 0	1540	819.753	.32	1.00	143	78	68				
SINKT 50	1600	819.153	—	—	—	—	—	—	—	—	
B1 55	1605	822.24	.50	1.55	145	72	70	<2	275	70	
2 60	1610	825.71	.47	1.45	145	82	72				
3 65	1615	829.07	.31	1.25	140	82	72				
4 70	1620	832.18	.37	1.15	140	85	74				
5 75	1625	835.17	.39	1.10	145	87	76				
6 80	1630	838.10	.33	1.05	145	87	77				
7 85	1635	840.55	.29	.78	145	87	77				
8 90	1640	843.54	.37	1.15	145	89	79				
9 95	1645	846.29	.31	.97	145	92	79				
10 0	1650	846.62	.27	.85	145	92	79				

COMMENTS:

## FIELD DATA



PLANT MST - WILLIAMS  
 DATE 1-24-74  
 SAMPLING LOCATION DUST EMISSION  
 SAMPLE TYPE EPA - 4" DUST  
 RUN NUMBER 2  
 OPERATOR JJ  
 AMBIENT TEMPERATURE 40  
 BAROMETRIC PRESSURE  
 STATIC PRESSURE, (P<sub>s</sub>) 2.0  
 FILTER NUMBER (S) F.L. 40%

### PROBE LENGTH AND TYPE 5' GLASS

NOZZLE I.D. .3125  
 ASSUMED MOISTURE, % 12.0  
 SAMPLE BOX NUMBER 6-1022  
 METER BOX NUMBER 6-1022  
 METER ΔH@ 1.81  
 C FACTOR .87  
 PROBE HEATER SETTING 250-300  
 HEATER BOX SETTING 250-300  
 REFERENCE AP 2.4

327  
 100  
 100  
 100  
 100

SCHEMATIC OF TRAVERSE POINT LAYOUT  
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER (Sink)	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V <sub>m</sub> ), ft <sup>3</sup>	VELOCITY HEAD (ΔP <sub>s</sub> ), in. H <sub>2</sub> O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H <sub>2</sub> O		DESIRABLE STACK TEMPERATURE (T <sub>s</sub> ), °F	ACTUAL STACK TEMPERATURE (T <sub>s</sub> ), °F	DRY GAS METER TEMPERATURE (T <sub>m in</sub> ), °F	OUTLET (T <sub>m out</sub> ), °F	PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL							
A 1	3 1142	864.81	.43	3.20	3.20	52	50	52	50	3.0	300	470
2	12 1147	864.51	.41	3.15	3.15	125	125	68	53	3	3	3
3	13 1152	864.32	.45	3.45	3.45	110	110	70	54	3	3	3
4	14 1157	864.31	.44	3.40	3.40	100	100	73	54	3	3	3
5	25 1202	864.11	.43	3.17	3.17	100	100	75	56	3	3	3
6	30 1207	864.02	.41	3.15	3.15	100	100	77	57	3	3	3
7	35 1212	863.66	.39	3.00	3.00	115	115	86	60	3	3	3
8	40 1217	863.17	.35	2.70	2.70	115	115	82	61	3	3	3
9	45 1222	862.64	.31	2.10	2.10	110	110	85	63	3	3	3
10	50 1227	862.18	.28	2.10	2.10	110	110	83	63	3	3	3
11	55 1232	862.18										
12	55 1236	862.18	.41	3.15	3.15	125	125	75	64	4	4	4
13	60 1243	862.17	.43	3.10	3.10	135	135	77	64	4	4	4
14	65 1248	861.40	.35	2.10	2.10	145	145	85	64	4	4	4
15	70 1253	861.11	.33	2.00	2.00	145	145	85	64	4	4	4
16	75 1258	861.13	.34	2.10	2.10	145	145	84	65	4	4	4
17	80 1303	861.26	.29	2.10	2.10	145	145	85	67	4	4	4
18	85 1308	861.51	.35	2.10	2.10	140	140	85	67	4	4	4
19	90 1313	861.65	.33	2.10	2.10	130	130	85	67	4	4	4
20	95 1318	861.85	.31	2.10	2.10	135	135	85	67	4	4	4
21	100 1323	862.04	.28	2.10	2.10	130	130	83	68	4	4	4

COMMENTS:

Y - 8300 W

FIELD DATA



PLANT MSI  
 DATE 1/23/74  
 SAMPLING LOCATION SCF UBBER OUTLET  
 SAMPLE TYPE PART  
 RUN NUMBER 3  
 OPERATOR RSC JJ  
 AMBIENT TEMPERATURE 40  
 BAROMETRIC PRESSURE 30.28  
 STATIC PRESSURE, (P<sub>s</sub>) .20  
 FILTER NUMBER (s) EL734, FL649

PROBE LENGTH AND TYPE 5' GLASS  
 NOZZLE I.D. .516"  
 ASSUMED MOISTURE, % 12  
 SAMPLE BOX NUMBER A  
 METER BOX NUMBER 6-102  
 METER ΔH .81  
 C FACTOR .89  
 PROBE HEATER SETTING 250-300  
 HEATER BOX SETTING 250-300  
 REFERENCE AP .24

SCHEMATIC OF TRAVERSE POINT LAYOUT

READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24-hr CLOCK)	GAS METER READING (V <sub>m</sub> ), ft <sup>3</sup>	VELOCITY HEAD (ΔP <sub>s</sub> ), in. H <sub>2</sub> O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H <sub>2</sub> O		DESIRED	ACTUAL	STACK TEMPERATURE (T <sub>s</sub> ), °F	DRY GAS METER TEMPERATURE (T <sub>m</sub> in), °F	PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL							
START	0	1520	943.987									
B1	5	1525	948.86	.45	3.90	3.20	140	44	44	19	275	70
2	10	1530	952.73	.45	3.40	3.00	145	62	48	19		
3	15	1535	951.88	.45	3.10	2.50	145	65	48	19		
4	20	1550-1555	961.97	.42	3.20	3.20	140	68	52	7		
5	25	1600	965.68	.38	2.85	2.85	140	72	54	6		
6	30	1605	969.30	.38	2.85	2.85	135	78	59	6		
7	35	1610	973.89	.35	2.65	2.65	130	82	59	6		
8	40	1615	977.60	.35	2.65	2.65	130	84	61	6		
9	45	1620	982.00	.33	2.50	2.50	130	85	63	6		
10	50	1625	986.266	.30	2.15	2.15	130	85	63	5		
START	50	1631	986.266	-	-	-	-	-	-	-		
A1	55	1636	991.88	.50	3.75	3.75	135	72	63	8		
2	60	1641	997.41	.50	3.75	3.75	135	75	63	8		
3	65	1646	1003.20	.55	4.15	4.15	135	86	63	12		
4	70	1651	1009.00	.55	4.15	4.15	135	90	65	12		
5	75	1656	1014.95	.52	3.85	3.85	135	94	68	12		
6	80	1701	1019.77	.49	3.65	3.65	135	95	69	12		
7	85	1706	1024.16	.49	3.65	3.65	140	95	67	12		
8	90	1711	1029.50	.48	3.60	3.60	140	95	67	14		
9	95	1716	1034.60	.45	3.40	3.40	135	95	67	15		
10	100	1721	1039.378	.43	3.25	3.25	135	95	67	18		

COMMENTS:

CO = 0.4%

CO<sub>2</sub> = 2.8%  
 O<sub>2</sub> = 14.8%

SO<sub>2</sub>, SO<sub>3</sub> EMISSION DATAClient M.S.I. Industries Inc.Plant Location Willimantic, Conn.Unit Tested Sewage Sludge Incinerator

Load \_\_\_\_\_

Run Number	1A	1B	2A	2b	3A	3b
Date	1/23	1/23	1/24	1/24	1/24	1/24
mg SO <sub>2</sub> Collected	5.13	10.90	6.57	7.21	5.93	4.17
ppm SO <sub>2</sub> by Volume Dry	34.4	79.6	48.1	53.5	47.5	31.2
Stack Flow (SCFMD)	5568	5568	5473	5473	5978	5978
Lb./Hr. SO <sub>2</sub>	1.90	4.41	2.62	2.91	2.83	1.86
MMBTU/Hr. Heat Input	-	-	-	-	-	-
Lb./MMBTU SO <sub>2</sub>	-	-	-	-	-	-
% O <sub>2</sub>	-	-	-	-	-	-
ppm SO <sub>2</sub> @ % O <sub>2</sub>	-	-	-	-	-	-
% Excess Air	-	-	-	-	-	-
ppm SO <sub>2</sub> @ % Excess Air	-	-	-	-	-	-
mg SO <sub>3</sub> Collected	4.32	3.68	1.92	1.44	2.40	4.10
ppm SO <sub>3</sub> by Volume Dry	23.2	21.5	11.25	8.55	15.4	24.6
Lb./Hr. SO <sub>3</sub>	1.60	1.49	.765	.581	1.14	1.82
Lb./MMBTU SO <sub>3</sub>	-	-	-	-	-	-
ppm SO <sub>3</sub> @ % O <sub>2</sub>	-	-	-	-	-	-
ppm SO <sub>3</sub> @ % Excess Air	-	-	-	-	-	-

OXIDES OF NITROGEN EMISSIONSClient M.S.I. Industries Inc.Plant Location Willimantic, Conn.Unit Tested Sewage Sludge IncineratorLoad —

Run Number	1A	1B	1C	2A	2B	2C
Date	1/23	1/23	1/23	1/24	1/24	1/24
Mg. NO <sub>2</sub> Collected	.159	.046	.106	.091	.106	.136
PPM as NO <sub>2</sub> by Volume Dry	51.5	13.3	30.5	22.2	33.5	46.5
Stack Flow (SCFMD)	5568	5568	5568	5473	5473	5473
Lb/Hr. as NO <sub>2</sub>	—	—	—	—	—	—
MMBTU/Hr. Heat Input	—	—	—	—	—	—
Lb/MMBTU as NO <sub>2</sub>	—	—	—	—	—	—
% O <sub>2</sub>	—	—	—	—	—	—
PPM as NO <sub>2</sub> @ %O <sub>2</sub>	—	—	—	—	—	—
% Excess Air	—	—	—	—	—	—
PPM as NO <sub>2</sub> @ % Excess Air	—	—	—	—	—	—

OXIDES OF NITROGEN EMISSIONSClient MSI INDUSTRIES INCPlant Location WILLIMANTIC, CONN.Unit Tested SEWAGE SLUDGE INCINERATORLoad —

Run Number	3a	3b	3c			
Date	1/24	1/24	1/24			
Mg. NO <sub>2</sub> Collected	.121	.095	.114			
PPM as NO <sub>2</sub> by Volume Dry	35.6	26.2	40.0			
Stack Flow (SCFMD)	5978	5978	5978			
Lb/Hr. as NO <sub>2</sub>	1.52	1.12	1.71			
MMBTU/Hr. Heat Input	—	—	—			
Lb/MMBTU as NO <sub>2</sub>	—	—	—			
% O <sub>2</sub>	—	—	—			
PPM as NO <sub>2</sub> @ %O <sub>2</sub>	—	—	—			
% Excess Air	—	—	—			
PPM as NO <sub>2</sub> @ % Excess Air	—	—	—			

HYDROCARBON EMISSION DATA

Job No. Y-8300W  
Date 1-23-74 (Test 1a), 1-24-74 (Test 2a-3c)  
Plant WILLIMANTIC STP Location OUTLET  
Ambient Temp. 50  
Operator J.F.

Test No.	Time	Flask Temp.	CONCENTRATION
1a	1502	300	10.29 ppm
2a	1205	300	3.94
2b	1300	300	32.7
3a	1545	300	2.0
3b	1607	300	4.1
3c	1658	300	1.2

OXIDES OF NITROGEN FIELD DATA

Job No. Y-8300W

Client MSI INDUSTRIES

Plant Location WILLIMANTIC, CT, USA

Unit No. SCRUBBER

Sampling Location OUTLET

Operator KC

Run Number	1a	1b	1c	2a	2b	2c
Date	1/23	1/23	1/22	1/24	1/24	1/22
Flask Number	7	5	1	18	10	4
Flask Volume Corrected(liters) (V <sub>f</sub> )	2.042	2.041	2.037	2.045	2.040	2.032
Initial Flask Vacuum(in.Hg) (P <sub>i</sub> )	27.0	27.0	27.0	27.3	27.3	27.1
Final Flask Vacuum(in.Hg) (P <sub>f</sub> )	3.7	2.2	0.7	2.7	4.3	5.2
Flask Temperature (T <sub>f</sub> )	60	60	60	44	44	44
% O <sub>2</sub>	14.4	14.4	14.4	14.8	14.8	14.8

OXIDES OF NITROGEN FIELD DATA

Job No. Y-8300W

Client MEI INDUSTRIES

Plant Location WILLIMANTIC CONN.

Unit No. SCRUBBER

Sampling Location CUTLET

Operator KE

<u>Run Number</u>	<u>3a</u>	<u>2b</u>	<u>3c</u>			
<u>Date</u>	<u>1/24</u>	<u>1/24</u>	<u>1/24</u>			
<u>Flask Number</u>	<u>7</u>	<u>1</u>	<u>5</u>			
<u>Flask Volume Corrected(liters) (V<sub>f</sub>)</u>	<u>20.0</u>	<u>20.0</u>	<u>20.0</u>			
<u>Initial Flask Vacuum(in.Hg) (P<sub>i</sub>)</u>	<u>27.2</u>	<u>27.2</u>	<u>27.2</u>			
<u>Final Flask Vacuum(in.Hg) (P<sub>f</sub>)</u>	<u>21.5</u>	<u>21.8</u>	<u>21.5</u>			
<u>Flask Temperature (T<sub>f</sub>)</u>	<u>+1</u>	<u>+1</u>	<u>+1</u>			
<u>% O<sub>2</sub></u>	<u>14.8</u>	<u>14.8</u>	<u>14.8</u>			

GAS SAMPLING FIELD DATA

JOB NO. 4-8300W

Material Sampled for SO<sub>x</sub>

Date 1-23-74

Plant WILLIMANTIC Location OUTLET

Bar. Pressure 29.87 "Hg Comments:

Ambient Temp. 60

Run No. 1A

Power Stat Setting 80%

Filter Used: Yes    No X

Operator KB

CLOCK TIME	METER (Ft <sup>3</sup> )	FLOW METER SETTING (CFM)	METER TEMPERATURE TM
1404	421.260	.1	60
1410	421.810	.1	60
1415	482.220	.1	60
1420	432.690	.1	60
1425	426.10	.1	60

Comments:

Impinger Bucket No. \_\_\_\_\_

Meter Box No. \_\_\_\_\_

## **GAS SAMPLING FIELD DATA**

JOB NO. 4-8300w

Material Sampled for SO<sub>x</sub>

Date 1-23-74

Plant WILLIMATIC Location OUTLET

Bar. Pressure 29.87 "Hg Comments:

Ambient Temp. 63

Run No. 1b

Power Stat Setting 800

Filter Used: Yes No

CLOCK TIME	METER (Ft <sup>3</sup> )	FLOW METER SETTING (CFM)	METER TEMPERATURE TM
1529	499.300	1	63
1535	499.85	1	63
1540	490.26	1	63
1545	491.65	1	63
1550	491.100	1	63

**Comments:**

Impinger Bucket No. \_\_\_\_\_

**Meter Box No.** \_\_\_\_\_

GAS SAMPLING FIELD DATAJOB NO. Y-8300wMaterial Sampled for SOxDate 1-24-74Plant WILLIMENTIC Location OUTLETBar. Pressure 30.27 "Hg Comments:Ambient Temp. 45Run No. 2aPower Stat Setting 80%Filter Used: Yes    No XOperator KG

CLOCK TIME	METER (Ft <sup>3</sup> )	FLOW METER SETTING (CFM)	METER TEMPERATURE TM
1101	496.700	.05	42
1105	496.82	.05	42
1110	497.415	.05	42
1115	497.000	.05	42
1121	497.04	.05	42
1125	498.45	.05	42
1130	498.400	.05	42

Comments:

Impinger Bucket No. \_\_\_\_\_

Meter Box No. \_\_\_\_\_

GAS SAMPLING FIELD DATAJOB NO. Y-8300wMaterial Sampled for SO<sub>x</sub>Date 1-24-74Plant WILLIMANTICLocation OUTLETBar. Pressure 30.27 "Hg Comments:Ambient Temp. 43°Run No. 2bPower Stat Setting 80°Filter Used: Yes    No   Operator KB

CLOCK TIME	METER (Ft <sup>3</sup> )	FLOW METER SETTING (CFM)	METER TEMPERATURE TM
1341	499.600	.05	41
1350	499.755	.05	41
1355	500.14	.05	41
1402	500.40	.05	41
1409	500.87	.08	41
1414	501.675	.08	41

Comments:

Impinger Bucket No.   Meter Box No.

**GAS SAMPLING FIELD DATA**

JOB NO. Y-8300W

**Material Sampled for**

50 x

Date 1-24-74

Plant WILLMANTIC

Location OUTLET

Bar. Pressure 30.28 "Hg Comments:

Ambient Temp. 40

Run No. 3a

Power Stat Setting 80°

Filter Used: Yes  No

Operator KB

CLOCK TIME	METER (Ft <sup>3</sup> )	FLOW METER SETTING (CFM)	METER TEMPERATURE TM
1518	504.875	.06	41
1525	505.25	.05	41
1532	505.158	.05	41
1545	505.24	.05	41
1551	505.425	.05	41

**Comments:**

**Impinger Bucket No.**

**Meter Box No.**

## GAS SAMPLING FIELD DATA

JOB NO. Y-8380W

**Material Sampled for**

Date 1-24-74

Plant WILLIMANTIC

50 x

Bar. Pressure 30.28 "Hg Comments:

Ambient Temp. 4

Run No. 36

Power Stat Setting 80

Filter Used: Yes No

CLOCK TIME	METER (Ft <sup>3</sup> )	FLOW METER SETTING (CFM)	METER TEMPERATURE TM
1637	508.100	.07	41
1645	508.12	.06	41
1653	509.02	.06	41
1700	509.415	.06	41
1702	509.767	.06	41

**Comments:**

**Impinger Bucket No.**

**Meter Box No.**

NCAP 36 (12/67)





STATE OF CONNECTICUT  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

STATE OFFICE BUILDING

HARTFORD, CONNECTICUT 06115



October 4, 1973

Mr. Robert Epstein  
York Research Corporation  
One Research Drive  
Stamford, Connecticut 06906

Dear Mr. Epstein:

You are hereby notified that "Intent to Test" form No. 730082 which describes a test plan for sampling emissions from the sludge incinerator at the Willimantic Wastewater Treatment Plant, Willimantic, Connecticut, is acceptable and meets the test criteria required by the State of Connecticut, Department of Environmental Protection.

The field tests will be observed by Mr. Carl Dodge unless you are otherwise notified. He should be informed of progress and problems that may alter the test program.

Very truly yours,

*Terrence DellaVecchia*  
Terrence DellaVecchia  
Air Pollution Engineer

TD:kr

cc: Mr. John Carpenter  
MSI Industries, Inc.

Date 11/16/74 Box No. 6-102Pump OKPump Oil OKClean Quick Connects OKValves OKManometers OKDry Test Meter OKThermometers OKLights OKElectrical Check - Amphenol OKVariac OKVacuum Gauge OKLeak Check at 27" hg. - OK

CFM

Remarks Call Captain Charles off Eber

Initial each item when checked and write in any remarks.

## Calibration - Orifice and Meter

Date JAN 16/74Box No. 6-102P<sub>b</sub> 29.84

Man Orifice	CF <sub>w</sub>	CF <sub>d</sub>	T <sub>w</sub>	IT <sub>d</sub>	OT <sub>d</sub>	T <sub>d</sub> Avg.	Time t
0.5	5	5.016	72	77.6	72.4	75	12.91
1.0	5	5.042	73	84.6	77.2	80.9	9.48
2.0	10	10.095	73	89.5	79.5	84.5	12.73
4.0	10	10.104	73	96	81.5	87.3	9.26
6.0	10	10.042	73	98.5	83.5	91.0	7.56
8.0	10						

Calculate Y & H<sub>@</sub> at man. 2.0

$$Y = \frac{CF_w, P_b (T_d \text{ avg.} + 460)}{CF_d (P_b + 0.147) (T_w + 460)}$$

$$Y = \frac{(\text{ } + 460)}{(\text{ } + 0.147)}$$

$$\Delta H_{@} = \frac{0.0634}{P_b (OT_d + 460)} \left( \frac{(T_w + 460)^2}{CF_w} \right)$$

$$\Delta H_{@} = \frac{0.0634}{(\text{ } + 460)} \left( \frac{(\text{ } + 460)^2}{t} \right)$$

## Tolerances

$$Y = 0.99 - 1.00 - 1.01$$

$$\Delta H_{@} = 1.6 - 1.84 - 2.1$$

0.3117 (Man. Orifice)

$$\Delta H_{\text{Q}} = \frac{(T_w + 460)t^2}{P_b (0T_d + 460)}$$

Calibration Calculations Meter and Pump Box  
Date TAW 16 74 Box No. 6-102

$$P_b (0T_d + 460)$$

$$Y = \frac{CF_w P_b (T_d \text{ avg.} + 460)}{CF_d P_b + \frac{\text{Man. Orifice}}{13.6} (T_w + 460)}$$

$$\Delta H_{\text{Q}} = \frac{(72 + 460)^2}{(12.71 + 460) \frac{5}{5}}$$

$$0.01585$$

$$.5 \quad 1.88$$

$$P_b (0T_d + 460)$$

$$Y = \frac{5 \times 29.84 (75 + 460)}{5.016 (29.84 + 0.0368) (72 + 460)}$$

$$0.0317$$

$$1.0 \quad 2.02$$

$$P_b (0T_d + 460)$$

$$Y = \frac{5 \times 29.84 (80.9 + 460)}{5.042 (29.84 + 0.0737) (73 + 460)}$$

$$0.0634$$

$$1.0 \quad 2.02$$

$$P_b (0T_d + 460)$$

$$Y = \frac{10 \times 29.84 (84.5 + 460)}{10.042 (29.84 + 0.147) (73 + 460)}$$

$$0.1268$$

$$1.0 \quad 2.02$$

$$P_b (0T_d + 460)$$

$$Y = \frac{10 \times 29.84 (87.3 + 460)}{10.104 (29.84 + 0.294) (73 + 460)}$$

$$0.1902$$

$$1.0 \quad 2.02$$

$$P_b (0T_d + 460)$$

$$Y = \frac{10 \times 29.84 (91 + 460)}{10.042 (29.84 + 0.431) (73 + 460)}$$

$$0.2536$$

$$1.0 \quad 2.02$$

$$P_b (0T_d + 460)$$

$$Y = \frac{10 \times 29.84 (95 + 460)}{(10 + 0.588) (73 + 460)}$$

$$8.0$$

$$8.0$$

