

Note: This material is related to a section in AP42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

ed 7/28/86

14

The file name refers to the file number, the AP42 chapter and then the section. The file name "rel01_c01s02.pdf" would mean the file relates to AP42 chapter 1 section 2. The document may be out of date and related to a previous version of the section. The document has been saved for archival and historical purposes. The primary source should always be checked. If current related information is available, it will be posted on the AP42 webpage with the current version of the section.

#06

PARTICULATE EMISSION TEST REPORT
For a Sewage Sludge Incinerator at
THE CITY OF SHELBY WASTEWATER TREATMENT PLANT
Shelby, North Carolina

Performed by the Source Testing Staff
of the
North Carolina Department
of Natural Resources & Community Development
Division of Environmental Management
Environmental Management
February 6, 1979

CONTENTS

	Page
Introduction	1
Source and Process Description	2
Sampling and Analytical Procedure	3
Summary of Results	4
References	4
Test Summary	5
APPENDIX A - Calculation Summary	6
APPENDIX B - Dry Molecular Weight Determination	11
APPENDIX C - Analytical Data	12
APPENDIX D - Source Sampling Field Data	15
APPENDIX E - Preliminary Field Data	18
APPENDIX F - Nomograph Data	19
APPENDIX G - Sludge Charge Rate & Allowable Emissions	20

INTRODUCTION

This report presents the results of a test performed on the exhaust of a sewage sludge incinerator at the wastewater treatment plant of the City of Shelby, North Carolina. The test was performed on February 6, 1979.

The test was performed to determine compliance with 15 NCAC 2D .0505 "Control of Particulates From Refuse Burning Equipment" (Reference 1).

G. L. Comer and R. E. Wooten, Jr. of the source testing staff performed the test. Assistance was provided by Randy Hyatt of the Asheville Regional Office.

SOURCE AND PROCESS DESCRIPTION

The City of Shelby incinerates its municipal sewage sludge with a No. 2 oil-fired fluidized bed incinerator.

The sludge is dewatered on a filter. The filter cake drops to a conveyor and is transported to the incinerator. The sludge is weighed at one point on the conveyor. The weight tally is automatically kept and displayed on a counter in the control room.

The emissions of the incinerator are controlled by scrubbing with water. Consequently, the stack exhaust is saturated with water, or nearly so.

The allowable particulate emissions from the incinerator are defined by 15 NCAC 2D .0505 "Control of Particulates From Refuse Burning Equipment" (Reference 1). See Appendix G for the computation of the allowable emissions for the three test runs.

SAMPLING AND ANALYTICAL PROCEDURE

Particulate testing and analysis of samples were performed according to procedures developed by the U.S. Environmental Protection Agency and referred to as Method 5. Sampling port locations and number of test points to be used were determined according to Method 1. Port placement and test point locations are shown in Appendix E.

The flue gas composition was determined in accordance with Method 3. A gas sample was withdrawn continuously from a point near the particulate sampling nozzle and was collected in a Tedlar bag. The gas sample was analyzed for CO₂ and O₂ with an Orsat apparatus; the balance of the sample was presumed to be N₂. The results of this analysis are reported in Appendix B.

The above named Federal Test methods appear in their original form in the December 23, 1971 Federal Register (Reference 2), with updated versions appearing in the Environment Reporter (Reference 3).

The charge rate for waste was determined from the control room weight totalizer, which was presumed accurate. The charge rate data is given in Appendix G along with the allowable emission calculations.

It should be mentioned that part of the cyclone bypass was broken during disassembly of the third collection train. Care was taken that no glass slivers ended up as sample catch, at least none were seen. Any sample on the walls of the cyclone bypass was discarded. Consequently, the reported results for run 3 may be slightly low.

During the second run, the recording of the final gas meter reading before the final leak test was overlooked. Thus, after the leak test, a second leak test was performed without the meter box controls being touched. The change in gas volume during the second leak test was subtracted from the gas meter reading at the end of the first leak test to get a close approximation to the end-of-test gas meter reading.

SUMMARY OF RESULTS

As shown on the following test summary, the particulate emissions from the City of Shelby's sludge incinerator are less than one tenth what is allowed by 15 NCAC 2D .0505.



Robert E. Wooten, Jr.
Robert E. Wooten, Jr., P.E.
Source Test Engineer
March 20, 1979

REFERENCES

1. North Carolina Administrative Code, Title 15, Chapter 2, Subchapter 2D, Section .0505 "Control of Particulates From Refuse Burning Equipment", Environmental Management Commission, Raleigh, N.C. (February 1, 1976).
2. Federal Register, Standards of Performance for New Stationary Sources, Volume 36, Number 247, U.S. Government Printing Office, Washington, D.C. (December 23, 1971).
3. Environment Reporter, pp 121:1543 - 121:1578 updated thru April 21, 1978, The Bureau of National Affairs, Washington, D.C.

TEST SUMMARY - City of Shelby Sludge Incinerator

<u>Parameter</u>		<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>
Q_s	Stack volume flow rate, acfm	1887	1881	1987
Q_{std}	Stack volume flow rate, scfm	1648	1632	1707
%I	Percent isokinetic, %	99.3	98.3	99.5
pmr_{avg}	Emission rate, lb/hr.	0.1894	0.1459	0.1593
%EA	Percent excess air, %	43.8	29.8	45.4
	Refuse charge rate, lb/hr.	994	1145	1182
	Allowed emission rate, *lb/hr.	1.99	2.29	2.36
	Percent that emission rate is of the allowed rate, %	9.52	6.37	6.75

*Based on 15 NCAC 2D .0505

Calculation Summary

SOURCE City of Shelby Sludge Incin. Date 6 Feb 79
 LOCATION Shelby, N.C.

ENTRY	RUN 1	RUN 2	RUN 3	ANSWER
Ave. ΔH (in H_2O)	2.0000	2.0000	2.0000	
P_{atm} (in Hg)	29.5500	29.4800	29.4800	
P_s (gage) (in H_2O)	29.7022	29.6115	29.5581	P_m (in Hg)
	-0.1400	-0.1400	-0.1400	
T_m ($^{\circ}R$)	29.5397	29.4497	29.3897	P_s (in Hg)
v_m (ft ³)	517.0000	525.0000	522.0000	
	45.9000	45.3000	46.9100	
	46.7013	45.2499	47.0424	v_{mstd} (ft ³)
v_{lq} (ml)	196.0000	216.0000	240.0000	
	9.2708	10.2168	11.3520	v_{vstd} (ft ³)
	55.9721	55.4667	58.3944	v_{std} (ft ³)
	16.5632	18.4197	19.4402	$\%M$
	0.8344	0.8158	0.8056	M_d
MW_d	30.0000	30.1900	30.0500	
	28.0124	27.9446	27.7075	M
T_s ($^{\circ}R$)	599.0000	601.0000	606.0000	
$\Sigma\sqrt{\Delta p}$	4.5654	4.5306	4.7430	
$n_{\Delta p}$	12.0000	12.0000	12.0000	
	0.3805	0.3776	0.3953	Ave $\sqrt{\Delta p}$
C_p	0.0000	0.0000	0.0000	
	23.1668	23.1668	24.4623	v_s (ft/sec)
D_s (in)	15.7500	15.7500	15.7500	
	1.3530	1.3530	1.3530	A_s (ft ²)
	1887.	1881.	1987.	Q_s (ft ³ /min)
	1648.	1632.	1707.	Q_{std} (ft ³ /min)
W_t (gm)	0.0488	0.0378	0.0413	
	0.1291	0.1471	0.1597	pmr_c (lb/hr)
D_n (in)	0.7110	0.3780	0.3770	
	0.1122	0.1122	0.1116	A_n (in ²)
θ (min)	60.0000	60.0000	60.0000	
	0.1589	0.1447	0.1589	pmr_a (lb/hr)
	99.3326	98.3395	99.5088	$\%I$
	0.1894	0.1459	0.1593	pmr_{avg} (lb/hr)
$\%CO$	0.0000	0.0000	0.0000	
$\%O_2$	6.6300	5.0000	6.7700	
$\%N_2$	92.3000	92.5700	92.1300	
	43.7624	29.7646	45.3987	$\%EA$
F Factor				

HI (10⁶ BTU/hr.)
 pmr_u (lbs/10⁶ BTU)

NOMENCLATURE

A_n	(in ²), Cross sectional area of nozzle
A_s	(in ²), Cross sectional area of stack
A'_s	(ft ²), Cross sectional area of stack
C_p	Pitot tube calibration coefficient
%EA	Percent Excess Air
F	(scfd/10 ⁶ BTU), F factor
ΔH	(in H ₂ O), Average orifice meter reading
HI	(10 ⁶ BTU/hr), Heat Input Rate
%I	Percent Isokineticity
M	(lb/lb mole), Molecular Weight of wet gas
%M	Percent Moisture
M_d	Mole fraction of dry gas
MW_d	(lb/lb mole) Molecular weight of dry gas
$n_{\Delta p}$	Number of Δp readings
P_{atm}	(in Hg), Local atmospheric pressure
P_m	(in Hg), Absolute pressure in dry gas meter
P_s	(in Hg), Absolute stack pressure
$P_{s(gage)}$	(in H ₂ O), Measured static stack pressure
P_{std}	(29.92 in Hg), Standard pressure
pmr_a	(lb/hr), Pollutant mass rate based on ratio of areas
pmr_{avg}	(lb/hr), Average pollutant mass rate
pmr_c	(lb/hr), Pollutant mass rate based on concentration
pmr_u	(lb/10 ⁶ BTU), Specific emission rate
Δp	(in H ₂ O), Velocity pressure
Q_s	(ft ³ /min), Actual stack volume flow rate
Q_{std}	(ft ³ /min), Stack volume flow rate at standard conditions

APPENDIX A

T_m	(°R), Average dry gas meter temperature
T_s	(°R), Average stack temperature
T_{std}	(530 °R), Standard temperature
V_{lq}	(ml), Liquid volume
V_m	(ft ³), Sample volume measured by dry gas meter
V_{mstd}	(ft ³), Sample volume at standard conditions
V_{std}	(ft ³), Total sample volume at standard conditions
V_{vstd}	(ft ³), Volume of water vapor collected, corrected to standard conditions
v_s	(ft/sec), Stack velocity
W_t	(gm), Total weight of particulate collected
θ	(min), Duration of test

EQUATIONS

1. Absolute Pressure in Dry Gas Meter - P_m (in. Hg.)

$$P_m = P_{atm} + \frac{\Delta H}{13.6}$$

2. Absolute Stack Pressure - P_s (in. Hg.)

$$P_s = P_{atm} + \frac{P_{s(gage)}}{13.6}$$

3. Sample Volume at Standard Conditions - V_{mstd} (ft³)

$$V_{mstd} = V_m \frac{T_{std}}{T_m} \frac{P_m}{P_{std}}$$

4. Volume of Water Vapor Collected, Corrected to Standard Conditions - V_{vstd} (ft³)

$$V_{vstd} = K_2 V_{lq} \frac{T_{std}}{P_{std}} \quad K_2 = 0.00267 \text{ (units conversion)}$$

5. Total Sample Volume at Standard Conditions - V_{std} (ft³)

$$V_{std} = V_{mstd} + V_{vstd}$$

6. Percent Moisture in Stack Gas - %M

$$\%M = \frac{V_{vstd}}{V_{std}} \times 100$$

7. Mole Fraction of Dry Gas - M_d

$$M_d = \frac{100 - \%M}{100}$$

8. Molecular Weight of Wet Gas - M (lb/lb mole)

$$M = (MW_d \times M_d) + 18(1 - M_d)$$

9. Stack Velocity - v_s (ft/sec)

$$v_s = K_p C_p \sqrt{\frac{T_s}{P_s M}} \frac{\Sigma \sqrt{\Delta p}}{n \Delta p}$$

$$K_p = 85.48 \text{ (units conversion factor)}$$

10. Stack Volume Flow Rate - Q_s (ft^3/min)

$$Q_s = K_1 v_s A_s' \quad K_1 = 60 \text{ (units conversion)}$$

11. Stack Volume Flow Rate at Standard Conditions - Q_{std} (ft^3/min)

$$Q_{\text{std}} = \frac{T_{\text{std}}}{P_{\text{std}}} \frac{P_s}{T_s} Q_s$$

12. Pollutant Mass Rate Based on Particulate Concentration - pmr_c (lb/hr)

$$\text{pmr}_c = K_3 \frac{W_t Q_{\text{std}}}{V_{\text{std}}} \quad K_3 = 0.1323 \text{ (units conversion)}$$

13. Pollutant Mass Rate Based on the Ratio of the Cross Sectional Area of the Stack and the Sampling Nozzle - pmr_a (lb/hr)

$$\text{pmr}_a = K_3 \frac{W_t A_s}{\theta A_n} \quad K_3 = 0.1323 \text{ (units conversion)}$$

14. Percent Isokineticity - %I

$$\%I = \frac{\text{pmr}_a}{\text{pmr}_c} \times 100$$

15. Average Pollutant Mass Rate - pmr_{avg} (lb/hr)

$$\text{pmr}_{\text{avg}} = \frac{\text{pmr}_a + \text{pmr}_c}{2}$$

16. Percent Excess Air - %EA

$$\%EA = \frac{\%O_2 - .5(\%CO)}{.264(\%N_2) - \%O_2 + .5(\%CO)} \quad (100)$$

17. Heat Input Rate - HI (10^6 BTU/hr)

$$HI = \frac{60 Q_{\text{std}} M_d}{F(100 + \%EA)} \quad (100)$$

18. Specific Emission Rate - pmr_u ($\text{lb}/10^6$ BTU)

$$\text{pmr}_u = \frac{\text{pmr}_{\text{avg}}}{HI}$$

DRY MOLECULAR WEIGHT DETERMINATION

COMMENTS:

PLANT City of Shelby
 DATE 8 Feb 79 (Samples taken 6 Feb 79)
 SAMPLING LOCATION Stack of Sludge Incinerator
 SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS) Integrated
 ANALYTICAL METHOD O₂ S₂
 AMBIENT TEMPERATURE 70°F
 OPERATOR _____

Run 1 Lung 4 REW									
Time	read	%	read	%	read	%	Average Volume	Multiplier	Molecular Weight M _d
%CO ₂	10.9	10.9	11.8	10.8	10.9	10.9	10.87	.44	4.78
%O ₂	17.5	6.6	11.5	6.7	17.5	6.6	6.63	.32	2.12
%N ₂	82.5	82.5		82.5		82.5	82.5	.28	23.10
									30.00

Run 2 Lung 5 GC									
Time	read	%	read	%	read	%	Average Volume	Multiplier	Molecular Weight M _d
%CO ₂	12.5	12.5	12.4	12.4	12.4	12.4	12.43	.44	5.47
%O ₂	11.5	5.0	11.3	4.9	17.5	5.1	5.00	.32	1.60
%N ₂		82.5		82.7		82.5	82.5	.28	23.12
									30.19

Run 3 Lung 6 REW									
Time	read	%	read	%	read	%	Average Volume	Multiplier	Molecular Weight M _d
%CO ₂	11.1	11.1	11.1	11.1	11.1	11.1	11.10	.44	4.88
%O ₂	11.9	6.5	11.8	6.7	17.9	6.8	6.77	.32	2.17
%N ₂		82.1		82.2		82.1	82.13	.28	23.00
									30.05

ANALYTICAL DATA

Lab No. 0707

3-6-79

JRB
✓

Plant City of Shelby
 Run Number 1 Date 2/6/79
 Location Shelby N.C.

FILTER WEIGHTS

TOTALS

Filter Number 55603
 Final Weight (g) _____
 Tare Weight (g) .4069

WASHINGS

TOTALS

Beaker Number 8
 Volume (Acetone) 200
 Final Weight (g) 183.7520
 Tare Weight (g) 183.2956

ACETONE BLANK

TOTAL PARTICULATE CATCH

Lot Number 775109 Filter Final Weight * _____
 Beaker Number B + Washings, Final Weight 183.7520
 Volume (ml) 300 - Filter Tare .4069
 Final Weight (g) 182.0239 - Beaker Tare (Washings) 183.2956
 Tare Weight (g) 182.0229 - Corrected Blank .0007
 Blank Residue (g) .0010 = Total Particulate (g) .0488

BLANK CORRECTION =

$$\left(\frac{\text{Vol. Washings}}{\text{Vol. Blank}} \right) \times (\text{Blank Residue})$$

$$\left(\frac{200}{300} \right) \times (.0010) = .0007$$

IMPINGERS (1, 2, 3)

SILICA GEL

Final Volume (ml) 374 Final Weight (g) 222.2
 Initial Volume (200 ml) 200 Initial Weight (g) 200
 Water Collected (ml) 174 Moisture Collected (g) 22.2

Total Water Collected (ml) 196.2

*These blocks will be blank if filter is weighed together with the washings.

ANALYTICAL DATA

Lab No. 0708

Plant City of Shelby
 Run Number 2 Date 2/6/79
 Location Shelby N.C.

FILTER WEIGHTS

TOTALS

Filter Number 55604
 Final Weight (g) _____
 Tare Weight (g) .3950

WASHINGS

TOTALS

Beaker Number BMF6
 Volume (Acetone) 150
 Final Weight (g) 168.0597
 Tare Weight (g) 167.6264

ACETONE BLANK

TOTAL PARTICULATE CATCH

Lot Number Fisher 775109
 Beaker Number _____
 Volume (ml) As on
 Final Weight (g) #707
 Tare Weight (g) _____
 Blank Residue (g) _____

Filter Final Weight * _____
 + Washings, Final Weight 168.0597
 - Filter Tare .3950
 - Beaker Tare (Washings) 167.6264
 - Corrected Blank .0005
 = Total Particulate (g) .0378

BLANK CORRECTION =

$$\left(\frac{\text{Vol. Washings}}{\text{Vol. Blank}} \right) \times (\text{Blank Residue})$$

$$\left(\frac{150}{300} \right) \times (.0010) = .0005$$

IMPINGERS (1, 2, 3)

SILICA GEL

Final Volume (ml) 397
 Initial Volume (200 ml) 200
 Water Collected (ml) 197

Final Weight (g) 218.8
 Initial Weight (g) 200
 Moisture Collected (g) 18.8

Total Water Collected (ml) 215.8

*These blocks will be blank if filter is weighed together with the washings.

ANALYTICAL DATA

Lab No. 0709

3-6-79

Plant City of Shelby
 Run Number 3 Date 2/6/79
 Location Shelby, N.C.

FILTER WEIGHTS

TOTALS

Filter Number 55605
 Final Weight (g) _____
 Tare Weight (g) .4033

WASHINGS

TOTALS

Beaker Number AG
 Volume (Acetone) 100
 Final Weight (g) 175.0689
 Tare Weight (g) 174.6240

ACETONE BLANK

Fisher

TOTAL PARTICULATE CATCH

Lot Number 775109
 Beaker Number ↑
 Volume (ml) As on
 Final Weight (g) #707
 Tare Weight (g) ↓
 Blank Residue (g) _____

Filter Final Weight * _____
 + Washings, Final Weight 175.0689
 - Filter Tare .4033
 - Beaker Tare (Washings) 174.6240
 - Corrected Blank .0003
 = Total Particulate (g) .0413

BLANK CORRECTION =

$$\left(\frac{\text{Vol. Washings}}{\text{Vol. Blank}} \right) \times (\text{Blank Residue})$$

$$\left(\frac{100}{300} \right) \times (.0010) = .0003$$

IMPINGERS (1, 2, 3)

Final Volume (ml) 418
 Initial Volume (200 ml) 200
 Water Collected (ml) 218

SILICA GEL

Final Weight (g) 221.8
 Initial Weight (g) 200.0
 Moisture Collected (g) 21.8

Total Water Collected (ml) 239.8

*These blocks will be blank if filter is weighed together with the washings.

AIR QUALITY SECTION

SOURCE SAMPLING FIELD DATA

Plant Crop Valley
 Date 6 Feb 76
 Location Study Increment
 Sample Type Particulate
 Run Number 1
 Operator REW
 Sample Box No. 41
 Meter Box No. 2

Meter ΔH_0 1.84
 C Factor 120-189 140-173
 Probe Type probe
 Probe Length 3 ft / 4 ft
 Probe Tip Dia., In. 3/16
 Probe Heater Setting probe
 Heater Box Setting probe
 Assumed Moisture % assumed

Ambient Temperature 13.2°F
 Barometric Pressure, In. Hg. 29.55
 Static Pressure (P_s), -1.14
 Stack Dimension(s) 15.75 in. dia.
 Distance: Disturbance to port 24 ft
 Distance: Port to exit 13 ft
 Leak Rate 0.01 cfm @ 15 in. Hg.
 Filter number(s) 55603

Remarks:



Exhaust to 1000 ft. to 1000 ft. Hg

TRAVERSE POINT NUMBER	CLOCK TIME SAMPLING TIME, min	GAS METER READING (V _m), ft ³	VELOCITY HEAD (ΔP _s), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPIGNER TEMPERATURE, °F	% CO ₂ (Fyrite)
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F				
1	1:00	706.273	1.0	1.25	1.25	13.5		42	3	200	40	12.5
2	1:05	707.238	1.1	1.25	1.25	13.5		42	3	205	41	12.5
3	1:10	712.26	1.6	1.7	1.7	16.0		46	5	215	44	12.5
4	1:15	718.67	1.21	2.6	2.6	15.0		50	7	220	62	12.5
5	1:20	719.82	1.22	2.7	2.7	15.0		52	7	220	91	13.5
6	1:25	724.29	1.17	3.3	3.3	15.0		56	6	225	71	14.0
7	1:30	728.498	1.07	1.0	1.0	13.5		60	3	225	60	14.0
8	1:35	731.25	1.0	1.5	1.5	13.0		62	4	225	55	14.5
9	1:40	734.48	1.3	1.9	1.9	13.5		64	5	225	50	10.0
10	1:45	738.14	1.17	2.8	2.8	13.5		66	6	225	48	7.5
11	1:50	742.664	1.18	3.1	3.1	12.0		70	7	225	49	7.0
12	1:55	747.6	1.6	2.7	2.7	11.5		72	6	225	50	7.0
13	2:00	752.194										

% CO₂ = 10.9

T_m = 57°F

T_s = 139°F

ΔH = 2.07

U_m = 45.90

WOCR

12-15-72 6-2-76

AIR QUALITY SECTION

SOURCE SAMPLING FIELD DATA

Plant Citrus Processing Date 6/15/68 Meter ΔH_0 1.8 Ambient Temperature 33.0°F Remarks:

Location Stadys Incinerator C Factor 130-132 Barometric Pressure, In. Hg. 29.46

Sample Type gas, filter, cond Probe Type 3/4" x 4' Static Pressure (P_s), in. Hg. 1.4

Run Number 2 Probe Length 3/4" x 4' Stack Dimension(s) 15.75 in Dia

Operator A.E.W. Probe Tip Dia., In. 1.375 Distance: Disturbance to port 7.30

Sample Box No. 2 Probe Heater Setting 150 Distance: Port to exit 1.0

Meter Box No. 2 Heater Box Setting 150 Leak Rate 1001 cfm @ 15 in Hg

Assumed Moisture % 2.06 Filter number(s) 5544

TRAVERSE POINT NUMBER	CLOCK TIME (24-hr CLOCK)	SAMPLING TIME, min	GAS METER READING (V _m), ft ³	VELOCITY HEAD (ΔP _s), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
					DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
1	2:35		752.595	10.1		1.26	130		56	13	152	39
2			745.881	10.9		1.25	140		57	3	190	36
3	3:00		758.500	11.4		2.0	140		58	4	195	37
4	3:15		761.916	12.0		2.7	145		60	5	200	38
5	3:30		766.24	12.0		2.8	140		64	6	210	39
6	3:45		770.78	12.0		2.7	141		64		210	
7	3:50		775.262									
1	4:30		775.292	10.7		1.88	150		68	3	210	63
2	4:45		773.91	10.9		1.3	135		68	3	210	55
3	5:00		780.31	11.4		2.0	140		70	4	215	50
4	5:15		784.61	11.9		2.7	140		70	5	210	47
5	5:30		788.96	12.1		2.9	140		72	6	210	45
6	5:45		793.61	12.1		2.7	151		72	6	210	45
7	6:00		798.204	12.1								
8	6:15		803.1									

AIR QUALITY SECTION

SOURCE SAMPLING FIELD DATA

Plant Aluminum Refining
 Date 6 Feb 72
 Location St. Louis, Mo.
 Sample Type for lead
 Run Number 1
 Operator RFL
 Sample Box No. 1
 Meter Box No. 2

Meter ΔH 1.87
 C Factor 140-187 140-175 160-156
 Probe Type gauge
 Probe Length 3' 1/4'
 Probe Tip Dia., In. .327
 Probe Heater Setting high
 Heater Box Setting high
 Assumed Moisture % 55

Ambient Temperature 35
 Barometric Pressure, In. Hg. 29.40
 Static Pressure (P_s), -.14
 Stack Dimension(s) 15.75 in.
 Distance: Disturbance to port 24 ft
 Distance: Port to exit 13 ft
 Leak Rate .001 cfm @ 16 in. Hg.
 Filter number(s) 55605

Remarks:



End of line .000 of line 6 10 in. Hg.

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m) ft ³	VELOCITY HEAD (ΔP_s), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg.	SAMPLE BOX TEMPERATURE, °F	IMPING TEMPERATURE, °F	O ₂ , CO ₂ (Fyrite)
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F				
1	4:42	793.613	.11		1.4	150		54	3	160	30	11
2		804.85	.12		1.6	150		54	4	200	35	12
3		805.14	.14		2.0	140		46	5	220	36	12
4		805.27	.11		2.7	140		58	6	225	40	11 1/2
5		813.17	.21		3.0	140		60	7	230	60	12
6		817.56	.16		2.0	150		64	5	240	71	13
7		822.002										
8		822.002										
9		822.002	.075		.94	150		64	3	235	50	13
10		824.07	.15		1.1	140		64	4	240	50	11
11		824.24	.14		1.9	145		66	5	240	50	11 1/2
12		831.74	.22		2.8	150		68	7	240	50	13 1/2
13		836.13	.26		3.0	155		70	8	240	53	12
14		840.70	.14		2.7	140		70	7	240	66	12 1/2
15		845.523										

AQ-44 $V_m = 46.91$ $\bar{P}_s = 2.15$ $\bar{T}_s = 146^\circ F$ $\bar{T}_m = 62^\circ F$ $\%CO_2 = 12.1$
 12-15-72 6-2-76 WOCR 522°K

Sketch of stack or duct
showing location of sampling
ports

Duct Diameter $15 \frac{3}{4}"$ 1.313 ft
Nipple 2.75' 1'

[illegible]

APPENDIX F

NOMOGRAPH DATA

PLANT City of Shelby Wastewater Treatment
 DATE 6 Feb 79
 SAMPLING LOCATION Sludge Incinerator

CALIBRATED PRESSURE DIFFERENTIAL ACROSS ORIFICE, in. H ₂ O	ΔH_0	1.847
AVERAGE METER TEMPERATURE (AMBIENT + 20°F), °F	$T_{m,avg.}$	60
PERCENT MOISTURE IN GAS STREAM BY VOLUME	B_{wo}	saturated
BAROMETRIC PRESSURE AT METER, in. Hg	P_m	29.55
STATIC PRESSURE IN STACK, in. Hg ($P_m \pm 0.073 \times$ STACK GAUGE PRESSURE in in. H ₂ O)	P_s	-1.14
RATIO OF STATIC PRESSURE TO METER PRESSURE	P_s/P_m	1
AVERAGE STACK TEMPERATURE, °F	$T_{s,avg.}$	138
AVERAGE VELOCITY HEAD, in. H ₂ O	$\Delta p_{avg.}$	115
MAXIMUM VELOCITY HEAD, in. H ₂ O	$\Delta p_{max.}$	120
C FACTOR		120-1.87 140-1.75 130-1.82 150-1.68 160-1.56
CALCULATED NOZZLE DIAMETER, in.		
ACTUAL NOZZLE DIAMETER, in.		.376
REFERENCE Δp , in. H ₂ O		

Preliminary
Traverse

Point	Δp	T_s
A 1	.06	135
2	.105	140
3	.135	140
4	.19	135
5	.120	140
6	.118	140

$\bar{\Delta p} = .15$
 $\bar{T}_s = 138$

01/12/87
 per Don Rhom
 City of Shelby
 WW Tst. Plant
 - weighed
 off vac. filter
 ∴ dry

APPENDIX G

SLUDGE CHARGE RATE AND ALLOWABLE EMISSIONS

		<u>Weight totalizer</u>	<u>Time</u>
Run 1	End	2591920 lb	2:10 pm
	Begin	2590843 lb	1:05 pm
	Total	<u>1077 lb</u>	1 hr. 5 min.
Run 2	End	2594168 lb	4:05 pm
	Begin	2592928 lb	3:00 pm
	Total	<u>1240 lb</u>	1 hr. 5 min.
Run 3	End	2596321 lb	5:48 pm
	Begin	2595041 lb	4:43 pm
	Total	<u>1280 lb</u>	1 hr. 5 min.

Run 1

$$E = (.002) \left(\frac{1077 \text{ lb}}{65 \text{ min}} \times \frac{60 \text{ min.}}{1 \text{ hr.}} \right) = (.002) (994 \frac{\text{lb}}{\text{hr.}})$$

$$E = 1.99 \text{ lb/hr}$$

Run 2 $E = 2.29 \text{ lb/hr}$

Run 3 $E = 2.36 \text{ lb/hr}$