

Note: This material is related to a section in AP42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the file number, the AP42 chapter and then the section. The file name "rel01_c01s02.pdf" would mean the file relates to AP42 chapter 1 section 2. The document may be out of date and related to a previous version of the section. The document has been saved for archival and historical purposes. The primary source should always be checked. If current related information is available, it will be posted on the AP42 webpage with the current version of the section.

logged 1/28/86 21
Rec. (#00)
3-27-86
Air Quality
Rel.
Hd Qtrs

ENTROPY


ENVIRONMENTALISTS INC.

POST OFFICE BOX 12291
RESEARCH TRIANGLE PARK
NORTH CAROLINA 27709-2291
919-781-3550

Received
3/25/86
LON

STATIONARY SOURCE SAMPLING REPORT

EEI REF. NO. 2988



OSBORNE WASTE WATER TREATMENT PLANT
GREENSBORO, NORTH CAROLINA

PARTICULATE EMISSIONS AND
PARTICLE SIZE DISTRIBUTION TESTING

SLUDGE INCINERATOR SCRUBBER INLET AND SCRUBBER STACK

performed for:

NICHOLS ENGINEERING AND RESEARCH CORPORATION

OCTOBER 1, 2, & 3, 1985

REPORT CERTIFICATION

The sampling and analysis performed for this report was carried out under my direction and supervision.

Date October 29, 1985

Signature Will M. Harden

Will M. Harden

I have reviewed all testing details and results in this test report and hereby certify that the test report is authentic and accurate.

Date October 29, 1985

Signature D. James Grove

D. James Grove, P.E.

TABLE OF CONTENTS

	<u>PAGE</u>
INTRODUCTION	
1.1 Outline of Test Program	1-1
1.2 Test Participants	1-2
SUMMARY OF RESULTS	
2.1 Particulate	2-1
2.2 Particle Size	2-1
2.3 Sludge Analysis	2-1
2.4 Particulate Loss-On-Ignition Analysis	2-1
PROCESS DESCRIPTION AND OPERATION	
3.1 Process Description	3-1
3.2 Source Air Flow Description	3-1
SAMPLING AND ANALYTICAL PROCEDURES	
4.1 General	4-1
4.2 Sampling Points	4-1
4.3 Flue Gas Velocity and Molecular Weight	4-1
4.3.1 Particulate Tests	4-1
4.3.2 Particle Size Tests	4-1
4.4 Particulate Emissions	4-1
4.5 Particle Size Distribution	4-4
4.6 Lab Analyses	4-4
4.6.1 Sludge Analysis	4-4
4.6.2 Method 5 Particulate Loss-On-Ignition	4-4
4.7 Equipment	4-4
APPENDICES	
A. Test Results	
1. Particulate Emissions	
a. Scrubber Inlet	
b. Scrubber Stack	
2. Particle Size Distributions	
a. Scrubber Inlet	
b. Scrubber Stack	
3. Example Calculations	
B. Field and Analytical Data	
1. Particulate Emissions	
a. Scrubber Inlet	
b. Scrubber Stack	
2. Particle Size Distributions	
a. Scrubber Inlet	
b. Scrubber Stack	
C. Sampling and Analytical Procedures	
D. Calibration Data	

INTRODUCTION

1.1 Outline of Test Program. Stationary source sampling was performed for Nichols Engineering and Research Corporation at the Osborne Waste Water Treatment Plant in Greensboro, North Carolina, on October 1-3, 1985. Concurrent testing was performed at the sludge incinerator scrubber inlet and scrubber stack to determine the particulate emissions and particle size distributions. The particulate collection efficiency of the scrubber, the contents of sludge samples taken during each test set, and the results of loss-on-ignition analyses on the Method 5 particulate samples are also reported. Table 1-1 outlines the test program.

TABLE 1-1
SAMPLING LOG
Sludge Incinerator Scrubber

<u>Test Date</u>	<u>- - - Sampling Objective</u>	<u>- - - Method</u>	<u>Test Set</u>	<u>Concurrent Inlet</u>	<u>Runs Stack</u>
10/1	Particulate	EPA 5	1	I-2*	O-1
	Particle Sizing	Cascade Impactor	2	SI-1	SO-1
	Particulate	EPA 5	3	I-3**	O-3**
10/2	Particulate	EPA 5	4	I-4	O-4
	Particle Sizing	Cascade Impactor	5	SI-4	SO-4
10/3	Particulate	EPA 5	6	I-5	O-5
	Particle Sizing	Cascade Impactor	7	SI-5	SO-5

* Run I-2 performed to replace run I-1; for scrubber efficiency calculations runs I-2 and O-1 are considered concurrent runs.

** Aborted due to stoppage of process

SUMMARY OF RESULTS

2.1 Particulate. Table 2-1 summarizes the results of particulate testing performed at the sludge incinerator scrubber inlet and scrubber stack on October 1, 2, and 3, 1985. Run-by-run results are presented in Tables 2-2 and 2-3 for the scrubber inlet and scrubber stack, respectively. Detailed test results are given in Appendix A; field and analytical data are provided in Appendix B.

2.2 Particle Size. The particle size distributions at the scrubber inlet and scrubber stack are tabulated in Table 2-4. Based upon the Method 5 particulate emission rates, emission rates and scrubber collection efficiencies using cumulative emissions greater than each particle size range are also presented. Figure 2-1 summarizes for the three particle sizing test sets the scrubber collection efficiencies by particle size range. Figures 2-2, 2-3, and 2-4 present the particle size distributions for particle sizing test sets 2, 5, and 7, respectively.

2.3 Sludge Analysis. The analytical results of sludge samples collected during each of the seven test sets are presented in Table 2-5.

2.4 Particulate Loss-On-Ignition Analysis. Table 2-6 gives the Method 5 particulate loss-on-ignition results.

1.2 Test Participants. Table 1-2 lists the personnel present during the test program.

TABLE 1-2
TEST PARTICIPANTS

Nichols Engineering and
Research Corporation

Rick Leuser
Test Coordinator

Charlie Shaw
Test Coordinator

Bob Eastman
Test Coordinator

Entropy, Inc.

Neill M. Harten
Entropy Project Director

Steve Terll
Sampling Team Leader

W. Douglas Engerstaff
Engineering Technician

Robert Williams
Engineering Technician

TABLE 2-1
PARTICULATE EMISSIONS SUMMARY
Sludge Incinerator Scrubber

	1-2, 0-1	Test Set 4 1-4, 0-4	6 1-5, 0-5	
Sludge Dry Solids, %	21.2	22.2	20.4	
Sludge Feed Rate, Tons/Hr				
Wet	6.81	6.25	5.93	6.25
Dry	1.44	1.39	1.21	1.21
Emission Rate, Lbs/Hr				
Inlet	31.3	41.8	27.6	
Stack	3.88	5.21	4.95	4.68
Efficiency, %	87.6*	87.5	82.1	85.7
Concentration, Stack	0-1	0-0	0-5	
Gr/DSCF	0.0450	0.0593	0.0575	0.0539
Gr/DSCF @ 12% CO ₂	0.0693	0.0837	0.00784	0.0771
Lb/Dry Ton of Sludge**	2.69	3.75	4.07	3.503

* Runs 1-2 and 0-1 are treated as concurrent runs used to calculate the collection efficiency

** Calculated by dividing the scrubber stack particulate emission rate (lbs/hr) by the dry sludge feed rate (tons/hr)

Note:
incorrect
decimal
placement

$$C_{in} = (0.5) (12) = 0.0784$$

$$P_c = \frac{(0.0539)(14)}{21 - 10.5} = 0.0791$$

$$C_{12} = 0.0575(12) = 0.69$$

TABLE 2-2
PARTICULATE TESTS SUMMARY OF RESULTS

	Scrubber Inlet		
	I-2	I-4	I-5
RUN DATE	10/01/85	10/02/85	10/03/85
TEST TRAIN PARAMETERS:			
VOLUME OF DRY GAS SAMPLED, SCF*	29.362	20.563	15.765
PERCENT ISOKINETIC	103.0	89.9	108.4
FLUE GAS PARAMETERS:			
TEMPERATURE, DEG. F	826	943	915
GAS FLOW RATES SCFM*, DRY	11,021	11,793	10,956
ACFM, WET	38,558	48,236	47,316
METHOD 5 TEST RESULTS:			
CATCH, MILLIGRAMS	629.7	551.4	300.0
GRAINS PER DSCF*	0.3310	0.4138	0.2937
LBS PER HOUR	31.26	41.83	27.58

* 68 Deg. F. - 29.92 in. Hg.

3,56
Inlet

TABLE 2-3

PARTICULATE TESTS SUMMARY OF RESULTS

	Scrutcher Stack			
	0-1	0-4	0-5	
RUN DATE	10/01/85	10/02/85	10/03/85	
TEST TRAIN PARAMETERS:				
VOLUME OF DRY GAS SAMPLED, SCF*	29.552	38.282	37.032	
PERCENT ISOKINETIC	97.8	100.2	102.2	
FLUE GAS PARAMETERS:				
TEMPERATURE, DEG. F	132	139	139	136.7
GAS FLOW RATES SCFM*, DRY	10.061	10.254	10.051	10,122
ACFM, WET	12.515	13.429	13.102	13,015
PERCENT EXCESS AIR	112.4	96.5	89.3	
METHOD 5 TEST RESULTS:				
CATCH, MILLIGRAMS	86.2	147.1	137.9	
GRAINS PER DSCF*	0.0450	0.0593	0.0575	0.0535
LBS PER HOUR	3.88	5.21	4.95	4.95

* 68 Deg. F. - 29.92 in. Hg.




FIGURE 2-1. SLUDGE INCINERATOR SCRUBBER EFFICIENCY VERSUS PARTICLE SIZE DIAMETER

TABLE 2-4
SCRUBBER EFFICIENCY BY PARTICLE DIAMETER

Particle Dia., Microns	Inlet Run SI-1				Stack Run SO-1				Collection Efficiency, %
	Cum. % Less Than	Catch, %	Emissions Lb/Hr*	Cum. > Lb/Hr	Cum. % Less Than	Catch, %	Emissions Lb/Hr**	Cum. > Lb/Hr	
> 15	22.0	78.0	24.4	24.4	95.0	5.0	0.194	0.194	99.2
10	18.5	3.5	1.10	25.5	94.0	1.0	0.039	0.233	99.1
8	18.0	0.5	0.16	25.7	93.0	1.0	0.039	0.272	98.9
6	17.5	0.5	0.16	25.8	92.5	0.5	0.019	0.291	98.9
4	17.0	0.5	0.16	26.0	91.5	1.0	0.039	0.330	98.7
3	16.8	0.2	0.063	26.0	91.0	0.5	0.019	0.349	98.7
2	16.5	0.3	0.094	26.14	89.0	2.0	0.078	0.427	98.4
1	15.2	1.3	0.41	26.55	81.5	7.5	0.291	0.718	97.3
0.6	13.0	2.2	0.69	27.24	70.0	11.5	0.450	1.17	95.7
< 0.6	-	13.0	4.07	31.31	-	70.0	2.72	3.89	87.6

* Based on run I-2 emissions, 31.3 lb/hr

** Based on run O-1 emissions, 3.89 lb/hr

Particle Dia., Microns	Inlet Run SI-4				Stack Run SO-4				Collection Efficiency, %
	Cum. % Less Than	Catch, %	Emissions Lb/Hr*	Cum. > Lb/Hr	Cum. % Less Than	Catch, %	Emissions Lb/Hr**	Cum. > Lb/Hr	
> 15	22.0	78.0	32.6	32.6	97.0	3.0	0.16	0.16	99.5
10	21.0	1.0	0.42	33.0	95.5	1.5	0.078	0.238	99.3
8	19.5	1.5	0.63	33.7	94.0	1.5	0.078	0.316	99.1
6	18.5	1.0	0.42	34.1	92.0	2.0	0.10	0.416	98.8
4	17.8	0.8	0.33	34.4	89.5	2.5	0.13	0.546	98.4
3	17.5	0.3	0.13	34.5	87.5	2.0	0.10	0.646	98.1
2	17.0	0.5	0.21	34.7	84.0	3.5	0.18	0.826	97.6
1	16.5	0.5	0.21	35.0	75.0	9.0	0.47	1.30	96.3
0.6	15.2	1.3	0.54	35.5	65.0	10.0	0.52	1.82	94.9
< 0.6	-	15.2	6.35	41.8	-	65.0	3.39	5.21	87.5

* Based on run I-4 emissions, 41.8 lb/hr

** Based on run O-4 emissions, 5.21 lb/hr

TABLE 2-4
SCRUBBER EFFICIENCY BY PARTICLE DIAMETER
(continued)

Particle Dia., Microns	Inlet Run SI-5				Stack Run SO-5				Collection Efficiency, %
	Cum. % Less Than	Catch, %	Emissions Lbs/Hr*	Cum. % Less Than	Catch, %	Emissions Lbs/Hr*	Cum. % Less Than	Cum. % Less Than	
> 15	13.8	86.2	23.8	97.8	2.2	0.11	0.11	0.11	99.5
10	13.8	0.0	0.0	96.2	1.6	0.079	0.189	0.189	99.2
8	13.5	0.3	0.083	95.0	1.2	0.059	0.248	0.248	99.0
6	13.0	0.5	0.14	91.0	2.0	0.009	0.347	0.347	98.6
4	12.5	0.5	0.14	91.0	1.0	0.000	0.446	0.446	98.1
3	12.5	0.0	0.0	88.2	2.8	0.14	0.586	0.586	97.6
2	12.0	0.5	0.14	85.0	3.2	0.16	0.746	0.746	96.9
1	10.8	1.2	0.33	76.0	9.0	0.45	1.20	1.20	95.1
0.6	8.0	2.8	0.77	54.0	22.0	1.09	2.29	2.29	91.0
< 0.6	-	8.0	2.21	-	54.0	2.67	4.95	4.95	82.1

* Based on run I-5 emissions, 27.6 lb/hr

** Based on run O-5 emissions, 4.95 lb/hr

DENSITY = 1 GM/CM³




FIGURE 2-2. SLUDGE INCINERATOR PARTICLE SIZE DISTRIBUTION, RUNS S11 AND S01

DENSITY = 1 GM/CM³




FIGURE 2-3. SLUDGE INCINERATOR PARTICLE SIZE DISTRIBUTION, RUNS SI4 AND SO4

DENSITY = 1 GM/CM³




FIGURE 2-4. SLUDGE INCINERATOR PARTICLE SIZE DISTRIBUTION, RUNS S15 AND S05

TABLE 1-5
SLUDGE ANALYSIS

	Test Sets						
	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>
Moisture, Wt. %	78.8	80.9	79.1	77.8	79.7	79.6	81.0
Ash, Wt. %, Dry	31.1	31.6	31.2	31.3	29.6	28.8	28.7
Silica as Si, Mg/Kg, Dry	4,500	5,300	4,400	3,460	5,040	10,800	9,730
Oil & Grease Mg/Kg, as Recvd.	146	112	135	146	166	186	186

Composite Sample*

Weight %, Dry	
Hydrogen	5.54
Carbon	40.7
Nitrogen	4.74
Sulfur	1.92
Oxygen	17.9
Heat Content Btu/Lb, Dry	7,380

* Composite of all sludge samples taken during each test set

TABLE 1-6
METHOD 5 PARTICULATE LOSS-ON-IGNITION ANALYSIS
Weight %

	Test Set			
	<u>1</u>	<u>2</u>	<u>4</u>	<u>6</u>
	<u>I-2</u>	<u>I-3</u>	<u>I-4</u>	<u>I-5</u>
Inlet	12.0	11.1	8.63	12.2
	<u>O-1</u>	<u>O-2</u>	<u>O-4</u>	<u>O-5</u>
Outlet	21.0	21.1	14.4	13.0

PROCESS DESCRIPTION AND OPERATION

3.1 Process Description. The Osborne Waste Water Treatment Plant operates a sludge incinerator system to reduce dewatered sludge to ash by use of combustion. The incinerator consists of seven vertically stacked hearths. Dewatered sludge cake is fed into the top hearth and moved from hearth to hearth by a center shaft with attached arms and teeth which direct the flow of material through the incinerator. The incinerator is equipped with fuel oil-fired burners used to ignite the volatile components of the sludge feed. Combustion air is supplied through auxiliary air fans into hearths 2 through 6. The upper hearths are designed for final drying of the sludge, intermediate hearths are used for combustion, and the bottom hearth is used for ash cooling. Ash is discharged to the ash handling system from a point outside the bottom hearth.

3.2 Source Air Flow. After leaving the incinerator, combustion gases pass through a venturi scrubber system and an induced draft fan before exhausting through the stack to the atmosphere. Air is forced through the center shaft and arms to provide protection from the high temperatures in the incinerator. During normal operation, a portion of the exhaust air from the cooling process (now heated to approximately 400°F) is directed back into the incinerator through warm air return ducts in hearths 6 and 7. The remaining hot air is vented through the scrubber outlet stack. The incinerator system is shown schematically in Figure 3-1.




FIGURE 3-1. SLUDGE INCINERATOR AIR FLOW SCHEMATIC SHOWING TEST LOCATIONS

SAMPLING AND ANALYTICAL PROCEDURES

4.1 General. All sampling and analytical procedures were those generally recommended by the United States Environmental Protection Agency and the North Carolina Department of Natural Resources and Community Development. The sampling equipment and procedures are described in Appendix C, which is extracted from 40 CFR (Code of Federal Regulations) Part 60.

4.2 Sampling Points.

4.2.1 Scrubber Stack. The number and location of the sampling points were determined according to procedures outlined in EPA Method 1. As shown in Figure 4-1, the stack cross section was divided into 24 equal areas, with 12 sampling points on each of two traverse axes, labeled A and B.

4.2.2 Scrubber Inlet. Nichols Engineering and Research Corporation and Entropy agreed to divide the inlet duct cross section into 12 equal areas, with four sampling points on each of three traverse axes, labeled A, B, and C. The sampling point configuration is shown in Figure 4-2.

4.3 Flue Gas Velocity and Molecular Weight.



4.3.1 Particulate Tests. Velocity measurements were made according to EPA Method 2. At the scrubber stack, flue gas composition and molecular weight were determined according to EPA Method 3 once during each test day; the Method 3 gas samples were taken during runs 0-1, 0-4, and 0-5 at the scrubber stack. The scrubber inlet particulate test results were calculated using flue gas composition and molecular weight values determined for concurrent runs at the scrubber stack.

4.3.2 Particle Size Tests. Flue gas molecular weight values used to calculate the scrubber inlet and scrubber stack particle size distributions were the values determined at the scrubber stack during particulate testing on the same day.

4.4 Particulate Emissions. Particulate emissions were determined according to EPA Method 5.

TRAVERSE POINTS

2 AXIS
12 POINTS/AXIS
24 TOTAL POINTS

**SECTION F-F****ELEVATION VIEW**

FROM I.D. FAN

FIGURE 4-1. SCRUBBER STACK TEST LOCATION




FIGURE 4-2. SCRUBBER INLET TEST LOCATION

4.4.1 Scrubber Stack. Each of the 24 equal areas was sampled for 2.5 minutes, resulting in a net run time of 60 minutes. Run 0-1 was only 50 minutes in length due to process outage.

4.4.2 Scrubber Inlet. During Run I-2, each of the 12 equal areas was sampled for four minutes, resulting in a net run time of 48 minutes. During Runs I-4 and I-5, each of the 12 equal areas was sampled for three minutes, resulting in a net run time of 36 minutes.

4.5 Particle Size Distribution. Particle sizing was performed using a cascade impactor attached to a probe on a Method 5 sampling train; the sizing is achieved aerodynamically in the stack. The moisture content value used to calculate the scrubber inlet and scrubber stack particle size distributions was taken from the scrubber stack Method 5 particulate run performed on the same day. Refer to Appendix B for sampling point identities and run times.

4.6 Lab Analyses. All the following laboratory analyses were performed by Industrial & Environmental Analysts, Inc.

4.6.1 Sludge Analysis. The sludge feed samples taken during each test set were subjected to analysis for content of water and dry volatiles, heat content of the dry volatiles, and silica, oil, and grease content in the sludge. A composite of the seven sludge samples was subjected to ultimate analysis.

4.6.2 Method 5 Particulate Loss-On-Ignition. The particulate catch from each Method 5 run was subjected to loss-on-ignition analysis.

4.7 Equipment. All sampling equipment was manufactured by Nutech Corporation or Entropy. Calibration data is provided in Appendix D.

A. TEST RESULTS

1. Particulate Emissions

a. Scrubber Inlet

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: Osborne Waste Water Treatment Plant, Greensboro, North Carolina

RUN		SAMPLING LOCATION		TEST TEAM LEADER	
I-2		Scrubber Inlet		Steve Terl	
I-4		Scrubber Inlet		Steve Terl	
I-5		Scrubber Inlet		Steve Terl	
		I-2	I-4	I-5	
RUN DATE		10/01/85	10/02/85	10/03/85	
RUN START TIME		1503	1246	1215	
RUN FINISH TIME		1555	1325	1255	
NET SAMPLING POINTS		12	12	12	
Theta	NET RUN TIME, MINUTES	48.00	36.00	36.00	
Dia	NOZZLE DIAMETER, INCHES	0.370	0.370	0.306	
Cp	PITOT TUBE COEFFICIENT	0.840	0.840	0.840	
Y	DRY GAS METER CAL. FACTOR	1.007	1.007	1.007	
Pbar	BAROMETRIC PRESSURE, IN. HG.	29.90	29.30	29.30	
Delta H	AVG. PRESS. DIFFERENTIAL OF ORIFICE METER, IN. H2O	1.210	1.210	1.701	
Vm	VOLUME OF METERED GAS SAMPLE DRY ACTUAL CUBIC FEET	31.142	22.255	22.630	
tm	DRY GAS METER TEMP., DEG. F	105	105	90	
Vm(std)	VOLUME OF METERED GAS SAMPLE @ DRY STD. COND., DSCF*	29.362	20.563	23.765	
Vlc	VOLUME OF WATER CATCH IN IMPINGERS & SIL. GEL., ML	269.0	219.5	209.5	
Vw(std)	VOLUME OF WATER VAPOR, SCF*	12.662	10.332	9.861	
%H2O	MOISTURE, PERCENT BY VOLUME	30.1	33.4	33.5	
Mfd	DRY MOLE FRACTION	0.699	0.666	0.615	

(continued next page)

		I-2	I-4	I-5
		-----	-----	-----
%CO ₂	PERCENT CO ₂ BY VOLUME, DRY	7.8	8.5	8.8
%O ₂	PERCENT O ₂ BY VOLUME, DRY	11.3	10.5	10.1
%CO+N ₂	PERCENT CO + N ₂ BY VOLUME	80.9	81.0	81.1
M _d	DRY MOLECULAR WT, LB/LB-MOLE	29.70	29.78	29.81
M _s	WET MOLECULAR WT, LB/LB-MOLE	26.17	25.84	25.27
P _g	GAS STATIC PRESS., IN. H ₂ O	-1.1	-1.2	0.5
P _s	ABSOLUTE GAS PRESS., IN. HG.	29.82	29.22	29.34
t _s	GAS TEMPERATURE, DEG. F	826	943	915
Delta P	AVG VELOCITY HEAD, IN. H ₂ O	0.2525	0.3503	0.3377
v _s	FLUE GAS VELOCITY, FT/SEC	46.3	57.9	56.8
A	STACK/DUCT AREA, SQUARE IN.	1,998.0	1,998.0	1,998.0
Q _{sd}	GAS FLOW RATE, DRY SCFM *	11,021	11,793	10,956
Q _{aw}	GAS FLOW RATE, WET ACFM	38,558	48,236	47,316
%I	PERCENT ISOKINETIC	103.0	89.9	108.4
	METHOD 5 RESULTS:			

m _s	CATCH, MILLIGRAMS	629.7	551.4	300.0
gr/DSCF	CONCEN., GRAINS PER DSCF*	0.3310	0.4138	0.2937
Lb/Hr	EMISSION RATE, LBS/HOUR	31.26	41.83	27.58

* 68 Deg. F - 29.92 in. Hg.

A. TEST RESULTS

1. Particulate Emissions

b. Scrubber Stack

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: Osborne Waste Water Treatment Plant, Greensboro, North Carolina

RUN		SAMPLING LOCATION		TEST TEAM LEADER		
-----		-----		-----		
0-1		Scrubber Stack		Neill M. Harden		
0-4		Scrubber Stack		Neill M. Harden		
0-5		Scrubber Stack		Neill M. Harden		
				0-1	0-4	0-5
				-----	-----	-----
RUN DATE				10/01/85	10/02/85	10/03/85
RUN START TIME				1100	1228	915
RUN FINISH TIME				1200	1330	1253
NET SAMPLING POINTS				20	24	24
Theta	NET RUN TIME, MINUTES			50.00	60.00	60.00
Dia	NOZZLE DIAMETER, INCHES			0.244	0.248	0.244
Cp	PITOT TUBE COEFFICIENT			0.840	0.840	0.840
Y	DRY GAS METER CAL. FACTOR			0.998	0.995	0.995
Pbar	BAROMETRIC PRESSURE, IN. HG.			29.20	29.30	29.30
Delta H	AVG. PRESS. DIFFERENTIAL OF ORIFICE METER, IN. H2O			1.300	1.550	1.400
Vm	VOLUME OF METERED GAS SAMPLE DRY ACTUAL CUBIC FEET			31.800	40.561	38.605
tm	DRY GAS METER TEMP., DEG. F			85	87	78
Vm(std)	VOLUME OF METERED GAS SAMPLE @ DRY STD. COND., DSCF*			29.550	38.282	37.032
Vlc	VOLUME OF WATER CATCH IN IMPINGERS & SIL. GEL., ML			51.5	105.5	98.0
Vw(std)	VOLUME OF WATER VAPOR, SCF*			2.424	4.966	4.613
%H2O	MOISTURE, PERCENT BY VOLUME			7.5	11.5	11.1
Mfd	DRY MOLE FRACTION			0.924	0.885	0.889

(continued next page)

		0-1	0-4	0-5
%CO2	PERCENT CO2 BY VOLUME, DRY	7.8	8.5	8.8
%O2	PERCENT O2 BY VOLUME, DRY	11.3	10.5	10.1
%CO+N2	PERCENT CO + N2 BY VOLUME	80.9	81.0	81.1
Md	DRY MOLECULAR WT, LB/LB-MOLE	29.70	29.78	29.81
Ms	WET MOLECULAR WT, LB/LB-MOLE	28.81	28.43	28.50
Pg	GAS STATIC PRESS., IN. H2O	-0.1	-0.1	-0.1
Ps	ABSOLUTE GAS PRESS., IN. HG.	29.19	29.29	29.29
ts	GAS TEMPERATURE, DEG. F	132	139	139
Delta P	AVG VELOCITY HEAD, IN. H2O	0.4093	0.4611	0.4401
vs	FLUE GAS VELOCITY, FT/SEC	38.5	41.4	40.4
A	STACK/DUCT AREA, SQUARE IN.	779.3	779.3	779.3
Qsd	GAS FLOW RATE, DRY SCFM *	10,061	10,254	10,051
Qaw	GAS FLOW RATE, WET ACFM	12,515	13,429	13,102
%I	PERCENT ISOKINETIC	97.8	100.2	102.2
%EA	PERCENT EXCESS AIR	112.4	96.5	89.3
METHOD 5 RESULTS:				
mg	CATCH, MILLIGRAMS	86.2	147.1	137.9
gr/DSCF	CONCEN., GRAINS PER DSCF*	0.0450	0.0593	0.0575
Lb/Hr	EMISSION RATE, LBS/HOUR	3.88	5.21	4.95

* 68 Deg. F - 29.92 in. Hg.

A. TEST RESULTS

2. Particle Size Distributions

a. Scrubber Inlet

PARTICLE SIZING FIELD DATA & RESULTS TABULATION

RUN SI:

PLANT: Osborne Waste Water Treatment Plant, Greensboro, North Carolina

SAMPLING LOCATION: Scrubber Inlet

DATE: 100185

START-FINISH TIME: 1401-1409	VOLUME METERED, ACF: 2.572
SR) SAMPLING RATE, ACFM 0.576	NOZZLE DIA., INCHES: 0.248
ST) SAMPLING TIME, MINUTES: 8.00	Y) METER CAL. FACTOR: 1.007
PB) BARO. PRESS., IN. HG.: 29.90	TM) METER TEMP., DEG F: 104
PSI) STATIC PRESS., IN. H2O: -1.00	DH) DELTA H AVG., IN. H2O: 0.30
TS) STACK GAS TEMP., DEG F: 216	DN) PARTICLE DENSITY, GM/CC: 1.00
PMV) MOISTURE % BY VOLUME: 32.4	DCF) VISCOSITY CORR. FACTOR: 1.091
DCF) DENSITY CORR. FACTOR: 1.000	MD) MOL WT, DRY LB/LB-MOLE: 29.70
	CONCENT., GR/DSCF: 0.5087

STAGE NO.	- PARTICLE DIAMETER - (microns)		CATCH WEIGHT (mgms)	PERCENT OF TOTAL (%)	CUM. % LESS THAN GIVEN DIA
	FROM GRAPH	AERODYNAMIC			
PreSep	11.19	12.21	64.10	80.2	20.0
PreImp	9.75	10.64	0.70	0.9	19.1
1	6.39	6.97	0.20	0.3	18.8
2	4.08	4.45	0.30	0.4	18.4
3	2.62	2.86	0.90	1.1	17.3
4	1.56	1.70	0.70	0.9	16.4
5	1.03	1.12	0.60	0.8	15.6
6	0.64	0.70	1.10	1.4	14.2
7	0.37	0.40	1.40	1.8	12.4
FILTER	< 0.37	< 0.40	9.90	12.4	

TOTAL CATCH 79.90

ENTROPY

PARTICLE SIZING FIELD DATA & RESULTS TABULATION

RUN SI4

PLANT: Osborne Waste Water Treatment Plant, Greensboro, North Carolina

SAMPLING LOCATION: Scrubber Inlet

DATE: 100285

START-FINISH TIME:	1434-1442	VOLUME METERED, ACF:	3.095
SR) SAMPLING RATE, ACFM	0.705	NOZZLE DIA., INCHES:	0.248
ST) SAMPLING TIME, MINUTES:	8.00	Y) METER CAL. FACTOR:	1.007
PB) BARO. PRESS., IN. HG.:	29.90	TM) METER TEMP., DEG F:	103
PSI) STATIC PRESS., IN. H2O:	1.10	DH) DELTA H AVG., IN. H2O:	0.49
TS) STACK GAS TEMP., DEG F:	220	DEN) PARTICLE DENSITY, GM/CC:	1.00
PMV) MOISTURE % BY VOLUME:	33.4	VCF) VISCOSITY CORR. FACTOR:	1.094
DCF) DENSITY CORR. FACTOR:	1.000	MD) MOL WT, DRY LB/LB-MOLE:	29.78
		CONCENT., GR/DSCF:	0.4456

STAGE NO.	- PARTICLE DIAMETER - (microns)		CATCH WEIGHT (mgms)	PERCENT OF TOTAL (%)	CUM. % LESS THAN GIVEN DIA
-----	FROM GRAPH	AERODYNAMIC	-----	-----	-----
PreSer	10.07	11.02	66.30	78.6	21.4
PreImp	8.77	9.59	0.30	0.4	21.0
1	5.75	6.29	1.80	2.1	18.9
2	3.68	4.03	0.60	0.7	18.2
3	2.37	2.59	0.50	0.6	17.6
4	1.41	1.54	0.30	0.4	17.2
5	0.93	1.02	0.20	0.2	17.0
6	0.58	0.63	1.30	1.5	15.5
7	0.33	0.36	1.70	2.0	13.5
FILTER	< 0.33	< 0.36	11.40	13.5	

TOTAL CATCH 84.40

ENTROPY

PARTICLE SIZING FIELD DATA & RESULTS TABULATION

RUN SI5

PLANT: Osborne Waste Water Treatment Plant, Greensboro, North Carolina

SAMPLING LOCATION: Scrubber Inlet

DATE: 100385

START-FINISH TIME: 1321-1329	VOLUME METERED, ACF: 2.751
SR) SAMPLING RATE, ACFM 0.693	NOZZLE DIA., INCHES: 0.248
ST) SAMPLING TIME, MINUTES: 8.00	Y) METER CAL. FACTOR: 1.007
PB) BARO. PRESS., IN. HG.: 29.30	TM) METER TEMP., DEG F: 94
PSI) STATIC PRESS., IN. H2O: -0.53	DH) DELTA H AVG., IN. H2O: 0.33
TS) STACK GAS TEMP., DEG F: 220	DEN) PARTICLE DENSITY, GM/CC: 1.00
PMV) MOISTURE % BY VOLUME: 38.5	VCF) VISCOSITY CORR. FACTOR: 1.094
DCF) DENSITY CORR. FACTOR: 1.000	MD) MOL WT, DRY LB/LB-MOLE: 29.81
	CONCENT., GR/DSCF: 0.5531

STAGE NO.	- PARTICLE DIAMETER - (microns)		CATCH WEIGHT (mgms)	PERCENT OF TOTAL (%)	CUM. % LESS THAN GIVEN DIA
-----	FROM GRAPH	AERODYNAMIC	-----	-----	-----
PreSep	10.16	11.12	79.40	85.7	14.5
PreImp	8.85	9.68	0.00	0.0	14.5
1	5.80	6.35	0.70	0.8	13.7
2	3.71	4.06	0.50	0.5	13.2
3	2.39	2.61	0.70	0.8	12.4
4	1.42	1.55	0.80	0.9	11.5
5	0.94	1.03	1.30	1.4	10.1
6	0.58	0.63	1.10	1.2	8.9
7	0.34	0.37	1.00	1.1	7.8
FILTER	< 0.34	< 0.37	7.20	7.8	

TOTAL CATCH 92.70

ENTROPY

A. TEST RESULTS

2. Particle Size Distributions

b. Scrubber Stack

PARTICLE SIZING FIELD DATA & RESULTS TABULATION

RUN S01

PLANT: Osborne Waste Water Treatment Plant, Greensboro, North Carolina

SAMPLING LOCATION: Scrubber Stack

DATE: 100185

START-FINISH TIME: 1345-1500	VOLUME METERED, ACF: 22.975
SR) SAMPLING RATE, ACFM 0.348	NOZZLE DIA., INCHES: 0.168
ST) SAMPLING TIME, MINUTES: 75.00	Y) REF CAL. FACTOR: 0.998
PB) BARO. PRESS., IN. HG.: 29.20	TM) REF TEMP., DEG F: 102
PSI) STATIC PRESS., IN. H2O: -0.10	DH) DELTA H AVG., IN. H2O: 0.28
TS) STACK GAS TEMP., DEG F: 129	DEN) PARTICLE DENSITY, GM/CC: 1.00
PMV) MOISTURE % BY VOLUME: 7.8	VCF) VISCOSITY CORR. FACTOR: 1.039
DCF) DENSITY CORR. FACTOR: 1.000	MD) MOL WT., DRY LB/LB-MOLE: 29.70
	CONCENT., GR/DSCF: 0.0479

STAGE NO. -----	- PARTICLE DIAMETER - (microns)		CATCH WEIGHT (mgms) -----	PERCENT OF TOTAL (%) -----	CUM. % LESS THAN GIVEN DIA -----
	FROM GRAPH -----	AERODYNAMIC -----			
0	16.46	17.10	3.20	4.9	95.2
1	10.24	10.64	0.50	0.8	94.4
2	6.90	7.17	0.90	1.4	93.0
3	4.76	4.95	0.40	0.6	92.4
4	3.00	3.12	0.50	0.8	91.6
5	1.55	1.61	2.30	3.5	88.1
6	0.96	1.00	4.80	7.4	80.7
7	0.66	0.69	4.00	6.3	74.4
FILTER	< 0.66	< 0.69	48.80	74.4	

TOTAL CATCH 65.30

ENTROPY

PARTICLE SIZING FIELD DATA & RESULTS TABULATION

RUN S04

PLANT: Osborne Waste Water Treatment Plant, Greensboro, North Carolina

SAMPLING LOCATION: Scrubber Stack

DATE: 100285

START-FINISH TIME: 1410-1515	VOLUME METERED, ACF: 20.618
SR) SAMPLING RATE, ACFM 0.391	NOZZLE DIA., INCHES: 0.168
ST) SAMPLING TIME, MINUTES: 65.00	Y) METER CAL. FACTOR: 0.998
PB) BARO. PRESS., IN. HG.: 29.30	TM) METER TEMP., DEG F: 88
PSI) STATIC PRESS., IN. H2O: -0.10	DH) DELTA H AVG., IN. H2O: 0.30
TS) STACK GAS TEMP., DEG F: 139	DEN) PARTICLE DENSITY, GM/CC: 1.00
PMV) MOISTURE % BY VOLUME: 11.5	VCF) VISCOSITY CORR. FACTOR: 1.045
DCF) DENSITY CORR. FACTOR: 1.000	MD) MOL WT, DRY LB/LB-MOLE: 29.78
	CONCENT., GR/DSCF: 0.0543

STAGE NO. -----	- PARTICLE DIAMETER - (microns) FROM GRAPH AERODYNAMIC -----		CATCH WEIGHT (grams) -----	PERCENT OF TOTAL (%) -----	CUM. % LESS THAN GIVEN DIA -----
0	15.51	16.21	1.60	2.3	97.5
1	9.66	10.09	1.40	2.0	95.5
2	6.50	6.79	1.80	2.6	92.9
3	4.49	4.69	1.60	2.3	90.6
4	2.83	2.96	2.10	3.1	87.5
5	1.46	1.53	3.30	4.8	82.7
6	0.90	0.94	5.30	7.8	74.9
7	0.62	0.65	4.60	6.7	68.2
FILTER	< 0.62	< 0.65	46.60	68.2	

TOTAL CATCH 68.30

ENTROPY

PARTICLE SIZING FIELD DATA & RESULTS TABULATION

RUN S05

PLANT: Osborne Waste Water Treatment Plant, Greensboro, North Carolina

SAMPLING LOCATION: Scrubber Stack

DATE: 100385

START-FINISH TIME: 1320-1410	VOLUME METERED, ACF: 16.092
SR) SAMPLING RATE, ACFM 0.395	NOZZLE DIA., INCHES: 0.168
ST) SAMPLING TIME, MINUTES: 50.00	Y) METER CAL. FACTOR: 0.995
PB) BARO. PRESS., IN. HG.: 29.30	TM) METER TEMP., DEG F: 84
PSI) STATIC PRESS., IN. H2O: -0.10	DH) DELTA H AVG., IN. H2O: 0.31
TS) STACK GAS TEMP., DEG F: 136	DEN) PARTICLE DENSITY, GM/CC: 1.00
PMV) MOISTURE % BY VOLUME: 11.1	VCF) VISCOSITY CORR. FACTOR: 1.043
DCF) DENSITY CORR. FACTOR: 1.000	MD) MOL WT, DRY LB/LB-MOLE: 29.81
	CONCENT., GR/DSCF: 0.0568

STAGE NO. -----	- PARTICLE DIAMETER - (microns)		CATCH WEIGHT (mgms) -----	PERCENT OF TOTAL (%) -----	CUM. % LESS THAN GIVEN DIA -----
	FROM GRAPH -----	AERODYNAMIC -----			
0	15.43	16.09	1.00	1.8	98.2
1	9.61	10.02	1.00	1.8	96.4
2	6.46	6.74	1.30	2.3	94.1
3	4.47	4.66	1.40	2.5	91.6
4	2.81	2.93	1.70	3.0	88.6
5	1.45	1.51	3.40	6.1	82.5
6	0.89	0.93	4.70	8.4	74.1
7	0.62	0.65	4.10	7.3	66.8
FILTER	< 0.62	< 0.65	37.40	66.8	

TOTAL CATCH 56.00

ENTROPY

APPENDIX A.3

A. TEST RESULTS

3. Example Calculations

ENTROPY

EXAMPLE PARTICULATE TEST CALCULATIONS NO. 1-2

Scrubber Inlet

VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS

$$V_m(\text{std}) = 17.64 * Y * V_m * \frac{(P_{\text{bar}} + \Delta H/13.6)}{(460 + t_a)}$$

$$V_m(\text{std}) = 17.64 * 1.007 * 31.142 * \frac{(29.90 + 1.210/13.6)}{(460 + 105)} = 29.362 \text{ DSCF}$$

VOLUME OF WATER VAPOR AT STANDARD CONDITIONS

$$V_w(\text{std}) = 0.04707 * V_{1c}$$

$$V_w(\text{std}) = 0.04707 * 269.0 = 12.662 \text{ SCF}$$

PERCENT MOISTURE, BY VOLUME, AS MEASURED IN FLUE GAS

$$\%H_2O = 100 * V_w(\text{std}) / (V_w(\text{std}) + V_m(\text{std}))$$

$$\%H_2O = \frac{12.662}{12.662 + 29.362} * 100 = 30.1 \%$$

DRY MOLE FRACTION OF FLUE GAS

$$M_{fd} = 1 - \%H_2O/100$$

$$M_{fd} = 1 - 30.1/100 = 0.699$$

DRY MOLECULAR WEIGHT OF FLUE GAS

$$M_d = \%CO_2 * 0.44 + \%O_2 * 0.32 + \%CO+N_2 * 0.28$$

$$M_d = 7.8*0.44 + 11.3*0.32 + 80.9*0.28 = 29.70 \text{ LB/LB-MOLE}$$

WET MOLECULAR WEIGHT OF FLUE GAS

$$M_s = (M_d * M_{fd}) + (0.18 * \%H_2O)$$

$$M_s = 29.70 * 0.699 + (0.18 * 30.1) = 26.17 \text{ LB/LB-MOLE}$$

ENTROPY

ABSOLUTE FLUE GAS PRESSURE

$$P_s = P_{bar} + P_g / 13.6$$

$$P_s = 29.90 + (-1.0 / 13.6) = 29.82 \text{ IN. HG.}$$

AVERAGE FLUE GAS VELOCITY [Note: (Delta P)avg is square of avg sq. root]

$$v_s = 85.49 * C_p * \text{SQRT} \left[\frac{(\Delta P)_{avg} * (460 + t_s)}{P_s * M_s} \right]$$

$$v_s = 85.49 * 0.840 * \text{SQRT} \left[\frac{0.2525 * (460 + 826)}{29.82 * 26.17} \right] = 46.3 \text{ FT/SEC}$$

DRY VOLUMETRIC FLUE GAS FLOW RATE @ STANDARD CONDITIONS

$$Q_{sd} = \frac{60}{144} * M_{fd} * v_s * A * \frac{T_{std}}{t_s + 460} * \frac{P_s}{P_{std}}$$

$$Q_{sd} = \frac{60}{144} * 0.699 * 46.3 * 1,998.0 * \frac{528}{826 + 460} * \frac{29.82}{29.92}$$

$$Q_{sd} = 11,021 \text{ SCFM}$$

WET VOLUMETRIC STACK GAS FLOW RATE @ FLUE GAS CONDITIONS

$$Q_{aw} = 60 / 144 * v_s * A$$

$$Q_{aw} = 60 / 144 * 46.3 * 1,998.0 = 38,558 \text{ ACFM}$$

PERCENT ISOKINETIC OF SAMPLING RATE

$$\%I = \frac{P_{std}}{T_{std}} * \frac{100}{60} * \frac{(t_s + 460) * V_m(std)}{P_s * v_s * M_{fd} * \theta * \text{Area-nozzle, sq.ft.}}$$

$$\%I = \frac{29.92}{528} * \frac{100}{60} * \frac{(826 + 460) * 29.362}{29.82 * 46.3 * 0.699 * 48.00 * 0.0007467}$$

$$\%I = 103.0 \%$$

GRAINS PER DRY STANDARD CUBIC FOOT

$$\text{gr/DSCF} = \frac{7000}{453,592} * \frac{\text{mass}}{V_m(\text{std})}$$

$$\text{gr/DSCF} = \frac{7000}{453,592} * \frac{629.7}{29.362} = 0.3310 \text{ gr/DSCF}$$

POUNDS PER HOUR

$$\text{Lb/Hr} = 60 / 7000 * \text{gr/DSCF} * Q_{sd}$$

$$\text{Lb/Hr} = 60/7000 * 0.3310 * 11,021 = 31.26 \text{ LB/HR}$$

B. FIELD AND ANALYTICAL DATA

1. Particulate Emissions


a. Scrubber Inlet

Preliminary Field Data

PLANT NAME Nichols (OSBORNE WATER)
 LOCATION GREENSBORO N.C.
 SAMPLING LOCATION Incinerator
FURNACE OUTLET
 DUCT DEPTH (Scrubber Inlet)
 FROM INSIDE FAR WALL TO OUTSIDE OF PORT 62"
 NIPPLE LENGTH 6 1/2"
 DEPTH OF DUCT 55 1/2"
 WIDTH (RECTANGULAR DUCT) 36
 EQUIVALENT DIAMETER:

$$D_E = \frac{2 \times \text{DEPTH} \times \text{WIDTH}}{\text{DEPTH} + \text{WIDTH}} = \frac{2(55 \frac{1}{2} \times 36)}{(55 \frac{1}{2} + 36)} = 43.67$$

 DISTANCE FROM PORTS UPSTREAM DOWNSTREAM
 TO NEAREST FLOW FEET 5.5 1
 DISTURBANCE: STACK DIAMETERS 1.5 < 1
 STACK AREA = 55 1/2" X 36" = 1998 N²



Point	% OF DIAMETER	DISTANCE FROM INSIDE WALL	DISTANCE FROM OUTSIDE OF PORT
1	12.5	6.93	13 1/2
2	37.5	20.8	27.0
3	62.5	34.6	41.0
4	87.5	45.5	51.5
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			

LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

	4	6	8	10	12	14	16	18	20	22	24
1	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3	75.0	29.6	19.4	14.6	11.9	9.9	8.5	7.5	6.7	6.0	5.5
4	93.3	70.4	32.3	22.4	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5		85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6		95.4	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7			99.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8			96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9				91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10				97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11					93.3	85.4	78.0	70.4	61.2	39.3	32.3
12					97.9	90.1	83.1	76.4	69.4	60.7	39.8
13						94.3	87.5	81.2	75.0	68.5	60.2
14						98.2	91.5	85.4	79.6	73.8	67.7
15							95.1	89.1	83.5	78.2	72.8
16							98.4	92.5	87.1	82.0	77.0
17								95.6	90.3	85.4	80.6
18								98.6	93.3	88.4	83.9
19									96.1	91.3	86.8
20									98.7	94.0	89.5
21										96.5	92.1
22										98.9	94.5
23											96.8
24											98.9

LOCATION OF TRAVERSE POINTS IN RECTANGULAR STACKS

	2	3	4	5	6	7	8	9	10	11	12
1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3		83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
4			87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
5				90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6					91.7	78.6	68.8	61.1	55.0	50.0	45.8
7						92.9	81.3	72.2	65.0	59.1	54.2
8							93.8	83.3	75.0	68.2	62.5
9								94.4	85.0	77.3	70.8
10									95.0	86.4	79.2
11										95.5	87.5
12											95.8

COMPANY NAME NICHOLS OSBORNE WATER TREATMENT RUN NUMBER 15
ADDRESS GREENSBORO NC. TIME START 12:46
SAMPLING LOCATION FURNACE OUTLET (scrubber Inlet) TIME FINISH 13:25
DATE 10/2/85 TEAM LEADER ST TECHNICIANS DWB
BAROMETRIC PRESSURE, IN. HG 29.3 STATIC PRESSURE, IN. H₂O -1.15
SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 17 _____
SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.000 0.000 _____

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
✓ PITOTS, PRE-TEST		REAGENT BOX <u>217</u>	NOZZLE <u>110</u> DIAMETER <u>.370</u>
✓ PITOTS, POST-TEST		METER BOX <u>N-12</u>	T/C READOUT <u>007</u>
— ORSAT SAMPLING SYSTEM		UMBILICAL <u>4-20</u>	T/C PROBE <u>7-10</u>
— TEDLAR BAG		SAMPLE BOX <u>25</u>	ORSAT PUMP <u>—</u>
✓ THERMOCOUPLE @ <u>883 °F</u>		PROBE <u>7-2</u>	TEDLAR BAG <u>—</u>
<u>FILTER #</u>	<u>TARE</u>	<u>NOMOGRAPH SET-UP</u>	<u>NOMOGRAPH #</u> <u>5T</u>
<u>E 3622</u>	<u>.4967</u>	ΔH_e <u>1.64</u>	C FACTOR <u>0.56</u>
		METER TEMP <u>100</u>	STACK TEMP <u>800 / 900</u>
		% MOISTURE <u>32</u>	REF. ΔP <u>0.39 / 0.42</u>
			<u>K = 4.717 x 10³</u>

[illegible]
$$\frac{22.255}{V_M} \quad \frac{.3503}{(\sqrt{\Delta P})^2} \quad \frac{1.21}{\Delta H} \quad \frac{105}{T_M} \quad \frac{943}{T_S}$$

ENTROPY

[illegible]

24.93

.2546

1.22

107

821

 V_M
$$(\sqrt{\Delta P})^2$$
 ΔH

T

Tg

ENTROPY

[illegible]

826

ENTROPY

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
✓ PITOTS, PRE-TEST		REAGENT BOX <u>237</u>	NOZZLE <u>109</u> DIAMETER <u>.3c-</u>
✓ PITOTS, POST-TEST		METER BOX <u>N-12</u>	T/C READOUT <u>007</u>
— ORSAT SAMPLING SYSTEM		UMBILICAL <u>u20</u>	T/C PROBE <u>7-10</u>
— TEDLAR BAG		SAMPLE BOX <u>25</u>	ORSAT PUMP <u>—</u>
✓ THERMOCOUPLE @ <u>0922</u> °F		PROBE <u>7-2</u>	TEDLAR BAG <u>—</u>
<u>FILTER #</u>	<u>TARE</u>	<u>NOMOGRAPH SET-UP</u>	<u>NOMOGRAPH #</u> <u>—</u>
<u>E 3635</u>	<u>.4827</u>	ΔH_0 <u>1.04</u>	C FACTOR <u>0.56</u>
		METER TEMP <u>100</u>	STACK TEMP <u>800 / 900</u>
		% MOISTURE <u>32</u>	REF. ΔP <u>.80 .90</u>
			<u>V = 2.3</u>

[illegible]
$$\frac{16.63}{V_M} \cdot \frac{.3377}{(\sqrt{\Delta P})^2} = \frac{.701}{\Delta H} \cdot \frac{90}{T_M}$$

9.5

ENTROPY

PARTICULATE SAMPLING LABORATORY RESULTS

Plant Name NICHOLS Ref. # 2988
 Sampling Location SCRUBBER INLET
 Date Received 10/3 Date Analyzed 10/9 Reagent Box(es) 0237

Run Number	<u>I2</u> <u>2</u>	<u>I3</u> <u>2</u>
Run Date	<u>10/1</u>	<u>10/1</u>

SUMMARY OF PARTICULATE ANALYSES

Sum of Particulate, mg.	<u>1095.3</u>	<u>92.5</u>	
Total Filter Tare mg.	<u>465.2</u>	<u>486.4</u>	
Blank Residue, mg. (<u>275</u> ml)	<u>0.4</u>	(<u>275</u> ml) <u>0.4</u>	ml)
TOTAL PARTICULATE CATCH, mg.	<u>629.7</u>	<u>434.7</u>	

ANALYSIS OF MOISTURE CATCH

<u>Reagent 1 (H₂O):</u>			
Final Weight, g.	<u>440.0</u>	<u>440.0</u>	
Tared Weight, g.	<u>200.0</u>	<u>200.0</u>	<u>200.0</u>
Water Catch, g.	<u>240.0</u>	<u>240.0</u>	
<u>Reagent 2 ()::</u>			
Final Weight, g.	—	—	—
Tared Weight, g.	—	—	—
Water Catch, g.	—	—	—
CONDENSED WATER, g.	<u>240.0</u>	<u>240.0</u>	
<u>Silica Gel:</u>			
Final Weight, g.	<u>229.0</u>	<u>224.5</u>	
Tared Weight, g.	<u>200.0</u>	<u>200.0</u>	<u>200.0</u>
ABSORBED WATER, g.	<u>29.0</u>	<u>24.5</u>	
TOTAL WATER COLLECTED, g.	<u>269.0</u>	<u>264.5</u>	

Blank Beaker # <u>12</u>	--- Legend ---	<u>Notes and Comments</u>
Final wt. mg. <u>49974.2</u>	✓ = Final Weight	
Tare wt. mg. <u>49973.9</u>	L = Loose Particulate	
Residue, mg. <u>0.3</u>	F = Filter D = Dish	
Volume, ml. <u>200</u>	R = Rinse P = Pan	
Concen., mg/ml. <u>.0015</u>		

LABORATORY SAMPLE WEIGHT CALCULATION

Plant Name NICHOLS

Ref. # 2988

Run Number	<u>+ 12</u>	<u>2 33</u>	
Run Date	<u>10/1</u>	<u>10</u>	<u>10/</u>
Sample ID/Container #	<u>FER-268</u>	<u>FER-268</u>	<u>FER-</u>
	144.1390	147.4450	
	144.1387	147.4450	
	144.1383	147.4450	
Tare Wt., g.	<u>144.1399</u>	<u>147.4450</u>	
	<u>143.0430</u>	<u>146.5250</u>	
SAMPLE WT., g.	1.0953	.925	
Sample ID/Container #	<u> </u>	<u> </u>	<u> </u>
Tare Wt., g.	<u> </u>	<u> </u>	<u> </u>
SAMPLE WT., g.			
Sample ID/Container #	<u> </u>	<u> </u>	<u> </u>
Tare Wt., g.	<u> </u>	<u> </u>	<u> </u>
SAMPLE WT., g.			
Sample ID/Container #	<u> </u>	<u> </u>	<u> </u>
Tare Wt., g.	<u> </u>	<u> </u>	<u> </u>
SAMPLE WT., g.			

PARTICULATE SAMPLING LABORATORY RESULTS

Plant Name NICHOLS EEI Ref. # 2988
 Sampling Location SCRUBBER INLET
 Date Received 10/3 Date Analyzed 10/8 Reagent Box(es) _____

Run Number 15 34 _____
 Run Date 10/3 _____

SUMMARY OF PARTICULATE ANALYSES

Sum of Particulate, mg. 783.2 648.4 _____
 Total Filter Tare mg. 482.7 496.7 _____
 Blank Residue, mg. (325 ml) 0.5 (200 ml) 0.3 (_____ ml) _____

TOTAL PARTICULATE CATCH, mg. 300.0 551.4

ANALYSIS OF MOISTURE CATCH

Reagent 1 (H_2O):

Final Weight, g. 398.0 394.0 _____
 Tared Weight, g. 200.0 200.0 _____
 Water Catch, g. 198.0 194.0 _____

Reagent 2 (_____):

Final Weight, g. — — _____
 Tared Weight, g. — — _____
 Water Catch, g. — — _____

CONDENSED WATER, g. 198.0 194.0 _____

Silica Gel:

Final Weight, g. 211.5 225.5 _____
 Tared Weight, g. 200.0 200.0 _____

ABSORBED WATER, g. 11.5 25.5 _____

TOTAL WATER COLLECTED, g. 209.5 219.5

Blank Beaker # 12

Final wt. mg. 49974.2
 Tare wt. mg. 49973.9
 Residue, mg. 0.3
 Volume, ml. 200
 Concen., mg/ml. .0015

--- Legend ---

✓ = Final Weight
 L = Loose Particulate
 F = Filter D = Disc
 R = Rinse P = Pan

Notes and Comments

LABORATORY SAMPLE WEIGHT CALCULATIONS

Plant Name NICHOLS

EEI Ref. # 2988

Run Number	<u>I5</u>	<u>I4</u>	
Run Date	<u>10/3</u>		
Sample ID/Container #	<u>FOR-312</u>	<u>FOR-20</u>	
		128.4059	
		✓128.4055	
		128.4069	
		128.5000	
		127.351	
Tare Wt., g.	✓134.1299 134.1299 <u>133.3467</u>		
SAMPLE WT., g.	.7832	1.0464	
Sample ID/Container #			
Tare Wt., g.			
SAMPLE WT., g.			
Sample ID/Container #			
Tare Wt., g.			
SAMPLE WT., g.			
Sample ID/Container #			
Tare Wt., g.			
SAMPLE WT., g.			

CUSTODY SHEET FOR REAGENT BOX # 0237Date of Makeup 9/26 Initials VP Locked? ☒Individual Tare of Reagent: 200 mls. of H₂O

Individual Tare of Reagent: _____ mls. of _____

Individual Silica Gel Tare Weight: 200 gms.PLANT NAME Nicholas (Greensboro)SAMPLING LOCATION FURNACE outlet

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked?
I2 <u>+</u>	<u>10/1/85</u>	<u>ST</u>	<u>yes</u>	<u>10/1/85</u>		<u>ST</u>	<u>yes</u>
I3 <u>+</u>	<u>10/1/85</u>	<u>ST</u>	<u>yes</u>	<u>10/1/85</u>		<u>ST</u>	<u>yes</u>

Received in Lab 10/2 Date 10/2 Initials MS Locked? ☒Sampling Method: M-5Zero & Span Balance
Initials MS

Filter # Tare Weight (mgms) Used on Test

Remarks:

E 2970 .4652 + I2E 3541 .4864 + I3

CUSTOM SHEET FOR REAGENT BOX # 0217

Date of Makeup 9/26 Initials VP Locked? ✓

Individual Tare of Reagent: 200 mls. of H₂O

Individual Tare of Reagent: _____ mls. of _____

Individual Silica Gel Tare Weight: 200 gms.

PLANT NAME NICHOLS

SAMPLING LOCATION FUR. #2 OUTLET

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked?
I-5 I-6	10-3	<i>mt</i>	✓	10-3	80	<i>mt</i>	✓
I-55	10-3	<i>mt</i>	✓	10-3	50	<i>mt</i>	✓

Received in Lab _____ Date _____ Initials *IE* Locked? ✓

Sampling Method: M-5

Zero & Span Balance
Initials *IE*

Filter # _____ Tare Weight (mgms) _____ Used on Test _____

Remarks:

<u>E 3635</u>	<u>.4827</u>	<u>I-5</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

3. FIELD AND ANALYTICAL DATA

1. Particulate Emissions


b. Scrubber Stack

Preliminary Field Data

PLANT NAME Nichols
 LOCATION Greensboro
 SAMPLING LOCATION outlet stack
 DUCT DEPTH
 FROM INSIDE FAR WALL TO OUTSIDE OF PORT 38"
 NIPPLE LENGTH 6 1/2
 DEPTH OF DUCT 31 1/2
 WIDTH (RECTANGULAR DUCT) _____
 EQUIVALENT DIAMETER:

$$D_E = \frac{2 \times \text{DEPTH} \times \text{WIDTH}}{\text{DEPTH} + \text{WIDTH}} = \frac{2(\quad) (\quad)}{(\quad) + (\quad)} = \quad$$

 DISTANCE FROM PORTS UPSTREAM DOWNSTREAM
 TO NEAREST FLOW FEET 12' 15
 DISTURBANCE: STACK DIAMETERS 4 5
 STACK AREA = $(31.5/2)^2 \pi = 779.3 \text{ m}^2$



Point	% OF DIAMETER	DISTANCE FROM INSIDE WALL	DISTANCE FROM OUTSIDE OF PORT
1	2.1	1"	7 1/2
2	6.7	2 1/4"	8 3/4
3	11.8	3 3/4"	10 1/4
4	17.8	5 1/2"	12
5	25.0	7 7/8"	14 3/8
6	35.6	11 1/4"	17 3/4
7	64.4	20 1/4"	26 3/4
8	75.0	23 1/2"	30
9	82.3	25 7/8"	32 3/8
10	88.2	27 7/8"	34 5/8
11	93.3	29 3/4"	36 1/4
12	97.9	30 1/8"	37 7/8
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			

LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

	4	6	8	10	12	14	16	18	20	22	24
1	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3	75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4	93.3	70.4	42.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5		85.4	47.7	24.2	25.0	20.1	16.5	14.6	12.9	11.6	10.5
6		95.4	80.6	65.8	55.6	46.9	39.2	33.6	29.5	26.2	23.2
7			89.5	77.4	64.4	54.6	45.3	38.6	33.0	29.4	26.1
8			96.8	85.4	75.0	63.4	53.5	45.6	39.2	34.0	30.4
9				91.8	82.3	73.1	62.5	53.2	45.6	39.2	34.0
10				97.4	88.2	79.9	71.7	61.8	53.0	45.6	39.2
11					93.3	85.4	78.1	70.4	61.2	53.0	45.6
12					97.9	90.1	83.2	76.4	69.4	60.7	53.0
13						94.3	87.5	81.2	75.0	68.5	60.2
14						98.2	91.5	85.4	79.6	73.8	67.7
15							95.2	89.1	83.5	78.2	72.8
16							98.4	92.5	87.1	82.0	77.0
17								95.6	90.3	85.4	80.6
18								98.6	93.3	88.4	83.9
19									96.1	91.3	86.8
20									98.7	94.0	89.5
21										96.5	92.1
22										98.9	94.5
23											96.8
24											98.9

LOCATION OF TRAVERSE POINTS IN RECTANGULAR STACKS

	2	3	4	5	6	7	8	9	10	11	12
1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3		83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
4			87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
5				90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6					91.7	78.6	68.8	61.1	55.0	50.0	45.8
7						92.9	81.2	72.2	65.0	59.1	54.2
8							93.8	83.3	75.0	68.2	62.5
9								94.4	85.0	77.3	70.8
10									95.0	86.4	79.2
11										95.5	87.5
12											92.8

Plant Name NICHOLSSampling Location SCRUBBER STACK

Fuel Type _____

Run and/or Sample No. 20-1 Leak Test? ☒ Date 10-1-85 Operator MM

Time of Sample Collection	Time of Analysis	CO ₂ Reading A	O ₂ Reading B	CO Reading C	%O ₂ B-A	%CO C-B	%N ₂ 100-C
1130	1230	7.8	19.0	—	11.2	—	
TO		7.7	19.0		11.3		
1222							
Avg.		7.8	Avg.		11.3		80.9

Run and/or Sample No. 0-4 Leak Test? ☒ Date 10-2 Operator MM

Time of Sample Collection	Time of Analysis	CO ₂ Reading A	O ₂ Reading B	CO Reading C	%O ₂ B-A	%CO C-B	%N ₂ 100-C
1228	1345	8.5	19.0	—	10.5	—	
TO		8.5	19.0		10.5		
1330							
Avg.		8.5	Avg.		10.5		81.0

Run and/or Sample No. 0-5 Leak Test? ☒ Date 10-3 Operator MM

Time of Sample Collection	Time of Analysis	CO ₂ Reading A	O ₂ Reading B	CO Reading C	%O ₂ B-A	%CO C-B	%N ₂ 100-C
1040 0915	1315	8.7	18.8	—	10.1	—	
TO		8.8	18.8		10.0		
1253							
Avg.		8.8	Avg.		10.1		81.1

PARTICULATE FIELD DATA

0-1

Restarted
(1130)

COMPANY NAME <u>NICHOLS</u>		RUN NUMBER <u>3</u>	
ADDRESS <u>GREENSBORO, NC</u>		TIME START <u>1100</u>	
SAMPLING LOCATION <u>SCRUBBER STACK</u>		TIME FINISH <u>1222</u>	
DATE <u>10-1-85</u>	TEAM LEADER <u>MR</u>	TECHNICIANS <u>RW</u>	
BAROMETRIC PRESSURE, IN. HG <u>29.2</u>		STATIC PRESSURE, IN. H ₂ O <u>-1.10</u>	
SAMPLING TRAIN LEAK TEST VACUUM, IN. HG <u>1.5</u> <u>6(P)</u>			
SAMPLING TRAIN LEAK RATE, CU. FT./MIN. <u>0.010</u> <u>0.012</u>			

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
☒ PITOTS, PRE-TEST		REAGENT BOX <u>277</u>	NOZZLE <u>304</u> DIAMETER <u>.244</u>
☒ PITOTS, POST-TEST		METER BOX <u>N8</u>	T/C READOUT
☒ ORSAT SAMPLING SYSTEM		UMBILICAL	T/C PROBE
☒ TEDLAR BAG		SAMPLE BOX	ORSAT PUMP <u>05</u>
☒ THERMOCOUPLE @ <u> </u> °F		PROBE <u>4-3</u>	TEDLAR BAG <u>20</u>

FILTER # <u>E 3856</u>		TARE <u>4846</u>	

NOMOGRAPH SET-UP		NOMOGRAPH # <u>MY</u>	
ΔH _g <u>1.61</u>	C FACTOR <u>.90</u>		
METER TEMP <u>95</u>	STACK TEMP <u>140</u>		
% MOISTURE <u>6</u>	REF. ΔP <u>.60</u>		

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H ₂ O	ORIFICE SETTING (ΔH), IN. H ₂ O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
A 1	0	269.670	.35	1.10	1.10	84	1	250	60	132	
2	22	271.22	.47	1.46	1.46	86	1	250	60	133	
3	5	272.78	.48	1.48	1.48	88	1	250	60	133	
4	72	274.49	.49	1.50	1.50	89	2	250	60	133	
5	10	276.20	.45	1.40	1.40	91	2	250	60	133	
6	122	277.70	.40	1.23	1.23	92	2	250	60	133	
7	15	279.51	.37	1.14	1.14	93	2	250	60	133	
8	172	280.88	.34	1.07	1.07	94	2	250	60	133	
9	20	282.37	.35	1.10	1.10	95	2	250	60	133	
10	222	283.92	.37	1.14	1.14	97	2	250	60	133	
11	25	285.36	.39	1.25	1.25	97	2	250	60	133	
12	272	287.00	.42	1.37	1.37	99	3	250	60	128	
B 1	30/0	288.627	.40	1.23	1.23	99	3	250	60	129	
2	52	290.25	.43	1.38	1.38	101	3	250	60	129	
3	5	291.66	.45	1.40	1.40	101	4	250	60	129	
4	72	293.48	.42	1.37	1.37	101	4	250	60	130	
5	10	295.08	.40	1.23	1.23	101	5	250	60	130	
6	122	296.74	.36	1.20	1.20	100	5	250	60	130	
7	15	298.22	.43	1.38	1.38	100	6	250	60	135	
8	172	300.15	.44	1.48	1.48	101	6	250	60	145	
9	20/20	301.472									
10	222										
11	25										
12	272										
	60/0FF										

31.802 4093

1.30 95

132

V_M

(ΔP)²

ΔH

T_M

T_S

ENTROPY

PARTICULATE FIELD DATA

0-3

COMPANY NAME <u>NICHOLS</u>		RUN NUMBER <u>4</u>	
ADDRESS <u>GREENSBORO, NC</u>		TIME START <u>1628</u>	
SAMPLING LOCATION <u>SCRUBBER STACK</u>		TIME FINISH <u>1701</u>	
DATE <u>10-1-86</u>	TEAM LEADER <u>ML</u>	TECHNICIANS <u>RW</u>	
BAROMETRIC PRESSURE, IN. HG <u>29.2</u>		STATIC PRESSURE, IN. H ₂ O <u>- .10</u>	
SAMPLING TRAIN LEAK TEST VACUUM, IN. HG <u>15</u>			
SAMPLING TRAIN LEAK RATE, CU. FT./MIN. <u>0.003</u>			

EQUIPMENT CHECKS ☒ PITOTS, PRE-TEST ☐ PITOTS, POST-TEST ☐ ORSAT SAMPLING SYSTEM ☐ TEDLAR BAG ☐ THERMOCOUPLE @ _____ °F	IDENTIFICATION NUMBERS REAGENT BOX <u>277</u> NOZZLE <u>304</u> DIAMETER <u>.244</u> METER BOX <u>N8</u> T/C READOUT _____ UMBILICAL _____ T/C PROBE _____ SAMPLE BOX _____ ORSAT PUMP <u>ON</u> PROBE <u>4-</u> TEDLAR BAG _____
--	---

FILTER # <u>E 3706</u> TARE <u>1.5004</u>	NOMOGRAPH SET-UP NOMOGRAPH # <u>ML</u> ΔH _g <u>1.661</u> C FACTOR <u>.90</u> METER TEMP <u>95</u> STACK TEMP <u>130</u> % MOISTURE <u>1</u> REF. ΔP <u>.60</u>
--	--

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H ₂ O	ORIFICE SETTING (ΔH), IN. H ₂ O		GAS METER TEMP, °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP, °F	IMP. EXIT TEMP, °F	STACK TEMP, °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
B 1	0	324.838	.26	1.00	1.10	87	1	250	60	135	
2	2 ¹ / ₂	326.30	.40	1.23	1.23	88	2	250	60	136	
3	5	327.78	.43	1.32	1.32	88	2	250	60	136	
4	7 ¹ / ₂	329.25	.46	1.41	1.41	89	2	250	60	134	
5	10	331.00	.46	1.41	1.41	90	3	250	60	133	
6	12 ¹ / ₂	332.74	.44	1.35	1.35	90	3	250	60	132	
7	15	334.41	.46	1.41	1.41	90	3	250	60	132	
8	17 ¹ / ₂	336.08	.50	1.53	1.53	91	4	250	60	133	
9	20	337.84	.50	1.53	1.53	92	5	250	60	134	
10	22 ¹ / ₂	339.59	.50	1.53	1.53	93	5	250	60	134	
11	25	341.27	.45	1.38	1.38	93	5	250	60	144	
12	27 ¹ / ₂	342.69	.42	1.29	1.29	94	6	250	60	144	
A 1	30/0	344.532	.38	1.20	1.20	94	6	250	60	144	
2	32 ¹ / ₂	345.780									
3	35										
4	37 ¹ / ₂										
5	40										
6	42 ¹ / ₂										
7	45										
8	47 ¹ / ₂										
9	50										
10	52 ¹ / ₂										
11	55										
12	57 ¹ / ₂										

20.942 .4420

1.36 91

136

V_M

(ΔP)²

ΔH

T_M

T_S

ENTROPY

PARTICULATE FIELD DATA

0.4

COMPANY NAME NICHOLS RUN NUMBER 05
 ADDRESS GREENSBORO, NC TIME START 1228
 SAMPLING LOCATION SCRUBBER STACK TIME FINISH 1330
 DATE 10-2-85 TEAM LEADER MM TECHNICIANS RW
 BAROMETRIC PRESSURE, IN. HG 29.3 STATIC PRESSURE, IN. H₂O -1.0
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 10(F)
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.005 0.004

EQUIPMENT CHECKS	IDENTIFICATION NUMBERS
☒ PITOTS, PRE-TEST ☒ PITOTS, POST-TEST ☒ ORSAT SAMPLING SYSTEM ☒ TEDLAR BAG ☒ THERMOCOUPLE @ <u>132</u> °F	REAGENT BOX <u>218</u> NOZZLE <u>304</u> DIAMETER <u>2.48</u> METER BOX <u>RAC1</u> T/C READOUT <u>01</u> UMBILICAL _____ T/C PROBE <u>5-11</u> SAMPLE BOX _____ ORSAT PUMP <u>05</u> PROBE <u>4-3</u> TEDLAR BAG <u>20</u>
FILTER # TARE	NOMOGRAPH SET-UP NOMOGRAPH #
<u>E 3632</u> <u>.4888</u> _____ _____	ΔH _g <u>1.76</u> C FACTOR <u>90</u> <u>.97</u> METER TEMP <u>95</u> <u>90</u> STACK TEMP <u>130</u> % MOISTURE <u>6</u> REF. ΔP <u>.58</u> <u>.55</u>

TOTAL MOISTURE

105.5

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H ₂ O	ORIFICE SETTING (ΔH), IN. H ₂ O		GAS METER TEMP, °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP, °F	IMP. EXIT TEMP, °F	STACK TEMP, °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
A 1	0	346.767	.48	1.52	1.52	82	2	250	60	132	
2	2 1/2	347.88	.49	1.57	1.57	83	2	250	60	132	
3	5	349.49	.53	1.70	1.70	82	3	250	60	132	- NOMO
4	7 1/2	351.02	.53	1.80	1.80	82	4	250	60	133	
5	10	353.27	.53	1.80	1.80	82	4	250	60	133	
6	12 1/2	354.86	.51	1.73	1.73	82	4	250	60	134	
7	15	356.86	.44	1.50	1.50	83	4	250	60	135	
8	17 1/2	358.42	.43	1.45	1.45	84	4	250	60	136	
9	20	360.06	.42	1.42	1.42	85	5	250	60	136	
10	22 1/2	361.69	.41	1.38	1.38	86	5	250	60	137	
11	25	363.75	.42	1.42	1.42	86	6	250	60	138	
12	27 1/2	364.88	.41	1.38	1.38	86	6	250	60	139	
B 1	30 1/2	366.530	.40	1.38	1.35	87	6	250	60	138	
2	32 1/2	368.28	.40	1.35	1.35	87	6	250	60	138	
3	35	369.63	.44	1.50	1.50	88	7	250	60	138	
4	37 1/2	371.45	.45	1.52	1.52	89	7	250	60	141	
5	40	373.12	.45	1.52	1.52	89	7	250	60	145	
6	42 1/2	374.71	.47	1.50	1.50	90	8	250	60	145	
7	45	376.37	.44	1.50	1.50	90	8	250	60	145	
8	47 1/2	378.00	.47	1.60	1.60	92	9	250	60	144	
9	50	379.83	.50	1.70	1.70	93	9	250	60	144	
10	52 1/2	381.69	.50	1.70	1.70	93	9	250	60	144	
11	55	383.31	.50	1.70	1.70	95	10	250	60	144	
12	57 1/2	385.27	.50	1.70	1.70	96	10	250	60	143	
60 OFF		386.825	16.2974								

40.5611 (1.6791) .4611

1.55 87

138.6
139

V_M

(ΔP)²

ΔH

T_M

T_S

ENTROPY

PARTICULATE FIELD DATA

COMPANY NAME NICHOLS RUN NUMBER 0-5
 ADDRESS GREENSBORO, NC TIME START 0915
 SAMPLING LOCATION SCRUBBED STACK TIME FINISH 1253
 DATE 10-3-85 TEAM LEADER MM TECHNICIANS RW
 BAROMETRIC PRESSURE, IN. HG 29.3 STATIC PRESSURE, IN. H₂O -1.10
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 10(E)
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.006 0.017

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
☒ PITOTS, PRE-TEST		REAGENT BOX	NOZZLE <u>304</u> DIAMETER <u>.244</u>
☒ PITOTS, POST-TEST		METER BOX <u>RAC 1</u>	T/C READOUT <u>01</u>
☒ ORSAT SAMPLING SYSTEM		UMBILICAL	T/C PROBE <u>5-11</u>
☒ TEDLAR BAG		SAMPLE BOX	ORSAT PUMP <u>05</u>
☒ THERMOCOUPLE @ <u> </u> °F		PROBE <u>4-3</u>	TEDLAR BAG <u>20</u>

FILTER #		TARE	NOMOGRAPH SET-UP		NOMOGRAPH #
<u> </u>	<u> </u>	<u> </u>	ΔH@ <u>1.76</u>	C FACTOR <u>.95</u>	<u>MM</u>
<u> </u>	<u> </u>	<u> </u>	METER TEMP <u>80</u>	STACK TEMP <u>140</u>	
<u> </u>	<u> </u>	<u> </u>	% MOISTURE <u>7</u>	REF. ΔP <u>.58</u>	

Restarted
(1040) ←

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H ₂ O	ORIFICE SETTING (ΔH), IN. H ₂ O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK... CHECK READINGS
				IDEAL	ACTUAL						
B 1	0	408.697	39.42	1.24	1.33	71	2	250	60	138	
2	2½	410.340	.46	1.45	1.45	71	2	250	60	134	
3	5	411.89	.47	1.45	1.49	74	2	250	60	134	
4	7½	413.57	.50	1.58	1.58	75	2	250	60	139	
5	10	415.03	.50	1.58	1.58	79	4	250	60	140	
6	12½	416.68	.47	1.49	1.49	82	4	250	60	141	
7	15	418.25	.46	1.42	1.42	81	5	250	60	141	
8	17½	419.97	.46	1.45	1.45	79	5	250	60	141	
9	20	421.54	.47	1.49	1.49	80	5	250	60	141	
10	22½	423.15	.45	1.42	1.42	81	6	250	60	142	
11	25	424.90	.48	1.52	1.52	80	6	250	60	142	
12	27½	426.85	.47	1.49	1.49	73	6	250	60	139	STOP TEST 1107
A 1	30/0	428.308	.42	1.33	1.33	74	6	250	60	132	STARTED 1220
2	2½	429.30	.44	1.40	1.40	75	6	250	60	132	
3	5	431.55	.44	1.40	1.40	76	7	250	60	135	
4	7½	433.16	.46	1.45	1.45	77	8	250	60	139	
5	10	434.87	.45	1.42	1.42	77	8	250	60	140	
6	12½	436.53	.43	1.36	1.36	78	8	250	60	140	
7	15	438.02	.40	1.27	1.27	78	8	250	60	140	
8	17½	439.58	.37	1.17	1.17	80	8	250	60	140	
9	20	441.03	.40	1.27	1.27	81	8	250	60	141	
10	22½	442.66	.39	1.24	1.24	82	8	250	60	141	
11	25	444.15	.40	1.27	1.27	82	8	250	60	141	
12	27½	445.68	.38	1.21	1.21	83	8	250	60	141	
60/0FF		447.202									

38.605 .4401

1.40 78

139

V_M

(ΔP)²

ΔH

T_M

T_S

PARTICULATE SAMPLING LABORATORY RESULTS

Plant Name NICHOLS EEI Ref. # 2988

Sampling Location SCRUBBER STACK

Date Received 10/2 Date Analyzed 10/8 Reagent Box(es) 0277

Run Number

0-1
3

0-3
4

Run Date

10/1

10/1

SUMMARY OF PARTICULATE ANALYSES

Sum of Particulate, mg. 571.0 565.7

Total Filter Tare mg. 484.6 500.4

Blank Residue, mg. (100 ml) 0.2 (100 ml) 0.2 (ml)

TOTAL PARTICULATE CATCH, mg.

86.2

65.1

ANALYSIS OF MOISTURE CATCH

Reagent 1 (H₂O):

Final Weight, g.

236.0

223.0

Tared Weight, g.

200.0

200.0

200.0

Water Catch, g.

36.0

23.0

Reagent 2 ():

Final Weight, g.

-

-

-

Tared Weight, g.

-

-

-

Water Catch, g.

-

-

-

CONDENSED WATER, g.

36.0

23.0

Silica Gel:

Final Weight, g.

215.5

213.0

Tared Weight, g.

200.0

200.0

200.0

ABSORBED WATER, g.

15.5

13.0

TOTAL WATER COLLECTED, g.

51.5

36.0

Blank Beaker # 12

Final wt. mg. 49974.2

Tare wt. mg. 49973.9

Residue, mg. 0.3

Volume, ml. 200

Concen., mg/ml. .0015

--- Legend ---

✓ = Final Weight

L = Loose Particulate

F = Filter D = Dish

R = Rinse P = Pan

Notes and Comments

LABORATORY SAMPLE WEIGHT CALCULATIONS

Plant Name NICHOLS

EEI Ref. # 2988

Run Number

30-1

A 0-3

Run Date

10/1

10/1

Sample ID/Container #

F&R-271

F&R-272

141.7241

148.0609

✓ 141.7233

✓ 148.0604

141.7257

148.0613

141.7268

148.0625

Tare Wt., g.

141.1523

147.4947

SAMPLE WT., g.

5710

5657

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.

PARTICULATE SAMPLING LABORATORY RESULTS

Plant Name NICHOLS EEI Ref. # 2988
 Sampling Location SCRUBBER STACK
 Date Received 10/3 Date Analyzed 10/9 Reagent Box(es) _____

Run Number	<u>0-5</u>	<u>0-4</u>	_____
Run Date	<u>10/3</u>	_____	_____

SUMMARY OF PARTICULATE ANALYSES

Sum of Particulate, mg.	<u>632.3</u>	<u>636.1</u>	_____
Total Filter Tare mg.	<u>494.2</u>	<u>488.8</u>	_____
Blank Residue, mg. (<u>140</u> ml)	<u>0.2</u>	(<u>150</u> ml) <u>0.2</u>	(_____ ml) _____

TOTAL PARTICULATE CATCH, mg.	137.9	147.1	
------------------------------	---	---	---

ANALYSIS OF MOISTURE CATCH

Reagent 1 (H₂O):

Final Weight, g.	<u>282.0</u>	<u>285.0</u>	_____
Tared Weight, g.	<u>200.0</u>	<u>200.0</u>	_____
Water Catch, g.	<u>82.0</u>	<u>85.0</u>	_____

Reagent 2 (_____):

Final Weight, g.	—	—	_____
Tared Weight, g.	—	—	_____
Water Catch, g.	—	—	_____

CONDENSED WATER, g.	<u>82.0</u>	<u>85.0</u>	_____
---------------------	-------------	-------------	-------

Silica Gel:

Final Weight, g.	<u>216.0</u>	<u>220.5</u>	_____
Tared Weight, g.	<u>200.0</u>	<u>200.0</u>	_____

ABSORBED WATER, g.	<u>16.0</u>	<u>20.5</u>	_____
--------------------	-------------	-------------	-------

TOTAL WATER COLLECTED, g.	98.0	105.5	
---------------------------	--	---	---

Blank Beaker # 12

Final wt. mg. 49974.2
 Tare wt. mg. 49973.9
 Residue, mg. 0.3
 Volume, ml. 200

Concen., mg/ml.

.0015

--- Legend ---

✓ = Final Weight
 L = Loose Particulate
 F = Filter D = Dish
 R = Rinse P = Pan

Notes and Comments

LABORATORY SAMPLE WEIGHT CALCULATIONS

Plant Name NICHOLS

EEI Ref. # 298E

Run Number

0-5

0-4

Run Date

10/3

Sample ID/Container #

FR-315

FR-298

Tare Wt., g.

133.3115
✓ 133.3111
132.6788

146.4589
✓ 146.4586
146.4591
146.4643
145.8225

SAMPLE WT., g.

.6323

.6361

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.

CUSTODY SHEET FOR REAGENT BOX # 0277Date of Makeup 9/25/85 Initials MLD Locked ☒Individual Tare of Reagent: 2.00 mls. of H₂O

Individual Tare of Reagent: _____ mls. of _____

Individual Silica Gel Tare Weight 2.00 gms.PLANT NAME NICHOLSSAMPLING LOCATION SCRUBBER STACK

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked?
0-1 <u>3</u>	<u>10-1-85</u>	<u>MLT</u>	☒	<u>10-1</u>	<u>50</u>	<u>MLT</u>	☒
0-3 <u>4</u>	<u>10-1</u>	<u>MLT</u>	☒				

Received in Lab Date 10/2 Initials MLT Locked? ☒Sampling Method: M-5Zero & Span Balance
Initials MLT

Filter #	Tare Weight (mgms)	Used on Test
----------	--------------------	--------------

Remarks:

E 3856 .484 3 0-1E 3706 .500 4 0-3

CUSTODY SHEET FOR REAGENT BOX # 0218

Date of Makeup 9/13 Initials MSJ Locked? ☒
Individual Tare of Reagent: 200 mls. of H₂O
Individual Tare of Reagent: _____ mls. of _____
Individual Silica Gel Tare Weight 200 gms.

PLANT NAME

NICHOLS

SAMPLING LOCATION

SCRUBBER STACK

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked?
0.4 1-5	10-2	MMK	✓	10-2	70	MMK	✓
0-5 0-6	10-3	MMK	✓	10-3	70	MMK	✓

Received in Lab Date 10/2 Initials MSJ Locked? ☒

Sampling Method: _____

Zero & Span Balance
Initials MSJ

Filter #	Tare Weight (mgms)	Used on Test
----------	--------------------	--------------

Remarks:

E 3632	.4888	0-4
E 3631	.4942	0-5
_____	_____	_____
_____	_____	_____
_____	_____	_____

B. FIELD AND ANALYTICAL DATA

2. Particle Size Distribution

a. Scrubber Inlet

SI-1

14c
$$\frac{2.572}{V_M} \quad \frac{.27}{(\sqrt{\Delta P})^2} \quad \frac{.30}{\Delta H} \quad \frac{104}{T_M} \quad \frac{216}{T_S} \quad \frac{167}{T_S}$$

ENTROPY

SI-4

[illegible]

.49 03
 ΔH T_m

957

ENTROPY

SI-5

[illegible]

933

T_g

ENTROPY

PARTICLE SIZING LABORATORY DATA

CUSTOMER NICHOLS JOB # 2988 SAMPLING LOCATION SCRUBBER INLET

DATE 10/1-2-3 ANALYST McGowan

RUN SI1

RUN SI4

RUN SI5

STAGE	PARTICULATE FILTER				PARTICULATE FILTER				PARTICULATE FILTER			
	FILTER NUMBER	AND FILTER WEIGHT (mg)	TARE (mg)	CATCH (mg)	FILTER NUMBER	AND FILTER WEIGHT (mg)	TARE (mg)	CATCH (mg)	FILTER NUMBER	AND FILTER WEIGHT (mg)	TARE (mg)	CATCH (mg)
PtN	—	—	—	64.1	PtN	—	—	66.3	PtN	—	—	79.4
0	PI			0.7	PI	—	—	0.3	PI	—	—	0.0
1	457	209.9	209.7	0.2	450	211.7	209.9	1.8	415	207.9	207.2	0.7
2	458	206.5	206.2	0.3	451	208.1	207.5	0.6	416	207.4	206.9	0.5
3	459	207.9	207.0	0.9	452	209.1	208.6	0.5	417	207.3	206.6	0.7
4	461	205.7	205.1	0.7	453	208.6	208.3	0.2	418	210.2	209.4	0.8
5	461	205.7	205.1	0.6	454	208.5	208.3	0.2	419	208.6	207.3	1.3
6	462	207.5	206.4	1.1	455	209.3	208.0	1.3	420	207.8	206.7	1.1
7	463	208.1	206.7	1.4	456	209.5	207.8	1.7	421	207.5	206.5	1.0
BU	SF323	219.1	209.2	9.9	SF322	220.0	208.6	11.4	SF317	216.4	209.2	7.2

PI = Pre-impactor

PIN = PROBE AND NOZZLE

BU = Back-up Filter

B. FIELD AND ANALYTICAL DATA

2. Particle Size Distributions

b. Scrubber Stack

50-

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H ₂ O	ORIFICE SETTING (ΔH), IN. H ₂ O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK EX. CHECK TEMP. °F
				IDEAL	ACTUAL					
B 2	01	301.573	.43	.28	.28	103	1	—	65	125
	51	302.69			.28	106	1		65	125
	10	304.58			.28	107	1		65	125
	15	306.15			.28	106	2		65	125
	20	307.65			.28	105	2		65	125
	25	309.21			.28	105	2		65	125
	30	310.72			.28	104	2		65	125
B 7	35	312.28			.28	103	2		65	125
	40	313.8			.28	102	2		65	125
	45	315.35			.28	101	3		65	125
	50	316.84			.28	100	3		65	125
	55	318.41			.28	98	3		65	125
	60	319.98			.28	97	3		65	125
	65	321.52			.28	97	3		65	125
	70	323.06			.28	99	3		65	125
	75 OFF	324.548								

125

ENTROPY

50-4

139

T₈

ENTROPY

50-5

136
T₈

PARTICLE SIZING LABORATORY DATA

CUSTOMER NICHOLS JOB # 2908 ANALYST MS Jackson SAMPLING LOCATION SCRUBBER Stack

DATE 10/1-2-3

RUN SO1

RUN SO2

RUN SO3

STAGE	PARTICULATE FILTER			PARTICULATE FILTER			PARTICULATE FILTER		
	FILTER NUMBER	AND FILTER WEIGHT (mg)	TARE (mg)	CATCH (mg)	FILTER NUMBER	AND FILTER WEIGHT (mg)	TARE (mg)	CATCH (mg)	FILTER TARE (mg)
Nozzle	—	—	—	2.4	Nozzle	—	—	0.4	—
1	1554	165.6	164.1	0.1	1541	151.1	141.1	1.1	15.1
2	1558	148.0	147.5	0.5	A 424	129.5	128.1	1.4	126.4
3	1559	165.4	164.5	0.9	B 425	143.8	142.0	1.8	152.7
4	1559	148.5	148.1	0.4	A 425	128.5	126.9	1.6	127.9
5	1560	165.9	165.4	0.5	B 426	145.0	142.9	2.1	143.5
6	1560	150.1	147.8	2.3	A 426	149.9	146.6	3.3	126.5
7	1561	169.0	164.2	4.8	B 427	167.6	162.3	5.3	144.2
8	1561	151.9	147.8	4.1	A 427	150.0	145.4	4.6	146.4
BU	1561	320.7	272.1	48.6	SF180	313.9	267.3	46.6	266.2
					SF179	303.6			37.4

PI = Pre-impactor
BU = Back-up Filter

APPENDIX C

SAMPLING AND ANALYTICAL PROCEDURES

ENTROPY

3.3 END-TO-END CALIBRATION

Before actual sampling is begun, it is strongly recommended that an end-to-end calibration be performed at ambient conditions with a dry gas meter which has already been calibrated against a primary standard. As is, the flowmeter provides 95% accuracy for full scale reading; however, this accuracy will decrease at lower flow rates. For this reason, an end-to-end calibration at 3 or 4 points with a dry gas meter will provide extremely accurate flow information at any desired flow rate and can be accomplished in 10 - 15 minutes. Simply plot Flow Rate (as determined with the dry gas meter and stop watch) vs. flowmeter reading. Draw a line through the points and in this manner accurate, instantaneous flow measurements at any rate can be accomplished with only the flowmeter during actual stack sampling. The above calibration to be performed as quickly as possible to avoid any collection in stack head.

4.0 STACK SAMPLING PROCEDURE

Stack Sampling is simple in principle, but in practice it is complicated by the need to ensure that the collected particulates are representative of the particulates flowing at any one sampling point and also at all possible points in the cross section of the flue at the sampling position. The first requirement is satisfied by isokinetic sampling in which the inlet sampling nozzle velocity is equal and in the same direction as the flue gas velocity. The weight of particulates collected is then equal to the weight of particulates flowing through an area in the flue equal to the area of the sampling nozzle. If sampling is not isokinetic, the gas flow lines are disturbed by the presence of the nozzle and either too few or too many particles are collected.

The second requirement, ensuring that the sample is representative of the average particle flow past the sampling position, presents no problem when the distribution of solids flow is uniform over the area of the flue. Samples taken at all points will be identical and any chosen point will give a representative sample. The weight of solids E passing through the flue per unit time is then found by multiplying the weight w/t collected per unit time at the sampling point (w being the weight collected during the time t) by the ratio of the area A of the flue to the area a of the nozzle:

$$E = \frac{w}{t} \cdot \frac{A}{a}$$

However, the particulates are not usually distributed uniformly over the cross-sectional area of the flue and it is necessary to collect the sample in increments taken separately at each point and the average weight calculated from the separate observations, which is called incremental sampling. Or a single gross sample may be collected by moving the sampling nozzle from point to point which is called cumulative sampling. The incremental method is recommended for the beginner because it is easier to spot mistakes. Also, it is preferred by research investigators and is recommended for those who require the best accuracy because it gives information on the reliability of the average. The cumulative method may be slightly quicker and may be preferred by those doing routine testing not requiring the highest degree of accuracy. Incremental sampling is recommended when using the Andersen Stack Sampler. The cumulative method may be used on occasion and will be discussed later.




Figure 1-3. Example showing circular stack cross section divided into 12 equal areas, with location of traverse points indicated.

Table 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter																						
	2	4	6	8	10	12	14	16	18	20	22	24											
1	14.6	6.7	4.4	3.2	2.5	2.1	1.8	1.6	1.4	1.3	1.1	1.1											
2	25.4	23.8	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2											
3		75.0	39.5	19.4	14.5	11.8	9.9	8.5	7.5	6.7	6.0	5.5											
4			90.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7											
5				85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6											
6					95.5	80.6	65.8	56.6	48.0	40.8	35.4	30.5											
7						89.5	77.4	64.4	53.1	43.6	36.0	30.2											
8							90.4	78.0	63.4	52.5	43.0	36.1											
9								91.8	82.3	72.1	62.5	53.0											
10									92.2	83.1	73.0	63.5											
11										93.3	84.4	74.5											
12											94.1	85.1											
13												94.7											
14													95.2										
15														95.6									
16															95.9								
17																96.2							
18																	96.4						
19																		96.6					
20																			96.8				
21																				96.9			
22																					97.0		
23																						97.1	
24																							97.2




Figure 1-4. Example showing rectangular stack cross section divided into 12 equal areas, with a traverse point at centroid of each area.

Level and zero the manometer. Connect a Type B pitot tube to the manometer. Position the Type B pitot tube at each traverse point, in succession, so that the planes of the face openings of the pitot tube are perpendicular to the stack cross-sectional plane; when the Type B pitot tube is in this position, it is at "0" reference. Note the differential pressure (Δp) reading at each traverse point. If a null (zero) pitot reading is obtained at 0° reference at a given traverse point, an acceptable flow condition exists at that point. If the pitot reading is not zero at 0° reference, rotate the pitot tube up to 45° yaw angle, until a null reading is obtained. Carefully determine and record the value of the rotation angle (α) to the nearest degree. After the null technique has been applied at each traverse point, calculate the average of the cosine values of α ; assign a value of 0° to those points for which no rotation was required, and include those in the overall average. If the average value of α is greater than 10°, the overall flow condition in the stack is unacceptable and alternative methodology, subject to the approval of the Administrator, must be used to perform accurate sample and velocity traverses.

1. Bibliography

1. Determining Dust Concentration in a Gas Stream. ASME Performance Test Code No. 21. New York, NY.
2. Devortin, Howard, et al. Air Pollution Source Testing Manual. Air Pollution Control District, Los Angeles, CA. November 1963.
3. Methods for Determination of Velocity, Volume, Dust and Mass Content of Gases. Western Precipitation Division of Joy Manufacturing Co. Los Angeles, CA. Bulletin WP-44. 1966.
4. Standard Method for Sampling Stacks for Particulate Matter. In: 1971 Book of ASTM Standards, Part 23. ASTM Designation D-2909-71. Philadelphia, Pa. 1971.
5. Hanson, H. A., et al. Particulate Sampling Strategies for Large Power Plants Including Nonuniform Flow. THEPA, ORD, ESRL, Research Triangle Park, N.C. EPA-600/2-76-170. June 1976.
6. Entropy Environmentalists, Inc. Determination of the Optimum Number of Sampling Points: An Analysis of Method 1 Criteria. Environmental Protection Agency, Research Triangle Park, N.C. EPA Contract No. 68-02-3172. Task 7.
7. Hanson, H.A., R.J. Davini, J.K. Morgan, and A.A. Iversen. Particulate Sampling Strategies for Large Power Plants Including Nonuniform Flow. U.S. Environmental Protection Agency, Research Triangle Park, N.C. Publication No. EPA-600/2-76-170. June 1976. 350 p.
8. Brooks, E.F., and R.L. Williams. Flow and Gas Sampling Manual. U.S. Environmental Protection Agency, Research Triangle Park, N.C. Publication No. EPA-600/2-76-203. July 1976. 93 p.
9. Entropy Environmentalists, Inc. Traverse Point Study. EPA Contract No. 68-02-3172. June 1977. 19 p.
10. Brown, J. and K. Yu. Test Report: Particulate Sampling Strategy in Circular Ducts. Emission Measurement Branch, Emission Standards and Engineering Division. U.S. Environmental Protection Agency, Research Triangle Park, N.C. 27711. July 31, 1980. 12 p.
11. Hawksley, P.G.W., S. Badzioch, and J.H. Backett. Measurement of Solids in Flue Gases. Leatherhead, England, The British Coal Utilisation Research Association, 1961. p. 129-133.
12. Knapp, K.T. The Number of Sampling Points Needed for Representative Source Sampling. In: Proceedings of the Fourth National Conference on Energy and the Environment. Theodore, L., et al. (ed.). Dayton, Dayton Section of the American Institute of Chemical Engineers. October 3-7, 1971. p. 563-568.

PROPOSED REVISION - OCTOBER 29, 1984

SEE ATTACHED

METHOD 2—DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE (TYPE S PIVOT TUBE)

1. Principle and Applicability

1.1 Principle. The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Stauscheibe or reverse type) pivot tube.

1.2 Applicability. This method is applicable for measurement of the average velocity of a gas stream and for quantifying gas flow.

This procedure is not applicable at measurement sites which fail to meet the criteria of Method 1, Section 2.1. Also, the method cannot be used for direct measurement in cyclonic or swirling gas streams; Section 2.4 of Method 1 shows how to determine cyclonic or swirling flow conditions. When unacceptable conditions exist, alternative procedures, subject to the approval of the Administrator, U.S. Environmental Protection Agency, must be employed to make accurate flow rate determinations; examples of such alternative procedures are: (1) to install straightening vanes; (2) to calculate the total volumetric flow rate stoichiometrically, or (3) to move to another measurement site at which the flow is acceptable.

2. Apparatus

Specifications for the apparatus are given below. Any other apparatus that has been demonstrated (subject to approval of the Administrator) to be capable of meeting the specifications will be considered acceptable.

2.1 Type S Pivot Tube. The Type S pivot tube (Figure 2-1) shall be made of metal tubing (e.g., stainless steel). It is recommended that the external tubing diameter (dimension D , Figure 2-2b) be between 0.63 and 0.85 centimeters ($1/4$ and $1/2$ inch). There shall be an equal distance from the base of each leg of the pivot tube to its face opening plane (dimension P_1 and P_2 , Figure 2-2b); it is recommended that this distance be between 1.25 and 1.50 times the external tubing diameter. The face openings of the pivot tube shall, preferably, be aligned as shown in Figure 2-2; however, slight misalignments of the openings are permissible (see Figure 2-3).

The Type S pivot tube shall have a known coefficient, determined as outlined in Section 4. An identification number shall be assigned to the pivot tube; this number shall be permanently marked or engraved on the body of the tube.

Figure 2-1. Type S pivot tube manometer assembly.





Figure 2-2. Properly constructed Type S pivot tube, shown in: (a) end view; face opening planes perpendicular to transverse axis; (b) top view; face opening planes parallel to longitudinal axis; (c) side view; both legs of equal length and concentric construction, when viewed from both sides. Base-line coefficient values of 0.84 may be assigned to pivot tubes constructed this way.




Figure 2-3. Types of face opening misalignment that can result from field use or improper construction of Type S pivot tubes. These will not affect the base-line value of C if α is less than 45° and $\alpha_2 < 10^\circ$, P_1 and $P_2 < 0.75 \times D$, $D < 0.85$ cm (0.033 in.) and $w < 0.02$ cm (0.003 in.) between 11 to Section 4.

A standard pitot tube may be used instead of a Type B, provided that it meets the specifications of Sections 2.7 and 2.8; note, however, that the static and impact pressure holes of standard pitot tubes are susceptible to plugging in particulate-laden gas streams. Therefore, whenever a standard pitot tube is used to perform a traverse, adequate provision must be furnished that the openings of the pitot tube have not plugged up during the traverse period; this can be done by taking a velocity head (Δp) reading at the final traverse point, cleaning out the impact and static holes of the standard pitot tube by "back-purging" with pressurized air, and then taking another Δp reading. If the Δp readings made before and after the air purge are the same (± 5 percent), the traverse is acceptable. Otherwise, repeat the run. Note that if Δp at the final traverse point is unacceptably low, another point may be selected. If "back-purging" at regular intervals is part of the procedure, then comparative Δp readings shall be taken, as above, for the last two back purges at which notably high Δp readings are observed.

2.2 Differential Pressure Gauge. An inclined manometer or equivalent device is used. Most gauging units are equipped with a 10-in. (water column) inclined vertical manometer, having 0.01-in. H₂O divisions on the 0- to 1-in. inclined scale, and 0.1-in. H₂O divisions on the 1- to 10-in. vertical scale. This type of manometer for other gauges of equivalent sensitivity is acceptable for the measurement of Δp values as low as 1.5 mm (0.06 in.) H₂O. However, a differential pressure gauge of greater sensitivity shall be used subject to the approval of the Administrator. If any of the following is found to be true: (1) the arithmetic average of all Δp readings at the traverse points in the stack is less than 1.5 mm (0.06 in.) H₂O; (2) for traverses of 12 or more points, more than 10 percent of the individual Δp readings are below 1.5 mm (0.06 in.) H₂O; (3) the traverse of fewer than 12 points more than one Δp reading is below 1.5 mm (0.06 in.) H₂O. Citation 16 in Section 6 describes commercially available instrumentation for the measurement of low-range gas velocities.

As an alternative to criteria (1) through (3) above, the following calculation may be performed to determine the necessity of using a more sensitive differential pressure gauge:

$$T = \frac{\sum_{i=1}^n \sqrt{\Delta p_i + K}}{\sum_{i=1}^n \sqrt{\Delta p_i}}$$

where:

Δp_i = Individual velocity head reading at a traverse point, mm H₂O (in. H₂O).

n = Total number of traverse points.

K = 0.15 mm H₂O when metric units are used and 0.005 in. H₂O when English units are used.

If T is greater than 1.05, the velocity head data are unacceptable and a more sensitive differential pressure gauge must be used.

Note.—If differential pressure gauges other than inclined manometers are used (e.g., magnohelic gauges), their calibration must be checked after each test series. To check the calibration of a differential pressure gauge, compare Δp readings of the gauge with those of a gauge-oil manometer at a minimum of three points, approximately representing the range of Δp values in the stack. If, at each point, the values of Δp as read by the differential pressure gauge and gauge-oil manometer agree to within 5 percent, the differential pressure gauge shall be considered to be in proper calibration. Otherwise, the test series shall either be voided, or procedures to adjust the measured Δp values and final results shall be used, subject to the approval of the Administrator.

2.3 Temperature Gauge. A thermocouple, liquid-filled bulb thermometer, limetallic thermometer, mercury-in-glass thermometer, or other gauge capable of measuring temperature to within 1.5 percent of the minimum absolute stack temperature shall be used. The temperature gauge shall be attached to the pitot tube such that the sensor tip does not touch any metal; the gauge shall be in an interference-free arrangement with respect to the pitot tube face openings (see Figure 2-1 and also Figure 2-7 in Section 4). Alternate positions may be used if the pitot tube-temperature gauge system is calibrated according to the procedure of Section 4. Provided that a difference of not more than 1 percent in the average velocity measurement is introduced, the tem-

perature gauge need not be attached to the pitot tube; this alternative is subject to the approval of the Administrator.

2.4 Pressure Probe and Gauge. A piezometer tube and manometer, or water-filled U-tube manometer capable of measuring stack pressure to within 2.5 mm (0.1 in.) Hg is used. The static tap of a standard type pitot tube or one leg of a Type B pitot tube with the legs opening planes positioned parallel to the gas flow may also be used as the pressure probe.

2.5 Barometer. A mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in. Hg) may be used. In many cases, the barometric reading may be obtained from a nearby national weather service station, in which case the station value (which is the absolute barometric pressure) shall be requested and an adjustment for elevation difference between the weather station and the sampling point shall be applied at a rate of minus 2.5 mm (0.1 in.) Hg per 10-meter (330 feet) elevation increase, or vice-versa for elevation decrease.

2.6 Gas Density Determination Equipment. Method 3 equipment, if needed (see Section 3.6), to determine the stack gas dry molecular weight, and Method 4 or Method 5 equipment for moisture content determination; other methods may be used subject to approval of the Administrator.

2.7 Calibration Pitot Tube. When calibration of the Type B pitot tube is necessary (see Section 6), a standard pitot tube is used as a reference. The standard pitot tube shall, preferably, have a known coefficient, obtained either (1) directly from the National Bureau of Standards, Route 270, Quince Orchard Road, Gaithersburg,

Maryland, or (2) by calibration against another standard pitot tube with an NBS-traceable coefficient. Alternatively, a standard pitot tube designed according to the criteria given in 2.7.1 through 2.7.5 below and illustrated in Figure 2-4 (see also Citations 7, 8, and 17 in Section 6) may be used. Pitot tubes designed according to these specifications will have bearing coefficients of about 0.99±0.01.

2.7.1 Hemispherical (shown in Figure 2-4), ellipsoidal, or conical tip.

2.7.2 A minimum of six diameters straight run (based upon D , the external diameter of the tube) between the tip and the static pressure holes.

2.7.3 A minimum of eight diameters straight run between the static pressure holes and the centerline of the external tube, following the 90 degree bend.

2.7.4 Static pressure holes of equal size (approximately 0.1 D), equally spaced in a piezometer ring configuration.

2.7.5 Ninety degree bend, with curved or mitered junction.

2.8 Differential Pressure Gauge for Type B Pitot Tube Calibration. An inclined manometer or equivalent is used. If the single-velocity calibration technique is employed (see Section 4.1.2.2), the calibration differential pressure gauge shall be readable to the nearest 0.15 mm H₂O (0.006 in. H₂O). For multi-velocity calibrations, the gauge shall be readable to the nearest 0.15 mm H₂O (0.006 in. H₂O) for Δp values below 1.5 and 25 mm H₂O (0.06 and 1.0 in. H₂O), and to the nearest 1.5 mm H₂O (0.06 in. H₂O) for Δp values above 25 mm H₂O (1.0 in. H₂O). A special, more sensitive gauge will be required to read Δp values below 1.5 mm H₂O (0.06 in. H₂O) (see Citation 16 in Section 6).




Figure 2-4. Standard pitot tube design specifications.

3. Procedure

3.1 Set up the apparatus as shown in Figure 2-1. Capillary tubing or surge tanks installed between the manometer and pitot tube may be used to dampen Δp fluctuations. It is recommended, but not required, that a pretest leak-check be conducted, as follows: (1) blow through the pitot impact opening until at least 7.6 cm (3 in.) H₂O velocity pressure registers on the manometer; then, close off the impact opening. The pressure shall remain stable for at least 15 seconds; (2) do the same for the static pressure side, except using suction to obtain the minimum of 7.6 cm (3 in.) H₂O. Other leak-check procedures, subject to the approval of the Administrator, may be used.

3.2 Level and zero the manometer. Because the ma-

nometer level and zero may drift due to vibrations and temperature changes, make periodic checks during the traverse. Record all necessary data as shown in the example data sheet (Figure 2-5).

3.3 Measure the velocity head and temperature at the traverse points specified by Method 1. Ensure that the proper differential pressure gauge is being used for the range of Δp values encountered (see Section 2.2). If it is necessary to change to a more sensitive gauge, do so, and remeasure the Δp and temperature readings at each traverse point. Conduct a post-test leak-check (mandatory), as described in Section 3.1 above, to validate the traverse run.

3.4 Measure the static pressure in the stack. One reading is usually adequate.

3.5 Determine the atmospheric pressure.

2.3 Determine the cross-sectional area of the stack or duct at the sampling location. Whenever possible, physically measure the stack dimensions rather than using blueprints.

4. Collection

4.1 **Type 8 Pilot Tube.** Before its initial use, carefully examine the Type 8 pilot tube in top, side, and end views to verify that the flow openings of the tube are aligned within the specifications illustrated in Figure 3-6 or 3-7. The pilot tube shall not be used if it fails to meet these alignment specifications.

After verifying the line opening alignment, measure and record the following dimensions of the slit tube:

(a) the external tubing diameter (dimension D , Figure 2-25); and (b) the mean-square plane distance D_{ms} between the centers of the tubes (Figure 2-25). If D is between 0.45 and 0.65 (3), and if D_{ms} is between 0.45 and 0.65, then P_s and P_p are equal and between 1.55 and 1.56. If D and D_{ms} are equal and between 1.55 and 1.56, then there are two possible options: (1) the pilot tube may be substituted according to the procedure outlined in Section 4.1.5 through 4.1.8 below, or (2) a baseline (dashed tube) having a value of 0.64 may be assigned to the pilot tube. Note, however, that if the pilot tube is part of an assembly, substitution may still be required. Despite knowledge of the baseline coefficient values (see Section 4.1.1),

If D_1 , P_1 , and P_2 are outside the specified limits, the pitot tube must be calibrated as outlined in 4.1.2 through 4.1.4 below.

4.1.1 Type S Pitot Tube Assemblies. During nacelle and velocity traverses, the isolated Type S pitot tube is not always used; in many instances, the pitot tube is used in combination with other probe-sampling components (thermocouples, sampling probes, etc.) as part of an "assembly." The presence of other sampling components can sometimes affect the baseline value of the Type S pitot tube coefficient (Citation 9 in Section 6); therefore an assigned (or otherwise known) baseline coefficient

value may or may not be valid for a given assembly. The baseline and assembly component values will be identical only when the relative placement of the components in the assembly is such that the interference effects are eliminated. Figures 2-3 illustrate interference-free component arrangements. Type 1 pin tubes having external tubing diameters of 0.005 in. (0.005 and 0.006 in.), Type 2 pin tubes having diameters that fall in most or all of the specifications of Figures 3-4 through 3-6 shall be calibrated according to the procedure outlined in Sections 4.1.5 through 4.1.5 below, and prior to calibration, the values of the intercomponent spacings (pitch-count, pitch-thickness, pitch-probe depth) shall be measured and recorded.

NOTE.—Do not use any Type 2 pitot tube assembly which is constructed such that the impact pressure opening plane of the pitot tube is below the entry plane of the nozzle (see Figure 2-4b).

4.1.3 Calibration Set-up. If the Type B pilot tube is to be calibrated, one leg of the tube shall be permanently marked A, and the other, B. Calibration shall be done in a flow system having the following essential design features:

[illegible]

Figure 2-2 Velocity versus time




Figure 2-6. Proper gage tube - sampling nozzle configuration to prevent aerodynamic interference; butterfly-type nozzle; center of nozzle and gage opening aligned; O_2 between 0.48 and 0.95 cm (3/16 and 3/8 in.).

4.1.2.1 The flowing gas stream must be contained in a duct of definite cross-sectional area, either circular or rectangular. For circular cross-sections, the minimum duct diameter shall be 25.4 cm (2 in.); for rectangular cross-sections, the width (shorter side) shall be at least 25.4 cm (2 in.).

4.1.2.2 The cross-sectional area of the calibration duct must be constant over a distance of 30 or more duct diameters. For a rectangular cross-section, use an equivalent diameter, calculated from the following equation, to determine the number of duct diameters:

$$D_e = \frac{2LW}{(L+W)}$$

Equation 2-1

where:

D_e = Equivalent diameter

L = Length

W = Width

To ensure the presence of stable, fully developed flow patterns at the calibration site, or "test section," the run must be located at least eight diameters downstream and two diameters upstream from the nearest disturbance.

NOTE.—The eight- and two-diameter criteria are minimum; other test section locations may be used subject to approval of the Administrator, provided the flow at the test site is stable and demonstrably passive to the duct axis.

4.1.2.3 The flow system shall have the capacity to produce a test-section velocity around 915 m/min (2,800 ft/min). This velocity must be constant with time to guarantee steady flow during calibration. Note that Type S pitot tube coefficients obtained by single-velocity calibration at 915 m/min (2,800 ft/min) will generally be valid to within ± 3 percent for the measurement of velocities above 305 m/min (1,000 ft/min) and to within ± 5 percent for the measurement of velocities between 305 and 360 m/min (1,000 and 1,200 ft/min). To ensure precise correlation between C_p and velocity V desired, the flow system shall have the capacity to generate at least four distinct, time-invariant test-section velocities covering the velocity range from 305 to 1,200 m/min (1,000 to 3,600 ft/min), and calibration data must be taken at regular velocity intervals over this range (see Sections V and VI in Section 6 for details).

4.1.2.4 Two entry ports, one each for the standard and Type S pitot tubes, shall be cut in the test section; the standard pitot entry port shall be located slightly downstream of the Type S port, so that the standard and Type S impact openings will lie in the same cross-sectional plane during calibration. To facilitate alignment of the pitot tubes during calibration, it is advisable that the test section be constructed of plexiglas or some other transparent material.

4.1.3 Calibration Procedure. Note that this procedure is a general one and must not be used without first referring to the special considerations presented in Section 4.1.6. Note also that this procedure applies only to single-velocity calibration. To obtain calibration data for the A and B sides of the Type S pitot tube, proceed as follows:

4.1.3.1 Make sure that the manometer is properly filled and that the oil is free from contamination and at the proper density. Inspect and leak-check all pitot lines; repair or replace if necessary.

4.1.3.2 Level and zero the manometer. Turn on the fan and allow the flow to stabilize. Seal the Type S entry port.

4.1.3.3 Ensure that the manometer is level and zero. Position the standard pitot tube at the calibration point (determined as outlined in Section 4.1.2.2), and align the tube so that its tip is pointed directly into the flow. Particular care should be taken in aligning the tube to avoid yaw and pitch angles. Make sure that the entry port surrounding the tube is properly sealed.

4.1.3.4 Read Δp_{std} and record its value in a data table similar to the one shown in Figure 2-8. Remove the standard pitot tube from the duct and disconnect it from the manometer. Seal the standard entry port.

4.1.3.5 Connect the Type S pitot tube to the manometer. Open the Type S entry port. Check the manometer level and zero. Insert and align the Type S pitot tube so that its A side impact opening is at the same point as was the standard pitot tube and is pointed directly into the flow. Make sure that the entry port surrounding the tube is properly sealed.

4.1.3.6 Read Δp_{std} and enter its value in the data table. Remove the Type S pitot tube from the duct and disconnect it from the manometer.

4.1.3.7 Repeat steps 4.1.3.3 through 4.1.3.6 above until three pairs of Δp readings have been obtained.

4.1.3.8 Repeat steps 4.1.3.3 through 4.1.3.7 above for the B side of the Type S pitot tube.

4.1.3.9 Perform calculations, as described in Section 4.1.4 below.

4.1.4 Calculations:

4.1.4.1 For each of the six pairs of Δp readings (i.e., three from side A and three from side B) obtained in Section 4.1.3 above, calculate the value of the Type S pitot tube coefficient:




Figure 2-7. Proper thermocouple placement to prevent interference; D_t between 0.48 and 0.95 cm (3/16 and 3/8 in.).




Figure 2-8. Minimum pitot-sample probe separation needed to prevent interference; D_t between 0.48 and 0.95 cm (3/16 and 3/8 in.).

PITOT TUBE IDENTIFICATION NUMBER: _____ DATE: _____
CALIBRATED BY: _____

"A" SIDE CALIBRATION				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	Δp_{std} cm H ₂ O (in. H ₂ O)	$C_{p,A}$	DEVIATION $C_{p,A} - \bar{C}_{p,A}$
1				
2				
3				
			$\bar{C}_{p,A}$ (SIDE A)	

"B" SIDE CALIBRATION				
RUN NO.	Δp_{std} cm H ₂ O (in. H ₂ O)	Δp_{std} cm H ₂ O (in. H ₂ O)	$C_{p,B}$	DEVIATION $C_{p,B} - \bar{C}_{p,B}$
1				
2				
3				
			$\bar{C}_{p,B}$ (SIDE B)	

$$\text{AVERAGE DEVIATION} = \frac{1}{N} \sum |C_{p,A} - \bar{C}_{p,A} \text{ OR } C_{p,B} - \bar{C}_{p,B}| \quad \text{--- MUST BE } < 0.01$$

$$|\bar{C}_{p,B} - \bar{C}_{p,A}| \quad \text{--- MUST BE } < 0.01$$

Figure 2-9. Pitot tube calibration data.

$$C_{p(s)} = C_{p(Std)} \sqrt{\frac{\Delta P_{Std}}{\Delta P_s}}$$

Equation 2-2

where:

$C_{p(s)}$ = Type S pitot tube coefficient

$C_{p(Std)}$ = Standard pitot tube coefficient; use 0.99 if the coefficient is unknown and the tube is defined

according to the criteria of Sections 2.7.1 to 2.7.3 of this method.

ΔP_{Std} = Velocity head measured by the standard pitot tube, cm H_2O (in. H_2O)

ΔP_s = Velocity head measured by the Type S pitot tube, cm H_2O (in. H_2O)

4.1.4.3 Calculate $\bar{C}_p$ (side A), the mean A-side coefficient, and $\bar{C}_p$ (side B), the mean B-side coefficient; calculate the difference between these two average values.

4.1.4.4 Calculate the deviation of each of the three A-side values of $C_{p(s)}$ from $\bar{C}_p$ (side A), and the deviation of each B-side value of $C_{p(s)}$ from $\bar{C}_p$ (side B). Use the following equation:

$$\text{Deviation} = C_{p(s)} - \bar{C}_p \text{ (A or B)}$$

Equation 2-3

4.1.4.5 Calculate $\bar{C}_p$, the average deviation from the mean, for both the A and B sides of the pitot tube. Use the following equation:

$$\bar{C}_p \text{ (side A or B)} = \frac{\sum |C_{p(s)} - \bar{C}_p \text{ (A or B)}|}{3}$$

Equation 2-4

4.1.4.6 Use the Type S pitot tube only if the values of $\bar{C}_p$ (side A) and $\bar{C}_p$ (side B) are less than or equal to 0.01 and if the absolute value of the difference between $\bar{C}_p$ (A) and $\bar{C}_p$ (B) is 0.01 or less.

4.1.5 Special considerations.

4.1.5.1 Selection of calibration point.

4.1.5.1.1 When an isolated Type S pitot tube is calibrated, select a calibration point at or near the center of the duct, and follow the procedures outlined in Sections 4.1.3 and 4.1.4 above. The Type S pitot coefficient so obtained, i.e., $\bar{C}_p$ (side A) and $\bar{C}_p$ (side B), will be valid, so long as either: (1) the isolated pitot tube is used; or (2) the pitot tube is used with other components (nozzle, thermometer, sample probe) in an arrangement that is free from aerodynamic interference effects (see Figures 2-4 through 2-6).

4.1.5.1.2 For Type S pitot tube-thermometer combinations (without sample probe), select a calibration point at or near the center of the duct, and follow the procedures outlined in Sections 4.1.3 and 4.1.4 above. The coefficient so obtained will be valid so long as the pitot tube-thermometer combination is used by itself or with other components in an interference-free arrangement (Figures 2-4 and 2-6).

4.1.5.1.3 For assemblies with sample probes, the calibration point should be located at or near the center of the duct; however, insertion of a probe sheath into a small duct may cause significant cross-sectional area blockage and yield incorrect coefficient values (Criterion 9 in Section 6). Therefore, to minimize the blockage effect, the calibration point may be a few inches off-center if necessary. The actual blockage effect will be negligible when the theoretical blockage, as determined by a projected-area model of the probe sheath, is 2 percent or less of the duct cross-sectional area for assemblies without external sheaths (Figure 2-10a), and 3 percent or less for assemblies with external sheaths (Figure 2-10b).

4.1.5.1.4 For those probe assemblies in which pitot tube-nozzle interference is a factor (i.e., those in which the pitot-nozzle separation distance fails to meet the specification illustrated in Figure 2-4a), the value of $C_{p(s)}$ depends upon the amount of free-space between the tube and nozzle, and therefore is a function of nozzle size. In these instances, separate calibrations shall be performed with each of the commonly used nozzle sizes in place. Note that the single-velocity assumption technique is acceptable for this purpose, even though the larger nozzle sizes (>0.025 in. or 1/4 in.) are not ordinarily used for isokinetic sampling at velocities around 100 m/min (3,000 ft/min), which is the calibration velocity; note also that it is not necessary to draw an isokinetic sample during calibration (see Criterion 10 in Section 6).

4.1.5.1.5 For a probe assembly constructed such that its pitot tube is always used in the same orientation, only one side of the pitot tube need be calibrated (the side which will face the flow). The pitot tube must still meet the alignment specifications of Figure 2-2 or 2-3, however, and must have an average deviation ($\bar{C}_p$) value of 0.01 or less (see Section 4.1.4.4).




Figure 2-10. Projected-area models for typical probe assemblies.

4.1.6 Field Use and Recalibration.

4.1.6.1 Field Use.

4.1.6.1.1 When a Type S pitot tube (isolated tube or assembly) is used in the field, the appropriate coefficient value (whether obtained or determined by calibration) shall be used to perform velocity calculations. For calibrated Type S pitot tubes, the A-side coefficient shall be used when the A side of the tube faces the flow, and the B-side coefficient shall be used when the B side faces the flow; alternatively, the arithmetic average of the A and B side coefficient values may be used, irrespective of which side faces the flow.

4.1.6.1.2 When a probe assembly is used to sample a small duct (12 to 24 in. in diameter), the probe sheath sometimes blocks a significant part of the duct cross-section, causing a reduction in the effective value of $C_{p(s)}$. Consult Criterion 9 in Section 6 for details. Conventional pitot-sampling probe assemblies are not recommended for use in ducts having inside diameters smaller than 12 inches (Criterion 10 in Section 6).

4.1.6.2 Recalibration.

4.1.6.2.1 Isolated Pitot Tubes. After each field use, the pitot tube shall be carefully examined in top, side, and end views. If the pitot face openings are still aligned within the specifications illustrated in Figure 2-2 or 2-3, it can be assumed that the isokinetic coefficient of the pitot tube has not changed. If, however, the tube has been damaged to the extent that it no longer meets the specifications of Figure 2-2 or 2-3, the damage shall either be repaired to restore proper alignment of the face openings or the tube shall be discarded.

4.1.6.2.2 Pitot Tube Assembly. After each field use, check the face opening alignment of the pitot tube, as in Section 4.1.6.1.1; also, measure the intercomponent spacings of the assembly. If the intercomponent spacings have not changed and the face opening alignment is acceptable, it can be assumed that the coefficient of the assembly has not changed. If the face opening alignment is no longer within the specifications of Figure 2-2 or 2-3, either repair the damage or replace the pitot tube (restoring the new assembly, if necessary). If the intercomponent spacings have changed, restore the original spacings or recalibrate the assembly.

4.2 Standard pitot tube (if applicable). If a standard pitot tube is used for the velocity traverse, the tube shall be constructed according to the criteria of Section 2.7 and shall be assigned a baseline coefficient value of 0.99. If the standard pitot tube is used as part of an assembly, the tube shall be in an interference-free arrangement (subject to the approval of the Administrator).

4.3 Temperature Gauges. After each field use, calibrate dual thermometers, liquid-filled bulb thermometers, thermocouple-potentiometer systems, and other gauges at a temperature within 10 percent of the average absolute stack temperature. For temperatures up to 400° C (750° F), use an ASTM mercury-in-glass reference thermometer, or equivalent, as a reference; alternatively, either a reference thermometer and potentiometer (calibrated by NBS) or thermometric fixed points, e.g., ice bath and boiling water (corrected for barometric pressure) may be used. For temperatures above 400° C (750° F), use an NBS-calibrated reference thermocouple-potentiometer system or an alternate reference, subject to the approval of the Administrator.

If, during calibration, the absolute temperatures measured with the gauge being calibrated and the reference gauge agree within 1.5 percent, the temperature data taken in the field shall be considered valid. Otherwise, the sufficient omission test shall either be considered invalid or adjustments (if appropriate) of the test results shall be made, subject to the approval of the Administrator.

4.4 Barometer. Calibrate the barometer used against a mercury barometer.

5. Calculations

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

5.1 Summary.

- 1. Cross-sectional area of stack, m^2 (ft²).
- 2. Flow vapor in the gas stream (from Method 5 or Reference Method 4), proportion by volume.
- 3. Pitot tube coefficient, dimensionless.
- 4. Pitot tube constant,

$$K = \frac{1}{C_p} \left[\frac{(g/g\text{-mole})(\text{mm Hg})}{(^{\circ}K)(\text{mm Hg})} \right]^{1/2}$$

5. Gas velocity, m/min and

$$V = \frac{C_p}{K} \left[\frac{(g/g\text{-mole})(\text{in. Hg})}{(^{\circ}K)(\text{in. Hg})} \right]^{1/2}$$

6. Gas velocity, m/min.

7. Gas velocity, m/min.

8. Gas velocity, m/min.

9. Gas velocity, m/min.

10. Gas velocity, m/min.

11. Gas velocity, m/min.

12. Gas velocity, m/min.

13. Gas velocity, m/min.

14. Gas velocity, m/min.

15. Gas velocity, m/min.

16. Gas velocity, m/min.

17. Gas velocity, m/min.

18. Gas velocity, m/min.

19. Gas velocity, m/min.

20. Gas velocity, m/min.

21. Gas velocity, m/min.

22. Gas velocity, m/min.

23. Gas velocity, m/min.

24. Gas velocity, m/min.

25. Gas velocity, m/min.

26. Gas velocity, m/min.

27. Gas velocity, m/min.

28. Gas velocity, m/min.

29. Gas velocity, m/min.

30. Gas velocity, m/min.

31. Gas velocity, m/min.

32. Gas velocity, m/min.

33. Gas velocity, m/min.

2. Stephens, R. T., W. F. Todd, and W. S. Smith. Considerations of Errors in Stack Sampling Measurements. U.S. Environmental Protection Agency, Research Triangle Park, N.C. (Presented at the Annual Meeting of the Air Pollution Control Association, St. Louis, Mo., June 14-19, 1973.)
3. Standard Method for Sampling Gases for Particulate Matter. In: *Methods of ASTM Standards*, Part 28. Philadelphia, Pa. 1971. ASTM Designation D-689-71.
4. Vukobratovic, J. E. *Elementary Fluid Mechanics*. New York: John Wiley and Sons, Inc. 1967.
5. Fluid Motions—Their Theory and Application. American Society of Mechanical Engineers, New York, N.Y. 1959.
6. ASHRAE Handbook of Fundamentals. 1972. p. 289.
7. Annual Book of ASTM Standards, Part 28. 1974. p. 281.
8. Vellora, R. F. Guidelines for Type S Pitot Tube Calibration. U.S. Environmental Protection Agency, Research Triangle Park, N.C. (Presented at 1st Annual Meeting, Source Evaluation Society, Dayton, Ohio, September 24, 1974.)
9. Vellora, R. F. A Type S Pitot Tube Calibration Study. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. July 1974.
10. Vellora, R. F. The Effect of Impact Opening Misalignment on the Value of the Type S Pitot Tube Coefficient. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. October 1974.
11. Vellora, R. F. Establishment of a Reading Coefficient Value for Properly Constructed Type S Pitot Tubes. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. November 1974.
12. Vellora, R. F. An Evaluation of Single-Velocity Calibration Techniques as a Means of Determining Type S Pitot Tube Coefficients. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. August 1975.
13. Vellora, R. F. The Use of Type S Pitot Tubes for the Measurement of Low Velocities. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. November 1974.
14. Smith, Marvin L. Velocity Calibration of EPA Type Source Sampling Probes. United Technologies Corporation, Pratt and Whitney Aircraft Division, East Hartford, Conn. 1974.
15. Vellora, R. F. Recommended Procedure for Sample Traverse in Ducts Smaller than 12 inches in Diameter. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. November 1974.
16. Owen, E. and R. C. Pankhurst. *The Measurement of Air Flow*, 2nd Ed. London, Pergamon Press. 1964.
17. Vellora, R. F. A Survey of Commercially Available Instruments for the Measurement of Low-Range Gas Velocities. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. November 1974. (Unpublished Paper)
18. Gays, A. W., C. C. St. Pierre, D. S. Smith, D. Messer, and J. Schuler. An Experimental Investigation of the Effect of Pitot Tube-Sampling Probe Configurations on the Magnitude of the S-Type Pitot Tube Coefficient for Commercially Available Source Sampling Probes. Prepared by the University of Windsor for the Ministry of the Environment, Toronto, Canada. February 1974.

METHOD 3—GAS ANALYSIS FOR CARBON DIOXIDE, OXYGEN, EXCESS AIR, AND DRY MOLECULAR WEIGHT

1. Principle and Applicability

1.1 **Principle.** A gas sample is extracted from a stack, by one of the following methods: (1) single-point, grab sampling; (2) single-point, integrated sampling; or (3) multi-point, integrated sampling. The gas sample is analyzed for percent carbon dioxide (CO_2), percent oxygen (O_2), and, if necessary, percent carbon monoxide (CO). If a dry molecular weight determination is to be made, either an Oxy or a Pyrite analyzer may be used for the analysis for excess air or oxidation rate conversion factor determination, as Oxy must be used.

1.2 **Applicability.** This method is applicable for determining CO_2 and O_2 concentrations, excess air, and dry molecular weight of a stream from a gas stream of a fuel-burn combustion process. The method may also be applicable to other processes where it has been determined that compounds other than CO_2 , O_2 , CO , and nitrogen

(N_2) are not present in concentrations sufficient to affect the results.

Other methods, as well as modifications to the procedure described herein, are also applicable for some or all of the above determinations. Examples of specific methods and modifications include: (1) a multi-point sampling method using an Oxy analyzer to analyze individual grab samples obtained at each point; (2) a method using CO_2 or O_2 and stoichiometric calculations to determine dry molecular weight and excess air; (3) adapting a value of 28.8 for dry molecular weight, in lieu of actual measurements, for processes burning natural gas, coal, or oil. These methods and modifications may be used, but are subject to the approval of the Administrator.

2. Apparatus

As an alternative to the sampling apparatus and systems described herein, other sampling systems (e.g., liquid displacement) may be used provided such systems are capable of obtaining a representative sample and maintaining a constant sampling rate, and are otherwise

capable of yielding acceptable results. Use of such systems is subject to the approval of the Administrator.

2.1 Grab Sampling (Figure 3-1).

2.1.1 **Probe.** The probe should be made of stainless steel or boron-nitride tubing and should be equipped with an in-line air-seal filter to remove particulate matter (a plug of glass wool is satisfactory for this purpose). Any air-seal must not react with O_2 , CO_2 , CO , and N_2 and resistant to temperatures at sampling conditions may be used for no more than 1000 hours of use.

2.1.2 **Probe.** A one-way squeeze bulb, or equivalent, is used to draw the gas sample to the analyzer.

2.2 Integrated Sampling (Figure 3-2).

2.2.1 **Probe.** Same as that described in Section 2.1.1 is suitable.

1. Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.




Figure 3-1. Grab-sampling train.




Figure 3-2. Integrated gas-sampling train.

3-2

than (a) 0.2 percent by volume when O_2 is less than 15.0 percent or (b) 0.2 percent by volume when O_2 is greater than 15.0 percent. Average the three acceptable values of percent O_2 and report the results to the nearest 0.1 percent.

4.2.6.3 For percent CO, repeat the analytical procedure until the results of any three analyses differ by no more than 0.1 percent. Average the three acceptable values of percent CO and report the results to the nearest 0.1 percent.

4.2.7 After the analysis is completed, leak-check (mandatory) the Orsat analyzer once again, as described in Section 5. For the results of the analysis to be valid, the Orsat analyzer must pass this leak test before and after the analysis. Note: Although in most instances only CO_2 or O_2 is required, it is recommended that both CO_2 and O_2 be measured, and that Section 4.1 be used to validate the analytical data.

4.3 Multi-Point, Integrated Sampling and Analytical Procedure.

4.3.1 Both the minimum number of sampling points and the sampling point location shall be as specified in Section 3.1.1 of this method. The use of fewer points than specified is subject to the approval of the Administrator.

4.3.2 Follow the procedures outlined in Sections 4.2.2 through 4.2.7, except for the following: Traverse all sampling points and sample at each point for an equal length of time. Record sampling data as shown in Figure 3-2.

4.4 Quality Control Procedures.

4.4.1 Data Validation When Both CO_2 and O_2 Are Measured. Although in most instances, only CO_2 or O_2 measurement is required, it is recommended that both CO_2 and O_2 be measured to provide a check on the quality of the data. The following quality control procedure is suggested.

Note—Since the method for validating the CO_2 and O_2 analyses is based on combustion of organic and fossil fuels and dilution of the gas stream with air, this method does not apply to sources that (1) remove CO_2 or O_2 through processes other than combustion, (2) add O_2 (e.g., oxygen enrichment) and N_2 in proportions different from that of air, (3) add CO_2 (e.g., cement or lime kilns), or (4) have no fuel factor, F_a , values obtainable (e.g., extremely variable waste mixtures). This method validates the measured proportions of CO_2 and O_2 for the fuel type, but the method does not detect sample dilution resulting from leaks during or after sample collection. The method is applicable for samples collected downstream of most lime or limestone flue-gas desulfurization units as the CO_2 added or removed from the gas stream is not significant in relation to the total CO_2 concentration. The CO_2 concentrations from other types of scrubbers using only water or basic slurry can be significantly affected and would render the F_a check minimally useful.

4.4.1.1 Calculate a fuel factor, F_a , using the following equation:

$$F_a = \frac{20.9 - \%O_2}{\%CO_2} \quad \text{Eq. 3-3}$$

Where:

$\%O_2$ = Percent O_2 by volume (dry basis).

$\%CO_2$ = Percent CO_2 by volume (dry basis).

20.9 = Percent O_2 by volume in ambient air.

If CO is present in quantities measurable by this method, adjust the O_2 and CO_2 values before performing the calculation for F_a as follows:

$$\%CO_2(\text{adj}) = \%CO_2 + \%CO$$

$$\%O_2(\text{adj}) = \%O_2 - 0.5 \%CO$$

Where: $\%CO$ = Percent CO by volume (dry basis).

4.4.1.2 Compare the calculated F_a factor with the expected F_a values. The following table may be used in establishing acceptable ranges for the expected F_a if the fuel being burned is known. When fuels are burned in combination, calculate the combined fuel F_a and F_a factors (as defined in Method 19) according to the procedure in Method 19 Section 5.2.3. Then calculate the F_a factor as follows:

$$F_a = \frac{0.209 F_a}{F_a} \quad \text{Eq. 3-4}$$

Fuel type	F_a range
Coal	
Anthracite and lignite	1.016-1.120
Bituminous	1.063-1.230
Oil	
Diesel	1.280-1.413
Residual	1.210-1.370
Gas	
Natural	1.000-1.030
Propane	1.034-1.060
Butane	1.008-1.050
Wood	1.000-1.120
Wood bark	1.003-1.130

Calculated F_a values beyond the acceptable ranges shown in this table should be investigated before accepting the test results. For example, the strength of the solutions in the gas analyzer and the analyzing technique should be checked by sampling and analyzing a known concentration, such as air; the fuel factor should be reviewed and verified. An acceptability range of ± 12 percent is appropriate for the F_a factor of mixed fuels with variable fuel ratios. The level of the emission rate relative to the compliance level should be considered in determining if a retest is appropriate. I.e., if the measured emissions are much lower or much greater than the compliance limit, repetition of the test would not significantly change the compliance status of the source and would be unnecessarily time-consuming and costly.

5. Leak-Check Procedure for Orsat Analyzers

Moving an Orsat analyzer frequently causes it to leak. Therefore, an Orsat analyzer should be thoroughly leak-checked on site before the flue gas sample is introduced into it. The procedure for leak-checking an Orsat analyzer is:

5.1.1 Bring the liquid level in each pipette up to the reference mark on the capillary tubing and then close the pipette stopcock.

5.1.2 Raise the leveling bulb sufficiently to bring the containing liquid meniscus onto the graduated portion of the burette and then close the manifold stopcock.

5.1.3 Remove the meniscus position.

5.1.4 Observe the meniscus in the burette and the liquid level in the pipette for movement over the next 4 minutes.

5.1.5 For the Orsat analyzer to pass the leak-check, two conditions must be met.

5.1.5.1 The liquid level in each pipette must not fall below the bottom of the capillary tubing during this 4-minute interval.

5.1.5.2 The meniscus in the burette must not change by more than 0.2 ml during this 4-minute interval.

5.1.6 If the analyzer fails the leak-check procedure, all rubber connections and stopcocks should be checked until the cause of the leak is identified. Leaking stopcocks must be disassembled, cleaned, and reassembled. Leaking rubber connections must be replaced. After the analyzer is reassembled, the leak-check procedure must be repeated.

6. Calculations

6.1 Nomenclature.

M_a = Dry molecular weight, g/g-mole (lb/lb-mole).

$\%EA$ = Percent excess air.

$\%CO_2$ = Percent CO_2 by volume (dry basis).

$\%O_2$ = Percent O_2 by volume (dry basis).

$\%CO$ = Percent CO by volume (dry basis).

$\%N_2$ = Percent N_2 by volume (dry basis).

0.209 = Ratio of O_2 to N_2 in air, v/v.

0.280 = Molecular weight of N_2 or CO, divided by 100.

0.120 = Molecular weight of O_2 divided by 100.

0.160 = Molecular weight of CO_2 divided by 100.

6.2 Percent Excess Air. Calculate the percent excess air (if applicable), by substituting the appropriate values of percent O_2 , CO_2 , and N_2 (obtained from Section 4.1.3 or 4.1.4) into Equation 3-1.

$$\%EA = \left[\frac{\%O_2 - 0.5\%CO}{0.264\%N_2 - (\%O_2 - 0.5\%CO)} \right] 100 \quad \text{Equation 3-1}$$

Note.—The equation above assumes that ambient air is used as the source of O_2 and that the fuel does not contain appreciable amounts of N_2 (as do coke oven or blast furnace gases). For those cases when appreciable amounts of N_2 are present (coal, oil, and natural gas do not contain appreciable amounts of N_2) or when oxygen enrichment is used, alternate methods, subject to approval of the Administrator, are required.

6.3 Dry Molecular Weight. Use Equation 3-2 to calculate the dry molecular weight of the stack gas

$$M_a = 0.440(\%CO_2) + 0.280(\%CO) + 0.280(\%N_2) + \%CO \quad \text{Equation 3-2}$$

Note.—The above equation does not consider argon in air (about 0.9 percent, molecular weight of 39.9). A negative error of about 0.4 percent is introduced. The tester may opt to include argon in the analysis using procedures subject to approval of the Administrator.

7. Bibliography

1. Altshuler, A. F. Storage of Gases and Vapors in Plastic Bags. International Journal of Air and Water Pollution, 4:73-81, 1961.
2. Conner, William D. and J. S. Nader. Air Sampling with Plastic Bags. Journal of the American Industrial Hygiene Association, 25:291-297, 1964.
3. Burrell Manual for Gas Analysis, Seventh edition. Burrell Corporation, 2225 Fifth Avenue, Pittsburgh, Pa. 15219, 1951.
4. Mitchell, W. J. and M. R. Midgett. Field Reliability of the Orsat Analyzer. Journal of Air Pollution Control Association 18:491-493, May 1978.
5. Shigehara, R. T., R. M. Neulicht, and W. S. Smith. Validating Orsat Analysis Data from Fossil Fuel-Fired Units. Stack Sampling News, 4(2):21-24, August, 1978.

METHOD 4—DETERMINATION OF MOISTURE CONTENT IN STACK GASES

1. Principle and Applicability

1.1 Principle. A gas sample is extracted at a constant rate from the source; moisture is removed from the sample stream and determined either volumetrically or gravimetrically.

1.2 Applicability. This method is applicable for determining the moisture content of stack gas.

Two procedures are given. The first is a reference method, for accurate determinations of moisture content such as are needed to calculate emission data. The second is an approximation method, which provides estimates of percent moisture to aid in setting automatic sampling rates prior to a pollutant emission measurement run. The approximation method described herein is only a suggested approach; alternative means for approximating the moisture content, e.g., drying tubes, wet bulb-dry bulb techniques, condensation techniques, psychrometric calculations, previous experience, etc., are also acceptable.

The reference method is often conducted simultaneously with a pollutant emission measurement run; when it is, calculation of percent moisture, pollutant emission rate, etc., for the run shall be based upon the results of the reference method or its equivalent; these calculations shall not be based upon the results of the approximation method, unless the approximation method is shown, to the satisfaction of the Administrator, U.S. Environmental Protection Agency, to be capable of yielding results within 1 percent H₂O of the reference method.

Note.—The reference method may yield considerable results when applied to saturated gas streams or to streams that contain water droplets. Therefore, when these conditions exist or are suspected, a rapid determination of the moisture content shall be made simultaneously with the reference method, as follows: Assume that the gas stream is saturated. Attach a temperature sensor capable of measuring to $\pm 1^\circ\text{C}$ ($\pm 1.8^\circ\text{F}$) to the reference method probe. Measure the stack gas temperature at each traverse point (see Section 2.1.1) during the reference method traverse; calculate the average stack gas temperature. Next, determine the moisture percentage, either by: (1) using a psychrometric chart and making appropriate corrections if stack pressure is different from that of the chart, or (2) using saturation vapor pressure tables. In cases where the psychrometric chart or the saturation vapor pressure tables are not applicable (based on evaluation of the percent), alternate methods, subject to the approval of the Administrator, shall be used.

2. Reference Method

The procedure described in Method 3 for determining moisture content is acceptable as a reference method.

2.1 Apparatus. A schematic of the sampling train used in this reference method is shown in Figure 4-1. All components shall be maintained and calibrated according to the procedure outlined in Method 3.

2.1.1 Probe. The probe is constructed of stainless steel or glass tubing, sufficiently heated to prevent water condensation, and is equipped with a filter, either in-stack (e.g., a plug of glass wool inserted into the end of the probe) or heated out-stack (e.g., as described in Method 3), to remove particulate matter.

When stack conditions permit, other metals or plastic tubing may be used for the probe, subject to the approval of the Administrator.

2.1.2 Condenser. The condenser consists of four impingers connected in series with ground glass, leak-free fittings or any similarly leak-free non-contaminating fittings. The first, third, and fourth impingers shall be of the Greenburg-Smith design, modified by replacing the tip with a 1.5 centimeter (5/16 inch) ID glass tube extending to about 1.5 cm (5/8 inch) from the bottom of the flask. The second impinger shall be of the Greenburg-Smith design with the standard tip. Modifications (e.g., using flexible connections between the impingers, using materials other than glass, or using flexible vacuum lines to connect the filter holder to the condenser) may be used, subject to the approval of the Administrator.

The first two impingers shall contain known volume of water, the third shall be empty, and the fourth shall contain a known weight of 5- to 10-mesh indigestible type silica gel, or equivalent desiccant. If the silica gel has been previously used, dry at 175°C (350°F) for 2 hours. New silica gel may be used as received. A thermometer, capable of measuring temperature to within 1°C (1.8°F), shall be placed at the outlet of the fourth impinger, for monitoring purposes.

Alternatively, any system may be used subject to the approval of the Administrator that cools the sample gas stream and allows measurement of both the water that has been condensed and the moisture leaving the condenser, such as within 1 ml or 1 g. Acceptable means are to measure the condensed water, either gravimetrically or volumetrically, and to measure the moisture leaving the condenser by: (1) monitoring the temperature and pressure at the exit of the condenser and using Dalton's law of partial pressures, or (2) passing

the sample gas stream through a tared silica gel (or equivalent desiccant) trap, with exit gases kept below 25°C (77°F), and determining the weight gain.

If means other than silica gel are used to determine the amount of moisture leaving the condenser, it is recommended that silica gel (or equivalent) still be used between the condenser system and pump, to prevent moisture condensation in the pump and metering device and to avoid the need to make corrections for moisture in the metered volume.

2.1.3 Cooling System. An ice bath container and crushed ice (or equivalent) are used to aid in condensing moisture.

2.1.4 Metering System. This system includes a vacuum gauge, leak-free pump, thermometers capable of measuring temperature to within 2°C (3.6°F), dry gas meter capable of measuring volume to within 2 percent, and related equipment as shown in Figure 4-1. Other metering systems, capable of maintaining a constant sampling rate and determining sample gas volume, may be used, subject to the approval of the Administrator.

2.1.5 Barometer. Mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in. Hg) may be used. In many cases, the barometric reading may be obtained from a nearby national weather service station, in which case the station value (which is the absolute barometric pressure) must be requested and an adjustment for elevation difference between the weather station and the sampling point shall be applied at a rate of about 2.5 mm Hg (0.1 in. Hg) per 20 m (66 ft) elevation increase or vice versa for elevation decrease.

2.1.6 Graduated Cylinder and/or Balance. Three types are used to measure condensed water and moisture caught in the silica gel to within 1 ml or 0.1 g. Graduated cylinders shall have subdivisions no greater than 2 ml. Most laboratory balances are capable of weighing to the nearest 0.1 g or less. These balances are suitable for use here.

2.2 Procedure. The following procedure is written for a condenser system (such as the impinger system described in Section 2.1.2) incorporating volumetric analysis to measure the condensed moisture, and silica gel and gravimetric analysis to measure the moisture leaving the condenser.




Figure 4-1. Moisture sampling train-reference method

2.2.2 Select a total sampling time such that a minimum total gas volume of 0.40 scm (21 and) will be collected, at a rate no greater than 0.020 m/min (0.75 scm). When both moisture content and pollutant emission rate are to be determined, the moisture determination shall

2.2.3 Set up the sampling train as shown in Figure 4-1. Turn on the probe heater and (if applicable) the filter heating system to temperatures of about 125° C (245° F), to prevent water condensation ahead of the condenser; allow time for the temperatures to stabilize; Flare crushed ice in the ice bath container. It is recommended, but not required, that a leak check be done, as follows: Disconnect the probe from the first impinger or

(If applicable) from the filter holder. Plug the tank to the first (upstream) (or filter holder) and pull a 300 mm (15 in.) Hg vacuum; a lower vacuum may be used, provided that it is not exceeded during the test. A leakage rate in excess of 4 percent of the average sampling rate or 0.0007 m³/min (0.02 cfm), whichever is less, is unacceptable. Following the leak check, reconnect the probe to the sampling train.

2.1.4 During the sampling run, maintain a sampling rate within 10 percent of constant rate, or as specified by the Administrator. For each run, record the data required on the sample data sheet shown in Figure 4-2. Be sure to record the dry gas meter reading at the beginning and end of each sampling time increment and when

2.2.5 To begin sampling, position the probe tip at the first traverse point. Immediately start the pump and adjust the flow to the desired rate. Turn on the cross section, sampling at each traverse point for an equal length of time. Add more ice and, if necessary, salt to maintain a temperature of less than 20° C (68° F) at the orifice and outlet.


2.2.4 After collecting the sample, disconnect the probe from the filter holder (or from the first impinger) and conduct a leak check (mandatory) as described in Section

2.2.3. Record the leak rate. If the leakage rate exceeds the allowable value, the tester shall either repeat the test or shall correct the sample volume in a Section 6.2 of Method 3. Next, measure the volume of the moisture condensed to the nearest ml. Determine the increase in weight of the silicon gel (or silicon gel plus desiccant) to the nearest 0.5 g. Record this information (for example data sheet, Figure 4-3) and calculate the moisture percentage, as described in 2.2 below.

2.2.7 A quality control check of the volume metering system at the fix site is suggested before collecting the sample following the procedure in Method 3 Section 4.4.

2.3 Calculations. Carry out the following calculations, retaining at least one extra decimal figure beyond that of the required data. Round off figures after final calculation.

PLANT _____
LOCATION _____
OPERATOR _____
DATE _____
RUN NO. _____
AMBIENT TEMPERATURE _____
BAROMETRIC PRESSURE _____
PROBE LENGTH (IN) _____



SCHEMATIC OF STACK CROSS SECTION

[illegible]

Figure 4-2. Field moisture determination-reference method.

	DIFFERENCE VOLUME, cc	SILICA GEL WEIGHT, g
FINAL		
INITIAL		
DIFFERENCE		

Figure 4-3. Analytical data - reference method.

2.3.1 Nomenclature.

- B_{ws} - Proportion of water vapor, by volume, in the gas stream.
 M_w - Molecular weight of water, 18.0 g/g-mole (18.0 lb/lb-mole).
 P_w - Absolute pressure (for this method, same as barometric pressure) at the dry gas meter, mm Hg (in. Hg).
 P_{std} - Standard absolute pressure, 760 mm Hg (29.92 in. Hg).
 R - Ideal gas constant, 0.08206 (mm Hg) (m³/g-mole) (°K) for metric units and 21.85 (in. Hg) (ft³/lb-mole) (°R) for English units.
 T_w - Absolute temperature of meter, °K (°R).
 T_{std} - Standard absolute temperature, 293° K (672° R).
 V_w - Dry gas volume measured by dry gas meter, scm (ccf).
 ΔV_w - Incremental dry gas volume measured by dry gas meter at each traverse point, scm (ccf).
 $V_{w(scm)}$ - Dry gas volume measured by the dry gas meter, corrected to standard conditions, scm (ccf).
 $V_{w(ccf)}$ - Volume of water vapor condensed corrected to standard conditions, scm (ccf).
 $V_{w(ccf)}$ - Volume of water vapor collected in silica gel corrected to standard conditions, scm (ccf).
 V_f - Final volume of condenser water, ml.
 V_i - Initial volume, if any, of condenser water, ml.
 W_f - Final weight of silica gel or silica gel plus impinger, g.
 W_i - Initial weight of silica gel or silica gel plus impinger, g.
 Y - Dry gas meter calibration factor.
 ρ_w - Density of water, 0.9998 g/ml (0.002201 lb/ml).

2.3.2 Volume of water vapor condensed.

$$V_{w(ccf)} = \frac{(V_f - V_i) \rho_w R T_{std}}{P_{std} M_w} = K_1 (V_f - V_i) \quad \text{Equation 4-1}$$

where:

- K_1 - 0.001333 m³/ml for metric units
 - 0.00707 ft³/ml for English units

2.3.3 Volume of water vapor collected in silica gel.

$$V_{w(ccf)} = \frac{(W_f - W_i) R T_{std}}{P_{std} M_w} = K_2 (W_f - W_i) \quad \text{Equation 4-2}$$

where:

- K_2 - 0.002201 m³/g for metric units
 - 0.00715 ft³/g for English units

2.3.4 Sample gas volume.

$$V_{w(ccf)} = V_w Y \frac{(P_w)(T_{std})}{(P_{std})(T_w)} = K_3 Y \frac{V_w P_w}{T_w} \quad \text{Equation 4-3}$$

where:

- K_3 - 0.3048 °K/mm Hg for metric units
 - 17.44 °R/in. Hg for English units

NOTE - If the past-test leak rate (Section 2.2.6) exceeds the allowable rate, correct the value of V_w in Equation 4-3, as described in Section 4.3 of Method 1.

2.3.5 Moisture Content.

$$B_{ws} = \frac{V_{w(ccf)} + V_{w(ccf)}}{V_{w(ccf)} + V_{w(ccf)} + V_{w(ccf)}} \quad \text{Equation 4-4}$$

Equation 4-4

NOTE - In saturated or moisture droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one using a value based upon the saturated conditions (see Section 1.2), and another based upon the results of the impinger analysis. The lower of these two values of B_{ws} shall be considered correct.

2.3.6 Verification of constant sampling rate. For each time increment, determine the ΔV_w . Calculate the average. If the value for any time increment differs from the average by more than 10 percent, reject the results and repeat the run.

3. Approximation Method

The approximation method described below is presented only as a suggested method (see Section 1.2).

3.1 Apparatus.

3.1.1 Probe. Stainless steel or glass tubing, sufficiently heated to prevent water condensation and equipped with a filter (either in-stack or heated out-stack) to remove particulate matter. A plug of glass wool, inserted into the end of the probe, is satisfactory filter.

3.1.2 Impingers. Two midget impingers, each with 30 ml capacity, or equivalent.

3.1.3 Ice Bath. Container and ice, to aid in condensing moisture in impingers.

3.1.4 Drying Tube. Tube packed with new or regenerated 4- to 16-mesh indicating-type silica gel (or equivalent desiccant), to dry the sample gas and to protect the meter and pump.

3.1.5 Valve. Needle valve, to regulate the sample gas flow rate.

3.1.6 Pump. Leak-free, diaphragm type, or equivalent, to pull the gas sample through the train.

3.1.7 Volume Meter. Dry gas meter, sufficiently accurate to measure the sample volume within 3%, and calibrated over the range of flow rates and conditions actually encountered during sampling.

3.1.8 Rate Meter. Rotameter, to measure the flow range from 0 to 3 lpm (0 to 0.11 cfm).

3.1.9 Graduated Cylinder. 50 ml.

3.1.10 Barometer. Mercury, aneroid, or other barometer, as described in Section 3.1.5 above.

3.1.11 Vacuum Gauge. At least 760 mm Hg (30 in. Hg) gauge, to be used for the sampling leak check.

3.2 Procedure.

3.2.1 Place exactly 5 ml distilled water in each impinger.

Leak check the sampling train as follows: Temporarily insert a vacuum gauge at or near the probe inlet; then, plug the probe inlet and pull a vacuum of at least 250 mm Hg (10 in. Hg). Note: the time rate of change of the dry gas meter disk alternately, a rotameter (0-60 cc/min) may be temporarily attached to the dry gas meter outlet to determine the leakage rate. A leak rate not in excess of 2 percent of the average sampling rate is acceptable.

NOTE - Carefully release the probe inlet plug before turning off the pump.




Figure 4-4. Moisture-sampling train - approximation method.

METHOD 5—DETERMINATION OF PARTICULATE EMISSIONS FROM STATIONARY SOURCES

1. Principle and Applicability

1.1 **Principle.** Particulate matter is withdrawn isokinetically from the source and collected on a glass fiber filter maintained at a temperature in the range of 120±14° C (248±25° F) or such other temperature as specified by an applicable subset of the standards or approved by the Administrator, U.S. Environmental Protection Agency, for a particular application. The particulate mass, which includes any material that condenses at or above the filtration temperature, is determined gravimetrically after removal of uncombined water.

1.2 **Applicability.** This method is applicable for the determination of particulate emissions from stationary sources.

2. Apparatus

2.1 **Sampling Train.** A schematic of the sampling train used in this method is shown in Figures 5-1. Complete construction details are given in APTD-6851 (Chapter 2) in "Engineering and construction details of the train are also available. For changes from APTD-6851 and for allowable modifications of the train shown in Figure 5-1, see the following subsections.

The operating and maintenance procedures for the sampling train are described in APTD-6851 (Chapter 3) in "Operating and maintenance procedures for the sampling train. In all cases, all cases should read APTD-6851 and adopt the operating and maintenance procedures outlined in it, unless otherwise specified herein. The sampling train consists of the following components:

2.1.1 **Probe Nozzle.** Stainless steel (316) or glass with sharp, tapered leading edge. The angle of taper shall be 30° and the taper shall be on the outside to preserve a constant internal diameter. The probe nozzle shall be of the bottom-feed or other design, unless otherwise specified by the Administrator. If made of stainless steel, the nozzle shall be constructed from seamless tubing; other materials of construction may be used, subject to the approval of the Administrator.

A range of nozzle sizes suitable for isokinetic sampling should be available, e.g., 0.32 ± 0.02 in. (8.1 ± 0.5 mm) or larger if higher volume sampling rates are used—inside diameter (ID) section is a maximum of 0.16 cm (1/4 in.). Each nozzle shall be measured according to the procedures outlined in Section 2.1.2.

2.1.2 **Probe Liner.** Borosilicate or fused glass tubing with a heating system capable of maintaining a gas temperature at the exit end during sampling at 120±14° C (248±25° F), or such other temperature as specified by an applicable subset of the standards or approved by the Administrator for a particular application. (The heater may opt to operate the equipment at a temperature lower than that specified.) Size or wall temperature at the outlet of the probe is not controlled during sampling; probes constructed according to APTD-6851 and utilizing the calibration curve in APTD-6851 for calibrated according to the procedure outlined in APTD-6851 will be considered acceptable.

Either borosilicate or quartz glass probe liners may be used for stack temperatures up to 2,000° C (3,632° F); quartz liners shall be used for temperatures between 650 and 1,000° C (1,200 and 1,832° F). Each type of liner may be used at higher temperatures than specified for short periods of time, subject to the approval of the Administrator. The maximum temperature for borosilicate is 1,000° C (1,832° F), and for quartz is 2,000° C (3,632° F).

Whenever practical, every effort must be made to use borosilicate or quartz glass probe liners. Alternatively, metal liners (e.g., 304 stainless steel, Inconel 600, or other corrosion resistant metals) must be used when they may be used, subject to the approval of the Administrator.

2.1.3 **Pitot Tube.** Type E, as specified in Section 2.1 of Method 2, or other device approved by the Administrator. The pitot tube shall be located in the probe (as shown in Figure 5-1) to allow accurate measuring of the stack gas velocity. The impact (stagnation) pressure opening plane of the pitot tube shall be over 10 cm (4 in.) above the nozzle entry plane (see Method 2, Figure 1-6b) during sampling. The Type E pitot tube assembly shall have a known coefficient, determined as stated in Section 4 of Method 2.

* Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.

2.1.4 **Differential Pressure Gauge.** Inclined manometer or equivalent device (two), as specified in Section 2.2 of Method 2. One manometer shall be used for velocity head (Δp) readings, and the other, for orifice differential pressure readings.

2.1.5 **Filter Holder.** Borosilicate glass, with a glass frit filter support and a silicone rubber gasket. Other materials of construction (e.g., stainless steel, Teflon, Viton) may be used, subject to approval of the Administrator. The holder design shall provide a positive seal against leakage from the outside or around the filter. The holder shall be attached immediately at the outlet of the probe (or cyclone, if used).

2.1.6 **Filter Heating System.** Any heating system capable of maintaining a temperature around the filter holder during sampling at 120±14° C (248±25° F), or such other temperature as specified by an applicable subset of the standards or approved by the Administrator for a particular application. Alternatively, the heater may opt to operate the equipment at a temperature lower than that specified. A temperature gauge capable of measuring temperature to within 2° C (3.6° F) shall be installed so that the temperature around the filter holder can be regulated and monitored during sampling. Heating systems other than the one shown in APTD-6851 may be used.

2.1.7 **Condenser.** The following system shall be used to determine the stack gas moisture content: Four impingers connected in series with back-free ground glass fittings or any similar leak-free gas-containing fittings. The first, third, and fourth impingers shall be of the Greenburg-Smith design, modified by replacing the tip with 1.3 cm (1/2 in.) ID glass tube extending to about 1.3 cm (1/2 in.) from the bottom of the flask. The second impinger shall be of the Greenburg-Smith design with the standard tip. Modifications (e.g., using flexible connections between the impingers, using materials other than glass, or using flexible vacuum lines to connect the filter holder to the condenser) may be used, subject to the approval of the Administrator. The first and second impingers shall contain known quantities of water (Section 4.1.3); the third shall be empty, and the fourth shall contain a known weight of silica gel, or equivalent desiccant. A thermometer, capable of measuring




Figure 5-1. Particulate sampling train.

ing temperature to within 1° C (2° F) shall be placed at the outlet of the fourth impinger for monitoring purposes.

Alternatively, any system that cools the sample gas stream and allows measurement of the water condensed and moisture leaving the condenser, each to within 1 ml or 1 g may be used, subject to the approval of the Administrator. Acceptable means are to measure the condensed water either gravimetrically or volumetrically and to measure the moisture leaving the condenser by: (1) monitoring the temperature and pressure at the exit of the condenser and using Dalton's law of partial pressures; or (2) passing the sample gas stream through a tared silica gel (or equivalent desiccant) trap with exit gases kept below 25° C (77° F) and determining the weight gain.

If means other than silica gel are used to determine the amount of moisture leaving the condenser, it is recommended that silica gel (or equivalent) still be used between the condenser system and pump to prevent moisture condensation in the pump and metering devices and to avoid the need to make corrections for moisture in the metered volume.

Note.—If a determination of the particulate matter collected in the impingers is desired in addition to moisture content, the impinger system described above shall be used, without modification. Individual States or control agencies requiring this information shall be contacted as to the sample recovery and analysis of the impinger contents.

2.1.8 Metering System. Vacuum gauge, leak-free pump, thermometer capable of measuring temperature to within 2° C (3.6° F), dry gas meter capable of measuring volume to within 2 percent, and related equipment, as shown in Figures 3-1. Other metering systems capable of maintaining sampling rates within 10 percent of indicated and of determining sample volume to within 2 percent may be used, subject to the approval of the Administrator. When the metering system is used in conjunction with a pitot tube, the system shall enable checks of static pressure.

Sampling transmission metering systems designed for higher flow rates than that described in APTD-0341 or APTD-0476 may be used provided that the specifications of this method are met.

2.1.9 Barometer. Mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in. Hg). In many cases, the barometric reading may be obtained from a nearby national weather service station, in which case the station value (which is the absolute barometric pressure) shall be requested and an adjustment for elevation difference between the weather station and sampling point shall be applied at a rate of minus 2.5 mm Hg (0.1 in. Hg) per 30 m (100 ft) elevation increase or vice versa for elevation decrease.

2.1.10 Gas Density Determination Equipment. Temperature sensor and pressure gauge, as described in Sections 2.3 and 2.4 of Method 2, and gas analyzer, if necessary, as described in Method 3. The temperature sensor shall, preferably, be permanently attached to the pitot tube or sampling probe in a fixed configuration, such that the tip of the sensor extends beyond the leading edge of the probe sheath and does not touch any metal. Alternatively, the sensor may be attached just prior to use in the field. Note, however, that if the temperature sensor is attached in the field, the sensor must be placed in an interference-free arrangement with respect to the Type 5 pitot tube openings (see Method 2, Figure 3-7). As a second alternative, if a difference of not more than 1 percent in the average velocity measurement is to be introduced, the temperature gauge need not be attached to the probe or pitot tube. (This alternative is subject to the approval of the Administrator.)

2.2 Sample Recovery. The following items are needed:

2.2.1 Probe-Liner and Probe-Neck Brushes. Nylon bristle brushes with stainless steel wire handles. The probe brush shall have extensions (at least as long as the probe) of stainless steel, Nylon, Teflon, or similarly inert material. The brushes shall be properly sized and shaped to brush out the probe liner and neck.

2.2.2 Wash Bottles—Two. Glass wash bottles are recommended; polyethylene wash bottles may be used at the option of the tester. It is recommended that acetone not be stored in polyethylene bottles for longer than a month.

2.2.3 Glass Sample Storage Containers. Chemically resistant, borosilicate glass bottles, for acetone washes, 400 ml or 1000 ml. Screw cap liners shall either be rubber-backed Teflon or shall be constructed so as to be leak-free and resistant to chemical attack by acetone. (Narrow mouth glass bottles have been found to be less prone to leakage.) Alternatively, polyethylene bottles may be used.

2.2.4 Petri Dishes. For filter samples, glass or polyethylene, unless otherwise specified by the Administrator.

2.2.5 Graduated Cylinder and/or Balance. To measure condensed water to within 1 ml or 1 g. Graduated cylinders shall have subdivisions no greater than 2 ml. Most laboratory balances are capable of weighing to the nearest 0.5 g or less. Any of these balances is suitable for use here and in Section 2.3.4.

2.2.6 Plastic Storage Containers. Air-tight containers to store silica gel.

2.2.7 Funnel and Rubber Policeman. To aid in transfer of silica gel to container; not necessary if silica gel is weighed in the field.

2.2.8 Funnel. Glass or polyethylene, to aid in sample recovery.

2.3 Analysis. For analysis, the following equipment is needed:

2.3.1 Glass Weighing Dishes.

2.3.2 Desiccator.

2.3.3 Analytical Balance. To measure to within 0.1 mg.

2.3.4 Balance. To measure to within 0.5 g.

2.3.5 Beaker. 500 ml.

2.3.6 Hygrometer. To measure the relative humidity of the laboratory environment.

2.3.7 Temperature Gauge. To measure the temperature of the laboratory environment.

3. Reagents

3.1.1 Filters. Glass fiber filters, without organic binder, exhibiting at least 99.95 percent efficiency (<0.05 percent penetration) on 0.3-micron dioctyl phthalate smoke particles. The filter efficiency test shall be conducted in accordance with ASTM standard method D2986-71 (Reapproved 1978) (incorporated by reference—see § 80.17). Test data from the supplier's quality control program are sufficient for this purpose. In sources containing SO₂ or SO₃, the filter material must be of a type that is unreactive to SO₂ or SO₃. Citation 10 in Section 7 Bibliography may be used to select the appropriate filter.

3.1.2 Silica Gel. Indicating type, 6 to 14 mesh, if previously used, dry at 175° C (350° F) for 2 hours. New silica gel may be used as received. Alternatively, other types of desiccants (equivalent or better) may be used, subject to the approval of the Administrator.

3.1.3 Water. When analysis of the material caught in the impingers is required, distilled water shall be used. Run blanks prior to field use to eliminate a high blank on test samples.

3.1.4 Crested Ice.

3.1.5 Stoppcock Grease. Acetone-insoluble, heat-stable silicone grease. This is not necessary if screw-on connectors with Teflon sleeves, or similar, are used. Alternatively, other types of stopcock grease may be used, subject to the approval of the Administrator.

3.2 Sample Recovery. Acetone—reagent grade, <0.001 percent residue. In glass bottles is required. Acetone from metal containers generally has a high residue blank and should not be used. Sometimes, suppliers transfer acetone to glass bottles from metal containers; thus, acetone blanks shall be run prior to field use and only acetone with low blank values (<0.001 percent) shall be used. In no case shall a blank value of greater than 0.001 percent of the weight of acetone used be subtracted from the sample weight.

3.3 Analysis. Two reagents are required for the analysis:

3.3.1 Acetone. Same as 3.2.

3.3.2 Desiccant. Anhydrous calcium sulfate, indicating type. Alternatively, other types of desiccants may be used, subject to the approval of the Administrator.

4. Procedure

4.1 Sampling. The complexity of this method is such that, in order to obtain reliable results, testers should be trained and experienced with the test procedure.

4.1.1 Protect Personnel. All the components shall be maintained and used according to the procedure described in APTD-0341 unless otherwise specified herein.

Weigh several 20 to 30 g portions of silica gel in air-tight containers to the nearest 0.5 g. Record the total weight of the silica gel plus container on each container. As an alternative, the silica gel need not be preweighed, but may be weighed after a 25 impinger or sampling holder just prior to use.

Check filters visually under light for irregularities and flaws or pleat loss. Measure fibers of the proper diameter on the back side and use using number 2 machine ink. As an alternative, use the shipping containers (glass or plastic) and keep the filters in these containers at all times except during sampling and weighing.

Desiccate the silica gel at 250° C (482° F) and ambient pressure for a minimum of 2 hours and weigh at intervals of at least 1 hour to a constant weight, i.e., <0.5 mg change between weighings. Record results to the nearest 0.1 mg. During each weighing the filter must not be exposed to an ambient atmosphere for a period greater than 1 minute and a relative humidity above 30 percent. Alternatively (unless otherwise specified by the Administrator), the silica gel may be oven dried at 100° C (212° F) for 2 hours, desiccated for 2 hours, and weighed. Desiccants other than those described, which cannot remove humidity effects, may be used, subject to the approval of the Administrator.

4.1.2 Preliminary Determinations. Select the sampling site and the number of sampling points according to Method 1 as specified by the Administrator. Determine the meteorological conditions, and the range of velocity bands needed. It is recommended that a leak-check be performed (see Method 2, Section 2.1) be performed. Determine the moisture content using appropriate method 4 or its alternative for the purpose of moisture content sampling rate settings. Determine the static air molecular weight, as described in Method 2, Section 2.2. If integrated Method 3 sampling is used for weight determination, the integrated bag must be taken simultaneously with, and for the same length of time as, the particulate sample run.

Select a nozzle size and the range of velocity bands, such that it is possible to change the nozzle size in order to maintain constant sampling rates. During the run, do not change to a smaller size. Ensure that the proper differential pressure is chosen for the range of velocity bands selected in Section 2.2 of Method 2.

Select a suitable probe and probe length such that all traverse points can be attained. For large stacks, consider sampling from the outer edge of the stack to reduce the length of probe.

Select a total sampling time greater than or equal to the minimum time specified in the test procedure for the meteorological conditions such that (1) the sampling time per point is at least 2 min for some greater time interval specified by the Administrator, and (2) the sample volume is corrected to standard conditions will cover or exceed minimum total gas sample volume. The size is based on an approximate average sampling rate.

It is recommended that the number of minutes sampled at each point be at least 2 min or as large, plus one-half minute, in order to avoid truncating errors. The sampling time at each point shall be the same.

In some circumstances, e.g., batch cycles, it may be necessary to sample at longer times at the traverse points and to obtain larger gas sample volumes. In these cases, the Administrator's approval must first be obtained.

4.1.3 Preparation of Sampling Train. During preparation and assembly of a sampling train, keep all openings where contamination can occur covered until just prior to assembly. Sampling is about to begin. Place 100 ml of water in the first two impingers, leave the third impinger empty, and transfer approximately 200 to 300 g of silica gel from its container to the fourth impinger. More silica gel may be used, but care should be taken to ensure that it is not entrained and carried over during sampling.

Place the probe in a clean place for later use in the sample recovery. Alternatively, the weight of the silica gel plus container may be determined to the nearest 0.5 g and recorded.

Take other readings required by Figure 5-2 at least once for each sample point during each time increment and additional readings when significant changes (20 percent or more in velocity head readings) necessitate additional adjustments in flow rate. Level and zero the manometer. Because the manometer level and zero may shift due to vibrations and temperature changes, make periodic checks during the traverse.

Close the portholes prior to the test run to minimize the chance of sampling deposited material. To begin sampling, remove the nozzle cap, verify that the filter and probe leading systems are up to temperature, and hot the pilot tube and probe are properly positioned. Position the nozzle at the first traverse point with the tip pointing directly into the gas stream. Immediately start the pump and adjust the flow to isokinetic conditions. Isokinetic graphs are available, which aid in the rapid adjustment of the isokinetic sampling rate without successive computations. These nomographs are designed for use with the Type 8 pilot tube coefficient is 0.35 and 0.42, and to check gas equivalent density (dry molecular weight) equal to 29.26. APTD-857A details the procedure for using the nomographs. If C, and M, are outside the above stated ranges do not use the nomographs unless appropriate steps (see Citation 7 in Bibliography) taken to compensate for the deviations.

When the stack is under significant negative pressure, height of impinger stem 1, take care to close the coarse dust valve before inserting the probe into the stack to prevent water from backing into the filter holder. If necessary, the pump may be turned on with the coarse dust valve closed.

When the probe is in position, block off the openings around the probe and portholes to prevent unrepresentative diffusion of the gas stream.

Traverse the stack cross-section, as required by Method or as specified by the Administrator, being careful not to bump the probe nozzle into the stack walls when sampling near the walls or when removing or inserting the probe through the portholes; this minimizes the chance of disturbing deposited material.

During the test run, make periodic adjustments to keep the temperature around the filter holder at the upper level; add more ice and, if necessary, salt to maintain a temperature of less than 20° C (68° F) at the end of the run. Also, periodically check for level and zero of the manometer.

If the pressure drop across the filter becomes too high, making volumetric sampling difficult to maintain, the filter may be replaced in the middle of a sample run. It is recommended that another complete filter assembly be used rather than attempting to change the filter itself. Before a new filter assembly is installed, conduct a leak-check (see Section 4.1.4.2). The total particulate weight held inside the summation of all filter assembly catches.

A single train shall be used for the entire sample run, except in cases where simultaneous sampling is required in two or more separate ducts or at two or more different locations within the same duct, or, in cases where equipment failure necessitates a change of train. In all other situations, the use of two or more trains will be subject to the approval of the Administrator.

Note that when two or more trains are used, separate analyses of the front-half and (if applicable) impinger catches from each train shall be performed, unless identical nozzle sizes were used on all trains, in which case, the front-half catches from the individual trains may be combined (as may the impinger catches) and one analysis of front-half catch and one analysis of impinger catch may be performed. Consult with the Administrator for details concerning the calculation of results when two or more trains are used.

At the end of the sample run, turn off the coarse dust valve, remove the probe and nozzle from the stack, turn off the pump, record the final dry gas meter reading, and conduct a post-test leak-check, as outlined in Section 4.1.4.2. Also, leak-check the pilot lines as described in Method 2, Section 3.1; the lines must pass this leak-check in order to validate the velocity head data.

4.1.5 Calculation of Percent Isokinetic. Calculate percent isokinetic (see Calculations, Section 5) to determine whether the run was valid or another test run should be made. If there was difficulty in maintaining isokinetic rates due to source conditions, consult with the Administrator for possible variance on the isokinetic rates.

4.2 Sample Recovery. Proper cleanup procedure begins as soon as the probe is removed from the stack at the end of the sampling period. Allow the probe to cool.

When the probe can be safely handled, wipe off all external particulate matter near the tip of the probe nozzle and place a cap over it to prevent losing or gaining particulate matter. Do not cap off the probe tip tightly while the sampling train is cooling down as this would create a vacuum in the filter holder, thus drawing water from the impingers into the filter holder.

Before moving the sample train to the cleanup site, remove the probe from the sample train, wipe off the silicone grease, and cap the open outlet of the probe. Be careful not to lose any condensate that might be present. Wipe off the silicone grease from the filter inlet where the probe was fastened and cap it. Remove the umbilical cord from the last impinger and cap the impinger. If a flexible line is used between the first impinger or condenser and the filter holder, disconnect the line at the filter holder and let any condensed water or liquid drain into the impinger or condenser. After wiping off the silicone grease, cap off the filter holder outlet and impinger inlet. Either ground-glass stoppers, plastic caps, or serum caps may be used to close these openings.

Transfer the probe and filter-impinger assembly to the cleanup area. This area should be clean and protected from the wind so that the chances of contamination or losing the sample will be minimized.

Save a portion of the acetone used for cleanup as a blank. Take 200 ml of this acetone directly from the wash bottle being used and place it in a glass sample container labeled "acetone blank."

Inspect the train prior to and during disassembly and note any abnormal conditions. Treat the samples as follows:

Container No. 1. Carefully remove the filter from the filter holder and place it in its identified point dish container. Use a pair of tweezers and/or clean disposable surgical gloves to handle the filter. If it is necessary to fold the filter, do so such that the particulate onto is inside the fold. Carefully transfer to the point dish any particulate matter and/or filter fibers which adhere to the filter holder gasket, by using a dry Nylon bristle brush and/or a sharp-edged blade. Seal the container.

Container No. 2. Taking care to see that dust on the outside of the probe or other exterior surfaces does not get into the sample, quantitatively recover particulate matter or any condensate from the probe nozzle, probe stem, probe line, and front half of the filter holder by washing these components with acetone and placing the wash in a glass container. Distilled water may be used instead of acetone where approved by the Administrator and shall be used when specified by the Administrator; in these cases, save a water blank and follow the Administrator's directions on analysis. Perform the acetone rinses as follows:

1. Carefully remove the probe nozzle and clean the inside surface by rinsing with acetone from a wash bottle and brushing with a Nylon bristle brush. Brush until the acetone rinse shows no visible particles, after which make a final rinse of the inside surface with acetone. 2. Brush and rinse the inside parts of the Swagelok fitting with acetone in a similar way until no visible particles remain.

3. Rinse the probe line with acetone by tilting and rotating the probe while squirting acetone into its upper end so that all inside surfaces will be wetted with acetone. Let the acetone drain from the lower end into the sample container. A liquid film or polyethylene may be used to aid in transferring liquid wastes to the container. Follow the acetone rinse with a probe brush. 4. Dip the probe in an unlabeled position, moisten acetone with a twisting action through the probe; hold a sample container underneath the lower end of the probe, and catch any acetone and particulate matter which is brushed from the probe. Run the brush through the probe three times or more until no visible particulate matter is carried out with the acetone or until some remains in the probe line on visual inspection. With nothing new or other metal probes, run the brush through in the above prescribed manner at least six times since metal probes have small crevices in which particulate matter can be entrapped. Rinse the brush with acetone, and quantitatively collect these washings in the sample container. After the brushing, make a final acetone rinse of the probe as described above.

It is recommended that two people be used to clean the probe to minimize sample losses. Between sampling runs, keep brushes clean and protected from contamination.

After ensuring that all joints have been wiped clean of silicone grease, clean the inside of the front half of the filter holder by rubbing the surface with a Nylon bristle brush and rinsing with acetone. Rinse each side three times or more if needed to remove visible particles. Make a final rinse of the brush and filter holder. Carefully rinse out the glass cylinder, also if applicable. After all acetone washings and particulate matter have been collected in the sample container, tighten the lid on the sample container so that acetone will not leak out when it is shipped to the laboratory. Mark the height of the fluid level to determine whether or not leakage occurred during transport. Label the container to clearly identify its contents.

Container No. 3. Note the color of the indicating silica gel to determine if it has been completely spent and make a notation of its condition. Transfer the silica gel from the fourth impinger to its original container and seal. A funnel may make it easier to pour the silica gel without spilling. A rubber policeman may be used as an aid in removing the silica gel from the impinger. It is not necessary to remove the small amount of dust particles that may adhere to the impinger wall and are difficult to remove. Since the space in weight is to be used for moisture calculations, do not use any water or other liquids to transfer the silica gel. If a balance is available in the field, follow the procedure for container No. 3 in Section 4.2.

Impinger Water. Treat the impingers as follows: Make a notation of any color or film in the liquid catch. Measure the liquid which is in the first three impingers to within 0.1 ml by using a graduated cylinder or by weighing it to within 0.5 g by using a balance (if one is available). Record the volume or weight of liquid present. This information is required to calculate the moisture content of the effluent gas.

Discard the liquid after measuring and recording the volume or weight, unless analysis of the impinger catch is required (see Note, Section 2.1.1).

If a different type of condenser is used, measure the amount of moisture condensed either volumetrically or gravimetrically.

Whenever possible, containers should be shipped in such a way that they remain upright at all times.

4.3 Analysis. Record the data required on a sheet such as the one shown in Figure 5-3. Handle each sample container as follows:

Container No. 1. Leave the contents in the shipping container or transfer the filter and any loose particulate from the sample container to a tared glass weighing dish. Desiccate for 24 hours in a desiccator containing anhydrous calcium sulfate. Weigh to a constant weight and report the results to the nearest 0.1 mg. For purposes of this section, 4.3, the term "constant weight" means a difference of no more than 0.5 mg or 1 percent of total weight less tare weight, whichever is greater, between two consecutive weighings, with no less than 6 hour desiccation time between weighings.

Alternatively, the sample may be oven dried at 105 (220° F) for 2 to 3 hours, cooled in the desiccator, and weighed to a constant weight, unless otherwise specified by the Administrator. The latter may also opt to oven dry the sample at 105° C (220° F) for 2 to 3 hours, weigh the sample, and use this weight as a final weight.

Container No. 2. Note the level of liquid in the container and confirm on the analysis sheet whether or not leakage occurred during transport. If a noticeable amount of leakage has occurred, either void the sample or use methods, subject to the approval of the Administrator, to correct the final results. Measure the liquid in this container either volumetrically to 0.1 ml or gravimetrically to 0.5 g. Transfer the contents to a tared 250-ml beaker and evaporate to dryness at ambient temperature and pressure. Desiccate for 24 hours and weigh to a constant weight. Report the results to the nearest 0.1 mg.

Container No. 3. Weigh the spent silica gel (or silica gel plus impinger) to the nearest 0.5 g using a balance. This step may be conducted in the field.

"Acetone Blank" Container. Measure acetone in this container either volumetrically or gravimetrically. Transfer the acetone to a tared 250-ml beaker and evaporate to dryness at ambient temperature and pressure. Desiccate for 24 hours and weigh to a constant weight. Report the results to the nearest 0.1 mg.

NOTE.—At the option of the tester, the contents of Container No. 2 as well as the acetone blank container may be evaporated at temperatures higher than ambient. If evaporation is done at an elevated temperature, the temperature must be below the boiling point of the solvent; also, to prevent "bumping," the evaporation process must be closely supervised, and the contents of the beaker must be stirred occasionally to maintain an even temperature. Use extreme care, as acetone is highly flammable and has a low flash point.

4.4 Quality Control Procedures. The following quality control procedures are suggested to check the volume metering system calibration values at the field test site prior to sample collection. These procedures are optional for the tester.

4.4.1 Meter Orifice Check. Using the calibration data obtained during the calibration procedure described in Section 3.3, determine the ΔH_0 for the metering system orifice. The ΔH_0 is the orifice pressure differential in units of in. H₂O that correlates to 0.73 cfm of air at 528°R and 29.92 in. Hg. The ΔH_0 is calculated as follows:

$$\Delta H_0 = 0.0319 \frac{\Delta H}{P_{atm}} \frac{\theta}{Y V_{in}} \quad \text{Eq. 5-3}$$

Where:

ΔH = Average pressure differential across the orifice meter, in. H₂O.

T_{atm} = Absolute average dry gas meter temperature, °R.

P_{atm} = Barometric pressure, in. Hg.

θ = Total sampling time, min.

Y = Dry gas meter calibration factor, dimensionless.

V_{in} = Volume of gas sample as measured by dry gas meter, dcf.

$$1.0319 = (0.0367 \text{ in. Hg/}^\circ\text{R}) \times (0.73 \text{ cfm})$$

Before beginning the field test (a set of three runs usually constitutes a field test), operate the metering system (i.e., pump, volume meter, and orifice) at the ΔH_0 pressure differential for 10 minutes. Record the volume collected, the dry gas meter temperature, and the barometric pressure. Calculate a dry gas meter calibration check value, Y_c , as follows:

$$Y_c = \frac{10}{V_{in}} \left[\frac{0.0319 T_{atm}}{P_{atm}} \right] \quad \text{Eq. 5-4}$$

Where:

Y_c = Dry gas meter calibration check value, dimensionless.

10 = 10 minutes of run time.

Compare the Y_c value with the dry gas meter calibration factor Y to determine that: $0.97Y < Y_c < 1.03Y$

If the Y_c value is not within this range, the volume metering system should be investigated before beginning the test.

4.4.2 Calibrated Critical Orifice. A calibrated critical orifice, calibrated against a wet test meter or spirometer and designed to be inserted at the inlet of the sampling meter box, may be used as a quality control check, such procedure being subject to approval by the Administrator.

5. Calibration

Maintain a laboratory log of all calibrations.

5.1 Probe Nozzle. Probe nozzles shall be calibrated before their initial use in the field. Using a micrometer, measure the inside diameter of the nozzle to the nearest 0.001 mm (0.001 in.). Make three separate measurements using different diameters each time, and obtain the average of the measurements. The difference between the high and low numbers shall not exceed 0.1 mm (0.004 in.). When nozzles become nicked, dented, or corroded, they shall be reshaped, sharpened, and recalibrated before use. Each nozzle shall be permanently and uniquely identified.

5.2 Pitot Tube. The Type S pitot tube assembly shall be calibrated according to the procedure outlined in Section 4 of Method 2.

5.3 Metering System. Before its initial use in the field, the metering system shall be calibrated according to the procedure outlined in APTD-0574. Instead of physically adjusting the dry gas meter dial readings to correspond to the wet test meter readings, calibration factors may be used to mathematically correct the gas meter dial readings to the proper values. Before calibrating the metering system, it is suggested that a leak-check be conducted. For metering systems having diaphragm pumps, the normal leak-check procedure will not detect leakage within the pump. For these cases the following leak-check procedure is suggested: make a 10-minute calibration run at 0.0319 in. Hg (0.67 cfm); at the end of the run, take the difference of the measured wet test meter and dry gas meter volume; divide the difference by 10 to get the leak rate. The leak rate should not exceed 0.0057 in. Hg (0.67 cfm).

After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single, intermediate orifice setting (based on the previous field test), with the vacuum set at the maximum value reached during the test series. To adjust the vacuum, insert a valve between the wet test meter and the inlet of the metering system. Calculate the average value of the calibration factor. If the calibration has changed by more than 3 percent, recalibrate the meter over the full range of orifice settings, as outlined in APTD-0574.

Alternative procedures, e.g., using the orifice meter coefficients, may be used, subject to the approval of the Administrator.

Note.—If the dry gas meter coefficient values obtained before and after a test series differ by more than 3 percent, the test series shall either be voided, or calculations for the test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

5.4 Probe Heater Calibration. The probe heating system shall be calibrated before its initial use in the field according to the procedure outlined in APTD-0574. Probes constructed according to APTD-0581 need not be calibrated if the calibration curves in APTD-0576 are used.

5.5 Temperature Gauge. Use the procedure in Section 4.3 of Method 2 to calibrate in-stack temperature gauges. Dial thermometers, such as are used for the dry gas meter and condenser outlet, shall be calibrated against mercury-in-glass thermometers.

5.6 Leak Check of Metering System Shown in Figure 5-1. That portion of the sampling train from the pump to the orifice meter should be leak checked prior to initial use and after each shipment. Leakage after the pump will result in low volume being recorded than is actually sampled. The following procedure is suggested (see Figure 5-1): Close the main valve on the meter box. Insert a one-hole rubber stopper with rubber tubing attached into the orifice exhaust pipe. Disconnect and vent the low side of the orifice manometer. Close off the low side orifice tap. Pressurize the system to 13 to 16 cm (5 to 7 in.) water column by blowing into the rubber tubing. Finish off the tubing and observe the manometer for one minute. A loss of pressure on the manometer indicates a leak in the meter box; leaks, if present, must be corrected.

5.7 Barometer. Calibrate against a mercury barometer.

6. Calculations

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after the final calculation. Other forms of the equations may be used as long as they give equivalent results.

Pump _____

Date _____

Run No. _____

Filter No. _____

Amount liquid lost during transport _____

Aerocene blank volume, ml _____

Aerocene wash volume, ml _____

Aerocene blank concentration, mg/l (equation 5-4) _____

Aerocene wash blank, mg (equation 5-5) _____

CONTAINER NUMBER	WEIGHT OF PARTICULATE COLLECTED, mg		
	FINAL WEIGHT	TARE WEIGHT	WEIGHT GAIN
1			
2			
TOTAL			
Less aerocene blank			
Weight of particulate matter			

	VOLUME OF LIQUID WATER COLLECTED	
	IMPINGER VOLUME, ml	SILICA GEL WEIGHT, g
FINAL		
INITIAL		
- LIQUID COLLECTED		
TOTAL VOLUME COLLECTED		g ¹ ml

¹ CONVERT WEIGHT OF WATER TO VOLUME BY DIVIDING TOTAL WEIGHT INCREASE BY DENSITY OF WATER (1g/ml).

$$\frac{\text{INCREASE, g}}{1 \text{ g/ml}} = \text{VOLUME WATER, ml}$$

Figure 5-3. Analytical data.




Figure 5-4. Leak check of meter box.

6.1 Nomenclature

- A. = Cross-sectional area of nozzle, m^2 (ft^2).
- B. = Water vapor in the gas stream, proportion by volume.
- C. = Acetone blank residue concentration, mg/L .
- d. = Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, g/dscm (gr/dscf).
- I. = Percent of impingers sampling.
- L. = Maximum acceptable leakage rate for either a pretest leak check or for a leak check following a component change; equal to 0.0005 m^3/min (0.03 scfm) or 4 percent of the average sampling rate, whichever is less.
- L. = Individual leakage rate observed during the leak check conducted prior to the "n"-component change ($n=1, 2, 3, \dots, n$), m^3/min (scfm).
- L. = Leakage rate observed during the post-test leak check, m^3/min (scfm).
- m. = Total amount of particulate matter collected, mg .
- M. = Molecular weight of water, 18.0 g/g-mole (18.0 lb/lb-mole).
- n. = Mass of residue of acetone after evaporation, mg .
- P. = Barometric pressure at the sampling site, mm Hg (in. Hg).
- P. = Absolute stack gas pressure, mm Hg (in. Hg).
- P. = Standard absolute pressure, 760 mm Hg (30.02 in. Hg).
- R. = Ideal gas constant, 8.314 $\text{J/mole}^\circ\text{K}$ or 15.45 $\text{ft}^3\text{-lb}/\text{mole}^\circ\text{R}$.
- T. = Absolute average dry gas meter temperature (see Figure 5-2), $^\circ\text{K}$ ($^\circ\text{R}$).
- T. = Absolute average stack gas temperature (see Figure 5-2), $^\circ\text{K}$ ($^\circ\text{R}$).
- T. = Standard absolute temperature, 293 $^\circ\text{K}$ (527 $^\circ\text{R}$).
- V. = Volume of acetone blank, ml .
- V. = Volume of acetone used in wash, ml .
- V. = Total volume of liquid collected in impingers and silicon gel (see Figure 5-3), ml .
- V. = Volume of gas sample as measured by dry gas meter, dscm (dscf).
- V. = Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscm (dscf).

- V. = Volume of water vapor in the gas sample, corrected to standard conditions, m^3 (scf).
- V. = Stack gas velocity, calculated by Equation 5-4, using data obtained from Figure 5-4, m/s (ft/min).
- W. = Weight of residue in acetone wash, mg .
- Y. = Dry gas meter calibration factor.
- ΔH = Average pressure differential across the meter (see Figure 5-3), mm Hg (in. Hg).
- ρ_a = Density of acetone, mg/ml (gm and oz./in.^3).
- ρ_w = Density of water, 0.9992 gm/ml (8.33 lb/ft^3).
- θ = Total sampling time, min .
- θ_1 = Sampling time interval, from the beginning of a run until the first component change, min .
- θ_2 = Sampling time interval, between two successive component changes, beginning with the interval between the first and second changes, min .
- θ_n = Sampling time interval, from the time of component change until the end of the sampling run, min .
- 13.6 = Specific gravity of mercury.
- 60 = Seconds.
- 100 = Conversion to percent.
- 6.2 Average dry gas meter temperature and average orifice pressure drop, see data sheet (Figure 5-2).
- 6.3 Dry Gas Volume. Correct the volume measured by the dry gas meter to standard conditions (29 $^\circ\text{C}$, 760 mm Hg or 68 $^\circ\text{F}$, 30.02 in. Hg) by using Equation 5-1.

$$V_{n(\text{std})} = V_n Y \left(\frac{T_{\text{std}}}{T_n} \right) \left[\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{P_{\text{std}}} \right] - K_1 V_n Y \frac{P_{\text{bar}} + (\frac{\Delta H}{13.6})}{T_n}$$

Equation 5-1

where:
 $K_1 = 0.0005 \text{ } ^\circ\text{K/mm Hg}$ for metric units
 $K_1 = 0.0005 \text{ } ^\circ\text{R/in. Hg}$ for English units

Note.—Equation 5-1 can be used as written unless the leakage rate observed during any of the mandatory leak checks (i.e., the post-test leak check or leak checks conducted prior to component changes) exceeds L_n . If L_n or L_n exceeds L_n , Equation 5-1 must be modified as follows:

(a) Case I. No component changes made during sampling run. In this case, replace V_n in Equation 5-1 with the expression:

$$V_n = (L_n - L_n) \theta$$

(b) Case II. One or more component changes made during the sampling run. In this case, replace V_n in Equation 5-1 by the expression:

$$\left[V_n - (L_1 - L_n) \theta_1 - \sum_{i=2}^n (L_i - L_n) \theta_i - (L_n - L_n) \theta_n \right]$$

and substitute only for those leakage rates (L_1 or L_n) which exceed L_n .

6.4 Volume of water vapor.

$$V_{w(\text{std})} = V_n \left(\frac{\rho_w}{M_w} \right) \left(\frac{RT_{\text{std}}}{P_{\text{std}}} \right) = K_2 V_n$$

where:
 $K_2 = 0.00033 \text{ } \text{m}^3/\text{ml}$ for metric units
 $K_2 = 0.00033 \text{ } \text{ft}^3/\text{in.}^3$ for English units.

6.5 Moisture Content.

$$B_w = \frac{V_{w(\text{std})}}{V_{n(\text{std})} + V_{w(\text{std})}}$$

Equation 5-3

Note.—In saturated or water droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one from the impinger analysis (Equation 5-3), and a second from the assumption of saturated conditions. The lower of the two values of B_{ws} shall be considered correct. The procedure for determining the moisture content based upon assumption of saturated conditions is given in the Note of Section 1.2 of Method 4. For the purposes of this method, the average stack gas temperature from Figure 5-2 may be used to make this determination, provided that the accuracy of the in-stack temperature sensor is $\pm 1^\circ \text{C}$ ($^\circ \text{F}$).

6.6 Acetone Blank Concentration.

$$C_a = \frac{m_a}{V_a \rho_a}$$

Equation 5-4

6.7 Acetone Wash Blank.

$$W_a = C_a V_{ac} \rho_a$$

Equation 5-5

6.8 Total Particulate Weight. Determine the total particulate catch from the sum of the weights obtained from containers 1 and 2 less the acetone blank (see Figure 5-6). **Note.**—Refer to Section 4.1.5 to assist in calculation of results involving two or more filter assemblies or two or more sampling trains.

6.9 Particulate Concentration.

$$c_p = (0.001 \text{ g/mg}) (m_p / V_{std})$$

Equation 5-6

6.10 Conversion Factors:

From	To	Multiply by
cc/ g/lit	m ³ g/lit	0.000283
g/lit	lb/lit	15.43
g/lit	g/m ³	2.38×10^{-4}
	g/m ³	35.31

6.11 Isobaric Variation:

6.11.1 Calculation From Raw Data.

$$I = \frac{100 T_a [K_1 V_1 + (V_a / T_a) (P_{bar} + \Delta H / 13.6)]}{60 \theta v P_a A_a}$$

Equation 5-7

where:

$K_1 = 0.00454 \text{ mm Hg-molal-}^\circ \text{K}$ for metric units.

$= 0.00328 \text{ in. Hg-molal-}^\circ \text{F}$ for English units.

6.11.2 Calculation From Intermediate Values.

$$I = \frac{T_a V_{std} P_{std} 100}{T_{std} \theta A_a P_a 60 (1 - B_{ws})}$$

$$= K_2 \frac{T_a V_{std}}{P_a V_a A_a \theta (1 - B_{ws})}$$

Equation 5-8

where:

$K_2 = 4.188$ for metric units.

$= 0.00454$ for English units.

6.12 Acceptable Results. If 99 percent $\leq I \leq 110$ percent, the results are acceptable. If the results are low in comparison to the standard and I is beyond the acceptable range, or, if I is less than 99 percent, the Administrator may opt to accept the results. On Option 4 to make judgments. Otherwise, reject the results and repeat the test.

7. Alternative Procedures

7.1 Dry Gas Meter as a Calibration

Standard. A dry gas meter may be used as a calibration standard for volume measurements in place of the wet test meter

specified in Section 5.3, provided that it is calibrated initially and recalibrated periodically as follows:

7.1.1 Standard Dry Gas Meter Calibration.

7.1.1.1 The dry gas meter to be calibrated and used as a secondary reference meter should be of high quality and have an appropriately sized capacity, e.g., 3 liters/rev (0.1 ft³/rev). A spirometer (400 liters or more capacity), or equivalent, may be used for this calibration, although a wet test meter is usually more practical. The wet test meter should have a capacity of 30 liters/rev (1 ft³/rev) and capable of measuring volume to within ± 1.0 percent; wet test meters should be checked against a spirometer or a liquid displacement meter to ensure the accuracy of the wet test meter. Spirometers or wet test meters of other sizes may be used, provided that the specified accuracies of the procedure are maintained.

7.1.1.2 Set up the components as shown in Figure 5.7. A spirometer, or equivalent, may be used in place of the wet test meter in the system. Run the pump for at least 5 minutes at a flow rate of about 10 liters/min (0.35 cfm) to condition the interior surface of the wet test meter. The pressure drop indicated by the manometer at the inlet side of the dry gas meter should be minimized (no greater than 100 mm H₂O (4 in. H₂O) at a flow rate of 30 liters/min (1 cfm)). This can be accomplished by using large diameter tubing connections and straight pipe fittings.

7.1.1.3 Collect the data as shown in the example data sheet (see Figure 5-8). Make triplicate runs at each of the flow rates and at no less than five different flow rates. The range of flow rates should be between 10 and 34 liters/min (0.35 and 1.2 cfm) or over the expected operating range.

SHAW CODE 1540-60-01




Figure 5.7. Equipment arrangement for dry-gas meter calibration.

OPERATING INSTRUCTIONS FOR ANDERSEN STACK SAMPLING EQUIPMENT

1.0 INTRODUCTION

In the past, an accurate evaluation of the particulate sample collected from a stack has been difficult because the collection devices were designed mainly to be used exterior to the stack. In addition, there has been a lack of instrumentation capable of giving meaningful particle sizing information.

Now, however, the Andersen Stack Sampler is available which provides a reliable particulate sample that is collected and sized aerodynamically in the stack at isokinetic conditions simultaneously with the collection of gaseous samples. Isokinetic sampling requires that the stack gases are drawn into the sampling nozzle at the same velocity and in the same direction as they occur in the stack. This method of stack effluent analysis is easier and more economical for the simultaneous determination of grain loading, particle sizing, and gaseous content than any other technique.

There are two types or classes of stack sampling equipment. One class (external probe) has the solids-collecting device mounted outside the flue at the exit end of the probe tube and usually requires heating the probe tube and collection device to prevent condensation of water vapor. The other class (internal probe) has the solids-collecting device mounted inside the flue to provide sample collection done under actual stack conditions. The Andersen Stack Sampler is an internal collector and differs from more conventional devices in that it does not operate by means of filtration or impingement, but rather by means of inertial impaction.

A brief description of general stack sampling procedures follows. The unique characteristics and points to be considered when using the Andersen Stack Sampler will be covered in detail.

The particulate matter in stack gases is seldom distributed uniformly over the cross section of a flue; however, by a proper selection of sampling points, a representative sample can be obtained. Also, the quantity seldom remains steady over a substantial period of time because of the difficulty of maintaining uniform plant operating conditions. Therefore, it is necessary to know the operating cycles and cycle conditions in order to obtain representative samples during steady plant conditions. Peak loading times, temperatures, and humidity will all affect the sampling.

It should be clearly understood that the result of a test can give only an average value of emission during the period of sampling and can be representative only of the conditions during that period. Therefore, it is recommended that duplicate samples be taken whenever sampling flues.

Since it is not possible to collect all of the material emitted from a stack, it is necessary to obtain a representative sample. This requires the selection of a suitable sampling position, the collection of several samples and the conversion of the data obtained into a reliable estimate of total emission.

Sampling points in the stack should be selected to avoid gas turbulence as much as possible. When selecting a site, the general rule is for measurements to be made

eight to ten diameters downstream or three to five diameters upstream from a disturbance. Disturbances are usually caused by inlets, outlets, bends, constrictions, dampers, etc. Often, it is physically impossible to sample in a uniform gas mixture and compromises must be made. Whenever this occurs, all measurements and techniques must be carefully applied to ensure reasonable accuracy.

After the selection of a suitable sampling site, one is ready to make a preliminary survey including gas velocity, temperature, and combustion efficiency determinations. A preliminary traverse is made with a pitot tube connected to an inclined/vertical manometer.

The S pitot tube measures velocity head at the point in the gas stream where it is placed. Temperature, pressure, and humidity determinations must also be made on the sampling plane since these parameters may affect the stack gas density significantly. When making this traverse, the process cycle must be kept in mind because the stack gas velocity is dependent upon the cycle fluctuations. Also, at this time, an Orsat Analyzer is normally used to determine the efficiency of combustion. The acceptable level of CO_2 is 12 percent. It may be necessary to make several preliminary traverses in order to find an area which will conform to the previously discussed requirements. With the velocity information obtained, it is now possible to select a nozzle and flow rate that will be required for isokinetic sampling.

The sampling site selected must be able to safely accommodate two men during the taking of velocity, temperature, and humidity measurements in addition to collecting the samples. A probe tube clamp is provided in the Andersen Sampling Train to hold the stack head, probe tube, and condenser in place. The clamp has a standard 3 inch pipe thread for easy insertion into the access hole. When sampling for non-condensable particulates only, the probe tube may be screwed into the condenser for the removal of entrapped water. In this manner, the impinger may be eliminated entirely from the sampling apparatus. Whenever sampling for particulates and gases simultaneously, four Greenburg-Smith impingers in an ice bath will replace the condenser. Provisions are made so that the impinger case may be used with a rail. If a rail is not used to support the impinger case, a teflon-lined heated hose connecting the probe tube to the inlet part of the impinger case so that the case can be placed on the platform or ground could be used. In this manner, the temperature of the sample gases would be maintained above the dew point to prevent condensation upstream from the impinger case. The impinger case will replace the condenser also whenever one is concerned with collecting condensable particulates.

2.0 EQUIPMENT (SEE DRAWING 10048)


2.1 ANDERSEN STACK SAMPLING HEAD

The Andersen Stack Sampling Head consists of a stainless steel case and 1/2" female pipe fittings. It is designed to be inserted directly into the stack (standard 3 inch opening) where high temperature and/or corrosive conditions may exist.

The Sampler contains nine jet plates each having a pattern of precision-drilled orifices. The nine plates, separated by 2.5 millimeter stainless steel spacers, divide the sample into eight fractions or particle size ranges. The jets on each plate are arranged in concentric circles which are offset on each succeeding plate. The size of the orifices is the same on a given plate, but is smaller for each succeeding downstream plate. Therefore, as the sample is drawn through the Sampler

1004B

ZONE	LTR	DESCRIPTION	DATE	APPROV
B-5	A	CHANGED HERE	7-11-71	CP/E



NOTE:

REPLACE WITH GAS COLLECTION IMRINGER ASSY. (00-540) WHEN SAMPLING FOR GASES, GASES AND PARTICULATES OR CONDENSIBLE PARTICULATE.

EXPLODED VIEW

STACK WALL (REF)

- GOOSENECK NOZZLE (00-52)
- GOOSENECK NOZZLE (00-52)
- GOOSENECK NOZZLE (00-52)
- GOOSENECK NOZZLE (00-52)

THIS DRAWING AND ALL INFORMATION THEREON IS THE PROPERTY OF 2000 INCORPORATED AND IS PROPRIETARY IN NATURE. IT MUST NOT BE COPIED, REPRODUCED, OR DISCLOSED IN PART OR IN WHOLE WITHOUT WRITTEN PERMISSION BY 2000 INCORPORATED.

PATENT NO.		2 0 0 0 I N C.	
DRAWN		CHECKED	
ENGR.		PROJ.	
APPROVED, DESIGN ACTIVITY.		APPROVED	
MATERIAL:		SCALE NONE	
NEXT ASSY		USED ON	
APPLICATION		SHEET 1 OF 1	

ANDERSEN STACK TRAIN BLOCK DIAGRAM

SIZE CODE IDENT. NO. 1004B

DATE 3-4-71

at a constant flow rate, the jets of air flowing through any particular plate direct the particulates toward the collection area on the downstream plate directly below the circles of jets on the plate above. Since the jet diameters decrease from plate to plate, the velocities increase such that whenever the velocity imparted to a particle is sufficiently great, its inertia will overcome the aerodynamic drag of the turning airstream and the particle will be impacted on the collection surface. Otherwise, the particle remains in the airstream and proceeds to the next plate. Since the particle deposit areas are directly below the jets, seven of the plates act as both a jet stage and a collection plate. Thus, No. 0 plate is only a jet stage and No. 8 plate is only a collection plate. The types of plates available are stainless steel and nickel-plated brass. The case is made of 304 stainless steel. The temperature limitation of the Sampler is approximately 1500 degrees fahrenheit with the stainless steel plates.

The Andersen Stack Sampler has been calibrated by several independent laboratories in order to arrive at the current respective size cuts for each stage. The calibrations were referenced to unit density (1 g/cc), spherical particles so that the aerodynamically equivalent sized particles collected on each stage are always identical for any given flow rate. For this reason, a stack sample containing a mixture of shapes and densities is fractionated and collected according to its aerodynamic characteristics and is aerodynamically equivalent in size to the unit density spheres collected on each specific stage during calibration. For example, consider a golf ball and ping-pong ball of identical shape and physical size. Undoubtedly, they will not behave similarly in any environment because of the large differences in density. In other words, the aerodynamic size of a particle gives information relating to the physical size, shape, and density of the particle and indicates how the particle will behave in any environment. If the aerodynamic size distribution of the particulates in a stack sample is known, then the following pertinent information can be determined:

1. Particle behavior after leaving the stack.
2. Approximate area of environmental deposition.
3. Probable point of respiratory deposition.
4. Type of control equipment needed to collect the particles.


This type of information is impossible to obtain with only physical sizing data which is normally obtained by means of microscopic sizing or wet and/or dry screening.

Figure 1 is a plot of D_p versus flow rate through the Stack Sampler at 70° F. D_p is the effective aerodynamic diameter of a spherical, unit density particle. The efficiency of collection for polydisperse material as encountered under actual stack sampling conditions for any given effective cutoff diameter (ECD) is 95 plus percent.*

Figure 2 shows the correction factor for determining the physical diameter of spherical particles having other than unit density. Extreme caution should be exercised

*In Figure 1 it can be seen that the ECD for Stage 4 at 0.8 cfm is 2.0 microns (μ). For data presentation purposes, this means that essentially all of the 2.0 μ particles are separated by Stage 4 and collected on Stage 5. In reality, however, a small amount of the 2.1 μ particles that should be on Stage 5 pass on through to Stage 6. Likewise, a compensating small amount of the 1.9 μ particles that should be on Stage 6 land on Stage 5. The same correlation applies to the 2.2 μ and 1.8 μ particles, etc. In other words, the amount of overlapping on each stage is self-compensating.¹

Figure 1. Aerodynamic Diameter V₅₀ Rate through Andersen Stack Sampler



10, Aerodynamic Diameter, μm

Figure 2 Density Correction Factor for Physical Size of
Particles Captured in Andersen Stack Sampler





Figure 3. Temperature Correction Factor for Aerodynamic
Size of Particles Captured by Andersen Stack Sampler



when using Figure 2 because it is valid only if the assumption is made that the particles are spherical in shape. Normally this assumption is not valid. Multiply the effective aerodynamic diameter as determined from Figure 1 by the correction factor from Figure 2 to determine the physical diameter for that density.

Figure 3 shows the correction factor for determining the effective aerodynamic particle diameter for elevated temperatures. Multiply the effective aerodynamic diameter as determined from Figure 1 by the correction factor from Figure 3 to determine the diameter for that temperature.

3.3 END-TO-END CALIBRATION

Before actual sampling is begun, it is strongly recommended that an end-to-end calibration be performed at ambient conditions with a dry gas meter which has already been calibrated against a primary standard. As is, the flowmeter provides 95% accuracy for full scale reading; however, this accuracy will decrease at lower flow rates. For this reason, an end-to-end calibration at 3 or 4 points with a dry gas meter will provide extremely accurate flow information at any desired flow rate and can be accomplished in 10 - 15 minutes. Simply plot Flow Rate (as determined with the dry gas meter and stop watch) vs. flowmeter reading. Draw a line through the points and in this manner accurate, instantaneous flow measurements at any rate can be accomplished with only the flowmeter during actual stack sampling. The above calibration to be performed as quickly as possible to avoid any collection in stack head.

4.0 STACK SAMPLING PROCEDURE

Stack Sampling is simple in principle, but in practice it is complicated by the need to ensure that the collected particulates are representative of the particulates flowing at any one sampling point and also at all possible points in the cross section of the flue at the sampling position. The first requirement is satisfied by isokinetic sampling in which the inlet sampling nozzle velocity is equal and in the same direction as the flue gas velocity. The weight of particulates collected is then equal to the weight of particulates flowing through an area in the flue equal to the area of the sampling nozzle. If sampling is not isokinetic, the gas flow lines are disturbed by the presence of the nozzle and either too few or too many particles are collected.

The second requirement, ensuring that the sample is representative of the average particle flow past the sampling position, presents no problem when the distribution of solids flow is uniform over the area of the flue. Samples taken at all points will be identical and any chosen point will give a representative sample. The weight of solids E passing through the flue per unit time is then found by multiplying the weight w/t collected per unit time at the sampling point (w being the weight collected during the time t) by the ratio of the area A of the flue to the area a of the nozzle:

$$E = \frac{w}{t} \cdot \frac{A}{a}$$

However, the particulates are not usually distributed uniformly over the cross-sectional area of the flue and it is necessary to collect the sample in increments taken separately at each point and the average weight calculated from the separate observations, which is called incremental sampling. Or a single gross sample may be collected by moving the sampling nozzle from point to point which is called cumulative sampling. The incremental method is recommended for the beginner because it is easier to spot mistakes. Also, it is preferred by research investigators and is recommended for those who require the best accuracy because it gives information on the reliability of the average. The cumulative method may be slightly quicker and may be preferred by those doing routine testing not requiring the highest degree of accuracy. Incremental sampling is recommended when using the Andersen Stack Sampler. The cumulative method may be used on occasion and will be discussed later.

The accuracy of the measurements is dependent upon the proper choice of sampling points. The area of the flue is divided into a number of imaginary equal areas and the sample is made up of increments taken from the center point of each area. The greater the number of areas (greater number of sampling points) the more accurate the measurement will be.

In a circular duct, a traverse is made by dividing the duct into equal concentric areas and sampling in the center of each area on four sides of center. No sample is taken in the exact center. The number of equal areas chosen depends on the size of the duct and the accuracy desired. In a rectangular duct, a sample traverse is made by dividing the duct into equal areas and sampling at the center of each area. The number of areas used depends on the flow pattern and size of the duct. See Figure 4 for drawings and tables.

The Andersen Stack Head should be kept clean and assembled when not in use. Before using, examine the jet plates by holding them up to the light. If any hole is plugged, blow out with air or wash with a detergent-water solution and sponge. Rubbing back and forth across the holes usually suffices. The quickest and most economical way for cleaning the jet plates is to place the plates in an inexpensive ultrasonic cleaner with a solvent for a few seconds after each use to insure that the orifices are clean.

Under normal conditions, the orifices do not become plugged if proper sampling and handling techniques are followed. After the plates are cleaned, avoid touching the orifices to prevent oil and/or dirt from plugging the jet holes. If this precaution is taken, there are only two other causes of hole plugging: (1) collecting too much sample and (2) collecting a sample when the stack head temperature is below the dew point of the flue gases so that condensation occurs. These problems are easily eliminated by taking a sample of proper size and ensuring that the stack head temperature is maintained above the dew point during the sampling period.

With the jet plates in proper sequence, the sampler is ready to operate on the end of the probe tube. The appropriate nozzle is attached to the inlet end of the sampler to achieve the desired isokinetic sampling rate. The zero numbered plate is on the upstream end of the stack head followed by plates 1 through 8 respectively. Downstream from Stage 8 a backup filter and filter holder may be inserted if there is sub-micron material in the stack sample below the lower limit of the last collection stage. Glass fiber webs are recommended as backup filters if elevated stack gas temperatures are encountered.

The sampling head will operate efficiently in any position such as vertical or horizontal. Ideally, the collection head should be used with a straight inlet nozzle and an elbow on the downstream end connecting to the probe tube. This arrangement will work with any thin-walled stack (such as metal) and eliminates the possibility of particles being impinged in any bends or probe lines. If it is necessary to sample a thick-walled stack (such as brick) it will be impossible to insert the right angled elbow through a three inch sampling hole. In this case, the stack head will have to be connected in line with the probe tube and a standard gooseneck nozzle used.

After determining the average velocity pressure along the sampling line, the stack gas temperature is measured and the gas density is calculated. If the stack gases contain an appreciable amount of water vapor, a significant error will result if

not taken into consideration. With this data, the flue gas velocity is determined which also is the required inlet nozzle velocity. Choose the appropriate nozzle size to give the approximate velocity required for the flow range that is available. Then calculate the needed flow rate through the stack head at stack conditions (temperature and pressure) to give the correct nozzle velocity. $Q = AV$

Where: Q = actual flow rate in cubic feet per minute.

A = Area of the nozzle in square feet

V = Velocity in feet per minute.

Next, determine what flow rate is needed through the flowmeter at flowmeter conditions to give the required flow rate through the stack head at stack conditions.

EXAMPLE:

Cross Section Traverse

$\overline{VP}$	$\sqrt{\overline{VP}}$
.20	.448
.18	.424
.17	.413
.23	.480
.25	.500
.24	.491
.28	.530
.17	.413
.25	.500
.26	.510
.26	.510
.25	.510
.26	.510
.24	.491
.24	.491
.22	.470
.21	.459

Stack Temperature = 1115° F

Barometric Pressure = 26.0" Hg

Stack gases are dry.

Stack gas density at 32° F and 29.92" Hg = 0.0807 lbs/cu. ft.

V^2 = velocity pressure in inches of water

W = stack gas density in lbs/ft³

7-20-61 10:30 AM

1. *Journal of the American Medical Association*, 1997; 277: 103-107.

1. The first step in the process is to identify the problem or issue that needs to be addressed. This involves gathering information and understanding the context of the problem.

... ..

Journal of Management Education 30(6)p.789-804
© The Author(s) 2006. Reprints and permissions:
<http://www.sagepub.com/journalsPermissions.nav>

... ..

...and the fact that the *Journal* is a journal of the American Psychological Association, the largest and most influential organization in the field of psychology, adds to the journal's prestige and makes it a must-read for all psychologists.

2-8.150

$$\text{Average V P} = \left(\frac{8.150}{17} \right)^2 = 0.230$$

$$\text{Stack gas density} = 0.0807 \times \frac{26.0}{29.9} \times \frac{460 + 32}{460 + 1115} = 0.0310 \text{ lbs/cu. ft.}$$

$$\text{Stack gas velocity} = 18.27 \sqrt{\frac{VP}{W}} = 18.27 \sqrt{\frac{.230}{.0310}} = 49.8 \text{ feet per second}$$

$$= 49.8 \times 60 = 2988 \text{ feet per minute (fpm)}$$

Therefore, we need 2988 fpm inlet nozzle velocity.

1/4 inch nozzle area = 0.000341 ft²

$$Q = AV = (0.000341) (2988) = 1.02 \text{ cfm}$$

We need 1.02 cfm through the stack head at 1115° F and 26.0 inches H₂. At the flowmeter the pressure is 26.0" H₂ since it is downstream from the vacuum pump and exposed to the atmosphere. The flowmeter temperature is 85° F. Therefore, we need

$Q \times \frac{460 + 85}{450 + 1115} = 0.353 \text{ cfm}$ at the flowmeter to give the desired inlet nozzle velocity for isokinetic sampling.

If the velocity profile along the sample line is relatively flat (±15%) or if all of the particulates are 5 microns or less in size, then cumulative sampling may be performed without introducing significant errors (see Figure 5 for correcting to isokinetic rate). However, if the velocity profile is not uniform or if the particle size spectrum goes above 5 microns, then incremental sampling is recommended. This requires a clean set of plates at each point with a different flow rate to maintain isokinetic sampling. An alternate technique is to change nozzle diameters at the various sampling points while keeping the flow constant to adjust the inlet nozzle velocity. It is imperative that the flow rate does not change significantly while collecting a sample on a particular set of plates; otherwise, the particle size range collected on each plate will shift an unacceptably large amount with the changing flow rate.

Whenever collecting a sample, always turn the inlet nozzle away from the oncoming gas stream until the vacuum source is applied. At the same instant the pump is turned on, the sample nozzle may be turned into the oncoming flow gases. Also turn the inlet nozzle away from the oncoming gases as the pump is turned off. If the pump is turned on or off with the inlet nozzle facing the oncoming particulates, an error in collected sizes on each stage will be introduced. Before sampling, however, the pump should be turned on with the stack head out of the flow and the flow rate adjusted to the desired value as read on the flowmeter.

A unique feature of the Andersen Stack Sampler is that there is always a constant pressure drop across the entire system. Therefore, once the proper flow rate is adjusted, it will not change during the sampling period. This is particularly useful when sampling wet plumes. The Andersen Stack Sampler may be inserted directly into plumes saturated with water. The only point to keep in mind is that the stack head temperature must be maintained above the dew point to allow collection of dry samples on the plates with the vaporized water condensing out downstream in the condenser or impingers. An easy way to effect this is to wrap a constant temperature heat tape around the stack head and probe line. It will take 5 to 10 minutes for the stack head temperature to reach equilibrium. Of course, the gas temperature in the stack head must be monitored for flow rate determinations.

Good weighing accuracy is of primary concern during gravimetric analyses and is determined by the ratio of the quantity of sample collected to the sensitivity of the balance being used. A balance with four decimal place reading and sensitivity of 0.10 milligram is recommended. Normal samples vary from one to 10 milligrams per plate. Stage loadings in excess of 10 milligrams are not recommended because of re-entrainment problems.

Only with experience can an operator determine the optimum sampling time for a specific grain loading situation. The deposit areas should be discrete and there should be no material deposited between the sample piles which would indicate oversampling.

It is also suggested that tare weights be made on the plates after chemical and/or physical analyses and the plates have been cleaned. This eliminates the possibility of a change in tare weight taking place during the sampling period whenever sampling in hot and corrosive gases.




FIGURE 5

Some types of material become charged when passing through the orifices on the lower stages resulting in part of the sample adhering to the bottom side of the plates. This problem is easily remedied simply by grounding the probe line.

Whenever sampling for gases and/or condensible particulates, it is necessary to rinse the sampling train after the sampling is complete. Distilled water may be used as a wash for inorganic material. Organic constituents may be rinsed with acetone or another suitable organic solvent. The rinsing material should be poured into a beaker and retained for analysis.

When sampling for particulates only, the first two impingers are filled with exactly 250 and 150 ml of deionized water respectively. The quantity of water vapor in the stack can be determined by subtracting these initial volumes from the final volume. When sampling for a specific gas, the first impinger is left dry and the second is filled with 150 ml of the appropriate reagent. A precise volume is critical since condensation may occur in this impinger.

The third and fourth impingers trap any moisture leaving the first two impingers. The silica gel must be precisely weighed, as the difference in its weight after sampling will have to be taken into account.

To determine the weight of soluble and insoluble solids from the liquid impingers it is necessary to evaporate the liquid in a tared beaker. Then re-weigh the beaker to find total solids. If volatile organic particulate matter is collected, an extraction in some organic reagent such as chloroform or carbon tetrachloride is required. This reagent is then evaporated with a stream of dry air in a pre-weighed beaker and the difference in beaker weight before and after evaporation is the organic's weight.

The total weight of particulate matter collected is the sum of the aqueous and solvent residues.

5.0 DATA PRESENTATION

To determine the concentration of particulates for any specific size or size range first calculate the percentage of total particles for each stage. Then the cumulative percentage is determined beginning with either end of the impactor. Thus, if one starts with the first stage, 100% of the particles will be above 0 microns, some lesser percentage above the last stage, a lesser percentage yet above the next to last stage and so on.

Plot the cumulative percentage determined above against the corrected aerodynamic diameter of the particles corresponding to the same stage. Draw a smooth curve connecting the points. The curve will be hyperbolic in shape if standard arithmetic graph paper is used or a straight line will result if probability logarithmic graph paper is used. It is not uncommon for the curves to contain bulges whenever abnormal distributions occur. From the graph the particle concentration for any size range can be determined. Following in Table No. 1 and Figure 6 data from an actual sample is shown. Approximately 55% of the particles are below 0.59 microns. 100% of the particles are below 15.0 microns.

1. Personal communication, Dr. Andrew McFarland, University of Notre Dame, South Bend, Indiana - 1971.

100% PROBABILITY 48 8043
 X 3 LOG CYCLES
 KEUFFEL & ESSER CO.




TABLE 1

<u>Plate</u>	<u>Tare (g)</u>	<u>Final (g)</u>	<u>Net (mg)</u>	<u>Z</u>	<u>Cum. Z</u>	<u>ECD (Microns)</u>
1	20.48484	20.48628	1.34	13.4	100.0	15.0
2	21.38338	21.38394	.56	5.6	86.7	9.5
3	21.92025	21.92066	.41	4.1	81.1	6.3
4	21.55775	21.55817	.42	4.2	77.0	4.4
5	11.40815	11.40854	.39	3.9	72.8	2.86
6	11.61862	11.61961	.99	9.9	68.9	1.43
7	11.76540	11.76664	1.24	12.4	59.0	.87
8	20.99617	20.99737	1.20	12.0	46.6	.59
Back Up Filter	0.20810	0.21156	3.46	34.6	34.6	
Total			10.01			

APPENDIX D

CALIBRATION DATA

ENTROPY

CALIBRATIONS

GENERAL

All measuring equipment Entropy uses is initially calibrated before use. Equipment which can change calibration is both checked upon return from each field use and is also periodically recalibrated in full. When an instrument is found out of calibration, it is so noted in the report and appropriate adjustments are made to the final results. The equipment is then repaired and recalibrated or retired as needed. Specific equipment is handled as follows:

PITOT TUBE

All pitot tubes used by Entropy, whether separate or attached to a sampling probe, are constructed in-house or by Nutech Corporation. Prior to their initial usage, they are calibrated using EPA geometry standards. In general, if a type "S" pitot tube is assembled correctly, and positioned properly in relation to the probe nozzle, it will have an average C_p of 0.84. As long as it is not damaged, it should not change its calibration. The recalibration schedule for pitot tubes is related to the physical condition and usage of the pitot tube, not a fixed time schedule. Each pitot tube is inspected upon return to the laboratory from each field use.

DRY GAS METER AND ORIFICE METER

For the calibration of Entropy's dry gas metering systems, the protocol proposed in the Federal Register Vol. 47 No. 195, Thursday, October 7, 1982 is followed. Standard transfer meter number 1017057 (standard meter used for calibrating field metering systems) was calibrated with a spirometer at seven different flow rates between 0.25 and 1.40 cfm. Triplicate calibration runs were performed at each flow rate.

NOZZLES

Each nozzle is calibrated upon purchase, and thereafter whenever it becomes apparent that the nozzle has become damaged. Each nozzle is inspected upon return to laboratory from each field use. The diameter is measured on five different axes, with the high and low readings differing by no more than 0.004 inches as a tolerance.

TEMPERATURE MEASURING INSTRUMENTS

After each field use, the thermocouples or thermometers are calibrated against an ASTM precision mercury-in-glass thermometer across a wide range of temperatures. If the initial reading is not within $\pm 1.5\%$ of the absolute temperature reading of the standard thermometer, the instrument is adjusted until it is in the acceptable range.

MAGNEHELIC GAUGES

After each field use, each magnehelic gauge is calibrated against an inclined manometer at three different settings (low, medium, high) over the range of the individual gauges. If the readings differ more than $\pm 5\%$ from the manometer readings, the magnehelics are recalibrated.

BAROMETER

After each field use, each barometer is checked against a mercury barometer.

ENTROPY

Dry Gas Meter Identification: 1017057 Calibration by: Bruce Fowler

Date: 8/10/84

Barometric Pressure (P_b): 29.70 in. Hg

*Date: _____ *Barometric Pressure (P_b): _____ in. Hg



Approx. Flow Rate (Q) cfm	Spirometer # 2502		Dry Gas Meter		Pressure (Δp) in. H ₂ O	Time (t) min.	Flow Rate (Q) cfm	Meter Meter Coeff. (Y_{ds})	Avg. Meter Coeff. ($\bar{Y}_{ds}$)
	Gas Volume (V_g) ft ³	Temp. (t_g) °F	Gas Volume (V_{dgs}) ft ³	Temp. (t_{dgs}) °F					
0.25	2.550	73.4	2.554	76	-0.23	9.657	0.2594	1.0039	
	2.368	73.4	2.371	76	-0.22	9.170	0.2536	1.0041	
	2.468	77	2.486	77	-0.20	10.008	0.2406	0.9933	
0.40	3.962	73.4	3.999	75	-0.43	9.958	0.3908	0.9948	
	4.071	73.4	4.104	75	-0.43	10.033	0.3985	0.9960	
	4.089	73.4	4.118	76	-0.43	10.099	0.3977	0.9989	
0.60	5.993	75.2	6.090	77	-0.90	9.995	0.5869	0.9896	
	6.330	75.2	6.438	77	-0.95	10.001	0.6196	0.9889	
	6.330	75.2	6.435	77	-1.00	10.005	0.6193	0.9894	
0.80	7.933	73.4	8.046	76	-1.5	10.000	0.7792	0.9945	
	8.151	73.4	8.260	76	-1.6	10.001	0.8005	0.9956	
	8.188	73.4	8.302	76	-1.5	10.055	0.7998	0.9948	
1.00	9.153	75.2	9.298	76	-2.0	9.436	0.9495	0.9908	
	9.171	75.2	9.326	76	-2.0	9.460	0.9490	0.9898	
	9.126	75.2	9.304	76	-2.1	9.435	0.9468	0.9875	

$$Y_{ds} = \frac{(V_s)(t_{ds} + 460)(P_b)}{(V_{ds})(t_{ds} + 460)(P_b \pm (Q / 13.6))}$$

$$Q = (17.64) \frac{(P_b)(V_s)}{(t_s + 460)(Q)}$$

1017057

Calibration by:

Date: 8/10/84

Barometric Pressure (P_b): 29.70 in. Hg

#Date: _____

Barometric Pressure (P_b): _____ in. Hg

ENTROPY ENVIRONMENTALISTS, INC.

[illegible]

(viii) (c)(ii), (iii), (iv), (v), (vi)

$$Y_{d3} = \frac{(V_{A2} - U_2 + 460)(V_2 + (p/13.6))}{(V_{A2} - U_2 + 460)(V_2 + (p/13.6))}$$

$$u = (17.64) \frac{(v_1')^2 (v_2')}{(v_1' + v_2')^2} \quad (3)$$

CALIBRATION BY: MH

METER BOX NUMBER: N8

DATE: 2-27-85

BAROMETRIC PRESSURE (P_B): 29.64 IN. HG

*DATE: _____

*BAROMETRIC PRESSURE (P_B): _____ IN. HG

STANDARD METER NUMBER: 217057

COEFFICIENT (Y_{DS}): 0.9942

NOMINAL FLOW RATE ($\tilde{Q}$) CFM	STANDARD DRY GAS METER			METER BOX METERING SYSTEM		
	GAS VOLUME (V_{DS})	TEMP. (T_{DS})	TIME (θ)	ORIFICE SETTING (ΔH)	GAS VOLUME (V_D)	TEMP. (T_D)
	FT ³	°F	MIN.	IN. H ₂ O	FT ³	°F
0.4	1.165	69	10:00	0.50	4.248	89
	1.238	69	10:00	.5	4.324	87
0.8	3.443	69	10:00	1.10	8.700	88
	3.475	69	10:00	2.1	8.742	90
1.2	2.765	69	10:00	4.80	13.107	86
	2.702	69	10:00	4.8	13.079	89

NOMINAL FLOW RATE ($\tilde{Q}$) CFM	METER BOX METERING SYSTEM			
	FLOW RATE (Q_D)	ORIFICE FACTOR	COEFF.	$\Delta H @$
	CFM	(OF)	(Y_D)	IN. H ₂ O
0.4	0.4093	3.043	1.0104	1.590
	.4164	3.038	1.0063	1.541
0.8	.8296	6.231	0.9943	1.628
	.8328	6.242	.9969	1.610
1.2	1.2543	9.403	.9876	1.634
	1.2482	9.429	.9904	1.641
AVERAGE			0.998	1.61

$$\Delta H_D = \frac{0.0317 \cdot \Delta H}{P_B \cdot (T_D + 460)} \cdot \left[\frac{(T_{DS} - 460) \cdot \theta}{Y_{DS} \cdot V_{DS}} \right]^2$$

$$Y_D = \frac{Y_{DS} \cdot V_{DS} \cdot (T_D + 460) \cdot P_B}{V_D \cdot (T_{DS} + 460) \cdot (P_B - 33.5)}$$

ENTROPY

CALIBRATION BY: MF

METER BOX NUMBER: N 12

DATE: 11-7-84

BAROMETRIC PRESSURE (P_B): 29.89 IN. HG

*DATE: _____

*BAROMETRIC PRESSURE (P_B): _____ IN. HG

STANDARD METER NUMBER: 1017057

COEFFICIENT (Y_{DS}): 0.9947

NOMINAL FLOW RATE ($\tilde{Q}$) CFM	STANDARD DRY GAS METER			METER BOX METERING SYSTEM		
	GAS VOLUME (V_{DS})	TEMP. (T_{DS})	TIME	ORIFICE SETTING (ΔH)	GAS VOLUME (V_D)	TEMP.
	FT ³	°F	(θ) MIN.	IN. H ₂ O	FT ³	(T_{DS}) °F
0.4	4.128	66	10.0	.5	4.163	79
	4.109	67	10.0	.5	4.226	91
0.8	8.286	67	10.0	2.1	8.531	92
	8.296	67	10.0	2.1	8.515	93
1.2	13.717	66	11.0	4.8	13.959	86
	12.460	66	10.0	4.8	12.744	91

NOMINAL FLOW RATE ($\tilde{Q}$) CFM	METER BOX METERING SYSTEM			
	FLOW RATE (Q_D)	ORIFICE FACTOR	COEFF.	$\Delta H @$
	CFM	(OF)	(Y_D)	IN. H ₂ O
0.4	.4114	3.003	1.0090	1.616
	.4087	3.036	1.0095	1.602
0.8	.8242	6.238	1.0063	1.651
	.8252	6.233	1.0112	1.644
1.2	1.2427	9.364	1.0023	1.678
	1.2417	9.407	1.0064	1.666
AVERAGE			1.007	1.64

$$\Delta H_g = \frac{0.0317 \cdot \Delta H}{P_b \cdot (t_d + 460)} \cdot \left[\frac{(t_{ds} + 460) \cdot \theta}{Y_{ds} \cdot V_{ds}} \right]^2$$

$$Y_d = \frac{Y_{ds} \cdot V_{ds} \cdot (t_d + 460) \cdot P_b}{V_d \cdot (t_{ds} + 460) \cdot (P_b + \Delta H/13.6)}$$

ENTROPY

CALIBRATION BY: FREDDY JONES

METER BOX NUMBER: N-12

DATE: 10/6/85

BAROMETRIC PRESSURE (P_B): 29.55 IN. HG

*DATE: _____

*BAROMETRIC PRESSURE (P_B): _____ IN. HG

STANDARD METER NUMBER: 1017067

COEFFICIENT (Y_{DS}): 0.9924


POST-TEST METER BOX CALIBRATION

STANDARD DRY GAS METER				METER BOX METERING SYSTEM		
NOMINAL FLOW RATE ($\bar{Q}$) CFM	GAS VOLUME (V_{DS}) FT ³	TEMP. (T_{DS}) OF	TIME (t) MIN.	ORIFICE SETTING (ΔH) IN. H ₂ O	GAS VOLUME (V_D) FT ³	TEMP. (T_D) OF
	6.894	71	10.0	1.4	6.704	74
	6.893	71	10.0	1.4	6.717	79
	6.870	71	10.0	1.4	6.781	83
				VACUUM = <u>150</u> IN. HG		

METER BOX METERING SYSTEM				
NOMINAL FLOW RATE ($\bar{Q}$) CFM	FLOW RATE ($\bar{Q}$) CFM	ORIFICE FACTOR (OF)	COEFF. (Y_D)	ΔH IN. H ₂ O
	5.6728	5.030	1.0246	1.688
	5.6727	5.053	1.0229	1.673
	5.6705	5.072	1.0264	1.672
AVERAGE			1.024	1.68

$$\Delta P = \frac{0.0317 \cdot \Delta P}{P_B \cdot (T_D - 460)} \cdot \left[\frac{(T_{DS} - 460) \cdot P}{Y_{DS} \cdot V_{DS}} \right]^2$$

$$T_D = \frac{Y_{DS} \cdot V_{DS} \cdot (T_{DS} - 460) \cdot P_B}{V_D \cdot (T_{DS} - 460) \cdot (P_B - \Delta P/29.6)}$$



SCHEMATIC OF EQUIPMENT SET-UP FOR FULL AND POST-TEST METER BOX CALIBRATIONS

CALIBRATION BY: ML

METER BOX NUMBER: RAC 1

DATE: 11-8-84

BAROMETRIC PRESSURE (P_B): 29.95 IN. HG

*DATE: _____

*BAROMETRIC PRESSURE (P_B): _____ IN. HG

STANDARD METER NUMBER: 1017057

COEFFICIENT (Y_{DS}): 0.9942

NOMINAL FLOW RATE ($\tilde{Q}$) CFM	STANDARD DRY GAS METER			METER BOX METERING SYSTEM		
	GAS VOLUME (V_{DS})	TEMP. (T_{DS})	TIME	ORIFICE SETTING (ΔH)	GAS VOLUME (V_D)	TEMP.
	FT ³	°F	(θ) MIN.	IN. H ₂ O	FT ³	°F
0.4	4.023	66	10.0	.5	4.089	72
	4.004	66	10.0	.5	4.184	90
0.8	7.978	66	10.0	2.1	8.318	91
	9.607	66	12.0	2.1	10.040	96
1.2	11.933	66	10.0	4.8	12.175	84
	11.927	66	10.0	4.8	12.251	89

NOMINAL FLOW RATE ($\tilde{Q}$) CFM	METER BOX METERING SYSTEM			
	FLOW RATE (Q_D)	ORIFICE FACTOR	COEFF.	$\Delta H @$
	CFM	(OF)	(Y_D)	IN. H ₂ O
0.4	0.4017	2.980	0.9881	1.720
	0.3998	3.030	0.9936	1.680
0.8	0.7967	6.216	0.9936	1.774
	0.7994	6.244	1.0004	1.746
1.2	1.1916	9.337	0.9960	1.836
	1.1910	9.380	0.9985	1.821
AVERAGE			0.995	1.76

$$\Delta H_D = \frac{0.0317 \cdot \Delta H}{P_B \cdot (T_d + 460)} \cdot \left[\frac{(T_{ds} + 460) \cdot \theta}{Y_{ds} \cdot V_{ds}} \right]^2$$

$$Y_d = \frac{Y_{ds} \cdot V_{ds} \cdot (T_d + 460) \cdot P_B}{V_d \cdot (T_{ds} + 460) \cdot (P_B + \Delta H/13.6)}$$

ENTROPY

NOZZLE NUMBER: 104

[illegible]

NOZZLE NUMBER: 109

[illegible]

110

**ENTROPY
ENVIRONMENTALISTS, INC.**

NOZZLE NUMBER: 503

[illegible]

NOTE: All diameters measured in inches.

