


Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

BR 2.2

\*30  
4.0



# ANCHORAGE WATER & WASTEWATER UTILITY



3000 Arctic Boulevard  
Anchorage, Alaska 99503  
(907)

Tony Knowles  
Mayor

Owned by the Municipality  
of Anchorage

March 1, 1985

RECEIVED MAR 7 1985

Midwest Research Institute  
4505 Creedmoor Rd., Suite 202  
Raleigh, North Carolina 27612

Attention: Mr. Richard Cooper

RE: Sludge Incinerator Emissions Report

Mr. Cooper:

Attached please find a copy of our most recent incinerator emissions analysis which you requested for your survey. You additionally requested the geographic location of the facility. This information is as follows:

Latitude:  $61^{\circ} 12'$  North  
Longitude:  $150^{\circ} 2'$  West

If I may be of further assistance please write or call me at (907) 243-2151.

Sincerely,

A handwritten signature in cursive script that reads "J. Kris Warren".  
J. KRIS WARREN  
Superintendent  
Wastewater Treatment  
Anchorage Water & Wastewater Utility

JKW/tls



# American Services Associates

Consultants in Air, Water, Energy, Hygiene & Management

May 24, 1984

Mr. J. Kris Warren  
ANCHORAGE WATER & WASTEWATER UTILITY  
P.O. Box 6285  
Anchorage, Alaska 99502-2085

Dear Kris,

### Re: Clarifications-4/84 Pt Woronzof Sludge Incinerator Test

Our conference call conversation with Bill MacClarence of the Alaska Department of Environmental Conservation (ADEC) brought up the need for clarification of the following elements on the subject report. I apologize that the subject report requires these clarification comments.

1. How the atmospheric emissions were corrected to a carbon dioxide concentration of 12% less the contribution from auxiliary fuel (i.e. natural gas in the case of Pt. Woronzof Sewage Sludge Incinerator).
2. How the flowrate of shaft cooling air was determined.
3. How to determine if carbon dioxide is being absorbed in the scrubber which thereby increases the reported particulate emissions.

### Particulate Emission Corrections to 12% Carbon Dioxide

Particulate emissions on combustion sources can be diluted with air to meet emission standards based upon concentration bases. The correction to 12% carbon dioxide was developed to prevent air dilution as a means to get combustion sources to dilute with ambient air as a means to meet the particulate emission standard (i.e. "Dilution is NOT the Solution to Pollution").

The correction of particulate emissions from combustion sources to 12% carbon dioxide is based upon burning bituminous coal with 50% more air than is required for theoretically perfect combustion (Theoretically perfect burning of bituminous coal will produce 18% carbon dioxide in the exhaust gas). At the time the 12% carbon dioxide standard was developed, 50% excess air was an acceptable quantity of excess air to satisfactorily burn bituminous coal. The particulate emissions from combustion sources are measured and no correction is made if the carbon dioxide in the exhaust stack is 12%. If the exhaust gas concentration of the stack is 6% carbon dioxide, the combustion source burning bituminous coal is diluting with air (i.e. 100% excess air) so the particulate emissions are "corrected" to 12% carbon dioxide by a factor (i.e. 12/measured % carbon dioxide in the exhaust gas stack) to correct the exhaust gas back to 12% carbon dioxide and 50% excess air.

Combustion sources burn with supplemental fuel (i.e. auxiliary fuel) to perform special operations such as ignite the material being burned, raise the temperature in an afterburner to maintain a high temperature for combustion to be completed, evaporate water so the material will burn. The auxiliary fuel contributes carbon dioxide to the exhaust gas. Because the auxiliary fuel used in afterburners or in the burners of incinerators is assumed to burn efficiently and completely but contributes carbon dioxide to the exhaust gases, the quantity of carbon dioxide in the exhaust gases must be known and

subtracted from the carbon dioxide in the exhaust gas from the material being burned to determine the particulate emissions from the material being burned.

Auxiliary fuel is typically natural gas which is composed of 95% to 98% methane (i.e. one part carbon combined with four parts hydrogen-CH4). Methane will burn completely in an incinerator and produce one part carbon dioxide (i.e. CO<sub>2</sub>) for each one part of methane burned. Assuming that all of the auxiliary fuel is methane, that the fuel burns completely and that 24,500 cubic feet/day (i.e. 17 cubic feet per minute) was burned while the samples were being collected, then 17 cubic feet of methane was produced in the exhaust stack from the auxiliary fuel. The resulting carbon dioxide contribution in the exhaust gas from the auxiliary fuel is therefore 17 cubic feet per minute (i.e. standard cubic foot at 68 degrees F, one atmosphere pressure and dry). Using an average exhaust gas airflow of 5012 standard cubic feet per minute, the percent carbon dioxide from the auxiliary fuel is therefore:  $17 \times 100 / 5012 = 0.34\%$  carbon dioxide from auxiliary fuel

The 0.35% was subtracted from the measured carbon dioxide for each run (i.e. 5.66, 5.57 & 5.53% for Run Nos 1, 2 & 3 respectively) to arrive at the carbon dioxide from the material being burned of 5.32, 5.23 & 5.19% for Run Nos. 1, 2 & 3 respectively. The particulate emission correction to 12% carbon dioxide for each run was therefore 12/5.32, 12/5.23 and 12/5.19 for Run Nos 1, 2 & 3 respectively.

A more accurate analysis of the carbon dioxide contribution from the auxiliary fuel can be made from a reference provided by Mr. Bill MacClarence of ADEC if the composition of the natural gas is known. A copy of the procedure provided by Mr. MacClarence is enclosed as Reference No. 1. to this clarification.

#### Shaft Cooling Airflow Determination

The incinerator shaft is cooled with air (i.e. shaft cooling air) provided from a separate fan below the incinerator. The cooling air is then mixed with the incinerator exhaust gas (i.e. after the induced draft (I.D.) fan which pulls the exhaust gas out of the incinerator and through the scrubber) and exhausts through the roof and into the stack where the particulate samples were collected.

The quantity of air in the exhaust gases that was contributed from the shaft cooling air fan is necessary to know because it affects the opacity (i.e. the density of smoke) from the incinerator. The opacity meter is located at the scrubber outlet ahead of the shaft cooling air entrance point. The opacity meter is therefore reading a darker opacity than the stack exhaust. The temperature increases from approximately 60 degrees F at the scrubber outlet to 135 degrees F (from mixing with the over 400 degrees F shaft cooling air) at the stack also reduces the opacity at the outlet of the stack.

The quantity of shaft cooling air was determined by performing a mathematical balancing of the oxygen and air entering the stack from the two sources (i.e. air from the incinerator outlet and shaft cooling). Oxygen readings were taken with a Honeywell A7001 analyzer at the induced draft fan outlet and in the exhaust stack where the samples were collected. Knowing that the oxygen concentration of the dilution air is 21%, the total airflow is 5012 dscfm, the average oxygen at the incinerator exhaust fan outlet was 13.65%, the average oxygen concentration at the stack was 15.88% and balancing the oxygen and air

with the two equations listed below, the quantity of dilution air was determined.

$$\text{EQ 1. Incin Air} + \text{Dil Air} = \text{Stack Air} = I + D = 5012 \text{ dscfm}$$

$$\text{EQ 2, Incin O}_2 + \text{Dil O}_2 = \text{Stack O}_2 = (0.1588)(5012) = 795.9$$

$$(I)(0.1365) + (D)(0.21) = 795.9 \text{ with } D = 5012 - I$$

$$\text{Therefore, } D = 1521 \text{ dscfm}$$


The effect of dilution air on the emissions is accounted for in the correction to 12% carbon dioxide. Therefore the dilution air was not utilized to calculate an adjusted particulate emission concentration.

#### Carbon Dioxide Scrubber Absorption Effects on Emissions

Carbon dioxide can be absorbed in scrubber water which reduces the measured carbon dioxide concentration at the stack and therefore the 12% carbon dioxide correction factor is larger and the calculated particulate emission is larger. Mr. MacClarence of ADEC provided a reference (i.e. Reference No. 2 enclosed) to account for the absorption of carbon dioxide by the scrubber. Airflow and carbon dioxide before the scrubber were not measured on this project and because the particulate emissions were exceptionally low, the calculation of an adjusted carbon dioxide concentration was not performed. Mr. MacClarence's interest in accuracy in particulate emission concentration and opacity is to be commended in finding and providing the enclosed Reference No. 2. The measurement of carbon dioxide will be made simultaneously at the scrubber inlet and the stack on the next particulate emission sample to determine the significance of the scrubber absorption of carbon dioxide.

The above observations have been made to clarify the subject report. I apologize that the subject report was not clear enough for the layman to understand and will endeavor to make future reports more clear. What specific report improvements would make the subject report more clear to the layman?

Yours truly,  
AMERICAN SERVICES ASSOCIATES  
dba ASA CONSULTANTS



Wesley D. Snowden, P.E.

enclosures:

cc: Mr. Bill MacClarence  
ALASKA DEPARTMENT OF ENVIRONMENTAL CONSERVATION  
437 E Street  
Anchorage, Alaska 99501

REFERENCE No. 1 - CO<sub>2</sub> from Natural Gas Auxiliary Fuel  
 (Provided by courtesy of Mr. Bill MacClarence of ADEC-5/84)

COMBUSTION CALCULATION FOR NATURAL GAS

Fuel Analysis, Percent by Volume as Fired	ft <sup>3</sup> /ft <sup>3</sup> of combustible required for combustion			required for combustion moles/100 moles Fuel @ 100 percent total air			
	O <sub>2</sub>	Air	O <sub>2</sub>	Dry Air			
CH <sub>4</sub>	94.6	x	2.0 and x	9.528	=	189.2	901.3
C <sub>2</sub> H <sub>6</sub>	3.0		3.5	16.675		10.5	50.025
C <sub>3</sub> H <sub>8</sub>	0.5		5.0	23.821		2.5	11.911
C <sub>4</sub> H <sub>10</sub>	0.5		6.5	30.967		3.25	15.484
C <sub>5</sub> H <sub>12</sub>	0.2		8.0	30.114		1.6	6.023
N <sub>2</sub>	0.7		-	-		-	-
CO <sub>2</sub>	0.5		-	-		-	-
	100					207.05	984.743

$$\text{Total Air} = \left[ \frac{100}{\left[ \frac{(4407.0 + 4739.9 + 4240.5) \text{ SCFM exhaust-29.1 SCFM nat. gas}}{3} \right]} \right] \frac{29.1 \text{ SCFM natural gas}}{= 15234.9 \text{ percent}}$$

$$\text{Moles/100 Moles Fuel @ 15234.9% Total Air}$$

$$\text{O}_2 \text{ and dry air } \times \frac{15234.9\%}{100\%}, \text{ total} = \frac{\text{O}_2}{31543.9} \quad \frac{\text{Dry Air}}{150024.6}$$

$$\text{Excess air} = 150024.6 - 984.7 \quad 149039.9$$

$$\text{Excess O}_2 = 31543.9 - 207.1 \quad 31336.8$$

Products of Combustion

									Moles/100 Moles Fuel @ 15234.9	Percent by Volume
									Total Air	Dry Basis
CH <sub>4</sub>	C <sub>2</sub> H <sub>6</sub>	C <sub>3</sub> H <sub>8</sub>	C <sub>4</sub> H <sub>10</sub>	C <sub>5</sub> H <sub>12</sub>	N <sub>2</sub>	CO <sub>2</sub>	H <sub>2</sub> O*		105.6	0.07
CO <sub>2</sub>	94.6x1	3.0x2	0.5x3	0.5x4	0.2x5	---	0.5	--	1379.5	--
H <sub>2</sub> O	94.6x2	3.0x3	0.5x4	0.5x5	0.2x6	---	---		1583.4	
N <sub>2</sub>	(150024.6 x 0.79)				0.7	---	---		118520.1	79.03
O <sub>2</sub>	(excess)								31336.8	20.90
									151545.9	
									149962.5	100.00

$$\text{Wet/Dry} = 151545.9 - 1583.4$$

$$\text{*Moles H}_2\text{O in air:}$$

$$\frac{149039.9 \text{ Moles air}}{100 \text{ Moles Fuel}} \times \frac{28.77 \text{ lb air}}{\text{mole air}} \times \frac{.0058 \text{ lb H}_2\text{O}}{\text{lb air}} \times \frac{\text{Mole H}_2\text{O}}{18.02 \text{ lb H}_2\text{O}} = \frac{1379.5 \text{ moles H}_2\text{O}}{100 \text{ Moles Fuel}}$$

(3) The minimum data requirements have or have not been met; or, the minimum data requirements have not been met for errors that were unavoidable.

(4) Compliance with the standards has or has not been achieved during the reporting period.

(h) For the purposes of the reports required under § 60.7, periods of excess emissions are defined as all 6-minute periods during which the average opacity exceeds the applicable opacity standards under § 60.42a(b). Opacity levels in excess of the applicable opacity standard and the date of such excesses are to be submitted to the Administrator each calendar quarter.

(i) The owner or operator of an affected facility shall submit the written reports required under this section and subpart A to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.

(Sec. 114, Clean Air Act as amended (42 U.S.C. 7414).)

**Subpart E—Standards of Performance for Incinerators**

**§ 60.50 Applicability and designation of affected facility.**

[42 FR 37936, July 25, 1977]

(a) The provisions of this subpart are applicable to each incinerator of more than 45 metric tons per day charging rate (50 tons/day), which is the affected facility.

(b) Any facility under paragraph (a) of this section that commences construction or modification after August 17, 1971, is subject to the requirements of this subpart.

**§ 60.51 Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in Subpart A of this part.

(a) "Incinerator" means any furnace used in the process of burning solid waste

for the purpose of reducing the volume of the waste by removing combustible matter.

(b) "Solid waste" means refuse, more than 50 percent of which is municipal type waste consisting of a mixture of paper, wood, yard wastes, food wastes, plastics, leather, rubber, and other combustibles, and noncombustible materials such as glass and rock.

(c) "Day" means 24 hours.

**§ 60.52 Standard for particulate matter.**

(a) On and after the date on which the performance test required to be conducted by § 60.8 is completed, no owner or operator subject to the provisions of this part shall cause to be discharged into the atmosphere from any affected facility any gases which contain particulate matter in excess of 0.18 g/dscm (0.08 gr/dscf) corrected to 12 percent CO<sub>2</sub>.

[39 FR 20790, June 14, 1974]

**§ 60.53 Monitoring of operations.**

(a) The owner or operator of any incinerator subject to the provisions of this part shall record the daily charging rates and hours of operation.

[39 FR 20790, June 14, 1974]

(Sec. 114 of the Clean Air Act as amended (42 U.S.C. 7414).)

**§ 60.54 Test methods and procedures.**

(a) The reference methods in Appendix A to this part, except as provided for in § 60.8(b), shall be used to determine compliance with the standard prescribed in § 60.52 as follows:

(1) Method 5 for the concentration of particulate matter and the associated moisture content;

(2) Method 1 for sample and velocity traverses;

(3) Method 2 for velocity and volumetric flow rate; and

(4) Method 3 for gas analysis and calculation of excess air, using the integrated sample technique.

(b) For Method 5, the sampling time for each run shall be at least 60 minutes and the minimum sample volume shall be 0.85 dscm (30.0 dscf) except that smaller sampling times or sample volumes, when necessitated by process variables or other factors, may be approved by the Administrator.

(c) If a wet scrubber is used, the gas analysis sample shall reflect flue gas conditions after the scrubber, allowing for carbon dioxide absorption by sampling the gas on the scrubber inlet and outlet sides according to either the procedure under paragraphs (c) (1) through (c) (5) of this section or the procedure under paragraphs (c) (1), (c) (2) and (c) (6) of this section as follows:

(1) The outlet sampling site shall be the same as for the particulate matter measurement. The inlet site shall be selected according to Method 1, or as specified by the Administrator.

(2) Randomly select 9 sampling points within the cross-section at both the inlet and outlet sampling sites. Use the first set of three for the first run, the second set for the second run, and the third set for the third run.

(3) Simultaneously with each particulate matter run, extract and analyze for CO<sub>2</sub> an integrated gas sample according to Method 3, traversing the three sample points and sampling at each point for equal increments of time. Conduct the runs at both inlet and outlet sampling sites.

(4) Measure the volumetric flow rate at the inlet during each particulate matter run according to Method 2, using the full number of traverse points. For the inlet make two full velocity traverses approximately one hour apart during each run and average the results. The outlet volumetric flow rate may be determined from the particulate matter run (Method 5).

(5) Calculate the adjusted CO<sub>2</sub> percentage using the following equation:

$$(\% \text{ CO}_2)_{\text{adj}} = (\% \text{ CO}_2)_{\text{at}} \cdot (Q_{\text{at}}/Q_{\text{ad}})$$

where:  
 $(\% \text{ CO}_2)_{\text{at}}$  is the adjusted CO<sub>2</sub> percentage which removes the effect of CO<sub>2</sub> absorption and dilution air.

$(\% \text{ CO}_2)_{\text{at}}$  is the percentage of CO<sub>2</sub> measured before the scrubber, dry basis.

$Q_{\text{at}}$  is the volumetric flow rate before the scrubber, average of two runs, dscf/min (using Method 2), and

$Q_{\text{ad}}$  is the volumetric flow rate after the scrubber, dscf/min (using Methods 2 and 5).

(6) Alternatively, the following procedures may be substituted for the procedures under paragraphs (c) (3), (4), and (5) of this section:

(i) Simultaneously with each particulate matter run, extract and analyze for CO<sub>2</sub>, O<sub>2</sub>, and N<sub>2</sub> an integrated gas sample according to Method 3, traversing the three sample points and sampling for

Note      Final      Sample taken      4/29/83

RECEIVED before      scrubber      9.0% CO<sub>2</sub>

AMERICAN  
 STANDARDS  
 INSTITUTE

ALSID, SMITH, ASSOC.

equal increments of time at each point. Conduct the runs at both the inlet and outlet sampling sites.

(ii) After completing the analysis of the gas sample, calculate the percentage of excess air (% EA) for both the inlet and outlet sampling sites using equation 3-1 in Appendix A to this part.

(iii) Calculate the adjusted CO<sub>2</sub> percentage using the following equation:

$$(\% \text{ CO}_2)_{\text{adj}} = (\% \text{ CO}_2)_{\text{in}} \left[ \frac{100 + (\% \text{ EA})_{\text{in}}}{100 + (\% \text{ EA})_{\text{out}}} \right]$$

where:

(% CO<sub>2</sub>)<sub>in</sub> is the adjusted outlet CO<sub>2</sub> percentage,

(% CO<sub>2</sub>)<sub>out</sub> is the percentage of CO<sub>2</sub> measured before the scrubber, dry basis,

(% EA)<sub>in</sub> is the percentage of excess air at the inlet, and

(% EA)<sub>out</sub> is the percentage of excess air at the outlet.

(d) Particulate matter emissions, expressed in g/dscm, shall be corrected to 12 percent CO<sub>2</sub> by using the following formula:

$$c_{12} = \frac{12c}{c_{\text{CO}_2}}$$

where:

c<sub>12</sub> is the concentration of particulate matter corrected to 12 percent CO<sub>2</sub>,

c is the concentration of particulate matter as measured by Method 5, and

% CO<sub>2</sub> is the percentage of CO<sub>2</sub> as measured by Method 3, or when applicable, the adjusted outlet CO<sub>2</sub> percentage as determined by paragraph (c) of this section.

[39 FR 20790, June 14, 1974]

(Sec. 114 of the Clean Air Act as amended (42 U.S.C. 7414).)

#### Subpart E—Standards of Performance for Portland Cement Plants

##### **§ 60.60 Applicability and designation of affected facility.**

[42 FR 37936, July 25, 1977]

(a) The provisions of this subpart are applicable to the following affected facilities in portland cement plants: kiln, clinker cooler, raw mill system, finish mill system, raw mill dryer, raw material storage, clinker storage, finished product storage, conveyor transfer points, bagging and bulk loading and unloading systems.

(b) Any facility under paragraph (a) of this section that commences construction or modification after August 17, 1971, is subject to the requirements of this subpart.

##### **§ 60.61 Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in Subpart A of this part.

(a) "Portland cement plant" means any facility manufacturing portland cement by either the wet or dry process.

##### **§ 60.62 Standard for particulate matter.**

(a) On and after the date on which the performance test required to be conducted by § 60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any kiln any gases which:

(1) Contain particulate matter in excess of 0.15 kg per metric ton of feed (dry basis) to the kiln (0.30 lb per ton).

(2) Exhibit greater than 20 percent opacity.

[39 FR 39872, November 12, 1974]

(b) On and after the date on which the performance test required to be conducted by § 60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any clinker cooler any gases which:

(1) Contain particulate matter in excess of 0.050 kg per metric ton of feed (dry basis) to the kiln (0.10 lb per ton).

(2) Exhibit 10 percent opacity, or greater.

(c) On and after the date on which the performance test required to be conducted by § 60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility other than the kiln and clinker cooler any gases which exhibit 10 percent opacity, or greater.

(d) [Deleted].

[39 FR 20790, June 14, 1974; 40 FR 36250, October 6, 1975]

##### **§ 60.63 Monitoring of operations.**

(a) The owner or operator of any portland cement plant subject to the provisions of this part shall record the daily production rates and kiln feed rates.

[39 FR 20790, June 14, 1974]

(Sec. 114 of the Clean Air Act as amended (42 U.S.C. 7414).)

##### **§ 60.64 Test methods and procedures.**

(a) The reference methods in Appendix A to this part, except as provided for in § 60.8(b), shall be used to determine compliance with the standards prescribed in § 60.62 as follows:

(1) Method 5 for the concentration of particulate matter and the associated moisture content;

(2) Method 1 for sample and velocity traverses;

(3) Method 2 for velocity and volumetric flow rate; and

(4) Method 3 for gas analysis.

(b) For Method 5, the minimum sampling time and minimum sample volume for each run, except when process variables or other factors justify otherwise to the satisfaction of the Administrator, shall be as follows:

(1) 60 minutes and 0.85 dscm (30.5 dscf) for the kiln.

(2) 60 minutes and 1.15 dscm (40.6 dscf) for the clinker cooler.

(c) Total kiln feed rate (except fuels), expressed in metric tons per hour on a dry basis, shall be determined during each testing period by suitable methods; and shall be confirmed by a material balance over the production system.

(d) For each run, particulate matter emissions, expressed in g/metric ton of kiln feed, shall be determined by dividing the emission rate in g/hr by the kiln feed rate. The emission rate shall be determined by the equation, g/hr = Q<sub>c</sub> × c, where Q<sub>c</sub> = volumetric flow rate of the total effluent in dscm/hr as determined in accordance with paragraph (a)(3) of this section, and c = particulate concentration in g/dscm as determined in accordance with paragraph (a)(1) of this section.

[39 FR 20790, June 14, 1974]

(Sec. 114 of the Clean Air Act as amended (42 U.S.C. 7414).)

#### Subpart G—Standards of Performance for Nitric Acid Plants

##### **§ 60.70 Applicability and designation of affected facility.**

[42 FR 37936, July 25, 1977]

(a) The provisions of this subpart are applicable to each nitric acid production unit, which is the affected facility.

(b) Any facility under paragraph (a) of this section that commences construction or modification after August 17, 1971, is subject to the requirements of this subpart.

##### **§ 60.71 Definition.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in Subpart A of this part.

(a) "Nitric acid production unit" means any facility producing weak nitric acid by either the pressure or atmospheric pressure process.

(b) "Weak nitric acid" means acid which is 30 to 70 percent in strength.

##### **§ 60.72 Standard for nitrogen oxides.**

(a) On and after the date on which the performance test required to be conducted by § 60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases which:

[Sec. 60.72(a)]



# ANCHORAGE WATER & SEWER UTILITIES

3000 Arctic Boulevard  
Anchorage, Alaska 99503  
(907) 277-7622



Tony Knowles  
Mayor

Owned by the Municipality  
of Anchorage

May 7, 1984

Alaska Department of Environmental Conservation  
417 E. Street  
Anchorage, AK 99501

Attention: Mr. Bill Clarence

Reference: Pt. Woronzof Wastewater Treatment Facility.  
Incinerator Stack Emissions Report AAPCA-0580/ACC-517  
Permits.

Dear Mr. Clarence:

Listed below is information required semi-annually by the referenced permits. Attached is the stack analysis report required annually. This reporting period covers October 1983 through March 1984.

1. Days Operated:

1983	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>	1984	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>
	27.0	26.2	27.5		6.0*	0*	26.9

2. Average Hourly Charging Rate (Dry lbs per hour)

1983	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>	1984	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>
	1428	1322	1067		687*	NA*	NA**

3. Fuel Consumed (x 100 ft<sup>3</sup> Natural Gas)

1983	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>	1984	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>
	14409	13939	16930		3517*	NA*	8298

4. Opacity: Problems with both the old and new opacity instruments have persisted for the entire reporting period. Therefore, the information required by both permits regarding this parameter is unavailable.
- \* The sludge incinerator was down for three weeks in January and the entire month of February for a major overhaul.
- \*\* This figure is unavailable for March due to sampling and metering failures.

The next emmissions report will be submitted in October of this year. If any questions arise concerning this report I can be reached at telephone number 338-3870.


Sincerely,

RICHARD E. HUTSON  
Manager  
Treatment Division  
AWWU



# ANCHORAGE WATER & SEWER UTILITIES

3000 Arctic Boulevard  
Anchorage, Alaska 99503  
(907) 277-7622



Tony Knowles  
Mayor

Owned by the Municipality  
of Anchorage

May 7, 1984

Department of Health & Environmental Protection  
825 L. Street  
Anchorage, AK 99504

Attention: Mr. Robert L. Rasmussen  
Anchorage Air Pollution Control Agency

Reference: Pt. Woronzof Wastewater Treatment Facility.  
Incinerator Stack Emissions Report AAPCA-0580/ACC-517  
Permits.

Dear Mr. Rasmussen:

Listed below is information required semi-annually by the referenced permits. Attached is the stack analysis report required annually. This reporting period covers October 1983 through March 1984.

1. Days Operated:

1983	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>	1984	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>
	27.0	26.2	27.5		6.0*	0*	26.9

2. Average Hourly Charging Rate (Dry lbs per hour)

1983	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>	1984	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>
	1428	1322	1067		687*	NA*	NA**

3. Fuel Consumed (x 100 ft<sup>3</sup> Natural Gas)

1983	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>	1984	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>
	14409	13939	16930		3517*	NA*	8298

4. **Opacity:** Problems with both the old and new opacity instruments have persisted for the entire reporting period. Therefore, the information required by both permits regarding this parameter is unavailable.
  - \* The sludge incinerator was down for three weeks in January and the entire month of February for a major overhaul.
  - \*\* This figure is unavailable for March due to sampling and metering failures.

The next emmissions report will be submitted in October of this year. If any questions arise concerning this report I can be reached at telephone number 338-3870.

Sincerely,


RICHARD E. HUTSON  
Manager  
Treatment Division  
AWWU

# **ATMOSPHERIC EMISSION EVALUATION**

**ANCHORAGE WATER & WASTEWATER UTILITY  
SEWAGE SLUDGE INCINERATOR  
APRIL 1984**

**ASA CONSULTANTS**

15049 Bel-Red Road, Bellevue, WA 98007 (206)641-5130





# ASA CONSULTANTS

AIR, WATER, ENERGY, HYGIENE & MANAGEMENT


April 27, 1984

## INTRODUCTION

This atmospheric emission evaluation was performed at the Sewage Sludge Incinerator at the Point Woronzof Wastewater Treatment Plant which is owned and operated by the Municipality of Anchorage, Water and Wastewater Utility (AW&WWU). The tests were collected on April 13, 1984 to assess the atmospheric emissions for comparison to the State of Alaska, Department of Environmental Conservation (ADEC) regulations. The emission tests were observed and visible emissions were recorded by Mr. Bill MacClarence of ADEC. Mr. Wesley D. Snowden of ASA CONSULTANTS (ASA) performed this evaluation.

## SUMMARY

Atmospheric emissions were found to be 0.013, 0.015 and 0.014 grains per standard cubic foot of exhaust gas from three (3) samples while incinerating 1294, 1159 and 1193 pounds of dry solids per hour containing 28% moisture plus 18 gallons/hour of "scum" for Run Nos. 1, 2 & 3 respectively. The scrubber was operating at 11.0 inches water column pressure drop while utilizing 280 gallons of plant effluent water per minute for particulate removal. The standard cubic foot of exhaust gas is reported at 68 degrees F, 1.0 atmosphere pressure (i.e. 29.92 inches of mercury pressure), dry and corrected to 12% carbon dioxide less the contribution of carbon dioxide from the combustion of natural gas.

ASA CONSULTANTS  
  
Wesley D. Snowden, P.E.

### DISCUSSION

The incinerator at the Point Woronzof Treatment Plant of the Anchorage Water and Wastewater Utility is a continuous feed, continuous ash removal incinerator. The incinerator is identified as Furnace No. 71343 built by BSP-Envirotech in Belmont, California. A log of incinerator operation was maintained during the times the samples were collected and is available from J. Kris Warren of the Anchorage Water & Wastewater Utility (907)243-2151.

Over five (5.68) diameters were available ahead and more than two (2) diameters of straight unobstructed duct were available behind the two (2) sample ports at 90 degrees apart so sixteen (16) traverse points on each of two (2) diameters were selected for collecting the first sample. The first sample revealed a uniform velocity and resulted in collecting over 80 cubic feet of sample requiring 96 minutes to complete using three (3) minutes per sample traverse point. Samples two and three were collected with the same three (3) minutes per sample traverse point however the sample points were reduced to ten (10) per traverse for a sixty (60) minute sample period. Sample one was collected over the first half of the test assuming a fifteen percent (15%) moisture in the stack which accounts why the nozzle velocity was less than the desired minimum of 90%. Corrections were made for nonisokinetic nozzle velocities in the report. The first and second samples were collected assuming the nozzle diameter was 0.25 inches which upon checking after the second sample was found to be 0.265 inches. The assumed less than actual nozzle diameter accounts for the less than desirable nozzle velocity on Run #1 and why the Run #2 nozzle velocity was less than Run #3.

The particulate on this project consisted of the nozzle and probe catches (i.e. the "front-half" of the US Environmental Protection Agency (EPA) Method 5 sampling train). The probe was cleaned with reagent grade acetone and brushes and analyzed per the procedures in the Clean-up & Analysis section of this report. The condenser portion of Run #1 was inspected by Mr. MacClarence of ADEC to determine if hydrocarbon was present. No hydrocarbon was detected by sight or smell so the condenser portion of the sample was not analyzed for hydrocarbon.

The particulate emission samples collected on this project were reported on the basis of concentration corrected to 12% carbon dioxide less the contribution of carbon dioxide from the auxiliary fuel. The procedures in performing this emission sample project were specified by the Alaska Department of Environmental Conservation (ADEC).

Orsat grab samples were collected before, at the middle of the traverse and at the end of each sample. At least two samples with carbon dioxide concentrations agreeing within 0.5% were collected before the complete Orsat analysis was performed. The gas sample pump collected a gas sample from a tap at the outlet of the EPA Method 5 sample train, pumped the gas into the Orsat analyzer and then utilized the excess gas from the Orsat to collect a gas sample on each run. An inflatable bag was utilized to collect the gas not being used by the Orsat analyzer which constituted an integrated gas sample. The integrated bag gas sample was analyzed immediately after the sample and recorded on the field data sheet. The integrated bag sample was utilized to report the carbon dioxide, oxygen and carbon monoxide concentrations during the times of the samples. The gas sample line was checked frequently for

leaks by pinching the flexible hose connected to the Method 5 sample train outlet tap and the pump and was considered leak tight if the stack gas bubbling through the leveling bulb of the Orsat stopped after a short period of time (e.g. 30 seconds).

The quantity of auxiliary fuel burned during the day of sampling was 24,500 cubic feet or 17 cubic feet per minute. One cubic foot of natural gas produces one cubic foot of carbon dioxide in the combustion process. The percent carbon dioxide produced in the stack which consists of an average of 5012 dscfm from burning the auxiliary fuel is therefore 0.34% carbon dioxide which was subtracted from the measured carbon dioxide before making the correction to 12% carbon dioxide.

Dilution air (i.e from cooling of the incinerator shaft) was entering the stack at a position just after the incinerator exhaust fan and just below the roof. Oxygen readings were taken at the exhaust fan outlet (i.e. just below the dilution air inlet) and in the exhaust stack where the samples were collected. Knowing that the oxygen concentration of the dilution air is 21%, the total airflow is 5012 dscfm, the average oxygen at the incinerator exhaust fan outlet was 13.65%, the average oxygen concentration at the stack was 15.88% and balancing the oxygen and air with the two equations listed below, the quantity of dilution air was determined.

$$\text{EQ 1. Incin Air} + \text{Dil Air} = \text{Stack Air} = I + D = 5012 \text{ dscfm}$$

$$\text{EQ 2, Incin O}_2 + \text{Dil O}_2 = \text{Stack O}_2 = (0.1588)(5012) = 795.9$$

$$(I)(0.1365) + (D)(0.21) = 795.9 \text{ with } D = 5012 - I$$

$$\text{Therefore, } D = 1521 \text{ dscfm}$$

The effect of dilution air on the emissions is accounted for in the correction

to 12% carbon dioxide. Therefore the dilution air was not utilized to calculate an adjusted particulate emission concentration.

This report hereafter is arranged in the order in which the data can be most readily used. The report is arranged as follows:

- "EPA Method 5 Summary" (a summary of test results) if used on project.
- "Terminology & Equations" used in calculating the results
- "Procedure" illustrating how samples are typically collected
- "PMR Calculation" illustrates how calculations are performed for non-isokinetics
- "EPA Method 5 Particulate Sampling Train" schematic illustrates train parts
- "Clean-up and Analysis" procedures utilized on this project
- "EPA Method 5 Particulates" calculation sheet utilizes field traverse data sheet for input to the computer with one output sheet per Run
- "Particulate Calculation" utilizes laboratory data and calculates total particulate with one sheet per Run and sequentially placed with the above
- "EPA Method 5 Particulates" sheet
- "Orsat Data Calculation Sheet" used for determining dry molecular weight of the exhaust gas if the calculation is not performed by the "EPA Method 5 Particulates" output and sequentially placed with the above two computer output sheets
- Process Operating Log if used for project
- "Traverse Sampling Data Sheet" contains data collected from the field
- "Calibration Records" of the equipment utilized on this project. Spot calibrations are performed before and after the field work. If within 2%, no changes are made in the calibration records.

CLIENT: ANCHORAGE WATER &amp; WASTEWATER UTILITY PT WORONZOF TREATMENT PLANT

SAMPLING LOCATION: SEWAGE SLUDGE INCINERATOR STACK EMISSIONS - APRIL 1984

	RUN # 1 4/13/84	RUN # 2 4/13/84	RUN # 3 4/13/84
LAB NUMBER	27-4	28-4	29-4
24 HOUR START TIME	930	1335	1559
24 HOUR STOP TIME	1117	1437	1702
ELAPSED SAMPLING TIME, MIN	96.2	60	60
VOLUME SAMPLED, CU FT	81.636	56.192	64.894
VOLUME SAMPLED STANDARD, CU FT	78.9862	53.2465	61.9348
MOISTURE CONTENT OF STACK GAS, %	1.78421	1.75912	1.81087
MOLEC. WT OF STACK GAS, LB/LB MOLE	29.23	29.2223	29.2116
STACK PRESSURE, IN HG	29.6669	29.6869	29.7469
PITOT COEFFICIENT	.822	.822	.822
VELOCITY OF STACK GAS, FT/SEC	49.1617	48.2209	50.4552
STACK AREA, SQR FT	1.96895	1.96895	1.96895
STACK GAS FLOW RATE, ACTUAL CU FT/MIN, WET	5807.81	5696.67	5960.62
TEMPERATURE OF STACK, DEG F	142.313	132.9	138.4
STACK GAS FLOW RATE, STD CU FT/MIN, DRY	4958.11	4945.03	5134.26
DIAMETER OF NOZZLE, INCHES	.265	.265	.265
PERCENT ISOKINETIC OF TEST, %	85.1286	92.2543	103.353
WEIGHT PARTICULATE COLLECTED, MG	32.4	23.3	24.6
PARTICULATE CONCENTRATION, GRAINS/STD CU FT -03	6.31705E-03	6.73884E-03	6.11676E-03
PERCENT CO2 CONTENT OF STACK GAS	5.32	5.23	5.19
PART. CONC AT 12% CO2, GR/STD CU FT	.014249	.015462	.0141428
POLLUTANT MASS RATE (CONC. METHOD), LB/HR	.268449	.285618	.267172
POLLUTANT MASS RATE (AVERAGE RATE, METHOD), LB/HR	.228539	.263508	.27921
POLLUTANT MASS RATE (AVERAGE OF ABOVE), LB/HR	.243694	.274863	.273691
PARTICULATE CONCENTRATION (CORRECTED)	.0131891	.0148628	.0143795

# PARTICULATE CONCENTRATION AND PMR CALCULATION TERMINOLOGY $\dagger$

(Page 1)

VOLM, VOL <sub>m</sub> (V <sub>m</sub> )	= Dry gas meter volume @ meter temperature and pressure, dry-acf
PM, P <sub>m</sub> (P <sub>bar</sub> + $\frac{\Delta H}{13.6}$ )	= Dry gas meter pressure (recorded as inlet deflection across orifice meter) - "Hg
PBAR (P <sub>bar</sub> )	= Barometric Pressure @ sampling site (inches of Hg)
TM, T <sub>m</sub> (T <sub>m</sub> )	= Dry gas meter temperature (average of inlet and outlet) - $^{\circ}$ F (Use $^{\circ}$ R = 460 + $^{\circ}$ F in equations)
PSTD, P <sub>STD</sub> (P <sub>std</sub> )	= Standard atmospheric pressure, absolute - (29.92 "Hg)
TSTD, T <sub>STD</sub> (T <sub>std</sub> )	= Standard temperature, absolute - $^{\circ}$ R
VOLSTD, VOL <sub>STD</sub> (V <sub>m(std)</sub> )	= Standardized gas that passes through the sampling train - cubic feet, 70 $^{\circ}$ F, 1 atmosphere pressure, and dry
VOLW, VOL <sub>w</sub> (V <sub>w(std)</sub> )	Volume of water collected (expressed as vapor at standard temperature and pressure) - scf
VOLH <sub>2</sub> O (V <sub>lc</sub> )	= Volume of H <sub>2</sub> O collected (expressed in milliliters)
M, %M (100 B <sub>ws</sub> )	= %water, calculated from amount the train collected in impinger, bubblers, and on silica gel
MF (1-B <sub>ws</sub> )	= Mole fraction of dry gas
WD, W <sub>o</sub> (M <sub>d</sub> )	= Molecular weight of dry stack gas - 1b/1b mole
WW, W <sub>w</sub> (M <sub>s</sub> )	= Molecular weight of wet stack gas - 1b/1b mole
W <sub>a</sub> (*)	= Molecular weight of air (28.95 1b/1b mole)
CD, C <sub>D</sub> (*)	= Velocity correction coefficient for gas density at STP
PSN, P <sub>SN</sub> (P <sub>s</sub> )	= Stack pressure (static + barometric), absolute - "Hg
CS, C <sub>S</sub> (*)	= Velocity correction coefficient for stack pressure
VH, VH <sub>n</sub> ( $\Delta P$ )	= Individual pitot tube pressure differential readings - inches water
n (*)	= Number of velocity head readings
VO, V <sub>o</sub> (V <sub>s</sub> )	= Stack velocity @ stack conditions - fps
Q0, Q <sub>o</sub> (*)	= Stack flow rate at stack conditions - acfm
TS, T <sub>s</sub> (T <sub>s(ave)</sub> )	= Average stack temperature, absolute - $^{\circ}$ F (Use $^{\circ}$ R = 460 + $^{\circ}$ F in equations)
DELTA H ( $\Delta H$ )	= Deflection on orifice flow meter when sample air flows through meter box (inches of water)

## PARTICULATE CONCENTRATION AND PMR CALCULATION TERMINOLOGY

(Page 2)

$\gamma$ ( $\gamma$ )	= Dry gas meter calibration factor
$Q_s, Q_{os}$ ( $Q_{SD}$ )	= Stack flow rate at standard conditions - scfm (dry)
$T$ ( $\theta$ )	= Time over which sample was collected - minutes
$V_N, V_n$ ( $V_S$ (std))	= Velocity of gases inside nozzle during sampling, at STP - fps
$I$ (I)	= % Isokinetic ( $\pm$ 10% desirable)
$C_0, C_o$ ( $C_S$ )	= Particulate concentration - grains/scf
$N$ (% $CO_2$ )	= % $CO_2$ by volume in stack (12 indicates no % $CO_2$ correction is to be made)
$T_S, T_s$ ( $T_{Si}$ )	= Temperature of stack gas at each sampling point - $^{\circ}$ F (Use $^{\circ}R = 460 + ^{\circ}F$ in equations)
$C$ (*)	= Particulate concentration corrected to 12% $CO_2$
$PMRC, PMR_C$ (*)	= Pollutant mass rate - "concentration method" - lb/hr
$PMRR, PMR_r$ (*)	= Pollutant mass rate - "area ratio method" - lb/hr
$PMRAVG, \overline{PMR}$ (*)	= Average pollutant mass rate - lb/hr
$CPRIIME, C'$ (*)	= Particulate concentration corrected for non-isokinetic sampling condition - grains/scf
$P_T, P_T$ ( $M_n$ )	= Total particulate collected by sampling train - mg
$A_1, A_2, A_s$ (A)	= Area of stack - $FT^2$ $A_2 = 0$ if round stack
$A_n$ ( $A_n$ )	= Area of nozzle - $FT^2$
$DN$ (*)	= Diameter of nozzle in $IN^2$
$C_P, C_p$ ( $C_p$ )	= Velocity correction coefficient for type pitot tube used - dimensionless, normally 0.80 to 0.90 for "S" type pitot tube and 1.0 for "P" type pitot tube
$K_A, K_a$ (*)	= Average $\sqrt{VH \times T_s}$

†Notation in parenthesis to the right of the ASA nomenclature is the equivalent EPA 40 CFR 60 Method 5 notation

\* Notation used by ASA for calculations not required by 40 CFR 60 Method 5

PARTICULATE CONCENTRATION AND PMR CALCULATION EQUATIONS

$$\begin{aligned}
 1. \quad \text{VOL}_{\text{STD}} &= \frac{(Y)(\text{VOL}_m)(P_m)(T_{\text{STD}})}{(P_{\text{STD}})(T_m)} & 11. \quad V_n &= \frac{(\text{VOL}_{\text{STD}})(P_{\text{STD}})(T_S)}{(M_F)(T_{\text{STD}})(P_{\text{SN}})(T)(A_N)(60)} \\
 2. \quad \%M &= \frac{(100)(\text{VOL}_w)}{\text{VOL}_{\text{STD}} + \text{VOL}_w} & 12. \quad I &= (100) V_n/V_o \\
 3. \quad MF &= \frac{100 - M}{100} & *13. \quad C_o &= (0.0154) P_T / \text{VOL}_{\text{STD}} \\
 4. \quad W_w &= (W_d)(MF) + 18(1-MF) & 14. \quad C &= \frac{(C_o)(12)}{N} \\
 5. \quad C_D &= \sqrt{W_d/W_w} & *15. \quad \text{PMR}_c &= (C_o)(Q_s)(0.008571) \\
 6. \quad C_S &= \sqrt{P_{\text{STD}}/P_{\text{SN}}} & *16. \quad \text{PMR}_r &= \left( \frac{P_T}{T} \right) \left( \frac{A_s}{A_n} \right) (0.000132) \\
 7. \quad K_a &= \sum \sqrt{(VH_n \times T_{S_n})/n} & *17. \quad \overline{\text{PMR}} &= (\text{PMR}_c + \text{PMR}_r)/2 \\
 *8. \quad V_o &= 2.9 (K_a)(C_p)(C_D)(C_S) & *18. \quad C' &= (\overline{\text{PMR}})(1400)/Q_{os}N \\
 9. \quad Q_o &= (V_o)(A_S)(60) \\
 10. \quad Q_{os} &= \frac{(Q_o)(T_{\text{STD}})(P_{\text{SN}})(M_F)}{(T_S)(P_{\text{STD}})}
 \end{aligned}$$

\* UNITS FOR THE CONSTANTS USED ARE GIVEN BELOW:

$$\begin{aligned}
 8. \quad 2.9 \frac{(\text{ft})}{(\text{sec})} (\text{inches of H}_2\text{O} \times {}^{\circ}\text{R})^{-\frac{1}{2}} & \text{ based on Bernoulli's equation at STP and a} \\
 & \text{molecular weight of dry gas of 28.95 and} \\
 & \text{english units.} \\
 13. \quad .0154 \text{ grain/mg} &= \frac{(\text{mg})}{(\text{ft}^3)} \frac{(7000 \text{ grains})}{(1\text{b})} \frac{(1\text{b})}{(453.6\text{g})} \frac{(g)}{(1000\text{mg})} \\
 15. \quad .008571 \frac{\text{min-lbs}}{\text{hr-grains}} &= \frac{(\text{grains})}{(\text{ft}^3)} \frac{(\text{ft}^3)}{(\text{min})} \frac{(60 \text{ min})}{(\text{hr})} \frac{(1\text{bs})}{(7000 \text{ grains})} \\
 16. \quad .000132 \frac{(1\text{b-min})}{(\text{mg-hr})} &= \frac{(\text{mg})}{(\text{min})} \frac{(\text{ft}^2)}{(\text{ft}^2)} \frac{(g)}{(1000\text{mg})} \frac{(1\text{b})}{(453.6\text{g})} \frac{(60 \text{ min})}{(\text{hr})} \\
 18. \quad 1400 \frac{(\text{hr-grains})}{(\text{min-1b})} &= \frac{(1\text{b})}{(\text{hr})} \frac{(\text{min})}{(\text{ft}^3)} \frac{(12)}{(n)} \frac{(\text{hr})}{(60 \text{ min})} \frac{(7000 \text{ grains})}{(1\text{b})}
 \end{aligned}$$

## PROCEDURE

### EPA METHOD 5 PARTICULATE SAMPLING TRAIN

#### Sampling Train Preparation:

A tared and labeled glass fiber filter was placed in a glass filter holder. The filter (MSA1106BH) was desiccated and weighed to a constant weight to the nearest 0.5 mg. The condenser section consisted of four glass containers in series: one hundred milliliters of distilled-deionized water in a bubbler; one hundred milliliters in an impinger; a dry bubbler; and, a bubbler filled with approximately 500 grams of silica gel. All of the containers were weighed to the nearest 0.1 gram. The sampling train was assembled with connecting glassware so that sample gas would pass through the filter, the bubbler, impinger, the dry bubbler and the silica gel respectively.

A nozzle of a size that would allow for isokinetic sampling was selected and cleaned. A probe and liner of appropriate length to traverse the stack was chosen and the liner cleaned with acetone and a brush. The nozzle was connected with a cleaned union to the probe and liner. The probe was connected in front of the filter. A schematic of the sampling equipment is included in this report.

A leak test was performed on the assembled sampling train. The leak rate did not exceed 0.02 cfm at a vacuum of 10 inches Hg. The probe was heated and maintained at or above 250 degrees plus or minus 25 degrees F. The filter was heated and maintained at 250 degrees plus or minus 25 degrees F to avoid condensation of moisture on the filter. Crushed ice was placed around the condenser at the beginning of the test with new ice being added as required to keep the gases leaving the sampling train below 70 degrees F.

#### Sample Collection:

Sampling ports were selected and installed. The number of sampling points was determined based on the number of stack diameters from any flow disturbance to the port(s). The location of each sampling point was based on equal areas within the stack.

The time at each point was dependent on the stack velocity and the desired volume to be sampled.

The probe was inserted into the stack to the first traverse point with the nozzle tip pointing directly into the gas stream. The pump was started and immediately adjusted to sample at isokinetic velocities. Equal time was spent at each time interval. The EPA designed nomograph or equivalent was used to maintain isokinetic sampling throughout the sampling period. At the conclusion of the run the pump was turned off, and a final leak test was performed at the maximum vacuum incurred during sampling. If the post-test leak rate was found to be over 0.02 cfm the actual leak rate was recorded.





FIGURE 1.  
EPA METHOD 5 PARTICULATE SAMPLING TRAIN



Bellevue, WA

DOWN  
RSC  
CHECKED  
DATE  
9/30/74



## PMR CALCULATIONS

The weight of the dust per volume and weight of dust per time were calculated using two procedures:

### 1) The Concentration Method

The concentration of dust entering the sampling nozzle is calculated and then multiplied by the volumetric flow rate of the stack gases to obtain the pollutant mass rate on a concentration basis (PMR<sub>C</sub>).

Concentration in Nozzle x Volumetric Flow Rate =  
Pollutant Mass Rate On Concentration Basis

$$(P_T/VOL_{STD}) \times Q_s = PMR_C$$

Assuming the nozzle velocity is greater than the average stack gas velocity ( $V_n$  greater than  $V_o$ ), the calculated pollutant mass rate will be less than the true pollutant mass rate because the heavier dust particles will leave their velocity streamline and not enter the nozzle. If  $V_n$  is less than  $V_o$  then the calculated PMR<sub>C</sub> will be greater than the true PMR.

### 2) The Area Ratio Method

The weight of dust collected is divided by the sampling time and multiplied by the ratio of the stack area to the nozzle area to obtain the calculated pollutant mass rate based on the area ratio method (PMR<sub>r</sub>).

$$\frac{\text{Weight Collected}}{\text{Sample Time}} \times \frac{\text{Area of Stack}}{\text{Area of Nozzle}} = \text{Pollutant Mass Rate on Area Ratio Basis}$$

$$(P_T/T) \times A_s/A_n = PMR_r$$

Assuming the nozzle velocity is greater than the average stack gas velocity ( $V_n$  greater than  $V_o$ ), the calculated pollutant mass rate will be greater than the true pollutant mass rate because the lighter particles in the dust laden stream follow their streamlines and enter the sampling nozzle resulting in  $P_T/T$  being greater than true. If  $V_n$  is less than  $V_o$ , the calculated PMR<sub>r</sub> will be less than the true PMR.

To obtain a more true pollutant mass rate, the two calculated pollutant mass rates are averaged. This allows some of the bias introduced because of non-isokinetic sampling calculated by one method to offset the bias of the other method. The degree of bias is related to particle size and density.

ASA CONSULTANTS

E.P.A. METHOD 5 - PARTICULATES

JOB NAME: ANCHORAGE WATER & WASTEWATER UTILITY WORONZOF TREATMENT PLANT

PREPARED BY: W. D. SNOWDEN

DATE: 4/13/84

SUBJECT: SEWAGE SLUDGE INCINERATOR STACK EMISSIONS - RUN #1

\*\*\*\*\*

VOLM = 81.636 PBAR = 29.7 DELTA H = 2.27 TM = 84.2 LAB NUMBER = 27-4

PM = 29.8669 VOL(STD) = 78.9862 VOLH2O = 30.4 Y= .999

CO2 = 5.66 CO2 + O2 = 18.87 CO2 + O2 + CO = 18.87 O2 = 13.21 CO = 0

VOLW = 1.43488 WD = 29.434 PS = -.45 PSN = 29.6669 CP = .822

M = 1.78421 MF = .982158 WW = 29.23 CD = .995199 CS = 1.00426

A1 = 19 A2 = 0 AS = 1.96895 T = 96.2 DN = .265 PT = 32.4 N = 5.32

OBS	VH	TS	KA	OBS	VH	TS	KA
1	.45	141	16.4454	2	.45	141	16.4454
3	.54	143	18.0449	4	.6	145	19.0526
5	.6	146	19.0683	6	.64	146	19.6937
7	.69	142	20.3809	8	.72	149	20.9399
9	.72	142	20.8192	10	.81	133	21.9164
11	.85	125	22.2991	12	.88	120	22.592
13	.88	117	22.5335	14	.88	113	22.4553
15	.85	115	22.1077	16	.85	116	22.1269
17	.4	185	16.0624	18	.4	195	16.1864
19	.48	194	17.7178	20	.5	194	18.0831
21	.57	193	19.2927	22	.65	190	20.5548
23	.7	181	21.1825	24	.82	146	22.2917
25	.87	133	22.7136	26	.88	130	22.786
27	.92	124	23.1793	28	.92	118	23.0599
29	.92	115	23	30	.9	110	22.6495
31	.88	106	22.3177	32	.86	106	22.3177

\*\*\*\*\*

START TIME = 930 STOP TIME = 1117 FILE = 274

KA = 20.6349 TS = 142.313 VO = 49.1617 DO = 5807.81 DS = 4958.11

VN = 41.8506 T = 85.1286 CO = 5.31705E-03 C = .014249

PMRC = .268449 PMRR = .228539 PMRAVG = .248494 C' = .0131891

CLIENT: ANCHORAGE WATER &amp; WASTEWATER UTILITY WORONZOF TREATMENT PLANT

LOCATION: SEWAGE SLUDGE INCINERATOR STACK EMISSIONS

SAMPLE DATE: 4/13/84

ANALYSIS DATE: 4/16-24/84

RUN # 1

LAB # 27-4

\*\*\*\*\*

I. EVAPORATION OF 75 ml OF ACETONE RINSE AND (B)  
BRUSHING OF NOZZLE, PROBE AND GLASSWARE BEFORE FILTER.FINAL 79723.7 mg - TARE 79721.5 mg  
- BLANK (( 5E-03 mg/ml ) ( 75 ml ) = .375 mg) = 1.825 mg

II. FILTER CATCH - FILTER MSA1106BH - NUMBER 9-4 (A)

FINAL 424.5 mg - TARE 393.9 mg = 30.6 mg

VII. TOTAL PARTICULATE = SUM OF ABOVE = 32.425 mg

BLANKS

ACETONE (FINAL 80883.9 mg - TARE 80883.4 mg = .5 mg)  
/ 100 ml = 5E-03 mg/ml

CLIENT: ANCHORAGE WATER &amp; WASTEWATER UTILITY TREATMENT PLANT

LOCATION: SEWAGE SLUDGE INCINERATOR STACK EMISSIONS

SAMPLE DATE: 4/13/84

ANALYSIS DATE: 4/16-24/84

RUN # 2

LAB # 28-4

\*\*\*\*\*

I. EVAPORATION OF 95 ml OF ACETONE RINSE AND (B)  
BRUSHING OF NOZZLE, PROBE AND GLASSWARE BEFORE FILTER.

FINAL 77867.4 mg - TARE 77861.3 mg  
- BLANK (( 5E-03 mg/ml) ( 95 ml) = .475 mg) = 5.625 mg

II. FILTER CATCH - FILTER MSA1106BH - NUMBER 7-4 (A)

FINAL 406.1 mg - TARE 388.4 mg = 17.7 mg

VII. TOTAL PARTICULATE = SUM OF ABOVE = 23.325 mg

-----

BLANKS

-----

ACETONE (FINAL 80883.9 mg - TARE 80883.4 mg = .5 mg)  
/ 100 ml = 5E-03 mg/ml

ASA CONSULTANTS

E.P.A. METHOD 5 - PARTICULATES

JOB NAME: ANCHORAGE WATER & WASTEWATER UTILITY WORONZOF TREATMENT PLANT

PREPARED BY: W. D. SNOWDEN

DATE: 4/13/84

SUBJECT: SEWAGE SLUDGE INCINERATOR STACK EMISSIONS - RUN #2

\*\*\*\*\*

VOLM = 56.192 PBAR = 29.72 DELTA H = 2.61 TM = 96.5 LAB NUMBER = 28-4

PM = 29.9119 VOL(STD) = 53.2465 VOLH2O = 20.2 Y = .999

CO2 = 5.57 CO2 + O2 = 18.87 CO2 + O2 + CO = 18.9 O2 = 13.3 CO = .0300007

VOLW = .95344 WD = 29.4232 PS = .45 PSN = 29.6869 CP = .822

M = 1.75912 MF = .982409 WW = 29.2223 CO = .995331 CS = 1.00392

A1 = 19 A2 = 0 AS = 1.96895 T = 60 DN = .265 PT = 23.3 N = 5.23

OBS	VH	TS	KA	OBS	VH	TS	KA
1	.45	184	17.0235	2	.45	178	16.944
3	.47	174	17.2621	4	.54	160	18.2975
5	.64	132	19.4648	6	.83	122	21.9786
7	.9	118	22.8079	8	.91	116	22.8945
9	.91	110	22.775	10	.9	110	22.6495
11	.52	137	17.6193	12	.57	138	18.4624
13	.58	139	18.6392	14	.67	139	20.0332
15	.73	132	20.7885	16	.77	120	21.1329
17	.81	120	21.6749	18	.85	113	22.0692
19	.79	108	21.183	20	.79	108	21.183

\*\*\*\*\*

START TIME = 1335 STOP TIME = 1437 FILE = 284

KA = 20.2442 TS = 132.9 VO = 48.2209 QO = 5696.67 OS = 4945.03

VN = 44.4859 I = 92.2543 CO = 6.73884E-03 C = .015462

PMRC = .285618 PMRR = .263508 PMRAVG = .274563 C' = .0148628

ASA CONSULTANTS

E.P.A. METHOD 5 - PARTICULATES

JOB NAME: ANCHORAGE WATER & WASTEWATER UTILITY WORONZOF TREATMENT PLANT

PREPARED BY: W. D. SNOWDEN

DATE: 4/13/84

SUBJECT: SEWAGE SLUDGE INCINERATOR STACK EMISSIONS - RUN #3

\*\*\*\*\*

VOLM = 64.894 PBAR = 29.78 DELTA H = 3.69 TM = 95.1 LAB NUMBER = 29-4

PM = 30.0513 VOL(STD) = 61.9348 VOLH2O = 24.2 Y= .999

CO2 = 5.53 CO2 + O2 = 18.87 CO2 + O2 + CO = 18.87 O2 = 13.34 CO = 0

VOLW = 1.14224 WD = 29.4184 PS = -.45 PSN = 29.7469 CP = .822

M = 1.81087 MF = .981891 WW = 29.2116 CD = .995512 CS = 1.00291

A1 = 17 A2 = 0 A3 = 1.96895 T = 60 DN = .265 PT = 24.6 N = 5.19

OBS	VH	TS	KA	OBS	VH	TS	KA
1	.49	145	17.2177	2	.55	145	18.2414
3	.63	146	19.5392	4	.69	155	20.5998
5	.69	150	20.5159	6	.81	139	22.027
7	.87	130	22.6561	8	.91	118	22.9343
9	.91	113	22.8348	10	.87	108	22.2297
11	.44	190	16.9115	12	.48	198	17.7719
13	.62	186	20.013	14	.7	179	21.1495
15	.91	132	23.2103	16	.96	118	23.5559
17	.96	108	23.3512	18	.96	104	23.2689
19	.96	102	23.2276	20	.92	102	22.7385

\*\*\*\*\*

START TIME = 1559 STOP TIME = 1702 FILE = 294

KA = 21.1997 TS = 138.4 VO = 50.4552 OO = 5960.62 QS = 5134.26

VN = 52.1468 I = 103.353 CO = 6.11676E-03 C = .0141428

PMRC = .269172 PMRR = .27821 PMRAVG = .273691 C' = .0143795

CLIENT: ANCHORAGE WATER &amp; WASTEWATER UTILITY TREATMENT PLANT

LOCATION: SEWAGE SLUDGE INCINERATOR STACK EMISSIONS

SAMPLE DATE: 4/13/84

ANALYSIS DATE: 4/16-24/84

RUN # 3

LAB # 29-4

\*\*\*\*\*

I. EVAPORATION OF 130 ml OF ACETONE RINSE AND (B)  
BRUSHING OF NOZZLE, PROBE AND GLASSWARE BEFORE FILTER.

FINAL 80699.75 mg - TARE 80699.1000000001 mg  
- BLANK (( 5E-03 mg/ml) ( 130 ml) = .65 mg) = 2.38397E-08 mg

II. FILTER CATCH - FILTER MSA1106BH - NUMBER 11-4 (A)

FINAL 419.4 mg - TARE 394.8 mg = 24.6 mg

VII. TOTAL PARTICULATE = SUM OF ABOVE = 24.6 mg

-----

BLANKS

ACETONE (FINAL 80883.9 mg - TARE 80883.4 mg = .5 mg)  
/ 100 ml = 5E-03 mg/ml

A P P E N D I X



100% Acid Wastewater Incinerator Stack

ASA CONSULTANTS

TRAVERSE SAMPLING DATA SHEET

PORT LOCATION Sludge Incinerator Stack  
RUN NO. 1

OPERATOR/S SNOWDEN

SAMPLE BOX NO. BLACK METER BOX  $\Delta H = 1.82$

FILTER NO. 9-4 TARE NO.

FINAL WT. gm INITIAL WT. gm NET WT. gm  
428.5 931.7 = -3.2

425.1 425.1 = 0.0

352.5 349.2 = 3.3

720.7 700.4 = 20.3

TOTAL WATER VOLUME (1 mil = 1 ml) 30.4

DISTANCE UPSTREAM & DOWNSTREAM FROM OBSTRUCTION  
BEFR. DIC = 13' 7" 32' 0" 3' 4" 3' 4"  
AFTER DIC = 16' 0" 32' 0" 3' 4" 3' 4"  
BEFR. DIC = 14' 75" 3' 0" 3' 0" 3' 0"  
AFTER DIC = 12.5

INSTANTANEOUS READINGS: RECORDED @ BEGINNING OF TIME INTERVAL

CLOCK TIME (24 HRS.)	FLUE TIME (min.)	DRY GAS METER (CUBIC FEET)		BOX TEMP. (°F)	IMPINGER TEMP. (°F)	POINT OUTLET ("H <sub>2</sub> O)	PITOT VH ("H <sub>2</sub> O)	ORIFICE DESIRED ("H <sub>2</sub> O)	ACTUAL ("H <sub>2</sub> O)	PUMP VACUUM ("Hg GA)	STACK TEMP. (°F)	OPACITY OR %CO <sub>2</sub>
		INLET	OUTLET									
9:30	0	55	54	244	44	11	11	1/5	1/5	1.5	141	50, 18.8
	15	55	54	245	43	11	11	1/5	1/5	1.5	141	50, 18.8
	30	55	54	246	42	11	11	1/5	1/5	1.5	141	50, 18.8
	45	55	54	247	41	11	11	1/5	1/5	1.5	141	50, 18.8
	60	55	54	248	40	11	11	1/5	1/5	1.5	141	50, 18.8
	75	55	54	249	39	11	11	1/5	1/5	1.5	141	50, 18.8
	90	55	54	250	38	11	11	1/5	1/5	1.5	141	50, 18.8
	105	55	54	251	37	11	11	1/5	1/5	1.5	141	50, 18.8
	120	55	54	252	36	11	11	1/5	1/5	1.5	141	50, 18.8
	135	55	54	253	35	11	11	1/5	1/5	1.5	141	50, 18.8
	150	55	54	254	34	11	11	1/5	1/5	1.5	141	50, 18.8
	165	55	54	255	33	11	11	1/5	1/5	1.5	141	50, 18.8
	180	55	54	256	32	11	11	1/5	1/5	1.5	141	50, 18.8
	195	55	54	257	31	11	11	1/5	1/5	1.5	141	50, 18.8
	210	55	54	258	30	11	11	1/5	1/5	1.5	141	50, 18.8
	225	55	54	259	29	11	11	1/5	1/5	1.5	141	50, 18.8
	240	55	54	260	28	11	11	1/5	1/5	1.5	141	50, 18.8
	255	55	54	261	27	11	11	1/5	1/5	1.5	141	50, 18.8
	270	55	54	262	26	11	11	1/5	1/5	1.5	141	50, 18.8
	285	55	54	263	25	11	11	1/5	1/5	1.5	141	50, 18.8
	300	55	54	264	24	11	11	1/5	1/5	1.5	141	50, 18.8
	315	55	54	265	23	11	11	1/5	1/5	1.5	141	50, 18.8
	330	55	54	266	22	11	11	1/5	1/5	1.5	141	50, 18.8
	345	55	54	267	21	11	11	1/5	1/5	1.5	141	50, 18.8
	360	55	54	268	20	11	11	1/5	1/5	1.5	141	50, 18.8
	375	55	54	269	19	11	11	1/5	1/5	1.5	141	50, 18.8
	390	55	54	270	18	11	11	1/5	1/5	1.5	141	50, 18.8
	405	55	54	271	17	11	11	1/5	1/5	1.5	141	50, 18.8
	420	55	54	272	16	11	11	1/5	1/5	1.5	141	50, 18.8
	435	55	54	273	15	11	11	1/5	1/5	1.5	141	50, 18.8
	450	55	54	274	14	11	11	1/5	1/5	1.5	141	50, 18.8
	465	55	54	275	13	11	11	1/5	1/5	1.5	141	50, 18.8
	480	55	54	276	12	11	11	1/5	1/5	1.5	141	50, 18.8
	495	55	54	277	11	11	11	1/5	1/5	1.5	141	50, 18.8
	510	55	54	278	10	11	11	1/5	1/5	1.5	141	50, 18.8
	525	55	54	279	9	11	11	1/5	1/5	1.5	141	50, 18.8
	540	55	54	280	8	11	11	1/5	1/5	1.5	141	50, 18.8
	555	55	54	281	7	11	11	1/5	1/5	1.5	141	50, 18.8
	570	55	54	282	6	11	11	1/5	1/5	1.5	141	50, 18.8
	585	55	54	283	5	11	11	1/5	1/5	1.5	141	50, 18.8
	600	55	54	284	4	11	11	1/5	1/5	1.5	141	50, 18.8
	615	55	54	285	3	11	11	1/5	1/5	1.5	141	50, 18.8
	630	55	54	286	2	11	11	1/5	1/5	1.5	141	50, 18.8
	645	55	54	287	1	11	11	1/5	1/5	1.5	141	50, 18.8
	660	55	54	288	0	11	11	1/5	1/5	1.5	141	50, 18.8
	675	55	54	289	-1	11	11	1/5	1/5	1.5	141	50, 18.8
	690	55	54	290	-2	11	11	1/5	1/5	1.5	141	50, 18.8
	705	55	54	291	-3	11	11	1/5	1/5	1.5	141	50, 18.8
	720	55	54	292	-4	11	11	1/5	1/5	1.5	141	50, 18.8
	735	55	54	293	-5	11	11	1/5	1/5	1.5	141	50, 18.8
	750	55	54	294	-6	11	11	1/5	1/5	1.5	141	50, 18.8
	765	55	54	295	-7	11	11	1/5	1/5	1.5	141	50, 18.8
	780	55	54	296	-8	11	11	1/5	1/5	1.5	141	50, 18.8
	795	55	54	297	-9	11	11	1/5	1/5	1.5	141	50, 18.8
	810	55	54	298	-10	11	11	1/5	1/5	1.5	141	50, 18.8
	825	55	54	299	-11	11	11	1/5	1/5	1.5	141	50, 18.8
	840	55	54	300	-12	11	11	1/5	1/5	1.5	141	50, 18.8
	855	55	54	301	-13	11	11	1/5	1/5	1.5	141	50, 18.8
	870	55	54	302	-14	11	11	1/5	1/5	1.5	141	50, 18.8
	885	55	54	303	-15	11	11	1/5	1/5	1.5	141	50, 18.8
	900	55	54	304	-16	11	11	1/5	1/5	1.5	141	50, 18.8
	915	55	54	305	-17	11	11	1/5	1/5	1.5	141	50, 18.8
	930	55	54	306	-18	11	11	1/5	1/5	1.5	141	50, 18.8
	945	55	54	307	-19	11	11	1/5	1/5	1.5	141	50, 18.8
	960	55	54	308	-20	11	11	1/5	1/5	1.5	141	50, 18.8
	975	55	54	309	-21	11	11	1/5	1/5	1.5	141	50, 18.8
	990	55	54	310	-22	11	11	1/5	1/5	1.5	141	50, 18.8
	1005	55	54	311	-23	11	11	1/5	1/5	1.5	141	50, 18.8
	1020	55	54	312	-24	11	11	1/5	1/5	1.5	141	50, 18.8
	1035	55	54	313	-25	11	11	1/5	1/5	1.5	141	50, 18.8
	1050	55	54	314	-26	11	11	1/5	1/5	1.5	141	50, 18.8
	1065	55	54	315	-27	11	11	1/5	1/5	1.5	141	50, 18.8
	1080	55	54	316	-28	11	11	1/5	1/5	1.5	141	50, 18.8
	1095	55	54	317	-29	11	11	1/5	1/5	1.5	141	50, 18.8
	1110	55	54	318	-30	11	11	1/5	1/5	1.5	141	50, 18.8
	1125	55	54	319	-31	11	11	1/5	1/5	1.5	141	50, 18.8
	1140	55	54	320	-32	11	11	1/5	1/5	1.5	141	50, 18.8
	1155	55	54	321	-33	11	11	1/5	1/5	1.5	141	50, 18.8
	1170	55	54	322	-34	11	11	1/5	1/5	1.5	141	50, 18.8
	1185	55	54	323	-35	11	11	1/5	1/5	1.5	141	50, 18.8
	1200	55	54	324	-36	11	11	1/5	1/5	1.5	141	50, 18.8
	1215	55	54	325	-37	11	11	1/5	1/5	1.5	141	50, 18.8
	1230	55	54	326	-38	11	11	1/5	1/5	1.5	141	50, 18.8
	1245	55	54	327	-39	11	11	1/5	1/5	1.5	141	50, 18.8
	1260	55	54	328	-40	11	11	1/5	1/5	1.5	141	50, 18.8
	1275	55	54	329	-41	11	11	1/5	1/5	1.5	141	50, 18.8
	1290	55	54	330	-42	11	11	1/5	1/5	1.5	141	50, 18.8
	1305	55	54	331	-43	11	11	1/5	1/5	1.5	141	50, 18.8
	1320	55	54	332	-44	11	11	1/5	1/5	1.5	141	50, 18.8
	1335	55	54	333	-45	11	11	1/5	1/5	1.5	141	50, 18.8
	1350	55	54	334	-46	11	11	1/5	1/5	1.5	141	50, 18.8
	1365	55	54	335	-47	11	11	1/5	1/5	1.5	141	50, 18.8
	1380	55	54	336	-48	11	11	1/5	1/5	1.5	141	





SOURCE NAME  
Pt. Wauzuf STP Incinerator

ADDRESS  
2300 Hutton Dr

SOURCE ID NUMBER  
8321-4A007

OBSERVATION DATE  
4/13/84

STATE  
AK ZIP 99503 PHONE 243-2151

OBSERVER'S NAME (PRINT)  
Bill MacClarence

ORGANIZATION  
AK Dept. of Env. Conserv



CERTIFIED BY  
Anch. Air Pollution Control Agency

DATE  
10/27/83



PROCESS	OPERATING MODE	START TIME	1043	STOP TIME	1102
Sludge Incinerator		0	15	30	45
CONTROL EQUIPMENT	OPERATING MODE	1	5	0	5
wet scrubber		2	5	5	10
ESCRIBE EMISSION POINT	stack exit after dilution air	3	5	5	5
MISSION POINT HEIGHT ABOVE GROUND LEVEL	EMISSION POINT HEIGHT RELATIVE TO OBSERVER	4	5	0	5
35'	40	5	5	5	5
DISTANCE TO MISSION POINT	DIRECTION TO EMISSION POINT	6	5	10	5
150'	NNE	7	5	0	5
ESCRIBE EMISSIONS	straight well defined plume	8	10	0	5
COLOR OF EMISSIONS	CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/>	9	0	5	0
black to yellow	INTERMITTENT <input type="checkbox"/>	10	0	0	5
WATER/VAPOR PRESENT	IF YES, IS PLUME ATTACHED <input type="checkbox"/> N/A <input checked="" type="checkbox"/> DETACHED <input type="checkbox"/>	11	0	0	0
NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>		12	0	5	10
AT WHAT POINT WAS OPACITY DETERMINED	stack exit	13	0	0	0
		14	5	0	0
		15	5	10	0
		16	0	0	10
		17	5	5	0
		18	5	5	5
		19	5	0	5
		20	0	0	5
		21			
		22			
		23			
		24			
		25			
		26			
		27			
		28			
		29			
		30			
COMMENTS	during run No. 8	AVERAGE OPACITY	3.0%	NUMBER OF READINGS ABOVE 20 % WERE none	
Source test transmissometer reading 80%		RANGE OF OPACITY			
	READINGS	FROM	0	TO 15	
				DRAW NORTH ARROW	

SOURCE LAYOUT SKETCH



OBSERVER'S SIGNATURE

DATE  
4/13/84



I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS.

SIGNATURE

TITLE

DATE // /

VERIFIED BY

SOURCE NAME Pt. Wrenz F STP Incinerator	SOURCE ID NUMBER 0321-AA007	OBSERVATION DATE 4/13/84	
ADDRESS 3200 Hwy Dr.	OBSERVER'S NAME (PRINT) B.I. MacClarence	ORGANIZATION AK Dept. of Env. Conserv.	
STATE AL	ZIP 94503	PHONE 243-2151	CERTIFIED BY Arch. Air Pollution Control Agency
			DATE 10/27/84
PROCESS Sludge Incinerator	OPERATING MODE	START TIME 1608	STOP TIME 1627
CONTROL EQUIPMENT wet scrubber	OPERATING MODE	0 15 30 45	0 15 30 45
DESCRIBE EMISSION POINT stack exit after dilution air	EMISSION POINT HEIGHT ABOVE GROUND LEVEL 35'	EMISSION POINT HEIGHT RELATIVE TO OBSERVER 45'	1 5 5 5 5 2 10 5 0 5 3 5 5 5 5 4 0 5 0 5 5 5 5 0 10 6 5 5 0 0 7 0 5 5 0 8 5 5 0 0 9 0 0 0 5 10 5 10 0 5 11 0 5 0 5 12 5 5 0 0 13 0 0 0 0 14 0 0 0 5 15 0 0 0 0 16 5 0 0 10 17 5 0 0 0 18 0 0 5 5 19 0 0 5 5 20 5 0 0 0 21 22 23 24 25 26 27 28 29 30
DISTANCE TO EMISSION POINT 180'	DIRECTION TO EMISSION POINT NE		
DESCRIBE EMISSIONS straight well defined plume	COLOR OF EMISSIONS brown/yellow	CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	
WATER/VAPOR PRESENT NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>	IF YES, IS PLUME ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/> N/A		
AT WHAT POINT WAS OPACITY DETERMINED stack exit			
DESCRIBE BACKGROUND overcast sky	COLOR OF BACKGROUND white	SKY CONDITIONS overcast	
WIND SPEED 0-5	WIND DIRECTION E		
AMBIENT TEMPERATURE 50	RELATIVE HUMIDITY		
COMMENTS during run No. 3 source test transmissometer reading 8%	AVERAGE OPACITY 2.1%	NUMBER OF READINGS ABOVE 20 % WERE none	
SOURCE LAYOUT SKETCH	RANGE OF OPACITY READINGS FROM 0 TO 10	DRAW NORTH ARROW	
			
OBSERVER'S SIGNATURE 	DATE 4/13/84	I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS. SIGNATURE TITLE	
VERIFIED BY		DATE //	

PITOT TUBE IDENTIFICATION NUMBER: #28 DATE: 4/18/84  
 CALIBRATED BY: W. L. SWOARDEN

"A" SIDE CALIBRATION (#1)				
RUN NO.	$\Delta P_{std}$ cm H <sub>2</sub> O (in. H <sub>2</sub> O)	$\Delta P(s)$ cm H <sub>2</sub> O (in. H <sub>2</sub> O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1	0.98	1.4	0.828	0.006
2	0.52	0.74	0.830	0.008
3	0.04	0.06	0.808	0.01
	$\bar{C}_p$ (SIDE A)		0.822	

"B" SIDE CALIBRATION (#2)				
RUN NO.	$\Delta P_{std}$ cm H <sub>2</sub> O (in. H <sub>2</sub> O)	$\Delta P(s)$ cm H <sub>2</sub> O (in. H <sub>2</sub> O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1	0.98	1.40	0.828	0.006
2	0.52	0.74	0.830	0.008
3	0.04	0.06	0.808	0.01
	$\bar{C}_p$ (SIDE B)		0.822	

$$\text{AVERAGE DEVIATION} = \sigma_{(A \text{ OR } B)} = \frac{1}{3} \sum_{s=1}^3 |C_p(s) - \bar{C}_p(A \text{ OR } B)| \quad \leftarrow \text{MUST BE} \leq 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \quad \leftarrow \text{MUST BE} \leq 0.01$$

Figure 2-9. Pitot tube calibration data.

# DRY GAS METER AND ORIFICE CALIBRATION LOG

Meter Box No. 41

Dry Gas Meter Identification Meter Box #1

Date 4/17/84

Barometric Pressure, Pb 29.8 In. HG

Technician W. D. Snowden

Orifice Manometer Setting, $\Delta H$ , in $H_2O$	Gas Volume Wet Test Meter $V_w$ , $ft^3$	Gas Volume Dry Gas Meter $V_d$ , $ft^3$	Temperature				Time $\theta$ min.	$\gamma$	$\Delta H\theta$			
			Wet Test		Dry Gas Meter							
			Meter $t_w$ $^{\circ}F$	Inlet $t_{di}$ $^{\circ}F$	Outlet $t_{do}$ $^{\circ}F$	Average $t_d$ $^{\circ}F$						
0.5	5	5.14	64.5	87.5	76.5	82	13.6	1.004	2.011			
1.0	5	5.212	64	96.5	84	90.25	9.3	0.993	1.852			
2.0	10	10.628	63.5	108	89.5	97.5	12.8	0.997	1.733			
4.0	10	10.738	63.5	119	95.5	107.25	9.1	0.999	1.733			
6.0	10	10.757	63.5	125.5	99.5	112.5	7.5	1.002	1.753			
	10											
<b>Average</b>								<b>0.999</b>	<b>1.816</b>			

## Calculations

$\Delta H$	$\frac{\Delta H}{13.6}$	$\gamma$	$\Delta H\theta$	
			$\frac{V_w Pb (t_d + 460)}{V_d (Pb + \Delta H/13.6) (t_w + 460)}$	$\frac{0.0317 \Delta H}{Pb (t_d + 460)} \frac{(t_w + 460) \theta}{V_w}^2$
		$( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	
		$( \quad ) ( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	
		$( \quad ) ( \quad ) ( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	
		$( \quad ) ( \quad ) ( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	
		$( \quad ) ( \quad ) ( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	
		$( \quad ) ( \quad ) ( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	
		$( \quad ) ( \quad ) ( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	
		$( \quad ) ( \quad ) ( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	
		$( \quad ) ( \quad ) ( \quad ) ( \quad ) ( \quad ) =$	$0.0317 ( \quad ) [ \quad ]^2 =$	

$\gamma$  = Ratio of accuracy of wet test meter to dry test meter. Tolerance =  $\pm 0.01$

$\Delta H$  = Orifice pressure differential that gives 0.75 cfm of air at 70°F and 29.92 inches of mercury in  $H_2O$ . Tolerance =  $\pm 0.15$


Hearth	Temp (°F)	No. of Gas Burners
1	1000 (538°C)	2
2	1250	2
3	1250 (677°C)	
4	1400 (760°C)	2
5	900-1400	2
6	500 max	-

rec'd @ plant

4/13/83

sent to TRW

& EPA



BSP-Envirotech  
Furnace No. 71343  
Job No. 5737  
Contract #12, phase 2  
Lurgi (Parent Co.)  
Belmont, Calif.

FIGURE 11-6

CROSS SECTION OF A MULTIPLE-HEARTH FURNACE

14 Ft 3 1/2 in

WESLEY D. SNOWDEN, P.E.

FEBRUARY 1984

Mr. Snowden is the founder and principal of ASA CONSULTANTS. Prior to forming ASA, Mr. Snowden was Manager of the Environmental Services Department of Valentine, Fisher and Tomlinson for seven years and was a Sanitary Engineer with the U.S. Environmental Protection Agency (EPA) for three years. Mr. Snowden directs and performs air quality modeling, monitoring and source evaluation, training, energy optimization, economic feasibility, professional services management, and control system design services of ASA CONSULTANTS. Projects performed for industrial clients include reduction of atmospheric emissions, industrial waste water discharges, solid wastes, occupational workroom pollutants, and noise levels.

Mr. Snowden is a certified Diplomat in the American Academy of Environmental Engineers and a member in the Air Pollution Control Association, American Society of Civil Engineers, Source Evaluation Society, American Management Association, the National Society of Professional Engineers and American Institute of Professional Consultants. Mr. Snowden was a founder and served as the first president (1974) of the Source Evaluation Society (SES). The SES is an international association of professionals who perform air quality and source evaluations and strive to enhance the state-of-the-art. Mr. Snowden served in the past as Editor of "Stack Sampling News", a nation-wide monthly publication, and is listed in "Who's Who in Engineering" and "Who's Who in the West".

Mr. Snowden holds a Masters Degree in Business Administration from Seattle University and a Bachelor of Science Degree in Civil Engineering from the University of Washington. Mr. Snowden has presented training courses and authored numerous technical articles on air quality studies, atmospheric emissions from combustion sources, energy optimization of combustion sources, sampling data reporting and calculations and management of professional-technical service organizations. Mr. Snowden is a certified opacity reader from the State of Washington.

Mr. Snowden has served as an expert witness on legal suits wherein disputes have arisen between the purchaser and manufacturer of air pollution control equipment. Testimony provided by Mr. Snowden included evaluation of testing results, equipment specifications and installation performance. Mr. Snowden authored a chapter titled "Parameters to Evaluate for Specifying Air Pollution Control Equipment" in a book by Young and Cross published in 1982 by Marcel Dekker, Inc. of New York, N.Y. Mr. Snowden is publishing a book on "Tuning Small Boilers for Energy Optimization"