

STAPPA/ALAPCC 730024

REPORT NO. Y-8155

PAGE

2.5

#36

71

12/17/86

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

INCINERATOR COMPLIANCE TEST

at

ENFIELD

SEWAGE TREATMENT PLANT

in

ENFIELD, CONNECTICUT

for

THE RSP DIVISION
ENVIROTECH SYSTEMS, INC.

Prepared By

YORK RESEARCH CORPORATION
ONE RESEARCH DRIVE
STAMFORD, CONNECTICUT 06906

REPORT NO. Y-8155

July 14, 1973

TABLE OF CONTENTS

	<u>PAGE</u>
I. ABSTRACT	1
II. SUMMARY OF RESULTS	2
III. GENERAL TEST METHODS	4
IV. ANALYTICAL METHODS	6
V. FIGURES	10
VI. APPENDIX	18

Testing Acceptance Letter
Description of Operations
Operating Logs
Calculations
Calibration

I. ABSTRACT

On May 29th and June 1st, 1973, York Research, an independent consulting firm in the environmental field, began a series of emission sampling tests at the Enfield Sewage Treatment Plant in Enfield, Connecticut.

The purpose of these tests was to determine compliance with Connecticut State Regulations for particulate emissions from an incinerator. NO_x , SO_x , hydrocarbon and CO were also tested per a State request.

The Connecticut State Regulations as specified in "Administrative Regulations", Department of Environmental Protection, Abatement of Air Pollution, May 23, 1972, Page 14B, Section 19-508-18 "Control of Particulate Emissions" subsection (C) (3) (i) "Emission Standards. Particulates" states:

No person shall construct, install, use or cause to be used any new (constructed or modified after June 1, 1972) incinerator which will result in particulate matter in the effluent in excess of 0.08 gr/SCF (0.18 gm/NM³) corrected to 12% CO₂, maximum 2 hour average. No person shall use or cause to be used any existing incinerator which will emit more than 0.4 lb. particulate/1000 lbs. of flue gases adjusted to 50% excess air.

The following Table gives the results of the scrubber outlet sampling in terms as used in the Connecticut State Regulations.

Particulate Test	gr/SCF (12% CO ₂)	lbs./1000 lbs. (Flue Gas @ 50% Excess Air)
1	.0140	.033
2	.0085	.014
3	.0103	.017
Average	.0109	.027
State Limitations	.08 gr/SCF (12% CO ₂)	.4 lbs./1000 lbs. (Flue Gas @ 50% Excess Air)

II. SUMMARY OF RESULTSOUTLET PARTICULATE

<u>Test</u>	<u>1</u>	<u>2</u>	<u>3</u>
<u>Date</u>	5-29-73	5-29-73	6-1-73
<u>Time</u>	1529-1724	1803-1957	1324-1516
Gas Velocity, FPM	1160	1080	1050
Gas Flow, SCFM	4480	4170	4170
Isokinetic Sampling Rate, %	103.3	102.3	100.2
Particulate Concentration, gr/SCF	.0165 ✓	.0071	.0079
gr/SCF (12% CO ₂)	.0140	.0085	.0103
Particulate Emission Rate, lb/hr.	.6334	.2537	.2823
lbs/1000 lbs. (50% E.A.)	.033	.014	.017 ✓

	<u>SO_x</u>	
<u>Test</u>	<u>1</u>	<u>2</u>
<u>Date</u>	6-1-73	6-1-73
<u>Time</u>	1527-1547	1618-1638
SO ₂ (ppm)	23.9	15.8
SO ₃ (ppm)	3.69	1.97

NOTE: Only two tests were sampled due to the diminishing sludge supply.

NOx

<u>Test</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>	<u>11</u>	<u>12</u>
<u>Date</u>	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73
<u>Time</u>	1420	1425	1427	1431	1433	1435	1437	1441	1444	1453	1455	1457
NO2 (ppm)	41.6	48.3	45.1	61.2	61.7	99.8	106.9	77.2	56.8	55.7	91.8	69.3

67.95

HYDROCARBON

<u>Test</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>
<u>Date</u>	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73
ppm*	4.80	3.36	2.81	8.42	4.86	10.82	2.40	5.07

5.32

*Based on C₆ H₁₄

III. GENERAL TEST METHODS

Particulate Sampling Train - EPA Method 5

The sampling apparatus consisted of a three (3) foot probe, cyclone bypass, filter, four impingers, dry gas meter, vacuum pump and flow meter (See Figure 1). The stainless steel, button-hook type probe tip (1) was connected by a stainless steel coupling (2) with asbestos packing to the probe. The probe (3) consisted of 5/8 inch outside diameter medium wall Pyrex glass tube with a ground balljoint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 250°F in the probe. The wire wound tube was wrapped with fiberglass tape and enclosed in a 1-inch-OD stainless steel casing for protection. The end of the steel probe casing does not have the balljoint protruding but has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a cyclone bypass (4). The cyclone bypass connects to a very coarse fritted glass filter holder (5), which holds a tared glass fiber filter. The cyclone, flask, and filter were contained in an electrically heated enclosed box (6) which is thermostatically maintained at a minimum temperature of 250°F to prevent water condensation. Attached to the heated box was an ice bath (7) containing four impingers connected in series with glass balljoints. The first impinger (8) receives the gas stream from the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a 1/2 inch ID glass tube extending to 0.5 inches from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is of the Greenburg-Smith design and like the first was initially filled with 100 milliliters of distilled water. The third impinger (10), which was left dry, is a Greenburg-Smith impinger modified like the first. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained dry silica gel.

From the fourth impinger (11) the effluent stream flows through a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a needle valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous flow rates. The three thermometers (21) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range

up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from 1 to 10 inches.

The circular outlet stack was measured as 30" I.D. Two ports 90° to each other were located approximately 7 feet above the nearest downstream restriction, and approximately 5 feet from the top of the stack. (See Figure 2) Six points were sampled in each port for ten minutes each. Readings were taken every five minutes. (See Figure 3) The location of each sampling position was determined by Method 1 of the Federal Register, December 23, 1971.

Readings Taken

During each run the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head (ΔP in inches water)
5. Desired pressure drop across orifice (ΔH in inches of water)
6. Actual pressure drop across orifice (ΔH in inches of water)
7. Dry gas temperature (°F) gas meter inlet
8. Dry gas temperature (°F) gas meter outlet
9. Vacuum pump gauge reading (in. Hg)
10. Filter box temperature (°F)
11. Dry gas temperature (°F) at the discharge of last impinger
12. Stack temperature (°F)
13. Stack pressure (inches water)

The relationship of ΔP reading with the ΔH reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between ΔP and ΔH could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

IV. ANALYTICAL PROCEDURE

Particulate

The filter discs were previously tare weighed and the weights recorded at York Research's Laboratory. Upon return they were dried, cooled in a dessicator, then weighed on an analytical balance. The amount of particulate collected is the difference in the weights. The probe and nozzle acetone wash solution is placed into a tared beaker, evaporated with an Infra-Red lamp and the beaker weighed again. The difference in weight is the weight of the particulate in the wash. This is combined with the filter catch as the weight of the sample.

Hydrocarbons

Hydrocarbon samples are collected by the grab sample technique. This method employs a 250 ml flask with a two-way valve at each end. One end of the flask is inserted in the sample stream and the other end is connected to a vacuum pump. The sample is collected by purging the flask with flue gas while heating to prevent condensation. The valve on the pump side is closed first then the valve on the stack side is closed. The sample is then sent to the lab for analysis. (See Figure 4)

Hydrocarbon samples are analyzed by use of the gas chromatography method.

Carbon Monoxide

Carbon Monoxide are analyzed by using the grab flasks used for hydrocarbons and analyzing them by non-dispersive Infra-Red (NDIR) analysis. Detection tubes are also used in the field as a check. The laboratory sample of CO comes from the 250 ml flask used for hydrocarbon collection.

Oxides of Nitrogen (EPA Method No. 7)

A grab sample is collected in an evacuated flask containing a dilute sulfuric acid - hydrogen peroxide absorbing solution.

The sampling procedure consists of pipetting 25 ml of H_2SO_4 - H_2O_2 absorbing solution into a 2 liter sampling flask. The flask is then evacuated to at least 3 in. Hg. absolute pressure. The next step is to evacuate the probe prior to sampling. The sample is then taken over a period of 15 seconds. After the sample has been collected, the flask is shaken for approximately 5 minutes. After this period the flask must be left with the sample for a minimum of 16 hours. After the 16 hours, the flask

is reshaken for a period of two minutes. After this the final pressure of the flask is recorded and the sample is transferred to the lab for analysis. The sampling apparatus used to collect oxide of nitrogen samples is shown in Figure 5.

In the laboratory, the amount of nitrogen in the sample is determined by the phenoldisulphonic method. This method is as follows:

The sample is placed in a beaker and NaOH is slowly added until the solution is neutral or slightly basic by litmus paper indication. This solution is then evaporated in the beaker used for neutralization. To the dry residue, two (2) milliliters of phenoldisulphonic acid are added and mixed to dampen all the precipitate. Then add two (2) milliliters of distilled water and mix thoroughly; add twenty (20) more milliliters of distilled water and mix. Add concentrated NH_4OH to this solution in excess of neutralization. Filter solution if necessary and transfer to a volumetric flask. Using a spectrophotometer at 420 m μ , compare results with a standard curve based on standard concentrations, and read milligrams of nitrogen in the sample.

After the amount of nitrogen in the sample is known, the concentration is calculated using the following formula.

$$\text{ppm NO}_x = \frac{(29.63) (\text{Mg NO}_x) (T_f + 460)}{(V_f) (P_i - P_f)}$$

Where: ppm NO_x = parts per million of NO_x
 Mg NO_x = milligrams of NO_x in sample
 T_f = flask temperature ($^{\circ}\text{F}$)
 P_i = initial flask pressure (in. Hg.)
 P_f = final flask pressure
 V_f = flask volume

SO_2 , SO_3 Analysis (EPA Method No. 6)

The sulfur dioxide sampling train consists of the following components arranged and illustrated schematically (See Figure 6): (1) glass wool filter, (2) an electrically heated glass probe, (3) variac, (4,5,6,7) four midjet impingers, (8) ice bath, (9) drying tube containing silica gel, (10) vacuum gauge, (11) control valve, (12) vacuum pump, (13) dry gas meter, and (14) thermometer.

The probe is made of an 18" length of medium wall Pyrex tubing wound with 26 gauge nichrome heating wire. The front end of the probe includes a two-inch long area for insertion of glass wool to be used as a filtering device. The wire is connected to a variable transformer which allows the voltage and hence the heat input to be controlled. The wire is covered with a fiberglass insulation tape.

Samples of stack gas are drawn through a heated glass probe which is packed with glass wool in the sampling end. From the sampling probe the gas is drawn through three midget impingers.

The first midget impingers contain 15 ml of 80% isopropanol and 15 ml of 3% hydrogen peroxide to trap the SO_3 and SO_2 respectively. The third impinger is left dry and is followed by a drying tube packed with silica gel. The remaining gas goes to a vacuum pump, rotometer, and a dry gas meter for measurement of the quantity of gas sampled. The impinger set up is connected in series. The chamber near the bubbler outlet is stuffed with fine glass wool to prevent any H_2SO_4 from entering into the H_2O_2 . An ice bath is provided for the bubbler and impingers. Attached to the outlet of the third impinger is a drying tube filled with silica gel of the indicator type. A bypass valve is provided for the leakless pump and a vacuum gauge and needle valve are installed at the inlet of the pump. The dry gas meter has a sensitivity of 0.001 cubic foot and is fitted with a thermometer on the meter inlet.

The sampling method draws the flue gas through the sampling train at the rate of .1 cubic foot per minute for a period of 20 minutes. After the actual sampling time the sample is aspirated on ambient air for the same length of time the sample was taken. After this step, the samples are transported to the lab for analyses.

In the laboratory the amount of sulfur dioxide and sulfur trioxide are measured as follows:

Dilute solution used for sampling to 50 ml. Pipette 10 ml. of this solution into a 125 ml. Erlenmeyer flask. Add 40 ml. of isopropanol and two to four drops of thorin indicator. Titrate to a pink endpoint using 0.01 N barium perchlorate. Run a blank with each series of samples.

The SO_2 and SO_3 concentration is calculated as follows:

$$C_{\text{SO}_2} = (7.05 \times 10^{-5} \frac{\text{lb-l}}{\text{g-ml}}) \frac{(V_t - V_{tb}) N (V_{\text{soln}})}{V_{\text{mstd}} (V_a)}$$

Where: V_t = Volume of Barium perchlorate titrant used, ml.
 V_{tb} = Volume of Barium perchlorate titrant used in blank, ml.
 N = Normality of Barium perchlorate titrant, g-eq./l.
 V_{soln} = Total solution volume of SO_2 , SO_3 , 50 ml.
 V_a = Volume of sample aliquot titrated, ml.
 V_{mstd} = Volume of gas sample through the dry gas meter (std. conditions), cu.ft.


CO₂ and O₂

CO₂ and O₂ samples were collected by traverse through a sampling tube attached to the particulate sampling probe and aspirated into leveling bottles as illustrated in Figure 7. The gas collected was immediately tested with an Orsat apparatus for CO₂ and O₂ concentration.

TEST TEAM

Louis Terracciano
Robert S. Epstein
Jerold Grabiner
Andrew Gabriel

Prepared By:


Robert S. Epstein
Asst. Project Director

Reviewed By:


Roy S. Eydal
Engineering Manager

Approved By:


Abraham J. Kurtz
Vice President-Operations

V. FIGURES

PARTICULATE SAMPLING TRAIN







FIGURE #1

GAS FLOW
FIGURE 2


SAMPLING POINT LOCATION
FIGURE 3

THE DIMENSION INDICATED IS FROM THE
PORT (ID) TO THE SAMPLING POINT

HYDROCARBON SAMPLING
FIGURE 4



NO_x SAMPLING TRAIN

**FIGURE #5**

SO_x SAMPLING TRAIN






FIGURE #6

CO_2 AND O_2
Sample Collection

FIGURE 7



Sample recovery



VI. APPENDIX

OXIDES OF NITROGEN FIELD DATA

JOB NO. 8155

Date 5.29.73

Plant ENFIELD SEWAGE TREATMENT

Sample Collected By RSE

Run No. 1-6

Power Stat Setting 75%

Field Data

	1	2	3	4	5	6
Clock Time	1420	1425	1427	1431	1432	1435
Flask Number	1	2	3	4	5	6
Volume of flask less correction (liter)	2.042	2.061	2.033	2.034	2.066	2.055
Pressure before sampling in Hg.	-25.0	-25.3	-25.0	-25.2	-25.2	-25.1
Pressure after sampling in Hg.	-.5	-1.4	-2.9	-.1	-1.6	0
Flask temperature, °F	70	70	70	70	70	70

Remarks:



OXIDES OF NITROGEN FIELD DATA

JOB NO. 8155

Date 5.29.73

Plant ENFIELD SEWAGE TREATMENT

Sample Collected By RSE

Run No. 7-12

Power Stat Setting 75%

Field Data

	7	8	9	10	11	12
Clock Time	1437	1441	1444	1453	1455	1457
Flask Number	7	8	9	10	11	12
Volume of flask less correction (liter)	2.064	2.053	2.012	2.031	2.053	2.041
Pressure before sampling in Hg.	-25.3	-25.5	-25.5	-25.0	-25.5	-25.5
Pressure after sampling in Hg.	-2.5	-2.2	-2.3	0	-1.7	-3.8
Flask temperature, °F	70	70	70	70	70	70

Remarks:



NO_x EMISSION DATA

RUN NO.	1	2	3	4	5	6	
Date	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	
mg NO ₂	.1327	.1516	.1289	.1990	.1914	.3279	
T _f - Flask Temperature, °F	70	70	70	70	70	70	
V _f - Flask Volume, liters	2.042	2.061	2.033	2.034	2.066	2.055	
P _i - Initial Flask Vacuum, "Hg.	-25.0	-25.3	-25.0	-25.2	-25.2	-25.1	
P _f - Final Flask Vacuum, "Hg.	-.5	-1.4	-2.9	-.1	-1.6	0	
ppm NO ₂	41.6	48.3	45.1	61.2	61.7	99.8	

$$\text{ppm NO}_2 = \frac{29.63 \times \text{mg NO}_2 \times (T_f + 460)}{V_f \times (P_i - P_f)}$$

$$\#1 \quad \frac{29.63 \times .1327 \times 530}{2.042 \times 24.5} = 41.6$$

$$\#4 \quad \frac{29.63 \times .1990 \times 530}{2.034 \times 25.1} = 61.2$$

$$\#2 \quad \frac{29.63 \times .1516 \times 530}{2.061 \times 23.9} = 48.3$$

$$\#5 \quad \frac{29.63 \times .1914 \times 530}{2.066 \times 23.6} = 61.7$$

$$\#3 \quad \frac{29.63 \times .1289 \times 530}{2.033 \times 22.1} = 45.1$$

$$\#6 \quad \frac{29.63 \times .3279 \times 530}{2.055 \times 25.1} = 99.8$$

NO_x EMISSION DATA

RUN NO.	7	8	9	10	11	12	
Date	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	5/29/73	
mg NO ₂	.3203	.2350	.1687	.1800	.2976	.1952	
T _f - Flask Temperature, °F	70	70	70	70	70	70	
V _f - Flask Volume, liters	2.064	2.053	2.012	2.031	2.053	2.041	
P _i - Initial Flask Vacuum, "Hg.	-25.3	-25.5	-25.5	-25.0	-25.5	-25.5	
P _f - Final Flask Vacuum, "Hg.	-2.5	-2.2	-2.3	0	-1.7	-3.8	
ppm NO ₂	106.9	77.2	56.8	55.7	91.8	69.3	

$$\text{ppm NO}_2 = \frac{29.63 \times \text{mg NO}_2 \times (T_f + 460)}{V_f \times (P_i - P_f)}$$

$$\#7 \quad \frac{29.63 \times .3203 \times 530}{2.064 \times 22.8} = 106.9$$

$$\#10 \quad \frac{29.63 \times .1800 \times 530}{2.031 \times 25.0} = 55$$

$$\#8 \quad \frac{29.63 \times .2350 \times 530}{2.053 \times 23.3} = 77.2$$

$$\#11 \quad \frac{29.63 \times .2976 \times 530}{2.053 \times 24.8} = 91$$

$$\#9 \quad \frac{29.63 \times .1687 \times 530}{2.012 \times 23.2} = 56.8$$

$$\#12 \quad \frac{29.63 \times .1952 \times 530}{2.041 \times 21.7} = 69$$

GAS SAMPLING FIELD DATA

JOB NO. 8155

Material Sampled for SO_x

Date 6-1-73

Plant ENFIELD Location SCRUBBER OUTLET

Bar. Pressure 29.91 "Hg

Ambient Temp. 90

Run No. 1

Power Stat Setting 75%

Filter Used: Yes X No

Operator RBE

Comments:

Impinger #1 ml

Impinger #2 ml

Impinger #3 ml

Impinger #4 ml

CLOCK TIME	METER (Ft ³)	FLOW METER SETTING (CFM)	METER TEMPERATURE TM
1527	384.098	.1	92
1532	384.735	.1	92
1537	385.103	.1	92
1542	385.662	.1	92
1547	385.903	.1	92

COMMENTS:



GAS SAMPLING FIELD DATA

JOB NO. 8155

Material Sampled for SOx

Date 6-1-73

Plant ENFIELD Location SCRUBBER OUTLET

Bar. Pressure 29.91 "Hg

Ambient Temp. 90

Run No. 2

Power Stat Setting 75%

Filter Used: Yes ☒ No ☐

Operator RSE

Comments:

Impinger #1 ml

Impinger #2 ml

Impinger #3 ml

Impinger #4 ml

CLOCK TIME	METER (Ft ³)	FLOW METER SETTING (CFM)	METER TEMPERATURE TM
1618	387.967	.1	92
1623	388.462	.1	92
1628	388.923	.1	92
1633	389.428	.1	92
1638	390.215	.1	92



REPORT NO. 8155

Page of Pages

SO₂ EMISSION DATA

RUN NO.	1	2				
Date	4/1/73	4/1/73				
mg SO ₂	3.11	2.56				
T _m - Average Gas Meter Temperature, °F	92	92				
P _b - Barometric Pressure, "Hg abs.	29.91	29.91				
V _m - Volume of dry gas sampled @ meter conditions, ft. ³	1.805	2.248				
ppm SO ₂	23.9	15.8				

$$\text{ppm SO}_2 = \frac{0.751 \times \text{mg SO}_2 \times (T_m + 460)}{P_b \times V_m}$$

$$\#1 \quad \frac{0.751 \times 3.11 \times 552}{29.91 \times 1.805} = 23.9$$

$$\#2 \quad \frac{0.751 \times 2.56 \times 552}{29.91 \times 2.248} = 15.8$$

ONLY TWO TEST WERE MADE DUE TO SLUDGE SUPPLY



SO₃ EMISSION DATA

RUN NO.	1	2						
Date	4/1/73	4/1/73						
mg SO ₃	0.60	0.40						
T _m - Average Gas Meter Temperature, °F	92	92						
P _b - Barometric Pressure, "Hg abs.	29.91	29.91						
V _m - Volume of dry gas sampled @ meter conditions, ft. ³	1.805	2.248						
ppm SO ₃	3.69	1.97						

$$\text{ppm SO}_3 = \frac{0.6008 \times \text{mg SO}_3 \times (T_m + 460)}{P_b \times V_m}$$

$$\#1 \quad \frac{0.6008 \times 0.60 \times 552}{29.91 \times 1.805} = 3.69$$

$$\#2 \quad \frac{0.6008 \times 0.40 \times 552}{29.91 \times 2.248} = 1.97$$

* ONLY TWO TESTS WERE MADE
DUE TO SLUDGE SUPPLY THINNING OUT

HYDROCARBON EMISSION DATAJob No. 8155Date 5-29-73Plant ENFIELD Location SCRUBBER OUTLETAmbient Temp. 70Operator R&E

Test No.	Time	Flask Temp.	Comments
1	1556	350°F	4.80 ppm
2	1610	350	3.36
3	1617	350	2.81
4	1625	350	8.42
5	1825	350	4.86
6	1837	350	10.82
7	1923	350	2.40
8	1942	350	5.07

YORK RESEARCH CORPORATION

TEMP PROBE CALIBRATION

Thermometer
Glass 0-230°F

Thermometer
Glass 200-750°F

Thermocouple
E.P.A. Train

Ambient
Air

68°

—

69°

Water

212

212

212

Light
Oil

—

375°

376°

—

775°

776°

OVEN

WITH 1000°F
THERMOMETER

Calibrated by:

R. L. Lasser

Meter Calibration

Accuracy within 1°F

Calibrated by:

R. L. Lasser

Calibration Calculations Meter and Pump Box

Date 5/9/73 Box No 5-1564 Meter No. _____

ΔH_0	P_b (Man. orifice)	$(T_v + 460)t^2$	Man.
	$P_b (OT_d + 460)$	CT_v	
	0.01585	$(73 + 460)^2$	
	<u>29.86</u>	<u>13.65</u>	<u>5.209</u>
		<u>5</u>	
	0.0317	$(73 + 460)^2$	
	<u>29.86</u>	<u>8.12</u>	<u>1.0186</u>
		<u>5</u>	
	0.0634	$(73 + 460)^2$	
	<u>29.86</u>	<u>13.3</u>	<u>2.0197</u>
		<u>10</u>	
	0.1268	$(73 + 460)^2$	
	<u>29.86</u>	<u>9.30</u>	<u>4.0191</u>
		<u>10</u>	
	0.1902	$(73 + 460)^2$	
		<u>6.0</u>	
	0.2536	$(73 + 460)^2$	
		<u>8.0</u>	

$CT_v P_b (T_v \text{ avg.} + 460)$	Man.	γ
$CT_d (P_b + \frac{\text{Man. orifice}}{13.6} (T_v + 460))$		
<u>5</u> $\times$ <u>29.86</u> (<u>77</u> + 460)	<u>5</u>	<u>.99</u>
<u>5</u> (<u>29.86</u> + 0.0368) (<u>73</u> + 460)		
<u>5</u> $\times$ <u>29.86</u> (<u>80</u> + 460)	<u>1.0</u>	<u>1.00</u>
<u>5.01</u> (<u>29.86</u> + 0.0737) (<u>73</u> + 460)		
<u>10</u> $\times$ <u>29.86</u> (<u>83.5</u> + 460)	<u>2.0</u>	<u>.99</u>
<u>10.11</u> (<u>29.86</u> + 0.147) (<u>73</u> + 460)		
<u>10</u> $\times$ <u>29.86</u> (<u>90.5</u> + 460)	<u>4.0</u>	<u>1.01</u>
<u>10.03</u> (<u>29.86</u> + 0.294) (<u>73</u> + 460)		
<u>10</u> $\times$ _____ (<u>100</u> + 460)	<u>6.0</u>	
<u>10</u> $\times$ _____ (<u>100</u> + 0.431) (<u>100</u> + 460)		
<u>10</u> $\times$ _____ (<u>100</u> + 460)	<u>8.0</u>	
<u>10</u> $\times$ _____ (<u>100</u> + 0.588) (<u>100</u> + 460)		

YORK RESEARCH CORPORATION

PITOT TUBE CALIBRATION

STD
8

.07
.10

$\sqrt{.7000}$

.836

.17
.25

$\sqrt{.6800}$

.824

.47
.68

$\sqrt{.6911}$

.831

.70
.99

$\sqrt{.7070}$

.840

Standard Pitot
Factor = 1.00

Calibrated By

D. E. Egan

Date

5/11/73

Pitot Tube #

16

Calibration - Orifice and Meter

Date 5/9/73 Box No. S-1564 Meter No. P-29.86

Man Orifice	CF _w	CF _d	T _w	T _d	OT _d	T _d ave.	Time
0.5	5	5	73	78	76	77	13.89
1.0	5	5.01	73	82	78	80	8.12
2.0	10	10.11	73	87	80	83.5	13.3
4.0	10	10.03	73	97	84	90.5	9.58
6.0	10						
8.0	10						

Calculate Y & H₀ at man. 2.0

$$Y = \frac{CF_w P_b (T_d \text{ ave.} + 460)}{CF_d (P_b + 0.147) (T_w + 460)}$$

$$Y = \frac{(+ 0.147) (+ 460)}{0.0634 (T_w + 460)^2}$$

$$\Delta H_0 = \frac{P_b (OT_d + 460)}{CF_w}$$

$$\Delta H_0 = \frac{0.0634 (+ 460)^2}{(+ 460)}$$

Tolerances

$$Y = 0.99 - 1.00 - 1.01$$

$$\Delta H_0 = 1.6 - 1.84 - 2.1$$

STANFORD Conn

710556 Box No. S-1564

Meter No.

Date 5/9/73

Pump OK

Pump oil OK

Clean quick connects OK

Valves OK

Manometers OK

Dry test meter OK

Thermometers OK

Lights OK

Buzzer

Electrical check - Amphenol OK

110 V recept.

Varia OK

Vacuum gauge OK

Leak check at 27" Hg. - Leakage = OK - NO LEAK

Remarks Box RECAL. WITHIN 30 DAYS

Initial each item when checked and write in any remarks.

STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION

STATE OFFICE BUILDING

HARTFORD, CONNECTICUT 06115

DAN W. LUFKIN
COMMISSIONER

May 17, 1973


Mr. Bob Epstein
York Research Corp.
One Research Drive
Stamford, Connecticut 06906

Dear Mr. Epstein:

You are hereby notified that "Intent to Test" for number 730024 which describes a test plan for sampling emissions from the Enfield sewage sludge incinerator, is acceptable and meets the test criteria required by the State of Connecticut, Department of Environmental Protection.

The field tests will be observed by Carl Dodge unless you are otherwise notified. He should be informed of progress and problems that may alter the test program.

Very truly yours,



Carl Dodge
Senior Air Pollution Engineer

CD/lp

cc Henry Mosher
Envirotech Systems Inc.
BSP Division
P.O. Box 8158
San Francisco, Calif. 94128

Enfield, Conn. 5726
March 26, 1973

DESCRIPTION OF OPERATIONS

The incinerator is a multiple-hearth furnace which is 22 ft. 3 in. in diameter and has 6 hearths. The temperatures in the furnace are regulated by North American burners (manufacturer of burners) located on hearths 1, 2, 4, & 5. The total burner system has a maximum capacity of 16,000,000 Btu/hr and consumes 114 (gph) of #2 fuel oil. The furnace is designed to burn 12,600 lb/hr of a mixture of primary and secondary sludge and skum. The composition of the sludge, skum, and fuel are:

Sludge & Skum

<u>75</u>	% Moisture
<u>70.4</u>	% Volatile Solids (Dry Basis)
<u>55.8</u>	% Carbon (Volatile Basis)
<u>8.2</u>	% Hydrogen (Volatile Basis)
<u>31.0</u>	% Oxygen (Volatile Basis)
<u>5.0</u>	% Nitrogen (Volatile Basis)
<u>0.0</u>	% Sulfur (Volatile Basis)
<u>11,000</u>	Btu/Lb Heating Value (Volatile Basis)

Enfield, Conn. 5726

March 26, 1973

Description of Operations (continued)

Fuel

#2 Fuel Oil

<u>86.1</u>	%	Carbon
<u>13.2</u>	%	Hydrogen
<u>0.0</u>	%	Oxygen
<u>0.1</u>	%	Nitrogen
<u>0.6</u>	%	Sulfur
<u>0.0</u>	%	CO ₂
<u>0.0</u>	%	ASH
<u>141,000</u>	Btu/Lb Heating Value (Btu/Gal)	

The combustion air for the sludge and/or other components of the waste will be supplied by separate fan such that 50% excess air on the volatiles is maintained.

As the sludge is burned, a relatively large amount of gases are produced. What remains after combustion is a sterile ash which is transported to another location by some suitable means. Along with the combustion gases produced by the sludge and auxiliary fuel (if any) is particulate matter. This particulate matter is passed through a scrubbing system which removes the dust particles. The resulting effluent gas stream then conforms to the local air pollution regulations.

Enfield, Conn. 5726
March 26, 1973
Description of Operations (continued)

The scrubber shall be an impingement type using 350 gpm total water for adequate scrubbing of gases. The scrubber will have an outlet volume of 13,690 ACFM (maximum) @ 166°F with a differential pressure of 6" W.C. at the designed scrubber outlet volume with an inlet dust loading of approximately 9 # particulates/1000 # dry gases. The emission rate shall not exceed 0.2 #/hr of particulates per 1000# of dry gases corrected to 50% excess air.

The induced draft fan shall be rated at 7.5 Δ P static pressure and 13,690 ACFM @ 166°F and 0 ft. above sea level at operating conditions.

ENFIELD W.P.C.P. INC. OPERATION

DATE 5-29 1973
DAY TUESDAY

STANDBY RUNNING

SLUDGES		TEMPERATURES °										BURNERS ON			CONTROL SETTINGS							WATER CON		MISCELLANEOUS			
TIME	METER	R-1	R-2	R-3	R-4	H-3	H-4	H-5	H-6	SCRU	ID	DRIFT	AIR	SHAFT	SHAFT	SLUDGE	SCRU	SCRU	SCRU	SCRU	SCRU	PRE-COOL	SCRU	Filter	FUEL		
0:10	0	810	980	1140	1420	1340	520	60	70	260		0.15	—	—	—	—	—	—	—	—	70	276	20	OFF	16%	39.0	
1:10	5240	830	1100	1170	1440	1370	530	140	70	270		0.09	—	—	—	—	—	3.4	4.0	7.5	—	—	—	OFF	16%	37.2	
2:10	7575	820	1080	1130	1450	1400	550	140	70	280		0.09	2009	—	—	—	—	3.6	4.1	7.5	—	—	—	6%	16%	41.0	
3:10	27170	810	960	1180	1450	1340	560	160	80	260		0.075	—	20%	8.7	35	—	3.8	4.2	8.0	—	—	—	6%	16%	41.0	
4:10	44160	910	1180	1280	1430	1310	620	220	110	300		0.1	—	60%	7.3	35	—	6.2	7.2	10.5	—	—	—	6%	16%	54.0	
5:10	58950	910	1130	1350	1370	1130	530	240	100	310		0.1	—	50%	9.0	40	—	5.0	6.0	9.5	—	—	—	11%	14%	42.0	
6:10	75240	900	1160	1290	1390	1120	620	260	100	310		0.1	—	55%	8.0	40	—	5.2	6.4	10.0	—	—	—	—	14%	42.0	
7:10	92000	870	1160	1290	1400	1120	610	260	100	310		0.1	—	55%	8.0	40	—	5.2	6.4	9.9	—	—	—	—	16%	42.0	
8:10	109750	820	1070	1160	1420	1180	610	260	100	300		0.08	—	55%	8.0	35	—	5.0	6.0	9.5	—	—	—	—	16%	42.0	
9:10	12160	810	980	1070	1320	1280	600	250	100	290		0.1	—	50%	7.5	30	—	4.8	5.0	9.5	—	—	—	—	17%	42.0	
10:10	141350	800	950	1020	1400	1120	600	240	100	290		0.08	—	43%	2.5	50	—	4.4	5.4	9.3	—	—	—	—	17%	42.0	
10:45	151877	6263																									
AVERAGE	7550	510	1070	1400	410	240	560	205	90	290		0.10	50	11.6	37			4.7	5.5	9.1					12%	15%	42

REMARKS: PERFORMANCE TEST! ① FILTER #2 CAKE ON AT 10:10, 39% POLYMER AT 11:00
 ② START 2ND FILTER AT 12:05 CAKE ON AT 12:15
 ③ ASH SAMPLE TAKEN AT 16:20 THEREFORE EMITTING DUST PARTICLES TO STACK
 ④ TOTAL 95 lbs. POLYMER USED

TOTAL RUNNING TIME 10:10 THRU 20:45 = 10h 35m
 POUNDS TO INC. 159177 ÷ 2 = 79,588

126535	68381	3500
125212	67892	2900
12913	419	600

ENFIELD W.P.C.P. INC. OPERATION

DAY FRIDAY
DATE 6/1 1973

STANDBY RUNNING

SLUDGE			TEMPERATURES °F										BURNERS ON				CONTROL SETTINGS							WATER CFT			MISCELLANEOUS																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
TIME	METER	\$/HR	H-1	H-2	H-3	H-4	H-5	H-6	SCRUB INLET	ID FAN	HAFT AIR	H-1	H-2	H-4	H-5	DRAFT	AIR PORTS	SHAFT AIR %	% O ₂	SHAFT SPEED	SLUDGES CONC AIR	SCRUB PRESSURE IN. W.C.	ID SETTING PSIG	PRE-COOLER	SCRUB SPRAY	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	528	529	530	531	532	533	534	535	536	537	538	539	540	541	542	543	544	545	546	547	548	549	550	551	552	553	554	555	556	557	558	559	560	561	562	563	564	565	566	567	568	569	570	571	572	573	574	575	576	577	578	579	580	581	582	583	584	585	586	587	588	589	590	591	592	593	594	595	596	597	598	599	600	601	602	603	604	605	606	607	608	609	610	611	612	613	614	615	616	617	618	619	620	621	622	623	624	625	626	627	628	629	630	631	632	633	634	635	636	637	638	639	640	641	642	643	644	645	646	647	648	649	650	651	652	653	654	655	656	657	658	659	660	661	662	663	664	665	666	667	668	669	670	671	672	673	674	675	676	677	678	679	680	681	682	683	684	685	686	687	688	689	690	691	692	693	694	695	696	697	698	699	700	701	702	703	704	705	706	707	708	709	710	711	712	713	714	715	716	717	718	719	720	721	722	723	724	725	726	727	728	729	730	731	732	733	734	735	736	737	738	739	740	741	742	743	744	745	746	747	748	749	750	751	752	753	754	755	756	757	758	759	760	761	762	763	764	765	766	767	768	769	770	771	772	773	774	775	776	777	778	779	780	781	782	783	784	785	786	787	788	789	790	791	792	793	794	795	796	797	798	799	800	801	802	803	804	805	806	807	808	809	810	811	812	813	814	815	816	817	818	819	820	821	822	823	824	825	826	827	828	829	830	831	832	833	834	835	836	837	838	839	840	841	842	843	844	845	846	847	848	849	850	851	852	853	854	855	856	857	858	859	860	861	862	863	864	865	866	867	868	869	870	871	872	873	874	875	876	877	878	879	880	881	882	883	884	885	886	887	888	889	890	891	892	893	894	895	896	897	898	899	900	901	902	903	904	905	906	907	908	909	910	911	912	913	914	915	916	917	918	919	920	921	922	923	924	925	926	927	928	929	930	931	932	933	934	935	936	937	938	939	940	941	942	943	944	945	946	947	948	949	950	951	952	953	954	955	956	957	958	959	960	961	962	963	964	965	966	967	968	969	970	971	972	973	974	975	976	977	978	979	980	981	982	983	984	985	986	987	988	989	990	991	992	993	994	995	996	997	998	999	1000	1001	1002	1003	1004	1005	1006	1007	1008	1009	1010	1011	1012	1013	1014	1015	1016	1017	1018	1019	1020	1021	1022	1023	1024	1025	1026	1027	1028	1029	1030	1031	1032	1033	1034	1035	1036	1037	1038	1039	1040	1041	1042	1043	1044	1045	1046	1047	1048	1049	1050	1051	1052	1053	1054	1055	1056	1057	1058	1059	1060	1061	1062	1063	1064	1065	1066	1067	1068	1069	1070	1071	1072	1073	1074	1075	1076	1077	1078	1079	1080	1081	1082	1083	1084	1085	1086	1087	1088	1089	1090	1091	1092	1093	1094	1095	1096	1097	1098	1099	1100	1101	1102	1103	1104	1105	1106	1107	1108	1109	1110	1111	1112	1113	1114	1115	1116	1117	1118	1119	1120	1121	1122	1123	1124	1125	1126	1127	1128	1129	1130	1131	1132	1133	1134	1135	1136	1137	1138	1139	1140	1141	1142	1143	1144	1145	1146	1147	1148	1149	1150	1151	1152	1153	1154	1155	1156	1157	1158	1159	1160	1161	1162	1163	1164	1165	1166	1167	1168	1169	1170	1171	1172	1173	1174	1175	1176	1177	1178	1179	1180	1181	1182	1183	1184	1185	1186	1187	1188	1189	1190	1191	1192	1193	1194	1195	1196	1197	1198	1199	1200	1201	1202	1203	1204	1205	1206	1207	1208	1209	1210	1211	1212	1213	1214	1215	1216	1217	1218	1219	1220	1221	1222	1223	1224	1225	1226	1227	1228	1229	1230	1231	1232	1233	1234	1235	1236	1237	1238	1239	1240	1241	1242	1243	1244	1245	1246	1247	1248	1249	1250	1251	1252	1253	1254	1255	1256	1257	1258	1259	1260	1261	1262	1263	1264	1265	1266	1267	1268	1269	1270	1271	1272	1273	1274	1275	1276	1277	1278	1279	1280	1281	1282	1283	1284	1285	1286	1287	1288	1289	1290	1291	1292	1293	1294	1295	1296	1297	1298	1299	1300	1301	1302	1303	1304	1305	1306	1307	1308	1309	1310	1311	1312	1313	1314	1315	1316	1317	1318	1319	1320	1321	1322	1323	1324	1325	1326	1327	1328	1329	1330	1331	1332	1333	1334	1335	1336	1337	1338	1339	1340	1341	1342	1343	1344	1345	1346	1347	1348	1349	1350	1351	1352	1353	1354	1355	1356	1357	1358	1359	1360	1361	1362	1363	1364	1365	1366	1367	1368	1369	1370	1371	1372	1373	1374	1375	1376	1377	1378	1379	1380	1381	1382	1383	1384	1385	1386	1387	1388	1389	1390	1391	1392	1393	1394	1395	1396	1397	1398	1399	1400	1401	1402	1403	1404	1405	1406	1407	1408	1409	1410	1411	1412	1413	1414	1415	1416	1417	1418	1419	1420	1421	1422	1423	1424	1425	1426	1427	1428	1429	1430	1431	1432	1433	1434	1435	1436	1437	1438	1439	1440	1441	1442	1443	1444	1445	1446	1447	1448	1449	1450	1451	1452	1453	1454	1455	1456	1457	1458	1459	1460	1461	1462	1463	1464	1465	1466	1467

REMARKS: CAKE FEED STOPPED AT 0905; Second filter on 1105

Running looks good - stack appear to be Ringman's or less and little particulates. Some sludge balls but very small.

1530 - running low on sludge - torque meter now at 1/8

TEST OVER - 1705

TOTAL RUNNING TIME

POUNDS TO INC.

FEED SUPPLY SUPPLY TANK METER 9675



PARTICULATE CALCULATIONS

The following are the basic equations used in calculating final data as found in the final summary.

1. Volume of dry gas sampled at standard conditions - 70°F, 29.92" Hg, ft.³

$$V_{mstd} = \frac{17.7 \times V_m \left(\frac{P_b + P_m}{13.6} \right)}{(T_m + 460)} = \text{Ft.}^3$$

2. Volume of water vapor at 70°F and 29.92" Hg, Ft.³

$$V_{wgas} = 0.0474 \times V_w = \text{Ft.}^3$$

3. % Moisture in stack gas

$$\%M = \frac{100 \times V_{wgas}}{V_{mstd} + V_{wgas}} = \%$$

4. Mole fraction of dry gas

$$M_d = \frac{100 - \%M}{100}$$

5. Average molecular weight of dry stack gas

$$M W_d = (\% CO_2 \times \frac{44}{100}) + (\% O_2 \times \frac{32}{100}) + (\% N_2 \times \frac{28}{100})$$

6. Molecular weight of stack gas

$$M W = M W_d \times M_d + 18 (1 - M_d)$$



7. Stack velocity at stack conditions, fpm

$$V_s = 4350 \times \sqrt{\Delta P_s \times (T_s + 460)} \left(\frac{1}{P_s \times M W} \right)^{1/2} = \text{fpm}$$

8. Stack gas volume at standard conditions, SCFM

$$Q_s = \frac{0.123 \times V_s \times A_s \times M_d \times P_s}{(T_s + 460)} = \text{SCFM}$$

9. Percent isokinetic

$$\%I = \frac{1032 \times (T_s + 460) \times V_{mstd}}{V_s \times T_t \times P_s \times M_d \times (D_n)^2} = \%$$

10. Particulate - probe, cyclone and filter, gr/SCF

$$C_{an} = 0.0154 \times \frac{M_f}{V_{m \text{ std}}} = \text{gr/SCF}$$

11. Particulate total, gr/SCF

$$C_{ao} = 0.0154 \times \frac{M_t}{V_{m \text{ std}}} = \text{gr/SCF}$$

12. Particulate - probe, cyclone and filter, gr/CF at stack conditions

$$C_{at} = \frac{17.7 \times C_{an} \times P_s \times M_d}{(T_s + 460)} = \text{gr/CF}$$

13. Particulate - total, gr/CF at stack conditions

$$C_{au} = \frac{17.7 \times C_{ao} \times P_s \times M_d}{(T_s + 460)} = \text{gr/CF}$$



14. Particulate - probe, cyclone and filter, lb/hr.

$$C_{aw} = 0.00857 \times C_{an} \times Q_s = \text{lb/hr.}$$

15. Particulate - total, lb/hr.

$$C_{ax} = 0.00857 \times C_{ao} \times Q_s = \text{lb/hr.}$$

16. % Excess air at sampling point

$$\% \text{ EA} = \frac{100 \times \% \text{ O}_2}{0.264 \times \% \text{ N}_2 - \% \text{ O}_2} = \%$$

$$17. \frac{\text{Lb. (Part.)}}{10^3 \text{ lb. Flue Gas @ 50\% Ex. Air}} = \frac{\text{gr. (Part.)}}{\text{SCF @ 50\% Ex. Air}} \times \frac{\text{Lb. (Part.)}}{7000 \text{ gr}} \times \frac{10^3 \text{ lb-MOL}}{\text{MW-}10^3 \text{ Lb}} \times \frac{387 \text{ SCF}}{\text{Lb.-MOL}} \text{ Flue Gas}$$

REPORT NO.

PAGE

OF

PAGES

SOURCE TESTING CALCULATION FORMS

Test No. 8155No. Runs 3Name of Firm ENVIROTECHLocation of Plant ENFIELD, CONN.Type of Plant SEWAGE TREATMENTControl Equipment WET SCRUBBERSampling Point Locations OUTLET OF SCRUBBERPollutants Sampled PARTICULATE PER EPA #5

Time of Particulate Test:

Run No. 1 Date 5-29-73 Begin 1529 End 1734Run No. 2 Date 5-29-73 Begin 1803 End 2007Run No. 3 Date 6-1-73 Begin 1324 End 1526PARTICULATE EMISSION DATA

Run No.	1	2	3	
P _b barometric pressure, "Hg Absolute	29.72	29.72	29.91	
P _m orifice pressure drop, "H ₂ O	1.04	.901	.824	
V _m volume of dry gas sampled @ meter conditions, ft. ³	68.265	62.424	60.886	
T _m Average Gas Meter Temperature, °F	97.6	93.5	90.7	
V _m Volume of Dry Gas Sampled @ Standard std. conditions, ft. ³	64.567	59.936	58.653	
V _w Total H ₂ O collected, ml., Impingers & Silica Gel.	108.9	108.2	77.1	
V _w Volume of Water Vapor Collected gas ft. ³ @ Standard Conditions*	5.16	5.13	3.68	

* 70°F, 29.92" Hg.



REPORT NO. 81551000
Page of Pages

PARTICULATE EMISSION DATA (cont'd)



Run No.	1	2	3	
%M - % Moisture in the stack gas by volume	7.4	8.0	5.9	
M _d - Mole fraction of dry gas	.926	.920	.941	
% CO ₂	10.0	10.0	9.17	
% O ₂	7.95	7.95	8.87	
% N ₂	82.05	82.05	81.96	
M W _d - Molecular weight of dry stack gas	29.92	29.92	29.92	
M W - Molecular weight of stack gas	29.04	28.97	29.12	
ΔP _s - Velocity Head of stack gas, In. H ₂ O	—	—	—	
T _s - Stack Temperature, °F	119	115	115	
$\sqrt{\Delta P_s X (T_s + 460)}$	8.09	7.52	7.30	
P _s - Stack Pressure, "Hg. Absolute	29.74	29.74	29.89	
V _s - Stack Velocity @ stack conditions, fpm	1160	1080	1050	
A _s - Stack Area, in. ²	660	660	660	
Q _s - Stack Gas Volume @ Standard Conditions, *SCFM	4480	4170	4170	
T _t - Net Time of Test, min.	120	120	120	
D _n - Sampling Nozzle Diameter, in.	.313	.313	.313	
%I - Percent isokinetic	103.3	102.3	100.2	
m _f - Particulate - probe, cyclone and filter, mg.	69.2	27.6	30.0	
m _t - Particulate - total, mg.	—	—	—	
C _{an} - Particulate - probe, cyclone, and filter, gr/SCF	.0165	.0071	.0079	
C _{ao} - Particulate - total, gr/SCF	—	—	—	
C _{at} - Particulate - probe, cyclone, and	.0128	.0058	.0068	

REPORT NO. 8155

Page of Pages

PARTICULATE EMISSION DATA (cont'd)

Run No.	1	2	3	
C_{su} - Particulate, total, gr/cf @ stack cond.	—	—	—	
C_{aw} - Particulate, probe, cyclone, and filter, lb/hr.	.6334	.2537	.2823	
C_{ax} - Particulate - total, lb/hr.	—	—	—	
%EA - % Excess air @ sampling point	58.0	58.0	69.5	

* 70°F. 29.92" Hg.

gr/scf @ 12% CO_2	.0140	.0085	.0103
---------------------	-------	-------	-------

lbs/1000 lbs FLUE GAS @ 50% EXCESS AIR	.033	.014	.017
--	------	------	------

JOB NO. 8155Plant ENFIELDRun No. 1Location SCRUBBER OUTLETDate 5-29-73Operator LAT/RBESample Box No. 7-102Meter Box No. S-1564Meter ΔH 1.97Factor 1.05

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point.

PATHOLOGICAL INCINERATORS - read and record every 5 minutes.

FILTER # FL-238PILOT K = .824Ambient Temp °F 80Bar. Press. "Hg 29.72Assumed Moisture % 12Heater Box Setting, °F 300Probe Tip Dia., In. 5/16 (3/26)Probe Length 3 FTProbe Heater Setting 300Avg. ΔP — Avg. ΔH —

Factor

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
E 1	1529	126.462	.12	1.10	1.10	93	93	3	300	65	—	120
1	1534	189.44	.12	1.10	1.10	92	93	3	300	65	—	120
2	1539	142.42	.12	1.10	1.10	101	94	3.5	300	65	—	120
2	1544	145.35	.12	1.10	1.10	101	94	3.5	300	65	—	120
3	1549	148.27	.12	1.10	1.00	102	95	3.5	300	65	—	120
3	1551	201.22	.12	1.10	1.00	102	95	3.5	300	65	—	120
4	1559	204.16	.11	1.00	1.00	102	95	3.5	200	65	—	120
4	1604	206.88	.11	1.00	1.00	102	95	3.5	200	65	—	120
5	1609	209.61	.11	1.00	1.00	101	95	3.5	200	70	—	120
5	1614	212.39	.11	1.00	1.00	101	95	3.5	200	70	—	120
6	1619	215.16	.11	1.00	1.00	101	95	3.5	300	70	—	120
6	1624	217.91	.11	1.00	1.00	101	95	3.5	300	—	—	—
END	1629	220.673	—	—	—	—	—	—	—	—	—	—
51	1634	220.673	.13	1.20	1.20	101	95	3.5	300	70	—	120
				1.20	1.20	101	95	3.5	300	70	—	120

518

Test #1

5.29.73

[illegible]

JOB NO. 8165Plant ENFIELDRun No. 2Location SCRUBBER OUTLETDate 5-29-73Operator LAT/RJESample Box No. 7-102Heater Box No. S-1564Heater ΔH 1.97Factor 1.05

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point.

PATHOLOGICAL INCINERATORS - read and record every 5 minutes.

FILTER # FL-223PITOT K = .824Ambient Temp °F 80Bar. Press. "Hg 29.72Assumed Moisture % 8Heater Box Setting, °F 300Probe Tip Dia., In. 5/16 (.3125)Probe Length 3 FTProbe Heater Setting 300Avg. ΔP — Avg. ΔH —

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
S1	1803	255.602	.11	.98	.98	91	89	3	300	65	—	120
1	1808	252.35	.11	.98	.98	91	89	3	300	65	—	120
2	1813	261.09	.10	.92	.92	94	88	3	300	65	—	120
2	1818	263.81	.10	.92	.92	94	88	3	300	65	—	120
3	1823	266.53	.10	.92	.92	96	87	3	300	65	—	120
3	1828	269.14	.10	.92	.92	96	87	3	300	65	—	120
4	1833	271.84	.10	.92	.92	97	90	2.5	200	70	—	120
4	1838	274.23	.10	.92	.92	97	90	2.5	200	70	—	120
5	1843	276.61	.10	.92	.92	99	90	3	300	70	—	120
5	1848	276.36	.10	.92	.92	99	90	3	300	70	—	120
6	1853	282.11	.10	.92	.92	99	90	3	300	70	—	120
6	1858	284.86	.10	.92	.92	99	90	3	300	70	—	120
END	1903	287.614	—	—	—	—	—	—	—	—	—	—
WE 1	1907	287.614	.09	.82	.82	97	90	2.5	200	70	—	102
	1912	290.00	.09	.82	.82	97	90	2.5	200	70	—	102

5-29-73

#2 TEST

[illegible]

JOB NO. 8155Lant ENFIELD, CONN.In No. 3Location SCRUBBER OUTLETDate 6-1-73Operator LAT/REESample Box No. 7-102Filter Box No. 5-1564Filter ΔH 1.97Factor 1.08

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point.

PATHOLOGICAL INCINERATORS - read and record every 5 minutes.

FILTER # FL-266PITOT K = .824Ambient Temp °F 80Bar. Press. "Hg 29.91Assumed Moisture % 8Heater Box Setting, °F 200Probe Tip Dia., In. 5/16 (.3125)Probe Length 3 FTProbe Heater Setting 300Avg. ΔP — Avg. ΔH —

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
51	1324	323.212	.10	.89	.89	82	82	2	300	60	—	105
1	1329	325.81	.10	.89	.89	82	82	2	300	60	—	105
2	1334	328.40	.08	.73	.73	87	84	2	300	60	—	105
2	1339	330.74	.08	.73	.73	87	84	2	300	60	—	105
3	1344	333.08	.08	.73	.73	92	87	2.5	300	60	—	115
3	1349	335.42	.08	.73	.73	92	87	2.5	300	60	—	115
4	1354	337.76	.08	.73	.73	91	87	3	300	64	—	120
4	1359	340.13	.08	.73	.73	91	89	3	300	64	—	120
5	1404	342.50	.10	.89	.89	92	90	3	300	66	—	120
5	1409	345.02	.10	.89	.89	92	90	3	300	66	—	120
6	1414	347.54	.08	.73	.73	92	90	3	300	68	—	120
6	1419	349.91	.08	.73	.73	92	90	3	300	68	—	120
END	1424	352.274	—	—	—	—	—	—	—	—	—	—
E 1	1426	352.274	.09	.82	.82	90	90	3	300	70	—	110
1	1431	354.92	.09	.82	.82	90	90	3	300	70	—	110

6-1-73

[illegible]