

STAPPA/ALAPCO

2:5

#136

12/17/86

79

**Compliance Test Report
Mattabassett District
Pollution Control Plant
Main Incinerator
Cromwell, Connecticut**

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

ROJAC Environmental
Services, Inc.

**John S. Gammie
Project Manager**

ROJAC Project F86-20

September 1986

**P.O. Box 731
West Hartford, Connecticut 06107
(203) 527-7307**

TABLE OF CONTENTS

<u>SECTION</u>		<u>PAGE</u>
1.0	PURPOSE OF TEST.....	1
2.0	SUMMARY OF RESULTS.....	2
2.1	Particulate Emissions.....	2
2.2	Total Hydrocarbon Emissions.....	2
2.3	Total Lead Emissions.....	2
2.4	Sludge Analysis.....	2
3.0	DISCUSSION OF RESULTS.....	6
3.1	Particulate Tests.....	6
3.2	Total Hydrocarbon Tests.....	6
3.3	Lead Tests.....	7
4.0	DESCRIPTION OF SAMPLING LOCATIONS.....	8
4.1	Main Incinerator Particulate Tests.....	8
5.0	SAMPLING AND ANALYSIS METHODS.....	10
5.1	Particulate Matter Tests.....	10
5.2	Exhaust Gas Analysis.....	13
5.3	Sludge Analysis.....	13
5.4	Total Hydrocarbon Analysis.....	15
5.5	Lead Analysis.....	15

APPENDICES

A	Source Test Plan
B	Test Data Summaries
C	Laboratory Analysis Data
D	Field Data Sheets
E	Main Incinerator - Operational Data
F	Equipment Calibration Data
G	Orsat Analysis Validation Forms
H	Example Calculations

LIST OF FIGURES

<u>FIGURE</u>		<u>PAGE</u>
4-1	Incinerator Outlet Sampling Location, Mattabassett District Commission, Main Incinerator, Cromwell, Connecticut.....	9
5-1	Modified EPA Method 5 Particulate Sampling Train.....	11
5-2	Integrated Sample Setup for Molecular Weight Determination.....	14

LIST OF TABLES

<u>TABLE</u>		<u>PAGE</u>
2-1	Summary of Particulate Emissions, Mattabassett District Commission, Main Incinerator, Cromwell, Connecticut.....	4
2-2	Summary of Total Hydrocarbons, Mattabassett District Commission, Main Incinerator, Cromwell, Connecticut.....	5

1.0 PURPOSE OF TEST

The Mattabassett District Pollution Control Plant retained ROJAC Environmental Services, Inc. to conduct compliance testing for particulate, lead and hydrocarbon emissions on the Main Incinerator exhaust stack at the Mattabassett District Water Pollution Control Plant. All emission tests were to comply with the requirements of the Connecticut Department of Environmental Protection (DEP).

The Source Test Plan was submitted and reviewed by the Connecticut DEP prior to the beginning of the testing program. A copy of the test plan is contained in Appendix A. Field work was observed by Mr. George Miller of the DEP. The emission tests were conducted by ROJAC on August 27, 1986 by Messrs. Leigh Gammie and John Gammie. The test program was conducted with supervision from Mr. Christian Bratina of the Mattabassett District.

All testing was performed according to EPA Methods 1 through 5.

2.0 SUMMARY OF RESULTS

2.1 Particulate Emissions

A summary of the particulate emissions from the Main Incinerator exhaust stack is shown in Table 2-1. Four test runs were performed under varying operating conditions. The average particulate concentration was 0.21 pounds per 1000 pounds of flue gas at 50 percent excess air. The results ranged from 0.141 to 0.282 lb/1000 lb dry @ 50% excess air. The particulate concentration limit to be demonstrated was 0.40 pounds per 1000 pounds of flue gas at 50 percent excess air.

2.2 Total Hydrocarbon Emissions

A summary of the total hydrocarbon emissions from the incinerator exhaust stack is shown in Table 2-2. The average total hydrocarbon emission rate was 2.3 pounds per hour. Three tests were performed simultaneously with the particulate tests. Quantitation of the total hydrocarbons was based upon n-hexane.

2.3 Total Lead Emissions

The results of the lead emissions are shown in Table 2-1. The average lead emission rate was 0.036 pounds per hour, with results ranging from 0.024 to 0.050 pounds per hour. The lead content in the flue gas was determined from the EPA Method 5 filter used during the particulate test.

2.4 Sludge Analysis

Prior to and during the test program sludge samples were collected. Samples were then analyzed for mercury and beryllium.

The mercury concentration was <0.002 milligrams per kilogram and the beryllium concentration was less than 1 part per million. The results of these analyses may be found in Appendix C.

TABLE 2-1

SUMMARY OF PARTICULATE AND LEAD EMISSIONS
MATTABASSETT DISTRICT COMMISSION
INCINERATOR EXHAUST
CROMWELL, CONNECTICUT

Run Number	1		2		3		4	
	08/27/86	08/27/86	08/27/86	08/27/86	08/27/86	08/27/86	08/27/86	Average
Date	1019-1122	1219-1321	1431-1536	1725-1829				
Time								
Location	Outlet	Outlet	Outlet	Outlet	Outlet	Outlet	Outlet	Outlet
Volume of Gas Sampled, (ACF) ¹	49.05	50.35	48.42	51.10				
Volume of Gas Sampled, (DSCF) ²	46.32	47.06	45.14	48.02				
Volumetric Flowrate, (ACFM) ³	13100	15300	14500	14900				
Volumetric Flowrate, (DSCFM) ³	8500	7100	9600	9000				
Percent Moisture By Volume	25.3	45.0	23.7	29.8				
Average Stack Temperature, (°F)	149	164	144	152				
Percent Isokinetic	105.9	128.4	91.0	103.3				
Percent Oxygen, (Dry)	12.1	10.5	14.6	12.2				
Percent Carbon Dioxide, (Dry)	6.6	8.0	5.2	6.6				
Molecular Weight, (Stack)	26.6	24.4	26.7	26.1				
Total Particulate Collected, (mg) ⁴	151.3	359.4	141.6	286.4				
Emission Rate, (Pounds/Hour)	3.65	7.16	3.98	7.09				
Particulate Concentration, (Grains/DSCF) ⁵	0.05	0.12	0.04	0.09				0.075
Particulate Concentration, (Gr/DSCF@50%EA) ⁶	0.076	0.153	0.086	0.139				0.114
Particulate Concentration, (lbs/1000 lbs dry @ 50% EA) ⁷	0.141	0.282	0.160	0.258				0.210
Emission Limitation, (lbs/1000 lbs dry @ 50% EA)								0.40
Total Lead Collected, (mg)	1.244	2.496	1.348	0.956				
Lead Emission Rate, (lb/hr)	0.030	0.050	0.038	0.024				0.036

¹ Dry standard cubic feet @ 68 °F, 29.92 inches Hg.

² Actual cubic feet per minute.

³ Dry standard cubic feet per minute.

⁴ Milligrams (filter catch and acetone wash).

⁵ Grains per dry standard cubic feet.

⁶ Grains per dry standard cubic feet 50 percent excess air.

⁷ Pounds per 1000 pounds dry at 50 percent excess air.

TABLE 2-2

SUMMARY OF TOTAL HYDROCARBON EMISSIONS
MATTABASSETT DISTRICT COMMISSION
INCINERATOR EXHAUST
CROMWELL, CONNECTICUT

Run Number	1		2		3		Average
Date	08/27/86	08/27/86	08/27/86	08/27/86	08/27/86		
Time	1019-1122	1219-1321	1431-1536				
Location	Outlet	Outlet	Outlet	Outlet	Outlet	Outlet	Outlet
Volumetric Flowrate, (ACFM) ¹	13100	15300	14500				
Volumetric Flowrate, (DSCFM) ²	8500	7100	9600				
Percent Moisture By Volume	25.3	45.0	23.7				
Average Stack Temperature, (°F)	149	164	144				
THC Measured, (mg/l) ³	0.065	0.096	0.061				
THC Emission Rate, (Pounds/Hour)	2.1	2.6	2.2				2.3

1 Actual cubic feet per minute.

2 Dry standard cubic feet per minute.

3 Total hydrocarbons in milligrams per liter based on n-hexane.

3.0 DISCUSSION OF RESULTS

3.1 Particulate Tests

As previously mentioned the emission measurement tests were conducted while the incinerator and scrubber were operating at varying levels. The operating parameters were varied to determine which condition would meet the particulate compliance level. The following table will show the sludge input ranges versus the corresponding test run:

<u>Test Run</u>	<u>Sludge Input (Wet Ton/Hour)</u>
1	5.5 - 5.9
2	4.7 - 6.6
3	5.0 - 5.1
4	5.6 - 6.2

Originally, three tests were to be performed. However, during Run No. 2 a combination of process upsets with the incinerator and scrubber caused the emissions to increase substantially therefore, a fourth test was run.

The average particulate concentration, excluding Run No. 2, would be 0.19 lbs/1000 lb flue gas @ 50% excess air. As shown in Table 2-1 despite the changes in the operational parameters all four test runs met the compliance limit of 0.40 lbs/1000 lb flue gas @ 50% excess air.

3.2 Total Hydrocarbon Tests

Three total hydrocarbon tests were performed concurrently with the first three particulate tests. Quantitation of the total

hydrocarbons was based on n-hexane. Table 2-2 summarizes the total hydrocarbon emissions. Results ranged from 2.1 to 2.6 pounds per hour with an average emission rate of 2.3 pounds per hour. A fourth test run was not performed due to a shortage in clean gas sampling bags caused by the mishap on Run No. 2.


3.3 Lead Tests

Four lead tests were performed on the exhaust flue gases. As shown in Table 2-1 the emissions seem to be consistent. The average emission rate was 0.036 pounds per hour with a range from 0.024 to 0.050 pounds per hour.

4.0 DESCRIPTION OF SAMPLING LOCATION

The incinerator exhaust stack sampling location was located in a 39 inch ID vertical section of steel stack. Two 3 inch sampling ports were positioned 90 degrees apart in a horizontal plane and were located 288 inches (5.8 duct diameters) downstream from the louver damper and 84 inches (2.1 duct diameters) upstream from the top of the stack.

This sampling location did not meet the "eight and two diameters" criteria of EPA Method 1, so 10 sampling points were used on each of two traverse axes, for a total of 20 sampling points. A schematic diagram of the outlet location along with the traverse point distances is shown in Figure 4-1. Prior to the particulate matter tests, a full 20 point cyclonic flow check was performed.



Traverse Point Number	Traverse Point Location From Stack Wall (Inches)
1	1.0
2	3.2
3	5.7
4	8.8
5	13.3
6	25.6
7	30.2
8	33.3
9	35.8
10	37.9

Figure 4-1
Incinerator Outlet Sampling Location
Mattabassett District
Main Incinerator
Cromwell, Connecticut

5.0 SAMPLING AND ANALYSIS METHODOLOGY

5.1 Particulate Matter Tests

Particulate sampling was accomplished by using the EPA Method 5 collection train described in Title 40, Code of Federal Regulations, Part 60. It is shown schematically in Figure 5-1 and consists of a nozzle, probe, filter, four impingers, vacuum pump, dry gas meter, and an orifice flow meter. Complete sampling train calibrations were performed before and after this compliance test program.

A nozzle (1) was attached to a glass-lined probe (2) which was heated to prevent condensation. Reeve-Angel No. 934AH fiber-glass filter paper supported in a 3 inch glass filter holder (3) was used as the collection media. The filter assembly was enclosed in a heated box (4) to maintain temperatures at 250°F. An ice bath containing four impingers (5) was attached to the back end of the filter. The first two impingers contained distilled water, the third was dry, and the fourth contained silica gel to remove any remaining moisture. Flexible tubing (6), vacuum gauge (7), needle valve (8), leakless vacuum pump (9), bypass valve (10), dry gas meter (11), calibrated orifice and inclined manometer (12) completed the sampling train. The stack velocity pressure was measured using a pitot tube and inclined manometer (13). The stack temperature was monitored by a thermocouple that was attached to the pitot and connected to a potentiometer (14). A check valve was not used in the sampling train.




Figure 5-1
Modified EPA Method 5 Particulate Sampling Train

A nomograph was used to quickly determine the orifice pressure drop required for any pitot velocity pressure and stack temperature in order to maintain isokinetic sampling conditions. Sampling flow was adjusted by means of the bypass valve. Before and after each particulate test run the sampling train was leak checked.

Test data recorded is listed on the field data sheet shown in the Appendix. At the end of each test, three sample containers were used as follows:

Container #1 - Filter

Container #2 - Acetone wash of probe and front half of filter. The probe and nozzle were washed and brushed three times.

Container #3 - Silica gel from the fourth impinger.

The samples were transported to the laboratory and the following analyses performed:

Container #1 - Transferred the filter and any loose particulate matter from the sample container to a tared glass weighing dish, desiccated and dried to a constant weight. Reported results to the nearest 0.1 mg.

Container #2 - Transferred the acetone washings to a tared beaker and evaporated to dryness at ambient temperature and pressure. Desiccated and dried to a constant weight. Reported results to the nearest 0.1 mg.

Container #3 - Weigh silica gel to the nearest 0.5 g. The weight of the moisture entrapped in the silica gel, along with the volume of moisture which was condensed in the impingers, was used to calculate the moisture content to the flue gas.

Prior to testing a preliminary velocity traverse, covering all sampling points, was performed to check for cyclonic flow. The pitot-nulling technique was used to determine if cyclonic flow was present, as detailed in EPA Method 1.


A calculator program was used to calculate mass emission rates in pounds per hour and particulate concentrations in grains per dry standard cubic feet and pounds per 1000 pounds of flue gas at 50% excess air. The program also calculates percent moisture, molecular weight of the stack gas at stack conditions, and the percentage isokinetics.

5.2 Exhaust Gas Analysis

The composition of the gas stream at the sampling location was analyzed for oxygen and carbon dioxide during each test run in accordance with EPA Method 3 as specified in Title 40, CFR, Part 60, Appendix A. To make an accurate assessment of the flue gas composition, redundant Orsat analyses were conducted. During each particulate test run, at least one multipoint integrated sample of flue gas was taken for Orsat analysis. The integrated gas sampling train and grab sampling train used for EPA Method 3 are shown in Figure 5-2.

5.3 Sludge Analysis

The collected sludge samples (as charged to the incinerator) were analyzed for mercury and beryllium. Sludge samples collected for mercury analyses were taken in accordance with EPA Method 105 and subsequently analyzed by EPA Method 7471. The beryllium analyses were performed according to EPA Method 210. 1.



GRAB SAMPLE SETUP FOR MOLECULAR WEIGHT DETERMINATION




Figure 5-2
INTEGRATED SAMPLE SETUP FOR MOLECULAR WEIGHT DETERMINATION

5.4 Total Hydrocarbon Gas Analysis

A modified version of EPA Method 18 was used for the sampling and analysis. The modification consisted of identifying only total hydrocarbons (as n-hexane) instead of the normal specific compound identification usually performed for EPA Method 18. Sampling was performed in the same manner as the Orsat samples. Each gas sampling bag was placed in the rigid container; the air within the rigid container was then slowly evacuated. The resulting vacuum inflated the bag with the sampled flue gas. Figure shows the integrated gas sampling train.

The analysis method for the total hydrocarbon samples was by chromatography with flame ionization detection (GC/FID). GC/FID conditions were set to maximize peak resolution. Three calibrations constituted the range of the three standards.

5.5 Lead Analysis

The particulate collected on the EPA Method 5 filters was analyzed for lead after the gravimetric analysis had been performed. A section from each filter was acid digested and then analyzed by atomic absorption (direct aspiration). The analyses were performed in accordance with Methods for Chemical Analysis of Water and Waters, EPA - 600/4-79-020, March 1979.

Appendix A
Source Test Plan

THE MATTABASSETT DISTRICT
NEW BRITAIN-BERLIN-CROMWELL
REGIONAL SEWER AUTHORITY

GREGORY ABRAHAMIAN
EXECUTIVE DIRECTOR

P.O. BOX 137
CROMWELL, CONNECTICUT 06416
203-635-5550

August 20, 1986

Mr. George T. Miller
Sr. APC Engineer
State of Connecticut
Dept. of Environmental Protection
165 Capitol Avenue
Hartford, CT 06106

Dear Mr. Miller:

This letter is in regards to the test plan for sampling emissions from a Sewage Sludge Incinerator, owned and operated by the Mattabassett District in Cromwell, Connecticut. As required by the State of Connecticut, Department of Environmental Protection, sludge should be analyzed for Mercury and Beryllium. Sludge collected by EPA Method 105 for Mercury will be analyzed using EPA Method 7471. The test protocol for Beryllium will be EPA Method 210.1. Both analyses will be conducted by an independent certified laboratory.

If you have any questions concerning this matter please contact me at (203) 635-5550.

Sincerely,

THE MATTABASSETT DISTRICT

Terri Pelletier

Terri Pelletier
Chemist

TP/lg

cc: Christian Bratina
✓ Mr. John S. Gammie
Rojac Environmental Services, Inc.
P.O. Box 731
West Hartford, CT 06107



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



August 5, 1986

Mr. John S. Gammie
Project Manager
Rojac Environmental Services, Inc.
P.O. Box 731
W. Hartford, CT 06107

Dear Mr. Gammie:

You are hereby notified that "Intent to Test" form #860037, which describes a test plan for sampling emissions from a Sewage Sludge Incinerator that is owned and operated by the Mattabassett District Commission and located in Cromwell, Connecticut, is acceptable, subject to the following conditions, and meets the test criteria required by the State of Connecticut, Department of Environmental Protection.

1. Documented calibration of the sludge weighing device must be available on the day of the test.
2. If an incinerator by-pass stack exists, complete closure must be demonstrated for the duration of the test.
3. Are grit and scum incinerated? At what time interval and how are they fed to the incinerator?
4. Particulate results are requested in pounds/1000 pounds flue gas @ 50% excess air.
5. A sludge analysis for Mercury is required. Please submit a test protocol for E.P.A. method 105.
6. A sludge analysis for Beryllium is required. Please submit a test protocol.
7. Emission testing may be conducted at various operating parameters to determine compliance at various operating levels. Particulates, hydrocarbons and lead shall be sampled at each level.

Phone:

165 Capitol Avenue • Hartford, Connecticut 06106

An Equal Opportunity Employer

The field test will be observed by myself unless you are otherwise notified. I should be informed of progress and problems that may alter the test program. If you have any questions concerning the content or intent of this letter, do not hesitate to contact me at (203) 566-3310. Please complete the enclosed form(s) and include them in your test report.

Very truly yours,

George T. Miller
George T. Miller
Sr. APC Engineer

cc: Mr. Christian Bratina
Mattabassett District Commission
P.O. Box 137
Cromwell, CT 06416

Encl.

GTM/ja

Source Test Plan
Mattabassett District
Pollution Control Plant
Main Incinerator
Cromwell, Connecticut

ROJAC Environmental Services, Inc.

John S. Gammie
Project Manager

ROJAC Project F86-20

July 1986

P.O. Box 731
West Hartford, Connecticut 06107
(203) 527-7307

SOURCE TEST PLAN

Client Name: Mattabassett District
Water Pollution Control Plant
P.O. Box 137
Cromwell, CT 06416
Mr. Christian Bratina
(203) 635-5550

Test Location: Mattabassett District
Water Pollution Control Plant
Cromwell, Connecticut

Testing Organization: ROJAC Environmental Services, Inc.
P. O. Box 731
West Hartford, CT 06107
(203) 527-7303

Individual Preparing Test Plan: John S. Gammie

Source To Be Tested: Main Incinerator

Proposed Test Date: August 1986

TABLE OF CONTENTS

<u>LOCATION</u>	<u>PAGE</u>
1.0 PURPOSE OF TEST.....	1
2.0 SCOPE OF TEST PROGRAM.....	2
2.1 Particulate Tests.....	2
2.2 Exhaust Gas Analysis.....	2
2.3 Hydrocarbon Emission Tests.....	2
2.4 Lead Analysis.....	3
3.0 PROCESS DESCRIPTION.....	4
4.0 DESCRIPTION OF SAMPLING LOCATION.....	6
5.0 SAMPLING AND ANALYSIS METHODOLOGY.....	8
5.1 Particulate Matter Tests.....	8
5.2 Exhaust Gas Analysis.....	11
5.3 Hydrocarbon Gas Analysis.....	11
5.4 Lead Analysis.....	13
6.0 QUALITY ASSURANCE.....	14
6.1 Sampling Quality Assurance.....	14
6.2 Analytical Quality Control.....	15

LIST OF FIGURES

<u>FIGURES</u>	<u>PAGE</u>
4-1 Incinerator Outlet Sampling Location, Mattabassett District-Main Incinerator, Cromwell, Connecticut.....	7
5-1 Modified EPA Method 5 Particulate Sampling Train.....	9
5-2 Integrated Sample Setup For Molecular Weight Determination.....	12

1.0 PURPOSE OF TEST

The purpose of this test program is to determine the particulate, lead, and hydrocarbon emissions from the Mattabassett District main incinerator located in Cromwell, Connecticut. The tests will be carried out in conformance with the State of Connecticut Department of Environmental Protection guidelines for source emission testing. The incinerator at the Mattabassett facility must comply with the following emission limitations:

Particulate Matter - 0.08 grains per dry standard cubic feet corrected to 12% CO₂.

Lead and Hydrocarbons - for informational purposes only.

2.0 SCOPE OF TEST PROGRAM

2.1 Particulate Tests

The particulate emissions from the incinerator outlet stack will be tested in triplicate according to EPA Methods 1-5. Particulate compliance tests will be conducted on the Main Incinerator exhaust stack. The exhaust stack requires sampling at 20 traverse points. A minimum sample volume of thirty five (35) actual cubic feet will be collected during each test. All tests will be conducted while the facility is operating at its designed capacity of 3.75 wet tons/hour.

2.2 Exhaust Gas Analysis

The composition of the gas stream at the sampling location will be determined. Analysis will be conducted for oxygen and carbon dioxide during each test run in accordance with EPA Method 3. During each particulate test run at least one integrated sample of flue gas will be taken for Orsat analysis.

2.3 Hydrocarbon Emission Tests

The hydrocarbon emissions from the incinerator will be tested in triplicate according to a modified version of EPA Method 18. A single point within the incinerator will be sampled for 3 - 60 minute periods using an EPA Method 3 indirect fill gas sampling approach, commonly called "bag-in-the-box". Teflon gas sampling bags will be used. Analysis will be performed by gas chromatography.

2.4 Lead Analysis

Once the gravimetric analysis has been completed, for the EPA Method 5 test results, each filter will be analyzed for lead content. Analysis will be performed by atomic absorption.

3.0 PROCESS DESCRIPTION

The sewage sludge incinerator at this facility is of Bartlett-Snow Pacific design. Auxiliary fire is provided by natural gas. The designed maximum firing rate is approximately 2700 cubic feet per hour. Twenty-five percent excess air is provided for the fuel combustion. Approximately fifty percent excess air is provided for the sludge incineration. The maximum furnace temperature is 1800°F.

The ash exits at a temperature of approximately 400°F and is removed to an ash pond.

The exhaust gases pass through a wet cyclonic scrubber before exhausting out of the stack. The exit temperature of the exhaust gases during normal operating conditions is approximately 140°F. Volumetric flowrate is approximately 500,000 standard cubic feet per hour.

The operating capacity of sewage sludge to the incinerator is approximately 3 to 6 wet tons per hour. Fluctuations in the feed rate depend on the operation of the belt filter and are functions of the particular characteristics of the sludge being charged. This plant normally operates with a sludge input of approximately 3.75 wet tons per hour. Sludge is fed to the incinerator by a screw conveyor. The incinerator is stoked by rabble arms with overfire air. The incinerator utilizes six burners.

Sludge input weights will be measured using calibrated


scales. Weights will be taken and recorded before, during, and after each particulate test run.

During the course of each particulate test run grab samples of sludge, charged to the incinerator, will be collected to determine the dry sludge content. Three sludge samples will be collected for total solids residue determination.

4.0 DESCRIPTION OF SAMPLING LOCATION

The incinerator exhaust stack sampling location is located in a 39 inch ID vertical section of steel stack. Two 3 inch sampling ports are positioned 90 degrees apart in a horizontal plane and are located approximately 228 inches (5.8 duct diameters) downstream from the louver damper and approximately 84 inches (2.1 duct diameters) upstream from the top of the stack.

This sampling location did not meet the "eight and two diameters" criteria of EPA Method 1, so 10 sampling points will be used on each of two traverse axes, for a total of 20 sampling points. A schematic diagram of the outlet location along with the traverse point distances is shown in Figure 4-1. Prior to the particulate matter tests, a full 20 point cyclonic flow check will be performed.



Traverse Point Number	Traverse Point Location From Stack Wall (inches)
1	1.0
2	3.2
3	5.7
4	8.8
5	13.3
6	25.6
7	30.2
8	33.3
9	35.8
10	37.9

Figure 4-1
Incinerator Outlet Sampling Location
Mattabassett District
Main Incinerator
Cromwell, Connecticut

5.0 SAMPLING AND ANALYSIS METHODOLOGY

5.1 Particulate Matter Tests

Particulate sampling will be accomplished by using the EPA Method 5 collection train described in Title 40, Code of Federal Regulations, Part 60. It is shown schematically in Figure 5-1 and consists of a nozzle, probe, filter, four impingers, vacuum pump, dry gas meter, and an orifice flow meter. Complete sampling train calibrations are performed before and after every compliance test program.

A nozzle (1) is attached to a stainless steel or glass-lined probe (2) which is heated to prevent condensation. Reeve-Angel No. 934AH fiberglass filter paper supported in a 2-1/2 inch glass filter holder (3) is used as the collection media. The filter assembly is enclosed in a heated box (4) to maintain temperatures at 250°F. An ice bath containing four impingers (5) is attached to the back end of the filter. The first two impingers contain distilled water, the third is dry, and the fourth contains silica gel to remove any remaining moisture. Flexible tubing (6), vacuum gauge (7), needle valve (8), leakless vacuum pump (9), bypass valve (10), dry gas meter (11), calibrated orifice and inclined manometer (12) complete the sampling train. The stack velocity pressure is measured using a pitot tube and inclined manometer (13). The stack temperature is monitored by a thermocouple that is attached to the pitot and connected to a potentiometer (14). A check valve is not used in the sampling train.




Figure 5-1
Modified EPA Method 5 Particulate Sampling Train

A nomograph is used to quickly determine the orifice pressure drop required for any pitot velocity pressure and stack temperature in order to maintain isokinetic sampling conditions. Sampling flow is adjusted by means of the bypass valve. Before and after each particulate test run the sampling train is leak checked.

Test data to be recorded is listed on the field data sheet shown in the Appendix. At the end of each test, three sample containers will be used as follows:

Container #1 - Filter

Container #2 - Acetone wash of probe and front half of filter. The probe and nozzle are washed and brushed three times.

Container #3 - Silica gel from the fourth impinger.

The samples will be transported to the laboratory and the following analyses performed:

Container #1 - Transfer the filter and any loose particulate matter from the sample container to a tared glass weighing dish, desiccate and dry to a constant weight. Report results to the nearest 0.1 mg.

Container #2 - Transfer the acetone washings to a tared beaker and evaporated to dryness at ambient temperature and pressure. Desiccate and dry to a constant weight. Report results to the nearest 0.1 mg.

Container #3 - Weight silica gel to the nearest 0.5 mg. The weight of the moisture entrapped in the silica gel, along with the volume of moisture which is condensed in the impingers, is used to calculate the moisture content to the flue gas.

Prior to testing a preliminary velocity traverse, covering all sampling points, will be performed to check for cyclonic flow. The pitot-nulling technique will be used to determine if cyclonic flow is present, as detailed in EPA Method 1.


A calculator program is used to calculate mass emission rates in pounds per hour and particulate concentration in grains per dry standard cubic feet. The program also calculates percent moisture, molecular weight of the stack gas at stack conditions, and the percentage isokinetics.

5.2 Exhaust Gas Analysis

The composition of the gas stream at the sampling location will be analyzed for oxygen and carbon dioxide during each test run in accordance with EPA Method 3 as specified in Title 40, CFR, Part 60, Appendix A. To make an accurate assessment of the flue gas composition, redundant Orsat analyses will be conducted. During each particulate test run, at least one multipoint integrated sample of flue gas will be taken for Orsat analysis. The integrated gas sampling train and grab sampling train used for EPA Method 3 are shown in Figure 5-2.

5.3 Hydrocarbon Gas Analysis

A modified version of EPA Method 18 will be used for this sampling program. The modification will consist of identifying only total hydrocarbons instead of the normal specific compound identification usually performed for EPA Method 18. Sampling will be performed in the same manner as the Orsat samples. Each bag will be placed in the rigid container and slowly evacuating the



GRAB SAMPLE SETUP FOR MOLECULAR WEIGHT DETERMINATION




Figure 5-2
INTEGRATED SAMPLE SETUP FOR MOLECULAR WEIGHT DETERMINATION

air within the container. The resulting vacuum will inflate the bag with the sampled gas. Figure 5-2 shows the integrated gas sampling train.

The analysis method for total hydrocarbons will be gas chromatography with flame ionization detection (GC/FID). GC conditions will be set to maximize peak resolution. Three calibration standards will be prepared which will "box-in" the expected stack gas concentrations. High, low, and middle concentrations will constitute the range of the three standards.

5.4 Lead Analysis

The particulate collected on the EPA Method 5 filters will be analyzed for lead after the gravimetric analysis has been performed. A section from each filter will be acid digested and then analyzed by atomic absorption (direct aspiration). The analyses will be performed in accordance with Methods for Chemical Analysis of Water and Waters, EPA - 600/4-79-020, March 1979.

6.0 QUALITY ASSURANCE

The project manager will be responsible for implementation of the quality assurance program as applied to this project.

6.1 Sampling Quality Assurance

Generally, our implementation of quality assurance procedures for source measurement programs is designed so that the work is done:

1. by competent, trained individuals experienced in the specific methodologies being used;
2. using properly calibrated equipment; and
3. using approved procedures for sample handling and documentation.

ROJAC's measurement devices, pitot tubes, dry gas meters, thermocouples, and portable gas analyzers are uniquely identified and calibrated with documented procedures and acceptance criteria before and after each field effort. Records of all calibration data are maintained in ROJAC files.

Data are recorded on standard forms. Bound field notebooks are used to record observations and miscellaneous elements affecting data, calculations, or evaluation. Chain of custody forms are used to keep track of samples, all of which are uniquely identified. A sample chain of custody form is included in the Appendix.

Prior to each test, ROJAC will provide the official compliance test observer with the following:

1. Filter numbers and tare weights of all filters available for the test.

2. The results of a solvent blank run of the solvent to be used during the test.
3. Calibrations of all pitot tubes, dry gas meters, orifice meters, sampling nozzles, and thermocouples which will be used during the test. All calibrations will be performed within 4 months prior to the test date.

Specific details of ROJAC's QA program for stationary air pollution sources may be found in Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III (EPA-600/4-7027b).

6.2 Analytical Quality Control

Laboratory analysis of collected field samples is provided by Henry Souther Laboratories, Bloomfield, Connecticut. Henry Souther Laboratories, an accredited State of Connecticut laboratories, maintains a vigorous quality assurance program for all samples analyzed in the laboratory. This program is based on the general guidelines given in Handbook for Analytical Quality Control in Water and Wastewater Laboratories. (EPA 600/4-79-019; March 1979). This program suggests guidelines in the areas of:

- *Laboratory services
- *Instrument selection
- *Glassware
- *Reagents
- *Solvents
- *Gases
- *Analytical performance
- *Data handling and reporting
- *Laboratory safety

In addition, Henry Souther Laboratories routinely receives and analyzes quality control samples from the Federal EPA and/or State Department of Health (Connecticut). Results of these audits are available. This ROJAC/Henry Souther Laboratories implemented quality assurance program thus provided for the confident sampling

and analysis of all sources. Samples of all field data sheets, calibration forms, and chain of custody forms are contained in the appendix of this report.

I SOURCE INFORMATION

Name Mt. Agassiz District
 No. 1st. P.O. Box 137
 City Cromwell, CT 06416

III. IDENTIFY EQUIPMENT AND STACK TO BE TESTED

CONN. REGISTRATION OR PERMIT NO. 043-0012-0032-01

IV. Gas Stream Sampling Information. Identify all gas stream components to be sampled.

Component	Sampling Duration minutes per point	total test time	Number of tests (Minimum of 3)	Expected Concentrations	Brief description of the test method to be used for each pollutant
1. Particulate	3	60	3	< 0.08 grains / 100 ft ³ of air	EPA Methods 1-5
2. Lead		60	3	To be determined	EPA method 5 filter analyzed by AA
3. Hydrocarbons		60	3	To be determined	Modified EPA method 18
4.					
5.					

V. Stack Information:

- Approx. gas temp. 140 of _____
- Approx. gas flow 10,000 A.C.F.M.
- Approx. percent moisture 17 %
(percent by volume)

VI. Is equipment or process to be tested: 1. Presently under State Order? Yes X No _____
 2. Been issued a Notice of Violation? Yes X No _____ Notice No. _____

3. applying for a permit to construct _____? operate _____? 4. testing to comply with 100 ton source test reg? Yes _____ No _____

5. testing to prove compliance Yes X No _____ 6. other (specify) _____

VII. Identification of documents requested on attached sheets

VIII _____ X _____ XII _____ XIV _____
 IX _____ XI _____ XIII _____

II TESTER INFORMATION

Name RQJAC Environmental Person or Persons
 Responsible for Tests
 Address P.O. Box 731 Name John Gammie
 Telephone WH, CT 06107 Telephone 527-7307
 Signature _____
 Person Responsible for Tests
 Date _____

Proposed Test Date August 1986

Appendix B
Test Data Summaries

Process Information: SEWAGE SLUDGE INCINERATORS

I. Results

1. Particulates (lb/1000 lb) $\pm 50\%$ E.A.
(gr/SCF @ 12% CO₂)

TEST NUMBER			
1	2	3	4
<u>0.141</u>	<u>0.282</u>	<u>0.160</u>	Avg. <u>.210</u> <u>.22</u>
<u>.0916</u>	<u>.1768</u>	<u>.147</u>	Avg. <u>.1368</u> <u>.16</u>
		<u>0.0923</u>	

II. Description

1. Maximum Feed Rate (lb/hr)

3750

2. Normal Feed Rate

2500

3. Method of Feeding

Screw Conveyor

4. Method of Stoking

Rabble Arms

5. Fuel:

maximum firing rate (gal/hr, CFH)

2700

type - ultimate and proximate analysis

Natural Gas as Fuel

$$\frac{.04 \times 12\%}{5.2\%}$$

6. Dampers:

method of activation

Lower Induced Air
Fan Discharge

III. Operating Parameters During Test

1. Actual Burner Firing Rate (gal/hr, CFH)

1.7 EG

2. Material Incinerated:

% moisture

70

feed rate (lb/hr)

5000

incineration outlet temperature (s) (°F)

700-900

IV. Normal Operating Times

1. Hrs/Day

24/7

2. Days/Week

5

3. Weeks/Month

4

4. Shut Down Period
(If Applicable)

4 wks/yr

ANY ADDITIONAL INFORMATION AVAILABLE:

THIS FORM MUST BE COMPLETED AND INCLUDED IN FINAL REPORT.

I.T.T. # 860037

Test Report Data Form #1-7

I. Test Data
(Particulate - E.P.A. Method 5)

TEST NUMBER

1 2 3 4

1. Volume Water Collected (ML):				
impingers	<u>315</u>	<u>805</u>	<u>295</u>	<u>420</u>
silica gel	<u>18.3</u>	<u>15.6</u>	<u>3.7</u>	<u>14.6</u>
2. Meter Volume (Actual Cubic Feet)	<u>49.05</u>	<u>50.35</u>	<u>48.42</u>	<u>51.10</u>
3. Avg. Meter Temperature (°F)	<u>101</u>	<u>107</u>	<u>108</u>	<u>104</u>
4. Stack Pressure - Absolute (IN. HG)	<u>-0.0118</u>	<u>-0.0118</u>	<u>-0.0110</u>	<u>-0.010</u>
5. Avg. Orifice Press. Drop (IN. H ₂ O)	<u>2.26</u>	<u>2.40</u>	<u>2.09</u>	<u>2.44</u>
6. Pitot Coefficient	<u>.84</u>	<u>.84</u>	<u>.84</u>	<u>.84</u>
7. Stack Area (Ft ²)	<u>8.3</u>	<u>8.3</u>	<u>8.3</u>	<u>8.3</u>
8. Nozzle Diameter (IN.)	<u>.362</u>	<u>.362</u>	<u>.362</u>	<u>.362</u>
9. Avg. Stack Temp. (°F)	<u>149</u>	<u>164</u>	<u>144</u>	<u>152</u>
10. Atmospheric Press. (IN. HG)	<u>29.78</u>	<u>29.78</u>	<u>29.78</u>	<u>29.78</u>
11. Total Test Time (Min.)	<u>60</u>	<u>60</u>	<u>60</u>	<u>60</u>
12. Heat Input (MBTU/HR)	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
13. Total Particulate Collected (MG)	<u>151.3</u>	<u>359.4</u>	<u>141.6</u>	<u>286.4</u>
15. Avg. Velocity Press. Drop (IN. H ₂ O)	<u>.4193</u>	<u>.4633</u>	<u>.4643</u>	<u>.4707</u>
II. ORSAT Analysis:				
per cent CO ₂	<u>6.6</u>	<u>8.0</u>	<u>5.2</u>	<u>6.6</u>
per cent O ₂	<u>12.1</u>	<u>10.5</u>	<u>14.6</u>	<u>12.2</u>
per cent CO	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
III. Moisture Content (Per Cent H ₂ O)	<u>25.3</u>	<u>45.0</u>	<u>23.7</u>	<u>29.8</u>

I.T.T. # 860037

Test Report Data Form #2-5

Control Equipment Information: SCRUBBER

I. Description

1. Scrubber Type
(e.g. cyclone, orifice, mechanical,
venturi, packed tower)

Cyclonic

2. Maximum Gas Volume Capacity (CFM)

28,000

3. Scrubber Diameter (Ft)

7.6

4. Manufacturer

Airtron

5. Model Number

N/A

II. Operating Parameters

1. Inlet Gas Temperature (°F)

250

2. Outlet Gas Temperature (°F)

150

3. Gas Pressure Drop Across Unit
(In. H₂O)

3 1/2"

4. Outlet Gas Flow Rate (CFM)

28,000

5. Fan Horsepower

40

6. Liquid Flow Rate (GPM)

80

7. Injection Pressure (PSI)

120

III. For Packed Tower Scrubbers:

1. Type of Packing

NA

2. Packing Depth (Ft)

NA

3. Per Cent Free Volume of Packing

NA

4. Packing Surface Area (Ft²)

NA

ANY ADDITIONAL INFORMATION AVAILABLE:

PARTICULATE TEST DATA SUMMARY

TEST RUN 2
 LOCATION Innervator Outlet
 FIRM Mattabamett W.W.T.P.

TIME 1219-1321
 DATE 8-22-86
 PROJECT NO. FB6-20

INPUTS

PBAR BAROMETRIC PRESSURE, (in. Hg)
 AS STACK AREA, (ft²)
 DN NOZZLE DIAMETER, (in.)
 TIME TOT TOTAL SAMPLING TIME, (min.)
 Y CALIBRATION FACTOR
 CP PITOT COEFFICIENT
 DELTA P1/2 AVG. SQ. RT. VELOCITY HEAD, (in. H₂O)
 DELTA H AVG. ORIFICE PRESSURE DROP (in. H₂O)
 TH AVERAGE METER TEMPERATURE (°F)
 P STK AVERAGE STACK PRESSURE, (in. H₂O)
 T STK AVERAGE STACK TEMPERATURE, (°F)
 VM ACTUAL METER VOLUME, (ft³)
 VI TOTAL H₂O VAPOR COLLECTED, (ml)
 CO₂ Z CO₂ IN STACK GAS, (DRY)
 O₂ Z O₂ IN STACK GAS, (DRY)
 CO Z CO IN STACK GAS, (DRY)
 N₂ Z N₂ IN STACK GAS, (DRY)
 MN TOTAL PARTICULATE CATCH, (mg)
 HF Z HYDROGEN IN FUEL
 CF Z CARBON IN FUEL
 SF Z SULFUR IN FUEL
 NF Z NITROGEN IN FUEL
 OF Z OXYGEN IN FUEL
 GCV GROSS CALIFORIC VOLUME, (BTU/lb)

OUTPUTS

VM STD
 H₂O
 NS
 EA
 VS
 Q
 QSTD
 I
 C
 CS
 ER
 CS12CO₂
 FD
 E

29.78
 8.3
 1.362
 60
 1.0025
 .84
 46.33
 2.40
 107
 -0.16
 164
 50.35
 820.6
 80
 105
 0
 81.5
 351.4
 NA
 ↓
 ↓
 ↓
 ↓
 ↓

METER VOLUME STANDARD CONDITIONS (ft³)
 PERCENT MOISTURE IN STACK GAS
 MOLECULAR WEIGHT OF STACK GAS (WET)
 PERCENT OF EXCESS AIR
 AVERAGE VELOCITY OF STACK GAS, (FPM)
 ACTUAL STACK GAS FLOWRATE, (ACFM)
 STACK GAS FLOWRATE AT STP, (DSCFM)
 Z ISOKINETIC, (NOZZLE VEL./STACK/VEL.)
 ACTUAL PARTICULATE CONC., (GRAINS/ACF)
 PARTICULATE CONCENTRATION, (GR/DSCF)
 PARTICULATE EMISSION RATE, (lb/hr)
 PARTICULATE CONCENTRATION, (GR/DSCF @ 12% CO₂)
 F FACTOR, (DSCF/MMBTU)
 PARTICULATE EMISSIONS, (lb/MMBTU)
 Particulate Concentration,
 (lb/1000 lbs dry @ 50 EA)
 47.06
 45.0
 24.4
 95.3
 1849.2
 15348.8
 7096.8
 128.4
 .05
 .1178
 7.16
 .1768
 NA
 NA
 0.282

PARTICULATE TEST DATA SUMMARY

TEST RUN 3
 LOCATION Innervator Outlet
 FIRM Mattalmet W.W.T.P.

TIME 1431-1536
 DATE 8-27-86
 PROJECT NO. F86-20

INPUTS

PBAR BAROMETRIC PRESSURE, (in. Hg)
 AS STACK AREA, (ft²)
 DN NOZZLE DIAMETER, (in.)
 TIME TOT TOTAL SAMPLING TIME, (min.)
 Y CALIBRATION FACTOR
 CP PITOT COEFFICIENT
 DELTA P1/2 AVG. SQ. RT. VELOCITY HEAD, (in. H₂O)
 DELTA H AVG. ORIFICE PRESSURE DROP (in. H₂O)
 TH AVERAGE METER TEMPERATURE (°F)
 P STK AVERAGE STACK PRESSURE, (in. H₂O)
 T STK AVERAGE STACK TEMPERATURE, (°F)
 VH ACTUAL METER VOLUME, (ft³)
 VI TOTAL H₂O VAPOR COLLECTED, (ml)
 CO₂ % CO₂ IN STACK GAS, (DRY)
 O₂ % O₂ IN STACK GAS, (DRY)
 CO % CO IN STACK GAS, (DRY)
 N₂ % N₂ IN STACK GAS, (DRY)
 MN TOTAL PARTICULATE CATCH, (mg)
 HF % HYDROGEN IN FUEL
 CF % CARBON IN FUEL
 SF % SULFUR IN FUEL
 NF % NITROGEN IN FUEL
 OF % OXYGEN IN FUEL
 GCV GROSS CALIFORIC VOLUME, (BTU/lb)

OUTPUTS

VH STD
 H₂O
 NS
 EA
 VS
 Q
 QSTD
 I
 C
 CS
 ER
 CS12CO₂
 FD
 E

METER VOLUME STANDARD CONDITIONS (ft³)
 PERCENT MOISTURE IN STACK GAS
 MOLECULAR WEIGHT OF STACK GAS (WET)
 PERCENT OF EXCESS AIR
 AVERAGE VELOCITY OF STACK GAS, (FPM)
 ACTUAL STACK GAS FLOWRATE, (ACFM)
 STACK GAS FLOWRATE AT STP, (DSCFM)
 Z ISOINETIC, (NOZZLE VEL./STACK/VEL.)
 ACTUAL PARTICULATE CONC., (GRAINS/ACF)
 PARTICULATE CONCENTRATION, (GR/DSCF)
 PARTICULATE EMISSION RATE, (lb/hr)
 PARTICULATE CONCENTRATION, (GR/DSCF @ 12% CO₂)
 F FACTOR, (DSCF/MMBTU)
 PARTICULATE EMISSIONS, (lbs/MMBTU)

Particulate Concentration,
 (lbs/1000 lbs dry @ 50% EA)

PARTICULATE TEST DATA SUMMARY

TEST RUN 4
 LOCATION Inventor Outlet
 FIRM Metalabest w.v.T.P.

TIME 1725-1829
 DATE 8-27-86
 PROJECT NO. ESB-20

INPUTS

PBAR BAROMETRIC PRESSURE, (in. Hg)
 AS STACK AREA, (ft²)
 DN NOZZLE DIAMETER, (in.)
 TIME TOT TOTAL SAMPLING TIME, (min.)
 Y CALIBRATION FACTOR
 CP PITOT COEFFICIENT
 DELTA P1/2 AVG. SQ. RT. VELOCITY HEAD, (in. H₂O)
 DELTA H AVG. ORIFICE PRESSURE DROP (in. H₂O)
 TH AVERAGE METER TEMPERATURE (°F)
 P STK AVERAGE STACK PRESSURE, (in. H₂O)
 T STK AVERAGE STACK TEMPERATURE, (°F)
 VH ACTUAL METER VOLUME, (ft³)
 VI TOTAL H₂O VAPOR COLLECTED, (ml)
 CO₂ % CO₂ IN STACK GAS, (DRY)
 O₂ % O₂ IN STACK GAS, (DRY)
 CO % CO IN STACK GAS, (DRY)
 N₂ % N₂ IN STACK GAS, (DRY)
 MN TOTAL PARTICULATE CATCH, (mg)
 HF % HYDROGEN IN FUEL
 CF % CARBON IN FUEL
 SF % SULFUR IN FUEL
 NF % NITROGEN IN FUEL
 OF % OXYGEN IN FUEL
 GCV GROSS CALORIFIC VOLUME, (BTU/lb)

29.78
 8.3
 36.2
 60
 1.0035
 .84
 .4707
 2.44
 104
 -0.14
 15.2
 51.10
 434.6
 6.6
 12.2
 0
 81.2
 286.4
 NA
 /
 /
 /
 /
 /

OUTPUTS

VH STD
 H₂O
 NS
 EA
 VS
 Q
 QSTD
 I
 C
 CS
 ER
 CS12CO₂
 FD
 E

METER VOLUME STANDARD CONDITIONS (ft³)
 PERCENT MOISTURE IN STACK GAS
 MOLECULAR WEIGHT OF STACK GAS (NET)
 PERCENT OF EXCESS AIR
 AVERAGE VELOCITY OF STACK GAS, (FPM)
 ACTUAL STACK GAS FLOWRATE, (ACFM)
 STACK GAS FLOWRATE AT STP, (DSCFM)
 % ISOINETIC, (NOZZLE VEL./STACK VEL.)
 ACTUAL PARTICULATE CONC., (GRAINS/ACF)
 PARTICULATE CONCENTRATION, (GR/DSCF)
 PARTICULATE EMISSION RATE, (lb/hr)
 PARTICULATE CONCENTRATION, (GR/DSCF @ 12% CO₂)
 F FACTOR, (DSCF/MBTU)
 PARTICULATE EMISSIONS, (lb_s/MMBTU)

418.02
 29.87
 26.1
 132.0
 1800.0
 14440
 8943.9
 163.3
 .05
 .09
 7.09
 .1673
 NA
 NA
 0.258
 Particulate Concentration,
 (lb_s/1000 lb_s dry @ 50% EA)

PARTICULATE TEST DATA SUMMARY

TEST RUN 2 - Lead
 LOCATION Incinerator Outlet
 FIRM Mathabasset

TIME 619-1321
 DATE 8/27/86
 PROJECT NO. F86-20

INPUTS

PBAR BAROMETRIC PRESSURE, (in. Hg)
 AS STACK AREA, (F²)
 DN NOZZLE DIAMETER, (in.)
 TIME TOT TOTAL SAMPLING TIME, (min.)
 Y CALIBRATION FACTOR
 CP PITOT COEFFICIENT
 DELTA P1/2 AVG. SQ. RT. VELOCITY HEAD, (in. H₂O)
 DELTA H AVG. ORIFICE PRESSURE DROP (in. H₂O)
 TH AVERAGE METER TEMPERATURE (°F)
 P STK AVERAGE STACK PRESSURE, (in. H₂O)
 T STK AVERAGE STACK TEMPERATURE, (°F)
 VM ACTUAL METER VOLUME, (F³)
 VI TOTAL H₂O VAPOR COLLECTED, (ml)
 CO₂ % CO₂ IN STACK GAS, (DRY)
 O₂ % O₂ IN STACK GAS, (DRY)
 CO % CO IN STACK GAS, (DRY)
 N₂ % N₂ IN STACK GAS, (DRY)
 MN TOTAL PARTICULATE CATCH, (mg)
 HF % HYDROGEN IN FUEL
 CF % CARBON IN FUEL
 SF % SULFUR IN FUEL
 NF % NITROGEN IN FUEL
 OF % OXYGEN IN FUEL
 GCV GROSS CALORIFIC VOLUME, (BTU/lb)

OUTPUTS

VM STD
 H₂O
 MS
 EA
 VS
 Q
 QSTD
 I
 C
 CS
 ER
 CS/2CO₂
 FO
 E

METER VOLUME STANDARD CONDITIONS (F³)
 PERCENT MOISTURE IN STACK GAS
 MOLECULAR WEIGHT OF STACK GAS (NET)
 PERCENT OF EXCESS AIR
 AVERAGE VELOCITY OF STACK GAS, (FPM)
 ACTUAL STACK GAS FLOWRATE, (ACFM)
 STACK GAS FLOWRATE AT STP, (DSCFH)
 % ISOINETIC, (NOZZLE VEL./STACK VEL.)
 ACTUAL PARTICULATE CONC., (GRAINS/ACF)
 PARTICULATE CONCENTRATION, (GR/DSCF)
 PARTICULATE EMISSION RATE, (lb/hr)
 PARTICULATE CONCENTRATION, (GR/DSCF @ 12% CO₂)
 F FACTOR, (DSCF/MMBTU)
 PARTICULATE EMISSIONS, (lb/MMBTU)

29.78
 8.3
 0.362
 60
 1.0025
 0.84
 0.9633
 2.40
 107
 -0.10
 164
 50.35
 820.6
 8.0
 10.5
 0
 81.5
 2.976
 NA
)
)

47.06
 45.07
 24.42
 95.31
 1649.2
 15348
 7096.8
 128.4
 .0003
 .0003
 .0447
 .0012
 NA
 NA

PARTICULATE TEST DATA SUMMARY

TEST RUN 3-Lead
 LOCATION Incinerator Outlet
 FIRM Mathabessett

TIME 1431-1536
 DATE 2/27/86
 PROJECT NO. F86-20

INPUTS

PBAR BAROMETRIC PRESSURE, (in. Hg)
 AS STACK AREA, (F²)
 DN NOZZLE DIAMETER, (in.)
 TIME TOT TOTAL SAMPLING TIME, (min.)
 Y CALIBRATION FACTOR
 CP PITOT COEFFICIENT
 DELTA P1/2 AVG. SQ. RT. VELOCITY HEAD, (in. H₂O)
 DELTA H AVG. ORIFICE PRESSURE DROP (in. H₂O)
 TM AVERAGE METER TEMPERATURE (°F)
 P STK AVERAGE STACK PRESSURE, (in. H₂O)
 T STK AVERAGE STACK TEMPERATURE, (°F)
 VH ACTUAL METER VOLUME, (F³)
 VI TOTAL H₂O VAPOR COLLECTED, (ml)
 CO₂ Z CO₂ IN STACK GAS, (DRY)
 O₂ Z O₂ IN STACK GAS, (DRY)
 CO Z CO IN STACK GAS, (DRY)
 H₂ Z H₂ IN STACK GAS, (DRY)
 MN TOTAL PARTICULATE CATCH, (mg)
 HF Z HYDROGEN IN FUEL
 CF Z CARBON IN FUEL
 SF Z SULFUR IN FUEL
 NF Z NITROGEN IN FUEL
 OF Z OXYGEN IN FUEL
 GCV GROSS CALIFORIC VOLUME, (BTU/lb)

OUTPUTS

VH STD
 H₂O
 NS
 EA
 VS
 Q
 QSTD
 I
 C
 CS
 ER
 CS12CO₂
 FD
 E

METER VOLUME STANDARD CONDITIONS (F³)
 PERCENT MOISTURE IN STACK GAS
 MOLECULAR WEIGHT OF STACK GAS (NET)
 PERCENT OF EXCESS AIR
 AVERAGE VELOCITY OF STACK GAS, (FPM)
 ACTUAL STACK GAS FLOWRATE, (ACFM)
 STACK GAS FLOWRATE AT STP, (DSCFM)
 Z ISOINETIC, (NOZZLE VEL./STACK VEL.)
 ACTUAL PARTICULATE CONC., (GRAINS/ACF)
 PARTICULATE CONCENTRATION, (GR/DSCF)
 PARTICULATE EMISSION RATE, (lb/hr)
 PARTICULATE CONCENTRATION, (GR/DSCF @ 12% CO₂)
 F FACTOR, (DSCF/NBTV)
 PARTICULATE EMISSIONS, (lbs/NBTV)

29.78
8.3
0.362
60
1.0025
0.84
0.9692
2.09
108
-0.15
144
48.42
298.7
5.2
14.6
0
80.2
1.348
NA


Appendix C
Laboratory Analysis Data

ROJAC Environmental Services, Inc.

P.O. Box 731
West Hartford, Connecticut 06107
(203) 527-7307

SUBMITTAL FOR LABORATORY ANALYSES

TO: HENRY SOUTHER LANDS

FROM: ROJAC Environmental Services, Inc.

Date: 8-28-86

Project No.: FEB-20

<u>Sample Type</u>	<u>Sample ID</u>	<u>Analysis</u>
Filter 1	S1x	Weighing method 5
" 2	S2x	
" 3	S3x	
" 4	S6x	
Probe & Nozzle Rinse	PW-1	
" " "	PW-2	
" " "	PW-3	
" " "	PW-4	

Thank You,

JOHN S. Gammie
Print Name

ROJAC Environmental
Services, Inc.

P.O. Box 731
West Hartford, Connecticut 06107
(203) 527-7307

SUBMITTAL FOR LABORATORY ANALYSES

TO: THE HARTFORD LAB

FROM: ROJAC Environmental Services, Inc.

Date: 8-27-86

Project No.: F86-20

<u>Sample Type</u>	<u>Sample ID</u>	<u>Analysis</u>
TEOLAR BAGS	Run 1 THG-1	TOTAL HYDRO
" "	Run 2 THG-2	CARBONS
" "	Run 3 THG-3	" "
		" "

Thank You,

JOHN S. Gammie
Print Name

ROJAC Environmental
Services, Inc.

P.O. Box 731
West Hartford, Connecticut 06107
(203) 527-7307

SUBMITTAL FOR LABORATORY ANALYSES

TO: THE HARTFORD

FROM: ROJAC Environmental Services, Inc.

Date: 9/4/86

Project No.: FA6-20

Sample Type

Sample ID

Analysis

Filter

S1x

S2x

S3x

67x

Lead Analysis

Thank You,

JOHN S. GRAMMIE
Print Name

ACCOUNT *ROJAC*

LABORATORY R# 6525

ANALYST P. G. Murray

ANALYTICAL METHOD Gas Chromatography

DATE REPORTED 9-3-86

Total Hydrocarbons

SAMPLE I.D.

2/6/2

[illegible]

NOTES: Quantitation is based on *n*-hexane.

THE MATTABASSETT DISTRICT


METER CALIBRATION

Meter Sludge Weigh Scale Date 8-19-86 Personnel Grant Bergeron
 Flume Width N/A Hb N/A Pat DeStefano

Minutes	Time	Totalizer Reading	Chart Reading	Flume Depth	Distance to water	Depth of Flow	Calculated Flow
0		989042					
5							
10							
15							
20							
25							
30		989350					
	Diff.	Diff.	Avg.				Avg.
	30	308					317.5

	<u>Average Flow</u>	<u>% Error</u>
Calculated Flow	<u>6.35 T/hr</u>	
Totalizer Flow	<u>6.16 T/hr</u>	<u>- 3.6%</u>
Chart Flow		
Submergence (Hb/Ha)		

- 1) Measure the Flume width at the waist.
- 2) Measure the Flume Depth from top to bottom.
- 3) At Minute 0, note the Time, Totalizer Reading, Chart Reading, and Distance to water. Repeat every five minutes.
- 4) Find the Difference between the start and finish Time and Totalizer Reading.
- 5) To find the Depth of Flow, subtract the Distance to water from the Flume Depth.
- 6) Using the Parshall Flume tables, find the Calculated Flows.
- 7) Find the Totalizer Flow by dividing the Totalizer Reading Difference by the Time Difference.
- 8) Find the % Error by subtracting the Calculated Flow, and dividing by the Calculated Flow. Note whether + or -.
- 9) Divide H_b by the Depth of Flow (H_a) to find the Submergence.



Openly water level

INCINERATOR DAILY RECORD

Date 8-27-86

	HEARTH							SCALE	TONS PER HOUR	B	List any and all changes or adjustments on the Incinerator.
	#1	#2	#3	#4	#5	#6	#7				
2 MID	700	740	1370	1720	480	280	150	6935	3.15	-	
1 AM	640	790	1220	1660	430			7650	4.00	-	Belt FLI T: 26 B: 38
2	720	870	1310	1740	460	270		8120	4.70	-	Polymer 96
3	720	880	1350	1750	490			8570	4.50	-	Lbs/DT= 8.2
4	710	870	1330	1750	520	270	180	9080	5.10	-	Density= 32.5
5	700	820	1220	1520	510			7580	5.00	-	Wet Tons= 36.05
6	700	820	1120	1360	470	510		0070	4.90	5	Dry Tons= 11.7
7	750	880	1280	1520	720			0540	4.70	-	Inc Gas= 4
8	735	880	1415	1820	530	300	115	1000	4.60	-	Belt FLI
9	690	810	1115	1595	630			1430	4.30	5	T: 22 B: 36
10	660	785	1190	1490	750	215		1070	5.45	5	Polymer 96
11	680	804	1005	1260	775			2565	5.90	5	Lbs/DT= 7.3
NOON	650	800	1070	1220	710	480	210	3270	6.55	5	Density= 31.6
1	710	820	1080	1190	1270			3690	4.70	5	Wet Tons= 41.6
2	820	920	1380	1635	920	560		4190	5.00	-	Dry Tons= 13.1
3	820	960	1325	1515	625			4700	5.10	-	Inc Gas= 11
4	800	880	1200	1300	520	340	180	5270	5.75	5	Belt FLI
5	800	820	1020	1230	1590			5835	5.60	5	T: 26 B: 32
6	700	800	1350	1580	1600	1240		6450	6.15	-	Polymer 96
7	700	810	1100	1480	1260			7015	5.65	5	Lbs/DT= 7.6
8	780	950	1340	1680	1580	1140	800	7550	5.25	-	Density= 30
9	840	980	1540	1770	1260			8090	4.80	-	Wet Tons= 44.5
10	700	720	1100	1400	1005	1410		8545	5.15	-	Dry Tons= 17.8
PM	840	940	1550	1780	960			8465	5.10	-	Inc Gas= 10

Total Inc Gas 25

Inc Gas/Dry Ton .16

Daily Average Density 31.3

Total Wet Tons 120.3

Total Dry Tons 37.6

Appendix F
Equipment Calibration Data

Firm Name Martinez
 Plant Location Cameroon
 Test Number 2
 Sampling Location Incinerator Outlet
 Project No. FBG-36
 Date 8/27/86
 Tester JR/LAG

Orifice No. 175E
 Ambient Temp. 78 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 401
 Filter Ident. No. 521
 Duct Area 8.3 ft²
0.6428

Nozzle No. & Dia. 0.362 in.
 Assumed Moisture 24
 Test Duration 60 min.
 Traverse Point Interval 3 min.
 Probe Heater Setting 250 °F
 Filter Temp. Setting 250 °F
 Dry Gas Meter Y 1.0085

Manograph C Factor 0.60
 Pitot Coefficient 0.54
 Orifice All 1.78
 Test Start Time 1219
 Test Final Time 1321
 Leak Test Start 0.00 CMH 10 "Hg
 Leak Test Final 0.00 CMH 10 "Hg

Port	Point	Time Min.	Velocity ft/min	All in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle β	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
5		26	24	267	120	103		161	903	91		292	265	983	2		06
6		27	22	240	122	104		165	906	55		290		7	17		07
7		28	21	201	122	104		169	908	95		290		7	235		12
8		29	21	201	122	105		169	911	01		292		7	233		15
9		30	21	212	122	106		168	913	44		285		8	235		18
10		31	21	201	122	106		167	915	45		289			237		21
Average		32	24	240	107			164	5035								

H₂O Collected 805 ml
 SG Condition 15.6 g/m
 SG Weight 820.6 ml
 Total Volume Collected

Orsat Bag Sample
 Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂
8.0	10.5		
7.9	10.7		
8.0	10.5		

COMMENTS:

3'
 250
 127
 252
 90
 26
 813

FIELD DATA SHEET

Firm Name M. H. Bassett
 Plant Location Crawwell
 Test Number 3
 Sampling Location Incinerator Outlet
 Project No. FBG-20
 Date 8/27/86
 Tester LAS/DG
 Orifice No. 1758
 Ambient Temp. 76 °F
 Bar. Press. 27.78 "Hg
 Probe Ident. No. 401
 Filter Ident. No. 53A
 Duct Area 8.3 ft²
 O. G. 35

Nozzle No. & Dia. 0.362 in.
 Assumed Moisture 30
 Test Duration 60 min.
 Traverse Point Interval 3 min.
 Probe Heater Setting 250 °F
 Filter Temp. Setting 250 °F
 Dry Gas Meter Y 1.0005

Nomograph C Factor 0.60
 Pitot Coefficient 0.54
 Orifice All 1.78
 Test Start Time 1431
 Test Final Time 1536
 Leak Test Start 0.00 CFM @ 10 "Hg
 Leak Test Final 0.00 CFM @ 11 "Hg
 10f2

Port	Point	Time Min.	Velocity ΔP in H ₂ O	All in H ₂ O	T _M in °F	T _M out °F	P Stack in H ₂ O	T Stack °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
	1	30.24	0.21	200	98	73		142	919.63			274	265	4.5	228		
	2	1.021	0.21	200	100	95		143	922.86			286		4.5	332		
	3	0.22	0.22	210	106	96		145	925.07			291		4.5	324		
	4	0.24	0.24	232	110	97		146	927.44			269		5	220		
	5	0.25	0.25	240	112	98	-0.15	148	930.70			287		6	220		
	6	0.25	0.25	240	115	99		149	933.18			291		6	228		
	7	0.21	0.21	200	116	100		149	935.35			283		6	228		
	8	0.25	0.25	240	116	100		150	938.11			284		7	238		
	9	0.17	0.17	168	118	101		149	940.57			286		6	240		
	10	0.15	0.15	149	118	102		149	942.67			296		5	244		
	1	0.24	0.24	232	113	102		144	944.23			288		5	244		
	2	0.25	0.25	240	114	102		144	947.50			288		7	240		
	3	0.23	0.23	220	116	103		143	950.00			296		6.5	225		
	4	0.25	0.25	240	116	103		142	952.20			295		6.5	231		
Average		$\Sigma \Delta P$															

Orsat Bag Sample Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂

COMMENTS:

H₂O Collected _____ ml
 SG Condition _____
 SG Weight _____ gm
 Total Volume Collected _____ ml

FIELD DATA

Orifice No. 1758 of
 Ambient Temp. 76 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 401
 Filter Ident. No. 53X
 Duct Area 8.3 ft²

Firm Name Northrup
 Plant Location Cornwall
 Test Number 3
 Sampling Location Incinerator Outlet
 Project No. FB6-20
 Date 8/27/86
 Tester LHG/TJQ

Nozzle No. & Dia. 0.362 in.
 Assumed Moisture 20
 Test Duration 60 min.
 Traverse Point Interval 3 min.
 Probe Heater Setting 250 °F
 Filter Temp. Setting 250 °F
 Dry Gas Meter Y 1.0025

O.6436

Port	Point	Time Min.	Velocity ΔP In H ₂ O	Alt In H ₂ O	T _M in °F	T _M out °F	P Stack In H ₂ O	T Stack °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂	CO ₂
	5	50.25		240	119	104		143	954.86			268	265	8	226		
	6	102.4		237	120	105		142	957.74			273		7	230		
	7	102.8		220	121	105		139	959.99			258		7	235		
	8	101.8		176	121	106		138	962.13			265		6	234		
	9	101.8		156	121	106		138	964.61			261		6	231		
	10	101.5		149	118	105		139	966.24			274		6	232		
Average		Σ ΔP		209		108		144	4842								

21
24
27
30
33
36

Orsat Bag Sample
Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂
5.2	14.6		
5.2	14.6		
5.2	14.6		

COMMENTS:

250
135
110
495
200
895

H₂O Collected 295 ml
 SG Condition 3.7 g/m
 SG Weight 298.7 ml
 Total Volume Collected

Firm Name Northwest
 Plant Location Cromwell
 Test Number 4
 Sampling Location Incinerator
 Project No. 586-20
 Date 8/22/88
 Tester 457 BJS

Orifice No. 1758
 Ambient Temp. 76 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 401
 Filter Ident. No. 607X
 Duct Area 8.3 ft²

Orifice No. 0.78
 Pitot Coefficient 0.84
 Orifice All 1.78
 Test Start Time 1725
 Test Final Time 1829
 Leak Test Start 0.01 CMH 10 "Hg
 Leak Test Final 0.005 CMH 11 "Hg

1017A 2

Port	Point	Time Min.	Velocity ΔP in H ₂ O	All in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
1	30019	3	0.19	210	96	87		153	967.95			261	<65	5	231		25
2	019	1	0.19	210	96	88		152	971.83			270		5	229		28
3	020	1	0.20	220	98	89	-0.14	153	974.40			264		5	224		31
4	025	1	0.25	273	104	90		151	977.30			262		6	224		34
5	025	1	0.25	273	108	92		151	980.36			267		7	225		37
6	025	1	0.25	273	111	93		152	982.49			259		7	230		40
7	023	1	0.23	250	113	94		151	986.01			270		6	235		43
8	023	1	0.23	250	114	95		151	988.49			265		6	237		46
9	020	1	0.20	221	115	96		151	990.81			260		6	241		49
10	015	1	0.15	169	115	97		151	992.51			268		5	241		52
1	022	1	0.22	239	107	98		153	995.39			271		6	242		55
2	022	1	0.22	250	113	99		153	997.73			272		7	234		58
3	024	1	0.24	265	115	100		153	1000.61			271		8	221		61
4	024	1	0.24	265	116	100		152	1003.61			272		8	221		64
Average	Σ ΔP																

Orsat Bag Sample
Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂

H₂O Collected _____ ml
 SG Condition _____
 SG Weight _____ gm
 Total Volume Collected _____ ml

COMMENTS:

FIELD DATA SHEET

Firm Name Mathiasseff
 Plant Location Stonewell
 Test Number 4
 Sampling Location Incinerator
 Project No. F8620
 Date 8/27/86
 Tester JSG/LAG

Orifice No. 1758
 Ambient Temp. 76 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 401
 Filter Ident. No. 67X
 Duct Area 8.3 ft²
0.6462

Nozzle No. & Dia. 0.364 in.
 Assumed Moisture 24
 Test Duration 60 min.
 Traverse Point Interval 3 min.
 Probe Heater Setting 250 °F
 Filter Temp. Setting 250 °F
 Dry Gas Meter Y 1-0025

Nonograph C Factor 0.70
 Pitot Coefficient 0.84
 Orifice A₁ 1.78
 Test Start Time 1725
 Test Final Time 1827
 Leak Test Start 0.01 CPM 10 "Hg
 Leak Test Final 0.05 CPM 11 "Hg

2 of 2

Port	Point	Time Min.	Velocity AP in H ₂ O	All in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
5		34018		200	118	101		152	100611			269	265	6	229		14
6		1024		265	118	102		154	100870			269		8	245		17
7		024		265	119	102		152	101053			269		8	247		20
8		024		265	119	103		153	101370			270		8	244		22
9		1024		265	119	103		153	101626			271		8	242		26
10		1024		265	121	103		152	101905			270		9	244		29
Average		Σ	ΔP	244	104			152	5110								

H₂O Collected 420 ml
 SG Condition 14.6 gm
 SG Weight 434.6 ml
 Total Volume Collected

Orsat Bag Sample Triplicate Analysis, %

CO ₂	O ₂	N ₂
6.6	12.1	
6.7	12.2	
6.6	12.2	


250
 250
 120
 620
 200

COMMENTS:

Appendix E

Incinerator No. 1 Operational Data

84000 to 190001
 8-7-01



TYPE K THERMOCOUPLE

PRINTED IN U.S.A. HONEYWELL, FORT WASHINGTON, PA.

CHART NO. 8808





CHART NO. 8808

TYPE K THERMOCOUPLE

PRINTED IN U.S.A. HONEY

11 AM to 4 PM

8-2-58




PRINTED IN U.S.A. HONEYWELL FORT WASHINGTON, PA.

CHART NO. 6008

S-TYPE PITOT GEOMETRIC CALIBRATION PART 1 - PROBE CONFIGURATION

Probe Identification 401
Technical Specialist JSL
Date 7-11-86

Pitot Identification 401



Specifications (EPA Method 2)

$D_t = 3/16"$ to $3/8"$
 $D_n = 1/2"$
 $a \geq 3/4"$
 $b \geq 0$

$c \geq 3"$
 $d \geq 3"$
 $e \geq 3/4"$
 $f \geq 2"$

$P_a = P_b$
 $1.05 D_t \leq P \leq 1.50 D_t$

If these specifications are met, proceed with Part 2 Pitot alignment.


S-TYPE PITOT GEOMETRIC CALIBRATION
PART 2 - PITOT ALIGNMENT

Probe Identification 401
 Technical Specialist JSL
 Date 8-11-86

Pitot Identification 4101

A.

Transverse
Tube Axis



a 1.235
 b 0.388
 c 1.280
 d 0.388
 e 1.354
 θ 87.7°
 θ' 80.3

$$\frac{a^2 + b^2 - c^2}{2ab} = \cos \theta$$


$$\frac{a^2 + d^2 - e^2}{2ad} = \cos \theta'$$

$$(80^\circ < \theta < 100^\circ)$$

$$(30^\circ < \theta' < 100^\circ)$$

B.

Longitudinal
Tube Axis



a 1.235
 b 0.485
 c 1.305
 d 0.501
 e 1.340
 θ 87.3°
 θ' 86.6


$$\frac{a^2 + b^2 - c^2}{2ab} = \cos \theta$$

$$\frac{a^2 + d^2 - e^2}{2ad} = \cos \theta'$$

$$(35^\circ < \theta < 95^\circ)$$

$$(35^\circ < \theta' < 95^\circ)$$

C.



(f < 1/8")

f 0.000

D.



(g < 1/32")

g 0.000

NOTE: values in parentheses are EPA Method 2 specifications.

PROBE THERMOCOUPLE CALIBRATION

Tolerances

Expected Stack Temperature (T_s) _____ °R

Mercury Thermometer (T_{ref}) _____ °R

Thermocouple Readout _____ °R

Probe Identification _____

Technician _____

Date _____


($T_s \pm 10\%$)

($T_{ref} \pm 1.5\%$)

NOZZLE CALIBRATION DATA SHEET

BOX

NOZZLE SET NO. 1 DATE 2 AUGUST 86 TECHNICIAN ISC



NOZZLE NO.	DIAMETER*	A	B	C	AVERAGE**
1/8" ₁₋₁	0.180	0.179	0.181	0.180	0.180
1/4" ₁₋₂	0.245	0.245	0.247	0.245	0.245
3/8" ₁₋₃	0.362	0.361	0.360	0.364	0.362
1/2" ₁₋₄	0.497	0.499	0.496	0.495	0.497
1-5	0.397	0.398	0.396	0.398	0.397

* Measure to nearest .001"

** Three measurements must be within .004" of each other

METHOD 5 MODULE CALIBRATION

DATE 8-25-86 ORIFICE/MODULE NO. 51758 NAME JS6
 MANOMETRIC PRESSURE P_b 30.00 in Hg STANDARD METER 570415

MODULE ORIFICE SETTING ΔH (in. H ₂ O)	STANDARD METER			MODULE METER			γ	ΔH_a (in. H ₂ O)	Module Flowrate Q (SCFM)	OR
	Volume V_a (ft ³)	Factor F_a	Temperature t_a (°F)	Pressure ΔP_a (in. H ₂ O)	Volume V_m (ft ³)	Temperatures t_{m1} (°F)	Time θ (min)			
0.5	5.000	1.000	74	-0.5	5.136	93	12.40	1.004	1.69	
1.0	5.004	1.000	74	-0.5	5.170	95	8.93	992	1.74	
1.5	10.000	1.000	74	-0.5	10.323	96	14.86	1004	1.81	
2.0	10.007	1.000	74	-0.6	10.350	100.5	13.03	1007	1.83	
3.0	10.005	1.000	74	-1.0	10.401	103	10.68	10013	1.84	
							AVERAGE 1.0025		1.78	

CHECK:

FOR CHECK, USE THE AVERAGE ΔH_a FOR ΔH

$$\gamma = V_a (P_b + P_a) (T_m + 460) T_a$$

$$V_m (P_b + \frac{\Delta H}{13.6}) (t_a + 460)$$

$$\Delta H_a = \left[\frac{(0.0317) \Delta H}{P_b (t_m + 460)} \right] \left[\frac{(t_m + 460) \theta}{V_a T_a} \right]^2$$

$$Q = \gamma (17.64) V_m \left[\frac{P_b + \frac{\Delta H}{13.6}}{(t_m + 460) \theta} \right]$$

$$OR = \text{orifice factor} = \left[\frac{(t_m + 460) \Delta H}{P_b} \right]^{1/2}$$

ACCEPTANCE CRITERIA:

Each γ must be 1.00 ± 0.01
 Average ΔH_a must be 1.84 ± 0.25
 Each ΔH_a must be within 0.15 of the average ΔH_a

$$\text{Correlation Line Equation}$$

$$Q = m (OR) + b$$

$$Q = \text{---} \text{ OR } + \text{---}$$

TC Readout Calibrated with Constant Voltage Source
 t_{m1} or t_{m2} Reference Thermometer OR
 Module Leak Check ✓
 Heater Max Love Control OR Probe Heater Low Control ✓
 Module Cleaned ✓ Pilot tube manometer leak check ✓

Calibrated and Checked by JS6 Date 8-25-86
 Reviewed by _____ Date _____

METIKID 5 MODULE CALIBRATION

DATE 9-11-86 ORIFICE/MODULE NO. S 1758 NAME JSG
 BAROMETRIC PRESSURE P_b 29.92 In Hg STANDARD METER 570415

MODULE ORIFICE SETTING ΔH (In. H ₂ O)	STANDARD METER			MODULE METER				ΔH_a (In. H ₂ O)	Module Flowrate Q (SCFM)	OF
	Volume V_m (ft ³)	Factor Y_b	Temperature t_b (°F)	Pressure ΔP_b (In. H ₂ O)	Volume V_m (ft ³)	Temperatures t_{m1} t_{m2} (°F)	Time θ (min)			
0.5	5.000	1.000	76	-0.5	5.085	87.3 84.3	12.31	1.68		
1.0	5.000	1.000	76	-0.5	5.085	91 84	8.88	1.75		
1.5	10.001	1.000	76	-0.7	10.177	94.5 84.5	14.83	1.82		
2.0	10.005	1.000	76	-1.0	10.180	96.5 85.5	12.88	1.81		
3.0	10.003	1.000	76	-1.5	10.157	91.5 84	10.56	1.85		
							AVERAGE	1.78		

CHECK:

FOR CHECK, USE THE AVERAGE ΔH_a FOR ΔH

$$Y = V_b (P_b + P_s) (T_m + 460) Y_b$$

$$V_m (P_b + \frac{\Delta H}{13.6}) (t_b + 460)$$

$$\Delta H_a = \left[\frac{(0.0317) \Delta H}{P_b (t_m + 460)} \right] \left[\frac{(t_s + 460) \theta}{V_b Y_b} \right]^2$$

$$Q = Y (17.64) V_m \left[\frac{P_b + \frac{\Delta H}{13.6}}{(t_m + 460) \theta} \right]$$

$$OF = \text{orifice factor} = \left[\frac{(t_m + 460) \Delta H}{P_b} \right]^{1/2}$$

ACCEPTANCE CRITERIA:

Each Y must be 1.00 ± 0.01
 Average ΔH_a must be 1.84 ± 0.25
 Each ΔH_a must be within 0.15 of the average ΔH_a

$$Q = m (OF) + b$$

$$Q = \text{OF} +$$

TC Readout Calibrated with Constant Voltage Source of Reference Thermometer of

Module Leak Check Heater Box Love Control OK Probe Heater Low Control

Module Cleaned Pitot tube manometer leak check

Calibrated and Checked by JSG Date 9-11-86
 Reviewed by JSG Date 9/11/86

ANALYTICAL DATA

PLANT Mattabassett District
 DATE 8-27-86
 SAMPLING LOCATION Incinerator Outlet
 SAMPLE TYPE Method 5
 RUN NUMBER 1
 SAMPLE BOX NUMBER _____
 CLEAN-UP MAN JSB

COMMENTS:

FRONT HALF

ACETONE WASH OF NOZZLE, PROBE, CYCLONE (BYPASS),
 FLASK, FRONT HALF OF FILTER HOLDER

FILTER NUMBER T.W. → 6428
5/x F.W. 7435

LABORATORY RESULTS

CONTAINER Filter 1 100.7 mg

CONTAINER PW-1 50.6 mg

FRONT HALF SUBTOTAL 151.3 mg

BACK HALF

IMPINGER CONTENTS AND WATER WASH OF
 IMPINGERS, CONNECTORS, AND BACK
 HALF OF FILTER HOLDER

CONTAINER _____ mg
 ETHER-CHLOROFORM
 EXTRACTION _____ mg

ACETONE WASH OF IMPINGERS, CONNECTORS,
 AND BACK HALF OF FILTER HOLDER

CONTAINER _____ mg

BACK HALF SUBTOTAL _____ mg

TOTAL WEIGHT _____ mg

MOISTURE

IMPINGERS

FINAL VOLUME _____ ml
 INITIAL VOLUME _____ ml
 NET VOLUME _____ ml

SILICA GEL

FINAL WEIGHT _____ g
 INITIAL WEIGHT _____ g
 NET WEIGHT _____ g

TOTAL MOISTURE _____ g

ANALYTICAL DATA

PLANT Mattabasset District
 DATE 8-27-86
 SAMPLING LOCATION Incinerator Outlet
 SAMPLE TYPE Method 5
 RUN NUMBER 2
 SAMPLE BOX NUMBER _____
 CLEAN-UP MAN JSG

COMMENTS:

FRONT HALF

ACETONE WASH OF NOZZLE, PROBE, CYCLONE (BYPASS),
 FLASK, FRONT HALF OF FILTER HOLDER

FILTER NUMBER T.W. → 1438
52x F.W. → 2562

LABORATORY RESULTS

CONTAINER Filter 2 256.2 mg
 CONTAINER PW-2 103.2 mg

FRONT HALF SUBTOTAL 359.4 mg

BACK HALF

IMPINGER CONTENTS AND WATER WASH OF
 IMPINGERS, CONNECTORS, AND BACK
 HALF OF FILTER HOLDER

ACETONE WASH OF IMPINGERS, CONNECTORS,
 AND BACK HALF OF FILTER HOLDER

CONTAINER _____ mg
 ETHER-CHLOROFORM
 EXTRACTION _____ mg

CONTAINER _____ mg

BACK HALF SUBTOTAL _____ mg

TOTAL WEIGHT _____ mg

MOISTURE

IMPINGERS

FINAL VOLUME _____ ml
 INITIAL VOLUME _____ ml
 NET VOLUME _____ ml

SILICA GEL

FINAL WEIGHT _____ g _____ g _____ g
 INITIAL WEIGHT _____ g _____ g _____ g
 NET WEIGHT _____ g _____ g _____ g

TOTAL MOISTURE _____ g

ANALYTICAL DATA

PLANT Mattabessett District
DATE 8-27-86
SAMPLING LOCATION Incinerator Outlet
SAMPLE TYPE Method 5
RUN NUMBER 3
SAMPLE BOX NUMBER _____
CLEAN-UP MAN JSB

COMMENTS:

FRONT HALF

ACETONE WASH OF NOZZLE, PROBE, CYCLONE (BYPASS),
FLASK, FRONT HALF OF FILTER HOLDER

FILTER NUMBER T.W. — 2.6436
53x F.W. —

CONTAINER Filter 3

LABORATORY RESULTS

86.6 mgCONTAINER PW-355.0 mgFRONT HALF SUBTOTAL 141.6 mgBACK HALF

IMPINGER CONTENTS AND WATER WASH OF
IMPINGERS, CONNECTORS, AND BACK
HALF OF FILTER HOLDER

CONTAINER _____ mg
ETHER-CHLOROFORM
EXTRACTION _____ mg

ACETONE WASH OF IMPINGERS, CONNECTORS,
AND BACK HALF OF FILTER HOLDER

CONTAINER _____ mg

BACK HALF SUBTOTAL _____ mg

TOTAL WEIGHT	_____ mg
--------------	----------

MOISTURE

IMPINGERS

FINAL VOLUME _____ ml
INITIAL VOLUME _____ ml
NET VOLUME _____ ml

SILICA GEL

FINAL WEIGHT	_____ g	_____ g	_____ g
INITIAL WEIGHT	_____ g	_____ g	_____ g
NET WEIGHT	_____ g	_____ g	_____ g

TOTAL MOISTURE _____ g

EPA (Dur) 231

4.72

Appendix G

Orsat Analysis Validation Forms

ANALYTICAL DATA

PLANT Mattabasset District
 DATE 8-27-86
 SAMPLING LOCATION Incinerator Outlet
 SAMPLE TYPE Method 5
 RUN NUMBER 4
 SAMPLE BOX NUMBER _____
 CLEAN-UP MAN JSG

COMMENTS:

FRONT HALF

LABORATORY RESULTS

ACETONE WASH OF NOZZLE, PROBE, CYCLONE (BYPASS),
FLASK, FRONT HALF OF FILTER HOLDER

CONTAINER Filter 4 101.0 mg

FILTER NUMBER T.W. 6462
67X F.W. 1010

CONTAINER Pw-4 185.4 mg

FRONT HALF SUBTOTAL 286.4 mg

BACK HALF

IMPINGER CONTENTS AND WATER WASH OF
IMPINGERS, CONNECTORS, AND BACK
HALF OF FILTER HOLDER

CONTAINER _____ mg
ETHER-CHLOROFORM
EXTRACTION _____ mg

ACETONE WASH OF IMPINGERS, CONNECTORS,
AND BACK HALF OF FILTER HOLDER

CONTAINER _____ mg

BACK HALF SUBTOTAL _____ mg

TOTAL WEIGHT	_____ mg
--------------	----------

MOISTURE

IMPINGERS

FINAL VOLUME _____ ml
 INITIAL VOLUME _____ ml
 NET VOLUME _____ ml

SILICA GEL

FINAL WEIGHT	_____ g	_____ g	_____ g
INITIAL WEIGHT	_____ g	_____ g	_____ g
NET WEIGHT	_____ g	_____ g	_____ g

TOTAL MOISTURE _____ g

EPA METHOD 3
ORSAT EQUIPMENT CHECK, MOLECULAR WEIGHT
DETERMINATION, AND ANALYSIS VALIDATION

FIRM Mattalasset District
TEST NUMBER 1
SAMPLING TIME (24-hr CLOCK) 10/9 - 1122
SAMPLING LOCATION Main Incinerator Exhaust
SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS) _____
SAMPLE MOISTURE CONTENT 20 %
AMBIENT TEMPERATURE 70
TESTER/DATE JSB

An ORSAT analysis of boiler exhaust gases is considered valid if the F_o calculated from the ORSAT analysis is within $\pm 3\%$ of the F_o calculated from fuel analysis. If fuel analysis data is not available, the F_o calculated from the ORSAT analysis must be within $\pm 3\%$ of the average published F_o for a given fuel as follows:

FUEL	AVE. F_o	$\pm 3\%$ ACCEPTANCE LIMITS
Anthracite	1.070	1.016 - 1.124
Bituminous	1.140	1.083 - 1.197
Lignite	1.076	1.022 - 1.130
Oil	1.346	1.279 - 1.413
Natural Gas	1.749	1.662 - 1.836
Propane	1.510	1.434 - 1.586
Butane	1.479	1.405 - 1.553
Wood	1.050	0.9975 - 1.102
Bark	1.056	1.003 - 1.109

PRE-TEST ORSAT EQUIPMENT CHECK

ORSAT CHECK: PRE-TEST LEAK CHECK: INITIAL 4.8 ml 0 min.
ACCEPTANCE LIMIT: LEAK < 0.2 ml/5 min. FINAL 4.8 ml 5 min.
PRE-TEST AMBIENT O_2 = 20.8 %; ACCEPTANCE LIMITS OF O_2 = 20.6 - 21.2%

MOLECULAR WEIGHT DETERMINATION

GAS	1		2		3		AVERAGE	MULTIPLIER	CONTRIBUTION TO DRY MOLECULAR WEIGHT OF STACK GAS M_{di} lb/lb-mole
	ACTUAL READING (ml)		ACTUAL READING (ml)		ACTUAL READING (ml)				
CO_2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	44/100	
O_2	18.7	12.1	18.7	12.1	18.7	12.1	12.1	32/100	
CO								28/100	
N_2		81.3		81.3		81.3	81.3	28/100	

$$M_u = \frac{M_d (100 - \% H_2O) + 18 (\% H_2O)}{100}$$

$$M_d = \sum M_{di}$$

FOR F-FACTOR CALCULATIONS ALL ORSAT ANALYSES MUST BE RUN IN TRIPPLICATE AND MUST AGREE WITH EACH OTHER TO WITHIN 0.3% BY VOLUME

POST-TEST ORSAT EQUIPMENT CHECK

ORSAT CHECK: POST-TEST LEAK CHECK: INITIAL _____ ml 0 min.
ACCEPTANCE LIMIT: LEAK < 0.2 ml/5 min. FINAL _____ ml 5 min.
POST-TEST AMBIENT O_2 = _____ %; ACCEPTANCE LIMITS OF O_2 = 20.6 - 21.2%

ORSAT ANALYSIS VALIDATION

Average Published F_o = _____

Fuel Analysis F_o = $\frac{20.9 (1.53 \%C + 3.64 \%H + 0.57 \%S + 0.14 \%N - 0.46 \%O)}{0.321 \%C (100)}$ = _____

ORSAT Analysis F_o = $\frac{20.9 - \%O_2}{\%CO_2}$ = _____, Acceptance Limits are shown above.

*Assuming CO concentration is negligible (< 1000 ppm)

EPA METHOD 3
ORSAT EQUIPMENT CHECK, MOLECULAR WEIGHT
DETERMINATION, AND ANALYSIS VALIDATION

FIRM Mattalanni District
TEST NUMBER 2
SAMPLING TIME (24-hr CLOCK) 1219 - 1321
SAMPLING LOCATION Main Generator Exhaust
SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS) _____
SAMPLE MOISTURE CONTENT 20 %
AMBIENT TEMPERATURE 70
TESTER/DATE JJB

An ORSAT analysis of boiler exhaust gases is considered valid if the P_o calculated from the ORSAT analysis is within $\pm 5\%$ of the P_o calculated from fuel analysis. If fuel analysis data is not available, the P_o calculated from the ORSAT analysis must be within $\pm 5\%$ of the average published P_o for a given fuel as follows:

FUEL	AVE. P_o	$\pm 5\%$ ACCEPTANCE LIMITS
Anthracite	1.070	1.016 - 1.124
Bituminous	1.140	1.083 - 1.197
Lignite	1.076	1.022 - 1.130
Oil	1.346	1.279 - 1.413
Natural Gas	1.749	1.662 - 1.836
Propane	1.510	1.434 - 1.586
Butane	1.479	1.405 - 1.553
Wood	1.050	0.9975 - 1.102
Bark	1.056	1.003 - 1.109

PRE-TEST ORSAT EQUIPMENT CHECK

ORSAT CHECK: PRE-TEST LEAK CHECK: INITIAL _____ ml _____ min.
ACCEPTANCE LIMIT: LEAK < 0.2 ml/5 min. FINAL _____ ml _____ min.
PRE-TEST AMBIENT O_2 = _____ %; ACCEPTANCE LIMITS OF O_2 = 20.6 - 21.2%

MOLECULAR WEIGHT DETERMINATION

GAS	1		2		3		AVERAGE	MULTIPLIER	CONTRIBUTION TO DRY MOLECULAR WEIGHT OF STACK GAS M_{d1} lb/lb-mole
	ACTUAL READING (ml)		ACTUAL READING (ml)		ACTUAL READING (ml)				
CO_2	8.0	8.0	7.7	7.9	8.0	8.0	8.0	44/100	
O_2	18.5	10.5	18.6	10.7	18.5	10.5	10.5	32/100	
CO								28/100	
N_2		81.5		81.4		81.5	81.5	28/100	

$$M_v = \frac{M_d (100 - \% H_2O) + 18 (\% H_2O)}{100} = \underline{\hspace{2cm}}$$

$$M_d = \sum M_{d1} = \underline{\hspace{2cm}}$$

FOR P-FACTOR CALCULATIONS ALL ORSAT ANALYSES MUST BE RUN IN TRIPLICATE
AND MUST AGREE WITH EACH OTHER TO WITHIN 0.3% BY VOLUME

POST-TEST ORSAT EQUIPMENT CHECK

ORSAT CHECK: POST-TEST LEAK CHECK: INITIAL _____ ml _____ min.
ACCEPTANCE LIMIT: LEAK < 0.2 ml/5 min. FINAL _____ ml _____ min.
POST-TEST AMBIENT O_2 = _____ %; ACCEPTANCE LIMITS OF O_2 = 20.6 - 21.2%

ORSAT ANALYSIS VALIDATION

Average Published P_o = _____

Fuel Analysis P_o = $\frac{20.9 (1.53 \%C + 3.64 \%H + 0.57 \%S + 0.14 \%N - 0.46 \%O)}{0.321 \%C (100)}$ = _____

ORSAT Analysis P_o = $\frac{20.9 - \%O_2}{\%CO_2}$ = _____, Acceptance Limits are shown above.

*Assuming CO concentration is negligible (< 1000 ppm)

EPA METHOD 3
ORSAT EQUIPMENT CHECK, MOLECULAR WEIGHT
DETERMINATION, AND ANALYSIS VALIDATION

FIRM Mattabessett District
TEST NUMBER 3
SAMPLING TIME (24-HR CLOCK) 1431-1536
SAMPLING LOCATION Main Incinerator Exhaust
SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS) _____
SAMPLE MOISTURE CONTENT 20 %
AMBIENT TEMPERATURE 70 °F
TESTER/DATE J26

An ORSAT analysis of boiler exhaust gases is considered valid if the P_0 calculated from the ORSAT analysis is within $\pm 5\%$ of the P_0 calculated from fuel analysis. If fuel analysis data is not available, the P_0 calculated from the ORSAT analysis must be within $\pm 5\%$ of the average published P_0 for a given fuel as follows:

FUEL	AVE. P_0	$\pm 5\%$ ACCEPTANCE LIMITS
Anthracite	1.070	1.016 - 1.124
Bituminous	1.140	1.083 - 1.197
Lignite	1.076	1.022 - 1.130
Oil	1.346	1.279 - 1.413
Natural Gas	1.749	1.662 - 1.836
Propane	1.310	1.234 - 1.386
Butane	1.479	1.403 - 1.553
Wood	1.030	0.979 - 1.102
Barb	1.036	1.003 - 1.109

PRE-TEST ORSAT EQUIPMENT CHECK

ORSAT CHECK: PRE-TEST LEAK CHECK: INITIAL 0 ml 0 min.
ACCEPTANCE LIMIT: LEAK < 0.2 ml/3 min. FINAL 0 ml 0 min.
PRE-TEST AMBIENT O_2 = 20.6 %; ACCEPTANCE LIMITS OF O_2 = 20.6 - 21.2%

MOLECULAR WEIGHT DETERMINATION

GAS	1		2		3		AVERAGE	MULTIPLIER	CONTRIBUTION TO DRY MOLECULAR WEIGHT OF STACK GAS M_{d1} 18/18-32.0
	ACTUAL READING (ml)		ACTUAL READING (ml)		ACTUAL READING (ml)				
CO_2	5.2	5.2	5.2	5.2	5.2	5.2	5.2	44/100	
O_2	19.8	14.6	19.7	14.5	19.8	14.6	14.6	32/100	
CO								28/100	
N_2		80.2		80.3		80.2	80.2	28/100	

$$M_v = \frac{M_d (100 - \% H_2O) + 18 (\% H_2O)}{100}$$

$$M_d = \sum M_{d1}$$

FOR P-FACTOR CALCULATIONS ALL ORSAT ANALYSES MUST BE RUN IN TRIPPLICATE AND MUST AGREE WITH EACH OTHER TO WITHIN 0.3% BY VOLUME

POST-TEST ORSAT EQUIPMENT CHECK

ORSAT CHECK: POST-TEST LEAK CHECK: INITIAL 0 ml 0 min.
ACCEPTANCE LIMIT: LEAK < 0.2 ml/3 min. FINAL 0 ml 0 min.
POST-TEST AMBIENT O_2 = 20.6 %; ACCEPTANCE LIMITS OF O_2 = 20.6 - 21.2%

ORSAT ANALYSIS VALIDATION

Average Published P_0 = _____

Fuel Analysis P_0 = $\frac{20.9 (1.33 \text{ VC} + 1.64 \text{ VH} + 0.57 \text{ VS} + 0.14 \text{ VN} - 0.46 \text{ VO})}{0.321 \text{ VC} (100)}$ = _____

ORSAT Analysis P_0 = $\frac{20.9 - \% O_2}{\% CO_2}$ = _____, Acceptance Limits are shown above.

*Assuming CO concentration is negligible (< 1000 ppm)

**EPA METHOD 3
ORSAT EQUIPMENT CHECK, MOLECULAR WEIGHT
DETERMINATION, AND ANALYSIS VALIDATION**

FIRM Mathabassett District
TEST NUMBER 4
SAMPLING TIME (24-hr CLOCK) 1725 - 1829
SAMPLING LOCATION Incinerator Outlet
SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS) _____
SAMPLE MOISTURE CONTENT 20 %
AMBIENT TEMPERATURE 70
TESTER/DATE LAS

An ORSAT analysis of boiler exhaust gases is considered valid if the F_o calculated from the ORSAT analysis is within $\pm 5\%$ of the F_o calculated from fuel analysis. If fuel analysis data is not available, the F_o calculated from the ORSAT analysis must be within $\pm 5\%$ of the average published F_o for a given fuel as follows:

FUEL	AVE. F_o	$\pm 5\%$ ACCEPTANCE LIMITS
Anthracite	1.070	1.016 - 1.124
Bituminous	1.140	1.083 - 1.197
Lignite	1.076	1.022 - 1.130
Oil	1.346	1.279 - 1.413
Natural Gas	1.749	1.662 - 1.836
Propane	1.510	1.434 - 1.586
Butane	1.479	1.405 - 1.553
Wood	1.050	0.9975 - 1.102
Bark	1.056	1.003 - 1.109

PRE-TEST ORSAT EQUIPMENT CHECK

ORSAT CHECK: PRE-TEST LEAK CHECK: INITIAL 0 ml 0 min.
ACCEPTANCE LIMIT: LEAK < 0.2 ml/5 min. FINAL 5 ml 5 min.
PRE-TEST AMBIENT O_2 = 20.8 %; ACCEPTANCE LIMITS OF O_2 = 20.6 - 21.2%

MOLECULAR WEIGHT DETERMINATION

GAS	1		2		3		AVERAGE	MULTIPLIER	CONTRIBUTION TO DRY MOLECULAR WEIGHT OF STACK GAS M_{di} lb/lb-mole
	ACTUAL READING (ml)		ACTUAL READING (ml)		ACTUAL READING (ml)				
CO ₂	6.6	6.6	6.7	6.7	6.6	6.6	6.6	44/100	
O ₂	18.7	12.1	18.9	12.2	18.8	12.2	12.2	32/100	
CO								28/100	
N ₂		81.3		81.1		81.2	81.2	28/100	

$$M_w = \frac{M_d (100 - \% H_2O) + 18 (\% H_2O)}{100} = \underline{\hspace{2cm}}$$

$$M_d = \sum M_{di} = \underline{\hspace{2cm}}$$

FOR F-FACTOR CALCULATIONS ALL ORSAT ANALYSES MUST BE RUN IN TRIPPLICATE
AND MUST AGREE WITH EACH OTHER TO WITHIN 0.3% BY VOLUME

POST-TEST ORSAT EQUIPMENT CHECK

ORSAT CHECK: POST-TEST LEAK CHECK: INITIAL 6.2 ml 0 min.
ACCEPTANCE LIMIT: LEAK < 0.2 ml/5 min. FINAL 6.2 ml 5 min.
POST-TEST AMBIENT O_2 = 20.8 %; ACCEPTANCE LIMITS OF O_2 = 20.6 - 21.2%

ORSAT ANALYSIS VALIDATION

Average Published F_o = _____

Fuel Analysis F_o = $\frac{20.9 (1.53 \%C + 3.64 \%H + 0.57 \%S + 0.14 \%N - 0.46 \%O)}{0.321 \%C (100)}$ = _____

ORSAT Analysis F_o = $\frac{20.9 - \%O_2}{\%CO_2}$ = _____, Acceptance Limits are shown above.

*Assuming CO concentration is negligible (< 1000 ppm)

Appendix H
Example Calculations

EMISSION CALCULATION SYMBOLS

TEST No. 1

 L_a - Allowable leak rate, cfm $V_{m_{total}}$ - Total meter sample volume, ft^3 T_{total} - Total sampling time, min L_p - Final leak rate of sampling train, cfm $V_{mc_{total}}$ - Total volume sampled corrected for excessive leakage, ft^3 Y - Dry gas meter calibration factor, dimensionless T_{std} - Standard temperature, $^{\circ}F$ $T_{m_{avg.}}$ - Average dry gas meter temperature, $^{\circ}F$ P_{bar} - Barometric pressure, "Hg $\Delta H_{avg.}$ - Average orifice pressure drop, "H₂O P_{std} - Standard pressure, "Hg V_I - Volume of liquid collected in impingers, ml V_{SG} - Volume of liquid collected in silica gel, grams M_s - Molecular weight of stack gas, lb/lb-mole $\%CO_2$ - Percent CO₂ by volume (dry basis), % $\%CO$ - Percent CO by volume (dry basis), % $\%N_2$ - Percent N₂ by volume (dry basis), % $\%O_2$ - Percent O₂ by volume (dry basis), % D_{st} - Average duct gas density, lbs/ft^3 $P_{s_{avg}}$ - Average duct static pressure, "H₂O $T_{s_{avg}}$ - Average duct temperature, $^{\circ}F$ EA - Excess air, % V_s - Average duct velocity, ft/min C_p - Pitot tube coefficient, dimensionless $(\sqrt{\Delta P})_{avg}$ - Average square root of velocity head, $\sqrt{"H_2O}$ A_s - Cross-sectional area of duct, ft^2

EMISSION CALCULATION SYMBOLS (cont'd)

Q - Duct volumetric flow rate, acfm

Q_{std} - Duct volumetric flow rate, corrected to dry standard conditions, dscfm

D_n - Nozzle diameter, inches

F - F factor, DSCF/MM BTU

ZH - Percent by weight of hydrogen in fuel

ZC - Percent by weight of carbon in fuel

ZS - Percent by weight of sulfur in fuel

ZN - Percent by weight of nitrogen in fuel

ZO - Percent by weight of oxygen in fuel

GCV - Gross calorific value of fuel, BTU/lb.

C - Actual particulate concentration, grains/acf

C_s - Particulate concentration, grains/dscf

ER - Particulate emission rate, lbs/hr

E - Particulate emissions, lbs/MM BTU

$C_s @ 12\% CO_2$ - Particulate concentration, grains/dscf @ 12% CO_2

$C_s @ 50\% EA$ - Particulate concentration, grains/dscf @ 50% EA

C_{lb} - Particulate concentration, lbs/1000 duct gas

$C_{lb} @ 12\% CO_2$ - Particulate concentration, lbs/1000 lbs @ 12% CO_2

$C_{lb} @ 50\% EA$ - Particulate concentration, lbs/1000 lbs @ 50% EA

M_n - Total particulate collected, mg

1. Allowable Leak Rate

$$La = 0.02 \text{ cfm or } 0.04 \frac{V_m \text{ total}}{T_{\text{total}}} \text{ which ever is less.}$$

$$\frac{0.04 V_m \text{ total}}{T_{\text{total}}} = \frac{0.04 \times}{T_{\text{total}}}$$

$$La = \text{ cfm}$$

2. Correction for Excessive Leak Rate

$$Lp = \text{ cfm}$$

if $Lp > La$ use V_{mc} total in place of V_m total in all subsequent equations.

$$V_{mc} \text{ total} = V_m \text{ total} - (Lp - La) T_{\text{total}}$$

$$V_{mc} \text{ total} = \text{ } - (\text{ } - \text{ }) = \text{ } \text{ ft}^3$$

3. Volume of Sample Measured by Dry Gas Meter, Corrected to Standard Conditions

$$V_m \text{ total (std)} = V_m \text{ total} \times \left(\frac{T_{\text{std}} + 460}{T_m \text{ avg} + 460} \right) \left[\frac{P_{\text{bar}} + \frac{\Delta H_{\text{avg}}}{13.6}}{P_{\text{std}}} \right]$$

$$V_m \text{ total (std)} = 49.05 \times 1003 \left(\frac{68 + 460}{101 + 460} \right) \left[\frac{29.78 + \frac{2.26}{13.6}}{29.92} \right]$$

$$V_m \text{ total (std)} = 46.32 \text{ dscf}$$

4. Moisture Content of Duct Gas

$$\% H_2O = \frac{0.04707 (V_I + V_{SG})}{V_m \text{ total (std)} + 0.04707 (V_I + V_{SG})} \times 100$$

$$\% H_2O = \frac{0.04707 (\text{ } + \text{ })}{46.32 + 0.04707 (\text{ } + \text{ })} \times 100$$

$$\% H_2O = 25.3 \%$$

5. Molecular Weight of Stack Gas

$$M_s = \left[(0.44 \times \% \text{CO}_2) + (0.28 \times \% \text{CO}) + (0.28 \times \% \text{N}_2) + (0.32 \times \% \text{O}_2) \right] \left(1 - \frac{\% \text{H}_2\text{O}}{100} \right) + 0.18 (\% \text{H}_2\text{O})$$

$$M_s = \left[(0.44 \times 6.6) + (0.28 \times 0) + (0.28 \times 81.3) + (0.32 \times 12.1) \right] \left(1 - \frac{25.3}{100} \right) + 0.18 (25.3)$$

$$M_s = 26.6 \text{ lb/lb-mole}$$

6. Average Duct Gas Density

$$D_{st} = 0.0458 \times M_s \left(\frac{P_{bar} + \frac{P_{s \text{ avg}}}{13.6}}{T_{s \text{ avg}} + 460} \right)$$

$$D_{st} = 0.0458 \times \left(\frac{+ 13.6}{+ 460} \right)$$

$$D_{st} = NA \text{ lbs/ft}^3$$

7. Excess Air

$$EA = 100 \left[\frac{\% \text{O}_2 - 0.5 \% \text{CO}}{0.264 \% \text{N}_2 - (\% \text{O}_2 - 0.5 \% \text{CO})} \right]$$

$$EA = 100 \left[\frac{12.1 - 0.5 \times 0}{0.264 \times 81.3 - (12.1 - 0.5 \times 0)} \right]$$

$$EA = 129 \%$$

8. Average Duct Velocity

$$V_s = 5129.4 C_p (\sqrt{\Delta P})_{avg} \sqrt{\frac{T_{s \text{ avg}} + 460}{\left(P_{bar} + \frac{P_{s \text{ avg}}}{13.6} \right) M_s}}$$

$$V_s = 5129.4 \times 0.84 \times 0.4193 \sqrt{\frac{149 + 460}{\left(29.78 + \frac{0.16}{13.6} \right) 26.6}}$$

$$V_s = 1583 \text{ ft/min}$$

9. Duct Volumetric Flow Rate

$$Q = V_s \times A_s$$

$$Q = 1583.7 \times 8.3$$

$$Q = 13145 \text{ acfm}$$

10. Duct Volumetric Flow Rate, Corrected to Dry Standard Conditions

$$Q_{std} = Q \left(1 - \frac{\% H_2O}{100} \right) \left(\frac{T_{std} + 460}{T_{s \text{ avg}} + 460} \right) \left(\frac{P_{bar} + \frac{P_{s \text{ avg}}}{13.6}}{P_{std}} \right)$$

$$Q_{std} = 13145 \left(1 - \frac{25.3}{100} \right) \left(\frac{68 + 460}{149 + 460} \right) \left(\frac{29.78 + \frac{13.6}{29.92}}{29.92} \right)$$

$$Q_{std} = \text{dscfm}$$

11. Isokinetic Factor

$$I = \frac{5.67 (T_{s \text{ avg}} + 460) (V_m \text{ std})}{\left(P_{bar} + \frac{P_{s \text{ avg}}}{13.6} \right) V_s \times T_{total} \left(1 - \frac{\% H_2O}{100} \right) \left(\frac{(Dn)^2 \times 0.7854}{144} \right)}$$

$$I = \frac{5.67 (149 + 460) (46.32)}{\left(29.78 + \frac{4195}{13.6} \right) 1583 \times 60 \left(1 - \frac{25.3}{100} \right) \left(\frac{(36)^2 \times 0.7854}{144} \right)}$$

$$I = 1059 \%$$

12. F - Factor

$$F = \frac{10^6 (3.64\% H + 1.53\% C + 0.57\% S + 0.14\% N - 0.46\% O)}{GCV}$$

$$F = \frac{10^6 (3.64 \times \quad + 1.53 \times \quad + 0.57 \times \quad + 0.14 \times \quad - 0.46 \times \quad)}{\quad}$$

$$F = NA \text{ DSCF/MM BTU}$$

13. Actual Particulate Concentration

$$C = \frac{0.01543 \times Mn \left(\frac{T_{std}}{T_{s avg} + 460} \right) \left(\frac{P_{bar} + \frac{P_{s avg}}{13.6}}{P_{std}} \right) \left(1 - \frac{\%H_2O}{100} \right)}{V_{m std}}$$

$$C = \frac{0.01543 \times 151.3 (68 + 460) \left(\frac{29.92 + \frac{4193}{13.6}}{29.92} \right) \left(1 - \frac{35.3}{100} \right)}{46.32 (149 + 460) (29.92)}$$

$$C = 0.03 \text{ grains/acf}$$

14. Particulate Concentration, Corrected to Dry Standard Conditions

$$C_s = 0.01543 \times \frac{Mn}{V_{m std}}$$

$$C_s = 0.01543 \times \frac{151.3}{46.32}$$

$$C_s = 0.05 \text{ grains/dscf}$$

15. Particulate Emission Rate

$$ER = 0.008571 \times C_s \times Q_{std}$$

$$ER = 0.008571 \times 0.05 \times 8470$$

$$ER = 3.6 \text{ lbs/hr.}$$

16. Particulate Emission

$$E = 0.0001429 C_s \times F \left(\frac{20.9}{20.9 - \%CO_2} \right)$$

$$E = 0.0001429 \times \quad \times \left(\frac{20.9}{20.9 - \quad} \right)$$

$$E = NA \text{ lbs/MM BTU}$$

17. Particulate Concentration Corrected to Dry Standard Conditions and 12% CO₂

$$C_s @ 12\% CO_2 = \frac{12}{\% CO_2} \times C_s$$

$$C_s @ 12\% CO_2 = \frac{12}{6.6} \times 0.05$$

$$C_s @ 12\% CO_2 = 0.09 \text{ grains/dscf @ 12\% CO}_2$$

18. Particulate Concentration Corrected to Dry Standard Conditions and 50% Excess Air

$$C_s @ 50\% EA = \frac{\% EA + 100}{150} \times C_s$$

$$C_s @ 50\% EA = \frac{129.2 + 100}{150} \times .05$$

$$C_s @ 50\% EA = 0.07 \text{ grains/dscf @ 50\% EA}$$

19. Particulate Concentration Based on Duct Gas Weight

$$C_{Lb} = 0.1429 \times \frac{C}{D_{st avg}}$$

$$C_{Lb} = 0.1429 \times \text{_____}$$

$$C_{Lb} = NA \text{ lbs/1000 lbs duct gas (uncorrected)}$$

20. Particulate Concentration Based on Duct Gas Weight Corrected to 12% CO₂

$$C_{Lb} @ 12\% CO_2 = \frac{C_s @ 12\% CO_2 \times 0.104 (T_{std} + 460)}{(0.44 \times \% CO_2) + (0.28(\% CO + \% N_2)) + (0.32 \times \% O_2)}$$

$$C_{Lb} @ 12\% CO_2 = \frac{\text{_____} \times 0.104 (528)}{(0.44 \times \text{_____}) + (0.28(\text{_____} + \text{_____})) + (0.32 \times \text{_____})}$$

$$C_{Lb} @ 12\% CO_2 = NA \text{ lbs/1000 lbs dry corrected to 12\% CO}_2$$

21. Particulate Concentration Based on Duct Gas Weight Corrected to 50% Excess Air

$$C_{Lb} @ 50\% EA = \frac{C_s @ 50\% EA \times 0.104 (T_{std} + 460)}{(0.44 \times \% CO_2) + (0.28(\% CO + \% N_2)) + (0.32 \times \% O_2)}$$

$$C_{Lb} @ 50\% EA = \frac{0.07 \times 0.104 (528)}{(0.44 \times 6.6) + (0.28(0 + 81.3)) + (0.32 \times 12.1)}$$

$$C_{Lb} @ 50\% EA = 0.141 \text{ lbs/1000 lbs dry @ 50\% EA}$$

Total Hydrocarbon Emissions

Test No. 1

$$0.065 \frac{\text{mg}}{\text{L}} \times \frac{28.32 \text{ L}}{1 \text{ ft}^3} \times \frac{1 \text{ lb}}{453.6 \text{ g}} \times \frac{1 \text{ g}}{1000 \text{ mg}}$$

$$= 4.06 \text{ E}^{-6} \text{ lb} / \text{dscf}$$

$$\frac{4.06 \text{ E}^{-6} \text{ lb}}{\text{dscf}} \times \frac{8470 \text{ dscf}}{\text{min.}} \times \frac{60 \text{ min}}{\text{hr}}$$

$$= 2.1 \text{ pounds total hydrocarbon} / \text{hour}$$

Test No. 2

$$0.096 \frac{\text{mg}}{\text{L}} \times \frac{28.32 \text{ L}}{\text{ft}^3} \times \frac{1 \text{ lb}}{453.6 \text{ g}} \times \frac{1 \text{ g}}{1000 \text{ mg}}$$

$$= 6.0 \text{ E}^{-6} \text{ lb} / \text{dscf}$$

$$\frac{6.0 \text{ E}^{-6} \text{ lb}}{\text{dscf}} \times \frac{7077 \text{ dscf}}{\text{min.}} \times \frac{60 \text{ min}}{\text{hr}}$$

$$= 2.6 \text{ pounds total hydrocarbon} / \text{hour}$$

Total Hydrocarbon Emissions

Test No. 3

$$0.061 \frac{\text{mg}}{\text{L}} \times \frac{28.32 \text{ L}}{1 \text{ ft}^3} \times \frac{1 \text{ lb}}{453.6 \text{ g}} \times \frac{1 \text{ g}}{1000 \text{ mg}}$$


$$= 3.8 \text{ E}^{-6} \text{ lb} / \text{dscf}$$

$$\frac{3.8 \text{ E}^{-6} \text{ lb}}{\text{dscf}} \times 9597 \frac{\text{dscf}}{\text{min}} \times 60 \frac{\text{min}}{\text{hr}}$$

$$= 2.2 \text{ pounds total hydrocarbon / hour}$$

ACCOUNT RO-FA C

ROJAC



ANALYST Cipriello, Adamus

ANALYTICAL METHOD Atomic Absorption Spectrometry

DATE REPORTED 9-16-86

SAMPLE I.D. Air Volume

Lead

NOTES:

A. RICHARD LOMBARDI, P.E.
PRESIDENT
THOMAS D. LEE
DIRECTOR
FREDERICK O. A. ALMQUIST, P.E.
SANITARY ENGINEER
H. F. SACHS
BACTERIOLOGIST
J. LAIRD NEWELL, P.E.
CONSULTANT

THE NEWLANDS SANITARY LABORATORY
HENRY SOUTHER LABORATORIES, PROPRIETOR
SANITARY, CHEMICAL AND BACTERIOLOGICAL INVESTIGATIONS
24 TOBEY ROAD
BLOOMFIELD, CONNECTICUT 06002
TEL. (203) 242-6291

WATER SUPPLY AND PURIFICATION
SEWAGE & INDUSTRIAL WASTE DISPOSAL
DESIGN-SUPERVISION-VALUATION
CHEMICAL & BIOLOGICAL LABORATORIES
AIR POLLUTION STUDIES

August 29, 1986

ROJAC Environmental Services, Inc.
P.O. Box 731
West Hartford, Conn. 06107

Attn: Mr. Leigh A. Gammie

Gentlemen:

We have the following to report on the sample submitted to this laboratory on August 28, 1986.

Sample No. 1523H6
Mark Project #F86-20

Particulate Matter:

Filters

#1 - 51X	0.1007 grams
#2 - 52X	0.2562 grams
#3 - 53X	0.0866 grams
#4 - 67X	0.1010 grams

Condensibles:

Probe & Nozzle Rinse

PW-1	0.0506 grams
PW-2	0.1032 grams
PW-3	0.0550 grams
PW-4	0.1854 grams

Very truly yours,

THE NEWLANDS SANITARY LABORATORY

Thomas D. Lee
Thomas D. Lee
Laboratory Director

TDL/cas



**ENVIRONMENTAL
SCIENCE
CORPORATION**

P.O. BOX 616
50 WALNUT STREET • MIDDLETOWN, CONN. 06457
TELEPHONE: 347-6961

Laboratory Report

LAB. REPORT NO.

C - 2154

State Certification No. PH-0476

CLIENT

DATE September 5, 1986

Terrie Pelletier
Mattabassett District
P.O. Box 137
Cromwell, CT 06416

CLIENT
PHONE NO. 635-5550

SPECIAL INSTRUCTIONS:

P.O.#9034

SAMPLE DESCRIPTION

TEST

RESULTS

18,000 Tank
11:00 - 7:00

Mercury

mg/kg
< 0.002

18,000 Tank
7:00 - 3:00
8-27-86

Mercury

< 0.002

18,000 Tank
3:00 - 11:00
8-28-86

Mercury

< 0.002

REMARKS:

7-16-86
received

September 12, 1986
DATE REPORTED

Thomas F. McElroy
LABORATORY DIRECTOR

ENVIRONMENTAL
LABORATORIES

August 4, 1986

WATER AND AIR ANALYSIS

OSHA, DEP, EPA
COMPLIANCE TESTING

Ms. Terri Pelletier
Mattabassett
P.O. Box 137
Cromwell, CT 06416

RE: Lab. No. 066312-003
P.O. NO. 8891
Inv. No. 11680

Dear Ms. Pelletier:

The following is a report of analysis performed
on samples received June 26, 1986:

	6-20-86 Sludge <u>Good Quality</u>	6-25-86 Sludge <u>Bad Quality</u>		
Beryllium (ppm)	<1	- - - - -		
Mercury	<0.1	- - - - -		
MBAS	417	173		
Coliform. Total	6-25-86 46/100ml	6-26-86 33/100ml		
	6-20-86 Good Quality <u>Sludge</u>	6-20-86 Good Quality <u>Filtrate</u>	6-25-86 Bad Quality <u>Sludge</u>	6-25-86 Bad Quality <u>Filtrate</u>
Chloride (mg/l)	113	113	135	90
Oil & Grease	16	610	7.4	430

If you have any questions, please contact us.

Very truly yours,

Stephen J. Franco
Stephen J. Franco
Laboratory Director

SJF/br



GRISWOLD & FUSS
ENVIRONMENTAL LABORATORIES, INC.

360 East Center St. Manchester, Conn. 06040 Tel. (203) 646-5628

Appendix D
Field Data Sheets

Firm Name McHarris
 Plant Location Conwell
 Test Number 1
 Sampling Location Incinerator
 Project No. Outlet
 Date 8/27/86
 Tester JG/LTG

Orifice No. 1758
 Ambient Temp. 75 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 401
 Filter Ident. No. 51X
 Duct Area 0.3 ft²
 Nozzle No. & Dia. 0.362 in.
 Assumed Moisture 18
 Test Duration 60 min.
 Traverse Point Interval 3 min.
 Probe Heater Setting 282 °F
 Filter Temp. Setting 252 °F
 Dry Gas Meter Y 1.0025

Nomograph C Factor 0.77
 Pitot Coefficient 0.84
 Orifice A₁ 1.78
 Test Start Time 1019
 Test Final Time 1122
 Leak Test Start 0.00 CPM 15 "Hg
 Leak Test Final 0.01 CPM 11 "Hg

1019
 02
 25
 28
 31
 34
 37
 40
 43
 46
 49
 52
 55
 58
 01
 04

Port	Point	Time Min.	Velocity ΔP in H ₂ O	All in H ₂ O	T _M in °F	T _M out °F	P Stack in H ₂ O	T Stack °F	Gas Sample Volume cu. ft.	P R O B E	Dyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
1	1	30.22	26.8	26.8	84	76		147	817.8			288	<65	5	234		
2	2	30.23	28.0	28.0	85	78		146	821.0			293		6	226		
3	3	30.18	28.3	28.3	92	79		143	823.1			255		5.5	224		
4	4	30.24	29.6	29.6	95	80	-0.15	145	825.4			259		8	222		
5	5	30.20	24.9	24.9	100	82		145	828.5			258		7	221		
6	6	30.13	15.1	15.1	102	84		146	830.8			246		2	222		
7	7	30.24	05.0	05.0	109	85		148	831.6			261		2	227		
8	8	30.24	05.0	05.0	102	85		149	833.0			260		3	227		
9	9	30.14	17.8	17.8	102	86		153	835.1			249		5	217		
10	10	30.18	22.3	22.3	102	90		149	837.2			271		7	226		
1	1	30.23	28.0	28.0	106	92		149	840.6			267		8	223		
2	2	30.24	29.6	29.6	110	93		146	843.7			262		8	216		
3	3	30.24	29.6	29.6	112	95		148	845.8			255		8.5	220		
4	4	30.24	29.6	29.6	116	96		152	847.0			244			224		
Average		ΣΔP															

383
 125

Orsat Bag Sample Triplicate Analysis, %			
CO ₂	O ₂	CO	N ₂

COMMENTS:

H₂O Collected _____ ml
 SG Condition _____
 SG Weight _____ gm
 Total Volume Collected _____ ml

FIELD DATA SHEET

Firm Name Mattokkylä
 Plant Location Cismwell
 Test Number 1
 Sampling Location Inlet
 Project No. 586-20
 Date 8/27/80
 Tester JSS/LAS
 Orifice No. 1758
 Ambient Temp. 75 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 401
 Filter Ident. No. 51X
 Duct Area 8.3 ft²
 Orifice Coefficient 0.77
 Orifice Area 1.78
 Test Start Time 1019
 Test Final Time 1122
 Leak Test Start 5.00 CPM
 Leak Test Final 0.41 CPM

Nozzle No. & Dia. 0.363 in.
 Assumed Moisture 18 %
 Test Duration 60 min.
 Traverse Point Interval 3 min.
 Probe Heater Setting 250 °F
 Filter Temp. Setting 250 °F
 Dry Gas Meter Y 1.0425

Port	Point	Time Min.	Velocity ΔP in H ₂ O	ΔH in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
	5	30	15	157	118	98		156	85163			257	265	6	215		0.7
	6	31	15	196	118	99		155	85411			236	215	9	215		10
	7	32	15	280	120	100		152	85736			266	218	9	218		13
	8	33	15	257	120	101		150	85952			253	215	6	215		16
	9	34	15	237	120	102		148	86207			256	215	6	215		19
	10	35	15	137	120	103		147	86385			257	215	5	215		20
Average		Σ	ΣΔP	226	101			149	4905								

H₂O Collected 315 ml
 SG Condition Moist
 SG Weight 18.3 gm
 Total Volume Collected 333.3 ml

Orsat Bag Sample Triplicate Analysis, %

CO ₂	O ₂	N ₂
6.6	13.1	
6.6	13.1	
6.6	13.1	

COMMENTS:
 250
 165
 100
 515
 200
 315

FIELD DATA 9

Firm Name Martek Energy
 Plant location Cemex
 Test Number 2
 Sampling Location Incinerator Outlet
 Project No. 186-20
 Date 8/27/86
 Tester JSG/KAG

Orifice No. 1758
 Ambient Temp. 78 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 401
 Filter Ident. No. 501
 Duct Area 8.3 ft²

Nozzle No. & Dia. 0.362 in.
 Assumed Moisture 24
 Test Duration 860 min.
 Traverse Point Interval 3 min.
 Probe Heater Setting 250 °F
 Filter Temp. Setting 250 °F
 Dry Gas Meter Y 1.0025

Nomograph C Factor 0.68
 Pitot Coefficient 0.84
 Orifice C_d 1.78
 Test Start Time 1219
 Test Final Time 1321
 Leak Test Start 0.00 CFM @ 10 "Hg
 Leak Test Final 0.00 CFM @ 10 "Hg

10/22

Port	Point	Time Min.	Velocity ΔP in H ₂ O	All in H ₂ O	T _M in °F	T _M out °F	P Stack in H ₂ O	T Stack °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
	1	3:02	2.4	26.7	94	93		165	86.8	19		206	265	6	208		
	2	3:04	2.4	26.7	100	93		165	87.0	22		265		6	218		
	3	3:06	2.4	26.7	103	93	-0.16	164	87.3	25		254		7	217		
	4	3:08	2.4	26.7	108	94		162	87.6	28		258		7	213		
	5	3:10	2.4	27.5	111	95		161	87.9	31		270		7	211		
	6	3:12	2.4	28.2	113	95		163	88.1	34		288		6	217		
	7	3:14	2.4	26.7	114	97		164	88.4	37		283		7	218		
	8	3:16	2.4	24.0	116	98		166	88.6	40		293		7	201		
	9	3:18	2.1	21.3	116	98		165	88.8	43		287		6	203		
	10	3:20	2.1	14.8	116	99		164	89.0	46		289		5	228		
	1	3:22	2.2	22.8	116	99		157	89.3	49		286		7	234		
	2	3:24	2.2	25.9	118	100		158	89.6	51		284		8	236		
	3	3:26	2.4	26.7	118	102		158	89.8	54		281		8	230		
	4	3:28	2.4	26.7	120	103		158	89.9	57		280		7	221		
Average			$\Sigma \Delta P$														

Orsat Bag Sample
Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂

H₂O Collected _____ ml
 Si Condition _____
 Si Weight _____ gm
 Total Volume Collected _____ ml

COMMENTS: