

STAPPA / ALAPCC
2.5

#136 12/17/86
800064 81

PARTICULATE EMISSION TESTS
TOWN OF VERNON
MUNICIPAL SLUDGE INCINERATOR
FEBRUARY 10-11, 1981
VERNON, CONNECTICUT

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.



EDWARD D. ASTLE
ENVIRONMENTAL ENGINEER

MARCH 20, 1981

TRC PROJECT NO. 1438-E53

125 SILAS DEANE HIGHWAY
WETHERSFIELD
CONNECTICUT 06109
(203) 563-1431

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
1.0	INTRODUCTION.	1
2.0	SUMMARY AND CONCLUSION.	2
3.0	RESULTS AND DISCUSSION.	3
4.0	DESCRIPTION OF SAMPLING AREA.	6
5.0	PARTICULATE SAMPLING AND ANALYSIS METHODOLOGY	8

LIST OF TABLES

<u>Table</u>		
3-1	SUMMARY OF PARTICULATE TEST RESULTS OF VERNON MUNICIPAL SEWAGE SLUDGE INCINERATOR	4
3-2	SUMMARY OF FUEL CONSUMPTION AT VERNON MUNICIPAL SEWAGE SLUDGE INCINERATOR.	5
4-1	TRAVERSE POINT LOCATIONS.	7

LIST OF FIGURES

<u>Figure</u>		
4-1	SAMPLING PORT LOCATIONS	7
5-1	MODIFIED EPA PARTICULATE SAMPLING TRAIN	9

LIST OF APPENDICES

A	SOURCE TEST PLAN AND COMMUNICATIONS WITH CONNECTICUT DEP
B	COMPLETED DEP TEST REPORT DATA FORMS AND FUEL ANALYSIS
C	FIELD DATA SHEETS
D	CALIBRATION DATA, FILTER PREWEIGHTS AND LAB REPORT ON FILTER AND PROBE WASH
E	FUEL RATES (TIME, WEIGHT, RATE)
F	INCINERATOR OPERATING DATA
G	EMISSION CALCULATIONS
H	WEIGHT BELT CALIBRATION

1.0 INTRODUCTION

TRC-Environmental Consultants, Inc. was retained by Zimpro, Inc. to determine the particulate emission rate from the Town of Vernon Sewage Sludge Incinerator located in Vernon, Connecticut. This test program was conducted to satisfy the requirements of the Connecticut Department of Environmental Protection.¹

All tests were conducted in the breeching of the incinerator using methods and procedures described in the Intent to Test Form 800064, approved by the Department of Environmental Protection of the State of Connecticut on July 28, 1980. A copy of the Source Test Plan and letter of acceptance are included in Appendix A. The completed DEP test report data forms are in Appendix B. The test methods and procedures are also presented in Section 4.0 of this report.

The tests were conducted on February 10 and 11, 1981 by TRC's Edward D. Astle, Environmental Engineer; and Susan M. Reynolds, Technical Assistant. Incinerator operation was initiated and monitored by Mr. Jim Torreano of Zimpro, Inc., Rothschild, Wisconsin. Mr. David Sattler from the Connecticut DEP witnessed the testing.

¹Particulate: Section 19-508-18(d)(1) of the State of Connecticut Department of Environmental Protection Administrative Regulations for the Abatement of Air Pollution.

2.0 SUMMARY AND CONCLUSION

Three particulate emission tests were conducted on February 10 and 11, 1981. The average rate of emission was 0.32 pounds/ton of dry sludge for this testing program.

The results show that the incinerator is in compliance with the Connecticut Department of Environmental Protection Regulation of 1.3 pounds per ton of dry sludge.¹

¹ *ibid.*

3.0 RESULTS AND DISCUSSION

Table 3-1 summarizes the particulate emissions for the three tests run on the incinerator. Table 3-2 presents the process data - sludge and fuel oil consumption. The average particulate emission concentration from the incinerator was 0.315 pounds per ton of dry sludge, which is less than 25% of the allowable emission for sludge incinerators.

Test Number 3 was not included in the calculation of the average emission rate. A power outage in the town of Vernon during this test caused the test to be terminated at minute 117 of the 128 minute test. Mr. George Miller of the Connecticut Department of Environmental Protection was notified of the incomplete test and he agreed to waive the specification requiring three complete tests, if the remaining two tests met the specifications for sample size and sampling rate. A letter documenting the waiver is contained in Appendix A of this report.

TABLE 3-1

SUMMARY OF PARTICULATE TEST RESULTS
ON VERNON MUNICIPAL SEWAGE SLUDGE
INCINERATOR IN VERNON, CONNECTICUT
FEBRUARY 10-11, 1981

Test No.	Date	Time Period	Isokinetic Percentage	Volume Sampled (DSCF) ¹	Sampling Time Min.	Percent Moisture In Stack Gas	Air Flow ACFM	Particulate Emissions			
								Grains/ ACF	LB/Hr	Lbs/Ton of Dry Sludge	Emission Standard ²
1	2/10/81	1409-1631	99.1	102.70	128	2.6	6910	0.0058	.368	0.341	0.375, 1.3
2	2/11/81	1004-1225	100.9	84.17	128	3.7	5760	0.0043	.230	0.215	0.256, 1.3
3*	2/11/81	1413-1637	106.4	69.03	113.5	3.7	5140	0.0036	.171	0.132	0.221, 1.3
Average**				93.43	128	3.2	6340	0.0051	0.277	0.315	0.340 *

¹Standard Conditions: 68°F, 29.92 inches Hg, dry.

²Connecticut Department of Environmental Protection Air Laws, Section 19-508-18(d)(1).

*Test No. 3 test time was shortened by 10.5 minutes because of a power outage in the town of Vernon.

**Test No. 3 was not included in the average.

10/11.

Dry Loss Sludge/Hr.

per George Miller, 27 Dec 1981
Sims recommended these
numbers from the test
data

TABLE 3-2

SUMMARY OF FUEL CONSUMPTION AT
VERNON MUNICIPAL SEWAGE SLUDGE INCINERATOR
IN VERNON, CONNECTICUT
FEBRUARY 10-11, 1981

<u>Test No.</u>	<u>Wet Sludge Consumption Tons/Hr</u>	<u>Percent Moisture of Sludge</u>	<u>Tons of Dry Sludge/Hr</u>	<u>Gal/Hr</u>
1	2.72	66.5	0.911	43.2
2	2.38	65.0	0.833	44.0
3	1.75	65.9	0.597	37.6

4.0 DESCRIPTION OF SAMPLING AREA

TRC sampled two test ports located 90° apart in the 23.5" ID breeching. The ports were approximately three diameters downstream from the last direction change and approximately one diameter upstream from the discharge into the stack.

Zimpro bridged the four foot space between the roof's end and the stack with a platform that extended eight feet on either side of the breeching (See Figure 5-1). The platform was fitted with upper and lower safety rails. The upper rails were positioned 35"-44" above the platform.




FIGURE 4-1
SAMPLING PORT LOCATIONS

TRAVERSE POINT LOCATIONS

TABLE 4 -1

POINT NUMBER	DISTANCE-INSIDE WALL TO TRAVERSE POINT (INCHES)
1	0.38
2	1.15
3	2.00
4	2.94
5	3.94
6	5.17
7	6.65
8	8.81
9	14.69
10	16.85
11	18.33
12	19.53
13	20.56
14	21.50
15	22.35
16	23.12

5.0 PARTICULATE SAMPLING AND ANALYSIS METHODOLOGY

Complete sampling train calibrations were performed before the test program. The inside diameter of each nozzle was measured to the nearest 0.0001 in. with a micrometer. The probe pitot tubes were calibrated against a reference standard pitot tube in a 20" ID wind tunnel capable of velocities ranging from 0 to 100 fps. The dry gas meters and orifice meters were calibrated against a wet test meter. The chromelalumel thermocouples and indicators were calibrated electronically.

Particulate sampling was accomplished by using the modified EPA collection train, Method 5, described in the August 18, 1977 edition of the Federal Register. It is shown schematically in Figure 5-1 and consists of a nozzle, probe, filter, four impingers, vacuum pump, dry gas meter, and an orifice flow meter. TRC manufactures their own sampling train.

The nozzle (1) was attached to a stainless steel, glass-lined probe (2) that is wrapped with nichrome heating wire and jacketed to prevent condensation. Following the probe, the gas stream impacts on a 4-1/2 inch glass filter holder (3). Gelman Spectro Grade No. 64948 glass fiber filter media were used. The filter assembly is enclosed in a heated box (4) to maintain temperatures at $248^{\circ} \pm 25^{\circ}\text{F}$. An ice bath containing four impingers (5) was attached to the back end of the filter via a flexible umbilical cord. The first two impingers contained distilled water, the third was dry, and the fourth contained silica gel to remove any remaining moisture. Leaving the fourth impinger, the sample stream flows through a flexible tubing (6), a vacuum gauge (7) needle valve (8), a leakless vacuum pump (9) in parallel with a bypass valve (10) and a dry gas meter (11). A calibrated orifice and inclined manometer (12) completes the sampling train. The stack velocity pressure was measured using a pitot tube and inclined manometer (13). The stack temperature was monitored by a thermocouple that is attached to the pitot and connected to a potentiometer (14).




FIGURE 5-1: MODIFIED EPA PARTICULATE SAMPLING TRAIN
AUGUST 18, 1977. FEDERAL REGISTER

A nomograph was used to quickly determine the orifice pressure drop required for any pitot pressure and stack temperature in order to maintain isokinetic sampling conditions. Sampling flow was adjusted by means of a bypass valve. Before and after each particulate test run the sampling train was leak checked.

The data, test time, sampling duration at each traverse point, pitot pressure, stack pressure, was recorded at each sampling point. At the end of each test, three sample containers were used as follows:

- o Container No. 1 - Filter;
- o Container No. 2 - Acetone wash of probe and front half of filter.
The probe and nozzles are washed and brushed three times; and,
- o Container No. 3 - Silica gel from the fourth impinger.

The samples were then transported to TRC's laboratory and the following analyses were performed:

- o Container No. 1 - Transfer the filter, and any loose particulate matter from the sample container to a tared glass weighing dish, desiccate and dry to a constant weight. Report results to the nearest 0.1 mg.
- o Container No. 2 - Transfer the acetone washings to a tared beaker and evaporate to dryness at ambient temperature and pressure. Desiccate and dry to a constant weight. Report results to the nearest 0.1 mg.
- o Container No. 3 - Weigh silica gel to the nearest 0.5 g. The weight of the moisture entrapped in the silica gel, along with the volume of moisture which is condensed in the impingers, is used to calculate the moisture content of the flue gas.

A calculator program developed by TRC was used to calculate mass emission rates in pounds per dry standard cubic foot and also pounds per hour. The program also calculated percent moisture, molecular weight of stack gas at stack conditions and the percent isokinetics.

APPENDIX A

SOURCE TEST PLAN AND COMMUNICATIONS WITH CONNECTICUT DEP

July 11, 1980

Mr. Tony Calvo
Air Pollution Control Engineer
Air Quality - Enforcement
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06115

Re: TRC Project #1438-E53-00

Dear Tony:

Enclosed is TRC's Source Test Plan for Particulate Emissions Tests for Vernon Sewage Incinerator in Vernon, Connecticut for your review and approval.

If there are any questions, please contact Will Wade or myself.

Yours truly,

TRC-Environmental Consultants, Inc.



Edward D. Astle
Environmental Engineer

EDA/jjs



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION

STATE OFFICE BUILDING

HARTFORD, CONNECTICUT 06115

July 28, 1980



Mr. Edward D. Astle
Environmental Engineer
TRC Environmental Consultants, Inc.
125 Silas Deane Highway
Wethersfield, Conn. 06109

Dear Mr. Astle:

You are hereby notified that "Intent to Test" form #800064 which describes a test plan for sampling emissions from a sewage sludge incinerator, owned and operated by the Town of Vernon and located on Windsorville Road, Vernon, Connecticut, is acceptable subject to the following conditions and meets the test criteria required by the State of Connecticut, Department of Environmental Protection:

1. Sampling shall be conducted at a minimum of four minutes per point.
2. A calibration shall be performed on the sludge weighing system.
3. If a bypass stack exists, complete closure shall be demonstrated.

As part of a quality control program to assess weighing accuracy, the Department has instituted a procedure whereby six wafers of unknown weight are to be weighed coincidental with the various weight determinations specified by the "Method 5" test procedures. Three wafers are to be clearly identified as having been weighed during the filter tare weight determinations, and the remaining three are to be weighted concurrently with final filter and probe wash weight determinations and identified as having been weighed at that time. Please return the wafers with the report submittal.

The field tests will be observed by myself unless you are otherwise notified. I should be informed of progress and problems that may alter the test program. If you have any questions concerning the contents or intent of this letter, do not hesitate to contact either myself or Carl Dodge at 566-3310. Please complete the enclosed forms and include them in your test report,

Sincerely,

George T. Miller
Sr. Air Pollution Control Engineer

GTM:jr
Encs.



THE RESEARCH CORPORATION of New England

125 SILAS DEANE HIGHWAY, WETHERSFIELD, CONNECTICUT 06109

Environmental Consultants To Management

203 533-1431

December 1, 1978

Mr. Carleton L. Dodge
Principal Air Pollution Engr.
Air Quality-Monitoring
Dept. of Env. Protection
State Office Bldg.
Hartford, CT. 06115

re: TRC Project #51995

Dear Mr. Dodge:

Please find enclosed a copy of the "Source Test Plan for the Vernon Sewage Sludge Incinerator". I will meet with you and Mr. James Torreano of Zimpro, Inc. on Friday, December 8, 1978 at 9:00am in your office to review the plan.

If you have any questions, please contact Willard Wade or me.

Yours truly,

TRC-THE RESEARCH CORPORATION
of New England

Benjamin F. Brown
Senior Technical Specialist
Project Manager

BFB/jp

enc: Source Test Plan



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION

STATE OFFICE BUILDING

HARTFORD, CONNECTICUT 06115

December 12, 1978



Mr. Benjamin F. Brown
The Research Corp. of New England
125 Silas Deane Highway
Wethersfield, Conn. 06109

Dear Mr. Brown:

You are hereby notified that "Intent to Test" form #780062 which describes a test plan for sampling emissions from a sewage sludge incinerator, owned and operated by the Town of Vernon and located on Windsorville Road, Vernon, Connecticut, is acceptable subject to the following conditions and meets the test criteria required by the State of Connecticut, Department of Environmental Protection:

1. Sampling shall be conducted at a minimum of four (4) minutes per point.
2. In future Source Test Plans, please use revised Source Test Form #1 (enclosed).

The field tests will be observed by myself unless you are otherwise notified. I should be informed of progress and problems that may alter the test program. Please complete the enclosed forms and include them in your test report.

Very truly yours,

George T. Miller

George T. Miller
Air Pollution Control Engineer
Telephone 566-3310

GTM:jr
Encs.

cc: Mr. James Torreano
Vernon Sewage Sludge Incinerator

SOURCE TEST PLAN
FOR THE
VERNON SEWAGE
SLUDGE INCINERATOR



EDWARD D. ASTLE
PROJECT MANAGER

TRC PROJECT #1438-E53-00
JULY 10, 1980

125 SILAS DEANE HIGHWAY
WETHERSFIELD
CONNECTICUT 06109
(203) 563-1431

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
1.0	PURPOSE OF TESTS	1
2.0	SCOPE OF TESTS	2
3.0	DESCRIPTION OF OPERATION	3
4.0	OPERATIONAL PARAMETERS	4
5.0	DESCRIPTION OF SAMPLING AREA	5
6.0	SAMPLING AND ANALYSIS METHODOLOGY	7
6.1	Particulate	7
6.2	Flue Gas Sampling and Analysis	10
6.3	Sludge Sampling and Analysis	10
6.4	Oil Sampling and Analysis	10
 <u>Appendix</u>		
A	SOURCE TEST FORM #1	
B	FIELD DATA SHEET	

SOURCE TEST PLAN

CLIENT NAME: Zimpro, Inc.

TEST LOCATION: Vernon, Connecticut

SOURCE TO BE TESTED: Vernon Municipal Sewage Sludge Incinerator

PREPARED BY: Edward D. Astle

SCHEDULED TEST DATE: July 28, 1980

1.0 PURPOSE OF TESTS

The Town of Vernon has added a newly constructed, sewage sludge incinerator to their Wastewater Treatment Plant.

The New Source Performance Standards of the Clean Air Act require that a new sewage sludge incinerator comply with the emissions standard of 1.3 lb/ton of dry sludge input.

These tests will measure the particulate emissions from the incinerator to determine their compliance with emission and acceptance standards.

2.0 SCOPE OF TESTS

Triplicate particulate and flue gas composition measurements will be conducted on the incinerator gases after they exit the two stage, emissions impingement scrubber. Each particulate test will consist of two traverses across the 23.5" breeching duct with 16 points on a traverse. Each traverse point will be sampled for four (4) minutes in order to obtain a minimum sample volume of 30 DSCF. (The sampling interval per point may be increased if four (4) minutes per point does not provide a sufficient sample volume.)

An integrated gas sample will be collected during each particulate test and analyzed with an ORSAT for carbon dioxide and oxygen. The gas samples will be collected at the same locations that the particulate tests are being conducted.

During the tests the sewage sludge will be fed into the incinerator at the rate of 5,690 wet lb/hr with 20% solids and characteristics specified by the Town of Vernon.

Zimpro personnel will obtain sludge and oil samples in accordance with EPA Regulations on Standards of Performance for New Stationary Sources¹ for sewage treatment plants.

TRC will composite and have the sample analyzed in accordance with EPA Regulations¹ (see Sludge Sampling and Analysis, Page 10).

¹EPA Regulations On Standards of Performance For Stationary Sources, Part 60, Subpart O, Sewage Treatment Plants, Section 60.152.

3.0 DESCRIPTION OF OPERATION

The sewage sludge furnace at the Vernon, Connecticut facility is a Zimpro, Multiple Hearth, F-11C Incinerator. The sludge is conveyed into the top of the furnace and passes through a succession of six hearths which measure 16' 9" in diameter. This passage drives off residual moisture until the dry sludge ignites and burns. Ash from the furnace is carried via screw conveyors and a bucket elevator to a hopper. Another screw conveyor unloads the ash from the hopper into trucks.

Effluent gases exit the furnace and pass through a venturi and a two-stage impingement scrubber. After the scrubber, the gases are drawn through an ID fan and exhausted into a breeching and finally discharged up the stack.

Center shaft cooling is used to heat combustion air. The center shaft cooling can be diverted directly to the stack to heat the exhaust gases to a temperature of 1800°F.

The incinerator is designed for a feed rate of 5,690 lb/hr of wet filter cake with an 80% moisture content.

Gas pilots provide ignition for the incinerator which has auxiliary burners fired with number two fuel oil on each hearth level.

4.0 OPERATIONAL PARAMETERS

During the tests, Zimpro personnel will determine or monitor and record the following parameters:

1. Sludge feed rate (to be kept at approximately 5,690 lb/hr wet).
2. Fuel meter readings GPM (every 30 minutes).
3. All hearth and furnace outlet temperatures (every 30 minutes).
4. Scrubber inlet and outlet temperatures (every 30 minutes).
5. Venturi Delta Pressure and Scrubber Delta Pressure (every 30 minutes).
6. All scrubber water flow rates in GPM (every 30 minutes).
7. Burner conditions (on/off - every 30 minutes).

TRC will monitor and record:

1. Exhaust stack temperatures.
2. Ambient temperatures.
3. Barometric pressures.
4. Stack gas flow.
5. Visual checks of stack exhaust.
6. Test instruments.

5.0 DESCRIPTION OF SAMPLING AREA

TRC will sample at two test ports located 90° apart in the 23.5" ID breeching. The ports will be approximately 3 diameters downstream from the last direction change and approximately 1 diameter upstream from the discharge into the stack.

Zimpro will bridge the four foot space between the roof's end and the stack with a platform that will extend eight feet on either side of the breeching (See Figure 5-1). The platform will be fitted with upper and lower safety rails. The upper ones are to be positioned 35"-44" above the platform.




FIGURE 5-1

TABLE 5-1

POINT NUMBER	DISTANCE-INSIDE WALL TO TRAVERSE POINT (INCHES)
1	0.38
2	1.15
3	2.00
4	2.94
5	3.94
6	5.17
7	6.65
8	8.81
9	14.69
10	16.85
11	18.33
12	19.53
13	20.56
14	21.50
15	22.35
16	23.12

6.0 SAMPLING AND ANALYSIS METHODOLOGY

6.1 Particulate

Particulate sampling will be accomplished by using the modified EPA collection train, Method 5, described in the August 18, 1977 edition of the Federal Register. It is shown schematically in Figure 6 and consists of a nozzle, probe, filter, four impingers, vacuum pump, dry gas meter, and an orifice flow meter.

The nozzle (1) is stainless steel glass-lined probe (2) that is wrapped with nichrome heating wire and jacketed. This prevents condensation of the sampled gas. Following the probe, the gas stream impacts on a 4 1/2" glass filter holder. Reeve Angel filter paper is used. Enclosing the whole filter assembly is a heated box (4) to maintain temperatures above 250°F. Again, condensation is prevented. An ice bath containing four impingers (5) is attached to the back end of the filter via a flexible umbilical cord. All condensible material in the sample stream is collected here. The first two impingers contain distilled water, the third is dry and the fourth contains silica gel to remove any remaining moisture. Leaving the fourth impinger, the sample stream flows through flexible tubing (6), a vacuum gauge (7) needle valve (8), a leakless vacuum pump (9) in parallel with a bypass valve (10) and a dry gas meter (11). A calibrated orifice and inclined manometer (12) complete the sampling train. The stack velocity pressure is measured using a pitot tube and inclined manometer (13) and stack temperature is monitored by a thermocouple attached to the pitot and connected to a potentiometer (14).

A nomograph is used to quickly determine the orifice pressure drop required for any pitot velocity pressure and stack temperature in order to maintain isokinetic sampling conditions. Sampling flow is adjusted by means of the bypass valve.




FIGURE 6-1: MODIFIED EPA PARTICULATE SAMPLING TRAIN
AUGUST 18, 1977, FEDERAL REGISTER

Test data recorded will include test time, sampling duration at each traverse point, pitot pressure, stack temperature, meter volume, meter inlet-outlet temperature and orifice pressure drop. A sample field data sheet is included in Appendix A. At the end of each test, three sample containers will be used as follows:

Container #1 - Filter

Container #2 - Acetone wash of probe and front half of filter.

Container #3 - Silica gel from the fourth impinger.

The samples will be transported to TRC's laboratory and the following analyses performed:

Container #1 - Transfer the filter and any loose particulate matter from the sample container to a tared glass weighing dish, desiccate and dry to a constant weight. Report results to the nearest 0.1 mg.

Container #2 - Transfer the acetone washings to a tared beaker and evaporate to dryness at ambient temperature and pressure. Desiccate and dry to a constant weight. Report results to the nearest 0.1 mg.

Container #3 - Weigh silica gel to the nearest 0.5 g. The weight of the moisture entrapped in the silica gel, along with the volume of moisture which is condensed in the impingers, is used to calculate the moisture content of the flue gas.

A computer program developed by TRC is used to calculate mass emission rates in lb/hr, grain loading in grains per actual and grains per standard cubic foot, and the volume flow in the duct stack.

6.2 Flue Gas Sampling and Analysis

An integrated flue gas sample will be collected in a Saran bag during each test. The sampling apparatus consists of a probe which is attached to the particulate sampling probe to obtain a flue gas sample from the same locations in the stack from whence the particulate sample is withdrawn. An air cooled condenser is used to remove the water from the flue gas. The flue gas is pumped by a metal bellows (leakless) pump through a flow meter to the Saran or other inert, impervious bag.

Upon completion of the test run, the bag sample is analyzed by the use of an Orsat to determine the percentage composition of CO₂, O₂, and (by difference) N₂.

6.3 Sludge and Ash Sampling and Analysis

A sludge sample will be composited from the sludge burned during each of the three tests and analyzed in accordance with EPA regulations (Page 2) for moisture content by an outside contract laboratory. A portion of the sample will be given to the DEP test observer for any additional analyses that the enforcement agency deems necessary.

6.4 Oil Sampling and Analysis

A sample of the No. 2 fuel oil, which is fired in the auxiliary burners while the incinerator is in operation will be composited from the oil fired during the tests. The oil will be analyzed by an outside contract laboratory using ASTM methods for the following:

PROXIMATE ANALYSIS

API 60°F
BTU/lb
BTU/gal
Specific Gravity

ULTIMATE ANALYSIS

Carbon
Sulfur
Ash
Hydrogen
Nitrogen

APPENDIX A

SOURCE TEST FORM #1

SOURCE INFORMATION

Name Vernon Sewage Sludge Incinerator
 Address Windsorville Rd
Vernon, Connecticut

Person or Persons
 Responsible for tests
 Name James Torreano
 Telephone 872-3472

II TESTER INFORMATION

Name TRC-Environmental Consultants, Inc.
 Address 125 Silas Deane Hwy
Wethersfield, CT
 Signature Edward D. Ascoli
 Person Responsible for Tests
 Date July 9, 1980
 Proposed Test Date July 28, 1980

Person or Persons
 Responsible for Tests
 Name Edward D. Ascoli
 Telephone 563-1431

IV. IDENTIFY EQUIPMENT AND STACK TO BE TESTED

Stack # 187-65-P6-02

IV. Gas Stream Sampling Information. Identify all gas stream components to be sampled.

Component	Sampling Duration		Number of tests (Minimum of 3)	Expected Concentrations	Brief description of the test method to be used for each pollutant
	minutes per point	total test time			
1. Particulate	3	96	3	~ .75 lb/ton	EPA Method 5
2. CO ₂	3	96 (Inte- grated sample)	3	3-4%	ORSAT EPA Method 3
3. O ₂	3	96 (Inte- grated sample)	3	10-12%	ORSAT EPA Method 3
4.					
5.					

V. Stack Information: 1. Approx. gas temp. 120 OF
 3. Approx. percent moisture 6 %
 (percent by volume)

2. Approx. gas flow 8,000 A.C.F.M.
 4. Approx. gas density .07 lb/ft³ (at stack condition)

1. Presently under State Order? Yes No Order No.
 2. Been issued a Notice of Violation? Yes No Notice No.

VI. Is equipment or process to be tested: 1. testing to comply with 100 ton source test reg? Yes No
 3. applying for a permit to construct ? operate ? 4. testing to comply with 100 ton source test reg? Yes No
 5. testing to prove compliance Yes No 6. other (specify)

VII. Identification of documents requested on attached sheets

VIII X XII XIV
 IX XI XIII

APPENDIX B

FIELD DATA SHEET

APPENDIX B
COMPLETED DEP TEST REPORT DATA FORMS AND FUEL ANALYSIS

I.I.T. # 800064

Test Report Data Form #1-

Process Information: SEWAGE SLUDGE INCINERATORS

I. Results

TEST NUMBER

1

2

3

1. Particulates lb/ton of
dry sludge

TEST NUMBER	1	2	3	Avg.
Particulates lb/ton of dry sludge	0.374	0.256	0.221	0.284

II. Description

1. Maximum Feed Rate (lb/hr)

5690 lb/hr of wet filter cake

2. Normal Feed Rate

5690 lb/hr of wet filter cake

3. Method of Feeding

conveyed into top

4. Method of Stoking

oil burner

5. Fuel:

maximum firing rate (gal/hr, CFH)

148 gal/hr

type - ultimate and proximate analysis

6. Dampers:

method of activation

Pneumatic

location

III. Operating Parameters During Test

1. Actual Burner Firing Rate (gal/hr, CFH) 39 gal/hr

2. Material Incinerated:

Municipal sludge

% moisture

65.8%

feed rate (lb/hr)

incineration outlet temperature (s) (°F)

IV. Normal Operating Times

1. Hrs/Day

8

2. Days/Week

4

3. Weeks/Month

1

96 hr/month

4. Shut Down Period
(If Applicable)

ANY ADDITIONAL INFORMATION AVAILABLE:

THIS FORM MUST BE COMPLETED AND INCLUDED IN FINAL REPORT.

FF 1-1

L.T.T. # 800064

Test Report Data Form #2-5

Control Equipment Information: SCRUBBER

I. Description

- | | |
|---|---|
| 1. Scrubber Type
(e.g. cyclone, orifice, mechanical,
venturi, packed tower) | <u>venturi scrubber</u>
<u>with a quencher inlet</u>
<u>impingement cooling</u> |
| 2. Maximum Gas Volume Capacity (CFM) | <u>24036 cfm</u> |
| 3. Scrubber Diameter (Ft) | <u>Quencher dia. 2'5" square</u>
<u>impingement cooling dia. 4'6" ID cir.</u> |
| 4. Manufacturer | <u>Air Pollution Industries</u> |
| 5. Model Number | <u>Venturi scrubber with impingement cooling</u> |

II. Operating Parameters

- | | |
|--|---------------------------|
| 1. Inlet Gas Temperature (°F) | <u>1400</u> |
| 2. Outlet Gas Temperature (°F) | <u>90</u> |
| 3. Gas Pressure Drop Across Unit
(In. H ₂ O) | <u>27" H₂O</u> |
| 4. Outlet Gas Flow Rate (CFM) | <u>5837</u> |
| 5. Fan Horsepower | <u>45</u> |
| 6. Liquid Flow Rate (GPM) | <u>130 ppm</u> |
| 7. Injection Pressure (PSI) | <u>15 psi</u> |

III. For Packed Tower Scrubbers:

- | | |
|--|----------|
| 1. Type of Packing | <u>-</u> |
| 2. Packing Depth (Ft) | <u>-</u> |
| 3. Per Cent Free Volume of Packing | <u>-</u> |
| 4. Packing Surface Area (Ft ²) | <u>-</u> |

ANY ADDITIONAL INFORMATION AVAILABLE:

I. Test Data
(Particulate - E.P.A. Method 5)

TEST NUMBER

1 2 3

1. Volume Water Collected (ML):

impingers

385242

silica gel

19.7316.2713.88

2. Stack Pressure - Absolute (IN. HG)

30.2829.8229.64

3. Avg. Stack Temp. (°F)

134136143

4. Meter Volume (Actual Cubic Feet)

94.9282.0768.11

5. Avg. Meter Temperature (°F)

40.765760

6. Atmospheric Press. (IN. HG)

30.5529.9429.787. Avg. Orifice Press. Drop (IN. H₂O)1.991.391.10

8. Pitot Coefficient

0.840.840.849. Stack Area (Ft²)2.762.762.76

10. Nozzle Diameter (IN.)

0.25910.25910.2591

11. Total Test Time (Min.)

128128113.5

12. Heat Input (MBTU/HR)

13. Total Particulate Collected (MG)

43.327.516.0

14. Avg. Stack Temperature (°F)

13413614315. Avg. Velocity Press. Drop (IN. H₂O)0.5070.3430.268

II. ORSAT Analysis:

per cent CO₂5.66.66.5per cent O₂14.212.212.8

per cent CO

---III. Moisture Content (Per Cent H₂O)2.583.683.67

Fuel Engineering Company of New York

Energy and Environmental Services

30 CLAIRMONT AVENUE • THORNWOOD, N.Y. 10594 • (914) 769-7900

Test Report # 317180

Sample Identification
Project #1438-E53-20

#2 Fuel Oil
Composite Oil Sample

Date Received 2/18/1981

P.O. # 7728

Sampled by: (You) YES Date: _____

CERTIFICATE OF OIL ANALYSIS

Approved by [Signature]

Date Mailed 2/23/1981

Degrees API @60°F 35.3

Specific Gravity @60°F 0.8483

Flash Point °F _____

Bottom Sediment (incl water) _____

Sulfur % 0.38

BTU per pound 19402

BTU per gallon 137056

Viscosity @ _____ °F
@ _____ °F
@ _____ °F
@ _____ °F

Ash 0.006

Carbon 86.12

Hydrogen 12.89

Sulfur 0.38

Nitrogen 0.03

Oxygen 0.57

Water by Distillation _____

Sediment by Extraction _____

Pour Point _____

Fire Point _____

Freezing Point _____

TRC
125 Silas Deane Highway
Wethersfield, Connecticut 06109

CHEMICAL ANALYSIS

Sodium _____

Vanadium _____

Potassium _____

Iron _____

Lead _____

Nickel _____

Copper _____

Magnesium _____


Calcium _____

Manganese _____

Carbon Residue _____

Neutralization No. _____

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.



GILBERT ASSOCIATES, INC., P. O. Box 1498, Reading, PA 19603/Tel. 215 775-2600

CERTIFICATE OF ANALYSIS

LABORATORY NO: 6563 RECEIVED: 2/24/81 REPORTED: 3/6/81


CLIENT: TRC Environmental Consultants, Inc.
125 Silas Deane Highway, Wethersfield, CT 06109

SAMPLE DESCRIPTION: Sludge Analysis
Project No. 1438-E53-20
Test No. 3
No sampling date

- - - - -

	AS RECEIVED	DRY BASIS
% TOTAL MOISTURE	65.9	
% VOLATILE MATTER	13.9	40.7
HEATING VALUE - Btu/lb	1646	4828

Respectfully submitted,



R. M. Large - Chemist
Laboratory Services

OMD

cc: Ed Astle (3)

Gilbert/Commonwealth engineers and consultants

LABORATORY SERVICES
30 NOBLE STREET, READING PA 19611

GILBERT ASSOCIATES, INC., P. O. Box 1498, Reading, PA 19603/Tel. 215 775-2600

CERTIFICATE OF ANALYSIS

LABORATORY NO: 6562

RECEIVED: 2/24/81

REPORTED: 3/6/81

CLIENT:

TRC Environmental Consultants, Inc.
125 Silas Deane Highway, Wethersfield, CT 06109


SAMPLE DESCRIPTION:

Sludge Analysis
Project No. 1438-E53-20
Test No. 2
No sampling date

- - - - -

	AS RECEIVED	DRY BASIS
% TOTAL MOISTURE	65.0	
% VOLATILE MATTER	14.1	40.2
HEATING VALUE - Btu/lb	1698	4851

Respectfully submitted,



R. M. Large - Chemist
Laboratory Services

OMD

cc: Ed Astle (3)✓


GILBERT ASSOCIATES, INC., P. O. Box 1498, Reading, PA 19603/Tel. 215 775-2600

CERTIFICATE OF ANALYSIS

LABORATORY NO: 6561 RECEIVED: 2/24/81 REPORTED: 3/6/81
CLIENT: TRC Environmental Consultants, Inc.
125 Silas Deane Highway, Wethersfield, CT 06109
SAMPLE DESCRIPTION: Sludge Analysis
Project No. 1438-E53-20
Test No. 1
No sampling date

	AS RECEIVED	DRY BASIS
% TOTAL MOISTURE	66.5	
	13.1	39.2
% VOLATILE MATTER		
HEATING VALUE - Btu/lb	1636	4829

Respectfully submitted,


R. M. Large - Chemist
Laboratory Services

OMD

cc: Ed Astle (3)

APPENDIX C
FIELD DATA SHEETS

TRAVERSE POINT LOCATION FOR CIRCULAR DUCTS

PLANT Town of Vernon Sludge Incinerator
DATE 8/16/80
SAMPLING LOCATION Breeding
INSIDE OF FAR WALL TO
OUTSIDE OF NIPPLE, (DISTANCE A) _____
INSIDE OF NEAR WALL TO
OUTSIDE OF NIPPLE, (DISTANCE B) _____
STACK I.D., (DISTANCE A - DISTANCE B) 23 1/4"
NEAREST UPSTREAM DISTURBANCE _____
NEAREST DOWNSTREAM DISTURBANCE _____
CALCULATOR FDA

SCHEMATIC OF SAMPLING LOCATION

[illegible]

PRELIMINARY VELOCITY TRAVERSE

PLANT ZEMROC
DATE 2-10-91
LOCATION _____
STACK I.D. 22.5
BAROMETRIC PRESSURE, in. Hg 30.00
STACK GAUGE PRESSURE, in. H₂O -0.23
OPERATORS LOA / SMR
Cp 0.84

SCHEMATIC OF TRAVERSE POINT LAYOUT

TRAVERSE POINT NUMBER	VELOCITY HEAD (Δp_s), in. H ₂ O	STACK TEMPERATURE (T _s), °F
1	.75	131
2	.72	129
3	.7	133
4	.69	131
5	.66	136
6	.6	141
7	.55	145
* 8	.54	149
9	.47	157
10	.50	155
11	.52	154
12	.55	155
13	.52	153
14	.52	154
15	.47	147
16	.47	146
AVERAGE	70.157	146

EPA (Dur) 233
4/72

TRAVERSE POINT NUMBER	VELOCITY HEAD (Δp_s) , in. H ₂ O	STACK TEMPERATURE (T _s), °F
1	.50	139
2	.62	137
3	.65	134
4	.60	148
5	.62	134
6	.57	146
7	.56	147
* 8	.54	147
9	.57	147
10	.63	148
11	.60	140
12	.68	136
13	.62	137
14	.6	137
15	.62	132
16	.54	127
AVERAGE	.593	140

T.H. 583 T 143



FIELD DATA SHEET

Firm Name ZIMPRO
Plant Location LEARN-C
Test Number 1
Sampling Location STACK
TRC Project No. 1438-ES3
Date 2/10/91
Tester EDT/ABC

Orifice No. T-1
Ambient Temp. 40 °F
Bar. Press. 30.55 "Hg
Probe Ident. No. 29
Filter Ident. No. 10225
Duct Area 2.76 ft²

Nozzle No. & Dia. 0.2591 in.
Assumed Moisture 5 %
Test Duration 128 min.
Traverse Point Interval 4 min.
Probe Heater Setting 260±25 °F
Filter Temp. Setting 250±25 °F
Dry Gas Meter Y 100

Monograph C Factor 0.93
Pitot Coefficient 0.84
Orifice A1 1.83
Test Start Time 1409
Test Final Time 1631
Leak Test Start 0.000 CFM - 10 "Hg
Leak Test Final 0.000 CFM - 10 "Hg

PAGE 1083

Port	Point	Time Min.	Velocity ΔP in H ₂ O	Alt in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle β	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
1	1	41	72	275	41	41	-027	129	879	101		290	48	3.5	261		
2	2	70	70	276	42	41		132	882	60		282	48	3.5	250		
3	3	58	58	225	42	41		134	886	04		284	48	3.0	250		
4	4	53	53	205	42	41		137	889	36		280	48	3.0	260		
5	5	62	62	235	44	41		133	892	27		284	48	3.0	260		
6	6	63	63	240	42	41		140	895	47		276	48	3.5	250		
7	7	65	65	215	42	41		139	898	72		281	48	3.0	250		
8	8	65	65	200	42	41		143	901	84		282	48	3.0	250		
9	9	65	65	195	42	42		147	904	85		284	48	3.0	260		
10	10	64	64	185	41	42		150	907	79		277	48	3.0	250		
11	11	64	64	185	42	41		151	910	68		280	48	3.0	250		
12	12	64	64	185	42	41		152	913	55		269	48	3.0	250		
13	13	63	63	180	42	41		139	916	43		294	48	2.5	251		
14	14	64	64	160	42	41		140	919	00		276	48	2.5	250		
Average		Σ-ΔP															

Orsat Bag Sample
Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂
5.6	14.2	0	80.2
5.6	14.2	0	80.2

H₂O Collected 3.9 ml
SG Condition
SG Weight 19.73 gm
Total Volume Collected 57.73 ml

COMMENTS:



FIELD DATA SHEET

Firm Name 2. mpro Orifice No. T-1 Nozzle No. & Dia. 0.254 in.
Plant Location Waco, CR Ambient Temp. 40 °F Assumed Moisture 5 %
Test Number 1 Bar. Press. 30.65 "Hg Test Duration 128 min.
Sampling Location Stack Probe Ident. No. 29 Traverse Point Interval 4 min.
TRC Project No. 1438-ESS3 Filter Ident. No. 10225 Probe Heater Setting 260 ± 25 °F
Date 2/10/81 Duct Area 2.76 ft² Filter Temp. Setting 260 ± 25 °F
Tester EDA/3mpe Dry Gas Meter Y 1.00

PAGE #2063

Port	Point	Time Min.	Velocity ΔP in H ₂ O	All in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
1	15	4	0.40	15.5	41	41	-0.27	149	921.66	1		273	48	2.5	250		
2	16	7	0.40	15.5	41	41		137	924.80	1		286	48	2.5	250		
3	1	4	0.41	23.5	40	40	-0.27	129	926.93	1		285	48	3.5	250		
4	2	1	0.42	23.5	40	40		121	930.14	1		280	48	3.5	250		
5	3	1	0.43	24.0	40	40		124	933.36	1		278	48	3.5	250		
6	4	1	0.58	22.5	40	40		124	936.63	1		278	48	3.5	250		
7	5	1	0.57	22.0	41	40		123	939.78	1		284	48	3.5	253		
8	6	1	0.54	21.0	40	40		126	942.99	1		277	48	3.5	250		
9	7	1	0.54	22.0	40	40		126	945.96	1		275	48	3.5	250		
10	8	1	0.55	21.5	41	40		126	949.07	1		275	48	3.5	254		
11	9	1	0.54	23.0	41	40		127	952.15	1		280	48	3.5	251		
12	10	1	0.65	25.0	41	40		128	955.34	1		280	48	3.5	250		
13	11	1	0.45	17.5	41	40		126	958.67	1		280	48	3.5	262		
Average		Σ-ΔP															3.13

Orsat Bag Sample Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂
5.6	14.2	0	80.2
5.6	14.2	0	80.2

H₂O Collected 38 ml
SG Condition 19.73 g/m
SG Weight 57.73 ml
Total Volume Collected

COMMENTS:

Firm Name Zimpro Inc
Plant Location Vancouver, Cn
Test Number 1
Sampling Location STACK
TMC Project No. 1438-E53
Date 2/10/81
Tester EDA

Orifice No. T-1
Ambient Temp. 70 °F
Bar. Press. 30.55 "Hg
Probe Ident. No. 29
Filter Ident. No. 10235
Duct Area 2.76 ft²

Nozzle No. & Dia. 0.2541 in.
Assumed Moisture 5 %
Test Duration 12h min.
Traverse Point Interval 4 min.
Probe Heater Setting 350 ± 25 °F
Filter Temp. Setting 250 ± 25 °F
Dry Gas Meter Y 1.00

Nonograph	
C factor	0.93
Pitot Coefficient	0.84
Orifice ΔH	1.83
Test Start Time	1409
Test Final Time	1637
Leak Test Start	0000
Leak Test Final	0.000
	-10
	-10

Page 6 of 3

Port	Point	Time Min.	Velocity ΔP in H ₂ O	All in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle β	Heater Box Temp.	Temp. of Gas Leaving Condenser OF	Pump Vac. in lig	Probe Temp. °F	O ₂ %	CO ₂ %
2	12	9	.037	145	40	40	-0.27	139	96.153			280	48	2.0	252		
	13	11	.033	130	40	40		137	96.410			270	48	2.0	250		
	14	11	.034	135	40	40		134	96.654			275	48	2.0	250		
	15	11	.034	135	40	40		131	96.904			280	48	2.0	250		
	16	11	.034	135	39	40		131	97.152			280	48		250		
									97.402								
Average			$\Sigma \Delta P$	149			-0.27	134	94.92								


40.76

97.12

1120 Collected	38.44	ml
SG Condition		
SG Weight	19.73	gm
Total Volume Collected	57.73	ml

Orsat Bag Sample Triplicate Analysis, %				
CO ₂	O ₂	CO	N ₂	
5.6	14.2	0	80.2	
5.6	14.2	0	80.2	

COMMENTS:



FIELD DATA SHEET

Firm Name Zimpro
Plant Location Kenia
Test Number #2
Sampling Location STACK
TRC Project No. 1438-ES3
Date 2/1/81
Tester EDA/SMP

Orifice No. T-1
Ambient Temp. 50 °F
Bar. Press. 29.94 "Hg
Probe Ident. No. 29
Filter Ident. No. 10206
Duct Area 2.76 ft²

Nozzle No. & Dia. 0.2591 in.
Assumed Moisture 3.0 min.
Test Duration 128 min.
Traverse Point Interval 4 min.
Probe Heater Setting 250±15 °F
Filter Temp. Setting 280±35 °F
Dry Gas Meter Y 1.00

Nonograph
C Factor 0.73
Pitot Coefficient 0.84
Orifice Δh 1.83
Test Start Time 10:04
Test Final Time
Leak Test Start 0.000 CH# -6 "Hg
Leak Test Final 0.000 CH# -4 "Hg

PAGE#1023

Port	Point	Time Min.	Velocity AP in H ₂ O	Alt in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle #	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
1	1	4	049	19.5	53	53	-0.10	117	97.4	74		260	56	3.0	250		
2	2	1	040	16.0	53	53		121	97.7	76		260	56	3.0	251		
3	3	1	039	15.5	53	53		121	98.0	52		275	56	2.5	250		
4	4	1	037	14.5	54	54		125	98.3	21		287	54	2.0	255		
5	5	1	012	04.9	55	54		127	98.5	85		285	54	1.0	250		
6	6	1	012	04.9	55	54		121	98.7	69		276	54	1.0	250		
7	7	1	044	17.5	55	54		121	98.9	27		280	54	3.0	250		
8	8	1	046	18.0	56	55		139	99.1	98		284	54	3.0	250		
9	9	1	035	14.0	56	55		139	99.4	87		285	54	3.0	253		
10	10	1	035	14.0	56	56		144	99.7	49		282	54	3.0	257		
11	11	1	036	14.0	56	56		148	100.0	06		273	54	3.0	261		
12	12	1	033	13.0	56	56		151	100.2	64		283	54	3.0	261		
13	13	1	031	12.5	57	57		155	100.5	14		281	54	3.0	261		
14	14	1	030	12.0	57	56		158	100.7	59		279	54	2.0	260		
Average		$\Sigma \Delta P$															

Orsat Bag Sample
Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂
6.6	12.2	0	81.2
6.6	12.2	0	81.2
6.6	12.3	0	81.1

H₂O Collected 5.2 ml
SG Condition 16.27 gm
SG Weight 68.27 ml
Total Volume Collected

COMMENTS: AS OPERATOR AND MAY
ARE RUNNING 3 Ton Sludge
PLEASE STOPPED AT THE WAY INSIDE

Firm Name Zimpro
 Plant Location Vermont
 Test Number #2
 Sampling Location Stack
 Location Brackburn
 TRC Project No. 1428-ES3
 Date 2/4/84
 Tester EDR/SMR

Orifice No. T-1
 Ambient Temp. 50 °F
 Bar. Press. 29.94 "Hg
 Probe Ident. No. 29
 Filter Ident. No. 1000010206
 Duct Area 2.76 ft²

Nozzle No. & Dia. G-2591 in.
 Assumed Moisture 3.0 %
 Test Duration 126 min.
 Traverse Point Interval 4 min.
 Probe Heater Setting 250 ± 25 °F
 Filter Temp. Setting 250 ± 25 °F
 Dry Gas Meter Y 1.00

Nomograph C Factor 0.13
 Pitot Coefficient 0.84
 Orifice Δh 1.83
 Test Start Time 10:04
 Test Final Time
 Leak Test Start 0:00 CIME -6 "Hg
 Leak Test Final 0:00 CIME -4 "Hg

Page #2 of 3

Port	Point	Time Min.	Velocity ΔP in H ₂ O	Δh in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
1	15	4	030	120	57	57	-0.10	157	101000			271	54	2.0	261		
2	16	1	030	120	57	57		145	101240			274	54	2.0	260		
3	1	4	37	145	57	57	-0.14	140	101474			267	54	2.0	253		
4	2	1	42	165	58	58		136	101742			273	54	2.0	256		
5	3	1	43	170	58	58		130	102020			276	54	3.0	286		
6	4	1	43	170	58	58		132	102305			276	54	3.0	286		
7	5	1	38	150	58	58		136	102591			267	54	3.0	257		
8	6	1	44	175	58	58		130	102862			268	54	3.0	286		
9	7	1	39	155	58	58		138	103149			268	54	3.0	255		
10	8	1	43	170	58	58		134	103423			263	54	3.0	256		
11	9	1	34	135	59	59		141	103706			262	54	3.0	260		
12	10	1	31	125	59	59		145	103974			284	54	3.0	261		
13	11	1	29	115	59	59		130	104212			262	54	3.0	259		
Average		$\Sigma \Delta P$															

Orsat Bag Sample Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂
6.6	12.2	0	81.2
6.6	12.2	0	81.2
6.6	12.3	0	81.1

H₂O Collected 52 ml
 SG Condition
 SG Weight 16.27 gm
 Total Volume Collected 68.27 ml

COMMENTS: Asst was dropped out of survey
Point

Firm Name Ziv-Pro Orifice No. T-1 Nozzle No. & Dia. 0.2591 in.
 Plant Location Venues Ct Ambient Temp. 50 °F Assumed Moisture 30 %
 Test Number 2 Bar. Press. 29.94 "Hg Test Duration 128 min.
 Sampling Location STACK Probe Ident. No. 29 Traverse Point Interval Y min.
 Location BAIECHANG Filter Ident. No. 10249? Probe Heater Setting 250 ± 25 °F
 TRC Project No. 1436-E53 Filter Temp. Setting 250 ± 25 °F
 Date 2/11/84 Duct Area 2.76 ft² Dry Gas Meter Y 1.00
 Tester EDD/AMF DA 22.5"

Page # 3083

Port	Point	Time Min.	Velocity ΔP in H ₂ O	Alt in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle β	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
2	12	4	32	12.5	59	59	-0.14	138	104452			262	54	2.0	257		
	13	1	31	12.5	59	59		134	104695			267	54	2.0	256		
	14	1	31	12.5	59	59		132	104943			267	54	2.0	256		
	15	1	31	12.5	59	59		130	105200			266	54	2.0	257		
	16	1	31	12.5	59	59		130	105438			273	54	2.0	257		
	17								105681								
Average																	
Σ-ΔP																	

H₂O Collected 52 ml Orsat Bag Sample Triplicate Analysis, %
 SG Condition same - base little bit O₂ CO N₂
 SG Weight 16.27 gm 6.6 12.2 6.6
 Total Volume Collected 68.27 ml 6.6 12.2 6.6

COMMENTS:

Firm Name Zimpro
 Plant Location BRAC
 Test Number 3
 Sampling Location BRAC
 TRC Project No. 1438-ES3
 Date 02/11/84
 Tester IDA/SMP
 Orifice No. T-1
 Ambient Temp. 50 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 29
 Filter Ident. No. 10227
 Duct Area 2.76 ft²
 Nozzle No. & Dia. 0.2591 in.
 Assumed Moisture 3 %
 Test Duration 113.5 min.
 Traverse Point Interval 4 min.
 Probe Heater Setting 250 ± 25 °F
 Filter Temp. Setting 250 ± 25 °F
 Dry Gas Meter Y 1.00
 Nomograph C Factor 0.98
 Pitot Coefficient 0.84
 Orifice dia. 1.83
 Test Start Time 1413
 Test Final Time 1637
 Leak Test Start 0.000 CME -8 "Hg
 Leak Test Final 0.000 CME -8 "Hg

Page #1083

Port	Point	Time Min.	Velocity ΔP in H ₂ O	ΔH in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle β	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
2	1	41	0.37	1.50	60	61	-0.14	120	57	16		286	54	2.5	250		
	2	41	0.33	1.40	60	61		121	59	96		286	56	2.5	250		
	3	41	0.29	1.20	61	60		127	62	57		283	60	2.5	250		
	4	41	0.32	1.30	60	61		137	65	02		283	62	2.0	250		
	5	41	0.28	1.15	60	61		144	67	53		280	52	1.5	250		
	6	41	0.26	1.05	60	60		150	69	43		282	52	1.5	250		
	7	41	0.24	0.97	60	61		152	72	19		285	52	1.5	250		
	8	41	0.24	0.97	60	60		145	74	39		280	50	1.0	250		
	9	41	0.24	0.97	60	60		135	76	60		281	50	1.0	250		
	10	41	0.29	1.20	60	60		135	78	77		277	50	1.5	250		
	11	41	0.22	0.88	59	60		130	81	20		276	50	1.5	250		
	12	41	0.27	1.10	60	60		140	83	33		272	50	1.5	250		
	13	41	0.25	1.00	59	60		144	85	63		276	50	1.5	250		
	14	41	0.26	1.05	59	60		134	87	85		276	50	1.5	250		
Average			Σ ΔP														

Orsat Bag Sample

Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂
6.5	13.2		80.3
6.5	13.0		80.5
6.5	12.3		81.2

COMMENTS:

H₂O Collected 42 ml
 SG Condition 13.88
 SG Weight 81.2 gm
 Total Volume Collected 55.88 ml

Firm Name Zimmer
 Plant Location Verona CT
 Test Number 3
 Sampling Location Stack
 TRC Project No. 1438-653
 Date 2/11/61
 Tester DDA/SUE

Orifice No. T-1
 Ambient Temp. 50 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 27
 Filter Ident. No. 10227
 Duct Area 2.76 ft²
214 22.5

Nozzle No. & Dia. 4 0.2591 in.
 Assumed Moisture 3
 Test Duration 113.5 min.
 Traverse Point Interval 4
 Probe Heater Setting 250 ± 25 °F
 Filter Temp. Setting 250 ± 25 °F
 Dry Gas Meter Y 100

Page # 2 of 3

Port	Point	Time Min.	Velocity ΔP in H ₂ O	ΔH in H ₂ O	T _M in °F	T _M out °F	P _{Stack} in H ₂ O	T _{Stack} °F	Gas Sample Volume cu. ft.	P R O B E	Cyc. Angle	Heater Box Temp.	Temp. of Gas Leaving Condenser °F	Pump Vac. in Hg	Probe Temp. °F	O ₂ %	CO ₂ %
2	15	41	0.25	1.00	59	60	-0.14	145	90	1	1	276	50	1.5	250		
	16	42	0.25	1.00	60	60		159	92	3	3	276	50	1.5	250		
									94	58							
1	1	43	0.34	1.40	60	60	-0.15	136	94	59		280	50	2.0	250		
	2	44	0.40	1.65	60	60		135	97	28		250	50	2.0	250		
	3	45	0.30	1.20	61	61		131	100	08		298	50	2.0	250		
	4	46	0.28	1.15	60	61		138	102	53		273	50	2.0	250		
	5	47	0.29	1.15	60	61		120	104	91		260	50	2.0	250		
	6	48	0.25	1.00	60	60		135	107	28		281	50	2.0	250		
	7	49	0.25	1.00	61	61		143	109	51		261	50	2.0	250		
	8	50	0.26	1.05	61	60		145	111	73		276	52	2.0	250		
	9	51	0.24	0.97	61	61		154	114	00		274	52	2.0	250		
	10	52	0.22	0.88	61	61		163	116	20		284	54	2.0	250		
	11	53	0.23	0.93	61	61		145	118	31		270	54	2.0	250		
Average		Σ-ΔP															

Orsat Bag Sample Triplicate Analysis, %

CO ₂	O ₂	CO	N ₂
6.5	13.2	0	80.3
6.5	13.0	0	80.5
6.5	12.3	0	81.2

H₂O Collected 42 ml
 SG Condition
 SG Weight 13.88 gm
 Total Volume Collected 55.88 ml

COMMENTS:

There are readings towards
 Sludge. 30%
 The Draft fan keeps going
 on and off



FIELD DATA SHEET

Orifice No. 1-1
 Ambient Temp. 50 °F
 Bar. Press. 29.78 "Hg
 Probe Ident. No. 29
 Filter Ident. No. 10227
 Duct Area 2.76 ft²

C Factor 0.98
 Pilot Coefficient 0.84
 Orifice d_A 1.83
 Test Start Time 1413
 Test Final Time 1637
 Leak Test Start 0.000 C_{100} -8 ^{11}g
 Leak Test Final 0.000 C_{100} -8 ^{11}g

Tester CPD FNPAverage

COMMENTS:

H ₂ O Collected	42 ml
SG Condition	
SG Weight	13.88 gm
Total Volume Collected	55.88 ml

APPENDIX D


CALIBRATION DATA, FILTER PREWEIGHTS AND
LAB REPORT ON FILTER AND PROBE WASH

S-TYPE PITOT GEOMETRIC CALIBRATION
PART 1 - PROBE CONFIGURATION


Procedure No. T/S-811
 Revision No. 1
 Date December 9, 1980
 Page of

TRC Probe Identification 29
 Technical Specialist LAG
 Date 2/9/01


Pitot Identification



D_t 0.250
 D_n 0.500
 a 0.859




P_a 0.560
 P_b 0.560
 b 0.841



c
 d
 e

OR



c 0.625
 f NA

Specifications (EPA Method 2)

$D_t = 3/16"$ to $3/8"$
 $D_n = 1/2"$
 $a \geq 3/4"$
 $b \geq 0$

$c \geq 3"$
 $d \geq 3"$
 $e \geq 3/4"$
 $f \geq 2"$

$P_a = P_b$
 $1.05 D_t \leq P \leq 1.50 D_t$

If these specifications are met, proceed with Part 2 Pitot alignment.


S-TYPE PITOT GEOMETRIC CALIBRATION
PART 2 - PITOT ALIGNMENT

TRC Probe Identification 29
Technical Specialist LAG
Date 2/9/81

Pitot Identification

A.

Transverse
Tube Axis



a 1.120
b 0.386
c 1.159
d 0.386
e 1.160
 θ 86.6
 θ' 86.2

$$\frac{a^2 + b^2 - c^2}{2ab} = \cos \theta$$


$$\frac{a^2 + d^2 - e^2}{2ad} = \cos \theta'$$

$$(80^\circ < \theta < 100^\circ)$$

$$(80^\circ < \theta' < 100^\circ)$$

B.

Longitudinal
Tube
Axis



a 1.125
b 0.550
c 1.252
d 0.550
e 1.255
 θ 90.0
 θ' 90.3


$$\frac{a^2 + b^2 - c^2}{2ab} = \cos \theta$$

$$\frac{a^2 + d^2 - e^2}{2ad} = \cos \theta'$$

$$(85^\circ < \theta < 95^\circ)$$

$$(85^\circ < \theta' < 95^\circ)$$

C.



f < 1/8"

(f < 1/8")

D.



g < 1/32"

(g < 1/32")

NOTE: values in parentheses are EPA Method 2 specifications.

PROBE THERMOCOUPLE CALIBRATION

Tolerances

Expected Stack Temperature (T_s) °R

Mercury Thermometer (T_{ref}) °R

Thermocouple Readout °R

Probe Identification

Technician

Date

($T_s \pm 10\%$)

($T_{ref} \pm 1.5\%$)

DATE 02/05/81 ORIFICE J T-1 NAME GAMMIE

BAROMETRIC PRESSURE 30.27 IN HG DRY GAS METER NO 1

ORIFICE GAS VOLUME TEMPERATURE
HANDMETER WET TEST DRY GAS WET TEST DRY GAS METER
SETTING METER METER METER INLET OUTLET AVERAGE TIME
IN WATER CU FT CU FT F F F MIN RATIO DHO

0.5 5.0 5.05 72.0 80.0 79.0 79.5 12.6 1.00 1.75
1.0 5.0 5.05 72.0 80.0 79.0 79.5 9.2 1.00 1.85
2.0 10.0 10.07 72.0 80.0 80.0 80.0 13.0 1.00 1.85
3.0 10.0 10.10 72.0 80.0 80.0 80.0 10.7 1.00 1.88

AVERAGE 1.00 1.83

DATE 11/29/77

INSPECTION REPORT

ELFRED MACHINE COMPANY

CUSTOMER TRC - THE RESEARCH CORP.

CUSTOMER P.O. NO. 9964

S.O. NUMBER

PURCHASED FROM ELFRED P.O. NO.

PART NO.

NO. PIECES ORDERED 1 NO. PIECES RECEIVED 1

TOOL NO.

PART NAME ST/STL NOZZLE

TOOL NAME

[illegible]

1st PIECE INSPECTION

PARTIAL INSPECTION

COMPLETE INSPECTION

ACCEPTED

REJECTED

INSPECTOR

RED MACHINE COMPANY
165 JORDAN LANE
WETHERFIELD, CONN. 06109

FILTER WEIGHTS

- ☐ Put in Oven
☐ Not put in Oven
☒ Pre-weight
☐ Post-weight

Client: HEALTHTEX

Project No.: 1533-E32

Date					
Time	1000	5:30			
Temp.	70°	70°			
Humidity	18%	15%			
Initials	-SMR	SMR			
Filter Number	Wt. 1(g)	Wt. 2(g)	Wt. 3(g)	Wt. 4(g)	Final Ave. Weight
10191	0.8549 ✓	0.8546 ✓			0.85475
10192	0.8518 ✓	0.8518 ✓			0.8518
10193	0.8497 ✓	0.8499 ✓			0.8495
10194	0.8532 ✓	0.8529 ✓			0.85305
10195	0.8475 ✓	0.8474 ✓			0.84745
✓ 2-17-81 EMS 10196 Skunkley Wats	0.8253	0.8248	0.8251	0.8249 ✓	0.82495
10197	0.8264 ✓	0.8262 ✓			0.8263
10198	0.8355 ✓	0.8355 ✓			0.8355
10199	0.8284 ✓	0.8284 ✓			0.8284
10200	0.8185 ✓	0.8183 ✓			0.8184
10201	0.8334	0.8333			0.83335
10202	0.8311 ✓	0.8309 ✓			0.8310
10203	0.8406 ✓	0.8444 ✓	0.8421	0.8410	
10204	0.8381 ✓	0.8378 ✓			0.83795
10205	0.8528	0.8420 ✓	0.8423 ✓		0.8425
✓ Zimpio 2-18-81 EMS 10206	0.8364 ✓	0.8362 ✓			0.8363
10207	0.8303 ✓	0.8305 ✓			0.8304
10208	0.8269 ✓	0.8269 ✓			0.8269
10209	0.8317 ✓	0.8315 ✓			0.8316
10210	0.8224 ✓	0.8224 ✓			0.8224
10211	0.8657	0.8656			0.86568

FILTER WEIGHTS

- ☐ Put in Oven
☐ Not put in Oven
☒ Pre-weight
☐ Post-weight

Client: GETTY

Project No.: 1421-E31

	Date				
	Time	11-81	1-20-81		
	Temp.	0900	3:30		
	Humidity	68°	20-72°		
	Initials	1790	2070		
		-SMR	Smr		
Filter Number	Wt. 1(g)	Wt. 2(g)	Wt. 3(g)	Wt. 4(g)	Final Ave. Weight
✓ 10223 Stanley Works	0.8500 ✓	0.8502 ✓		0.8500	0.8501
10224	0.8403	0.8484 0.8530	0.8443	0.8398	
✓ 10225 Zimpro 2-18-81 emb	0.8439 ✓ 0.8559 ✓	0.8559 ✓			0.8559
10226	0.8574	0.8574	0.8594	0.8566	
✓ 10227 Zimpro 2-18-81 emb	0.8461 ✓	0.8461 ✓			0.8461
✓ 10228 Stanley Works	0.8590 ✓	0.8588 ✓	0.8589		0.8589
✓ 10229 emb 1/2" dia	0.8598 ✓	0.8599 ✓	0.8598	ck	0.85985
✓ 10230 emb 1/2" dia	0.8575 ✓	0.8575 ✓	0.8575	7 wk	0.8575
✓ 10231 ↓	0.8610 ✓	0.8610 ✓	0.8612		0.8610
10232	0.8513 ✓	0.8513 ✓			0.8513
10233	0.8546 ✓	0.8545 ✓			0.85455
10234	0.8543 ✓	0.8543 ✓			0.8543
10235	0.8498 ✓	0.8497 ✓			0.84975
10236	0.8496 ✓	0.8496 ✓			0.8496
10237	0.8469 ✓	0.8469 ✓			0.8469
10238	0.8519 ✓	0.8521 ✓			0.8520
10239	0.8545 ✓	0.8542 ✓			0.85435
10240	0.8524	0.8678			

Laboratory No: 277-611

Date Received: 2-12-81

Date Reported: 2-20-81

Date Reported: 2-20-81

[illegible]

APPENDIX E

FUEL RATES (TIME, WEIGHT, RATE)

Vernon Immanuel 2/11/81

Time	Sludge wt (lbs)	Oil (gallons)	Water Soil Water (gpm)	Venturi Scrubber Soil Water (gpm)
0900	219.625	6291	41	125
0930	220.675	62935	39	130
1000	221.515	62958	37	130
1030	223.030	62984	42	130
1100	224.370	63006	42	130
1130	225.400	63028	42	130
1200	226.718	63045	42	130
1230	227.774	63068	42	130
1300 *	229.017	63087	40	130
1330	229.599	63108	39	130
1400	230.750	63132	40	130
1430	231.803	63157	40	130
1500 ***	233.030	63175	40	130
1530	233.816	63194	40	125
1600	234.774	63211	40	125
1630	235.119	63226	40	130
1700	Test ended at 1630 due to power failure			

* Lost the filter at 1305. Filter back online at 1335.

up lost filter for 10 minutes

Vernon Immanuel Test 2/14/81

Time	Sludge wt (lbs)	Oil (gallons)	Water Soil Water (gpm)	Venturi Scrubber Soil Water (gpm)
1400	18540	61959	40	125
1430	186575	61976	40	125
1500	187530	61994	40	125
1530	188225	62017	40	125
1600	189310	62040	40	125
1630	190342	62067	40	125
1700	191070	62095	40	125
1730	192187	62127	40	125
1800	192690	62141	40	125
1830	193684	62173	42	125
1900	194703	62205	42	125
1930	195791	62234	42	125
2000	196873	62263	42	125
2030	197841	62296	42	125
2100	198855	62311	42	125
2130	199891	62336	42	125
2200	200669	62361	42	125
2230	201507	62388	42	125
2300	202201	62414	42	125

APPENDIX F
INCINERATOR OPERATING DATA

Operator: John J. Garry
John J. Garry

INCINERATOR CONTROL PANEL, SHEET 1, FOR VERNON, CONN.

Date: 2/11/81

Acceptance Test Record every 1/2 hour

Time	Temperature Recorder (TJR-10)						System Controllers										Water				Temperature Indicators				Draft
	Heat No. 1	Heat No. 2	Heat No. 3	Heat No. 4	Heat No. 5	Heat No. 6	Shaft Cooling Air	Scrubber Gas Discharge	Off Gas	Sludge Comb. Air	Fan Damper	Venturi Scrubber AP	PIC Incinerator	TIC Heart No. 1	TIC Heart No. 2	TIC Heart No. 4	TIC Heart No. 5	Impingement Scrubber	Venturi Scrubber	Heart No. 1	Heart No. 2	Heart No. 4	Heart No. 5		
1700	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	
1730	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	
1800	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	
1830	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	147	
1900	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	
1930	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	
2000	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	
2030	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	151	
2100	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	
2130	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	
2200	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	
2230	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	155	
2300	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	
2330	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	
2400	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	158	

OIL METER Finish
 Start 624.20
 Total

1400 L.T. #2 1400 off #2 Center shaft 12
 1400 off #3

1500 1-5'6" Burner's Center shaft 10
 1500 1-5'6" "

APPENDIX G
EMISSION CALCULATIONS

INCINERATOR TEST DATA

TEST 1 TIME 1409-1631
 LOCATION STACK BREACHING DATE 2-10-81
 FIRM ZIMPRO PROJECT NO. 1438-E53

Input A

P bar	Barometric Pressure - in. Hg	<u>30.55</u>
As	Stack Area - Ft ²	<u>2.76</u>
Dn	Nozzle Diameter - in.	<u>0.259</u>
Time	Total Sampling Time - min.	<u>128</u>
Y	Calibration Factor	<u>1.00</u>
Cp	Pitot Coefficient	<u>0.84</u>
(ΔP) ^{1/2}	Average Square Root of Vel. Head in. H ₂ O	<u>.712</u>
ΔH	Average Orifice Pressure Drop	<u>1.99</u>
Tm	Average Meter Temperature - °F	<u>40.76</u>
P stk	Average Stack Pressure - in H ₂ O	<u>-.87</u>
T stk	Average Stack Temperature - °F	<u>134</u>
Vm	Meter Volume at Meter Conditions - Ft ³	<u>94.92</u>
Vl	Total Water Vapor Collected	<u>57.73</u>
CO ₂	% CO ₂ in Stack Gas (Dry)	<u>5.6</u>
O ₂	% O ₂ in Stack Gas (Dry)	<u>14.2</u>
CO	% CO in Stack Gas (Dry)	<u>0</u>

Input B

Mh	Total Particulate Catch	<u>43.3</u>
----	-------------------------	-------------

Input C

% H	% Hydrogen in Fuel	
% C	% Carbon in Fuel	
% S	% Sulfur in Fuel	
% N	% Nitrogen in Fuel	
% O	% Oxygen in Fuel	
GCV	Gross Calificoric Volume - lb/BTU	

Calculated

Vm (std)	Meter Volume at Standard Conditions (Dry) - Ft ³	<u>102.70</u>
% H ₂ O	% Moisture in Stack Gas	<u>2.579</u>
Mw	Molecular weight of Stack Gas (wet)	<u>29.17</u>
Dst	Average Duct Gas Density - lb/Ft ³	<u>0.06866</u>
EA	Percent Excess Air	<u>203.65</u>
Vs	Average Velocity of Stack - Ft./min	<u>2505</u>
Q	Actual Stack Gas Flow Rate - ACFM	<u>6910</u>
Qs	Stack Gas Flowrate Corrected to dry stan. cond. - DSCFM	<u>6115</u>
% I	% Isokinetic (Avg. Nozzle Vel/Avg. Stack Vel.)	<u>99.1</u>
Cs	Particulate Concentration - Gr/DSCF	<u>0.00651</u>
C	Actual Particulate Concentration - Gr/ACF	<u>0.00575</u>
ER	Particulate Emission Rate - lb/hr	<u>0.341</u>
Cs@12%CO ₂	Particulate Concentration-Gr/DSCF @12% CO ₂	<u>0.0139</u>
Cs@50%EA	Particulate Concentration-Gr/DSCF @ 50% EA	<u>0.0260</u>
C1b	Particulate Concentration-lbs/1000-lbs duct gas uncorrected	<u>0.0132</u>
C1b@12%CO ₂	Particulate Concentration-lbs/1000-lbs dry corrected to 12% CO ₂	<u>0.0246</u>
C1b@50%EA	Particulate Concentration-lbs/1000-lbs dry corrected to 50% EA	<u>0.01196</u>
E	E-Factor - DSCF/MM BTU	

INCINERATOR TEST DATA

TEST 2 TIME 10:04 to 12:25
 LOCATION Stack Breaching DATE 2-11-81
 FIRM Zumpro PROJECT NO. 1438-E53

Input A

P bar	Barometric Pressure - in. Hg	<u>29.94</u>
As	Stack Area - Ft ²	<u>2.96</u>
Dn	Nozzle Diameter - in.	<u>0.2591</u>
Time	Total Sampling Time - min.	<u>128</u>
Y	Calibration Factor	<u>1.00</u>
Cp	Pitot Coefficient	<u>0.84</u>
(ΔP) ^{1/2}	Average Square Root of Vel. Head in. H ₂ O	<u>0.586</u>
ΔH	Average Orifice Pressure Drop	<u>1.39</u>
Tm	Average Meter Temperature - °F	<u>57</u>
P stk	Average Stack Pressure - in H ₂ O	<u>-0.12</u>
T stk	Average Stack Temperature - °F	<u>136</u>
Vm	Meter Volume at Meter Conditions - Ft ³	<u>82.07</u>
Vl	Total Water Vapor Collected	<u>68.27</u>
CO ₂	% CO ₂ in Stack Gas (Dry)	<u>6.6</u>
O ₂	% O ₂ in Stack Gas (Dry)	<u>12.2</u>
CO	% CO in Stack Gas (Dry)	<u>0</u>

Input B

Mn	Total Particulate Catch	<u>27.5</u>
----	-------------------------	-------------

Input C

% H	% Hydrogen in Fuel	
% C	% Carbon in Fuel	
% S	% Sulfur in Fuel	
% N	% Nitrogen in Fuel	
% O	% Oxygen in Fuel	
GCV	Gross Calificoric Volume - lb/BTU	

Calculated

Vm (std)	Meter Volume at Standard Conditions (Dry) - Ft ³	<u>84.17</u>
% H ₂ O	% Moisture in Stack Gas	<u>3.68</u>
Mw	Molecular weight of Stack Gas (wet)	<u>29.12</u>
Dst	Average Duct Gas Density - lb/Ft ³	<u>0.063</u>
EA	Percent Excess Air	<u>132.0</u>
Vs	Average Velocity of Stack - Ft./min	<u>2098</u>
Q	Actual Stack Gas Flow Rate - ACFM	<u>5763</u>
Qs	Stack Gas Flowrate Corrected to dry stan. cond. - DSCFM	<u>4919</u>
% I	% Isokinetic (Avg. Nozzle Vel/Avg. Stack Vel.)	<u>100.8</u>
Cs	Particulate Concentration - Gr/DSCF	<u>0.00504</u>
C	Actual Particulate Concentration - Gr/ACF	<u>0.00430</u>
ER	Particulate Emission Rate - lb/hr	<u>0.213</u>
Cs@12%CO ₂	Particulate Concentration-Gr/DSCF @12% CO ₂	<u>0.00917</u>
Cs@50%EA	Particulate Concentration-Gr/DSCF @ 50% EA	<u>0.0170</u>
Clb	Particulate Concentration-lbs/1000-lbs duct gas uncorrected	<u>0.00780</u>
Clb@12%CO ₂	Particulate Concentration-lbs/1000-lbs dry corrected to 12% CO ₂	<u>0.0145</u>
Clb@50%EA	Particulate Concentration-lbs/1000-lbs dry corrected to 50% EA	<u>0.00918</u>
F	F-Factor - DSCF/MM BTU	

INCINERATOR TEST DATA

TEST 3 TIME 1413 + 01637
 LOCATION STACK BREACHING DATE 2-11-81
 FIRM ZIMMCO PROJECT NO. 1438-153

Input A

P bar	Barometric Pressure - in. Hg	<u>29.78</u>
As	Stack Area - Ft ²	<u>2.76</u>
Dn	Nozzle Diameter - in.	<u>113.5 = .2591</u>
Time	Total Sampling Time - min.	<u>113.5</u>
Y	Calibration Factor	<u>1.00</u>
Cp	Pitot Coefficient	<u>0.84</u>
(ΔP) ^{1/2}	Average Square Root of Vel. Head in. H ₂ O	<u>0.518</u>
ΔH	Average Orifice Pressure Drop	<u>1.10</u>
Tm	Average Meter Temperature - °F	<u>60</u>
P stk	Average Stack Pressure - in H ₂ O	<u>- 0.145</u>
T stk	Average Stack Temperature - °F	<u>143</u>
Vm	Meter Volume at Meter Conditions - Ft ³	<u>68.11</u>
Vl	Total Water Vapor Collected	<u>55.88</u>
CO ₂	% CO ₂ in Stack Gas (Dry)	<u>6.5</u>
O ₂	% O ₂ in Stack Gas (Dry)	<u>12.8</u>
CO	% CO in Stack Gas (Dry)	<u>0</u>

Input B

Mn	Total Particulate Catch	<u>16</u>
----	-------------------------	-----------

Input C

% H	% Hydrogen in Fuel	
% C	% Carbon in Fuel	
% S	% Sulfur in Fuel	
% N	% Nitrogen in Fuel	
% O	% Oxygen in Fuel	
GCV	Gross Calificoric Volume - lb/BTU	

Calculated

Vm (std)	Meter Volume at Standard Conditions (Dry) - Ft ³	<u>69.03</u>
% H ₂ O	% Moisture in Stack Gas	<u>3.67</u>
Mw	Molecular weight of Stack Gas (wet)	<u>29.13</u>
Dst	Average Duct Gas Density - lb/Ft ³	<u>0.066</u>
EA	Percent Excess Air	<u>150.5</u>
Vs	Average Velocity of Stack - Ft.min	<u>1861</u>
Q	Actual Stack Gas Flow Rate - ACFM	<u>5137</u>
Qs	Stack Gas Flowrate Corrected to dry stan. cond. - DSCFM	<u>7310</u>
% I	% Isokinetic (Avg. Nozzle Vel/Avg. Stack Vel.)	<u>106.4</u>
Cs	Particulate Concentration - Gr/DSCF	<u>0.00358</u>
C	Actual Particulate Concentration - Gr/ACF	<u>0.00300</u>
ER	Particulate Emission Rate - lb/hr	<u>0.132</u>
Cs@12%CO ₂	Particulate Concentration-Gr/DSCF @12% CO ₂	<u>0.00660</u>
Cs@50%EA	Particulate Concentration-Gr/DSCF @ 50% EA	<u>0.0123</u>
Clb	Particulate Concentration-lbs/1000-lbs duct gas uncorrected	<u>0.00597</u>
Clb@12%CO ₂	Particulate Concentration-lbs/1000-lbs dry corrected to 12% CO ₂	<u>0.0111</u>
Clb@50%EA	Particulate Concentration-lbs/1000-lbs dry corrected to 50% EA	<u>0.00651</u>
F	F-Factor - DSCF/MM BTU	

APPENDIX H
WEIGHT BELT CALIBRATION

TEST REPORT

USER Seawater plant (Titan Northeast) MODEL DS-1-460 SERIAL # 15619

Rate Display: ☐ % Or ☒ Eng. Units

Integrator Registration: Tons

Mult. Reading By: .001

Set Point ☐ % Or ☐ Eng. Units

Test Wght or Chain Equiv. Electronic Calibration

Measured Belt Length 141.75 ft

Measured Time 1 Revolution of Belt 1.37 min

Measured Conveyor Belt Speed 103.467 fpm

Set Speed To 100% For 1 Belt Rev.

Counts/Ft. 500 Analog Rate Output 4.20

UC Excitation 10.152 V UC Tare Output 0 MV

Electronic Calib. Output 2.8 MV 2.8 MV

(As Found) (After Adjustment)

Metric Tons Kilograms

100% Capacity 15 TPH

100% Speed 120 fpm

Design Load 4.17 PPF

Calibration Time 92 Sec.

Pre-Amp Input 2.813 mV

DSP 6 BRM Number 08918 Gear Ratio 1-1

A. Lbs Tons
F. 1.00 2000

Long Tons

2240

2205

2.205

COMPUTATION I (Test Chain or Wt. must be in position)

70215 Belt Meas. Test Results + 500 Counts/Ft. = 140.43 Ft. of Belt

COMPUTATION II (Number of Totalized Lbs. for Calibration)

140.43 Ft. of Belt x 4.17 Test Chain Equivalent = 585.5931 Total Lbs.

COMPUTATION IIA

585.5931 Total Lbs. - .001 (F) - 2000 Integrator Registration = 292.792 Counts

COMPUTATION III (Theoretical Wt. Display with Load)

4.17 PPF Test Chain Equivalent + 4.17 PPF Design Load x 100 = 100% % Test Load

Parts Used From Merrick Stock:

TEST CHAIN OR WEIGHT CALIBRATION

	As Found	Test 1	Test 2	Test 3
Tare	542	3	26	3
Calib. Counts	291	293	293	293
Rate Display	12.5	12.9	12.3	12.7
Wt. Display	100	99.5	99.7	101.0
Speed Display	86.1	85.8	85.7	86.0
% Error	.614%	.069%	.269%	.069%
Adjusted		1/2 T.C.W.		

MATERIAL TEST

	Test 1	Test 2	Test 3
Material Wght.			
Integrator Total			
% Error			
Adjusted			

Reported By Richard H. Hall

Date 12/29/80

MERRICK SCALE MFG. COMPANY
GENERAL REPORT

✓ CC
D. PATTERSON

USER WILLOW WASTEWATER TREATMENT PLANT

Weighing Machine Type and Serial No. DS-1-460-15618

Location VERMONT CT

Purchase Order No. 17P-126-2

Date Arrived 12/29/80

Date Departed 12/29/80 Hrs.

Persons Interviewed

Title

Mr. B. Waugham Superintendent

Mr. J. Booth Worker

REPORT

Make note of any features of Conveyor design, drive, take-up, structure, uniformity of weight of empty conveyor, condition of same, material adhering to belt or pulleys, water or foreign substance, general conditions around conveyor, loading, weighing or feed location or others unmentioned that would be detrimental to accurate weighing.

12/29/80 Unit DS-15618. Inspected the scale head & weigh bridge. The customer swapped the cards & power supply from unit DS-1-460-16147 to DS-1-460-15618. Measured & timed the belt. Aligned the weigh bridge idlers & ran a tare test & adjusted the fine tare pot. Ran span tests & adjusted the p. pot. See test report for results.

Mr. A. Ward, ✓

The unit is accurate within the accuracy shown on the attached calibration report using the electronic calibration method.

[Signature]

Date 12/30/80

Reported By Richard S. M. [Signature]