

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section: 2.3

Background Chapter 4

Reference: 14

**Title: Medical Waste Incineration Emission Test Report,
Morristown Memorial Hospital, Morristown, New Jersey.**

**Prepared for the U.S. Environmental Protection Agency,
Office of Air Quality Planning and Standards. December 1991.**

EMB Report 91-MWI-8.

United States
Environmental Protection
Agency

Office of Air Quality
Planning and Standards
Research Triangle Park, NC

Environmental Monitoring
System

AP

DCN: 92-275-026-60-01

**MEDICAL WASTE INCINERATION
EMISSION TEST REPORT**

**Morristown Memorial Hospital
Morristown, New Jersey**

Prepared for:

**Dennis P. Holzschuh
Emissions Measurement Branch
U.S. Environmental Protection Agency
Research Triangle Park, North Carolina 27711**

Prepared by:

**Radian Corporation
1300 Nelson Highway/Chapel Hill Road
Post Office Box 13000
Research Triangle Park, North Carolina 27709**

September 11, 1992

CONTENTS

<u>Section</u>	<u>Page</u>
1. PROJECT DESCRIPTION	1-1
1.1 Introduction	1-1
1.2 Objectives	1-1
1.3 Test Matrix	1-3
1.4 Process Description	1-9
1.5 Description Of Report Contents	1-9
2. SUMMARY OF RESULTS	2-1
2.1 Emissions Test Log	2-1
2.2 CDD/CDF Results	2-1
2.3 Toxic Metals Results	2-15
2.4 Particulate Matter/Particle Size Distribution	2-41
2.5 Mercury Emissions By Method 101A	2-58
2.6 Halogen Gas Emissions	2-66
2.7 CEM Results	2-77
2.8 Microbial Survivability Results	2-81
3. PROCESS DESCRIPTION	3-1
3.1 Introduction	3-1
3.2 Process Description for MMH Incineration System	3-1
3.3 Pretest Activities	3-13
3.4 Process Operation During Testing	3-16
4. SAMPLING LOCATIONS	4-1
4.1 Spray Dryer Inlet	4-1
4.2 Baghouse Exit (Stack)	4-1
4.3 Ash Sampling Locations	4-5
4.4 Water and Slurry Samples	4-5
5. SAMPLING AND ANALYTICAL PROCEDURES BY ANALYTE	5-1
5.1 CDD/CDF Emissions Testing Method	5-1
5.2 Particulate Matter and Metals Emissions Testing Method	5-21
5.3 Mercury Emissions By Method 101A	5-33
5.4 Hydrogen Chloride/Hydrogen Bromide/Hydrogen Fluoride Emissions Testing By EPA Method 26	5-40
5.5 EPA Methods 1-4	5-44
5.6 Continuous Emissions Monitoring (CEM) Methods	5-45
5.7 Microbial Survivability Testing	5-55
5.8 Particulate Size Distribution Sampling Methods	5-70
5.9 Process Sampling Procedure	5-72

CONTENTS, continued

<u>Section</u>	<u>Page</u>
6. QUALITY ASSURANCE/QUALITY CONTROL	6-1
6.1 QA/QC Definitions and Objectives	6-2
6.2 Manual Flue Gas Sampling and Recovery Parameters	6-3
6.3 QC Procedures for Ash and Pipe Sampling	6-21
6.4 Analytical Quality Assurance	6-22
6.5 CEM Quality Assurances	6-31

VOLUME II

APPENDICES

A	FIELD DATA SHEETS
A.1	Traverse Point Location
A.2	Dioxins/Furans
A.3	Particulate Matter/Metals
A.4	Mercury
A.5	Hydrogen Chloride
A.6	Microbial
A.7	Particle Size Distribution
A.8	Opacity
B	PROCESS DATA SHEETS
C	SAMPLE PARAMETER CALCULATION SHEETS
C.1	Dioxins/Furans
C.2	Particulate Matter/Metals
C.3	Mercury
C.4	Microbial
D	CEM DATA
D.1	Tables
D.2	Calibration Drifts
D.3	QC Gas Responses

CONTENTS, continued

<u>Section</u>	<u>Page</u>
E	ANALYTICAL DATA
E.1	Dioxins/Furans
E.2	Particulate Matter/Metals
E.3	Mercury
E.4	Hydrogen Chloride
E.5	Microbial
E.6	Particle Size Distribution
E.7	Sample ID Log
F	CALIBRATION DATA SHEETS
G	SAMPLE EQUATIONS
H	PROJECT PARTICIPANTS
I	SAMPLING AND ANALYTICAL PROTOCOLS
I.1	Dioxins/Furans
I.2	Particulate Matter/Metals
I.3	Mercury
I.4	Hydrogen Chloride
I.5	Microbial
I.6	Particle Size Distribution

FIGURES

	<u>Page</u>
2-1 Run 1 Particle Size Distribution Results	2-54
2-2 Run 2 Particle Size Distribution Results	2-55
2-3 Run 3 Particle Size Distribution Results	2-56
2-4 Run 4 Particle Size Distribution Results	2-57
2-5 Hydrogen Chloride Results Comparison - Spray Dryer Inlet	2-72
2-6 Hydrogen Chloride Results Comparison - Baghouse Outlet	2-73
3-1 Schematic of Medical Waste Incinerator/Waste Heat Recovery Boiler System	3-2
3-2 Schematic of Spray Dryer/Fabric Filter Air Pollution Control System	3-3
3-3 Temperature Profiles for Run 1 (11-18-91)	3-21
3-4 Temperature Profiles for Run 2 (11-19-91)	3-22
3-5 Temperature Profiles for Run 3 (11-20-91)	3-23
3-6 Temperature Profiles for Run 4 (11-21-91)	3-24
3-7 Temperature Profiles for Run 5 (11-22-91)	3-25
3-8 Temperature Profiles for Run 6 (11-23-91)	3-26
4-1 Sample Port Locations at the Spray Dryer Inlet	4-2
4-2 Spray Dryer Inlet Traverse Point Layout	4-3
4-3 Sample Port Location of the Exhaust Stack	4-4
4-4 Traverse Point Layout at the Exhaust Stack	4-6
5-1 CDD/CDF Sampling Train Configuration	5-4
5-2 Impinger Configuration for CDD/CDF Sampling	5-9

FIGURES, continued

		<u>Page</u>
5-3	CDD/CDF Field Recovery Scheme	5-14
5-4	Extraction and Analysis Schematic for CDD/CDF Samples	5-18
5-5	Schematic of Multiple Metals Sampling Train	5-22
5-6	Impinger Configuration for Particulate Matter/Metals Sampling	5-24
5-7	Metals Sample Recovery Scheme	5-26
5-8	Metals Sample Preparation and Analysis Scheme	5-31
5-9	EPA Method 101A Sampling Train	5-34
5-10	Method 101A Sample Recovery Scheme	5-37
5-11	Method 101A Sampling Preparation and Analysis Scheme	5-39
5-12	Chlorine Sample Train Configuration	5-41
5-13	HCl/HBr/HF Sample Recovery Scheme	5-43
5-14	Schematic of CEM System	5-47
5-15	Sampling Train for Determination of Indicator Spore Emissions	5-58
5-16	Sample Recovery Scheme for Microbial Viability Testing	5-60
5-17	Modified (Mesh) Ash Quality Assembly	5-63
5-18	Sample and Analysis Scheme for Microbial Testing of Ash Samples	5-65
5-19	Analysis Scheme for Pipe Sample Microbial Viability Tests	5-66
5-20	Sample Preparation and Analysis Scheme for Microbial Testing	5-68
5-21	PM/CPM Sampling Train	5-71
6-1	Spray Dryer Inlet HCl Results With Control Limits	6-17

FIGURES, continued

	<u>Page</u>
6-2 Baghouse Outlet HCl Results With Control Limits	6-18

TABLES

		<u>Page</u>
1-1	Test Matrix	1-4
2-1	Test Log	2-2
2-2	CDD/CDF Inlet and Outlet Stack Gas Emissions and Removal Efficiencies For Condition 1	2-6
2-3	CDD/CDF Inlet and Outlet Stack Gas Emissions and Removal Efficiencies For Condition 2	2-7
2-4	CDD/CDF Inlet and Outlet Stack Gas Concentrations for Condition 1	2-8
2-5	CDD/CDF Inlet and Outlet Stack Gas Concentrations for Condition 2	2-9
2-6	CDD/CDF Inlet and Outlet Stack Gas Concentrations Corrected to 7 Percent O ₂ for Condition 1	2-10
2-7	CDD/CDF Inlet and Outlet Stack Gas Concentrations Corrected to 7 Percent O ₂ for Condition 2	2-11
2-8	CDD/CDF Average Flue Gas Toxic Equivalencies Corrected to 7 Percent O ₂ for Condition 1	2-12
2-9	CDD/CDF Average Flue Gas Toxic Equivalencies Corrected to 7 Percent O ₂ for Condition 2	2-13
2-10	Summary of CDD/CDF Flue Gas Sampling Parameters	2-14
2-11	CDD/CDF Concentrations and 2378 Toxic Equivalent Concentrations in Baghouse Residue for Condition 1	2-16
2-12	CDD/CDF Concentrations and 2378 Toxic Equivalent Concentrations in Baghouse Residue for Condition 2	2-17
2-13	CDD/CDF Concentrations and 2378 Toxic Equivalent Concentrations in Bottom Ash for Condition 1	2-18
2-14	CDD/CDF Concentrations and 2378 Toxic Equivalent Concentrations in Bottom Ash for Condition 2	2-19

TABLES, continued

		<u>Page</u>
2-15	CDD/CDF Concentrations and 2378 Toxic Equivalent Concentrations in Spray Dryer Residue for Condition 1	2-20
2-16	CDD/CDF Concentrations and 2378 Toxic Equivalent Concentrations in Spray Dryer Residue for Condition 2	2-21
2-17	CDD/CDF Concentrations in Make-Up Water and Lime Slurry for Run 1 ..	2-22
2-18	Average Metals Emission Rates and Removal Efficiencies, Without Carbon Injection	2-24
2-19	Average Metals Emission Rates and Removal Efficiencies, With Carbon Injection	2-25
2-20	Metals Concentrations	2-28
2-21	Metals Concentrations Corrected to 7 Percent O ₂	2-29
2-22	Ratio of Metals to Particulate Matter, Without Carbon Injection	2-30
2-23	Ratio of Metals to Particulate Matter, With Carbon Injection	2-31
2-24	Metals Amounts in Inlet Flue Gas - Sample by Sample Fraction	2-32
2-25	Metals Amounts in Outlet Flue Gas - Sample By Sample Fraction	2-35
2-26	Metals/Particulate Matter Emissions Sampling and Flue Gas Parameters at Inlet	2-37
2-27	Metals/Particulate Matter Emissions Sampling and Flue Gas Parameters at Outlet	2-38
2-28	Metals in Ash Concentrations - Bottom Ash	2-39
2-29	Metals in Ash Concentrations - Baghouse Ash	2-40
2-30	Metals in Ash Concentrations - Spray Dryer Ash	2-42
2-31	Metals in Make-Up Water Concentrations	2-43

TABLES, continued

	<u>Page</u>
2-32 Metals in Lime Slurry Concentrations	2-44
2-33 Particulate Matter Concentrations and Emission Rates	2-45
2-34 Particle Size Distribution Run 1 Results	2-48
2-35 Particle Size Distribution Run 2 Results	2-49
2-36 Particle Size Distribution Run 3 Results	2-50
2-37 Particle Size Distribution Run 4 Results	2-51
2-38 Summary of Particle Size Distribution Results	2-52
2-39 Particle Size Distribution Flue Gas and Sampling Parameters	2-53
2-40 Summary of Mercury 101A Results	2-59
2-41 Mercury 101A Sampling and Flue Gas Parameters at the Spray Dryer Inlet	2-62
2-42 Mercury 101A Sampling and Flue Gas Parameters at the Baghouse Outlet	2-63
2-43 Comparison of Mercury 101A Data to Digested Lab Filters	2-64
2-44 Comparison for Mercury Emission Rates and Removal Efficiencies, Method 101A versus Toxic Metals	2-65
2-45 Summary of Hydrogen Chloride Results	2-67
2-46 Summary of Hydrogen Chloride CEM Results	2-69
2-47 Comparison of Manual and CEM Hydrogen Chloride Results	2-71
2-48 Summary of Hydrogen Fluoride Removal Results	2-74
2-49 Summary of Hydrogen Bromide Results	2-76
2-50 Continuous Emission Monitoring Test Averages	2-79

TABLES, continued

		<u>Page</u>
2-51	Continuous Emission Monitoring Test Averages Normalized to 7 Percent O ₂	2-80
2-52	Summary of Incinerator Feed and Ash Generation	2-83
2-53	Overall Microbial Survivability	2-85
2-54	Summary of Flue Gas Sampling Parameters for Indicator Spore Emissions ..	2-86
2-55	Spore Pipe Sample Recovery and Analysis Results	2-88
3-1	Operating Setpoints During the Test	3-14
3-2	Incinerator Process Data Summary	3-17
3-3	Spray Dryer and Fabric Filter Process Data Summary	3-18
5-1	Test Methods Used For Morristown Memorial Hospital	5-2
5-2	Sampling Times, Minimum Sampling Volumes, and Detection Limits	5-3
5-3	CDD/CDF Glassware Cleaning Procedure	5-6
5-4	CDD/CDF Sampling Checklist	5-11
5-5	CDD/CDF Sample Fractions Shipped to Analytical Laboratory	5-15
5-6	CDD/CDF Congeners Analyzed	5-17
5-7	CDD/CDF Blanks Collected	5-20
5-8	Approximate Detection Limits for Metals	5-29
5-9	CEM Operating Ranges and Calibration Gases	5-52
5-10	Indicator Spore Testing QA/QC Checks	5-69
6-1	Summary of Data Quality	6-4
6-2	Leak Check Results For CDD/CDF Sample Trains	6-6

TABLES, continued

		<u>Page</u>
6-3	Isokinetic Sampling Rates for CDD/CDF, TM, M101A, and Microorganism Test Runs	6-7
6-4	Dry Gas Meter Post-Test Calibration Results	6-8
6-5	CDD/CDF Field Blank Results Compared to Average Run Results	6-9
6-6	Leak Check Results for Toxic Metals Sample Trains	6-11
6-7	Metals Field Blank Results Compared to Average Run Results	6-12
6-8	Leak Check Results for Mercury Sample Trains	6-13
6-9	Mercury 101A Field Blank and Method Results	6-14
6-10	Halogen Field, Method, and Reagent Blank Results	6-16
6-11	Leak Check Results For Microorganisms Sample Trains	6-19
6-12	Spore Spike Solution Confirmation Analysis	6-20
6-13	CDD/CDF Method Blank Results	6-24
6-14	Standards Recoveries for the CDD/CDF Modified Method 5 Inlet Analyses	6-25
6-15	Standards Recoveries for the CDD/CDF Modified Method 5 Outlet Analyses	6-26
6-16	Standards Recovery Results for CDD/CDF Bottom Ash and Scrubber Water Analyses	6-27
6-17	Standards Recovery Results for CDD/CDF Baghouse Residue Analyses	6-28
6-18	Standards Recovery Results for CDD/CDF Spray Dryer Residue Analyses ..	6-29
6-19	Standards Recovery Results for CDD/CDF Blank Analyses	6-30
6-20	Metals Ash and Flue Gas Method Blank Results	6-33

TABLES, continued

	<u>Page</u>
6-21 Metals Method and Matrix Spike Results	6-34
6-22 Mercury 101A Matrix Spike Results	6-35
6-23 Halogen Matrix Spike and Matrix Spike Duplicates Recovery Results	6-36
6-24 CEM Internal QA/QC Checks	6-37
6-25 Daily Calibration Drifts	6-38
6-26 QG Gas Responses	6-40
6-27 CEM Linearity Results	6-42

1. PROJECT DESCRIPTION

1.1 INTRODUCTION

The United States Environmental Protection Agency (EPA) has determined that medical waste incinerator (MWI) emissions may reasonably be anticipated to contribute to the endangerment of public health and welfare. As a consequence, new source performance standards (NSPS) for new MWIs and emission guidelines for existing MWIs will be developed under Sections 111(b), 111(d), and 129 of the Clean Air Act, as amended November 1990.

The Office of Air Quality Planning and Standards (OAQPS), through its Industrial Studies Branch (ISB) and Emissions Measurement Branch (EMB), is responsible for reviewing the existing air emissions data base and gathering additional data where necessary. As a result of this review, a series of MWI emission tests are being conducted to support the regulatory development program.

The emissions that are being studied for standards development are the criteria pollutants--particulate matter (PM), sulfur dioxide (SO₂), nitrogen oxides (NO_x), carbon monoxide (CO), and total hydrocarbons (THC); as well as other acid gases, such as hydrogen chloride (HCl); chlorinated organics, including dioxins and furans; trace metals; and pathogens.

1.2 OBJECTIVES

The purpose of the testing program at the Morristown Memorial Hospital in Morristown, New Jersey, is to obtain uncontrolled and controlled emission data from a semi-continuous ram-fed MWI. These data will be used in the regulatory development program for MWIs.

The MWI located at Morristown Memorial Hospital was selected for emissions testing for the following reasons:

- This facility is the first known installation of a spray dryer/fabric filter air pollution control system controlling emissions from a MWI;
- The rotary kiln MWI of this facility is typical of well-designed, rotary kiln MWI's currently being installed and for which no uncontrolled emission test data are available; and

- This facility provides a unique opportunity to obtain both uncontrolled emissions test data for a rotary kiln as well as control device performance data for a spray dryer/fabric filter at one test site.

The specific objectives of the test program are:

- Determine what levels of CO, PM, SO₂, NO_x, HCl, metals, THC and polychlorinated dibenzo-p-dioxins (CDD) and polychlorinated dibenzofurans (CDF) are emitted from the combustor when burning medical wastes;
- Determine the levels of PM, acid gases, metals including mercury (Hg), and CDD/CDF emissions associated with a spray dryer/fabric filter control technology;
- Calculate the control efficiencies for PM, acid gases, metals, and CDD/CDF;
- Investigate the mercury and dioxin removal efficiency capabilities of carbon injection;
- Determine the degree of combustion of the feed wastes based on percent carbon and loss on ignition (LOI) of the bottom ash, spray dryer flyash, and fabric filter flyash;
- Determine particle size distribution of uncontrolled emissions; and
- Determine the microbial survivability based on a surrogate indicator organism that is spiked into the incinerator feed.

Key process operating variables including flue gas oxygen (O₂), carbon dioxide (CO₂), primary and secondary chamber temperatures, air flows, lime feed rates, baghouse pressure drop, and the total amount of waste charged were monitored and recorded to document the operating conditions during each test.

The test program included an internal quality control program. The goal of the quality assurance/quality control (QA/QC) activities was to ensure that the results are of known precision and accuracy, and that they are complete, representative, and comparable.

1.3 TEST MATRIX

The sampling and analytical matrix that was performed is presented in Table 1-1. Both manual emissions tests and CEMs were employed for the Morristown Memorial Hospital MWI test program. In addition to flue gas sampling, incinerator bottom ash, spray dryer flyash, and fabric filter flyash samples were also taken. Each of the tests are briefly described in the following paragraphs.

Tests were conducted under two operating conditions. The first condition called for normal operation of the incinerator and SD/FF. Three test runs were conducted at a frequency of one 4-hour run per day. All test runs at each sampling location were conducted simultaneously. The second condition called for carbon to be injected into the lime slurry at a rate of 4 lb/hr. This was done to examine the effects of in-duct carbon injection on flue gas mercury removal. Three test runs were conducted under this condition at a frequency of one 4-hour run per day. The carbon used for all tests was a coal-based carbon manufactured by American Norit with a surface area of 900 m²/gram. The carbon was mixed into the lime slurry and introduced to flue gas in the spray dryer prior to the baghouse.

Total PM emissions along with a series of 13 metals [lead (Pb), chromium (Cr), cadmium (Cd), mercury (Hg), nickel (Ni), arsenic (As), beryllium (Be), antimony (Sb), barium (Ba), silver (Ag), thallium (Tl), copper (Cu), and aluminum (Al)], were determined using a single sample train. Particulate loading on the filter and front half (nozzle/probe, filter holder) rinse were determined gravimetrically. Metals analyses were then completed on the filter front half rinses and back half impinger catches using atomic absorption (AA) and inductively coupled argon plasma (ICAP) techniques. Mercury emissions were also determined by EPA Method 101A so that a comparison of results between the multi-metals train and the Method 101A train could be made.

Flue gas samples for CDD/CDF were collected using EPA Method 23. Flue gas was extracted isokinetically and CDD/CDF was collected on a filter and a chilled adsorbent trap. Recovery procedures were completed using toluene rinses as per the latest update of EPA CDD/CDF testing methodology. The analysis was completed using

TABLE 1-1. MORRISTOWN MEMORIAL HOSPITAL MWI TEST MATRIX

Sample Location	Number of Runs	Sample Type	Sample Method	Sample Duration	Analysis Method	Laboratory
Spray Dryer Inlet	6	Particulate/Metals (As, Cd, Cr, Hg, Ni, Pb, Be, Sb, Ba, Ag, Tl, Cu, Al)	EPA Method 5/ Combined Metals Train	4 hours	Gravimetric/Atomic Absorption/ICAP	Radian
	6	Hg	EPA Method 101A	4 hours	Atomic Absorption	
	6	CDD/CDF	EPA Method 23 and GC/MS Method 8290	4 hours	Gas Chromatography and High Resolution MS for CDD/CDF	Triangle Labs, Inc.
	6	HCl	EPA Method 26	Three 1-hour samples per run	Ion Chromatography	Radian
	3	Indicator Spores	EPA Draft Method	4 hours	Microbial Draft Method	American Type Culture Collection
	6	HCl NO _x SO ₂ O ₃ /CO ₂ THC CO	HCl CEM EPA Method 7E EPA Method 6C EPA Method 3A EPA Method 25A EPA Method 10	Continuous	NDIR CEM Chemiluminescence CEM UV Analyzer CEM Zirconium Oxide Cell/NDIR CEM FID CEM NDIR CEM	Radian
	4	PSD	Diagnostic Technique/ EPA Method 202	0.25 hour	Gravimetric	Radian

TABLE 1-1. CONTINUED

Sample Location	Number of Runs	Sample Type	Sample Method	Sample Duration	Analysis Method	Laboratory
Baghouse Outlet	6	Particulate/Metals (As, Cd, Cr, Hg, Ni, Pb, Be, Sb, Ba, Ag, Tl, Cu, Al)	EPA Method 5/ Combined Metals Train	4 hours	Gravimetric/Atomic Absorption /ICAP	Radian
	6	CDD/CDF	EPA Method 23 and GC/MS Method 8290	4 hours	Gas Chromatography and High Resolution MS for CDD/CDF	Triangle Labs, Inc.
	6	HCl	EPA Method 26	Three 1-hour samples per run	Ion Chromatography SW 846 9057	Radian
	6	O ₂ /CO ₂ THC HCl SO ₂	EPA Method 3A EPA Method 25A HCl CEM EPA Method 6C	Continuous	Zirconium Oxide Cell/NDIR CEM FID CEM (heated) NDIR CEM UV Analyzer CEM	Radian
	3	Speciated HC	EPA Method 18	3 injections per hour	Gas Chromatograph/Flame Ionization Detector (GC/FID)	Radian
	3	CO	EPA Method 10	Continuous	NDIR CEM	Radian
	3	NO _x	EPA Method 7E	Continuous	Chemiluminescence CEM	Radian
Stack	6	Hg	EPA Method 101A	4 hours	Atomic Absorption	Radian
	3	Opacity	EPA Method 9	1 hour		Radian

TABLE 1-1. CONTINUED

Sample Location	Number of Runs	Sample Type	Sample Method	Sample Duration	Analysis Method	Laboratory
Rotary Kiln	6	Kiln Bottom Ash	Representative Composite Sample	1 day	LOI, Carbon, Metals	Radian, McCoy Labs
	6	Kiln Bottom Ash	Representative Composite Sample	1 day	Dioxins/Furans	Triangle Labs, Inc.
	3	Kiln Bottom Ash	Representative Composite Sample	1 day	Microbial Draft Method	American Type Culture Collection
Spray Dryer	6	Spray Dryer Catch	Representative Composite Sample	1 day	LOI, Carbon, Metals	Radian, McCoy Labs
	6	Spray Dryer Catch	Representative Composite Sample	1 day	Dioxins/Furans	Triangle Labs, Inc.
	3	Spray Dryer Catch	Representative Composite Sample	1 day	Microbial Draft Method	American Type Culture Collection

TABLE 1-1. CONTINUED

Sample Location	Number of Runs	Sample Type	Sample Method	Sample Duration	Analysis Method	Laboratory
Baghouse	6	Fabric Filter Catch	Representative Composite Sample	1 day	LOI, Carbon, Metals	Radian, McCoy Labs
	6	Fabric Filter Catch	Representative Composite Sample	1 day	Dioxins/Furans	Triangle Labs, Inc.
	3	Fabric Filter Catch	Representative Composite Sample	1 day	Microbial Draft Method	American Type Culture Collection
Lime Injection	6	Lime Slurry Feed	Representative Composite Sample	1 day	Metals, Lime	Radian, McCoy Labs
	6	Lime Slurry Feed	Representative Composite Sample	1 day	Dioxins/Furans	Triangle Labs, Inc.
	6	Slurry Water Supply	Representative Composite Sample	1 day	Metals, Lime, Chlorine	Radian, McCoy Labs
	6	Slurry Water Supply	Representative Composite Sample	1 day	Dioxins/Furans	Triangle Labs, Inc.

high resolution gas chromatography coupled with high resolution mass spectrometry detection (HRGC/HRMS).

Hydrogen chloride, hydrogen bromide (HBr), and hydrogen fluoride (HF) concentrations in the stack gas were determined using EPA Method 26. Flue gas was extracted from the stack and passed through an acidified collection solution which stabilized the respective halogen ions (Cl^- , Br^- , F^-). The quantity of ions collected was determined using ion chromatography (IC) analyses.

Gaseous emissions (NO_x , CO , SO_2 , THC, and HCl) were measured using CEMs continuously during the day at the spray dryer inlet. The diluent gases (O_2 , CO_2) were measured using CEMs at all times when tests were being performed so that the emission results could be normalized to a reference O_2 or CO_2 basis. The O_2 and CO_2 results were also used for flue gas molecular weight calculations for stack gas flow rate calculations. Gaseous emissions of SO_2 , THC, HCl, O_2 , and CO_2 were measured at the baghouse outlet using an additional CEM system.

Three types of microbial survivability tests were performed on the incinerator. These tests were intended to evaluate the effectiveness of the MWI in destroying microbial elements in the waste. Indicator spore spikes were loaded onto material commonly found in the medical waste stream and then charged into the incinerator to determine the ability of the indicator organisms to survive in the combustion gases and the incinerator bottom ash. Surrogate indicator spore spikes were also encased in insulated double pipe containers. Spores were added when no carbon was injected and no spores were added when the carbon was injected. Flue gas testing for spore emissions were conducted simultaneously with the other emissions testing. The next day following the daily burn cycle, ash samples and pipe samples were recovered and subsequently analyzed for spore viability. Direct ash sampling and pipe sampling were conducted daily. Flue gas samples were collected isokinetically and passed through a circulating phosphate buffer solution. Following the test, the buffer solution samples were analyzed for viable spores using microbiological identification, culturing, and quantification techniques outlined in the EPA draft method "Microbial Survivability Test for Medical Waste Incinerator Emissions." Ash samples and pipe samples were analyzed

as outlined in the EPA draft method "Microbial Survivability Test for Medical Waste Incinerator Ash."

In addition to the flue gas samples, incinerator bottom ash, baghouse flyash, and spray dryer flyash were also sampled during the test program. Daily composites were directed to laboratories for LOI/carbon content analyses as well as metals, CDD/CDF, and microbes.

Additional descriptions of the sampling and analytical procedures are provided in Section 5.

1.4 PROCESS DESCRIPTION

The MWI at the Morristown Memorial Hospital is comprised of a rotary kiln and a ram feeder. Waste is fed to the kiln at approximately 800 lb/hr and is ignited by an auxiliary burner at the charging end. Ash falls from the discharge end of the kiln, where it is sprayed with water and collected into an ash cart. Combustion gas flows from the kiln to a secondary chamber with a gas residence time of 2.5 seconds at 2000°F.

The flue gas then flows to a waste heat recovery boiler which cools the gas to approximately 400°F. The cooled gases proceed to the emission control system which consists of a spray dryer and a baghouse. Lime slurry is injected into the spray dryer by a rotary atomizer. Lime and ash that fall to the bottom are collected. After the gas passes through the spray dryer it enters the baghouse where the fly ash, unreacted lime, and reacted lime are also collected. The gas stream subsequently passes to the stack through an induced draft fan.

1.5 DESCRIPTION OF REPORT CONTENTS

Section 1 of this report provides an introduction to the medical waste testing program conducted at Morristown Memorial Hospital in Morristown, New Jersey. This section includes the test objective, an overview of the emissions measurement program, a brief process description, and this description of the report contents.

Section 2 gives a summary of the test results. Included in the contents of this section are the emissions test log, CDD/CDF results, toxic metals results, PM/PSD emissions results, halogen results, CEM results, microbial results, and ash LOI and carbon results.

Section 3 details the process and operation of the Morristown MWI and gives process results. (This section is being provided by Midwest Research Institute (MRI).)

Section 4 provides a detailed description and drawings of the sample locations.

Section 5 presents detailed descriptions of sampling and analytical procedures. The descriptions that are covered in this section are the CDD/CDF testing method, the PM and toxic metals testing method, PSD method, microbial draft testing method, the manual halogen emissions testing method, EPA Methods 1 through 4, CEM methods, and process sampling procedures.

Section 6 provides the details of the QA/QC procedures used on this program and the QC results. Included in this section is a summary of QA/QC objectives, QC procedures for the manual flue gas sampling methods, QC procedures for the ash sampling, analytical QC procedures and QA parameters, and CEM QC procedure and QA parameters.

Appendices containing the actual field data sheets and computer data listings are contained in a separate volume.

2. SUMMARY OF RESULTS

This section provides results of the test program conducted at the Morristown Memorial Hospital from November 18 through 23, 1991. Included in this section are:

- The results of manual flue gas tests conducted for CDD/CDF, toxic metals, Hg, PM, PSD, microbes, and halogens;
- The results of continuous emissions monitoring for O₂, CO₂, CO, NO_x, SO₂, THC, and HCl gases; and
- The results from analyses of incinerator bottom ash, spray dryer ash, and baghouse ash.

The test conditions were defined by the injection of carbon into the lime slurry. Condition 1 was conducted with the process running under normal steady-state conditions without carbon being introduced into the lime slurry. Condition 2 was conducted the same as Condition 1, but with a carbon concentration present in the lime slurry that produced a carbon injection rate of 4 lb/hr into the spray dryer. Test Runs 1 through 3 were operated under Condition 1, and test Runs 4 through 6 were operated under Condition 2.

2.1 EMISSIONS TEST LOG

Six test runs were conducted over six test days. Flue gas sample locations were at the spray dryer inlet and baghouse outlet. One test run was conducted on each day with all sampling trains operated concurrently. Gas concentrations were monitored with the CEM instruments during the testing period. Table 2-1 presents the emissions test log. This table shows the test date, run number, test type, and run times for all the flue gas testing conducted during this period.

2.2 CDD/CDF RESULTS

Simultaneous CDD/CDF emission tests were conducted at the spray dryer inlet and baghouse exit under the two operating conditions. Testing protocol followed EPA Method 23.

Daily ash samples were taken from the kiln, spray dryer, and baghouse. Scrubber water samples were also taken. These samples were analyzed for tetra- through octa-CDD/CDF isomers.

Table 2-1

Test Log
Morristown Memorial Hospital (1991)

Date	Location	Parameter	Run Number	Start Time	Stop Time
11/18/91	Spray Dryer Inlet	CDD/CDF	1	14:10	18:40
11/18/91	Spray Dryer Inlet	PM/Metals	1	14:09	18:40
11/18/91	Spray Dryer Inlet	Mercury	1	14:09	18:40
11/18/91	Spray Dryer Inlet	HCl	1A	14:08	15:08
11/18/91	Spray Dryer Inlet	HCl	1B	15:35	17:10
11/18/91	Spray Dryer Inlet	HCl	1C	17:40	18:40
11/18/91	Spray Dryer Inlet	Microbes	1	14:14	18:08
11/18/91	Baghouse Outlet	CDD/CDF	1	14:02	18:41
11/18/91	Baghouse Outlet	PM/Metals	1	14:01	18:40
11/18/91	Baghouse Outlet	Mercury	1	14:01	18:40
11/18/91	Baghouse Outlet	HCl	1A	14:00	15:00
11/18/91	Baghouse Outlet	HCl	1B	15:35	17:10
11/18/91	Baghouse Outlet	HCl	1C	17:40	18:40
11/18/91	Stack	Opacity		14:00	16:00
11/19/91	Spray Dryer Inlet	CDD/CDF	2	15:50	20:55
11/19/91	Spray Dryer Inlet	PM/Metals	2	15:50	20:55
11/19/91	Spray Dryer Inlet	Mercury	2	15:50	20:55
11/19/91	Spray Dryer Inlet	HCl	2A	15:53	17:16
11/19/91	Spray Dryer Inlet	HCl	2B	17:23	19:25
11/19/91	Spray Dryer Inlet	HCl	2C	19:55	20:55
11/19/91	Spray Dryer Inlet	Microbes	2	15:50	19:50
11/19/91	Baghouse Outlet	CDD/CDF	2	15:52	20:55
11/19/91	Baghouse Outlet	PM/Metals	2	15:51	20:55
11/19/91	Baghouse Outlet	Mercury	2	15:51	20:55
11/19/91	Baghouse Outlet	HCl	2A	15:50	16:50
11/19/91	Baghouse Outlet	HCl	2B	17:20	19:25
11/19/91	Baghouse Outlet	HCl	2C	19:55	20:55
11/20/91	Spray Dryer Inlet	CDD/CDF	3	12:30	22:50
11/20/91	Spray Dryer Inlet	PM/Metals	3	12:30	22:50
11/20/91	Spray Dryer Inlet	Mercury	3	12:30	22:50

Table 2-1, continued

Test Log
Morristown Memorial Hospital (1991)

Date	Location	Parameter	Run Number	Start Time	Stop Time
11/20/91	Spray Dryer Inlet	HCl	3A	12:30	13:30
11/20/91	Spray Dryer Inlet	HCl	3B	13:50	21:22
11/20/91	Spray Dryer Inlet	HCl	3C	21:32	22:32
11/20/91	Spray Dryer Inlet	Microbes	3	12:30	16:54
11/20/91	Spray Dryer Inlet	PSD	1	21:31	21:51
11/20/91	Baghouse Outlet	CDD/CDF	3	12:30	22:50
11/20/91	Baghouse Outlet	PM/Metals	3	12:30	22:50
11/20/91	Baghouse Outlet	Mercury	3	12:30	22:50
11/20/91	Baghouse Outlet	HCl	3A	12:30	13:30
11/20/91	Baghouse Outlet	HCl	3B	14:00	21:20
11/20/91	Baghouse Outlet	HCl	3C	21:35	22:35
11/21/91	Spray Dryer Inlet	CDD/CDF	4	12:45	17:50
11/21/91	Spray Dryer Inlet	PM/Metals	4	12:45	17:50
11/21/91	Spray Dryer Inlet	Mercury	4	12:45	17:50
11/21/91	Spray Dryer Inlet	HCl	4A	12:45	14:20
11/21/91	Spray Dryer Inlet	HCl	4B	14:45	16:15
11/21/91	Spray Dryer Inlet	HCl	4C	16:37	17:37
11/21/91	Spray Dryer Inlet	PSD	2	14:30	14:45
11/21/91	Baghouse Outlet	CDD/CDF	4	12:45	17:50
11/21/91	Baghouse Outlet	PM/Metals	4	12:45	17:50
11/21/91	Baghouse Outlet	Mercury	4	12:45	17:50
11/21/91	Baghouse Outlet	HCl	4A	12:45	14:20
11/21/91	Baghouse Outlet	HCl	4B	14:45	16:15
11/21/91	Baghouse Outlet	HCl	4C	16:40	17:40
11/22/91	Spray Dryer Inlet	CDD/CDF	5	12:00	18:45
11/22/91	Spray Dryer Inlet	PM/Metals	5	12:00	18:45
11/22/91	Spray Dryer Inlet	Mercury	5	12:00	18:45
11/22/91	Spray Dryer Inlet	HCl	5A	12:00	13:25
11/22/91	Spray Dryer Inlet	HCl	5B	13:36	17:10
11/22/91	Spray Dryer Inlet	HCl	5C	17:45	18:45

Table 2-1, continued

Test Log
Morristown Memorial Hospital (1991)

Date	Location	Parameter	Run Number	Start Time	Stop Time
11/22/91	Spray Dryer Inlet	PSD	3	12:45	13:00
11/22/91	Baghouse Outlet	CDD/CDF	5	12:15	18:44
11/22/91	Baghouse Outlet	PM/Metals	5	12:00	18:44
11/22/91	Baghouse Outlet	Mercury	5	12:00	18:44
11/22/91	Baghouse Outlet	HCl	5A	12:15	13:15
11/22/91	Baghouse Outlet	HCl	5B	13:34	17:20
11/22/91	Baghouse Outlet	HCl	5C	17:45	18:45
11/23/91	Spray Dryer Inlet	CDD/CDF	6	09:30	13:50
11/23/91	Spray Dryer Inlet	PM/Metals	6	09:30	13:50
11/23/91	Spray Dryer Inlet	Mercury	6	09:35	13:50
11/23/91	Spray Dryer Inlet	HCl	6A	09:30	10:30
11/23/91	Spray Dryer Inlet	HCl	6B	11:10	12:25
11/23/91	Spray Dryer Inlet	HCl	6C	12:45	13:45
11/23/91	Spray Dryer Inlet	PSD	4	10:40	10:55
11/23/91	Baghouse Outlet	CDD/CDF	6	09:30	13:50
11/23/91	Baghouse Outlet	PM/Metals	6	09:30	13:50
11/23/91	Baghouse Outlet	Mercury	6	09:30	13:50
11/23/91	Baghouse Outlet	HCl	6A	09:30	10:30
11/23/91	Baghouse Outlet	HCl	6B	11:10	12:25
11/23/91	Baghouse Outlet	HCl	6C	12:45	13:45

Tables 2-2 through 2-5 present the flue gas mass flow rates of CDD/CDF, flue gas concentrations, and removal efficiencies for each of the six runs. All CDD/CDF congeners were detected in every run in the inlet flue gas throughout the program. 2378 TCDD was detected in only one of the six runs at the baghouse outlet. Runs 3 and 5 showed substantially higher CDD/CDF at the inlet with total CDD/CDF at 223.0 and 212.3 ng/dscm versus 101.88, 91.19, 182.6, and 46.0 ng/dscm for Runs 1, 2, 4, and 6, respectively. All test runs showed a decrease in CDD/CDF concentrations from the spray dryer inlet to the baghouse outlet. Average inlet CDD/CDF concentrations ranged from 0.763 ng/dscm for 2378 TCDF for Condition 1 to 0.141 ng/dscm for Condition 2. The average concentration of 2378 TCDF for Conditions 1 and 2 at the baghouse outlet was 0.342 and 0.009 ng/dscm, respectively. Average inlet mass rates of 2378 TCDF for the two conditions were 4.427 and 0.813 $\mu\text{g/hr}$, respectively. Removal efficiencies of 2378 TCDF for Conditions 1 and 2 were 37.17 and 95.39 percent, respectively. Removal efficiencies of total CDD/CDF for Conditions 1 and 2 were 83.97 and 98.29 percent, respectively. Removal efficiencies were substantially higher for all runs in test Condition 2 with carbon injection compared to runs in Condition 1 with no carbon injection.

The CDD/CDF concentrations normalized to 7 percent O_2 for each test condition are shown in Tables 2-6 and 2-7. The results show the same trends as discussed with uncorrected values. The normalized concentration of 2378 TCDD at the outlet for Condition 1 was 0.014 ng/dscm. The concentration of 2378 TCDD at the outlet for Condition 2 was below the detection limit.

The 2378 Toxic Equivalencies corrected to 7 percent O_2 for each run in test Condition 1 and 2 are presented in Tables 2-8 and 2-9.

The flue gas sample parameters are shown in Table 2-10. Values for sampling rate, metered volume, stack temperature, gas $\text{O}_2/\text{CO}_2/\text{H}_2\text{O}$ concentrations, stack gas flow rates, and isokinetics are shown.

Daily ash samples were collected from the kiln, baghouse, and spray dryer at the end of the test run and composited into a single sample per test run. The ash was passed through a one-half inch mesh sieve to remove large pieces of glass, metal, or other large objects. The shifted ash was sorted in a pre-cleaned stainless steel drum and

TABLE 2-2. CDD/CDF INLET AND OUTLET STACK GAS EMISSIONS AND REMOVAL EFFICIENCIES FOR CONDITION 1;
MORRISTOWN HOSPITAL (1991)

CONGENER	RUN 1			RUN 2			RUN 3			Average	
	Inlet (ug/hr)	Outlet (ug/hr)	Removal Efficiency (%)	Inlet (ug/hr)	Outlet (ug/hr)	Removal Efficiency (%)	Inlet (ug/hr)	Outlet (ug/hr)	Removal Efficiency (%)	Inlet (ug/hr)	Removal Efficiency (%)
DIOXINS											
2378 TCDD	0.117	(0.070)	>40.18	0.090	(0.023)	>74.38	0.142	0.091	36.42	0.116	0.030
Other TCDD	0.507	1.135	-123.88	0.513	0.205	60.09	1.540	0.362	76.49	0.853	0.567
12378 PCDD	0.293	0.162	44.56	0.295	(0.045)	>84.74	0.595	(0.068)	>88.58	0.394	0.054
Other PCDD	2.438	2.386	2.12	2.014	0.387	80.79	4.581	0.407	91.11	3.011	1.060
123478 HxCDD	0.410	0.209	49.09	0.500	0.068	86.36	1.203	0.045	96.24	0.704	0.107
123678 HxCDD	0.566	0.301	46.75	0.616	0.068	88.91	1.294	0.068	94.75	0.825	0.146
123789 HxCDD	1.014	0.440	56.60	1.167	0.114	90.25	2.976	0.091	96.96	1.719	0.215
Other HxCDD	5.032	3.452	31.40	5.412	0.933	82.77	13.160	0.882	93.29	7.868	1.756
1234678-HpCDD	8.972	2.549	71.59	9.106	0.591	93.50	25.363	0.430	98.31	14.480	1.190
Other HpCDD	9.947	3.244	67.39	9.875	0.682	93.09	26.010	0.475	98.17	15.277	1.467
Octa-CDD	43.103	4.634	89.25	36.295	1.433	96.05	94.334	1.199	98.73	57.911	2.422
Total CDD	72.397	18.581	74.33	65.882	4.550	93.09	171.199	4.118	97.59	103.159	9.083
FURANS											
2378 TCDF	8.777	7.414	15.53	2.693	0.523	80.57	1.812	0.407	77.52	4.427	2.781
Other TCDF	41.932	47.959	-14.37	22.572	11.079	50.92	52.796	19.730	62.63	39.100	26.256
12378 PCDF	3.121	2.317	25.76	2.309	0.364	84.23	3.364	0.385	88.57	2.931	1.022
Other PCDF	8.582	6.719	21.71	7.054	1.297	81.62	10.611	1.380	86.99	8.749	3.132
123478 HxCDF	63.386	51.666	18.49	45.914	14.036	69.43	100.933	18.598	81.57	70.078	28.100
123678 HxCDF	20.479	12.279	40.04	22.957	3.640	84.14	49.949	3.394	93.21	31.128	6.438
1234678 HxCDF	5.266	3.244	38.40	6.413	0.955	85.10	13.458	0.882	93.44	8.379	1.694
234678 HxCDF	21.454	8.341	61.12	21.931	3.185	85.48	51.502	2.715	94.73	31.629	4.747
123789 HxCDF	0.566	0.301	46.75	2.565	(0.114)	>95.56	1.242	(0.136)	>89.05	1.458	0.100
Other HxCDF	43.902	25.647	41.58	41.810	9.623	76.98	109.008	9.842	90.97	64.907	15.038
1234678-HpCDF	38.032	16.681	56.14	43.092	4.095	90.50	105.074	2.715	97.42	62.066	7.830
1234789-HpCDF	14.238	3.475	75.59	16.160	1.137	92.96	38.691	0.611	98.42	23.029	1.741
Other HpCDF	55.195	24.327	55.93	61.817	6.370	89.70	85.276	2.104	97.53	67.429	10.934
Octa-CDF	186.063	27.570	85.18	175.704	6.142	96.50	543.487	3.846	99.29	301.751	12.520
Total CDF	510.991	237.940	53.44	472.989	62.561	86.77	1167.20	66.745	94.28	717.061	122.415
Total CDD+CDF	583.388	256.521	56.03	538.871	67.111	87.55	1338.40	70.863	94.71	820.221	131.498
											83.97

Note: Condition 1 is no carbon injection.

() = Estimated maximum possible concentration.

TABLE 2-3. CDD/CDF INLET AND OUTLET STACK GAS EMISSIONS AND REMOVAL EFFICIENCIES FOR CONDITION 2;
MORRISTOWN HOSPITAL (1991)

CONGENER	RUN 4			RUN 5			RUN 6			Average	
	Inlet (ug/hr)	Outlet (ug/hr)	Removal Efficiency (%)	Inlet (ug/hr)	Outlet (ug/hr)	Removal Efficiency (%)	Inlet (ug/hr)	Outlet (ug/hr)	Removal Efficiency (%)	Average Inlet (ug/hr)	Average Removal Efficiency (%)
DIOXINS											
2378 TCDD	0.105	[0.011]	>89.53	0.078	[0.011]	>85.85	0.039	(0.007)	>82.02	0.074	[0.001]
Other TCDD	0.828	0.034	95.91	1.347	0.000	100.00	0.766	0.009	98.84	0.980	0.014
12378 PCDD	0.368	(0.011)	>97.01	0.350	[0.011]	>96.85	0.130	0.009	93.14	0.282	0.003
Other PCDD	1.865	0.011	99.40	3.277	0.102	96.89	1.168	0.080	93.14	2.103	0.064
123478 HxCDD	0.723	0.014	98.13	0.945	0.045	95.21	0.273	(0.022)	>91.93	0.647	0.020
123678 HxCDD	0.828	0.020	97.55	1.114	0.045	95.94	0.324	0.045	86.28	0.755	0.037
123789 HxCDD	1.708	0.045	97.36	2.331	0.090	96.12	0.597	0.089	85.09	1.545	0.075
Other HxCDD	7.383	0.124	98.32	11.929	0.452	96.21	3.868	0.467	87.92	7.726	0.348
1234678-HpCDD	16.026	0.271	98.31	23.573	0.679	97.12	5.192	0.645	87.57	14.930	0.532
Other HpCDD	18.522	0.226	98.78	25.774	0.611	97.63	5.581	0.712	87.24	16.626	0.516
Octa-CDD	66.470	0.745	98.88	93.124	1.832	98.03	22.065	1.669	92.44	60.553	1.415
Total CDD	114.826	1.500	98.69	163.842	3.857	97.65	40.003	3.747	90.63	106.224	3.035
FURANS											
2378 TCDF	1.169	(0.113)	>90.33	0.868	0.068	92.18	0.402	0.045	88.94	0.813	0.037
Other TCDF	30.096	2.821	90.63	40.837	1.290	96.84	15.043	0.912	93.94	28.659	1.674
12378 PCDF	2.102	0.068	96.78	2.072	0.045	97.82	0.727	0.022	96.94	1.634	0.045
23478 PCDF	6.962	0.226	96.76	7.901	0.113	98.57	2.336	0.111	95.24	5.733	0.150
Other PCDF	67.653	2.415	96.43	76.675	1.176	98.47	20.430	0.467	97.71	54.919	1.353
123478 HxCDF	35.206	0.632	98.21	47.663	0.498	98.96	11.811	0.467	96.04	31.560	0.532
123678 HxCDF	9.590	0.181	98.12	11.268	(0.136)	>98.79	3.115	0.156	95.00	7.991	0.112
234678 HxCDF	38.753	0.722	98.14	57.895	0.566	99.02	12.071	0.490	95.94	36.240	0.592
123789 HxCDF	1.012	0.023	97.77	1.062	0.023	97.87	0.350	(0.018)	>94.86	0.808	0.015
Other HxCDF	79.646	1.602	97.99	85.457	0.860	98.99	22.364	0.828	96.30	62.489	1.097
1234678-HpCDF	76.848	0.925	98.80	98.953	1.086	98.90	24.142	1.135	95.30	66.648	1.049
1234789-HpCDF	29.163	0.293	98.90	37.561	0.430	98.86	8.047	0.378	95.30	24.924	0.367
Other HpCDF	115.995	1.264	98.91	153.610	1.425	99.07	32.968	1.380	95.82	100.858	1.356
Octa-CDF	428.248	1.647	99.62	446.842	3.620	99.19	79.564	3.783	95.25	318.218	3.017
Total CDF	922.441	12.931	98.60	1068.66	11.334	98.94	233.371	10.191	95.63	741.492	11.486
Total CDD + CDF	1037.27	14.432	98.61	1232.51	15.192	98.77	273.374	13.938	94.90	847.716	14.521
											98.29

Note: Condition 2 is with carbon injection.

() = Estimated maximum possible concentration.

TABLE 2-4. CDD/CDF INLET AND OUTLET STACK GAS CONCENTRATIONS FOR CONDITION 1;
MORRISTOWN HOSPITAL (1991)

CONGENER	INLET CONCENTRATION ^a (ng/dscm, as measured)				OUTLET CONCENTRATION ^a (ng/dscm, as measured)			
	Run 1	Run 2	Run 3	Average	Run 1	Run 2	Run 3	Average
DIOXINS								
2378 TCDD	0.020	0.015	0.024	0.020	(0.009)	(0.003)	0.011	0.007
Other TCDD	0.089	0.087	0.257	0.144	0.140	0.024	0.043	0.069
12378 PCDD	0.051	0.050	0.099	0.067	0.020	(0.005)	(0.008)	0.011
Other PCDD	0.426	0.341	0.763	0.510	0.295	0.046	0.048	0.130
123478 HxCDD	0.072	0.085	0.201	0.119	0.026	0.008	0.005	0.013
123678 HxCDD	0.099	0.104	0.216	0.140	0.037	0.008	0.008	0.018
123789 HxCDD	0.177	0.197	0.496	0.290	0.054	0.013	0.011	0.026
Other HxCDD	0.879	0.916	2.193	1.329	0.426	0.110	0.105	0.214
1234678-HpCDD	1.567	1.540	4.227	2.445	0.315	0.070	0.051	0.145
Other HpCDD	1.737	1.671	4.335	2.581	0.401	0.081	0.056	0.179
Octa-CDD	7.527	6.140	15.721	9.796	0.572	0.170	0.142	0.295
Total CDD	12.643	11.146	28.531	17.440	2.295	0.539	0.489	1.108
FURANS								
2378 TCDF	1.533	0.456	0.302	0.763	0.916	0.062	0.048	0.342
Other TCDF	7.323	3.819	8.799	6.647	5.923	1.312	2.343	3.193
12378 PCDF	0.545	0.391	0.561	0.499	0.286	0.043	0.046	0.125
23478 PCDF	1.499	1.193	1.768	1.487	0.830	0.154	0.164	0.382
Other PCDF	11.069	7.767	16.821	11.886	6.381	1.663	2.208	3.417
123478 HxCDF	3.576	3.884	8.324	5.261	1.516	0.431	0.403	0.784
123678 HxCDF	0.920	1.085	2.243	1.416	0.401	0.113	0.105	0.206
234678 HxCDF	3.747	3.710	8.583	5.347	1.030	0.377	0.322	0.577
123789 HxCDF	0.099	(0.434)	0.207	0.247	0.037	(0.013)	(0.016)	0.022
Other HxCDF	7.667	7.073	18.167	10.969	3.167	1.140	1.169	1.825
1234678-HpCDF	6.642	7.290	17.511	10.481	2.060	0.485	0.322	0.956
1234789-HpCDF	2.486	2.734	6.448	3.889	0.429	0.135	0.073	0.212
Other HpCDF	9.639	10.458	14.212	11.436	3.004	0.755	0.250	1.336
Octa-CDF	32.493	29.724	90.576	50.931	3.405	0.728	0.457	1.530
Total CDF	89.237	80.017	194.522	121.259	29.385	7.410	7.926	14.907
Total CDD+CDF	101.880	91.163	223.054	138.699	31.680	7.949	8.415	16.015

Note: Condition 1 is no carbon injection.

^a Standard conditions are defined as 1 atm and 68 F.

() = Estimated maximum possible concentration.

TABLE 2-5. CDD/CDF INLET AND OUTLET STACK GAS CONCENTRATIONS FOR CONDITION 2;
MORRISTOWN HOSPITAL (1991)

CONGENER	INLET CONCENTRATION a (ng/dscm, as measured)				OUTLET CONCENTRATION a (ng/dscm, as measured)			
	Run 4	Run 5	Run 6	Average	Run 4	Run 5	Run 6	Average
DIOXINS								
2378 TCDD	0.019	0.013	0.007	0.013	[0.001]	[0.001]	[0.001]	0.000
Other TCDD	0.146	0.232	0.129	0.169	0.004	0.000	0.001	0.003
12378 PCDD	0.065	0.060	0.022	0.049	(0.001)	[0.001]	0.001	0.001
Other PCDD	0.328	0.564	0.197	0.363	0.001	0.012	0.009	0.008
123478 HxCDD	0.127	0.163	0.046	0.112	0.002	0.005	(0.003)	0.003
123678 HxCDD	0.146	0.192	0.055	0.131	0.002	0.005	0.005	0.004
123789 HxCDD	0.301	0.402	0.101	0.268	0.005	0.011	0.011	0.009
Other HxCDD	1.300	2.055	0.652	1.335	0.015	0.053	0.055	0.041
1234678-HpCDD	2.821	4.061	0.875	2.586	0.033	0.079	0.076	0.063
Other HpCDD	3.261	4.440	0.940	2.880	0.027	0.071	0.084	0.061
Octa-CDD	11.702	16.042	3.717	10.487	0.091	0.213	0.197	0.167
Total CDD	20.215	28.224	6.738	18.392	0.182	0.449	0.443	0.359
FURANS								
2378 TCDF	0.206	0.149	0.068	0.141	(0.014)	0.008	0.005	0.009
Other TCDF	5.298	7.035	2.534	4.956	0.343	0.150	0.108	0.200
12378 PCDF	0.370	0.357	0.122	0.283	0.008	0.005	0.003	0.005
23478 PCDF	1.226	1.361	0.394	0.993	0.027	0.013	0.013	0.018
Other PCDF	11.910	13.208	3.441	9.520	0.293	0.137	0.055	0.162
123478 HxCDF	6.198	8.211	1.990	5.466	0.077	0.058	0.055	0.063
123678 HxCDF	1.688	1.941	0.525	1.385	0.022	(0.016)	0.018	0.019
234678 HxCDF	6.822	9.973	2.033	6.276	0.088	0.066	0.058	0.070
123789 HxCDF	0.178	0.183	0.059	0.140	0.003	0.003	(0.002)	0.002
Other HxCDF	14.022	14.721	3.767	10.837	0.195	0.100	0.098	0.131
1234678-HpCDF	13.529	17.046	4.066	11.547	0.112	0.126	0.134	0.124
1234789-HpCDF	5.134	6.470	1.355	4.320	0.036	0.050	0.045	0.043
Other HpCDF	20.421	26.461	5.553	17.478	0.154	0.166	0.163	0.161
Octa-CDF	75.393	76.975	13.402	55.257	0.200	0.421	0.447	0.356
Total CDF	162.396	184.092	39.309	128.599	1.572	1.319	1.205	1.365
Total CDD+CDF	182.611	212.316	46.047	146.991	1.755	1.771	1.649	1.725

Note: Condition 2 is with carbon injection.

a Standard conditions are defined as 1 atm and 68 F.

() = Estimated maximum possible concentration.

TABLE 2-6. CDD/CDF INLET AND OUTLET STACK GAS CONCENTRATIONS FOR CONDITION 1;
MORRISTOWN HOSPITAL (1991)

CONGENER	INLET CONCENTRATION (ng/dscm, adjusted to 7% O ₂)				OUTLET CONCENTRATION (ng/dscm, adjusted to 7% O ₂)			
	Run 1	Run 2	Run 3	Average	Run 1	Run 2	Run 3	Average
DIOXINS								
2378 TCDD	0.029	0.022	0.032	0.028	(0.018)	(0.006)	0.020	0.014
Other TCDD	0.126	0.123	0.346	0.198	0.287	0.050	0.080	0.139
12378 PCDD	0.072	0.071	0.134	0.092	0.041	(0.011)	(0.015)	0.022
Other PCDD	0.604	0.483	1.030	0.706	0.602	0.094	0.090	0.262
123478 HxCDD	0.101	0.120	0.271	0.164	0.053	0.017	0.010	0.026
123678 HxCDD	0.140	0.148	0.291	0.193	0.076	0.017	0.015	0.036
123789 HxCDD	0.251	0.280	0.669	0.400	0.111	0.028	0.020	0.053
Other HxCDD	1.246	1.299	2.960	1.835	0.871	0.226	0.194	0.430
1234678-HpCDD	2.222	2.185	5.704	3.370	0.643	0.143	0.095	0.294
Other HpCDD	2.464	2.370	5.850	3.561	0.819	0.165	0.105	0.363
Octa-CDD	10.676	8.709	21.216	13.534	1.170	0.347	0.264	0.594
Total CDD	17.932	15.809	38.504	24.082	4.691	1.102	0.906	2.233
FURANS								
2378 TCDF	2.174	0.646	0.407	1.076	1.872	0.127	0.090	0.696
Other TCDF	10.387	5.416	11.874	9.226	12.107	2.683	4.342	6.377
12378 PCDF	0.773	0.554	0.757	0.695	0.585	0.088	0.085	0.253
23478 PCDF	2.126	1.693	2.386	2.068	1.696	0.314	0.304	0.771
Other PCDF	15.701	11.017	22.700	16.473	13.043	3.399	4.093	6.845
123478 HxCDF	5.072	5.509	11.234	7.272	3.100	0.881	0.747	1.576
123678 HxCDF	1.304	1.539	3.027	1.957	0.819	0.231	0.194	0.415
234678 HxCDF	5.314	5.262	11.583	7.386	2.106	0.771	0.598	1.158
123789 HxCDF	0.140	(0.615)	0.279	0.345	0.076	(0.028)	(0.030)	0.044
Other HxCDF	10.874	10.032	24.517	15.141	6.475	2.330	2.166	3.657
1234678-HpCDF	9.420	10.340	23.632	14.464	4.211	0.991	0.598	1.933
1234789-HpCDF	3.527	3.878	8.702	5.369	0.877	0.275	0.134	0.429
Other HpCDF	13.672	14.833	19.179	15.895	6.141	1.542	0.463	2.716
Octa-CDF	46.087	42.160	122.233	70.160	6.960	1.487	0.846	3.098
Total CDF	126.571	113.494	262.511	167.525	60.066	15.148	14.689	29.968
Total CDD+CDF	144.503	129.303	301.01	191.607	64.757	16.249	15.60	32.201

Note: Condition 1 is no carbon injection.

() = Estimated maximum possible concentration.

TABLE 2-7. CDD/CDF INLET AND OUTLET STACK GAS CONCENTRATIONS FOR CONDITION 2;
MORRISTOWN HOSPITAL (1991)

CONGENER	INLET CONCENTRATION (ng/dscm, adjusted to 7% O ₂)				OUTLET CONCENTRATION (ng/dscm, adjusted to 7% O ₂)			
	Run 4	Run 5	Run 6	Average	Run 4	Run 5	Run 6	Average
DIOXINS								
2378 TCDD	0.024	0.018	0.009	0.017	[0.003]	[0.003]	[0.001]	0.000
Other TCDD	0.193	0.319	0.176	0.229	0.008	0.000	0.002	0.005
12378 PCDD	0.086	0.083	0.030	0.066	(0.003)	[0.003]	0.002	0.002
Other PCDD	0.435	0.777	0.268	0.493	0.003	0.023	0.018	0.014
123478 HxCDD	0.168	0.224	0.063	0.152	0.003	0.010	(0.005)	0.006
123678 HxCDD	0.193	0.264	0.074	0.177	0.005	0.010	0.010	0.008
123789 HxCDD	0.398	0.553	0.137	0.363	0.011	0.020	0.020	0.017
Other HxCDD	1.721	2.828	0.888	1.812	0.030	0.100	0.104	0.078
1234678-HpCDD	3.735	5.588	1.192	3.505	0.064	0.150	0.143	0.119
Other HpCDD	4.317	6.110	1.281	3.903	0.054	0.135	0.158	0.116
Octa-CDD	15.491	22.078	5.065	14.211	0.177	0.406	0.371	0.318
Total CDD	26.761	38.843	9.182	24.929	0.357	0.855	0.832	0.684
FURANS								
2378 TCDF	0.272	0.206	0.092	0.190	(0.027)	0.015	0.010	0.017
Other TCDF	7.014	9.682	3.453	6.716	0.671	0.286	0.203	0.387
12378 PCDF	0.490	0.491	0.167	0.383	0.016	0.010	0.005	0.010
23478 PCDF	1.623	1.873	0.536	1.344	0.054	0.025	0.025	0.034
Other PCDF	15.767	18.178	4.689	12.878	0.575	0.261	0.104	0.313
123478 HxCDF	8.205	11.300	2.711	7.405	0.150	0.110	0.104	0.121
123678 HxCDF	2.235	2.671	0.715	1.874	0.043	(0.030)	0.035	0.036
234678 HxCDF	9.032	13.726	2.771	8.509	0.172	0.125	0.109	0.135
123789 HxCDF	0.236	0.252	0.080	0.189	0.005	0.005	(0.004)	0.005
Other HxCDF	18.562	20.260	5.133	14.652	0.381	0.191	0.184	0.252
1234678-HpCDF	17.910	23.459	5.542	15.637	0.220	0.241	0.252	0.238
1234789-HpCDF	6.797	8.905	1.847	5.850	0.070	0.095	0.084	0.083
Other HpCDF	27.033	36.417	7.567	23.673	0.301	0.316	0.306	0.308
Octa-CDF	99.806	105.935	18.263	74.668	0.392	0.802	0.840	0.678
Total CDF	214.981	253.354	53.568	173.968	3.077	2.512	2.263	2.618
Total CDD+CDF	241.742	292.197	62.75	198.897	3.434	3.367	3.096	3.301

Note: Condition 2 is with carbon injection.

() = Estimated maximum possible concentration.

TABLE 2-8. CDD/CDF AVERAGE FLUE GAS TOXIC EQUIVALENCIES CORRECTED TO 7% O₂ FOR CONDITION 1; MORRISTOWN HOSPITAL (1991)

CONGENER	Toxic Equivalency Factor a	INLET TOXIC EQUIVALENCIES (ng/dscm @ 7% O ₂)				OUTLET TOXIC EQUIVALENCIES (ng/dscm @ 7% O ₂)			
		Run 1	Run 2	Run 3	Average	Run 1	Run 2	Run 3	Average
DIOXINS									
2378 TCDD	1.00000	0.029	0.022	0.032	0.028	(0.018)	(0.006)	0.020	0.014
Other TCDD	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12378 PCDD	0.50000	0.036	0.035	0.067	0.046	0.020	(0.006)	(0.007)	0.011
Other PCDD	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123478 HxCDD	0.10000	0.010	0.012	0.027	0.016	0.005	0.002	0.001	0.003
123678 HxCDD	0.10000	0.014	0.015	0.029	0.019	0.008	0.002	0.001	0.004
123789 HxCDD	0.10000	0.025	0.028	0.067	0.040	0.011	0.003	0.002	0.005
Other HxCDD	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1234678-HpCDD	0.01000	0.022	0.022	0.057	0.034	0.006	0.001	0.001	0.003
Other HpCDD	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Octa-CDD	0.00100	0.011	0.009	0.021	0.014	0.001	0.000	0.000	0.001
Total CDD		0.147	0.142	0.300	0.197	0.070	0.019	0.033	0.041
FURANS									
2378 TCDF	0.10000	0.217	0.065	0.041	0.108	0.187	0.013	0.009	0.070
Other TCDF	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12378 PCDF	0.05000	0.039	0.028	0.038	0.035	0.029	0.004	0.004	0.013
23478 PCDF	0.50000	1.063	0.846	1.193	1.034	0.848	0.157	0.152	0.386
Other PCDF	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123478 HxCDF	0.10000	0.507	0.551	1.123	0.727	0.310	0.088	0.075	0.158
123678 HxCDF	0.10000	0.130	0.154	0.303	0.196	0.082	0.023	0.019	0.041
234678 HxCDF	0.10000	0.531	0.526	1.158	0.739	0.211	0.077	0.060	0.116
123789 HxCDF	0.10000	0.014	(0.062)	0.028	0.034	0.008	(0.003)	(0.003)	0.004
Other HxCDF	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1234678-HpCDF	0.01000	0.094	0.103	0.236	0.145	0.042	0.010	0.006	0.019
1234789-HpCDF	0.01000	0.035	0.039	0.087	0.054	0.009	0.003	0.001	0.004
Other HpCDF	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Octa-CDF	0.00100	0.046	0.042	0.122	0.070	0.007	0.001	0.001	0.003
Total CDF		2.678	2.415	4.330	3.141	1.732	0.379	0.330	0.814
Total CDD+CDF		2.825	2.558	4.630	3.338	1.802	0.398	0.363	0.854

a North Atlantic Treaty Organization, Committee on the Challenges of Modern Society. Pilot Study on International Information Exchange on Dioxins and Related Compounds: International Toxicity Equivalency Factor (I-TEF) Methods of Risk Assessment for Complex Mixtures of Dioxins and Related Compounds. Report No. 176, August 1988.

Note: Condition 1 is no carbon injection.

() = Estimated maximum possible concentration

TABLE 2-9. CDD/CDF AVERAGE FLUE GAS TOXIC EQUIVALENCIES CORRECTED TO 7% O₂ FOR CONDITION 2; MORRISTOWN HOSPITAL (1991)

CONGENER	Toxic Equivalency Factor ^a	INLET TOXIC EQUIVALENCIES (ng/dscm @ 7% O ₂)				OUTLET TOXIC EQUIVALENCIES (ng/dscm @ 7% O ₂)			
		Run 4	Run 5	Run 6	Average	Run 4	Run 5	Run 6	Average
DIOXINS									
2378 TCDD	1.00000	0.024	0.018	0.009	0.017	[0.003]	[0.003]	[0.001]	0.000
Other TCDD	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12378 PCDD	0.50000	0.043	0.041	0.015	0.033	(0.001)	[0.001]	0.001	0.001
Other PCDD	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123478 HxCDD	0.10000	0.017	0.022	0.006	0.015	0.000	0.001	(0.000)	0.001
123678 HxCDD	0.10000	0.019	0.026	0.007	0.018	0.000	0.001	0.001	0.001
123789 HxCDD	0.10000	0.040	0.055	0.014	0.036	0.001	0.002	0.002	0.002
Other HxCDD	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1234678-HpCDD	0.01000	0.037	0.056	0.012	0.035	0.001	0.002	0.001	0.001
Other HpCDD	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Octa-CDD	0.00100	0.015	0.022	0.005	0.014	0.000	0.000	0.000	0.000
Total CDD		0.196	0.242	0.068	0.169	0.004	0.006	0.006	0.006
FURANS									
2378 TCDF	0.10000	0.027	0.021	0.009	0.019	(0.003)	0.002	0.001	0.002
Other TCDF	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12378 PCDF	0.05000	0.024	0.025	0.008	0.019	0.001	0.001	0.000	0.001
23478 PCDF	0.50000	0.811	0.937	0.268	0.672	0.027	0.013	0.012	0.017
Other PCDF	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
123478 HxCDF	0.10000	0.820	1.130	0.271	0.741	0.015	0.011	0.010	0.012
123678 HxCDF	0.10000	0.223	0.267	0.072	0.187	0.004	(0.003)	0.003	0.004
234678 HxCDF	0.10000	0.903	1.373	0.277	0.851	0.017	0.013	0.011	0.014
123789 HxCDF	0.10000	0.024	0.025	0.008	0.019	0.001	0.001	(0.000)	0.000
Other HxCDF	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1234678-HpCDF	0.01000	0.179	0.235	0.055	0.156	0.002	0.002	0.003	0.002
1234789-HpCDF	0.01000	0.068	0.089	0.018	0.058	0.001	0.001	0.001	0.001
Other HpCDF	0.00000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Octa-CDF	0.00100	0.100	0.106	0.018	0.075	0.000	0.001	0.001	0.001
Total CDF		3.181	4.206	1.006	2.797	0.071	0.046	0.043	0.053
Total CDD+CDF		3.377	4.448	1.074	2.966	0.074	0.052	0.049	0.059

^a North Atlantic Treaty Organization, Committee on the Challenges of Modern Society. Pilot Study on International Information Exchange on Dioxins and Related Compounds: International Toxicity Equivalency Factor (I-TEF) Methods of Risk Assessment for Complex Mixtures of Dioxins and Related Compounds. Report No. 176, August 1988.

Note: Condition 2 is with carbon injection.

() = Estimated maximum possible concentration

TABLE 2-10. SUMMARY OF CDD/CDF FLUE GAS SAMPLING PARAMETERS
MORRISTOWN MEMORIAL HOSPITAL (1991)

	Spray Dryer Inlet							
	Run 1	Run 2	Run 3	Average	Run 4	Run 5	Run 6	Average
Total Sample Time (min)	240	240	240	240	240	240	240	240
Average Sampling Rate (dscfm)	0.43	0.68	0.68	0.60	0.64	0.66	0.67	0.66
Dry Standard Meter Volume (dscf)	104	163	164	143	153	158	162	157
Dry Standard Meter Volume (dscm)	2.9	4.6	4.6	4.1	4.3	4.5	4.6	4.5
Average Stack Temperature (F)	407	408	405	407	409	401	407	406
Oxygen Concentration (% V)	11.1	11.1	10.6	10.9	10.4	10.8	10.7	10.6
Carbon Dioxide Concentration (% V)	6.4	7.8	6.7	7.0	6.6	6.5	6.5	6.5
Percent Moisture (% V)	15.8	15.3	14.8	15.3	14.4	13.7	13.3	13.8
Volumetric Flow Rate (dscfm)	3370	3479	3531	3460	3343	3416	3494	3418
Volumetric Flow Rate (dscmm)	95.4	98.5	100.0	98.0	94.7	96.8	98.9	96.8
Percent Isokinetic (%)	102.6	102.0	101.1	NA	99.6	101.0	100.8	NA
	Bag House Outlet							
	Run 1	Run 2	Run 3	Average	Run 4	Run 5	Run 6	Average
Total Sample Time (min)	240	240	240	240	240	240	240	240
Average Sampling Rate (dscfm)	0.51	0.55	0.55	0.54	0.55	0.56	0.56	0.56
Dry Standard Meter Volume (dscf)	123	131	131	129	129	134	134	132
Dry Standard Meter Volume (dscm)	3.5	3.7	3.7	3.6	3.6	3.8	3.8	3.7
Average Stack Temperature (F)	279	292	293	288	293	291	292	292
Oxygen Concentration (% V)	14.1	14.1	13.4	13.9	13.8	13.6	13.5	13.6
Carbon Dioxide Concentration (% V)	5.0	5.0	5.3	5.1	5.2	5.0	5.3	5.2
Percent Moisture (% V)	14.7	14.7	14.6	14.6	15.0	13.3	13.3	13.8
Volumetric Flow Rate (dscfm)	4765	4968	4956	4897	4842	5055	4978	4958
Volumetric Flow Rate (dscmm)	135.0	140.7	140.4	138.7	137.1	143.2	141.0	140.4
Percent Isokinetic (%)	92.7	94.4	94.9	NA	96.7	94.9	96.5	NA

NA : Not applicable

allowed to cool. An approximately one liter bottle was filled and sent to the laboratory for CDD/CDF analyses.

Ash samples were analyzed for the same CDD/CDF isomers that the flue gas samples were analyzed for. All CDD/CDF congeners were detected in the test run samples. Tables 2-11 and 2-12 gives CDD/CDF concentrations and toxic equivalencies in the baghouse residue for Condition 1 and 2. The average total CDD/CDF concentrations were 24.2 and 32.7 parts per billion for Conditions 1 and 2. Test Run 5 had the highest total CDD/CDF concentration at 44.7 ppb.wt. Run 5 also showed the highest removal efficiency of 98.77 percent for total CDD/CDF in the flue gas.

Tables 2-13 through 2-16 present the CDD/CDF concentrations and toxic equivalencies in the bottom ash and spray dryer residue. Total CDD/CDF values for Conditions 1 and 2 in the bottom ash were 96.5 and 73.1 ppb.wt, and 9.2 and 6.2 ppb.wt in the spray dryer residue, respectively.

Table 2-17 presents the CDD/CDF make-up water and lime slurry tank analysis results. Spray dryer make-up water was sampled every test day. However, only one sample was analyzed with the results assumed to represent all test days. Results are given in units of parts per trillion by weight (ppt,wt). All congeners were present below the detection limit except for octa-CDD and CDF which were detected at very low levels.

2.3 TOXIC METALS RESULTS

2.3.1 Overview

A single sampling train was used to determine emission rates of a series of 13 metals [aluminum (Al), antimony (Sb), arsenic (As), barium (Ba), beryllium (Be), cadmium (Cd), chromium (Cr), copper (Cu), lead (Pb), mercury (Hg), nickel (Ni), silver (Ag), thallium (Tl)], and particulate matter (PM). Mercury was also sampled by Method 101A and will be discussed in Section 2.5. Three sampling runs were performed under both test conditions (without carbon injection and with carbon injection) in order to ensure representative test results.

Sampling locations, method, and QA/QC are discussed in Sections 4, 5, and 6, respectively. The average metals emission rates and removal efficiencies are summarized in Section 2.3.3. The results for each individual run are presented in Section 2.3.4.

TABLE 2-11. CDD/CDF CONCENTRATIONS AND 2378 TOXIC EQUIVALENT CONCENTRATIONS IN BAGHOUSE RESIDUE FOR CONDITION 1; MORRISTOWN HOSPITAL (1991)

CONGENER	CDD/CDF ASH CONCENTRATIONS				2378 TOXIC EQUIVALENCIES				
	RUN 1 (ppb)	RUN 2 (ppb)	RUN 3 (ppb)	Average (ppb)	Toxic Equiv. Factor a	RUN 1 (ppb)	RUN 2 (ppb)	RUN 3 (ppb)	Average (ppb)
DIOXINS									
2378 TCDD	0.003	0.002	0.003	0.003	1.00000	0.003	0.002	0.003	0.003
Other TCDD	0.034	0.011	0.038	0.028	0.00000	0.000	0.000	0.000	0.000
12378 PCDD	0.014	0.007	0.014	0.012	0.50000	0.007	0.003	0.007	0.006
Other PCDD	0.124	0.052	0.101	0.092	0.00000	0.000	0.000	0.000	0.000
123478 HxCDD	0.029	0.011	0.022	0.021	0.10000	0.003	0.001	0.002	0.002
123678 HxCDD	0.036	0.013	0.023	0.024	0.10000	0.004	0.001	0.002	0.002
123789 HxCDD	0.080	0.028	0.085	0.064	0.10000	0.008	0.003	0.008	0.006
Other HxCDD	0.399	0.140	0.241	0.260	0.00000	0.000	0.000	0.000	0.000
1234678-HpCDD	0.644	0.219	0.395	0.419	0.01000	0.006	0.002	0.004	0.004
Other Hepta-CDD	0.656	0.247	0.400	0.434	0.00000	0.000	0.000	0.000	0.000
Octa-CDD	2.490	1.070	1.220	1.593	0.00100	0.002	0.001	0.001	0.002
Total CDD	4.508	1.799	2.541	2.949		0.033	0.013	0.028	0.025
FURANS									
2378 TCDF	0.040	0.020	0.042	0.034	0.10000	0.004	0.002	0.004	0.003
Other TCDF	1.350	0.631	1.438	1.140	0.00000	0.000	0.000	0.000	0.000
12378 PCDF	0.096	0.047	0.086	0.076	0.05000	0.005	0.002	0.004	0.004
23478 PCDF	0.264	0.104	0.192	0.187	0.50000	0.132	0.052	0.096	0.093
Other PCDF	2.470	1.019	1.782	1.757	0.00000	0.000	0.000	0.000	0.000
123478 HxCDF	1.300	0.522	0.845	0.889	0.10000	0.130	0.052	0.085	0.089
123678 HxCDF	0.392	0.208	0.282	0.294	0.10000	0.039	0.021	0.028	0.029
234678 HxCDF	1.180	0.463	0.793	0.812	0.10000	0.118	0.046	0.079	0.081
123789 HxCDF	0.041	0.017	0.030	0.029	0.10000	0.004	0.002	0.003	0.003
Other HxCDF	3.008	1.380	1.921	2.103	0.00000	0.000	0.000	0.000	0.000
1234678-HpCDF	3.300	1.770	2.170	2.413	0.01000	0.033	0.018	0.022	0.024
1234789-HpCDF	0.942	0.373	0.669	0.661	0.01000	0.009	0.004	0.007	0.007
Other Hepta-CDF	4.448	1.977	2.941	3.122	0.00000	0.000	0.000	0.000	0.000
Octa-CDF	13.140	3.910	6.050	7.700	0.00100	0.013	0.004	0.006	0.008
Total CDF	31.970	12.441	19.240	21.217		0.488	0.203	0.334	0.341
Total CDD+CDF	36.478	14.240	21.781	24.166		0.521	0.216	0.362	0.366

a North Atlantic Treaty Organization, Committee on Challenges of Modern Society. Pilot Study on International Information Exchange on Dioxins and Related Compounds: International Toxicity Equivalency Factor (I - TEF) Methods of Risk Assessment for Complex Mixtures Of Dioxins and Related Compounds. Report No. 176, August 1988.

TABLE 2-12. CDD/CDF CONCENTRATIONS AND 2378 TOXIC EQUIVALENT CONCENTRATIONS IN BAGHOUSE RESIDUE FOR CONDITION 2; MORRISTOWN HOSPITAL (1991)

CONGENER	CDD/CDF ASH CONCENTRATIONS				2378 TOXIC EQUIVALENCIES				
	RUN 4 (ppb)	RUN 5 (ppb)	RUN 6 (ppb)	Average (ppb)	Toxic Equiv. Factor a	RUN 4 (ppb)	RUN 5 (ppb)	RUN 6 (ppb)	Average (ppb)
DIOXINS									
2378 TCDD	0.003	0.002	0.001	0.002	1.00000	0.003	0.002	0.001	0.002
Other TCDD	0.031	0.039	0.029	0.033	0.00000	0.000	0.000	0.000	0.000
12378 PCDD	0.015	0.012	0.006	0.011	0.50000	0.007	0.006	0.003	0.005
Other PCDD	0.113	0.157	0.081	0.117	0.00000	0.000	0.000	0.000	0.000
123478 HxCDD	0.030	0.028	0.012	0.024	0.10000	0.003	0.003	0.001	0.002
123678 HxCDD	0.039	0.037	0.020	0.032	0.10000	0.004	0.004	0.002	0.003
123789 HxCDD	0.083	0.065	0.029	0.059	0.10000	0.008	0.006	0.003	0.006
Other HxCDD	0.363	0.442	0.232	0.346	0.00000	0.000	0.000	0.000	0.000
1234678-HpCDD	0.705	0.733	0.300	0.579	0.01000	0.007	0.007	0.003	0.006
Other Hepta-CDD	0.755	0.857	0.352	0.655	0.00000	0.000	0.000	0.000	0.000
Octa-CDD	2.570	3.710	1.010	2.430	0.00100	0.003	0.004	0.001	0.002
Total CDD	4.707	6.083	2.073	4.288		0.036	0.032	0.015	0.027
FURANS									
2378 TCDF	0.039	0.030	0.013	0.027	0.10000	0.004	0.003	0.001	0.003
Other TCDF	1.431	1.210	0.443	1.028	0.00000	0.000	0.000	0.000	0.000
12378 PCDF	0.078	0.073	0.034	0.061	0.05000	0.004	0.004	0.002	0.003
23478 PCDF	0.306	0.259	0.104	0.223	0.50000	0.153	0.130	0.052	0.112
Other PCDF	2.976	2.719	1.062	2.252	0.00000	0.000	0.000	0.000	0.000
123478 HxCDF	1.460	1.290	0.506	1.085	0.10000	0.146	0.129	0.051	0.109
123678 HxCDF	0.445	0.371	0.160	0.325	0.10000	0.045	0.037	0.016	0.033
234678 HxCDF	1.590	1.180	0.526	1.099	0.10000	0.159	0.118	0.053	0.110
123789 HxCDF	0.040	0.027	0.012	0.026	0.10000	0.004	0.003	0.001	0.003
Other HxCDF	3.085	3.062	1.187	2.444	0.00000	0.000	0.000	0.000	0.000
1234678-HpCDF	3.450	3.790	1.280	2.840	0.01000	0.035	0.038	0.013	0.028
1234789-HpCDF	1.440	1.050	0.392	0.961	0.01000	0.014	0.011	0.004	0.010
Other Hepta-CDF	5.700	5.860	1.898	4.486	0.00000	0.000	0.000	0.000	0.000
Octa-CDF	13.040	17.690	4.040	11.590	0.00100	0.013	0.018	0.004	0.012
Total CDF	35.080	38.610	11.656	28.449		0.576	0.489	0.196	0.420
Total CDD+CDF	39.787	44.693	13.729	32.736		0.612	0.521	0.211	0.448

a North Atlantic Treaty Organization, Committee on Challenges of Modern Society. Pilot Study on International Information Exchange on Dioxins and Related Compounds: International Toxicity Equivalency Factor (I - TEF) Methods of Risk Assessment for Complex Mixtures Of Dioxins and Related Compounds. Report No. 176, August 1988.

TABLE 2-13. CDD/CDF CONCENTRATIONS AND 2378 TOXIC EQUIVALENT CONCENTRATIONS
IN BOTTOM ASH FOR CONDITION 1; MORRISTOWN HOSPITAL (1991)

CONGENER	CDD/CDF ASH CONCENTRATIONS				2378 TOXIC EQUIVALENCIES				
	RUN 1 (ppb)	RUN 2 (ppb)	RUN 3 (ppb)	Average (ppb)	Toxic Equiv Factor a	RUN 1 (ppb)	RUN 2 (ppb)	RUN 3 (ppb)	Average (ppb)
DIOXINS									
2378 TCDD	(0.015)	0.009	0.018	0.015	1.00000	(0.015)	0.009	0.018	0.015
Other TCDD	3.764	0.183	0.253	1.400	0.00000	0.000	0.000	0.000	0.000
12378 PCDD	0.165	0.077	0.108	0.117	0.50000	0.083	0.039	0.054	0.058
Other PCDD	3.875	0.587	0.761	1.741	0.00000	0.000	0.000	0.000	0.000
123478 HxCDD	0.351	0.184	0.242	0.259	0.10000	0.035	0.018	0.024	0.026
123678 HxCDD	0.359	0.126	0.155	0.213	0.10000	0.036	0.013	0.016	0.021
123789 HxCDD	0.893	0.418	0.499	0.603	0.10000	0.089	0.042	0.050	0.060
Other HxCDD	5.447	1.082	1.364	2.631	0.00000	0.000	0.000	0.000	0.000
1234678-HpCDD	3.740	2.150	1.790	2.560	0.01000	0.037	0.022	0.018	0.026
Other Hepta-CDD	4.930	2.200	1.890	3.007	0.00000	0.000	0.000	0.000	0.000
Octa-CDD	12.200	11.780	6.480	10.153	0.00100	0.012	0.012	0.006	0.010
Total CDD	35.740	18.796	13.560	22.699		0.308	0.154	0.186	0.216
FURANS									
2378 TCDF	0.349	0.148	0.263	0.253	0.10000	0.035	0.015	0.026	0.025
Other TCDF	16.591	7.422	11.507	11.840	0.00000	0.000	0.000	0.000	0.000
12378 PCDF	0.465	0.311	0.491	0.422	0.05000	0.023	0.016	0.025	0.021
23478 PCDF	1.100	0.696	1.090	0.962	0.50000	0.550	0.348	0.545	0.481
Other PCDF	7.495	9.733	12.759	9.996	0.00000	0.000	0.000	0.000	0.000
123478 HxCDF	5.030	5.490	6.440	5.653	0.10000	0.503	0.549	0.644	0.565
123678 HxCDF	1.400	1.160	1.310	1.290	0.10000	0.140	0.116	0.131	0.129
234678 HxCDF	2.860	2.800	2.920	2.860	0.10000	0.286	0.280	0.292	0.286
123789 HxCDF	0.078	0.079	0.104	0.087	0.10000	0.008	0.008	0.010	0.009
Other HxCDF	0.182	9.161	10.466	6.603	0.00000	0.000	0.000	0.000	0.000
1234678-HpCDF	7.600	12.080	7.050	8.910	0.01000	0.076	0.121	0.071	0.089
1234789-HpCDF	1.310	1.030	0.878	1.073	0.01000	0.013	0.010	0.009	0.011
Other Hepta-CDF	7.850	8.260	6.052	7.387	0.00000	0.000	0.000	0.000	0.000
Octa-CDF	10.400	26.440	12.610	16.483	0.00100	0.010	0.026	0.013	0.016
Total CDF	62.710	84.810	73.940	73.820		1.644	1.489	1.765	1.633
Total CDD+CDF	98.450	103.606	87.500	96.519		1.953	1.643	1.952	1.849

a North Atlantic Treaty Organization, Committee on Challenges of Modern Society. Pilot Study on International Information Exchange on Dioxins and Related Compounds: International Toxicity Equivalency Factor (I - TEF) Methods of Risk Assessment for Complex Mixtures Of Dioxins and Related Compounds. Report No. 176, August 1988.

() = Estimated maximum possible concentration

TABLE 2-14. CDD/CDF CONCENTRATIONS AND 2378 TOXIC EQUIVALENT CONCENTRATIONS IN BOTTOM ASH FOR CONDITION 2; MORRISTOWN HOSPITAL (1991)

CONGENER	CDD/CDF ASH CONCENTRATIONS				2378 TOXIC EQUIVALENCIES				
	RUN 4 (ppb)	RUN 5 (ppb)	RUN 6 (ppb)	Average (ppb)	Toxic Equiv. Factor a	RUN 4 (ppb)	RUN 5 (ppb)	RUN 6 (ppb)	Average (ppb)
DIOXINS									
2378 TCDD	0.007	0.012	0.016	0.012	1.00000	0.007	0.012	0.016	0.012
Other TCDD	0.178	0.285	0.193	0.219	0.00000	0.000	0.000	0.000	0.000
12378 PCDD	0.046	0.099	0.114	0.086	0.50000	0.023	0.050	0.057	0.043
Other PCDD	0.431	0.764	0.723	0.639	0.00000	0.000	0.000	0.000	0.000
123478 HxCDD	0.088	0.236	0.202	0.175	0.10000	0.009	0.024	0.020	0.018
123678 HxCDD	0.073	0.157	0.122	0.117	0.10000	0.007	0.016	0.012	0.012
123789 HxCDD	0.199	0.543	0.383	0.375	0.10000	0.020	0.054	0.038	0.038
Other HxCDD	0.661	1.394	1.033	1.029	0.00000	0.000	0.000	0.000	0.000
1234678-HpCDD	0.511	2.370	1.510	1.464	0.01000	0.005	0.024	0.015	0.015
Other Hepta-CDD	2.869	2.460	1.660	2.330	0.00000	0.000	0.000	0.000	0.000
Octa-CDD	3.830	10.440	5.910	6.727	0.00100	0.004	0.010	0.006	0.007
Total CDD	8.892	18.760	11.866	13.173		0.075	0.189	0.165	0.143
FURANS									
2378 TCDF	0.110	0.185	0.206	0.167	0.10000	0.011	0.019	0.021	0.017
Other TCDF	4.600	8.885	8.744	7.410	0.00000	0.000	0.000	0.000	0.000
12378 PCDF	0.165	0.385	0.463	0.338	0.05000	0.008	0.019	0.023	0.017
23478 PCDF	0.364	0.917	0.920	0.734	0.50000	0.182	0.459	0.460	0.367
Other PCDF	4.661	11.428	10.997	9.029	0.00000	0.000	0.000	0.000	0.000
123478 HxCDF	2.110	6.800	4.970	4.627	0.10000	0.211	0.680	0.497	0.463
123678 HxCDF	0.488	1.340	1.250	1.026	0.10000	0.049	0.134	0.125	0.103
234678 HxCDF	1.030	3.080	2.270	2.127	0.10000	0.103	0.308	0.227	0.213
123789 HxCDF	0.037	0.125	0.105	0.089	0.10000	0.004	0.013	0.011	0.009
Other HxCDF	3.495	9.895	9.295	7.562	0.00000	0.000	0.000	0.000	0.000
1234678-HpCDF	4.570	7.760	12.170	8.167	0.01000	0.046	0.078	0.122	0.082
1234789-HpCDF	(0.260)	7.760	0.940	2.987	0.01000	(0.003)	0.078	0.009	0.030
Other Hepta-CDF	2.668	1.590	7.540	3.933	0.00000	0.000	0.000	0.000	0.000
Octa-CDF	5.250	17.810	12.180	11.747	0.00100	0.005	0.018	0.012	0.012
Total CDF	29.810	77.960	72.050	59.940		0.621	1.804	1.507	1.311
Total CDD+CDF	38.702	96.720	83.916	73.113		0.696	1.993	1.672	1.454

a North Atlantic Treaty Organization, Committee on Challenges of Modern Society. Pilot Study on International Information Exchange on Dioxins and Related Compounds: International Toxicity Equivalency Factor (I - TEF) Methods of Risk Assessment for Complex Mixtures Of Dioxins and Related Compounds. Report No. 176, August 1988.

() = Estimated maximum possible concentration

TABLE 2-15. CDD/CDF CONCENTRATIONS AND 2378 TOXIC EQUIVALENT CONCENTRATIONS IN SPRAY DRYER RESIDUE FOR CONDITION 1; MORRISTOWN HOSPITAL (1991)

CONGENER	CDD/CDF ASH CONCENTRATIONS				2378 TOXIC EQUIVALENCIES				
	RUN 1 (ppb)	RUN 2 (ppb)	RUN 3 (ppb)	Average (ppb)	Toxic Equiv. Factor ^a	RUN 1 (ppb)	RUN 2 (ppb)	RUN 3 (ppb)	Average (ppb)
DIOXINS									
2378 TCDD	(0.001)	0.001	(0.001)	0.001	1.000	(0.001)	0.001	(0.001)	0.001
Other TCDD	0.006	0.008	0.006	0.007	0.000	0.000	0.000	0.000	0.000
12378 PCDD	0.004	0.004	0.004	0.004	0.500	0.002	0.002	0.002	0.002
Other PCDD	0.027	0.021	0.022	0.023	0.000	0.000	0.000	0.000	0.000
123478 HxCDD	0.008	0.008	0.009	0.008	0.100	0.001	0.001	0.001	0.001
123678 HxCDD	0.011	0.009	0.010	0.010	0.100	0.001	0.001	0.001	0.001
123789 HxCDD	0.021	0.018	0.021	0.020	0.100	0.002	0.002	0.002	0.002
Other HxCDD	0.105	0.100	0.100	0.101	0.000	0.000	0.000	0.000	0.000
1234678-HpCDD	0.233	0.197	0.187	0.206	0.010	0.002	0.002	0.002	0.002
Other Hepta-CDD	0.239	0.188	0.199	0.209	0.000	0.000	0.000	0.000	0.000
Octa-CDD	1.180	1.420	0.731	1.110	0.001	0.001	0.001	0.001	0.001
Total CDD	1.833	1.975	1.290	1.699		0.010	0.010	0.009	0.010
FURANS									
2378 TCDF	0.007	0.004	0.013	0.008	0.100	0.001	0.000	0.001	0.001
Other TCDF	0.202	0.098	0.436	0.245	0.000	0.000	0.000	0.000	0.000
12378 PCDF	0.020	0.012	0.027	0.020	0.050	0.001	0.001	0.001	0.001
23478 PCDF	0.059	0.034	0.072	0.055	0.500	0.029	0.017	0.036	0.027
Other PCDF	0.543	0.275	0.721	0.513	0.000	0.000	0.000	0.000	0.000
123478 HxCDF	0.280	0.172	0.375	0.276	0.100	0.028	0.017	0.038	0.028
123678 HxCDF	0.108	0.055	0.128	0.097	0.100	0.011	0.006	0.013	0.010
234678 HxCDF	0.329	0.184	0.359	0.291	0.100	0.033	0.018	0.036	0.029
123789 HxCDF	0.076	0.007	0.012	0.031	0.100	0.008	0.001	0.001	0.003
Other HxCDF	0.727	0.379	0.927	0.678	0.000	0.000	0.000	0.000	0.000
1234678-HpCDF	1.140	0.657	1.100	0.966	0.010	0.011	0.007	0.011	0.010
1234789-HpCDF	0.268	0.175	0.265	0.236	0.010	0.003	0.002	0.003	0.002
Other Hepta-CDF	1.292	0.738	1.305	1.112	0.000	0.000	0.000	0.000	0.000
Octa-CDF	3.060	2.620	3.160	2.947	0.001	0.003	0.003	0.003	0.003
Total CDF	8.109	5.410	8.898	7.472		0.127	0.071	0.143	0.114
Total CDD+CDF	9.942	7.385	10.188	9.171		0.137	0.081	0.152	0.123

^a North Atlantic Treaty Organization, Committee on Challenges of Modern Society. Pilot Study on International Information Exchange on Dioxins and Related Compounds: International Toxicity Equivalency Factor (I - TEF) Methods of Risk Assessment for Complex Mixtures Of Dioxins and Related Compounds. Report No. 176, August 1988.

() = Estimated maximum possible concentration

TABLE 2-16. CDD/CDF CONCENTRATIONS AND 2378 TOXIC EQUIVALENT CONCENTRATIONS IN SPRAY DRYER RESIDUE FOR CONDITION 2; MORRISTOWN HOSPITAL (1991)

CONGENER	CDD/CDF ASH CONCENTRATIONS				2378 TOXIC EQUIVALENCIES				
	RUN 4 (ppb)	RUN 5 (ppb)	RUN 6 (ppb)	Average (ppb)	Toxic Equiv. Factor ^a	RUN 4 (ppb)	RUN 5 (ppb)	RUN 6 (ppb)	Average (ppb)
DIOXINS									
2378 TCDD	0.000	(0.001)	0.001	0.001	1.000	0.000	(0.001)	0.001	0.001
Other TCDD	0.003	0.005	0.007	0.005	0.000	0.000	0.000	0.000	0.000
12378 PCDD	0.002	0.003	0.002	0.002	0.500	0.001	0.001	0.001	0.001
Other PCDD	0.016	0.028	0.026	0.023	0.000	0.000	0.000	0.000	0.000
123478 HxCDD	0.005	0.007	0.005	0.006	0.100	0.000	0.001	0.001	0.001
123678 HxCDD	0.006	0.009	0.008	0.008	0.100	0.001	0.001	0.001	0.001
123789 HxCDD	0.011	0.018	0.014	0.014	0.100	0.001	0.002	0.001	0.001
Other HxCDD	0.054	0.098	0.089	0.080	0.000	0.000	0.000	0.000	0.000
1234678-HpCDD	0.103	0.183	0.169	0.152	0.010	0.001	0.002	0.002	0.002
Other Hepta-CDD	0.100	0.176	0.157	0.144	0.000	0.000	0.000	0.000	0.000
Octa-CDD	0.468	0.921	1.050	0.813	0.001	0.000	0.001	0.001	0.001
Total CDD	0.769	1.449	1.528	1.249		0.005	0.008	0.007	0.007
FURANS									
2378 TCDF	0.005	0.007	0.004	0.005	0.100	0.001	0.001	0.000	0.001
Other TCDF	0.146	0.214	0.119	0.160	0.000	0.000	0.000	0.000	0.000
12378 PCDF	0.012	0.016	0.010	0.013	0.050	0.001	0.001	0.000	0.001
23478 PCDF	0.036	0.050	0.029	0.039	0.500	0.018	0.025	0.015	0.019
Other PCDF	0.328	0.503	0.260	0.364	0.000	0.000	0.000	0.000	0.000
123478 HxCDF	0.166	0.259	0.161	0.195	0.100	0.017	0.026	0.016	0.020
123678 HxCDF	0.051	0.081	0.052	0.061	0.100	0.005	0.008	0.005	0.006
234678 HxCDF	0.156	0.271	0.173	0.200	0.100	0.016	0.027	0.017	0.020
123789 HxCDF	0.006	0.006	0.006	0.006	0.100	0.001	0.001	0.001	0.001
Other HxCDF	0.377	0.623	0.347	0.449	0.000	0.000	0.000	0.000	0.000
1234678-HpCDF	0.463	0.796	0.576	0.612	0.010	0.005	0.008	0.006	0.006
1234789-HpCDF	0.130	0.211	0.161	0.167	0.010	0.001	0.002	0.002	0.002
Other Hepta-CDF	0.577	0.983	0.683	0.748	0.000	0.000	0.000	0.000	0.000
Octa-CDF	1.390	2.500	1.980	1.957	0.001	0.001	0.003	0.002	0.002
Total CDF	3.843	6.520	4.561	4.975		0.064	0.101	0.064	0.076
Total CDD+CDF	4.612	7.969	6.089	6.223		0.070	0.109	0.071	0.083

^a North Atlantic Treaty Organization, Committee on Challenges of Modern Society. Pilot Study on International Information Exchange on Dioxins and Related Compounds: International Toxicity Equivalency Factor (I - TEF) Methods of Risk Assessment for Complex Mixtures Of Dioxins and Related Compounds. Report No. 176, August 1988.

() = Estimated maximum possible concentration

TABLE 2-17. CDD/CDF CONCENTRATIONS IN
MAKE-UP WATER AND LIME SLURRY FOR RUN 1
MORRISTOWN MEMORIAL HOSPITAL (1991)

CONGENER	MAKE-UP WATER	LIME SLURRY TANK
	RUN 1 (ppt.wt)	RUN 1 (ppt.wt)
2378 TCDD	[0.008]	[0.500]
Other TCDD	0.000	0.000
12378 PCDD	[0.005]	[0.600]
Other PCDD	0.000	0.000
123478 HxCDD	[0.005]	[1.500]
123678 HxCDD	[0.003]	[0.900]
123789 HxCDD	(0.010)	[1.300]
Other HxCDD	0.000	0.830
1234678-HpCDD	0.030	5.200
Other Hepta-CDD	0.020	3.300
Octa-CDD	0.140	20.800
Total CDD	0.196	30.130
FURANS		
2378 TCDF	[0.005]	[0.400]
Other TCDF	0.008	0.000
12378 PCDF	[0.005]	[0.500]
23478 PCDF	[0.003]	[0.500]
Other PCDF	0.000	0.000
123478 HxCDF	[0.005]	[0.900]
123678 HxCDF	[0.003]	[0.600]
234678 HxCDF	0.006	0.620
123789 HxCDF	[0.005]	[1.000]
Other HxCDF	0.000	0.000
1234678-HpCDF	0.004	[0.900]
1234789-HpCDF	[0.005]	[1.600]
Other Hepta-CDF	0.005	0.000
Octa-CDF	0.009	(2.300)
TOTAL CDF	0.032	2.890
TOTAL CDD+CDF	0.228	33.020

[] : Minimum detection limit.

() : Estimated maximum possible concentration.

Concentrations at dry, standard conditions, adjusted to 7 percent O₂, and emission rates are shown. The metals to PM ratios are presented in Section 2.3.5, flue gas metals by sample fraction are presented in Section 2.3.6, metals concentrations in ash samples is presented in Section 2.3.7, and metals in make-up water and lime slurry are presented in Section 2.3.8.

2.3.2 Metals Data Reduction

The values reported in the following toxic metals results include detection limits for metals which were not detected in the samples. Since the samples were analyzed in three separate fractions (see Section 5 for details), guidelines for mathematically handling detection limits were required. The guidelines used for this report are:

- If a metal was detected in any fraction of the sample train but not in all fractions, only the detected values were used to determine total sample mass (i.e., non detects = zero).
- If a metal was not detected in any fraction of a sample train, the sum of the non-detects for each fraction was used as the overall sample detection limit.

For the purpose of calculating average results:

- If a metal was detected in one or more of the test runs but not all, only those runs for which a detected result was obtained were used in calculating the average. Runs where the metal was not detected were not included for averaging.
- If the metal was not detected in any of the three runs, then the average results were reported as not detected at the average detection limit.

The ash samples were analyzed for the same series of metals as the emission test samples. These results are reported in Section 2.3.7.

2.3.3 Metals Emissions

Tables 2-18 and 2-19 present the metals emissions results for Conditions 1 and 2, respectively. During Condition 1, where carbon was not injected into the lime slurry, Al had the highest average mass rate at the inlet of 98.4 g/hr, followed by Cu with a mass rate of 25.4 g/hr. Thallium was not detected in any of the samples at the spray dryer

TABLE 2-18. AVERAGE METALS EMISSION RATES AND REMOVAL EFFICIENCIES;
MORRISTOWN MEMORIAL HOSPITAL (1991)
* WITHOUT CARBON INJECTION *

Condition Location	Without Carbon Injection								
	Run 1			Run 2			Run 3		
	Inlet (g/hr)	Outlet (g/hr)	RE (%)	Inlet (g/hr)	Outlet (g/hr)	RE (%)	Inlet (g/hr)	Outlet (g/hr)	RE (%)
Aluminum	52.4	0.507	99.0%	96.2	0.431	99.6%	147	0.785	99.5%
Antimony	2.59	0.0567	97.8%	2.60	0.0242	99.1%	1.89	0.0238	98.7%
Arsenic	0.0450	[0.00322]	>92.9%	0.0521	[0.00318]	>93.9	0.0665	[0.00307]	>95.4%
Barium	12.2	0.0258	99.8%	11.2	0.0160	99.9%	18.0	0.0637	99.6%
Beryllium	0.00544	0.00114	79.0%	0.00808	[0.000798]	>90.1%	0.00651	[0.000662]	>89.8%
Cadmium	2.14	0.00797	99.6%	1.57	0.00346	99.8%	2.60	0.0105	99.6%
Chromium	0.541	0.0162	97.0%	0.476	0.0122	97.4%	0.733	0.0142	98.1%
Copper	22.2	0.105	99.5%	27.7	0.0631	99.8%	26.3	0.0980	99.6%
Lead	16.4	0.0170	99.9%	15.2	0.00457	100%	16.1	0.0499	99.7%
Mercury	9.51	4.67	50.9%	2.73	2.76	NA	23.4	17.6	24.6%
Nickel	0.327	0.0134	95.9%	0.534	0.0214	96.0%	0.463	0.00573	98.8%
Silver	0.0148	0.0138	6.97%	0.0190	0.00975	48.8%	0.0578	0.0154	73.4%
Thallium	[0.125]	[0.0802]	NA	[0.123]	[0.0798]	NA	[0.123]	[0.0770]	NA

NA = Not Applicable

[] = Minimum Detection Limit

TABLE 2-19. AVERAGE METALS EMISSION RATES AND REMOVAL EFFICIENCIES;
MORRISTOWN MEMORIAL HOSPITAL (1991)
* WITH CARBON INJECTION *

Condition Location	With Carbon Injection											
	Run 4			Run 5			Run 6			Average Emissions		
	Inlet (g/hr)	Outlet (g/hr)	RE (%)	Inlet (g/hr)	Outlet (g/hr)	RE (%)	Inlet (g/hr)	Outlet (g/hr)	RE (%)	Inlet (g/hr)	Outlet (g/hr)	RE (%)
Aluminum	106	0.379	99.6%	49.4	0.445	99.1%	72.5	0.364	99.5%	76.1	0.396	99.5%
Antimony	4.57	0.0226	99.5%	2.27	0.0221	99.0%	4.23	0.0193	99.5%	3.69	0.0214	99.4%
Arsenic	0.0792	[0.00303]	> 96.2%	0.0159	[0.00317]	> 80.0%	0.0321	[0.00313]	> 90.2%	0.0424	[0.00311]	> 92.7%
Barium	16.3	0.0171	99.9%	9.95	0.0225	99.8%	9.83	0.0169	99.8%	12.0	0.0188	99.8%
Beryllium	0.00794	[0.000760]	> 90.4%	0.00785	[0.000796]	> 89.9%	0.00692	[0.000784]	> 88.7%	0.00757	[0.000780]	> 89.7%
Cadmium	2.48	0.00367	99.9%	1.90	0.00419	99.8%	2.54	0.00310	99.9%	2.31	0.00366	99.8%
Chromium	0.809	0.00660	99.2%	0.666	0.0130	98.1%	0.652	0.0156	97.6%	0.709	0.0117	98.3%
Copper	35.8	0.0410	99.9%	31.1	0.0853	99.7%	30.4	0.0583	99.8%	32.4	0.0615	99.8%
Lead	20.1	0.0117	99.9%	22.4	0.0135	99.9%	19.7	0.00807	100%	20.7	0.0111	99.9%
Mercury	11.5	1.84	83.9%	10.6	0.436	95.9%	14.9	1.40	90.6%	12.3	1.23	90.0%
Nickel	0.824	0.00233	99.7%	0.481	0.00659	98.6%	0.515	0.00734	98.6%	0.607	0.00542	99.1%
Silver	0.00739	0.0136	NA	0.00193	0.0106	NA	0.00103	0.0127	NA	0.00345	0.0123	NA
Thallium	[0.178]	[0.0760]	NA	[0.0991]	[0.0796]	NA	0.0200	[0.0784]	> -292%	0.0200	[0.0778]	> -289%

NA = Not Applicable

[] = Minimum Detection Limit

inlet during these emissions tests. At the baghouse outlet, Hg was the most prevalent element collected during Condition 1 with an average emission rate of 8.35 g/hr, followed by Al with an average emission rate of 0.574 g/hr. Low levels of Ag were detected at both the spray dryer inlet and baghouse outlet locations. The emission rate at the outlet averaged 0.012 g/hr, which was higher than the average inlet emission rate of .0035. This may be due to trace amounts of silver introduced to the flue gas in the lime slurry at the spray dryer (see Table 2-32). Arsenic and Tl were not detected during any of the runs at the baghouse outlet.

During Condition 2, where carbon was injected into the lime slurry, Al had the highest average mass rate of the metals at the spray dryer inlet with 76.1 g/hr, followed by Cu with 32.4 g/hr. Consistent with Condition 1, Tl was the only metal not detected in any of the runs at the spray dryer inlet. At the baghouse outlet, Hg was the most prevalent element collected with an average emission rate of 1.23 g/hr. Arsenic, Be, and Tl were not collected in detectable amounts for any of the runs at the baghouse outlet. A detectable amount of Tl occurred during only one of the runs at the inlet or outlet.

The emission mass rates at the spray dryer inlet for all of the metals varied only slightly between conditions. This was also true for all of the metals at the baghouse outlet, except Hg. Therefore, all of the elements maintained basically the same removal efficiency with and without carbon injected into the lime slurry, except Hg. During Condition 1, Hg had a removal efficiency of 29.6 percent; whereas, during Condition 2, the removal efficiency increased to 90.0 percent. The results of this test show that the injection of carbon into the spray dryer positively effects the removal of Hg from the flue gas.

Sample results for Hg showed a negative removal efficiency for Run 2 which can be attributed to round-off error. A removal efficiency for Tl could not be calculated for most of the runs because all of the results were detection limits. All of the average removal efficiencies for Condition 2 were greater than 89 percent except for Ag and Tl. A removal efficiency is misleading for Tl because such a small amount is detected. This is also true of the removal efficiencies associated with Ag. Although it is detected during all the runs, the removal efficiencies are misleading because the values reported are only slightly higher than detection limits.

2.3.4 Metals Flue Gas Concentrations

Table 2-20 reports the flue gas concentrations for each of the 6 runs at the spray dryer inlet and baghouse outlet in $\mu\text{g}/\text{dscm}$. Table 2-21 contains the same data except corrected to $\mu\text{g}/\text{dscm}$ at 7 percent O_2 . Oxygen concentrations were calculated from CEM data averaged over the same time period as the manual testing was performed.

2.3.5 Flue Gas Metals to Particulate Matter Ratios

A summary of the ratio of total metals to PM for the emission tests without carbon injection is presented in Table 2-22. Metals to PM ratios are given in units of milligrams of metal to grams of PM collected by the sampling train. The metal with the highest ratio at the inlet was Al with an average of 19.8 mg/g and the lowest particulate ratio was Tl, which was not detected. At the outlet, the largest ratio was contributed to Hg, 363 mg/g. Such a large ratio occurred because without carbon injection, Hg is not substantially removed from the flue gas; whereas, the amount of PM is greatly decreased by the emission controls.

Table 2-23 presents a summary of the ratio by weight of total metals to PM for the emission tests with carbon injection. Average spray dryer inlet ratios ranged from 0.000804 mg/g for Ag to 13.7 mg/g for Al. Average ratios at the baghouse outlet ranged from non-detected metals to 166 mg/g of Hg.

A comparison between the spray dryer inlet ratios of both conditions shows that the ratios for each metal do not differ significantly. A comparison of the ratios at the baghouse outlet displays the same conclusion for all the metals except Hg. Without carbon injection, the average Hg ratio increases from 2.41 mg/g at the spray dryer inlet to 363 mg/g at the baghouse outlet. Whereas, with carbon injection, the average Hg ratio increases from 1.99 mg/g at the spray dryer inlet to 166 mg/g at the baghouse outlet. The metals/particulate ratio increases going from inlet to outlet for most of the metals; and for some, this increase is several orders of magnitude.

2.3.6 Flue Gas Metals by Sample Fraction and Sample Parameters

Table 2-24 presents the metal amounts in the inlet flue gas samples by fraction for each run. The highest proportion of Hg and Ag was consistently collected in the nitric acid impingers (Impingers 1-3), although Hg was the only metal to have a large majority of its total mass collected in the nitric acid impingers. All other metals detected, except

TABLE 2-20. METALS CONCENTRATIONS; MORRISTOWN MEMORIAL HOSPITAL (1991)

Toxic Metals Concentration (ug/dscm)											
Without Carbon Injection											
Metals	Run 1		Run 2		Run 3		Average Concentrations				
	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet			
Aluminum	8540	63.9	16000	53.3	22900	97.0	15813	71.4			
Antimony	422	7.15	433	2.99	294	2.94	383	4.36			
Arsenic	7.33	[0.405]	8.66	[0.394]	10.4	[0.380]	8.8	[0.393]			
Barium	1993	3.25	1860	1.98	2810	7.87	2221	4.37			
Beryllium	0.887	0.144	1.34	[0.0987]	1.02	[0.0818]	1.08	0.144			
Cadmium	348	1.00	260	0.427	406	1.29	338	0.91			
Chromium	88.2	2.05	79.1	1.51	114	1.75	94	1.77			
Copper	3620	13.2	4600	7.80	4100	12.1	4107	11.0			
Lead	2680	2.14	2520	0.565	2510	6.16	2570	2.96			
Mercury	1550	588	453	341	3650	2180	1884	1036			
Nickel	53.3	1.69	88.8	2.64	72.2	0.709	71.5	1.678			
Silver	2.41	1.74	3.17	1.21	9.02	1.90	4.87	1.61			
Thallium	[20.3]	[10.1]	[20.4]	[9.87]	[19.2]	[9.52]	[19.97]	[9.83]			
With Carbon Injection											
Metals	Run 4		Run 5		Run 6		Average Concentrations				
	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet			
Aluminum	17000	47.0	7590	52.0	11500	42.8	12030	47			
Antimony	730	2.80	349	2.59	672	2.27	584	2.55			
Arsenic	12.7	[0.375]	2.44	[0.371]	5.09	[0.367]	6.7	[0.371]			
Barium	2610	2.12	1530	2.63	1560	1.98	1900	2.2			
Beryllium	1.27	[0.0941]	1.21	[0.0930]	1.10	[0.0921]	1.19	[0.0931]			
Cadmium	396	0.455	292	0.490	403	0.364	364	0.44			
Chromium	129	0.818	102	1.51	104	1.83	112	1.39			
Copper	5720	5.08	4780	9.97	4830	6.84	5110	7.3			
Lead	3210	1.45	3440	1.58	3130	0.948	3260	1.3			
Mercury	1830	228	1630	50.9	2360	164	1940	148			
Nickel	132	0.288	74.0	0.770	81.8	0.861	95.8	0.64			
Silver	1.18	1.69	0.297	1.24	0.164	1.50	0.5	1.47			
Thallium	[28.5]	[9.41]	[15.2]	[9.30]	3.18	[9.21]	3.18	[9.31]			

[]= Detection limit

[] = Detection limit

TABLE 2-21. METALS CONCENTRATIONS; MORRISTOWN MEMORIAL HOSPITAL (1991)

Toxic Metals Concentration (ug/dscm @ 7% O ₂)									
Without Carbon Injection									
Metals	Run 1		Run 2		Run 3		Average Concentrations		
	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Outlet
Aluminum	12100	131	22700	109	30900	180	21900	140	
Antimony	599	14.6	614	6.12	397	5.45	537	8.73	
Arsenic	10.4	[0.828]	12.3	[0.805]	14.0	[0.704]	12.2	[0.779]	
Barium	2820	6.65	2640	4.05	3790	14.6	3083	8.4	
Beryllium	1.26	0.294	1.91	[0.202]	1.37	[0.152]	1.51	0.294	
Cadmium	494	2.05	369	0.874	549	2.40	471	1.77	
Chromium	125	4.18	112	3.09	154	3.25	131	3.50	
Copper	5134	27.0	6520	15.9	5530	22.4	5728	21.8	
Lead	3801	4.37	3570	1.16	3390	11.4	3587	5.7	
Mercury	2200	1200	643	697	4930	4040	2591	1979	
Nickel	75.6	3.4	126	5.40	97.5	1.31	99.7	3.39	
Silver	3.42	3.55	4.49	2.46	12.2	3.52	6.7	3.18	
Thallium	[28.8]	[20.6]	[28.9]	[20.2]	[26.0]	[17.6]	[27.9]	[19.5]	
With Carbon Injection									
Metals	Run 4		Run 5		Run 6		Average Concentrations		
	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Outlet
Aluminum	22500	92.0	10400	99.1	15700	80.4	16200	90	
Antimony	966	5.49	481	4.92	916	4.27	787	4.89	
Arsenic	16.7	[0.735]	3.36	[0.706]	6.94	[0.690]	9.0	[0.710]	
Barium	3460	4.15	2110	5.00	2130	3.72	2567	4.3	
Beryllium	1.68	[0.184]	1.66	[0.177]	1.50	[0.173]	1.61	[0.178]	
Cadmium	524	0.890	401	0.933	549	0.683	492	0.84	
Chromium	171	1.60	141	2.88	141	3.43	151	2.64	
Copper	7570	9.94	6580	19.0	6580	12.9	6910	13.9	
Lead	4250	2.84	4730	3.00	4260	1.78	4413	2.5	
Mercury	2420	446	2240	97.0	3220	309	2627	284	
Nickel	174	0.564	102	1.47	111	1.62	129.2	1.22	
Silver	1.56	3.30	0.408	2.36	0.223	2.81	0.7	2.82	
Thallium	[37.7]	[18.4]	[21.0]	[17.7]	4.33	[17.3]	4.33	[17.8]	

[] = Detection limit

TABLE 2-22. RATIO OF METALS TO PARTICULATE MATTER;
MORRISTOWN MEMORIAL HOSPITAL (1991)

* WITHOUT CARBON INJECTION *

METALS/PARTICULATE RATIO (mg metal per gram of particulate)								
Location Run	INLET			OUTLET				
	Run 1 (mg/g)	Run 2 (mg/g)	Run 3 (mg/g)	Average (mg/g)	Run 1 (mg/g)	Run 2 (mg/g)	Run 3 (mg/g)	Average (mg/g)
Aluminum	10.6	18.8	30.0	19.8	68.7	41.6	8.42	39.6
Antimony	0.522	0.508	0.385	0.472	7.68	2.34	0.255	3.43
Arsenic	0.00908	0.0102	0.0136	0.0109	[0.436]	[0.306]	[0.0329]	[0.258]
Barium	2.47	2.18	3.68	2.78	3.50	1.55	0.684	1.91
Beryllium	0.00110	0.00158	0.00133	0.00134	0.155	[0.0767]	[0.00710]	0.155
Cadmium	0.431	0.306	0.532	0.423	1.08	0.334	0.112	0.509
Chromium	0.109	0.0929	0.150	0.117	2.20	1.18	0.152	1.18
Copper	4.48	5.40	5.37	5.08	14.2	6.10	1.05	7.12
Lead	3.32	2.96	3.29	3.19	2.30	0.442	0.535	1.09
Mercury	1.92	0.532	4.78	2.41	632	266	189	363
Nickel	0.0660	0.104	0.0946	0.0883	1.81	2.06	0.0615	1.31
Silver	0.00299	0.00372	0.0118	0.00617	1.87	0.942	0.165	0.991
Thallium	[0.0251]	[0.0239]	[0.0252]	[0.0247]	[10.9]	[7.71]	[0.826]	[6.47]

[] = Minimum Detection Limit

TABLE 2-23. RATIO OF METALS TO PARTICULATE MATTER;
MORRISTOWN MEMORIAL HOSPITAL (1991)

* WITH CARBON INJECTION *

METALS/PARTICULATE RATIO (mg metal per gram of particulate)									
Location Run	INLET			OUTLET					Average (mg/g)
	Run 4 (mg/g)	Run 5 (mg/g)	Run 6 (mg/g)	Average (mg/g)	Run 4 (mg/g)	Run 5 (mg/g)	Run 6 (mg/g)	Average (mg/g)	
Aluminum	17.7	9.66	15.7	13.7	63.5	24.0	19.6	35.7	
Antimony	0.760	0.445	0.914	0.603	3.79	1.19	1.04	2.49	
Arsenic	0.0132	0.00310	0.00693	0.00815	[0.507]	[0.171]	[1.68]	[0.339]	
Barium	2.72	1.95	2.12	2.33	2.87	1.21	0.908	2.04	
Beryllium	0.00132	0.00154	0.00149	0.00143	[0.127]	[0.0428]	[0.0422]	[0.0850]	
Cadmium	0.413	0.371	0.549	0.392	0.615	0.226	0.167	0.420	
Chromium	0.135	0.130	0.141	0.132	1.10	0.698	0.838	0.901	
Copper	5.96	6.09	6.57	6.02	6.86	4.60	3.14	5.73	
Lead	3.35	4.38	4.26	3.86	1.96	0.726	0.435	1.34	
Mercury	1.91	2.08	3.21	1.99	308	23.5	75.4	166	
Nickel	0.137	0.0943	0.111	0.116	0.389	0.355	0.395	0.372	
Silver	0.00123	0.000378	0.000223	0.000804	2.28	0.572	0.686	1.42	
Thallium	[0.0297]	[0.0194]	0.00433	0.00433	[12.7]	[4.28]	[4.22]	[8.50]	

[] = Minimum Detection Limit

TABLE 2-24. METALS AMOUNTS IN INLET FLUE GAS - SAMPLES BY SAMPLE FRACTION;
MORRISTOWN MEMORIAL HOSPITAL (1991)

Metals	Run 1			Run 2			Run 3					
	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)
Aluminum	25500	42.6		25500	47800	31.9		47800	72000	42.3		72000
Antimony	1160	96.4		1260	1230	56.3		1290	885	41.4		926
Arsenic	21.9	[0.425]		21.9	25.8	[0.427]		25.8	32.7	[0.424]		32.7
Barium	5950	1.57		5950	5550	1.90		5550	8850	2.12		8850
Beryllium	2.65	[0.106]		2.65	4.00	[0.107]		4.00	3.20	[0.106]		3.20
Cadmium	1040	0.743		1040	775	0.363		775	1280	0.53		1280
Chromium	260	3.28		263	234	1.56		236	357	2.99		360
Copper	10800	26.5		10800	13700	33.6		13700	12900	12.8		12900
Lead	8000	1.08		8000	7500	0.474		7500	7900	0.558		7900
Mercury	213	4400	8.55	4620	55.5	1290	5.03	1350	867	10600	3.86	11500
Nickel	157	2.25		159	263	1.45		264	225	2.45		227
Silver	[3.00]	7.21		7.21	4.10	5.33		9.43	28.4	[0.637]		28.4
Thallium	[50.0]	[10.6]		[60.6]	[50.0]	[10.7]		[60.7]	[50.0]	[10.6]		[60.6]

Note: Impingers 4,5 and 6 sample fractions analyzed for mercury content only

[] = Minimum Detection Limit

TABLE 2-24 (Continued). METALS AMOUNTS IN INLET FLUE GAS - SAMPLES BY SAMPLE FRACTION;
MORRISTOWN MEMORIAL HOSPITAL (1991)

Metals	Run 4			Run 5				Run 6				
	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)
Aluminum	65400	230		65600	30200	53.7		30200	44400	43.6		44400
Antimony	2760	62.6		2820	1320	71.5		1390	2500	100		2600
Arsenic	48.9	[0.422]		48.9	9.70	[0.423]		9.70	19.7	[0.423]		19.7
Barium	10100	3.35		10100	6100	3.54		6100	6100	1.88		6100
Beryllium	4.90	[0.106]		4.90	4.80	[0.106]		4.80	4.25	[0.106]		4.25
Cadmium	1520	11.1		1530	1160	0.423		1160	1560	0.338		1560
Chromium	496	3.03		499	399	8.26		407	398	2.55		401
Copper	22000	74.7		22100	19000	21.0		19000	18700	18.9		18700
Lead	12400	26.5		12400	13700	1.08		13700	12100	0.904		12100
Mercury	148	6780	165	7090	78.5	6400	1.98	6480	30.0	9090	6.95	9130
Nickel	506	2.25		508	288	6.54		295	313	3.61		317
Silver	[6.00]	4.56		4.56	[3.00]	1.18		1.18	[3.00]	0.634		0.634
Thallium	[100]	[10.6]		[110]	[50.0]	[10.6]		[60.6]	[50.0]	12.3		12.3

Thallium	[100]	[105]
Note: Impingers 4,5 and 6 sample fractions analyzed for mercury content only		

Tl in Run 6, were collected in the highest proportions in the front half (filter, nozzle/probe rinse). This indicates that almost all of the Hg, and over half of the Ag in the flue gas, was in a vapor phase at the filter temperature.

The metal amounts in the outlet flue gas samples are presented in Table 2-25 by sample fraction. The highest proportion of Hg was collected in the nitric acid impingers for all runs. Most other metals were collected in the highest proportions in the front half fraction, except for Cu and Ni which had slightly more weight collected in the impingers during four of the six runs, and Cu for three of the six runs.

Sampling and flue gas parameters for the PM/metals runs at both sampling locations are shown in Tables 2-26 and 2-27. Total sampling times, sample volumes, and isokinetic results for each sampling run are presented. Appendix C contains a complete listing of these and additional sampling and flue gas parameters for each run.

2.3.7 Metals in Ash

Incinerator bottom ash, spray dryer ash, and baghouse ash were sampled daily as described in Section 5. Concentrations of the metals in the ash in units of mg/kg were determined by microwave digesting one-half gram of ash in acid and hydrogen peroxide, diluting the solution to 100 mL, and then analyzed as stated in Section 5.

The metals concentrations in the incinerator bottom ash are shown in Table 2-28. The most prevalent metal throughout all of the runs is Al with Cu being the second. Four of the metals are not detected in any of the runs, Sb, Hg, Ag, and Tl. A comparison of the metal to ash concentrations between the two conditions does not show any significant differences.

Table 2-29 presents the metals concentrations in the baghouse ash collected each day. As in the incinerator ash, Al is the most prevalent metal. Silver and Tl were not detected in any of the six samples taken. All of the metals showed no significant increase in average concentration in comparing the two conditions, except for Hg. The

TABLE 2-25. METALS AMOUNTS IN OUTLET FLUE GAS - SAMPLES BY SAMPLE FRACTION;
MORRISTOWN MEMORIAL HOSPITAL (1991)

	Run 1			Run 2			Run 3		
	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)	
Aluminum	193	34.0		227	166	26.3		192	
Antimony	13.5	11.9		25.4	10.8	[1.59]		10.8	
Arsenic	[1.00]	[0.435]		[1.44]	[1.00]	[0.424]		[1.42]	
Barium	8.58	2.98		11.6	5.60	1.55		7.15	
Beryllium	[0.250]	0.511		0.511	[0.250]	[0.106]		[0.356]	
Cadmium	1.90	1.67		3.57	1.33	0.212		1.54	
Chromium	3.25	4.02		7.27	2.95	2.50		5.45	
Copper	23.8	23.2		47.0	4.65	23.5		28.2	
Lead	6.85	0.752		7.60	2.04	[0.318]		2.04	
Mercury	[2.45]	2070	23.4	2090	[2.45]	1230	3.23	1230	
Nickel	2.58	3.41		5.99	7.13	2.40		9.53	
Silver	4.05	2.12		6.17	4.35	[0.636]		4.35	
Thallium	[25.0]	[10.9]		[35.9]	[25.0]	[10.6]		[35.6]	
							6.33		
								363	
								11.0	
								[1.42]	
								29.5	
								[0.306]	
								4.84	
								6.55	
								45.3	
								23.1	
							6.33	8170	
								2.65	
								7.11	
								[35.6]	

Note: Impingers 4,5 and 6 sample fractions analyzed for mercury content only
[] = Minimum Detection Limit

TABLE 2-25 (Continued). METALS AMOUNTS IN OUTLET FLUE GAS - SAMPLES BY SAMPLE FRACTION;
MORRISTOWN MEMORIAL HOSPITAL (1991)

Metals	Run 4				Run 5				Run 6			
	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)	Front Half (Total ug)	Impinger 1,2,3 (Total ug)	Impinger 4,5,6 (Total ug)	Total ug (Total ug)
Aluminum	154	23.7		178	167	32.2		199	142	23.4		165
Antimony	10.6	[1.59]		10.6	9.90	[1.60]		9.90	8.78	[1.60]		8.78
Arsenic	[1.00]	[0.425]		[1.42]	[1.00]	[0.425]		[1.42]	[1.00]	[0.425]		[1.42]
Barium	6.95	1.07		8.02	8.15	1.91		10.1	5.35	2.30		7.65
Beryllium	[0.250]	[0.106]		[0.356]	[0.250]	[0.106]		[0.356]	[0.250]	[0.106]		[0.356]
Cadmium	1.38	0.340		1.72	1.43	0.447		1.88	1.13	0.276		1.41
Chromium	2.20	0.892		3.09	1.85	3.95		5.80	1.60	5.46		7.06
Copper	8.20	11.0		19.2	6.68	31.5		38.2	4.85	21.6		26.5
Lead	5.10	0.384		5.48	5.30	0.735		6.04	3.28	0.385		3.67
Mercury	[2.45]	858	3.98	862	[2.45]	195	[0.390]	195	[2.45]	634	1.8	636
Nickel	[0.750]	1.09		1.09	[0.750]	2.95		2.95	[0.750]	3.33		3.33
Silver	5.45	0.924		6.37	4.75	[0.638]		4.75	5.78	[0.638]		5.78
Thallium	[25.0]	[10.6]		[35.6]	[25.0]	[10.6]		[35.6]	[25.0]	[10.6]		[35.6]

Note: Impingers 4,5 and 6 sample fractions analyzed for mercury content only

TABLE 2-26. METALS/PM EMISSIONS SAMPLING AND FLUE GAS PARAMETERS AT INLET
MORRISTOWN MEMORIAL HOSPITAL (1991)

Run No. Date	Run 1 11/18/91	Run 2 11/19/91	Run 3 11/20/91	Run 4 11/21/91	Run 5 11/22/91	Run 6 11/23/91	Average
Total Sampling Time (min)	240	240	240	240	240	240	NA
Average Sampling Rate (dscfm)	0.44	0.44	0.46	0.57	0.59	0.57	0.51
Metered Volume (dscf)	105	105	111	136	140	137	122
Metered Volume (dscm)	3.0	3.0	3.1	3.9	4.0	3.9	3.5
Average Stack Temperature (F)	408	408	407	399	409	407	406
O2 Concentration (%V)	11.1	11.1	10.6	10.4	10.8	10.7	10.8
CO2 Concentration (%V)	6.4	7.8	6.7	6.6	6.5	6.5	6.8
Stack Gas Moisture (%V)	16.2	15.9	15.8	16.1	14.3	14.4	15.5
Volumetric Flow Rate (dscfm)	3610	3539	3771	3686	3827	3708	3690
Volumetric Flow Rate (dscmm)	102.2	100.2	106.8	104.4	108.3	105.0	104.5
Percent Isokinetic	96.4	98.1	97.3	95.5	94.7	95.1	NA
Particulate Catch (grams)	2.4130	2.5373	2.4053	3.7079	3.1250	2.8438	2.8387

NA = Not Applicable

Note: The accuracy of all calculated results is limited to three significant digits. Summary tables generated by spreadsheet programs report additional digits that are not significant.

TABLE 2-27. METALS/PM EMISSIONS SAMPLING AND FLUE GAS PARAMETERS AT OUTLET
MORRISTOWN MEMORIAL HOSPITAL (1991)

Run No. Date	Run 1 11/18/91	Run 2 11/19/91	Run 3 11/20/91	Run 4 11/21/91	Run 5 11/22/91	Run 6 11/23/91	Average
Total Sampling Time (min)	240	240	240	239	240	240	NA
Average Sampling Rate (dscfm)	0.52	0.53	0.55	0.56	0.56	0.57	0.55
Metered Volume (dscf)	125	127	132	134	135	137	132
Metered Volume (dscm)	3.6	3.6	3.7	3.8	3.8	3.9	3.7
Average Stack Temperature (F)	285	285	285	289	270	287	284
O2 Concentration (%V)	14.1	14.1	13.4	13.8	13.6	13.5	13.8
CO2 Concentration (%V)	5.0	5.0	5.3	5.2	5.0	5.3	5.1
Stack Gas Moisture (%V)	14.7	12.3	15.0	14.7	13.7	12.0	13.7
Volumetric Flow Rate (dscfm)	4671	4761	4762	4753	5036	5012	4832
Volumetric Flow Rate (dscmm)	132.3	134.8	134.9	134.6	142.6	141.9	136.8
Percent Isokinetic	101.0	97.6	99.2	100.9	96.1	102.4	NA
Particulate Catch (grams)	0.0033	0.0046	0.0431	0.0028	0.0083	0.0041	0.0011

NA = Not Applicable

Note: The accuracy of all calculated results is limited to three significant digits. Summary tables generated by spreadsheet programs report additional digits that are not significant.

TABLE 2-28. METALS IN ASH CONCENTRATIONS - BOTTOM ASH
MORRISTOWN MEMORIAL HOSPITAL (1991)

Concentration (mg metal/kg ash)								
Metals	Run 1 (mg/kg)	Run 2 (mg/kg)	Run 3 (mg/kg)	Condition 1 Average (mg/kg)	Run 4 (mg/kg)	Run 5 (mg/kg)	Run 6 (mg/kg)	Condition 2 Average (mg/kg)
Aluminum	185000	194000	192000	190333	152000	79600	82200	104600
Antimony	[3.00]	[3.00]	[3.00]	[3.00]	[3.00]	[3.00]	[3.00]	[3.00]
Arsenic	65.4	84.8	194	114.7	54.8	80.4	90.8	75.3
Barium	3140	4340	3760	3747	6320	10000	6680	7667
Beryllium	0.440	0.440	0.420	0.433	[0.200]	0.480	0.440	0.460
Cadmium	21.8	10.6	11.4	14.6	20.8	8.52	11.7	13.7
Chromium	49.2	51.2	53.6	51.3	36.8	57.2	72.2	55.4
Copper	8900	32200	54800	31967	14300	17400	51000	27567
Lead	208	296	404	303	476	592	430	499
Mercury	[1.96]	[1.96]	[1.96]	[1.96]	[1.96]	[1.96]	[1.96]	[1.96]
Nickel	66.8	148	160	125	71.6	74.4	476	207
Silver	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]
Thallium	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]
% Carbon	7.01	1.62	2.38	3.67	1.04	3.83	1.52	2.13
pH	9.90	9.50	10.4	9.9	9.62	10.1	10.2	10.0
Ash (in lbs)	325	256	404	328	213	241	248	234

[] = Minimum Detection Limit

TABLE 2-29. METALS IN ASH CONCENTRATIONS - BAGHOUSE ASH
MORRISTOWN MEMORIAL HOSPITAL (1991)

Concentration (mg metal/kg ash)								
Metals	Run 1 (mg/kg)	Run 2 (mg/kg)	Run 3 (mg/kg)	Condition 1 Average (mg/kg)	Run 4 (mg/kg)	Run 5 (mg/kg)	Run 6 (mg/kg)	Condition 2 Average (mg/kg)
Aluminum	15200	18400	11500	15033	12800	12800	12600	12733
Antimony	11.4	4.34	3.56	6.43	23.4	5.54	19.3	16.1
Arsenic	2.44	2.22	2.06	2.2	2.66	1.91	2.96	2.5
Barium	1510	1250	1100	1287	1110	1240	1200	1183
Beryllium	[0.200]	0.300	0.220	0.173	0.220	0.220	0.320	0.270
Cadmium	108	75.6	84.4	89.3	98.0	53.2	80.6	77.3
Chromium	20.8	16.8	15.1	17.6	17.8	15.3	17.6	16.9
Copper	1100	1230	802	1044	1380	884	1010	1091
Lead	292	162	98.8	184	224	156	159	180
Mercury	34.8	10.1	40.8	28.6	208	288	444	313
Nickel	22.2	27.4	19.5	23.0	19.8	16.5	18.8	18.4
Silver	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]
Thallium	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]
% Carbon	2.21	1.22	3.88	2.44	3.89	2.22	3.67	3.26
Ash (in lbs)	185	122	215	174.0	99.0	292	156	182.3

[] = Minimum Detection Limit

average concentration was 28.6 mg/kg for Condition 1 and 313.3 mg/kg for Condition 2, almost a 1000 percent increase.

The metals concentrations in the spray dryer ash are summarized in Table 2-30. Aluminum had the highest concentration of all the metals tested for Conditions 1 and 2, averaging 35,933 mg/kg and 47,200 mg/kg, respectively. Antimony, Ag, and Tl were not detected in any of the samples. Mercury was the only metal to exhibit a significant change in concentration from Condition 1 to Condition 2. It had an average concentration of 12.5 mg/kg for Condition 1 and 31.3 mg/kg for Condition 2.

2.3.8 Metals in Make-Up Water and Lime Slurry

Table 2-31 presents the amount of metals and chloride present in the water used to make the lime slurry. The detected metals were Al, Sb, As, Ba, Cr, and Cu; as well as chloride. Table 2-32 presents the concentration of metals detected in the lime slurry. The metals detected were Al, Ba, Cu, Ni, and Ag. Of these metals, only Al and Ag were introduced into the spray dryer at rates which were significant when compared to the metals in the flue gas at the spray dryer inlet. The average mass flow rate of Al in the lime slurry was approximately half of the average mass flow rate of Al in the inlet flue gas, which was 76 g/hr. The mass flow rate of Ag in the lime slurry was approximately 100 times the mass flow rate of Ag in the inlet flue gas, although the total mass flow rate of Ag into the spray dryer was only 0.3 g/hr.

2.4 PARTICULATE MATTER/PARTICLE SIZE DISTRIBUTION

2.4.1 Particulate Matter Results

Particulate matter emissions were determined from the same sampling train used for metals determinations at the spray dryer inlet and baghouse outlet. Before metals analysis, PM collected in the filter and in the front half acetone rinse (probe, nozzle, filter holder) was analyzed gravimetrically as discussed in Section 5.

The PM stack gas concentrations and mass rates for the spray dryer inlet and baghouse outlet are presented in Table 2-33. Concentrations at standard conditions, concentrations adjusted to 7 percent O₂, emission rates, and removal efficiencies are shown.

For Condition 1, where carbon was not added to the lime slurry, the PM concentration and mass rate at the spray dryer inlet averaged 0.45 grains/dscf at

TABLE 2-30. METALS IN ASH CONCENTRATIONS - SPRAY DRYER ASH
MORRISTOWN MEMORIAL HOSPITAL (1991)

Metals	Concentration (mg metal/kg ash)							Condition 2 Average (mg/kg)
	Run 1 (mg/kg)	Run 2 (mg/kg)	Run 3 (mg/kg)	Condition 1 Average (mg/kg)	Run 4 (mg/kg)	Run 5 (mg/kg)	Run 6 (mg/kg)	
Aluminum	43800	45600	18400	35933	53200	44000	44400	47200
Antimony	[3.00]	[3.00]	[3.00]	[3.00]	[3.00]	[3.00]	[3.00]	[3.00]
Arsenic	7.00	7.36	2.80	5.72	3.56	6.10	4.00	4.55
Barium	2400	2260	1580	2080	1940	2120	3080	2380
Beryllium	0.400	0.420	0.300	0.373	0.360	0.360	0.380	0.370
Cadmium	37.8	32.8	46.2	38.9	26.8	22.6	27.6	25.7
Chromium	20.2	26.0	18.8	21.7	23.2	20.6	26.0	23.3
Copper	1020	1080	700	933	1020	976	1300	1099
Lead	312	306	102	240	248	274	234	252
Mercury	10.1	10.6	16.7	12.5	42.0	28.0	24.0	31.3
Nickel	36.0	40.2	26.2	34.1	33.0	35.8	46.2	38.3
Silver	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]	[1.20]
Thallium	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]	[20.0]
% Carbon	1.72	1.57	3.68	2.32	3.18	2.92	2.67	2.92
Ash (in lbs)	17.0	15.0	98.0	43.3	13.0	10.0	8.00	10.3

[] = Minimum Detection Limit

TABLE 2-31. METALS IN MAKE-UP WATER CONCENTRATIONS
MORRISTOWN MEMORIAL HOSPITAL (1991)

Metal	Run 1 (ug/L)	Run 2 (ug/L)	Run 3 (ug/L)	Run 4 (ug/L)	Run 5 (ug/L)	Run 6 (ug/L)	Average Runs 1-6 (ug/L)
Aluminum	37.7	9.25	10.0	12.1	8.63	8.35	14.3
Antimony	4.13	[3.48]	[3.38]	[3.33]	[3.56]	[3.38]	4.13
Arsenic	3.04	2.47	2.62	4.02	2.53	2.34	2.84
Barium	73.6	70.1	77.9	77.8	71.3	79.4	75.0
Beryllium	[0.236]	[0.231]	[0.225]	[0.222]	[0.238]	[0.226]	[0.230]
Cadmium	[0.470]	[0.464]	[0.451]	[0.444]	[0.473]	[0.453]	[0.459]
Chromium	3.32	[1.39]	[1.35]	[1.34]	1.57	1.47	2.12
Copper	71.7	53.1	99.6	146	311	184	144
Lead	[0.706]	[0.694]	[0.678]	[0.667]	[0.711]	[0.679]	[0.689]
Mercury	[0.434]	[0.434]	[0.432]	[0.432]	[0.435]	[0.433]	[0.433]
Nickel	2.10	[0.694]	[0.678]	[0.667]	1.09	0.837	1.34
Silver	45.7	1.95	[1.35]	[1.34]	[1.42]	[1.36]	23.8
Thallium	[23.6]	[23.1]	[22.5]	[22.2]	[23.8]	[22.6]	[23.0]
Chloride	0.00881	0.00951	0.00981	0.00947	0.00925	0.0103	0.00953
% Solid	0.024%	0.017%	0.030%	NSD	0.034%	NSD	0.026%

[] Minimum Detection Limit

NSD = No Solid Detected

TABLE 2-33. PARTICULATE MATTER CONCENTRATIONS AND EMISSION RATES;
MORRISTOWN MEMORIAL HOSPITAL (1991)

Date	Location	Run #	Time (min)	CONCENTRATION			EMISSION RATE		Removal Efficiency (%)
				(grains/dscf @ 7% O ₂)	(grams/dscm)	(grams/dscm @ 7% O ₂)	(lb/hr)	(kg/hr)	
11/18/91	Inlet	1	240	0.353	0.501	0.808	10.9	4.96	
11/19/91	Inlet	2	240	0.372	0.528	0.852	11.3	5.12	
11/20/91	Inlet	3	240	0.334	0.450	0.764	10.8	4.89	
Condition 1 Averages				0.353	0.493	0.808	11.0	4.99	
11/21/91	Inlet	4	240	0.419	0.555	0.959	13.2	6.01	
11/22/91	Inlet	5	240	0.343	0.472	0.786	11.2	5.11	
11/23/91	Inlet	6	240	0.321	0.438	0.735	10.2	4.63	
Condition 2 Averages				0.361	0.488	0.827	11.5	5.25	
11/18/91	Outlet	1	240	0.000410	0.000838	0.000930	0.0162	0.00738	99.9%
11/19/91	Outlet	2	240	0.000560	0.00114	0.00128	0.0228	0.0104	99.8%
11/20/91	Outlet	3	240	0.00504	0.00934	0.0115	0.205	0.0932	98.1%
Condition 1 Averages				0.002003	0.003775	0.00458	0.0814	0.03698	99.2%
11/21/91	Outlet	4	239	0.000320	0.000626	0.00074	0.0131	0.00598	99.9%
11/22/91	Outlet	5	240	0.000950	0.001809	0.00217	0.0409	0.01857	99.6%
11/23/91	Outlet	6	240	0.000460	0.000864	0.00106	0.0199	0.00903	99.8%
Condition 2 Averages				0.000577	0.001100	0.00132	0.0246	0.01119	99.8%

NOTE: Removal efficiency is based on the inlet and outlet emission rates. [(1-outlet/in) x 100]

7 percent O₂ and 11.0 lb/hr, respectively. At the baghouse outlet, the average concentration and emission rate was 0.0038 grains/dscf at 7 percent O₂ and 0.081 lb/hr, respectively.

For Condition 2, where carbon was added to the lime slurry, the average PM concentration at the spray dryer inlet was 0.49 grains/dscf at 7 percent O₂. The average emission rate for the three runs was 0.025 lb/hr.

The results at the spray dryer inlet recorded for both conditions were very similar; therefore, the removal efficiencies should not be biased. The results at the baghouse outlet for both conditions were also similar except for Run 3 which had a significantly higher emission rate. This might be explained by the fact that during the test day the "cake" that forms on the baghouse bags was lost due to a pressure drop across the baghouse. This would decrease the filtering performance of the baghouse. Aside from this occurrence, the average removal efficiencies for both conditions was above 99 percent.

A summary of the sampling and flue gas parameters for the PM runs is given in Tables 2-26 and 2-27 for the spray dryer inlet and baghouse outlet, respectively. Appendix A.2 presents a detailed listing of the calculated results for each sampling run. The gravimetric PM analytical results are included in Appendix E.2.

2.4.2 Particle Size Distribution Results

Four PSD test runs were conducted during the Morristown Memorial Hospital MWI test program. An eight stage Andersen MK III in-stack cascade impactor sampling device was used (see Section 5 for PSD method). The PSD sampling location was at the spray dryer inlet. Following a test, the impactor was inspected to determine if there was adequate particle loading on each of the filter stages. A properly loaded impactor has distinct particulate "piles" under each stage's acceleration jets (holes). An under-loaded impactor is evidenced by clean, undisturbed filters while an over-loaded impactor has particulate piles which overlap and appear to have "broken-up" (evidence of PM re-entrainment). An assessment of the quality of particulate loading was made by the recovery technician, and all of the runs met the recovery QC objectives. The test results for these runs are reported in the following section.

2.4.2.1 Overview

The figures in this section present the log-normal plot of the particle cut size (D_{p50}) at each impactor stage versus the mass fraction of particulate less than that D_{p50} for each PSD run. Linear regressions analyses were conducted and the correlation coefficients (R^2) are shown on each figure. The mass median particle size is calculated from the graphical representation of the linear regression. It is a particle size that represents a point on the distribution in which half of the weight of the particles collected would be aerodynamically larger than, and half of the weight of the particles collected would be aerodynamically smaller than. A weight percentage of the particles collected less than $10\ \mu\text{m}$ is also calculated from the linear regression.

2.4.2.2 Particle Size Distribution Results

Table 2-34 presents the Run 1 PSD results. Run 1 was conducted at the end of the third day of testing. The results are presented graphically in Figure 2-1. Approximately 71 percent of the total PM was less than $10\ \mu\text{m}$. The mass median particle size for Run 1 is approximately $2.3\ \mu\text{m}$.

Table 2-35 presents the results from PSD Run 2. This run was conducted during the fourth day of testing, November 21, 1991. The Run 2 PSD results are presented graphically in Figure 2-2. Slightly larger particle sizes were found in this run, as approximately 49 percent of the particles were less than $10\ \mu\text{m}$; as well as a mass median particle size of $11.0\ \mu\text{m}$.

Table 2-36 presents the results for PSD Run 3 which was conducted on the fifth day of testing, November 22, 1991. The graphical representation of this distribution, illustrated in Figure 2-3, shows a mass median particle size of $9.6\ \mu\text{m}$ and has 51 percent of the total PM less than $10\ \mu\text{m}$.

Table 2-37 presents the results from Run 4 conducted on the sixth day of testing, November 23, 1991. Figure 2-4 shows the particle size distribution of this run. The mass median particle size as $11.1\ \mu\text{m}$, and approximately 48 percent of the weight was less than $10\ \mu\text{m}$.

Table 2-38 is a summary of the PSD results for the 4 test runs. Run 1 appears to be different in size distribution from Runs 2, 3, and 4.

TABLE 2-34. PSD RUN 1 RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)

DATE:	11/20/91		Net Weight (grams)	Mass Fraction	Mass Fract. Less Than	Interval Geometric Midpoint (microns)	dM/dlog DP (gr/dscf)	CONC (gr/dscf)
	STAGE	Dp50 (microns)						
	Preim & 1	17.2126	0.00637	0.2026	0.7974 *	29.3365	5.698E-02	0.026387
	2	11.2808	0.00144	0.0458	0.7516	13.9346	3.251E-02	0.005965
	3	7.3596	0.00272	0.0865	0.6651	9.1117	6.075E-02	0.011267
	4	5.1957	0.00276	0.0878	0.5773	6.1837	7.561E-02	0.011433
	5	3.0731	0.00237	0.0754	0.5019	3.9959	4.305E-02	0.009818
	6	1.7399	0.00223	0.0709	0.4310	2.3123	3.739E-02	0.009238
	7	1.0579	0.00130	0.0413	0.3896	1.3567	2.492E-02	0.005385
	8	0.6562	0.00215	0.0684	0.3212	0.8332	4.294E-02	0.008906
	BACK-UP		0.01010	0.3212	0.0000 *	0.0573	1.975E-02	0.041838
	TOTAL		0.03144	1.0000				0.130237

* these values assume top end and bottom end dp50s of 50 and .005 um.

TABLE 2-35. PSD RUN 2 RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)

DATE:	11/21/91		Net Weight (grams)	Mass Fraction	Mass Fract. Less Than	Interval Geometric Midpoint (microns)	dM/dlog DP (gr/dscf)	CONC (gr/dscf)
	STAGE	Dp50 (microns)						
	Preim & 1	17.3944	0.01505	0.4421	0.5579 *	29.4910	1.839E-01	0.084348
	2	11.4000	0.00110	0.0323	0.5256	14.0818	3.360E-02	0.006165
	3	7.4373	0.00216	0.0635	0.4621	9.2079	6.526E-02	0.012106
	4	5.2506	0.00193	0.0567	0.4054	6.2490	7.153E-02	0.010817
	5	3.1055	0.00190	0.0558	0.3496	4.0380	4.669E-02	0.010649
	6	1.7581	0.00147	0.0432	0.3064	2.3366	3.334E-02	0.008239
	7	1.0689	0.00085	0.0250	0.2814	1.3708	2.204E-02	0.004764
	8	0.6627	0.00069	0.0203	0.2612	0.8416	1.863E-02	0.003867
	BACK-UP		0.00889	0.2612	0.0000 *	0.0576	2.348E-02	0.049824
	TOTAL		0.03404	1.0000				0.190777

* these values assume top end and bottom end dp50s of 50 and .005 um.

TABLE 2-36. PSD RUN 3 RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)

DATE:	11/22/91		Net Weight (grams)	Mass Fraction	Mass Fract. Less Than	Interval Geometric Midpoint (microns)	dM/dlog DP (gr/dscf)	CONC (gr/dscf)
	STAGE	Dp50 (microns)						
	Preim & 1	17.6739	0.01386	0.4510	0.5490 *	29.7270	1.839E-01	0.079370
	2	11.5831	0.00046	0.0150	0.5340	14.3080	3.360E-02	0.002634
	3	7.5568	0.00125	0.0407	0.4933	9.3558	6.526E-02	0.007158
	4	5.3349	0.00170	0.0553	0.4380	6.3494	7.153E-02	0.009735
	5	3.1553	0.00145	0.0472	0.3908	4.1028	4.669E-02	0.008304
	6	1.7861	0.00118	0.0384	0.3524	2.3740	3.334E-02	0.006757
	7	1.0857	0.00074	0.0241	0.3283	1.3925	2.204E-02	0.004238
	8	0.6728	0.00150	0.0488	0.2795	0.8546	1.863E-02	0.008590
	BACK-UP		0.00859	0.2795	0.0000 *	0.0580	2.348E-02	0.049191
	TOTAL		0.03073	1.0000				0.175978

* these values assume top end and bottom end dp50s of 50 and .005 um.

TABLE 2-37. PSD RUN 4 RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)

DATE:	11/23/91		Net Weight (grams)	Mass Fraction	Mass Fract. Less Than	Interval Geometric Midpoint (microns)	dM/dlog DP (gr/dscf)	CONC (gr/dscf)
	STAGE	Dp50 (microns)						
	Preim & 1	17.5700	0.01162	0.4602	0.5398 *	29.6395	1.839E-01	0.0658
	2	11.5150	0.00064	0.0253	0.5145	14.2239	3.360E-02	0.0036
	3	7.5124	0.00175	0.0693	0.4451	9.3008	6.526E-02	0.0099
	4	5.3035	0.00154	0.0610	0.3842	6.3121	7.153E-02	0.0087
	5	3.1367	0.00160	0.0634	0.3208	4.0787	4.669E-02	0.0091
	6	1.7757	0.00146	0.0578	0.2630	2.3601	3.334E-02	0.0083
	7	1.0794	0.00049	0.0194	0.2436	1.3844	2.204E-02	0.0028
	8	0.6690	0.00032	0.0127	0.2309	0.8498	1.863E-02	0.0018
	BACK - UP		0.00583	0.2309	0.0000 *	0.0578	2.348E-02	0.0330
	TOTAL		0.02525	1.0000				0.1431

* these values assume top end and bottom end dp50s of 50 and .005 um.

TABLE 2-38. SUMMARY OF PARTICLE SIZE DISTRIBUTION RESULTS;
MORRISTOWN MEMORIAL HOSPITAL (1991)

RUN NO.	MASS MEDIAN PARTICLE SIZE (μm)	WEIGHT PERCENTAGE LESS THAN 10 μm (%)	TOTAL PM CONCENTRATION (grains/dscf)
1	2.3	71	0.130
2	11.0	49	0.191
3	9.6	51	0.176
4	11.1	48	0.143
AVERAGE	8.5	55	0.160

TABLE 2-39. PSD FLUE GAS AND SAMPLING PARAMETERS
MORRISTOWN MEMORIAL HOSPITAL (1991)

FLUE GAS AND SAMPLING PARAMETERS	RUN 1	RUN 2	RUN 3	RUN 4	AVERAGE
Total Sampling Time (min.)	20.0	15.0	15.0	15.0	NA
Average Stack Temperature (°F)	410	410	410	410	410
Average Sampling Rate (dscfm)	0.200	0.198	0.192	0.194	0.196
Standard Metered Volume, Vm(std) (dscf)	4.00	2.96	2.89	2.91	3.19
Standard Metered Volume, Vm(std) (dscm)	0.121	0.090	0.087	0.088	0.097
Stack Moisture (%V)	0.149	0.147	0.139	0.140	0.144
Percent Isokinetic	104.5	103.0	101.8	102.9	NA




FIGURE 2-1. Run 1 PSD Results - Log Particle Size vs Mass Fraction
Less Than Particle Size. Morristown Memorial Hospital (1991)




FIGURE 2-2. Run 2 PSD Results - Log Particle Size vs Mass Fraction Less Than Particle Size. Morristown Memorial Hospital (1991)




FIGURE 2-3. Run 3 PSD Results - Log Particle Size vs Mass Fraction Less Than Particle Size. Morristown Memorial Hospital (1991)




FIGURE 2-4. Run 4 PSD Results - Log Particle Size vs Mass Fraction Less Than Particle Size. Morristown Memorial Hospital (1991)

Table 2-39 is a summary of the PSD flue gas and sampling parameters, including the isokinetic sampling ratios. All of the sampling parameters are consistent throughout the four runs, and the isokinetic ratios are all within ± 10 percent of 100 percent.

2.5 MERCURY EMISSIONS BY METHOD 101A

A Hg Method 101A sampling train was performed at the Morristown Memorial Hospital to further validate the Hg values from the toxic metal train. A comparison of the Method 101A Hg values to the multi-metals Hg values is discussed in more detail in Section 2.5.6.

2.5.1 Overview

A single sampling train was used to determine emission rates of Hg by Method 101A. Three sampling runs were performed under both test conditions (without carbon injection and with carbon injection) in order to ensure representative test results. Sampling locations, method, and QA/QC are discussed in Sections 4, 5, and 6, respectively. The results for each individual run are presented in Section 2.5.3. Concentrations at dry standard conditions, adjusted to 7 percent O₂, emission rates, and removal efficiencies are reported. The sample and flue gas parameters are presented in Section 2.5.4. The detected Hg weights separated by analytical filter digestion is discussed in Section 2.5.5. A comparison of the Hg collected in Method 101A versus the toxic metals trains is presented in Section 2.4.6.

2.5.2 Mercury Data Reduction

The values reported in the following Hg results were calculated using the same guidelines that are outlined for the metals in Section 2.3.2.

2.5.3 Mercury Emissions

Table 2-40 presents a summary of the Hg total weights, standard concentrations, concentrations corrected to 7 percent O₂, and emission rate results for each test condition.

For Condition 1, where carbon was not injected into the lime slurry, the Hg emission rate at the spray dryer inlet ranged from 5.20 to 19.8 g/hr with an average of 9.28 g/hr. At the baghouse outlet the emission rate ranged from 3.56 to 20.2 g/hr with an average of 10.4 g/hr.

TABLE 2-40. SUMMARY OF MERCURY 101A RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)

Condition	Run	Location								RE (%)
		Inlet (total ug)	Outlet (total ug)	Inlet (ug/dscm)	Outlet (ug/dscm)	Inlet (ug/dscm @ 7% O ₂)	Outlet (ug/dscm @ 7% O ₂)	Inlet (g/hr)	Outlet (g/hr)	
Without Carbon	1	2630	3450	902	943	1280	1930	5.20	7.51	-44.5%
	2	1480	1640	492	449	698	918	2.88	3.56	-23.5%
	3	9760	9350	3350	2480	4520	4600	19.8	20.2	-2.10%
Average		4623	4813	1581	1291	2166	2483	9.28	10.4	-12.2%
With Carbon	4	1500	998	502	264	664	516	3.10	2.13	31.3%
	5	4680	326	1630	83.7	2240	159	9.48	0.719	92.4%
	6	6470	697	2250	177	3070	332	13.2	1.48	88.8%
Average		4217	674	1461	175	1991	336	8.60	1.44	83.2%

For Condition 2, where carbon was injected into the lime slurry, the Hg emission rate at the spray dryer inlet ranged from 3.10 to 13.2 g/hr with an average of 8.6 g/hr. At the baghouse outlet, the mass emission rate ranged from 0.72 to 2.13 g/hr with an average of 1.44 g/hr.

The removal efficiencies during the emission tests without carbon injection display a slight Hg gain across the emission controls. A recent study on the precision of Method 101A when measuring exhaust gases from a municipal waste combustor (EPA 450/4-92-013) reported an average relative standard deviation (RSD) of the method of 15.6% when used without carbon injection. Assuming that the same RSD applies to Runs 1, 2, and 3 of this test program, all pairs of O₂-corrected Hg concentrations at the inlet and outlet agree within 2.6 standard deviations. The apparent gain in Hg concentrations over the control device in Runs 1-3 may therefore be due primarily to inherent variability in the sampling method.

The removal efficiencies during the emission tests with carbon injection present an average removal efficiency of 83.2 percent. Therefore, from the Method 101A Hg results, it is apparent that carbon injection into the spray dryer positively affects the removal of Hg in the flue gas.

2.5.4 Mercury Sample Parameters

Sampling and flue gas parameters for the Method 101A sampling trains at the inlet are shown in Table 2-41, and Table 2-42 presents the parameters for the runs performed at the outlet. Total sampling times, sample volume, and isokinetic results for each sampling run are presented. All of the runs were within the ± 10 percent isokinetic range. Appendix C contains a complete listing of these and additional sampling and flue gas parameters for each run.

2.5.5 Mercury Amounts by Sample Fraction

Table 2-43 presents the detected weights of Hg specific to both sample fractions and reports the amount of total weight detected by the first and second filter digestions. The first digestion is performed on the first analytical filter with 8N HCl, and the second digestion is performed on the second analytical filter with aqua regia (3/4 HCl and 1/4 HNO₃). Further details of this process are discussed in Section 5.

The first digestion of the front half of the sample train does detect significant additional amounts of Hg at the inlet runs. None of the second filtrations add significantly to the total Hg detected, especially in the back half of the sample.

2.5.6 Mercury Emissions Comparison

Table 2-44 presents the comparison of Hg emission rates and removal efficiencies for Method 101A to multi-metal trains. During the emission tests without carbon injection, the results from the Method 101A and multi-metals do not agree, more predominantly at the inlet. The fractional results of the multi-metals sample analysis shown in Table 2-25 show that most of the Hg was captured in the first three nitric acid impingers, before the gas reached the KMnO_4 solution. This allows the possibility that some forms of Hg may be captured more efficiently in the HNO_3 than in the KMnO_4 , and that the Method 101A train allows some Hg to break through. The municipal waste incinerator cited previously (EPA 450/4-92-013) also showed higher concentrations of Hg measured with the multi-metals train than with the Method 101A train. Differences in the forms of Hg present at the inlet and outlet locations could account for the difference in relative method performance at these two locations, however, speciation of Hg compounds is beyond the scope of this study.

Valuable data might be gathered in future tests by adding HNO_3 impingers to the back end of a Method 101 train, and analyzing impingers individually to further characterize Hg capture through the train fractions.

For Condition 1 at the spray dryer inlet, the average removal efficiency determined by the Method 101A train was -12.2 percent; in comparison, the multi-metals average removal efficiency was 29.7 percent.

For the emission tests with carbon injection, the results from Runs 5 and 6 display similar emission rates for both methods. The average removal efficiency determined from the Method 101A trains was 83.2 percent, and the average removal efficiency determined from the multi-metals trains was 90.0 percent; therefore, portraying more consistent results than the first three runs.

TABLE 2-41. MERCURY 101A SAMPLING AND FLUE GAS PARAMETERS AT THE SPRAY DRYER INLET;
MORRISTOWN MEMORIAL HOSPITAL (1991)

Run No. Date	Run 1 11/18/91	Run 2 11/19/91	Run 3 11/20/91	Run 4 11/21/91	Run 5 11/22/91	Run 6 11/23/91	Average
Total Sampling Time (min)	240	240	240	240	240	240	NA
Average Sampling Rate (dscfm)	0.43	0.44	0.43	0.44	0.42	0.42	0.43
Metered Volume (dscf)	103	106	103	106	102	101	103
Metered Volume (dscm)	2.9	3.0	2.9	3.0	2.9	2.9	2.9
Average Stack Temperature (F)	409	410	410	412	410	407	410
O2 Concentration (%V)	11.1	11.1	10.6	10.4	10.8	10.7	10.8
CO2 Concentration (%V)	6.4	7.8	6.7	6.6	6.5	6.5	6.8
Stack Gas Moisture (%V)	15.6	15.3	14.1	13.6	13.9	14.2	14.4
Volumetric Flow Rate (dscfm)	3393	3447	3473	3639	3422	3459	3472
Volumetric Flow Rate (dscmm)	96.1	97.6	98.4	103.0	96.9	98.0	98.3
Percent Isokinetic	101.2	102.7	94.2	96.7	99.0	97.8	NA

NA = Not Applicable

Note: The accuracy of all calculated results is limited to three significant digits. Summary tables generated by spreadsheet programs report additional digits that are not significant.

TABLE 2-42. MERCURY 101A SAMPLING AND FLUE GAS PARAMETERS AT THE BAGHOUSE OUTLET;
MORRISTOWN MEMORIAL HOSPITAL (1991)

Run No. Date	Run 1 11/18/91	Run 2 11/19/91	Run 3 11/20/91	Run 4 11/21/91	Run 5 11/22/91	Run 6 11/23/91	Average
Total Sampling Time (min)	240	240	240	239	240	240	NA
Average Sampling Rate (dscfm)	0.54	0.54	0.56	0.56	0.57	0.58	0.56
Metered Volume (dscf)	129	129	133	134	138	139	134
Metered Volume (dscm)	3.7	3.7	3.8	3.8	3.9	3.9	3.8
Average Stack Temperature (F)	285	285	285	289	270	287	284
O2 Concentration (%V)	14.1	14.1	13.4	13.8	13.6	13.5	13.8
CO2 Concentration (%V)	5.0	5.0	5.3	5.2	5.0	5.3	5.1
Stack Gas Moisture (%V)	14.3	14.4	14.4	14.6	13.4	13.7	14.1
Volumetric Flow Rate (dscfm)	4687	4664	4790	4758	5051	4932	4814
Volumetric Flow Rate (dscmm)	132.7	132.1	135.6	134.7	143.0	139.7	136.3
Percent Isokinetic	97.6	98.9	99.6	100.9	97.4	101.0	NA

NA = Not Applicable

Note: The accuracy of all calculated results is limited to three significant digits. Summary tables generated by spreadsheet programs report additional digits that are not significant.

TABLE 2-43. COMPARISON OF MERCURY 101A DATA TO DIGESTED LAB FILTERS;
MORRISTOWN MEMORIAL HOSPITAL (1991)

Run	Front Half					Back Half				
	Total ug without Lab Filters	Total ug with 1st Lab Filter	% Diff.	Total ug with 2nd Lab Filter	% Diff.	Total ug without Lab Filters	Total ug with 1st Lab Filter	% Diff.	Total ug with 2nd Lab Filter	% Diff.
Inlet 1	134	147	9.09%	150	1.73%	2480	2480	0.0%	2480	0.0%
Inlet 2	48.2	51.3	6.01%	52.0	1.35%	1430	1430	0.0%	1430	0.0%
Inlet 3	976	1030	5.24%	1060	2.83%	8690	8690	0.0%	8700	0.115%
Cond. 1 Avg.	386	410	6.78%	421	1.97%	4200	4200	0.0%	4200	0.0383%
Inlet 4	219	231	5.07%	233	1.17%	1270	1270	0.0%	1270	0.0%
Inlet 5	1640	1690	2.96%	1700	0.588%	2980	2980	0.0%	2980	0.0%
Inlet 6	132	143	7.82%	144	0.865%	6320	6320	0.0%	6320	0.0%
Cond. 2 Avg.	664	688	5.28%	693	0.874%	3523	3520	0.0%	3520	0.0%
Outlet 1	0.378	1.50	74.8%	1.66	9.60%	3450	3450	0.0%	3450	0.0%
Outlet 2	0.293	0.701	58.2%	0.701	0.0%	1640	1640	0.0%	1640	0.0%
Outlet 3	2.88	3.99	27.8%	3.99	0.0%	9340	9340	0.0%	9340	0.0%
Cond. 1 Avg.	1.18	2.06	53.6%	2.12	3.20%	4810	4810	0.0%	4810	0.0%
Outlet 4	0.378	0.566	33.2%	0.566	0.0%	993	998	0.452%	998	0.0%
Outlet 5	[0.206]	[0.835]	0%	0.159	100.0%	326	326	0.0%	326	0.0%
Outlet 6	[0.206]	0.320	>36%	0.320	0.0%	696	697	0.0754%	697	0.0%
Cond. 2 Avg.	0.378	0.443	23.1%	0.348	33.33%	672	673	0.176%	673	0.0%

[] = Not detected at the limit shown

a The greater weight is used as a reference point for the calculation of % Difference.

TABLE 2-44. COMPARISON FOR MERCURY EMISSION RATES AND REMOVAL EFFICIENCIES
METHOD 101A VERSUS TOXIC METALS;
MORRISTOWN MEMORIAL HOSPITAL (1991)

Condition	Run	Method 101A			Toxic Metal Trains		
		Inlet (g/hr)	Outlet (g/hr)	RE (%)	Inlet (g/hr)	Outlet (g/hr)	RE (%)
Without Carbon	1	5.20	7.51	-44.5%	9.51	4.67	50.9%
	2	2.88	3.56	-23.5%	2.7	2.76	-1.1%
	3	19.8	20.2	-2.10%	23.4	17.6	24.6%
	Average	9.28	10.4	-12.2%	11.9	8.35	29.7%
With Carbon	4	3.10	2.13	31.3%	11.4	1.84	83.8%
	5	9.48	0.719	92.4%	10.6	0.436	95.9%
	6	13.2	1.48	88.8%	14.9	1.40	90.6%
	Average	8.60	1.44	83.2%	12.3	1.23	90.0%

2.6 HALOGEN GAS EMISSIONS

Hydrogen chloride (HCl), HF, and HBr gas concentrations were manually sampled at the spray dryer inlet and the baghouse outlet, following EPA Method 26 procedures. In this method, flue gas is extracted from the sample location and passed through acidified water. The halogen gases solubilize and form halide ions. Ion chromatography was used to detect the chloride (Cl^-), bromide (Br^-), and fluoride (F^-) ions present in the sample. Three 1-hour samples were collected during each of the 6 test runs. The results are reported as a concentration (ppmv) and an emission rate (lb/hr) at dry standard conditions. Since a flow rate is not calculated using EPA Method 26, the corresponding flue gas flow rates determined from the CDD/CDF sampling trains were used in the calculation of emission rates.

The results for all 3 halogens from Runs 1 and 2 at the inlet and Runs 1B and 1C at the baghouse outlet were rejected and not reported. A comparison of the Method 26 and the HCl CEM data shows that these results are obvious outliers at a 90 percent confidence level.

2.6.1 Hydrogen Chloride Emissions Results

Table 2-45 presents a summary of HCl spray dryer inlet and baghouse outlet concentrations and emission rates determined by manual sampling and provides the HCl removal efficiencies for the emission control system. The removal efficiencies for the six runs conducted on the first two days could not be calculated because the spray dryer inlet results were outside acceptable control limits.

For Condition 1, where carbon was not added to the lime slurry, the HCl concentration at the spray dryer inlet ranged from 398.6 to 952.7 ppmvd at 7 percent O_2 , with an average of 723.7 ppmvd at 7 percent O_2 . The HCl mass rate entering the spray dryer ranged from 5.9 to 14.1 lb/hr with an average of 10.8 lb/hr. At the baghouse outlet, the HCl concentration ranged from 3.9 to 8.5 ppmvd at 7 percent O_2 with an average of 6.0 ppmvd at 7 percent O_2 . The HCl emission rate at the baghouse outlet ranged from 0.06 to 0.12 lb/hr with an average of 0.08 lb/hr.

TABLE 2-45. SUMMARY OF HYDROGEN CHLORIDE RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)

RUN NO.	SPRAYDRYER INLET				BAGHOUSE OUTLET						REMOVAL EFFICIENCY (%)
	O ₂ CONC. (% VOL.)	FLUE GAS FLOW (dscmm)	GAS CONC. (ppmV)	GAS CONC. (ppmV @7% O ₂)	EMISSION RATE (lb/hr)	O ₂ CONC. (% VOL.)	FLUE GAS FLOW (dscmm)	GAS CONC. (ppmV)	GAS CONC. (ppmV @7% O ₂)	EMISSION RATE (lb/hr)	
1A	11.1	95.4	b	b	b	14.1	135.0	3.70	7.56	0.100	NA
1B	11.1	95.4	b	b	b	14.1	135.0	b	b	b	NA
1C	11.1	95.4	b	b	b	14.1	135.0	b	b	b	NA
AVERAGE			NA	NA	NA			3.70	7.56	0.100	NA
2A	11.1	98.5	b	b	b	14.1	140.7	4.17	8.52	0.118	NA
2B	11.1	98.5	b	b	b	14.1	140.7	2.63	5.38	0.074	NA
2C	11.1	98.5	b	b	b	14.1	140.7	3.32	6.79	0.094	NA
AVERAGE			NA	NA	NA			3.37	6.90	0.095	NA
3A	10.6	100.0	607	820	12.2	13.4	140.4	2.12	3.93	0.060	99.5
3B	10.6	100.0	295	399	5.92	13.4	140.4	2.39	4.42	0.067	98.9
3C	10.6	100.0	706	953	14.2	13.4	140.4	2.79	5.17	0.078	99.4
AVERAGE			536	724	10.8			2.43	4.51	0.068	99.3
COND. 1 AVG.	10.9	98.0	536	724	10.8	13.9	138.7	3.02	5.97	0.084	99.3
4A	10.4	94.7	892	1181	16.9	13.8	137.1	3.24	6.34	0.089	99.5
4B	10.4	94.7	866	1146	16.4	13.8	137.1	29.2	57.1	0.803	95.1
4C	10.4	94.7	1015	1343	19.3	13.8	137.1	7.64	15.0	0.210	98.9
AVERAGE			924	1224	17.5			13.4	26.1	0.367	97.8
5A	10.8	96.8	656	902	12.7	13.6	143.2	[0.026]	[0.049]	[0.0007]	>99.99
5B	10.8	96.8	571	786	11.1	13.6	143.2	[0.026]	[0.050]	[0.0008]	>99.99
5C	10.8	96.8	836	1151	16.2	13.6	143.2	[0.025]	[0.047]	[0.0007]	>99.99
AVERAGE			688	946	13.3			[0.026]	[0.049]	[0.0007]	>99.99
6A	10.7	98.9	724	986	14.4	13.5	141.0	[0.023]	[0.044]	[0.0007]	>99.99
6B	10.7	98.9	493	672	9.79	13.5	141.0	[0.023]	[0.043]	[0.0007]	>99.99
6C	10.7	98.9	1043	1421	20.7	13.5	141.0	[0.026]	[0.049]	[0.0007]	>99.99
AVERAGE			753	1026	14.9			[0.024]	[0.045]	[0.0007]	>99.99
COND. 2 AVG.	10.6	96.8	788	1065	15.3	13.6	140.4	13.4	26.1	0.367	99.27

a The flow rates determined by the CDD/CDF sampling trains were used for HCl emission rate calculations.

b The results are not reported because the data are not within acceptable control limits.

c || = Not detected at the limit shown.

d Detection limits are not considered when calculating averages.

For Condition 2 where carbon was added to the lime slurry, the HCl concentration at the spray dryer inlet ranged from 672.1 to 1420.9 ppmvd at 7 percent O₂, with an average of 1065.4 ppmvd at 7 percent O₂. The mass emission rate entering the spray dryer ranged from 9.8 to 20.7 lb/hr with an average of 15.3 lb/hr. The HCl concentration leaving the baghouse ranged from less than 0.04 ppmvd at 7 percent O₂ to 57.1 ppmvd at 7 percent O₂ with an average of 26.1 ppmvd at 7 percent O₂. The mass emission rate at the baghouse outlet ranged from less than 0.0007 lb/hr to 0.8 lb/hr with an average of 0.37 lb/hr.

The mass flow rate of HCl into the spray dryer was approximately 42% higher during Condition 2 than Condition 1, but the difference was not great enough to significantly effect the removal efficiencies. Based on the results from Runs 5 and 6, carbon injection appears to improve HCl removal in the flue gas; however, the results from Run 4 are similar to the results obtained without carbon injection. Therefore, it cannot be concluded with confidence that carbon injection improves removal of HCl in the emission control system.

In addition to Method 26, the flue gas was analyzed for HCl using a CEM monitor as discussed in Section 5. Table 2-46 summarizes the CEM HCl results, including HCl removal efficiencies based on ppmvd corrected to 7 percent O₂. The HCl data is corrected to a dry basis using an average moisture percentage taken from the other manual trains. The values reported are averages of the CEM data that correspond to the exact time in which the Method 26 trains were run.

For the runs without carbon injection, the HCl concentration at the spray dryer inlet ranged from 798.3 to 1087.9 ppmvd at 7 percent O₂ with an average of 913.0 ppmvd at 7 percent O₂. At the baghouse outlet, the HCl concentration ranged from 8.37 to 20.19 ppmvd at 7 percent O₂ with an average of 15.6 ppmvd at 7 percent O₂.

For the runs with carbon injection, the HCl concentration at the spray dryer inlet ranged from 961.9 to 1090.1 ppmvd at 7 percent O₂ with an average of 1013.7 ppmvd at 7 percent O₂. At the baghouse outlet, the concentration ranged from 10.6 to 30.7 ppmvd at 7 percent O₂ with an average for the 3 runs of 18.6 ppmvd at 7 percent O₂.

**TABLE 2-46. SUMMARY OF HCI CEM RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)**

RUN NO.	SPRAYDRYER INLET					BAGHOUSE OUTLET					REMOVAL EFFICIENCY (%)
	O ₂ (%V)	H ₂ O (%V)	HCl (ppmV)	HCl (ppmVd)	HCl (ppmVd) @7% O ₂	O ₂ (%V)	H ₂ O (%V)	HCl (ppmV)	HCl (ppmVd)	HCl (ppmVd) @7% O ₂	
1	11.1	15.9	643	764	1088	14.2	14.6	7.57	8.87	18.3	98.3%
2	11.2	15.5	471	557	798	14.2	13.8	8.36	9.69	20.24	97.5%
3	10.7	14.9	535	629	853	13.6	14.7	3.77	4.42	8.37	99.0%
COND. 1 AVG.	11.0	15.4	550	650	913	14.0	14.4	6.56	7.66	15.6	98.3%
4	10.4	14.7	703	824	1090	14.2	14.8	12.5	14.7	30.6	97.2%
5	10.7	13.9	606	704	962	13.8	13.4	6.44	7.44	14.5	98.5%
6	10.6	14.0	629	731	989	13.9	13.0	4.67	5.36	10.6	98.9%
COND. 2 AVG.	10.6	14.2	646	753	1014	14.0	13.7	7.91	9.17	18.6	98.2%

a The O₂ results are averaged from CEM values corresponding to the three daily HCl runs.

b The HCl data is corrected to a dry basis using an average moisture percentage from the manual trains.

c Removal Efficiency is based on HCl values corrected to 7% O₂.

During Condition 1, the HCl removal efficiency ranged from 97.5 to 99.0 percent and averaged 98.3 percent for the 3 runs. During Condition 2, the HCl removal efficiency ranged from 97.5 to 98.9 percent and averaged 98.3 percent. At the spray dryer inlet, an average increase of 11.0 percent in the HCl concentration occurs from Condition 1 to Condition 2; whereas, at the baghouse outlet, an average increase of 18.9 percent in the HCl concentration occurs from Condition 1 to Condition 2. An increase of HCl at the spray dryer inlet is reflected as a similar increase at the baghouse outlet. From this data, one could conclude that the injection of carbon does not increase the removal of HCl in the emission control system.

Table 2-47 presents a comparison of the manual and CEM HCl concentrations (ppmvd at 7 percent O₂). The CEM values are data averages that correspond to the exact time periods during which the manual sampling was conducted. At the spray dryer inlet, the percent difference between the manual results and the CEM results ranged from -15.5 to 107.1, with an average difference of -1.7 percent. At the baghouse outlet, the percent difference ranged from -77.3 to 302.0 with an average difference of 42.3 percent.

Figure 2-5 presents a graphical representation of the manual and CEM HCl concentrations at the spray dryer inlet. This table illustrates the common trend between the results of both methods. Figure 2-6 presents a graphical representation of the manual and CEM HCl concentrations at the baghouse outlet. Here the common trend between the two methods is discernable, but is not as obvious at the baghouse outlet as it is at the spray dryer inlet. Actual correlation between methods on individual runs is weak for both locations.

2.6.2 Hydrogen Fluoride Emission Results

Table 2-48 presents a summary of HF inlet and outlet concentrations and emission rates determined by manual sampling, as well as providing emission control removal efficiencies. The removal efficiencies could not be calculated for the first six runs for reasons discussed previously.

For Condition 1, the HF concentrations at the spray dryer inlet ranged from less than 0.7 ppmvd at 7 percent O₂ to 1.3 ppmvd at 7 percent O₂ with an average of 1.3 ppmvd at 7 percent O₂. The HF emission rate entering the spray dryer ranged from

TABLE 2-47. COMPARISON OF MANUAL AND CEM HCl RESULTS;
MORRISTOWN MEMORIAL HOSPITAL (1991)

TEST RUN NUMBER	SPRAY DRYER INLET			BAGHOUSE OUTLET		
	MANUAL (ppm Vd @7% O ₂)	CEM (ppm Vd @7% O ₂)	% DIFF.	MANUAL (ppm Vd @7% O ₂)	CEM (ppm Vd @7% O ₂)	% DIFF.
1A	b	734 ^a	NA	7.56	1.72	-77.3%
1B	b	1060	NA	b	23.8	NA
1C	b	1470	NA	b	29.5	NA
AVERAGE	NA	1088	NA	7.56	18.3	143%
2A	b	781	NA	8.52	13.1	54.0%
2B	b	767	NA	5.38	20.2	275%
2C	b	847	NA	6.79	27.3	302%
AVERAGE	NA	798	NA	6.90	20.2	193%
3A	820	779	-4.9%	3.93	7.71	96.3%
3B	399	825	107%	4.42	7.03	59.0%
3C	953	954	0.1%	5.17	10.4	101%
AVERAGE	724	853	17.9%	4.51	8.37	85.7%
4A	1181	998	-15.5%	6.34	6.26	-1.31%
4B	1146	1064	-7.1%	57.1	59.8	4.59%
4C	1343	1208	-10.1%	15.0	25.9	73.4%
AVERAGE	1224	1090	-10.9%	26.1	30.6	17.2%
5A	902	794	-12.0%	[0.049]	6.19	NA
5B	786	832	5.8%	[0.050]	8.11	NA
5C	1151	1260	9.4%	[0.047]	29.1	NA
AVERAGE	946	962	1.6%	[0.049]	14.5	NA
6A	986	888	-10.0%	[0.044]	5.48	NA
6B	672	1056	57.2%	[0.043]	24.1	NA
6C	1421	1023	-28.0%	[0.049]	2.31	NA
AVERAGE	1026	989	-3.6%	[0.045]	10.6	NA
TOTAL AVERAGE	980	963	-1.7%	12.0	17.1	42.3%

a The CEM HCl data is corrected to a dry basis using an average moisture percentage from the manual trains.

b The results are not reported because the data is not within acceptable control limits.

c || = Not detected at the limit shown.




Figure 2-5. HCl Results Comparison - Spray Dryer Inlet
Morristown Memorial Hospital (1991)




Figure 2-6. HCl Results Comparison - Baghouse Outlet
Morristown Memorial Hospital (1991)

TABLE 2-48. SUMMARY OF HYDROGEN FLUORIDE REMOVAL RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)

RUN NO.	SPRAYDRYER INLET				BAGHOUSE OUTLET						REMOVAL EFFICIENCY (%)
	O ₂ CONC. (% VOL.)	FLUE GAS FLOW (dscmm)	GAS CONC. (ppmv)	GAS CONC. (ppmv @7% O ₂)	EMISSION RATE (lb/hr)	O ₂ CONC. (% VOL.)	FLUE GAS FLOW (dscmm)	GAS CONC. (ppmv)	GAS CONC. (ppmv @7% O ₂)	EMISSION RATE (lb/hr)	
1A	11.1	95.4	b	b	b	14.1	135.0	(1.56)	(3.20)	(0.0232)	NA
1B	11.1	95.4	b	b	b	14.1	135.0	b	b	b	NA
1C	11.1	95.4	b	b	b	14.1	135.0	b	b	b	NA
AVERAGE			NA	NA	NA			1.565	3.198	0.023	NA
2A	11.1	98.5	b	b	b	14.1	140.7	0.308	0.629	0.0048	NA
2B	11.1	98.5	b	b	b	14.1	140.7	0.270	0.552	0.0042	NA
2C	11.1	98.5	b	b	b	14.1	140.7	0.254	0.520	0.0039	NA
AVERAGE			NA	NA	NA			0.277	0.567	0.0043	NA
3A	10.6	100.0	(0.994)	(1.342)	(0.011)	13.4	140.4	0.246	0.457	0.0038	65.2
3B	10.6	100.0	0.721	0.972	0.008	13.4	140.4	0.332	0.615	0.0051	c
3C	10.6	100.0	0.540	0.729	0.006	13.4	140.4	0.225	0.417	0.0035	c
AVERAGE			0.994	1.34	0.011			0.268	0.496	0.0041	65.2
COND. 1 AVG.	10.9	98.0	0.994	1.34	0.011	13.9	138.7	1.565	3.198	0.023	65.2
4A	10.4	94.7	11.1	14.7	0.115	13.8	137.1	0.284	0.556	0.0043	96.3
4B	10.4	94.7	3.87	5.13	0.040	13.8	137.1	0.164	0.321	0.0025	93.9
4C	10.4	94.7	5.40	7.15	0.056	13.8	137.1	0.178	0.349	0.0027	95.2
AVERAGE			6.79	8.98	0.071			0.209	0.409	0.0032	95.1
5A	10.8	96.8	3.44	4.73	0.037	13.6	143.2	0.168	0.320	0.0027	92.8
5B	10.8	96.8	4.03	5.55	0.043	13.6	143.2	0.173	0.329	0.0027	93.7
5C	10.8	96.8	5.84	8.03	0.062	13.6	143.2	0.163	0.310	0.0026	95.9
AVERAGE			4.43	6.10	0.047			0.168	0.320	0.0027	94.1
6A	10.7	98.9	0.238	0.324	0.003	13.5	141.0	0.154	0.288	0.0024	c
6B	10.7	98.9	1.82	2.48	0.020	13.5	141.0	0.152	0.285	0.0024	88.1
6C	10.7	98.9	2.67	3.64	0.029	13.5	141.0	0.170	0.320	0.0026	90.9
AVERAGE			2.24	3.06	0.024			0.159	0.298	0.0025	89.5
COND. 2 AVG.	10.6	96.8	4.77	6.42	0.050	13.6	140.4	0.178	0.342	0.0028	93.3

a The flow rates determined by the CDD/CDF sampling trains were used for HCl emission rate calculations.

b The results are not reported because the data does not fall within acceptable control limits.

c The removal efficiency is not calculated because both inlet and outlet results are non-detects.

d [] = Not detected at the limit shown; () = Less than five times the detection limit.

e Detection limits are not considered when calculating averages.

less than 0.006 lb/hr to 0.01 lb/hr with an average of 0.01 lb/hr. The HF concentrations exiting the baghouse ranged from less than 0.4 ppmvd at 7 percent O₂ to 3.2 ppmvd at 7 percent O₂ with an average of 2.2 ppmvd at 7 percent O₂. The HF emission rate at the baghouse outlet ranged from less than 0.004 lb/hr to 0.02 lb/hr with an average of 0.016 lb/hr.

For Condition 2, the HF concentration at the spray dryer inlet ranged from less than 0.3 ppmvd at 7 percent O₂ to 14.7 ppmvd at 7 percent O₂ with an average of 6.4 ppmvd at 7 percent O₂. The emission rate of HF entering the spray dryer ranged from less than 0.003 lb/hr to 0.1 lb/hr with an average of 0.05 lb/hr. The HF concentration at the baghouse outlet ranged from less than 0.3 ppmvd at 7 percent O₂ to less than 0.6 ppmvd at 7 percent O₂ with an average of less than 0.34 ppmvd at 7 percent O₂. At the baghouse outlet, the HF emission rate ranged from less than 0.002 lb/hr to less than 0.004 lb/hr with an average of less than 0.003 lb/hr.

A comparison of the emission rates for both conditions at the spray dryer inlet cannot be made because only one detectable value at the inlet is reported. The baghouse outlet emission rates for both conditions are consistent. During Condition 1, HF was not detected in any of the 9 samples. The removal efficiency of the only reported run during Condition 2 ranged from 88.1 to 96.3 percent. With only one valid removal efficiency for Condition 1, it cannot be concluded with confidence that the injection of carbon into the lime slurry improves the HF removal efficiency of the emission control system.

2.6.3 Hydrogen Bromide Results

Table 2-49 summarizes the HBr spray dryer inlet and baghouse outlet concentrations and emission rates, as well as the removal efficiencies for the emission control system. The removal efficiencies could not be calculated for the first six runs for reasons discussed previously.

For Condition 1, the HBr concentration at the spray dryer inlet ranged from 8.4 to 14.4 ppmvd at 7 percent O₂ with an average of 11.0 ppmvd at 7 percent O₂. The HBr emission rate at the spray dryer inlet ranged from 0.28 to 0.47 lb/hr with an average of 0.36 lb/hr. At the baghouse outlet, the HBr concentration ranged from less than 0.042 ppmvd at 7 percent O₂ to 2.01 ppmvd at 7 percent O₂ with an average of

TABLE 2-49. SUMMARY OF HYDROGEN BROMIDE RESULTS
MORRISTOWN MEMORIAL HOSPITAL (1991)

RUN NO.	SPRAYDRYER INLET					BAGHOUSE OUTLET					REMOVAL EFFICIENCY (%)
	O2 CONC. (% VOL.)	FLUE GAS FLOW (dscmm)	GAS CONC. (ppmV)	GAS CONC. (ppmV @7% O2)	EMISSION RATE (lb/hr)	O2 CONC. (% VOL.)	FLUE GAS FLOW (dscmm)	GAS CONC. (ppmV)	GAS CONC. (ppmV @7% O2)	EMISSION RATE (lb/hr)	
1A 1B 1C AVERAGE	11.1	95.4	b	b	b	14.1	135.0	[0.034]	[0.070]	[0.0021]	NA
	11.1	95.4	b	b	b	14.1	135.0	b	b	b	NA
	11.1	95.4	b	b	b	14.1	135.0	b	b	b	NA
			NA	NA	NA			[0.034]	[0.070]	[0.0021]	NA
2A 2B 2C AVERAGE	11.1	98.5	b	b	b	14.1	140.7	[0.023]	[0.048]	[0.0015]	NA
	11.1	98.5	b	b	b	14.1	140.7	[0.020]	[0.042]	[0.0013]	NA
	11.1	98.5	b	b	b	14.1	140.7	0.168	0.343	0.011	NA
			NA	NA	NA			0.168	0.343	0.011	NA
3A 3B 3C AVERAGE	10.6	100.0	10.7	14.4	0.474	13.4	140.4	0.287	0.532	0.018	96.2
	10.6	100.0	7.54	10.2	0.335	13.4	140.4	0.357	0.661	0.022	93.4
	10.6	100.0	6.19	8.36	0.276	13.4	140.4	1.08	2.01	0.068	75.5
			8.13	11.0	0.362			0.576	1.07	0.036	88.3
COND. 1 AVG.	10.9	98.0	8.13	11.0	0.362	13.9	138.7	0.474	0.886	0.030	88.3
4A 4B 4C AVERAGE	10.4	94.7	5.80	7.68	0.244	13.8	137.1	0.348	0.680	0.021	91.3
	10.4	94.7	9.64	12.8	0.406	13.8	137.1	0.277	0.541	0.017	95.8
	10.4	94.7	2.73	3.61	0.115	13.8	137.1	0.256	0.502	0.016	86.4
			6.06	8.02	0.255			0.293	0.574	0.018	91.2
5A 5B 5C AVERAGE	10.8	96.8	9.34	12.8	0.402	13.6	143.2	[0.013]	[0.024]	[0.0008]	> 99.8
	10.8	96.8	7.32	10.1	0.315	13.6	143.2	[0.013]	[0.025]	[0.0008]	> 99.7
	10.8	96.8	2.15	2.96	0.093	13.6	143.2	[0.012]	[0.023]	[0.0008]	> 99.2
			6.27	8.63	0.270			[0.013]	[0.024]	[0.0008]	> 99.6
6A 6B 6C AVERAGE	10.7	98.9	[0.018]	[0.024]	[0.0008]	13.5	141.0	[0.012]	[0.022]	[0.0007]	c
	10.7	98.9	[0.020]	[0.027]	[0.0009]	13.5	141.0	[0.011]	[0.021]	[0.0007]	c
	10.7	98.9	2.70	3.68	0.119	13.5	141.0	[0.013]	[0.024]	[0.0008]	> 99.3
			2.70	3.68	0.119			[0.012]	[0.022]	[0.0007]	> 99.3
COND. 2 AVG.	10.6	96.8	5.67	7.66	0.242	13.6	140.4	0.293	0.574	0.018	95.9

a The flow rates determined by the CDD/CDF sampling trains were used for HCl emission rate calculations.

b The results are not reported because the data is not within acceptable control limits.

c The removal efficiency is not calculated because both inlet and outlet results are non-detectable.

d [] = Not detected at the limit shown; () = Less than five times the detection limit.

e Detection limits are not considered when calculating averages.

0.89 ppmvd at 7 percent O₂. The emission rate of HBr exiting the baghouse ranged from less than 0.0013 lb/hr to 0.068 lb/hr with an average of 0.030 lb/hr.

For Condition 2, the HBr concentration at the spray dryer inlet ranged from less than 0.024 ppmvd at 7 percent O₂ to 12.8 ppmvd at 7 percent O₂ with an average of 7.7 ppmvd at 7 percent O₂. The emission rate of HBr entering the spray dryer ranged from less than 0.0008 lb/hr to 0.41 lb/hr with an average of 0.24 lb/hr. At the baghouse outlet, the concentration of HBr ranged from less than 0.021 ppmvd at 7 percent O₂ to 0.68 ppmvd at 7 percent O₂ with an average of 0.57 ppmvd at 7 percent O₂. The mass emission rate of HBr exiting the baghouse ranged from less than 0.0007 lb/hr to 0.021 lb/hr, averaging 0.018 lb/hr.

At the spray dryer inlet, the results for Conditions 1 and 2 are similar enough not to bias the removal efficiencies between the two conditions. In comparing the results at the baghouse outlet from both conditions, the average HBr emission rates for each condition showed little difference, 0.03 lb/hr for Condition 1 and 0.018 lb/hr for Condition 2. Although the average removal efficiency during carbon injection was 7.6 percentage points higher than the removal efficiency without carbon injection, there is not enough evidence to show that carbon injection actually improves the removal of HBr through the emission control system.

2.7 CEM RESULTS

Continuous emissions monitoring was conducted at the spray dryer inlet and baghouse outlet during all test runs. The CEMs were operated from the beginning to the end of the test run. Monitoring was performed using an extractive sample system and instrument methods to measure NO_x, CO, SO₂, THC, and HCl concentrations. The diluent gases (O₂, CO₂) were measured using CEMs at all times so that emission results could be normalized to a reference 7 percent O₂. Concentrations of NO_x, SO₂, CO, CO₂, and O₂ were measured on a dry basis. The THC concentrations were monitored on a wet basis, by allowing the sample stream to bypass the gas conditioners. All CEM data were recorded as one minute averages over each sampling interval.

Two additional CEM analyzers were used during this program to monitor HCl concentrations at the inlet and outlet. These systems used separate gas extractive

systems employing dilution probe techniques. The resulting concentrations were measured on a ppm by volume, wet basis.

A leak was detected in the inlet sample line for the NO_x , SO_2 , CO, CO_2 , THC, and O_2 analyzers at the end of the second test run. The O_2 values for these two test runs were assumed to be 3 percent lower than the outlet O_2 values. This assumption was based on the average difference between inlet and outlet O_2 values for Runs 3 through 6. The measured values for NO_x , SO_2 , CO, CO_2 , and THC for Runs 1 and 2 were corrected for the leakage using the assumed O_2 averages.

The one minute CEM values were averaged over the sampling interval for each test run. The averages summarized in Tables 2-50 and 2-51 present actual and normalized values, respectively. Actual concentrations are presented as they were measured (NO_x , SO_2 , CO, CO_2 , and O_2 on a dry basis; THC and HCl-wet and dry). Each one minute CEM reading was corrected to 7 percent O_2 based on the corresponding O_2 value. Averages of the corrected values were then calculated.

The SO_2 concentrations decreased from the inlet to the outlet for both test conditions. The average concentrations for Conditions 1 and 2 at the inlet were 10.5 and 17.8 ppmv (at 7 percent O_2) on a dry basis. The outlet concentrations were 9.2 and 3.9 ppmv. The removal was 78 percent for Condition 2 with carbon injection compared to 12.4 percent for Condition 1. The CO concentrations were very low for all runs, showing good combustion efficiency. The measured concentrations were lower at the inlet than at the outlet. Records of the responses of the inlet and outlet CO monitors to QC gases show that the outlet monitor responded with a slightly lower value than the inlet monitor. The actual difference in CO concentrations at these locations, therefore, is probably not significant. CO concentrations were less than 3 ppmv at the outlet for all runs. The CO analyzer used had a scale of 0 to 500 ppm and hence readings near the zero scale might be biased toward the lower end. The CO_2 concentrations (at 7% O_2) were not significantly different between inlet and outlet. The outlet analyzer was off line for Runs 1 and 2. The averages for the 2 test conditions at the inlet and outlet were 9.7, 8.8, 9.9, and 9.9 percent, respectively. The NO_x concentrations (at 7% O_2) were almost the same at the inlet and outlet. The HCl concentrations decreased from the inlet to the outlet and are discussed in more detail in Section 2.6.

Table 2-50

Continuous Emissions Monitoring Test Averages
Morristown Memorial Hospital (1991)

Date	Run Number	O ₂ (%V, dry)	CO (ppmv, dry)	CO ₂ (%V, dry)	SO ₂ (ppmv, dry)	NO _x (ppmv, dry)	H ₂ O (%)	THC (ppmv, wet)	THC (ppmv, dry)	HCl (ppmv, wet)	HCl (ppmv, dry)
Spray Dryer Inlet Data											
11-18-91	1	11.1	15.5	6.4	5.9	60.3	15.9	3.9	4.6	663.1	788.5
11-19-91	2	11.1	8.5	7.8	9.5	57.0	15.5	2.5	3.0	498.1	589.5
11-20-91	3	10.6	7.1	6.7	7.1	65.2	14.9	1.2	1.4	524.9	616.8
Condition 1 Avg		10.93	10.37	6.97	7.5	60.83	15.4	2.53	3.0	562.0	664.3
11-21-91	4	10.4	6.4	6.6	17.8	63.5	14.7	2.8	3.3	673.0	788.9
11-22-91	5	10.8	8.7	6.5	16.0	61.3	13.9	2.5	2.9	586.0	680.6
11-23-91	6	10.7	4.7	6.5	6.0	58.6	14.0	0.5	0.6	593.1	689.7
Condition 2 Avg		10.63	6.6	6.53	13.27	61.13	14.2	1.93	2.3	617.4	719.6
Baghouse Outlet Data											
11-18-91	1	14.1	1.0	^a	2.6	49.6	14.6	1.1	1.3	9.2	10.8
11-19-91	2	14.1	0.3	^a	9.3	45.7	13.8	0.7	0.8	8.5	9.9
11-20-91	3	13.4	0.5	5.3	1.7	47.5	14.7	0.9	1.1	3.7	4.3
Condition 1 Avg		13.87	0.6	5.3	4.53	47.6	14.4	0.9	1.1	7.13	8.3
11-21-91	4	13.8	0.1	5.2	2.8	47.1	14.8	1.2	1.4	10.5	12.3
11-22-91	5	13.6	1.5	5.0	2.6	45.6	13.4	1.2	1.4	5.6	6.5
11-23-91	6	13.5	0.6	5.3	0.6	46.4	13.0	1.1	1.3	4.0	4.6
Condition 2 Avg		13.63	0.73	5.17	2.0	46.4	13.7	1.17	1.4	6.7	7.8

^aInstrument off line.

Note: Data for 11/18/91 and 11/19/91 were corrected for inletage.

O₂ was made to be 3 percent lower than the outlet O₂ (3 percent is the average difference in inlet and outlet O₂ for 11/19 through 11/23/91). CO, CO₂, SO₂, NO_x, and THC were corrected for the new O₂ level.

Table 2-51

Continuous Emissions Monitoring Test Averages
Normalized to 7 Percent Oxygen
Morristown Memorial Hospital (1991)

Concentration, ppmv, dry at 7% O ₂							
Date	Run Number	CO	CO ₂	SO ₂	NO _x	THC	HCl
Spray Dryer Inlet Data							
11-18-91	1	21.9	9.0	8.4	85.2	6.5	1118.4
11-19-91	2	12.0	11.0	13.5	81.1	4.3	836.1
11-20-91	3	9.7	9.1	9.6	88.4	1.9	832.4
Condition 1 Avg.		14.5	9.7	10.5	84.9	4.2	926.2
11-21-91	4	8.4	8.7	23.4	83.7	4.4	1044.4
11-22-91	5	11.9	9.0	22.0	84.4	4.0	936.7
11-23-91	6	6.4	8.8	8.1	79.6	0.8	939.9
Condition 2 Avg		8.9	8.8	17.8	82.6	3.1	973.9
Baghouse Outlet Data							
11-18-91	1	2.0	a	5.2	101.0	2.7	22.1
11-19-91	2	0.6	a	19.1	93.9	1.6	20.2
11-20-91	3	0.9	9.9	3.2	88.2	2.0	7.9
Condition 1 Avg		1.2	9.9	9.2	94.4	2.2	16.4
11-21-91	4	0.2	10.3	5.5	92.7	2.7	24.1
11-22-91	5	2.9	9.6	5.1	87.4	2.7	12.4
11-23-91	6	1.2	10.0	1.2	87.8	2.4	8.6
Condition 2 Avg		1.4	9.9	3.9	89.3	2.7	14.9

^aInstrument off line.

Note: Data for 11/18/91 and 11/19/91 were corrected for inleakage.

O₂ was made to be 3 percent lower than the outlet O₂ (3 percent is the average difference in inlet and outlet O₂ for 11/19 through 11/23/91). CO, CO₂, SO₂, NO_x, and THC were corrected for the new O₂ level.

2.8 MICROBIAL SURVIVABILITY RESULTS

This section provides the background and test matrix for microbial survivability testing and presents the test results for microbial survivability in emissions, in ash, and in ash pipes.

2.8.1 Background and Test Matrix

One of the objectives of this test program was to further develop testing methods to determine microbial survivability in incinerator processes. As part of the MWI test program at Morristown Memorial, testing was conducted to determine microbial survivability based on a surrogate indicator organism that was spiked into the incinerator feed during test Runs 1, 2, and 3. The surrogate indicator organism was the soil spore Bacillus stearothermophilus (B. stearothermophilus). This organism was chosen because it survives at high temperatures and it is easy to culture and identify. Also, it is non-pathogenic and is not commonly found in medical waste streams.

Two types of testing were performed. The purpose of the first test method was to determine microbial survivability in the combustion gases (emissions) and the bottom ash, spray dryer residue, and baghouse ash. For these tests, a known quantity of B. stearothermophilus in solution was absorbed onto materials commonly found in the medical waste stream and introduced into the incinerator at regular intervals during each run. Emissions testing was conducted at the incinerator exit upstream of the air pollution control system following the EPA draft method "Microbial Survivability Test for Medical Waste Incinerator Emissions." This testing was performed concurrently with other emissions testing (PM/Metals, CDD/CDF, halogens, and CEMs) during the burn periods. Ash samples were taken following each test run after the ash was cool enough to handle. The ash was sampled and analyzed as described in the EPA Draft Method "Microbial Survivability Test for Medical Waste Incinerator Ash."

The second Microbial Survivability test method utilized freeze dried spores encapsulated in metal pipes which were insulated with high temperature ceramic insulation and wrapped in wire mesh. This test was used to aid in the assessment of microbial survivability in the ash. Each pipe sample also contained five temperature indicating pellets. The pellets were selected to melt at specific temperatures between

400°F and 1200°F. They were used to record the maximum sample temperature reached in the incinerator.

Complete details of the microbial spiking, recovery and analysis procedures are given in Section 5.3.

Three test runs were performed at the rated incinerator operating conditions over a period of three days. At the start of each four-hour test run, liquid spores were poured into a plastic garbage bag containing absorbent materials and two dry spore pipe samples. The bag was then charged into the incinerator with the normal waste stream. This procedure was repeated each hour during the test, until a total of four bags of wet spores and eight dry spore pipe samples had been charged into the incinerator. A final dry spore pipe sample was charged into the incinerator at the end of the fourth testing hour, bringing the total number of pipe samples per test to nine.

Table 2-52 summarizes the spore spiking times, the total weight fed to the incinerator, and the total ash weights generated during each test run.

2.8.2 Overall Microbial Survivability

By comparing the number of spores spiked to the incinerator with the number of viable spores exiting in both the stack gas and incinerator ash, an overall microbial survivability value can be determined as follows:

$$MS = \left(\frac{S_e + A_e}{S_s} \right) \times 100$$

MS	=	spore microbial survivability (wet)
S_e	=	Number of viable spores detected exiting the stack
A_e	=	Number of viable spores detected in the incinerator ash
S_s	=	Number of viable spores spiked in the waste feed

This is an adaptation of the destruction efficiency (DE) calculation presented in the reference test protocol which calculates DE based only on stack emissions and a separate DE based on spores in ash. By combining the two DE estimates, a more complete estimate of Microbial Survivability (1 - DE) is obtained. The total number of spores in the ash was calculated by multiplying the number of spores found in 1 gram of ash by

Table 2-52
Summary of Incinerator Feed and Ash Generation
Morristown Memorial Hospital (1991)

Test Day	Date	Run Number	Time	Wet Spore ^a Samples	Dry (Pipe) Spore ^b Samples	Total Waste Feed (lbs)	Total Ash Weight (lbs)		
							Bottom	Spray Dryer	Baghouse
1	11/18/91	1	1408	1	2				
			1506	1	2				
			1601	1	2		325	17	185
			1703	1	2				
			1803	0	1				
2	11/19/91	2	1552	1	2				
			1700	1	2				
			1756	1	2		256	15	122
			1851	1	2				
			1958	0	1				
3	11/20/91	3	1234	1	2				
			1331	1	2				
			1431	1	2		404	98	215 ^c
			1648	1	2				
			2155	0	1				

^a Each wet spore sample contained approximately 3.5×10^{11} spores in 500 ml of solution.

^b Each dry spore contained approximately 1×10^7 freeze-dried spores.

^c Filter cake was removed during run on 11/20/91. Total ash dropped was 859 lbs in 1.5 hours. The 215 lbs shown in the table does not included any of the ash from cake removal.

the total weight of ash removed from the incinerator per day. The analytical results are shown in Appendix E.3.

Table 2-53 presents the overall survivability of the indicator spores. No viable spores were found either in the stack gas samples or in the incinerator ash. Flue gas microbial survivability are further discussed in the following sections.

2.8.3 Microbial Survivability in Emissions

Microbial Survivability in emissions tests were conducted to quantify the number of viable spores exiting the stack during each test run. The formulas normally used for calculating the number of viable spores existing in the stack, S_e are shown in Appendix F, and in the EPA draft method in Appendix K.

Approximately 1.5 liters of impinger collection solution was generated for each run. These run samples were recovered in a disinfected mobile laboratory, sealed, and sent to the analytical laboratory.

For each run performed, 9 aliquots were prepared for analysis: three 10 ml aliquots, three 100 ml aliquots, and 3 equal aliquots of a remaining filterable amount of sample. Both a first and second count on each aliquot were performed. The first count was conducted after approximately 24 hours incubation, and the second after approximately a 48 hour incubation period. Previous research has shown that the spore count does not increase after the 48-hour count incubation period. No viable spores were seen in any of the run samples after the 48-hour incubation period.

The Microbial Survivability sampling and flue gas parameters are shown in Table 2-54.

2.8.4 Microbial Survivability in Ash

Incinerator bottom ash was removed from the incinerator after each run and stored in a pre-cleaned, disinfected covered steel hopper. A composite ash sample was prepared by first removing large pieces of metal and glass from the hopper, then mixing the remaining ash and placing samples into clean, amber glass sample bottles. Spray dryer ash and baghouse ash were similarly composited into bottles after each run. The composite samples were then submitted to the laboratory for culturing, and enumeration of B. stearothermophilus.

Table 2-53

Overall Microbial Survivability
Morristown Memorial Hospital (1991)

Test Day	Date	Run Number	Number of Indicator Spores Spiked	Number Indicator Spores Exiting the Stack	Number of Indicator Spores in Ash	Spore Survivability (%)
1	11/18/91	1	14 x 10E11	0	0	100
2	11/19/91	2	14 x 10E11	0	0	0
3	11/20/91	3	14 x 10E11	0	0	0

TABLE 2-54. SUMMARY OF FLUE GAS SAMPLING PARAMETERS
FOR INDICATOR SPORE EMISSIONS
MORRISTOWN MEMORIAL HOSPITAL (1991)

	Run 1	Run 2	Run 3	Average
Total Sample Time (min)	231	240	151	207
Average Sampling Rate (dscfm)	0.61	0.58	0.61	0.60
Dry Standard Meter Volume (dscf)	140	140	91.4	123.8
Dry Standard Meter Volume (dscm)	3.96	3.96	2.59	3.50
Average Stack Temperature (F)	413	411	410	411
Oxygen Concentration (% V)	11.1	11.1	10.6	10.9
Carbon Dioxide Concentration (% V)	6.4	7.8	6.7	7.0
Percent Moisture (% V)	15.9	15.5	14.9	15.4
Volumetric Flow Rate (dscfm)	3512	3414	3617	3514
Volumetric Flow Rate (dscmm)	99.5	96.7	102	99.4
Percent Isokinetic (%)	96.6	95.7	93.8	NA

NA : Not applicable

No viable spores were found in any ash sample from the Morristown MWI tests. Three ash aliquots of approximately one gram were prepared from each sample. Six serial dilutions were prepared on each ash aliquot and triple plated. A summary of the analytical data is shown in Appendix E.3.

2.8.5 Microbial Survivability in Pipes

Pipe samples were loaded into the incinerator during each test run. The pipes were recovered the following morning during bottom ash sampling. Approximately half of the samples charged into the incinerator were recovered. The rest were lost, probably after becoming imbedded in the masses of molten glass which roll through the incinerator. Pipe samples which were recovered were removed from their insulating wrappings. The condition of the temperature indicating pellets was noted and the inner containers were sent to the laboratory for analysis. The analysis results from the recovered pipes are shown in Table 2-55.

Table 2-55

Spore Pipe Sample Recovery and Analysis Results

Run Number	Date	Sample Number	Charge Time	Sample Recovery	Maximum Temp.	Spores Cultured
1	11/18/91	10	1408	Yes	< 1200	0
1	11/18/91	11	1408	Yes	< 1000	0
1	11/18/91	12	1506	Yes	^a	0
1	11/18/91	13	1506	Yes	> 1200	0
1	11/18/91	14	1601	Yes	> 1200	0
1	11/18/91	16	1601	Yes	> 1200	0
1	11/18/91	17	1703	No	> 1200	--
1	11/18/91	18	1703	No	^d	--
1	11/18/91	19	1803	Yes	> 1200	0
2	11/19/91	20	1552	No	^d	--
2	11/19/91	21	1552	Yes	< 1200	0
2	11/19/91	22	1700	No	^d	--
2	11/19/91	23	1700	No	^d	--
2	11/19/91	24	1756	No	^d	--
2	11/19/91	26	1756	No	^d	--
2	11/19/91	27	1851	No	^d	--
2	11/19/91	28	1851	No	^d	--
2	11/19/91	29	1958	No	^d	--
3	11/20/91	30	1234	Yes	^d	0
3	11/20/91	31	1234	Yes ^c	^d	0
3	11/20/91	32	1331	Yes	^d	0
3	11/20/91	33	1331	No	^d	--
3	11/20/91	34	1431	No	^d	--
3	11/20/91	36	1431	Yes	> 1200	0
3	11/20/91	37	1648	No	^d	--
3	11/20/91	38	1648	Yes	^d	0

Table 2-55 (Continued)

Run Number	Date	Sample Number	Charge Time	Sample Recovery	Maximum Temp.	Spores Cultured
3	11/20/91	39	2155	No	^d	--
1	11/18/91	71 ^a	1631	Yes	> 1200	1
3	11/20/91	72 ^a	2120	Yes	> 1200	0
--	--	81 ^b	--	Yes	ambient	TNTC ^c
--	--	82 ^b	--	Yes	ambient	TNTC

^a Pipe samples 71 and 71 were empty sample blanks.

^b Pipe samples 81 and 82 were field blank control samples, which were not charged into the incinerator.

^c One sample was recovered from Run 3 without the sample identification tag. It was arbitrarily identified as No. 31.

^d Temperature pellets not recovered.

^e TNTC = to numerous to count.