

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

MWI TEST REPORTS: Answer as many as you can easily.

OK
3/1
Reference

1. Test report number 18

2. Facility name, location Bio-Medical Service Corp.
Lake City, GA

3. Design charging rate

4. Air pollution control device wet scrubber only

5. Test conducted by Russell Barton and Chris Roseberry
Air Techniques, Inc.
Marietta, GA

6. Date tested May 8, 1989

7. Pollutants tested particulates, HCl

8. Controlled and uncontrolled for which pollutants (just put all if applicable)?
-not indicated

9. Test methods used (if not EPA or CARB, note)

(EPA Method 1, EPA Method 2, Method 3 for flows and weights & sample points)
⇒ GA EPD Method 5T and 200 were combined for
particulate and HCl concentrations

10. Data quality rating, reason

B - Georgia Method was used

11. Reason for excluding test report

12. other - * waste composition not indicated

18.

Ref 31

COMPLIANCE EMISSION TESTING
FOR
PARTICULATE AND HYDROGEN CHLORIDE
AT
BIO-MEDICAL SERVICE CORPORATION
LAKE CITY, GEORGIA
MAY 8, 1989

AIR TECHNIQUES

1724 Nekoma Street, NE • Marietta, Georgia 30067 • 404.977-7090

Compliance Emission Testing

for

Particulate and Hydrogen Chloride

at


Bio-Medical Service Corporation

Lake City, Georgia

Test Date: May 8, 1989

Submitted by:

Air Techniques, Inc.
1724 Nekoma Street
Marietta, GA 30067



Bill Timpona, BSME
Technical Director



Russell Barton,
Testing Manager

TABLE OF CONTENTS

	<u>Page No.</u>
I. Introduction	1
II. Summary of Results	2
III. Test Methods and Sampling Procedures	3-7
Process Description	8
Process Schematic	9

Appendix

Summary of Results
Laboratory Data
Particulate Data
Chain of Custody
Test Calculations
Field Data Sheets
Process Data
Sample Train Schematic
Calibration Data
Nomenclature

I. Introduction

Compliance particulate and hydrogen chloride emissions testing was performed on the pathological waste incinerator exhaust at Bio-Medical Service Corporation, Lake City, Georgia. The purpose of the testing was to determine if particulate and HCL emissions comply with standards set forth by the Georgia Environmental Protection Division. Three, eighty minute test repetitions were performed on the incinerator.

The testing was performed on May 8, 1989 by Russell Barton and Chris Roseberry of Air Techniques, Inc., Marietta, Georgia.

Air Techniques would like to extend its appreciation to Mr. Larry Holloway and his associates at Bio-Medical Service Corporation for their assistance throughout the test program.

IV. Summary of Results and Conclusion

The complete summary of test results is shown in tabular form in the Appendix. Below is shown the particulate emission rate and HCl emission rate, expressed in pounds per hundred pounds of incinerator charge, and pounds per hour, respectively. Also shown is the incinerator charge rate in hundred pounds per hour.

<u>Test No.</u>	<u>Particulate Emission Rate (lb/100 lb)</u>	<u>HCl Emission Rate (lb/hr)</u>	<u>Charge Rate (100 lb/hr)</u>
1	0.08	0.04	10.54
2	0.06	0.03	10.54
3	0.08	0.04	10.54
Average	0.07	0.04	10.54

The allowable particulate emission rate as specified by the Georgia Department of Natural Resources is 0.20 pounds per hundred pounds of incinerator charge. The allowable HCl emission rate is 12.0 pounds per hour.

Due to the variation in stack gas moisture content, difficulty was encountered maintaining the proper sampling rate. Any resulting bias to the test results should be less than ten percent. However, the test results are the same for both the highest and lowest sampling rates so that no bias is felt to be present.

III. Test Methods and Sampling Procedures

The sampling train used for execution of the testing was manufactured by GII Enterprises, a division of Andersen Samplers, Atlanta, Georgia. The train meets all specifications as outlined by the U.S. Environmental Protection Agency.

As specified in the various test methods, all necessary calibrations on the dry gas meter, orifice, thermocouples, digital thermometer, sampling tip, pitot tubes, aneroid barometer, and analytical balance were performed. Included in the Appendix are the results of the calibrations.

The number of sample points and the sampling location were determined according to EPA Method 1. The test location and nearest disturbances (upstream and downstream) from the test site can be found in detail on the preliminary sample traverse data sheet in the Appendix.

EPA Method 2 was used to determine stack gas velocity and volumetric flow rate. An S- type pitot tube was used in conjunction with an inclined oil gauge manometer. After each test repetition, a leak check was performed on the pitot manometer assembly and indicated no leak for 15 seconds.

Dry molecular weight was determined according to EPA method 3 during each repetition by fyrite analysis of grab gas samples. The results of these analyses are reported on the field data sheets in the Appendix.

Georgia EPD Method 5T and 200 were combined to determine particulate and HCL concentrations. The sampling train consisted of a calibrated nozzle, probe with heated liner, glass fiber filter and filter holder, five impingers, 50' umbilical cord, pump, dry gas meter, and orifice. A detailed schematic of the train can be found in the Appendix.

Before each test, the probe and filter holder assembly were secured in the filter box. In each of first two impingers was placed 100 milliliters of deionized, chlorine demand free water. 100 milliliters of 0.1 N Potassium Hydroxide solution was loaded in each of the third and fourth impingers, and the fifth impinger was loaded with 200.0 g. of silica gel. Before each repetition, an optional leak check was performed to ensure all connections were secure.

After the probe and filter heaters warmed up to the specified operating temperature, the probe was inserted into the stack at the first sample traverse point. The stack gas parameters were recorded on the field data sheet, the pump turned on, and the sampling rate set at the isokinetic rate. At the end of the sampling period for the first point, the probe was moved to the next traverse point, and the sampling rate adjusted to maintain the isokinetic rate for the measured gas parameters at that point. This procedure was followed until all of the traverse points had been sampled. At each point, the following information was measured and recorded on the field

data sheet: dry gas meter volume, stack gas velocity pressure differential, orifice meter pressure differential, stack gas temperature, sample train filtration temperature, impinger train exit temperature, dry gas meter inlet and outlet temperature, and sample train system vacuum. After all of the points had been sampled, the pump was turned off and the probe removed from the stack.

Immediately following each repetition, a leak check was performed on the sample train and indicated less than the allowable 0.02 CFM. The train was then disassembled. The filter holder was first removed and immediately sealed to ensure no particulate matter was lost. Both ends of the probe assembly were sealed to ensure no particulate matter was lost from that component. The moisture catch from impingers one, two, three, and four was measured with a graduated cylinder, then placed in labeled containers. Impingers one and two and the connecting glassware were rinsed with acetone. The acetone wash was placed in a separate container. Impingers three and four were rinsed with distilled water and the rinse added to the appropriate containers. The silica gel from the fifth impinger was returned to its container and sealed.

The probe and nozzle were removed from the test site for cleaning. The nozzle, union, and probe liner were brushed and rinsed with reagent grade acetone until all particulate matter was removed. The acetone wash was placed in a labeled

polyethylene container.

After the test was completed, the sealed filter holder assembly was returned to the laboratory. The filter was removed from the holder assembly in a controlled environment to ensure that no particulate matter was lost during the recovery process. The filter was placed in a labeled container and desiccated for a minimum of 24 hours, then weighed to a constant weight. The front half of the filter holder assembly was rinsed with acetone and the wash was added to the labeled probe wash container of the same repetition. If any filter fibers remained on the holder gasket, they were carefully removed and also added to the probe wash container. The back half of the filter holder was rinsed with distilled water and the wash added to the appropriate impinger wash container. A sample of the acetone used for cleanup was saved as a blank in a separate container labeled "Acetone Blank". Likewise, a sample of the distilled water and the potassium hydroxide were saved as blanks.

After the test, the sample containers from each test repetition, along with the blanks, were returned to the laboratory. The contents of each probe wash bottle were transferred to tared beakers. The containers were then rinsed with acetone to ensure that all of the particulate matter was recovered. The volume of the acetone was recorded and then evaporated by placing the beakers on a low temperature steam bath. The evaporation was closely supervised to prevent

"bumping" and subsequent loss of the sample. Each beaker, with residue, was desiccated and weighed to the nearest 0.1 milligram.

The impinger catch was split for separate analyses. A 30 milliliter aliquot was taken for HCl analysis from the combined sample of impingers one and two. These aliquots, the potassium hydroxide solutions from impingers three and four, and the water and potassium hydroxide blanks were sent to Galbraith Laboratories, Knoxville, Tennessee. The amount of HCl in the samples and blanks was determined by ion chromatography for the chloride ion.

The organics in the water from impingers one and two were extracted with three, 25 milliliter portions of chloroform followed by three, 25 milliliter portions of ether. The extraction was placed in a tared beaker, evaporated, and weighed to a constant weight. After extraction, the impinger water was placed in a tared beaker, evaporated, and weighed to a constant weight.

The pre-weighed silica gel samples were returned to the laboratory in their original containers. The samples were weighed to the nearest 0.5 gram.

Process Description

The waste incinerator process is operated as a continuous waste feed combustion chamber with a continuous wet ash discharge system. The waste is combusted in a primary chamber and then a secondary chamber. The exhaust gases exiting the secondary chamber are drawn through a wet scrubber system consisting of a caustic and water quench chamber, venturi, and a packed separator. The gases exit through an I.D. fan into the atmosphere.

EXHAUST GAS
FROM INCUBATOR

SAMPLING LOCATION

VENTURI

BAFFLE QUENCH
W/ ONE SPRAY NOZZLE
FIVE BAFFLES

PACKED COLUMN
TELLEFRETTE PACKING
CHEVRON TYPE DEMISTER

ID. FAN

48" STACK
30" DIAMETER



AIR TECHNIQUES INC.

BIO-MEDICAL SERVICE
SLUBBER SYSTEM
LAKE CITY, GA.

APPENDIX

SUMMARY OF TEST RESULTS
Bio Medical Services
Scrubber Stack
May 8, 1989
Particulate

	Test # 1	Test # 2	Test # 3
Sample Volume (Vm):	28.192	37.136	42.562
Sqrt Delta P:	0.243	0.216	0.238
Sampling Time (min):	80	80	80
Barometric Pressure (Pb):	29.12	28.45	28.30
Delta H (H):	0.56	0.79	0.95
Volume in Impingers (mls):	232.0	135.5	299.5
Static Pressure (in. wc.):	-0.1	-0.1	-0.1
Stack Pressure (Ps):	29.11	28.44	28.30
Stack Temperature (Ts):	160	136	152
Meter Coefficient (Y):	1.022	1.022	1.022
Pitot Coefficient (Cp):	0.840	0.840	0.840
Meter Temperature (Tm):	86	101	110
Area Stack (As):	4.91	4.91	4.91
Area Nozzle (An):	0.000763	0.000763	0.000763
Percent CO2 (%):	4.0	5.0	4.0
Percent O2 (%):	15.0	14.0	15.0
Percent N2 (%):	81.0	81.0	81.0
Condensibles:	16.6	15.7	19.0
NonCondensibles:	45.4	42.8	69.4
Milligrams:	62.0	58.5	88.4
Molecular Weight Dry (Md):	29.24	29.36	29.24
Volume Water (Vwstd):	10.92	6.38	14.10
Volume Gas Sampled (Vmstd):	27.145	34.021	38.190
Wet Fraction (Bws):	0.287	0.158	0.270
Molecular Weight Wet (Ms):	26.02	27.57	26.21
Volume Gas Sampled (Vma):	45.936	47.970	64.086
Stack Gas Velocity, (Vs):	15.79	13.52	15.53
Volumetric Flowrate (Qs):	2,749	2,826	2,726
Volumetric Flowrate (Qa):	4,651	3,984	4,574
Grainloading, gr/dscf (cs):	0.0352	0.0265	0.0357
Grainloading, gr/ACF (csi):	0.0208	0.0188	0.0213
Emission Rate, #/Hour:	0.83	0.64	0.83
Percent Isokinetic Sampling:	79.50	96.92	112.79
Charge Rate, #/Hr:	1054	1054	1054
Emission Rate, #/100 # Charge:	0.0788	0.0610	0.0792

SUMMARY OF TEST RESULTS
Bio Medical Services
Scrubber Stack
May 8, 1989
HCL

	Test # 1	Test # 2	Test # 3
Sample Volume (Vm):	28.192	37.136	42.562
Sqrt Delta P:	0.243	0.216	0.238
Sampling Time (min):	80	80	80
Barometric Pressure (Pb):	29.12	28.45	28.30
Delta H (H):	0.56	0.79	0.95
Volume in Impingers (mls):	232.0	135.5	299.5
Static Pressure (in. wc.):	-0.1	-0.1	-0.1
Stack Pressure (Ps):	29.11	28.44	28.30
Stack Temperature (Ts):	160	136	152
Meter Coefficient (Y):	1.022	1.022	1.022
Pitot Coefficient (Cp):	0.840	0.840	0.840
Meter Temperature (Tm):	86	101	110
Area Stack (As):	4.91	4.91	4.91
Area Nozzle (An):	0.000763	0.000763	0.000763
Percent CO2 (%):	4.0	5.0	4.0
Percent O2 (%):	15.0	14.0	15.0
Percent N2 (%):	81.0	81.0	81.0
Milligrams:	2.9	2.4	4.1
Molecular Weight Dry (Md):	29.24	29.36	29.24
Volume Water (Vwstd):	10.92	6.38	14.10
Volume Gas Sampled (Vmstd):	27.145	34.021	38.190
Wet Fraction (Bws):	0.287	0.158	0.270
Molecular Weight Wet (Ms):	26.02	27.57	26.21
Volume Gas Sampled (Vma):	45.936	47.970	64.086
Stack Gas Velocity, (Vs):	15.79	13.52	15.53
Volumetric Flowrate (Qs):	2,749	2,826	2,726
Volumetric Flowrate (Qa):	4,651	3,984	4,574
Grainloading, gr/dscf (cs):	0.0016	0.0011	0.0017
Grainloading, gr/ACF (csi):	0.0010	0.0008	0.0010
Emission Rate, #/Hour:	0.04	0.03	0.04
Percent Isokinetic Sampling:	79.50	96.92	112.79
Charge Rate, #/Hr:	1054	1054	1054

TOTAL PARTICULATE MATTER COLLECTED

CLIENT: Bio-Medical Services DATE: 5-8-89

SOURCE: Incinerator Scrubber RUN #: 1-3

Acetone Blank Concentration (Equal to or less than 0.01 mg/g):

Ma = 0.8 mg Va = 250 Pa = .786

Ca = Ma / (Va * Pa) Ca = 0.004

Test # 1

Test # 2

Test # 3

Acetone Wash Blank:

Vaw = 200 ml 205 ml 225 ml

Wa = Ca * Vaw * Pa

Wa = 0.6 mg 0.6 mg 0.7 mg

Particulate Matter Collected in Acetone Wash:

Wf = 125.5575 g 126.7543 g 127.2757 g

Wi = 125.5459 g 126.7479 g 127.2597 g

Maw = 1000 (Wf - Wi) - Wa

Maw = 11.0 mg 9.8 mg 15.3 mg

Particulate Matter Collected on the Filter:

Wf = 0.3703 g 0.3680 g 0.3370 g

Wi = 0.3359 g 0.3350 g 0.3329 g

Mf = 1000 (Wf - Wi)

Mf = 34.4 mg 33.0 mg 54.1 mg

Total Particulate Matter Collected (Mn = Maw + Mf):

Mn = 45.4 mg 42.8 mg 69.4 mg

TOTAL WET CATCH PARTICULATE MATTER COLLECTED

CLIENT: Bio-Medical Services

DATE: 5-8-89

SOURCE: Incinerator Scrubber

RUN #: 1-3

Test # 1

Test # 2

Test # 3

Organic particulate matter extracted from impinger catch:

Wf = 125.5098 g 127.5000 g 126.3992 g

Wi = 125.5126 g 127.4985 g 126.3965 g

Mx = $1000 * (Wf - Wi)$

Mx = 2.8 mg 1.5 mg 2.7 mg

Total Particulate matter in impinger water after extraction:

WF = 132.8312 g 127.0257 g 130.6233 g

Wi = 132.8247 g 127.0180 g 130.6148 g

Mix = $1000 * (Wf - Wi)$

Mix = 6.5 mg 7.7 mg 8.5 mg

Total particulate matter collected in impinger acetone wash:

Wf = 131.4391 g 137.8780 g 123.0980 g

Wi = 131.4329 g 137.8728 g 123.0913 g

Mac = $1000 * (Wf - Wi)$

Mac = 6.2 mg 5.2 mg 6.7 mg

Total particulate matter collected in wet catch (Mx + Mix + Mac)

Mn = 15.5 mg 14.4 mg 17.9 mg

0.036 mg/ml 0.043 mg/ml 0.036 mg/ml

x 30 ml x 30 ml x 30

= 1.1 mg = 1.3 = 1.1

Total: 16.6 = 15.7 19.0

W. GALBRAITH, PH.D.
CHAIRMAN OF THE BOARD

KENNETH S. WOODS
PRESIDENT

GAIL R. HUTCHENS
EXECUTIVE VICE-PRESIDENT

VELMA M. RUSSELL
SECRETARY/TREASURER

GALBRAITH

Laboratories, Inc.

QUANTITATIVE MICROANALYSES

ORGANIC - INORGANIC

615/546-1335

2323 SYCAMORE DR.
KNOXVILLE, TN 37921-1750

P.O. BOX 51610
KNOXVILLE, TN 37950-1610

Mr. Russell Barton
Air Techniques, Inc.
1724 Nekoma Street
Marietta, Georgia 30067

May 15, 1989

Received: May 10th

Dear Mr. Barton:

Analysis of your compounds gave the following results:

Your #, Our #, mg/liter Chloride,

1 F-6461 5

2 F-6462 5

3 F-6463 7

1-3 F-6464 2

2-3 F-6465 2

3-3 F-6466 2

1-4 F-6467 2

2-4 F-6468 2


3-4 F-6469 2

1N KOH Blank F-6470 4

COF H₂O Blank 5-8-89
 F-6471 3

This is confirming our telephone call of May 15, 1989.

Sincerely yours,
GALBRAITH LABORATORIES, INC.


Gail R. Hutchens, Exec. Vice-President

AND SHIPMENTS BY U.S. MAIL - P.O. BOX 51610, KNOXVILLE, TN 37950-1610. OTHER CARRIERS - 2323 SYCAMORE DR. KNOXVILLE, TN 37921-1750

GRH:ph

ESTABLISHED 1950

SAMPLE ANALYSIS

Company: Bio-Med

Source: Incinerator Scrubber

Test Date: 5-8-89

Beaker No.	Test No.	Analysis	Date	
			Tare	Final
194	1	Probe Wash	5/1	5/17
176	2	"	5/5	5/17
191	3	"	5/5	5/17
172	1	Imp. Rinse	5/5	5/17
105	2	"	5/5	5/17
210	3	"	5/25	5/17

FILTERS

Filter No.	Test No.	Analysis	Tare	Final
2130	1	Gravimetric	4/14	5/17
2129	2	"	"	"
2128	3	"	"	"

SAMPLE ANALYSIS

Company: Bio-med

Source: Incinerator Scrubber

Test Date: 5-3-89

Beaker No.	Test No.	Analysis	Tare	Date	Final
193	1	Ether- Extraction	5/5	5/17	
174	2	"	5/5	5/17	
201	3	"	5/5	5/17	
165	1	Imp. Catch	5/5	5/17	
183	2	"	5/11	5/17	
156	3	"	5/11	5/17	
163		Acet. Blank	5/5	5/17	

FILTERS

[illegible]

DESIGN NOTES

Bio-Medical Services

5-8-89

Sample #

Total mls

1

460/30

2

365/30

3

519/30

1-3

108

1-4

122

2-3

107

2-4

120

3-3

107

3-4

100

JOB NO.	DATE	SUBJECT	☐ PURCHASE ORDER
TO:			☐ MEMO
FROM:			☐

CHAIN OF CUSTODY FORM

Plant: Res-Med Source: Incinerator Scrubber
 Date Sampled: 5-8-89 Run Number: 1-3

SAMPLE RECOVERY

Container Identification	Sample Description
<u>.01 N KOH Test 1 Imp 3</u>	<u>.01 Normal Potassium Hydroxide</u>
<u>" Test 1 Imp 4</u>	<u>"</u>
<u>" Test 2 Imp 3</u>	<u>"</u>
<u>" Test 2 Imp 4</u>	<u>"</u>
<u>" Test 3 Imp 3</u>	<u>"</u>
<u>" Test 3 Imp 4</u>	<u>"</u>
<u>H₂O Catch Test 1</u>	<u>CDE water</u>
<u>" Test 2</u>	<u>"</u>
<u>" Test 3</u>	<u>"</u>

Sample Recovery Person:

Signature and Title: Russell Banta

Recovery Location Wash: Test Site

Filter: ATJ LAB

Date and Time of Recovery Wash: Aft- each Run

Filter: 5-9-89 Am

Laboratory Person Receiving Sample:

Signature: Russell Banta

Date and Time of Receipt: 5-9-89 Am

Sample Storage: ATJ LAB

CHAIN OF CUSTODY FORM

Plant: Bio-Med Source: Incinerator Scrubber
Date Sampled: 5-9-89 Run Number: 1-3

SAMPLE RECOVERY

Container Identification

Sample Description

Probe Wash Test 1
" Test 2
" Test 3
Acetone Blank
Filter Test 1
" Test 2
" Test 3
H₂O Blank
0.1 N KOH

Acetone Wash
"
"
"
"

Sample Recovery Person:

Signature and Title: Russell Barton

Recovery Location Wash: Test Site

Filter: ATZ LAB

Date and Time of Recovery Wash: After each Run

Filter: 5-9-89 AM

Laboratory Person Receiving Sample:

Signature: Russell Barton

Date and Time of Receipt: 5-9-89 AM

Sample Storage: ATZ LAB

AIR TECHNIQUES INC.

1724 Nekoma Street, NE • Marietta, Georgia 30067 • 404/977-7090

E 6461-71

MAY 10 1989

CHAIN OF CUSTODY FORM

Plant: Bio-Medical Services

Source: Incinerator

Date Sampled: 5-8-89

Run Number: 1-3

SAMPLE RECOVERY

Container Identification

Sample Description

Sample 1 H₂O

H₂O Catch 30 ml aliquot.

Sample 2 H₂O

"

Sample 3 H₂O

"

Sample 1-3

.1N KOH Catch

Sample 2-3

: : "

Sample 3-3

"

Sample 1-4

.1N KOH Catch

Sample 2-4

"

Sample 3-4

"

Blank

H₂O + .1N KOH

Sample Recovery Person:

Signature and Title: Ronald Burt

Recovery Location

Catch

Wash: Test Site (Stack)

Filter: N/A

Date and Time of Recovery

Catch

Wash: After each Test Run

Filter: N/A

Laboratory Person Receiving Sample:

Signature: [Signature]

Date and Time of Receipt: 5/10/89

10: AM

Sample Storage: Normal

DESIGN NOTES

HCL Calculations

Bio-Medical Serv.

5-8-89

$$\text{Test 1: } (5) \frac{(460)}{1000} + (2) \frac{(108)}{1000} + (2) \frac{(122)}{1000} = 2.8 \text{ mg Cl}^-$$

$$(2.8 \text{ mg Cl}^-) \left(\frac{36.453}{35.453} \right) = 2.9 \text{ mg HCL}$$

$$\text{Test 2: } (5) \frac{(365)}{1000} + (2) \frac{(107)}{1000} + (2) \frac{(120)}{1000} = 2.3 \text{ mg Cl}^-$$

$$(2.3 \text{ mg Cl}^-) \left(\frac{36.453}{35.453} \right) = 2.4 \text{ mg HCL}$$

$$\text{Test 3: } (7) \frac{(519)}{1000} + (2) \frac{(107)}{1000} + (2) \frac{(100)}{1000} = 4.0 \text{ mg Cl}^-$$

$$(4.0 \text{ mg Cl}^-) \left(\frac{36.453}{35.453} \right) = 4.1 \text{ mg HCL}$$

JOB NO.	DATE	SUBJECT	☐ PURCHASE ORDER
TO:			☐ MEMO
FROM:			☐

TEST CALCULATIONS

I. Determination of Moisture in Stack Gases

a. Volume of Water Vapor Collected (Cubic Feet):

$$V_{wstd} = 0.04707 * (V_{lc})$$

b. Dry Gas Volume Through Meter (Cubic Feet):

$$V_{mstd} = 17.64 * V_m * Y * [(P_{bar} + (^H/13.6)) / (T_m + 460)]$$

c. Moisture Content: (Bws)

$$Bws = V_{wstd} / [V_{wstd} + V_{mstd}]$$

d. Wet Molecular Weight: (Ms)

$$M_s = [M_d * (1 - Bws)] + [18.0 * Bws]$$

II. Actual Stack Gas Volume Sampled (Cubic Feet):

$$V_{ma} = [V_{mstd} * (T_s + 460) * P_{std}] / [(1 - Bws) * T_{std} * P_s]$$

III. Determination of Stack Gas Velocity & Volumetric Flow Rate

a. Stack Gas Velocity (Feet per Second):

$$V_s = K_p * C_p * (SQR \hat{P}) * [SQR ((T_s + 460) / (P_s * M_s))]$$

b. Stack Volumetric Flow Rate (Cubic Feet per Minute):

1. Dry Standard Conditions (Qs)

$$Q_s = 60 * (1 - Bws) * V_s * A_s * (T_{std} / (T_s + 460)) * (P_s / P_{std})$$

2. Actual Conditions (Qa)

$$Q_a = V_s * A_s * 60$$

IV. Determination of Particulate Concentration (Grainloading)

a. Dry Standard Conditions: (cs)

$$cs = 0.01543 * (Mn / Vmstd)$$

b. Actual Conditions: (csl)

$$csl = 0.01543 * (Mn / Vmstd)$$

V. Emission Rate (Pounds per Hour)

$$E = 60 * Qs * cs / 7000$$

VI. Pollutant Emission Rate (Pounds per Million BTU's):

$$E = F * (cs / 7000 * [20.9 / (20.9 - \%O_2)]$$

VII. Heat Input (MMBTU per Hour):

$$Qh = 60 * Qs / F * [(20.9 - \%O_2) / 20.9]$$

VIII. Determination of Acceptability of Sampling Results: (I)

$$I = \frac{(Ts+460) * ((0.00267 * Vlc) + ((Vm*Y/(Tm+460))*(Pbar+(\hat{H}/13.6))))}{0.599 * \theta * Vs * Ps * An}$$

AIR TECHNIQUES, INC.
Field Data Summary
Bio-Medical Services

Points: 20
Per Point: 4.0
Scrubber Stack
May 8, 1989

	Volume Meter	Del P	SQRT Del P	Del H	Stack Temp	Meter Inlet	Temp Outlet
1	987.495	0.12	0.346	1.10	169	71	66
2		0.10	0.316	0.95	170	79	67
3		0.08	0.283	0.76	167	83	67
4		0.07	0.265	0.67	168	88	69
5		0.07	0.265	0.67	168	90	71
6		0.04	0.200	0.34	141	93	73
7		0.06	0.245	0.58	167	94	75
8		0.03	0.173	0.26	145	96	77
9		0.04	0.200	0.34	167	96	78
10		0.03	0.173	0.26	167	97	80
11		0.07	0.265	0.67	167	88	83
12		0.07	0.265	0.67	164	97	82
13		0.08	0.283	0.76	167	100	82
14		0.05	0.224	0.43	160	101	84
15		0.08	0.283	0.76	165	101	85
16		0.05	0.224	0.43	146	102	85
17		0.04	0.200	0.34	153	99	85
18		0.04	0.200	0.34	150	99	86
19		0.05	0.224	0.43	150	101	86
20		0.05	0.224	0.43	145	102	87

1015.687

AVERAGES

28.192 0.243 0.56 160 86

AIR TECHNIQUES, INC.
Field Data Summary
Bio-Medical Services

Points: 20
Point: 4.0
Rubber Stack
May 8, 1989

Volume Meter	Del P	SQRT Del P	Del H	Stack Temp	Meter Inlet	Temp Outlet
0.008	0.04	0.200	0.40	123	88	82
	0.05	0.224	0.50	142	97	82
	0.06	0.245	1.20	140	103	84
	0.04	0.200	0.77	137	104	85
	0.04	0.200	0.77	134	107	88
	0.04	0.200	0.70	127	110	91
	0.04	0.200	0.70	130	111	93
	0.03	0.173	0.53	123	111	94
	0.04	0.200	0.70	120	110	95
	0.04	0.200	0.70	121	110	95
	0.06	0.245	1.10	128	106	97
	0.07	0.265	1.20	138	112	96
	0.07	0.265	1.20	133	113	96
	0.04	0.200	0.70	152	114	97
	0.05	0.224	0.85	135	115	99
	0.05	0.224	0.85	131	114	98
	0.05	0.224	0.80	161	115	99
	0.04	0.200	0.64	152	114	99
	0.04	0.200	0.64	145	115	99
	0.05	0.224	0.80	140	115	100

53.144

AVERAGES

17.136

0.216 0.79 136 101

AIR TECHNIQUES, INC.
Field Data Summary
Bio-Medical Services

Number of Points: 20
 Points per Point: 4.0
 Station: Scrubber Stack
 Date: May 8, 1989
 No.: 3

Point	Volume Meter	Del P	SQRT Del P	Del H	Stack Temp	Meter Inlet	Temp Outlet
1	53.408	0.07	0.265	1.20	134	100	98
2		0.11	0.332	1.90	160	110	97
3		0.07	0.265	1.20	171	111	97
4		0.10	0.316	1.70	170	113	97
5		0.07	0.265	0.77	150	116	98
6		0.08	0.283	0.88	170	116	100
7		0.06	0.245	0.90	148	117	101
8		0.07	0.265	0.77	171	118	101
9		0.03	0.173	0.45	146	118	103
10		0.05	0.224	0.75	150	119	104
11		0.06	0.245	0.90	142	113	105
12		0.10	0.316	1.70	167	117	106
13		0.03	0.173	0.45	148	121	104
14		0.08	0.283	0.88	170	120	104
15		0.04	0.200	0.64	145	122	105
16		0.01	0.100	1.10	170	123	108
17		0.06	0.245	1.00	143	124	109
18		0.02	0.141	0.34	130	122	108
19		0.05	0.224	0.85	127	123	109
20		0.04	0.200	0.68	134	122	109
FINAL	95.970						
AVERAGES							
	42.562		0.238	0.95	152		110

Date: 5/8/89

Operator(s) Barton / Ruberry

Fyrite Analysis: %CO₂ 5 _____ %O₂ 15 _____

Comments _____

Run # 2- Method # ST w/HCL

Leak Checks:	Pre-Test	Post-Test
Sample Train:	<u>0.2</u> CFM @ <u>7</u> in. Hg	<u>0.1</u> CFM @ <u>9</u> in. Hg
Pitot Dynamic:	<u>—</u> in. H ₂ O for 15 sec.	<u>4.0</u> in. H ₂ O for 15 sec.
Pitot Static:	<u>—</u> in. H ₂ O for 15 sec.	<u>4.3</u> in. H ₂ O for 15 sec.
Method #3 Train:	<u>—</u> in. Hg for 30 sec.	<u>—</u> in. Hg for 30 sec.
Fyrite Analysis:	%CO ₂ <u>2.0</u> / <u>5.0</u> / <u>—</u>	%O ₂ <u>14.1</u> / <u>—</u> / <u>—</u>
Water Collected (ml.):	Tare <u>400</u>	Gross <u>528</u> Net <u>128</u>
Moisture Collected in Silica Gel (g.):	Tare <u>200</u>	Gross <u>207.5</u> Net <u>7.5</u>
Minutes per Point:	<u>40</u>	

[illegible]

Comments:

Field Data Sheet

Run # 3 Method # 5T w/ HCL

Plant Bio-Medical Services Source Incinerator
 Date 5/8/89 Start 2:40 am/pm am Stop 4:01 am pm City Lake City State Ga
 Operators Benton 1 Rosenberg 1 1
 Console # 1 EPA Box # 2 Nozzle # 3/8 A Diameter .374 Probe # 4 Length 3
 Console Km (-) .60 K-factor (-) 17 Barometer # A
 Ambient Conditions: Temp. (°F) _____ Pressure (in. Hg) 28.30
 Stack Conditions: Pressure (in. H₂O) -.06 Pressure (in. Hg) _____ Moisture(%) = 17

Leak Checks:	Pre-Test	Post-Test
Sample Train:	<u>OK</u> CFM @ <u>8</u> in. Hg	<u>0.0</u> CFM @ <u>6</u> in. Hg
Pitot Dynamic:	<u>✓</u> in. H ₂ O for 15 sec.	<u>4.6</u> in. H ₂ O for 15 sec.
Pitot Static:	<u>✓</u> in. H ₂ O for 15 sec.	<u>5.1</u> in. H ₂ O for 15 sec.
Method #3 Train:	<u>—</u> in. Hg for 30 sec.	<u>—</u> in. Hg for 30 sec.

Fyrite Analysis: %CO₂ 4.0 / / %O₂ 15.3 / /

Water Collected (ml.):	Tare <u>400</u>	Gross <u>690</u>	Net <u>290</u>
Moisture Collected in Silica Gel (g.):	Tare <u>200</u>	Gross <u>209.5</u>	Net <u>9.5</u>

Minutes per Point: 4.0

[illegible]

Comments: k-factor changes due to Temp + moisture fluctuations

DESIGN NOTES

Bio-medical Services

Time Log

5-8-89

7:50 Arrive at Bio-Med
Scrubber Not Running : Begin Setting up equip.

8:30 Notified by Larry Holloway that Dupp stack
lid is stuck open. Possible Delay

8:45 Ready to Begin Testing - Start Delay Time

9:50 Begin traversing stack and recording preliminary
data

10:15 Begin Test 1

11:45 End Test 1

12:25 Ready to begin Test 2
Flow seems low so we get other probe and
micro-manometer set up on stack to verify.
Flow is ok → AP .03-.07

12:45 Begin Test 2

2:10 End Test 2

2:40 Begin Test 3

4:01 End Test 3

4:50 Depart Bio-Med Facility

JOB NO.	DATE	SUBJECT	☐ PURCHASE ORDER
TO:			☐ MEMO
FROM:			☐

Work Sheet For Calculating Weight Burned At 500 Pounds An Hour

12/17/77

Shift 1

Operator Solomon D. Smith

	Box Weights	Total Weight	Min/Max
1:10	223.26	223.26	130 - 133
1:20	223.26	446.52	130 - 133
1:30	223.26	669.78	130 - 133
1:40	223.26	893.04	130 - 133
1:50	223.26	1116.30	130 - 133
2:00	223.26	1339.56	130 - 133
	Total		800 Pounds

1:10	223.26	223.26	130 - 133
1:20	223.26	446.52	130 - 133
1:30	223.26	669.78	130 - 133
1:40	223.26	893.04	130 - 133
1:50	223.26	1116.30	130 - 133
2:00	223.26	1339.56	130 - 133
	Total		800 Pounds

1:10	223.26	223.26	130 - 133
1:20	223.26	446.52	130 - 133
1:30	223.26	669.78	130 - 133
1:40	223.26	893.04	130 - 133
1:50	9:40	1116.30	130 - 133
2:00	9:55	2:14.73	130 - 133
	Total		800 Pounds

1:10	Time #1 10:15 = 1:11	223.26	130 - 133
1:20	10:10	223.26	130 - 133
1:30	10:20	223.26	130 - 133
1:40	10:30	1879.20	130 - 133
1:50	10:40	1895.30	130 - 133
2:00	10:50	182.02	130 - 133
	Total	1121.53	800 Pounds

TESTING

Work Sheet For Calculating Weight
Burned At 800 Pounds An Hour

05/07/89

Shift 1

Operator John T. Smith

	Box Weights	Total Weight	Min/Max
10	11:00	186.33	130 - 133
20	11:10	186.81	130 - 133
30	11:20	180.93	130 - 133
40	11:30	184.70	130 - 133
50	11:40	176.44	130 - 133
60	11:50	185.10	130 - 133
	Total	1100.31	800 Pounds

10	12:00	186.02	130 - 133
20	12:10	187.00	130 - 133
30	12:20	192.14	130 - 133
40	12:30	165.61	130 - 133
50	12:40 Test 2 12:45	186.81	130 - 133
60	12:50	181.99	130 - 133
	Total	1099.83	800 Pounds

10	1:00	182.50	130 - 133
20	1:10	184.03	130 - 133
30	1:20	185.71	130 - 133
40	1:30	180.43	130 - 133
50	1:40	185.12	130 - 133
60	1:50	183.18	130 - 133
	Total	1100.97	800 Pounds

10	2:00	189.25	130 - 133
20	2:10	179.26	130 - 133
30	2:20	188.26	130 - 133
40	2:30	176.29	130 - 133
50	2:40 Test 3 2:40 PM	184.58	130 - 133
60	2:50	183.26	130 - 133
	Total	1100.90	800 Pounds

TESTING

Work Sheet For Calculating Weight Burned At 500 Pounds An Hour

0907189

Shift 2

Operator _____

	Box Weights	Total Weight	Min/Max
3:10	3:00	182.79	130 - 133
3:20	3:10	185.73	130 - 133
3:30	3:20	185.18	130 - 133
3:40	3:30	184.58	130 - 133
3:50	3:40	191.08	130 - 133
4:00	3:50	173.45	130 - 133
	Total	1102.81	800 Pounds

6626.35

4:10	4:00	184.76	130 - 133
4:20	4:10	180.02	130 - 133
4:30	4:20	180.42	130 - 133
4:40	4:30	85.18	130 - 133
4:50	4:40	119.16	130 - 133
5:00			130 - 133
	Total		800 Pounds

7375.39

5:10			130 - 133
5:20			130 - 133
5:30			130 - 133
5:40			130 - 133
5:50			130 - 133
6:00			130 - 133
	Total		800 Pounds

6:10			130 - 133
6:20			130 - 133
6:30			130 - 133
6:40			130 - 133
6:50			130 - 133
7:00			130 - 133
	Total		800 Pounds

48.17

JOB BMS-2' TEST


6Y RESOURCE SYSTEMS, INC.
Office Box 117
Westtown, PA 18901
345-9446


SHEET NO. _____ OF _____
CALCULATED BY _____ DATE 5-8-89
CHECKED BY _____ DATE _____
SCALE _____

Time	Depth (in. v.c.)	Flow (gpm)	Press. (PSF)	pH	Temp. (°F)	Flow (gpm)	Press. (PSF)	pH	Temp. (°F)	ΔP (in. v.c.)	Blow (gpm)
10:25 AM	.15	27	32	8.6	175	230	45	9.7	183	—	6
10:40	.15	27	34	8.7	175	235	50	9.7	180		5
11:15	.15	27	34	8.6	175	225	50	9.5	166	16	5
12:15	.15	28	34	6.8	170	100	45	10	157	18	5
12:45	.15	27	32	6.7	173	100	45	9.8	155	18.5	5
1:30 PM	.125	27	32	8.4	170	100	45	9.9	149	17.5	5
2:00	.125	27	32	7.0	175	100	—	9.8	155	18	5
3:00	.125	24	32	7.3	175	100	50	9.9	160	17	5
3:30	.125	24	32	8.9	175	100	50	9.9	168	15.6	5
4:00	.125	24	32	6.7	175	100	45	10.1	169	15.5	5

NOTES:

1. Venturi Flow meter was tapping in making it inaccurate.
2. The Venturi Temperature instrument was out of calibration.





METHOD 5

AIR TECHNIQUES, INC.
Meter Calibration Form

Date 12-11-77

Console 611th

Pb = 28.57

ΔH ("H ₂ O)	Δcm ("H ₂ O)	V1cm (CF)	V2cm (CF)	V1dgm (CF)	V2dgm (CF)	tcm (oF)	t1 (oF)	t2 (oF)	
0.5	.10	000.00	000.349	678.642	614.145	63	107	113	1.52
1.0	.10	000.349	020.541	611.115	624.151	63	107	113	33.3
1.5	.10	020.541	040.731	611.115	644.410	63	107	113	20.2
2.0	.10	040.731	060.921	611.115	652.765	63	107	113	16.2
2.5	.10	060.921	081.112	611.115	661.145	63	107	113	14.2
3.0	.10	081.112	101.302	611.115	670.134	63	107	113	11.4

- ΔH = Orifice pressure differential, inches of water
 Δcm = Calibration meter pressure differential, inches of water
V1cm = Initial calibration meter volume, cubic feet
V2cm = Final calibration meter volume, cubic feet
V1dgm = Initial dry gas meter volume, cubic feet
V2dgm = Final dry gas meter volume, cubic feet
tcm = Temperature of calibration meter, degrees F
t1 = Inlet temperature of dry gas meter, degrees F
t2 = Outlet temperature of dry gas meter, degrees F
Tcm = Average temperature of calibration meter, degrees R
Tdgm = Average temperature of dry gas meter, degrees R
Pcm = Absolute pressure in calibration meter, "Hg.
Pdgm = Absolute pressure in dry gas meter, "Hg.

Calculations

1. $P_{cm} = P_b + (\Delta cm / 13.6)$
2. $P_{dgm} = P_b + (\Delta H / 13.6)$
3. Meter Correction Factor (MCF)

$$MCF = ((V2cm - V1cm) * (Tdgm) * (Pcm)) / ((V2dgm - V1dgm) * (Tcm) * (Pdgm))$$

MCF @ H=0.5 = 1.028

MCF @ H=1.0 = 1.019

MCF @ H=1.5 = 1.028

MCF @ H=2.0 = 1.015

MCF @ H=2.5 = 1.028

MCF @ H=3.0 = 1.015

AVERAGE MCF = 1.022

Signed [Signature]

Dry Gas Meter (Continued)

Console ATI 1

Date 5-10-89

PS-89.76

H (H ₂ O) (H ₂ O)	V_{1cm} (CF)	V_{2cm} (CF)	V_{1dgm} (CF)	V_{2dgm} (CF)	t_{cm} (F)	t_1 (F)	t_2 (F)
1.5	0.05	0.000	5.728	290.583	296.514	67°	75 / 68
							42 / 71
1.5	0.05	5.728	11.827	296.514	302.871	67°	74 / 71
							91 / 71
1.5	0.05	11.827	17.135	302.871	308.432	67°	89 / 74
							92 / 77

Calculations:

1) $P_{cm} = P_b + \frac{H}{13.6}$

2) $P_{dgm} = P_b + \frac{H}{13.6}$

3) Water Correction Factor (MCF)

$$MCF = \frac{(V_{2cm} - V_{1cm}) \cdot T_{dgm} \cdot P_{cm}}{(V_{2dgm} - V_{1dgm}) \cdot T_{cm} \cdot P_{dgm}}$$

4) AVERAGE = 0.979

Calculated by: C. R. H.

NOTES & NOMENCLATURE

H Orifice pressure differential (in. H₂O)

t_{cm} Calibration meter pressure differential (in. H₂O)

V_{1cm} Initial calibration meter volume (cu. ft.)

V_{2cm} Final calibration meter volume (cu. ft.)

V_{1dgm} Initial dry gas meter volume (cu. ft.)

V_{2dgm} Initial dry gas meter volume (cu. ft.)

t_{cm} Temperature of calibration meter (F)

t_1 Temperature of dry gas meter, inlet (F)

t_2 Temperature of dry gas meter, outlet (F)

T_{cm} Temperature of calibration meter, avg. (K)

t_{dgm} Temperature of dry gas meter, avg. (K)

P_{cm} Absolute pressure in calibration meter (in. Hg)

P_{dgm} Absolute pressure in dry gas meter (in. Hg)

AIR TECHNIQUES, INC.
Orifice Calibration Form

Date: 12-11-87

Console: 611th

ΔH ("H ₂ O)	V1 (CF)	V2 (CF)	θ (Min)	T1 (oR)	T2 (oR)	V2 - V1 (CF)	Qm (CFM)	Km
0.5	608.442	619.195	33.57	561	537.5	10.553	.302	.530
1.0	619.195	629.751	20.50	508	548	10.556	.488	.600
1.5	629.751	640.410	16.56	507.5	552.5	10.659	.612	.612
2.0	640.410	652.105	16.34	510	553.5	12.355	.710	.615
2.5	652.105	665.147	14.43	510.5	555.5	12.383	.904	.622
3.0	665.147	676.134	13.77	515	557	10.986	.845	.613

V1 = Dry gas meter at start of each calibration run

V2 = Dry gas meter at end of each calibration run

T1 = Dry gas meter inlet temperature

T2 = Dry gas meter outlet temperature

Pm = Atmospheric pressure (in. Hg.) + ($\Delta H/13.6$)

Mm = 28.97 #/# mole

Tm = T2 average

Calculations

1. $Q_m = [(V1 - V2) / \theta] * [(Avg T2) / (Avg T1+T2)]$

2. $K_m = [\text{square root} (P_m * M_m / T_m / \Delta H)] * Q_m$

Average orifice meter calibration: .594

Calibrated by: *John J. Smith*

AIR TECHNIQUES, INC.
DIGITAL THERMOMETER CALIBRATION

Date: 6-10-88

Digital Thermometer: GTI #1

<i>Micromite</i> Sending MV - degrees F	<i>GTI #1</i> Reading MV - degrees F	Accuracy
<u>68°</u>	<u>68</u>	<u> </u>
<u>150°</u>	<u>150</u>	<u> </u>
<u>250°</u>	<u>251</u>	<u> </u>
<u>401°</u>	<u>400</u>	<u> </u>
<u>600°</u>	<u>599</u>	<u> </u>
<u>750°</u>	<u>748</u>	<u> </u>
<u>1000°</u>	<u>998</u>	<u> </u>
<u>1200°</u>	<u>1248</u>	<u> </u>
<u>1500°</u>	<u>1498</u>	<u> </u>
<u>1750</u>	<u>1749</u>	<u> </u>
<u>1900</u>	<u>1874</u>	<u> </u>

Used as standard:


Thermo-Electric Micromite, calibration traceable to NBS standards.

Calibrated by: Greg D. Fournier

Thermocouple Calibration

Thermocouple: GII #1 Meter Inlet


Date performed: 8-20-87



Thermocouple Calibration

Thermocouple: GTT #1 Meier Outlet

Date performed: 8-20-87




ASTM Reference	T/C
32°F	35°F
206°F	206°F

Thermocouple Calibration

Thermocouple: EPA Box #2 Filter T/C

Date performed: 8-20-87




ASTM Reference	T/C
32°F	32°F
210°F	210°F

Thermocouple Calibration

Thermocouple - EPA Box #2 Imp. T/C

Date performed: 8-20-87




ASTM Reference	T/C
32°F	33°F
211°F	211°F

Thermocouple Calibration

Thermocouple: 314/1 Stack T/C

Date performed: 4-25-88



ASTM Reference	T/C
34°	35°
210°	212°

40 80 120 160 200 240

Thermocouple °F

Barometer Calibration

Barometer No. A

Date 78 OCT 88

Ambient Temperature 74

Corrected Mercury Barometer Reading 29.08

Initial Aneroid Barometer Reading 29.15


Final Aneroid Barometer Reading 29.08
(After Adjustment, If Necessary)

Calibrated By Pete Cdh

Comments _____

PROBE HEAT CALIBRATION

3 - ft Probe (5-min warmup)



PITOT PROBE CALIBRATION FORM

Plant: Bio-Medical Services Test Date: 5-8-89
Source: Incinerator Scrubber Calibrated By: Russell Bantz
Pre-test Calibration Date: 5-8-89 Probe No: 3' #4
Post-test Calibration Date: 5-8-87 Nozzle Size: 3/8 A
Pitot Assembly Coefficient: .84

ITEM	Pre-Test Value	Post-Test Value
Pitot Opening to Center Line, Pa	<u>0.55</u>	<u>0.55</u>
Pitot Opening to Center Line, Pb	<u>0.55</u>	<u>0.55</u>
Tubing Diameter, Dt	<u>.375</u>	<u>.375</u>
Pitot Opening to Thermocouple, Z	<u>2.1</u>	<u>2.1</u>
Pitot to Nozzle, X	<u>0.85</u>	<u>0.85</u>
Pitot to Probe, Y	<u>4.25</u> (RB) 0.65	<u>4.25</u>
Pitot Face Opening to Nozzle Opening, W	<u>0.65</u>	<u>0.65</u>

Pa=Pb; 1.05 Dt less than or equal to P less than or equal to 1.50 Dt
Z-greater than or equal to 2 in.; X-greater than or equal to 3/4 in.
Y-greater than or equal to 3 in.; W-greater than 0 in.

NOZZLE CALIBRATION

0.373	0.373	0.375	0.374
-------	-------	-------	-------

Average Diameter

Acceptable Limit of Error: Difference between high and low values
less than .004 inches.

AIR TECHNIQUES, INC.
ANALYTICAL BALANCE CALIBRATION FORM

Balance Name METTLER H80
Serial Number 60403EDD.9
Calibration Date 1-12-89

Class S Weight	Balance Reading
50.0 mg	50.0 mg
500.0 mg	499.6 mg
1.0000 g	1.0000 g
20.0000 g	20.0000 g
100.0000 g	100.0004 g

Calibrated by

John A. Sullivan

NOMENCLATURE

As	Cross-sectional area of stack, square feet
An	Cross-sectional area of nozzle, square feet
ACF	Actual cubic feet of gas at stack conditions
ACFM	Actual cubic feet of gas per minute at stack conditions
Bws	Proportion by volume of water vapor in gas stream
cs	Particulate concentration in stack gas, gr/dscf
csl	Particulate concentration in stack gas, gr/ACF
Ca	Distilled water blank residue concentration, mg/g
Cp	Pitot tube coefficient
delta H	Pressure drop across orifice meter, inches water
dp	Nozzle diameter, inches
delta P	Velocity head of stack gas, inches water
dscf	Cubic feet of dry gas corrected to standard conditions
E	Particulate emission rate, pounds/hour
Kp	Constant (85.49)
Ma	Mass of residue of distilled water after evaporation, mg
Maw	Mass of residue of distilled water blank, mg
Mf	Particulate matter collected on filter, mg
Mn	Total particulate matter collected, mg
I	Percent of isokinetic sampling
Pa	Density of water mg/ml
Pbar	Barometric pressure, inches mercury
Pm	Barometric pressure of dry gas meter, in. mercury
Ps	Absolute stack gas pressure, inches mercury
Pstd	Barometric pressure, standard conditions, 29.92 "Hg

Qa	Volumetric flow rate, actual conditions, ACF/min
Qs	Volumetric flow rate, dry standard conditions, dscf/min
Tm	Average dry gas meter temperature, degree F
Ts	Average stack gas temperature, degree F
Tstd	Absolute temperature at standard conditions, 528 R
θ	Total sampling time, minutes
Va	Volume of distilled water blank, ml
Vaw	Volume of distilled water used in wash, ml
Vf	Final volume of impinger contents, ml
Vi	Initial volume of impinger contents, ml
Vlc	Total volume collected in impingers and silica gel, ml
Vm	Volume of gas sampled through gas meter, cubic feet
Vma	Stack gas volume sampled, ACF
Vmstd	Volume of gas sampled through gas meter, cubic feet
Vs	Average stack gas velocity, feet/sec
Vwstd	Volume of water vapor in gas sampled, standard cubic feet
Wa	Weight of residue in distilled water wash, mg
Wf	Final weight of filter or probe wash beaker, g
Wi	Initial weight of filter or probe wash beaker, g
Y	Dry gas meter calibration factor