



State of New Jersey
DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF ENVIRONMENTAL QUALITY
Bureau of Technical Services
CN 411
Trenton, N.J. 08625-0411
(609) 530-4041

January 22, 1992

MEMORANDUM

TO: Scott Hawthorne, Regional Enforcement Officer
Southern Regional Enforcement Office

FROM: Edward Choromanski, Chief
Bureau of Technical Services 

SUBJECT: Camden County Energy Recovery Associates
Camden, New Jersey
Stack Emissions Test Program - Monthly Lead Tests
APC Plant ID No. 50617
NJ Stack No. 001
P/CT No. 83668 (Log No. 87-1012)

Stack emission tests were conducted at the above referenced facility on October 18, 1991. The purpose of these tests was to quantify the lead emissions being emitted to the atmosphere from Unit No. 1 (Incinerator Train). The results will be averaged for a twelve month period to verify compliance with the emission standards stated in the permit conditions.

Dan Strochak reviewed the submitted stack test report. His review indicates that the lead emissions were within the allowable emission standards, for each test run. His review indicated that lead emissions were only detected at the outlet during Run No. 1. Runs No. 2 and 3 had lead emissions below the detectable limit of the analytical procedure. However, based on the detection limit, the results would have been below the allowable emission standard. The results are consistent (being below the detection limit) with the previous lead stack test results. The amount and type of material being fed to the incinerator was monitored by personnel of the Division of Solid Waste Management. The results of their inspection are attached.

Final determination of the lead emissions compliance can not be made until the remaining nine months stack data has been completed.

c William O'Sullivan
Don Patterson
Iclal Atay
Chuck DeWeese
Dan Strochak

Attachment





State of New Jersey
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 DIVISION OF ENVIRONMENTAL QUALITY
 Bureau of Technical Services
 CN 411
 Trenton, N.J. 08625-0411
 (609) 530-4041

January 14, 1992

MEMORANDUM

To: Edward Choromanski

From: Dan Storchak *D.S.*

Subject: Camden County Resource Recovery Facility
 APC I.D. No. 50617
 N.J. Stack No. 001
 P/CT No. 83668
 Log No. 87-1012

On October 18, 1991, monthly lead tests were conducted at the above referenced facility. The tests were for removal efficiency on unit one, and were conducted by Entropy Environmentalists Inc. The results of the tests are as follows.

Contaminant	Run 1	Run 2	Run 3	Allowable
Lead gr/Dscf	0.0046	0.00639	0.00835	
gr/Dscf @ 12% CO ₂	0.00673	0.00871	0.00114	
gr/Dscf @ 7% O ₂	0.00644	0.00836	0.0108	
Lb/Hr	1.90	2.43	3.34	
 Outlet				
Lead gr/Dscf	7.44*10 ⁻⁶	<3.45*10 ⁻⁶	<3.45*10 ⁻⁶	
gr/Dscf @ 12% CO ₂	1.16*10 ⁻⁵	<5.18*10 ⁻⁶	<5.18*10 ⁻⁶	
gr/Dscf @ 7% O ₂	1.08*10 ⁻⁵	<4.89*10 ⁻⁶	<4.88*10 ⁻⁶	
Lb/Hr	0.00347	<0.00153	<0.00152	.08
 Removal Efficiency %	99.82	99.93	99.95	



Operating Data

Avg. Furnace Temp. (°F)	1109	1115	1170
Economizer Outlet Gas Temp.	442	443	455
Feedwater Pressure psig	1216	1218	1206
Lime Slurry Flow gpm	7.8	7.6	8.9
Lime Slurry ph	6.97	6.99	7.0
Oxygen (%)	9.0	8.99	8.70
Opacity (%)	0.06	0.04	0.03

Technical services calculations of the raw data supplied, indicates substantially the same results. The lead emissions for all three runs were within p/ct 83668 allowables. The amount of waste charged for the day of the tests was 240.75 tons.

CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES
600 MORGAN BOULEVARD, CAMDEN, NEW JERSEY 08104 - PHONE (609) 966-7174

November 22, 1991

Mr. Edward Choromanski, Chief
Department of Environmental Protection
Division of Environmental Quality
Bureau of Technical Services
CN 411
Trenton, N.J. 08625-0414

Subject: Camden County Energy Recovery Associates
APC I.D. 50617
Result of Monthly Stack Testing
October 1991

Dear Mr. Choromanski:

This letter serves to notify you of the results of monthly lead testing which was conducted at this facility on Tuesday October 18, 1991. Attached you will find the results of the subject test which were conducted by Entropy Environmentalist Inc.

Three 2 hour test runs were conducted on Unit 1 ("A" Boiler). Two of the three test runs showed less than detectable concentrations of lead in the stack flue gas and the overall average removal efficiency, based on SDA inlet sampling, was shown to be greater than 99.91%. The average emission rate calculated from the results of the tests was 0.00116 lb/hr or 1.45% of permit limitation of 0.08 lb/hr.


If there are any questions, please contact me at (609) 966-7174.

Sincerely,

Steve Warlick

Steve Warlick
Environmental Coordinator

CC M. Wattis File
B. Studley (OCTPbTest)
M. Cooper (W/Attachment)
C. Clamser



TELECOPY MESSAGEDATE: 10/10/91TIME: 1430

PLEASE HAND DELIVER THE FOLLOWING TELECOPY TO:

NAME: ED CHODOMANSKI / SUE SLACHETACOMPANY: NJOEP DEQ TECH SERVICESTELECOPY NO.: 530-5387FROM: S. WARLICK

CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES
600 MORGAN BOULEVARD
CAMDEN, NEW JERSEY 08104

TOTAL NUMBER OF PAGES (INCLUDING COVER SHEET) 2

This telecopy message is transmitted from (609) 966-7990
(an automatic machine). Please call
(609) 966-7174 if the telecopy you receive is incomplete
or illegible.

CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES

600 MORGAN BOULEVARD, CAMDEN, NEW JERSEY 08104 - PHONE (609) 966-7174

October 9, 1991

Mr. Edward Choromanski, Chief
Department of Environmental Protection
Division of Environmental Quality
Bureau of Technical Services
CN 411
Trenton, N.J. 08625-0414

Subject: Camden County Energy Recovery Associates
APC I.D. 50617 - 001
Notice of Monthly Stack Testing
October 18, 1991

Dear Mr. Choromanski:

This letter serves to notify you of scheduled monthly lead testing which will be conducted at this facility on Friday October 18, 1991. Entropy Environmentalist Inc. will be conducting the test. Entropy Plans to be on-site on Thursday October 17 1991 for set of equipment. Testing will begin on one unit on Friday the 18th.

If there are any questions, please contact me at (609) 966-7174.

Sincerely,

Steve Warlick

Steve Warlick
Environmental Coordinator

CC N. Wattis C. Mellon (NJDEP BRO)
B. Studley File
M. Cooper (MONTHLYTEST)
T BYRNE

This teletype message is transmitted from [REDACTED] or illegible. The message is [REDACTED] or incomplete.

LOG#	AVG FURN	OUTLET GAS	A-TEMP SPRAY FLOW	FEED- WATER FLOW	FEED- WATER PRESS	FEED- WATER TEMP	OUTLET STEAM FLOW	OUTLET STEAM PRESS	OUTLET STEAM TEMP	EXHAUST GAS OXYGEN	FEED- FUEL OIL	LIME	DAILY ASM	HOOR ASM	LINE SURF FLOW	LINE SURF PH
TIME	TEMP	TEMP	PH	PH	PSIG	DEGF	PH	PSIG	DEGF	Pct	PH	Tons	Tons	Tons	GPM	PH
01:00	1118.	441.0	527.00	69760.	1220	304.5	65792.	662.0	757.0	8.73	315.00	3124.000	9.33	9.33	7.49	6.98
02:00	1112.	440.5	522.00	69632.	1220	304.5	64576.	661.0	752.0	8.72	315.00	3132.000	16.75	7.45	7.52	6.98
03:00	1102.	440.0	580.00	66432.	1220	304.5	61504.	660.0	752.0	8.59	315.00	3140.000	26.75	9.98	7.54	6.98
04:00	1090.	439.5	871.00	67328.	1210	304.0	62376.	664.0	757.0	9.02	315.00	3152.000	37.57	10.76	7.41	6.98
05:00	1111.	442.0	1073.0	70656.	1216	305.0	63792.	670.0	757.0	8.65	315.00	3156.000	42.94	6.21	8.39	6.98
06:00	1060.	440.5	667.00	64320.	1216	304.5	63768.	669.0	761.0	9.60	317.00	3172.000	65.56	12.94	8.00	6.97
07:00	1070.	438.0	536.00	65920.	1220	305.0	60032.	668.0	751.0	9.36	317.50	3180.000	65.13	9.31	7.47	6.97
08:00	1092.	441.0	740.00	66608.	1216	304.5	61248.	671.0	765.0	9.28	317.50	3188.000	72.75	7.65	7.46	6.96
09:00	1090.	442.5	666.00	69008.	1216	304.5	61104.	668.0	764.9	9.20	317.69	3196.000	80.00	7.29	7.47	6.96
10:00	1134.	440.5	813.00	76920.	1212	304.5	69632.	667.0	762.0	8.11	315.00	3204.000	90.39	10.33	7.82	6.96
11:00	1160.	440.0	1258.0	83560.	1210	304.5	79232.	677.0	768.0	8.52	315.00	3220.000	103.50	13.20	8.20	6.96
12:00	1100.	441.0	847.00	79600.	1216	304.5	68736.	676.0	762.0	9.83	314.00	3226.000	113.20	9.75	7.62	6.96
13:00	1092.	444.0	751.00	70912.	1220	304.5	67840.	662.0	752.0	9.53	311.00	3236.000	120.13	7.86	7.94	6.98
14:00	1092.	440.0	609.00	66816.	1220	304.5	65216.	670.0	751.0	9.58	314.50	3244.000	129.76	9.48	8.56	6.92
15:00	1102.	446.5	947.00	71652.	1216	304.0	66944.	671.0	758.0	9.55	314.50	3256.000	147.75	11.90	7.63	6.92
16:00	1120.	443.5	1110.0	72960.	1216	304.5	70272.	662.0	767.0	8.80	316.00	3264.000	160.75	9.09	7.56	6.92
17:00	1150.	440.5	1162.0	76776.	1218	304.5	89760.	677.0	760.0	8.61	315.00	3272.000	167.20	6.58	7.50	6.92
18:00	1114.	441.0	1100.0	70664.	1216	304.5	66608.	671.0	762.0	9.06	315.00	3280.000	162.80	7.77	7.70	7.00
19:00	1170.	463.0	1194.0	81464.	1212	304.5	79616.	667.0	757.0	8.56	312.00	3288.000	174.25	7.80	8.36	7.00
20:00	1202.	469.5	1314.0	92544.	1198	304.5	88672.	672.0	765.0	8.31	308.50	3304.000	188.50	14.16	10.67	6.99
21:00	1194.	469.5	1232.0	91136.	1198	304.0	88632.	668.0	764.0	8.84	305.00	3316.000	201.50	13.16	9.26	6.98
22:00	1212.	469.5	1250.0	94336.	1194	304.5	92032.	669.0	763.0	8.03	306.00	3328.000	212.75	11.19	10.48	6.95
23:00	1202.	471.0	1110.0	93312.	1194	304.5	89760.	668.0	754.0	8.73	306.50	3344.000	227.75	15.06	9.00	7.00
24:00	1202.	466.0	1062.0	91660.	1192	304.0	87960.	667.0	764.0	8.77	306.50	3356.000	240.75	12.26	8.56	7.00
25:00	1212.	471.0	1314.0	94336.	1220	305.0	92032.	677.0	752.0	9.59	317.50	3372.000	257.75	15.06	10.67	7.00
26:00	1129.	447.2	912.72	75488.	1212	304.4	71421.	660.0	754.3	8.86	313.25	3388.000	272.75	10.65	9.15	6.96
27:00	1060.	436.0	622.00	63808.	1192	304.0	69968.	677.0	751.0	8.03	306.00	3404.000	287.75	6.21	7.41	6.96

000100	9.5	7.9	9.0	9.4	7.1	9.9	8.6	8.0	10.6	9.1	8.9	5.3	7.1	9.4	10.1	9.3	8.0	8.1	9.5	7.6	7.7	5.0	8.4	8.4
000101	9.2	7.9	8.2	9.2	9.4	9.2	8.3	8.0	10.2	9.1	8.7	2.8	8.9	9.4	10.1	9.3	7.9	8.5	9.5	7.4	7.5	9.1	8.2	8.2
000102	9.0	8.1	8.8	9.8	9.2	9.3	8.8	8.9	9.6	9.1	8.7	9.4	9.2	9.9	9.5	10.0	8.5	8.0	8.9	9.3	7.4	7.1	8.9	8.1
000103	8.9	8.6	8.6	8.9	8.9	9.4	8.8	9.1	9.0	9.1	9.4	9.2	9.9	9.5	10.0	8.5	8.0	8.9	9.3	7.4	7.1	8.9	8.1	
000104	8.9	8.6	8.4	8.8	9.2	9.7	8.8	9.5	9.6	9.1	9.5	9.3	9.9	9.6	10.1	8.9	8.2	9.0	9.0	7.7	7.7	8.6	8.9	
000105	9.1	8.5	8.6	9.0	9.6	10.2	9.0	9.0	9.4	9.1	9.8	9.1	9.8	9.9	9.6	9.9	9.2	8.3	8.6	8.9	7.7	7.0	8.1	
000106	9.4	8.3	8.8	8.9	9.4	10.3	8.9	9.4	9.4	8.5	9.7	9.5	10.0	9.4	10.0	9.2	8.4	8.7	7.5	8.0	7.8	9.3	8.2	
000107	9.4	8.0	9.0	9.1	9.2	10.4	8.8	9.2	9.4	8.5	9.6	9.2	9.9	9.3	10.2	9.0	8.3	8.9	7.0	8.6	7.4	9.3	8.2	
000108	9.2	8.8	8.9	8.9	8.9	10.4	8.9	9.3	9.5	8.6	9.3	9.3	9.6	9.1	10.8	8.8	8.1	7.8	9.0	8.0	8.7	7.6	9.0	
000109	9.3	8.8	8.7	9.2	8.3	10.3	9.0	9.5	9.8	8.4	9.2	9.4	9.3	9.0	11.0	8.9	8.1	7.5	8.5	8.3	8.8	7.5	9.4	
000110	9.0	8.0	8.4	9.4	9.4	10.0	8.9	9.4	9.7	8.2	9.0	9.4	9.6	9.6	10.6	9.1	9.0	8.2	8.1	8.9	7.1	8.9	8.1	
000111	9.1	8.6	8.3	9.4	7.9	10.0	9.1	9.3	9.8	9.7	8.0	8.9	9.6	10.1	9.6	11.1	9.0	8.7	7.0	8.0	8.2	9.0	8.2	
000112	9.0	8.1	8.5	9.0	7.7	9.9	9.1	9.8	9.7	8.1	8.5	9.1	9.7	9.6	11.0	8.8	8.3	8.0	8.9	8.1	9.4	7.8	9.5	
000113	9.7	9.0	8.4	9.6	9.0	9.7	9.7	9.1	9.4	8.4	8.3	9.2	9.7	9.6	11.0	9.1	8.5	8.4	8.9	8.1	9.2	9.4	8.8	
000114	9.8	8.7	8.3	8.3	8.5	10.0	9.8	9.2	9.0	8.6	8.6	9.3	9.3	9.6	10.9	9.1	8.4	8.0	8.7	8.3	9.6	8.3	9.6	
000115	9.0	8.9	8.0	8.4	8.4	10.6	10.0	9.5	9.5	9.3	8.7	7.8	9.3	9.6	10.6	9.4	9.1	8.1	7.8	8.5	8.2	9.3	9.5	
000116	9.0	8.0	8.0	8.0	8.0	10.2	9.9	9.1	9.0	8.5	8.5	9.5	9.5	9.5	10.6	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	
000117	8.9	8.7	7.8	8.7	8.7	10.1	9.8	8.7	8.8	8.7	7.4	9.6	8.8	9.7	10.5	9.4	8.7	8.6	8.5	8.8	10.4	7.9	9.5	
000118	9.0	9.0	7.6	8.7	8.5	9.3	10.0	8.7	9.3	8.7	7.5	9.7	9.2	9.8	10.4	9.3	9.3	8.7	8.4	9.2	10.2	8.0	9.5	
000119	9.0	9.0	7.6	8.7	8.5	9.3	10.0	8.7	9.3	8.7	7.5	9.7	9.2	9.8	10.4	9.3	9.3	8.7	8.4	9.2	10.2	8.0	9.5	
000120	9.0	9.0	7.6	8.7	8.5	9.3	10.0	8.7	9.3	8.7	7.5	9.7	9.2	9.8	10.4	9.3	9.3	8.7	8.4	9.2	10.2	8.0	9.5	
000121	9.0	9.0	7.6	8.7	8.5	9.3	10.0	8.7	9.3	8.7	7.5	9.7	9.2	9.8	10.4	9.3	9.3	8.7	8.4	9.2	10.2	8.0	9.5	
000122	9.0	9.0	7.6	8.7	8.5	9.3	10.0	8.7	9.3	8.7	7.5	9.7	9.2	9.8	10.4	9.3	9.3	8.7	8.4	9.2	10.2	8.0	9.5	
000123	8.2	8.4	7.0	8.1	8.2	10.7	9.7	8.0	9.1	8.3	7.7	9.5	10.6	9.9	10.8	9.1	9.4	8.3	8.6	9.1	9.5	8.9	9.2	
000124	8.1	8.8	6.8	8.6	8.3	10.7	9.8	7.9	9.2	7.8	8.0	9.0	10.7	9.9	10.5	9.0	9.3	8.5	8.6	9.0	9.9	9.0	8.8	
000125	8.0	9.0	7.1	8.8	8.2	10.4	8.9	7.5	9.2	7.4	8.1	8.0	10.7	9.9	10.1	9.5	8.8	8.6	9.0	8.7	10.2	8.8	9.2	
000126	8.0	9.0	7.1	8.8	8.2	10.4	8.9	7.5	9.2	7.4	8.1	8.0	10.7	9.9	10.1	9.5	8.8	8.6	9.0	8.7	10.2	8.8	9.2	
000127	8.0	9.0	7.1	8.8	8.2	10.4	8.9	7.5	9.2	7.4	8.1	8.0	10.7	9.9	10.1	9.5	8.8	8.6	9.0	8.7	10.2	8.8	9.2	
000128	8.0	9.0	7.1	8.8	8.2	10.4	8.9	7.5	9.2	7.4	8.1	8.0	10.7	9.9	10.1	9.5	8.8	8.6	9.0	8.7	10.2	8.8	9.2	
000129	8.1	9.0	7.6	9.1	8.8	10.6	10.1	7.6	8.9	7.4	8.5	8.1	10.1	9.8	9.3	9.3	9.1	9.5	7.6	9.3	8.7	8.6	9.7	
000130	8.3	8.9	7.6	8.6	8.3	10.0	10.3	7.4	8.7	7.7	8.6	8.3	10.1	10.1	9.2	9.1	9.3	9.8	7.8	9.4	9.1	8.6	10.0	
000131	8.4	8.2	7.2	8.1	8.1	9.8	9.9	7.7	8.5	7.4	8.7	8.0	9.5	10.3	9.3	8.0	9.4	9.7	7.9	9.1	8.2	9.9	8.8	
000132	8.5	8.3	7.2	9.0	7.7	9.4	9.8	7.7	8.5	7.4	8.7	8.0	9.5	10.3	9.3	8.0	9.4	9.7	7.9	9.1	8.2	9.9	8.8	
000133	8.5	8.3	7.2	9.0	7.7	9.4	9.8	7.7	8.5	7.4	8.7	8.0	9.5	10.3	9.3	8.0	9.4	9.7	7.9	9.1	8.2	9.9	8.8	
000134	8.5	8.3	7.2	9.0	7.7	9.4	9.8	7.7	8.5	7.4	8.7	8.0	9.5	10.3	9.3	8.0	9.4	9.7	7.9	9.1	8.2	9.9	8.8	
000135	8.6	8.3	7.2	9.0	7.7	9.4	9.8	7.7	8.5	7.4	8.7	8.0	9.5	10.3	9.3	8.0	9.4	9.7	7.9	9.1	8.2	9.9	8.8	
000136	8.7	9.4	8.4	8.8	7.8	9.3	9.8	9.1	8.8	7.3	8.0	7.8	8.8	9.8	8.8	9.0	8.5	9.5	9.1	7.8	9.1	8.0	8.7	
000137	8.7	9.4	8.4	8.8	7.8	9.3	9.8	9.1	8.8	7.3	8.0	7.8	8.8	9.8	8.8	9.0	8.5	9.5	9.1	7.8	9.1	8.0	8.7	
000138	8.7	9.4	8.4	8.8	7.8	9.3	9.8	9.1	8.8	7.3	8.0	7.8	8.8	9.8	8.8	9.0	8.5	9.5	9.1	7.8	9.1	8.0	8.7	
000139	8.7	9.4	8.4	8.8	7.8	9.3	9.8	9.1	8.8	7.3	8.0	7.8	8.8	9.8	8.8	9.0	8.5	9.5	9.1	7.8	9.1	8.0	8.7	
000140	8.7	9.4	8.4	8.8	7.8	9.3	9.8	9.1	8.8	7.3	8.0	7.8	8.8	9.8	8.8	9.0	8.5	9.5	9.1	7.8	9.1	8.0	8.7	
000141	9.3	8.0	9.8	9.3	8.4	8.3	8.4	8.3	9.1	10.1	9.1	7.5	8.7	9.0	9.2	9.1	8.0	7.6	8.5	9.9	8.9	7.7	8.2	
000142	9.2	8.2	10.0	9.2	8.3	9.1	9.1	10.1	9.1	7.5	8.7	9.0	9.2	9.1	8.0	7.6	8.5	10.3	9.0	5.7	8.7	8.0	7.8	
000143	8.9	8.6	9.3	9.6	8.1	9.2	10.1	8.7	7.7	8.7	8.7	9.4	9.0	9.0	7.9	8.4	8.3	8.6	8.9	7.7	8.4	6.8	7.3	
000144	8.9	8.6	9.3	9.6	8.1	9.2	10.1	8.7	7.7	8.7	8.7	9.4	9.0	9.0	7.9	8.4	8.3	8.6	8.9	7.7	8.4	6.8	7.3	
000145	8.9	8.6	9.3	9.6	8.1	9.2	10.1	8.7	7.7	8.7	8.7	9.4	9.0	9.0	7.9	8.4	8.3	8.6	8.9	7.7	8.4	6.8	7.3	
000146	8.9	8.6	9.3	9.6	8.1	9.2	10.1	8.7	7.7	8.7	8.7	9.4	9.0	9.0	7.9	8.4	8.3	8.6	8.					

CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES

600 MORGAN BOULEVARD, CAMDEN, NEW JERSEY 08104 - PHONE (609) 966-7174

November 25, 1991

Mr. Edward Choromanski, Chief
Department of Environmental Protection
Division of Environmental Quality
Bureau of Technical Services
CN 411
Trenton, N.J. 08625-0414

Subject: Camden County Energy Recovery Associates
APC I.D. 50617
Result of Monthly Stack Testing
October 1991

Dear Mr. Choromanski:

In my November 22, 1991 transmittal letter for the subject report I neglected to include the certification statement signed by Mr. Bruce Studley. Attached you will find the original certification statement.


If there are any questions, please contact me at (609) 966-7174.

Sincerely,

Steve Warlick

Steve Warlick
Environmental Coordinator

CC N. Wattis File
B. Studley (OCTPbcERT)
M. Cooper (W/Attachment)
C. Clamser



CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES

PERRYVILLE CORPORATE PARK • CLINTON, NEW JERSEY 08809-4000 • PHONE 201-730-4000

GENERAL PARTNERS
CAMDEN COUNTY ENERGY RECOVERY CORP.
FOSTER WHEELER CAMDEN COUNTY, INC.

CAMDEN RESOURCE RECOVERY FACILITY

I certify under penalty of law that the information provided in this document is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including fines or imprisonment or both, for submitting false, inaccurate or incomplete information.

B. C. Studley
Bruce C. Studley, P.E.
Vice President, Plant Operations
Foster Wheeler Power Systems, Inc.

NOVEMBER 23, 1991
(Date)

REPORT CERTIFICATION

SUBMITTAL DATE
November 6, 1991

The project was carried out under my direction and supervision. To the best of my knowledge, the data presented in this report is accurate and complete.

Signature



Allan F. Lowe

Project Manager

FOSTER WHEELER POWER SYSTEMS
FINAL REPORT DISTRIBUTION LIST

Revision <u>No.</u>	Date of <u>Revision</u>	Number <u>of Copies</u>	<u>Mailed To</u>
0	11/06/91	3	S. Warlick - CCERA
0	11/06/91	1	B. Studley - FW

TABLE OF CONTENTS

	<u>PAGE</u>
LIST OF TABLES AND FIGURES.....	iii
INTRODUCTION	
1.1 Background.....	1-1
1.2 Outline of Test Program.....	1-1
1.3 Test Participants.....	1-1
SUMMARY OF RESULTS.....	2-1
PROCESS DESCRIPTION AND OPERATION	
3.1 General.....	3-1
3.2 Source Air Flow.....	3-1
SAMPLING AND ANALYTICAL PROCEDURES	
4.1 General.....	4-1
4.2 Sampling and Velocity Traverse Points.....	4-1
4.3 Volumetric Air Flow Rates.....	4-1
4.3.1 Flue Gas Velocity.....	4-1
4.3.2 Flue Gas Composition.....	4-1
4.3.3 Flue Gas Moisture Content.....	4-4
4.4 Emissions Determinations.....	4-4
4.5 Equipment Calibration.....	4-5
4.6 Analytical Laboratory.....	4-5
QUALITY ASSURANCE/QUALITY CONTROL	
5.1 General.....	5-1
5.2 Preventive Maintenance and Equipment Calibration.....	5-1
5.3 Sample Processing.....	5-2
5.4 Instrument Calibration.....	5-4
5.5 Blanks and Spikes.....	5-4
5.6 Internal/External System Audit Checks.....	5-5
5.7 Data Reduction and Validation.....	5-5
5.8 QA/QC Summary.....	5-6

(continued next page)

TABLE OF CONTENTS (continued)

	<u>PAGE</u>
APPENDICES	
A. Test Results	
1. SDA Inlet.....	1
2. Stack.....	4
3. Example Calculations.....	7
B. Field and Analytical Data	
1. SDA Inlet.....	12
2. Stack.....	27
C. Calibration Data.....	42
D. Sampling and Analytical Procedures.....	70

LIST OF TABLES AND FIGURES

Table -----	Figure -----	Title -----	Page ----
1-1	-	Test Log.....	1-1
1-2	-	Test Participants.....	1-2
2-1	-	Lead Emission Rates, Concentrations, and Removal Efficiencies.....	2-1
		<u>Run-By-Run Tests Summaries</u>	
2-2	-	Unit No. 1 SDA Inlet.....	2-2
2-3	-	Unit No. 1 Stack.....	2-3
-	3-1	Unit Nos. 1, 2, and 3 Air Flow Schematic.....	3-2
-	4-1	Unit Nos. 1, 2, and 3 SDA Inlets Test Location.....	4-2
-	4-2	Unit Nos. 1, 2, and 3 Stack Test Location.....	4-3
5-1	-	In-House Equipment Calibration.....	5-1
5-2	-	In-House Instrument Calibration.....	5-4
5-3	-	Lead Duplicate Analyses Results.....	5-6

INTRODUCTION

1.1 Background. Foster Wheeler Enviresponse, Inc. has conducted a testing program to quantify lead emissions from Unit No. 1 of the Camden County Resource Recovery facility in Camden, New Jersey.

The facility consists of three mass-fired municipal refuse burning furnaces which produce electricity for sale to a local utility company. Each of the mass-fired boilers is equipped with a spray dryer adsorber (SDA) for acid gas removal, an electrostatic precipitator (ESP) for the control of suspended particulate emissions.

1.2 Outline of Test Program. This report covers stationary source sampling performed on October 18, 1991 at the Unit No. 1 SDA inlet and stack. Table 1-1 is a test log which presents the sampling locations, sampling parameters, sampling methods, test dates, and run numbers.

1.3 Test Participants. Table 1-2 lists the personnel involved in the test program.

TABLE 1-1

TEST LOG

<u>Sampling Location</u>	<u>Sampling Parameter</u>	<u>Sampling Method</u>	<u>Test Date</u>	<u>Run Numbers</u>		
				<u>1</u>	<u>2</u>	<u>3</u>
SDA Inlet	CO ₂ , O ₂	EPA 3	10/18	1-I-M3-1	1-I-M3-2	1-I-M3-3
	Lead	EPA MMTL	10/18	1-I-MMTL-1	1-I-MMTL-2	1-I-MMTL-3
Stack	CO ₂ , O ₂	EPA 3	10/18	1-S-M3-1	1-S-M3-2	1-S-M3-3
	Lead	EPA MMTL	10/18	1-S-MMTL-1	1-S-MMTL-2	1-S-MMTL-3

TABLE 1-2
TEST PARTICIPANTS

Foster Wheeler Enviresponse, Inc.

Bruce C. Studley
Test Coordinator

Camden County Energy
Recovery Associates

Steven B. Warlick
Test Coordinator

New Jersey State Department
of Environmental Protection

Frederick Ballay
Test Observer

Entropy Environmentalists Inc

Allan F. Lowe
Project Manager

Leslie C. Murray
Project Supervisor

Sean G. Daley
Sampling Team Leader

William E. Morgan
Sampling Team Leader

Patrick F. Daley
Engineering Technician

Reginald F. Holt
Engineering Technician

Lauren A. Sherwood
Laboratory Technician

SUMMARY OF RESULTS

Table 2-1 presents the emissions results for lead which has a specific emissions limits of 0.08 lb/hr stated in the permit. Tables 2-2 and 2-3 are run-by-run tests summaries; refer to the "List of Tables and Figures" on page iii of the "Table of Contents" for a cross-reference. Detailed test results are presented in Appendix A; field and analytical data is provided in Appendix B.

TABLE 2-1
LEAD EMISSION RATES, CONCENTRATIONS,
AND REMOVAL EFFICIENCIES

	----- Repetition -----			Average
	<u>1</u>	<u>2</u>	<u>3</u>	
<u>SDA Inlet</u>				
Concentration, gr/DSCF	0.00460	0.00639	0.00835	0.00645
Concentration, gr/DSCF@12%CO ₂	0.00673	0.00871	0.00114	0.00895
Concentration, gr/DSCF@7%O ₂	0.00644	0.00836	0.00108	0.00853
Emission Rate, lb/hr	1.90	2.43	3.34	2.56
<u>Stack</u>				
Concentration, gr/DSCF	7.44E-06	ND (<3.45E-06)	ND (<3.45E-06)	2.48E-06
Concentration, gr/DSCF@12%CO ₂	1.16E-05	ND (<5.18E-06)	ND (<5.18E-06)	3.87E-06
Concentration, gr/DSCF@7%O ₂	1.08E-05	ND (<4.89E-06)	ND (<4.88E-06)	3.60E-06
Emission Rate, lb/hr	0.00347	ND (< 0.00153)	ND (< 0.00152)	0.00116
Removal Efficiency, %*	99.82	> 99.93	> 99.95	> 99.91

* Calculated using lb/hr.

TABLE 2-2

Lead Tests Summary

Unit No. 1 SDA Inlet

	1-1-MMTL-1	1-1-MMTL-2	1-1-MMTL-3	Average
	10/18/91	10/18/91	10/18/91	
Run Date				
Run Start Time	0820	1500	1845	
Run Finish Time	1355	1734	2055	
Test Train Parameters:				
Volume Of Dry Gas Sample, SCF *	71.817	68.258	67.491	
Percent Isokinetic:	96.1	95.8	98.2	
Flue Gas Parameters:				
CO ₂ , Percent By Volume, Dry	8.2	8.8	8.8	8.6
O ₂ , Percent By Volume, Dry	11.0	10.3	10.2	10.5
Temperature, °F	438	421	426	428
Air Flow Rate, Dry SCFM *	48,267	44,362	46,747	46,459
Air Flow Rate, Wet ACFM	94,296	84,641	91,576	90,171
Lead:				
Concentration, grains/DSCF *	0.00460	0.00639	0.00835	0.00645
Concentration, gr/DSCF @ 12% CO ₂	0.00673	0.00871	0.0114	0.00895
Concentration, gr/DSCF @ 7% O ₂	0.00644	0.00836	0.0108	0.00853
Emission Rate, lb/hr	1.90	2.43	3.34	2.56

* 70° F (21° C) -- 29.92 Inches of Mercury (Hg)

TABLE 2-3

Lead Tests Summary

Unit No. 1 Stack

	1-S-MMTL-1	1-S-MMTL-2	1-S-MMTL-3	Average
	10/18/91	10/18/91	10/18/91	
Run Date				
Run Start Time	0820	1500	1845	
Run Finish Time	1355	1734	2055	
Test Train Parameters:				
Volume Of Dry Gas Sample, SCF *	91.328	89.343	89.392	
Percent Isokinetic:	96.6	99.7	100.1	
Flue Gas Parameters:				
CO ₂ , Percent By Volume, Dry	7.7	8.0	8.0	7.9
O ₂ , Percent By Volume, Dry	11.4	11.1	11.1	11.2
Temperature, °F	275	278	277	277
Air Flow Rate, Dry SCFM *	54,374	51,547	51,402	52,441
Air Flow Rate, Wet ACFM	89,635	86,092	86,833	87,520
Lead:				
Concentration, grains/DSCF *	7.44E-006	ND	ND	2.48E-006
Concentration, gr/DSCF @ 12% CO ₂	1.16E-005	ND	ND	3.87E-006
Concentration, gr/DSCF @ 7% O ₂	1.08E-005	ND	ND	3.60E-006
Emission Rate, lb/hr	0.00347	ND	ND	0.00116

* 70° F (21° C) -- 29.92 Inches of Mercury (Hg)
 ND Not detected used as zero (0)

PROCESS DESCRIPTION AND OPERATION

3.1 General. The Camden County Resource Recovery Facility in Camden, New Jersey operates three mass-fired municipal refuse burning furnaces which produce electricity for sale to a local utility company. Each of the mass-fired boilers is equipped with a Spray Dryer Absorber (SDA) for acid gas removal. The SDA is followed by an Electrostatic Precipitator (ESP) for the control of suspended particulate emissions. Each ESP is followed by an induced draft fan which directs the flue gas to a reinforced concrete stack. The facility has continuous emissions monitors for CO, SO₂, and O₂ at the SDA inlet and for SO₂, NO_x, O₂, and opacity in the stack. A microprocessor-based data acquisition system receives data from the monitoring system and is equipped with a printer which provides hard copies of emission values.

Bottom ash from the combustion grates and collected flyash are collected in a "semi-dry" conveying system. Sufficient moisture is added to the combined ash or "residue" to suppress dusting. A vibrating conveyor discharges residue from each boiler to an enclosed common ash storage area. A clam shell loader transfers the material to a vibrating conveyor and trommel screen separator. Oversize material is reclaimed as ferrous residue. Material passing through the screen is landfilled by truck.

3.2 Source Air Flow. Figure 3-1 is an air flow schematic which shows the passage of flue gases exhausted from the boilers.




FIGURE 3-1. UNIT NOS. 1, 2, AND 3 AIR FLOW SCHEMATIC.

SAMPLING AND ANALYTICAL PROCEDURES

4.1 General. All sampling and analytical procedures were those recommended by the United States Environmental Protection Agency and the New Jersey State Department of Environmental Protection. This section provides brief descriptions of the sampling and analytical procedures. Detailed descriptions of the procedures are provided in Appendix D.

4.2 Sampling Points. The number and location of the sampling points were determined according to the procedures outlined in EPA Method 1. As shown in Figure 4-1, the SDA inlet cross sections were divided into 24 equal areas with 12 sampling points on each of two traverse axes. As shown in Figure 4-2, the stack cross sections were divided into 12 equal areas with six sampling points on each of two traverse axes.

4.3 Volumetric Air Flow Rates


4.3.1 Flue Gas Velocity. The flue gas velocity and volumetric flow rate were determined according to the procedures outlined in EPA Method 2. Velocity head measurements (ΔP) were made using Type S Pitot tubes conforming to the geometric specifications outlined in EPA Method 2. Accordingly, each has been assigned a coefficient of 0.84. Differential pressures were measured with Magnehelic gauges of appropriate range. Flue gas temperatures were measured with chromel-alumel thermocouples equipped with hand-held digital readouts.

4.3.2 Flue Gas Composition. Flue gas samples were collected using the multipoint, integrated sampling technique outlined in EPA Method 3.

Sample Collection. A stainless steel probe and a peristaltic pump delivering 500 to 750 mL/min of flue gas were used to fill a Tedlar bag. Moisture was removed by means of a knockout jar located prior to the pump. Sampling was of the same duration (except purges following port changes) as the pollutant emissions runs.

Sample Analysis. Analysis for carbon dioxide and oxygen was performed using an Orsat apparatus. The analytical results were used to determine the flue gas composition, molecular weight, excess air, and emissions correction factor.

(continued on page 4-4)

**TRAVERSE POINTS**

2 AXES
12 POINTS / AXIS
24 TOTAL POINTS





FIGURE 4-1. UNIT NOS. 1, 2, AND 3 SDA INLETS TEST LOCATION.



Note: Unit Nos. 1, 2, and 3 stacks are identical.




FIGURE 4-2. UNIT NOS. 1, 2, AND 3 STACKS TEST LOCATIONS.

4.3.3 Flue Gas Moisture Content. The moisture content was determined in conjunction with the sampling method discussed in the following section.

4.4 Emissions Determinations. Samples were withdrawn isokinetically from the source using an EPA Draft Multi-Metal sampling train.

Sample Collection. The sampling train consisted of a glass nozzle, a heated glass probe with a Type S Pitot tube attached, a filter, four chilled impingers, and a metering console. The particulate sample was collected on a Pallflex 2500QAT-UP quartz filter maintained at a temperature of $248^{\circ}\text{F} \pm 25^{\circ}\text{F}$. The first impinger remained empty, the second and third impingers each contained 100 mL of 5% nitric acid (HNO_3)/10% hydrogen peroxide (H_2O_2), and the fourth contained preweighed silica gel. Each run was a minimum of two hours in duration with a minimum sample volume of 60 dry standard cubic feet. At the SDA inlet, each of the 24 points was sampled for five minutes, resulting in net run times of 120 minutes. At the stack, each of the 12 points was sampled for 10 minutes, resulting in net run times of 120 minutes.

Sample Recovery. A Teflon spatula and Teflon coated tweezers were used to remove the filter from the filter holder and place it in a 250 mL glass jar. The reagents were returned to the original bottles, weighed, the weights recorded on the labels, and the liquid levels marked. The silica gel was returned to the original container, weighed, and the weight recorded on the label. The volume of water vapor condensed in the impingers and the volume of water vapor collected in the silica gel were summed and entered into moisture content calculations.

The nozzle, probe, and fronthalf of the filter holder were rinsed with 100 mL of acetone into a 500 mL jar followed by rinsing with 100 mL of 0.1N HNO_3 into a second 500 mL jar. A Teflon probe brush was used for cleaning the probe.

The backhalf of the filter holder and the first, second, and third impingers were rinsed with 100 mL of 0.1N HNO_3 into the 1000 mL jar containing the $\text{HNO}_3/\text{H}_2\text{O}_2$ reagent.

Sample Analyses. For the metals analyses, the fronthalf acetone and HNO_3 rinses were evaporated to near dryness in a Teflon beaker. The filter, loose particulate, 3 mL of concentrated HNO_3 , and 5 mL of concentrated HF were added to the beaker. The sample was digested on a hotplate until brown fumes were evident, indicating the destruction of organic matter. After the addition of concentrated HNO_3 , the reagent and impinger rinses were evaporated to near dryness in a Teflon beaker on a hotplate. After cooling, 3 mL of concentrated HNO_3 and 5 mL of concentrated HF were added to the beaker and the sample was fumed on a hotplate to destroy organic residue.

The prepared filter and $\text{HNO}_3/\text{H}_2\text{O}_2$ reagent samples were combined, brought to a final volume of 100 mL with 10% HNO_3 , and analyzed for all metals with a Perkin Elmer 3030 atomic absorption analyzer using the appropriate SW-846 methods. Duplicate lead analyses were performed for approximately 30% of the emissions samples.

4.5 Equipment Calibration. Pertinent calibration data are provided in Appendix C.

4.6 Analytical Laboratory. Oxford Laboratory was the laboratory which performed lead analyses for this test program.

QUALITY ASSURANCE/QUALITY CONTROL

5.1 General. Entropy Environmentalists Inc. (EEI) is committed to the continued implementation of a Quality Assurance Program to assure the quality of sampling and analytical procedures of environmental measurement data. The Quality Assurance measures taken during this test project equals or exceeds the minimum QA/QC recommendations as set forth by the U.S. Environmental Protection Agency (EPA) for a particular method.

The following sections outline the QA program implemented by EEI to justify the validity of test procedures. As applicable, the QA system for the various test programs addresses the following areas:

- ▲ Preventive Maintenance & Equipment Calibration
- ▲ QA Sample Processing
- ▲ Analytical Instrument Calibration
- ▲ Blanks and Spiked Samples
- ▲ Internal/External System Checks
- ▲ Data Reduction & Validation
- ▲ QA/QC Summary

5.2 Preventive Maintenance and Equipment Calibration. An effective preventive maintenance program decreases downtime and thus increases data completeness and quality. Pretest and posttest equipment calibrations are conducted in a manner and at a frequency which meets or exceeds U.S. EPA specifications.

Each item transported to the field is inspected to detect equipment problems which may originate during periods of storage. All equipment returning from the field is cleaned, repaired, reconditioned, and recalibrated as necessary. Routine maintenance on equipment (dry gas meters, pumps, Magnehelics, manometers, pitot tubes, and nozzles) is carried out periodically for leaks, corrosion, dents, or any other damage. Table 5-1 shows the activities for equipment calibration.

TABLE 5-1
IN-HOUSE EQUIPMENT CALIBRATION

<u>Apparatus</u>	<u>Calibration Method And Frequency</u>	<u>Specifications</u>	<u>Corrective Action</u>
Type S Pitot Tubes	Standards contained in EPA Method 2. Visual inspection prior to shipment to test site and again prior to each day of testing.	Coefficient of 0.84 ± 0.02	Refurbish or recalibrate.

(continued next page)

ENTROPY

TABLE 5-1 (continued)
IN-HOUSE EQUIPMENT CALIBRATION

<u>Apparatus</u>	<u>Calibration Method And Frequency</u>	<u>Specifications</u>	<u>Corrective Action</u>
Manometers	Leak checked before and after each field use.		Adjust or replace.
Magnehelic Gauges	Initially calibrated over full range. After each field use, checked against inclined manometer at average settings encountered during testing.	0-10" water column Within $\pm 5\%$	Repair and Recalibrate.
Thermometers -Impinger -Dry Gas Meter -Filter Box	After purchase and prior to each field use, using ASTM mercury-in-glass thermometer.	Imp = $\pm 2^\circ\text{F}$ DGM = $\pm 5.4^\circ\text{F}$ FB = $\pm 5.4^\circ\text{F}$	Adjust, determine correction factor, or reject.
Thermocouple/ Potentiometer	After purchase. 3-point (ice bath, boiling water, and hot oil) using ASTM mercury-in-glass thermometer. Before and after each field use, compared to ASTM mercury-in-glass thermometer at ambient conditions.	$\pm 1.5\%$ of absolute temperature.	Adjust, determine correction factor, or reject.
Dry Gas Meter and Orifice	Full calibration (every 6 months) over wide range of orifice settings to obtain calibration factor (isokinetic meterbox). 10-minute quick calibration before sending to test site and again prior to each day of field use (isokinetic). Posttest (at average delta H and highest vacuum encountered during testing) to determine if meter gamma has changed (isokinetic).	DGM = ± 0.02 from avg. coeff. for each run. Ori. = ± 0.15 " H ₂ O over delta H range of 0.4" to 4.0" $\pm 3\%$ of full. $\pm 5\%$ of full. $\pm 5\%$ of full calibration. Gamma (initial or recalibration) that yields the lowest sample volume for the testing is used for calculations.	Adjust or replace. Use if no backup. Do not use. Recalibrate or replace.
Dry Gas Meter Transfer Standard	Full calibration w/spirometer before/after each field use (nonisokinetic meterbox). Annual calibrations conducted in triplicate using EPA wet test meter. Calibrations conducted at 7 flow rates from 0.25 to 1.40 cfm.	$\pm 5\%$ of pretest, .02 from average coeff. from each run $\pm 2\%$ of average factor for each calibration run.	Recalibrate. Adjust and recalibrate.
Barometer	Before and after each field use against an aneroid barometer. Reference barometer adjusted for elevation differences.	± 0.1 " mercury.	Adjust to agree.
Probe Nozzle	Average of 5 I.D. measurements using a micrometer. Visual inspection before and after each field use.	Difference between high and low measurement ≤ 0.004 "	Repair and recalibrate.

5.3 Sample Processing. Entropy employs systems which ensure the integrity of an environmental sample from the time of acquisition, through analysis, and ultimately to proper disposal. These systems are necessary to allow valid

conclusions to be drawn from analytical results separated in time and space from the sampling operation. In addition, these systems recognize that samples are occasionally of value even after analytical results have been reported.

Samples are collected, transported, and stored in clean containers which are constructed of materials inert to the analytical matrix. Containers are used which allow air tight seals. When necessary, containers are employed which prevent photochemical reactions. All sample containers are labeled with the following information:

- ▲ Unique source identifier
- ▲ Sample run identifier
- ▲ Analyte identifier
- ▲ Sample matrix identifier
- ▲ Sample analyst identifier

Additional information relating to the sample is recorded on the data sheet for the sampling run that afforded the subject sample. Accordingly, the sampling data sheet contains all the information listed above, plus the date and time the sample was acquired and supplemental information such as observations pertinent to the quality of the sample. For condensed samples, e.g., samples in liquid media, the sample levels are marked on the outside of the container; this mark is used to indicate sample loss, and as such, may serve as a reference in adjusting results accordingly.

For transport from the field to the laboratory, samples are stored in sealed containers and secured in a fashion which minimizes movement and thus prevents breakage of containers. Containers used for transporting glass are packed with foam. Samples which require chilling are kept cold until analyzed.

Samples remain in the custody of the sampler, from acquisition until conveyance to the sample custodian. All custody transfers are signed for and documented on a record of custody form, which remains with the sample until turned over to the custodian.

Analytical data are identified in a manner identical to that of the sampling data. Accordingly, all data generated from the analysis of samples are documented with the following information:

- ▲ Source identifier
- ▲ Sample run identifier
- ▲ Analyte identifier
- ▲ Sample matrix identifier
- ▲ Analyst identifier
- ▲ Analysis date

Portions of samples remaining after analysis are returned to their original

ENTROPY

sample containers. These samples are stored in designated storage areas until their destruction is authorized.

5.4 Instrument Calibration. Instrument calibration is one of the most important functions in generating precise and accurate quality data. A listing of major in-house instrumentation and the corresponding Quality Assurance program is given in Table 5-2.

All of the contract laboratories involved in the analytical testing for the test program maintained rigorous QA programs for instrument calibration.

TABLE 5-2
IN-HOUSE INSTRUMENT CALIBRATION

<u>Apparatus</u>	<u>Calibration Method And Frequency</u>	<u>Corrective Specifications</u>	<u>Action</u>
Analytical & Top Loading Balance	Daily and monthly checks with a series of class S weights. Balance serviced annually by a qualified service representative and checked with a series of NBS weights.	± 1 mg of class S weights.	Adjust or repair.
Gas Chromatograph	3-point calibration curve at the expected range. Duplicate injection of the sample until $\pm 5\%$ variation is achieved. Calibration repeated at the end of each test series.		
HPLC/Ion Chromatograph	Calibrations conducted at the beginning, after the first injection, and after the second injection.		
Fisher Accumant 925 pH/Selective Ion Meter	5- point calibration prior to analyzing the samples for the specific ions.		

5.5 Blanks and Spikes. Field blanks, method blanks, trip blanks, lab-proof blanks and filter blanks are obtained, digested and analyzed when applicable. The blanks reflect the background contamination obtained from the various sources during the sampling and analysis. Thus, data adjustment or correction can be made accordingly.

In most cases, it is not necessary to digest and analyze the method blanks, reagent blanks or the lab-proof blanks unless the field blank shows a high level of contamination. If a high level of contamination is present, it is imperative to individually analyze the above blanks to help determine the cause of contamination.

Spiked samples are used to check on the performance of a routine analysis or the recovery efficiency of a method. During spiking, a known amount of stock solutions of the substance of interest is added to the sample prior to sample extraction, digestion, and analysis.

5.6 Internal/External System Audit Checks. System and performance audits are routine elements of all Entropy QA/QC programs.

Internal Systems Audit: The following sampling equipment checks were conducted prior to sample collection.

- ▲ All sampling equipment was thoroughly checked to ensure clean and operable components.
- ▲ Equipment was inspected for possible damage from shipment.
- ▲ The oil manometers or Magnehelic gauges were leveled and zeroed.
- ▲ The temperature measurement systems were checked for damage and operability by measuring the ambient temperature.

Performance Audits: Performance audits of the laboratory are conducted prior to the processing of any compliance samples for analysis. Audit materials typically include samples available from the EPA prior to new source testing. Also, samples of known concentration are specially prepared in-house or obtained from the EPA for Internal QA checks.

External Systems Audits: Entropy is subject to a system audit each time a test is conducted for any Air Pollution Control agency. This procedure entails an EPA observer on-site to do qualitative evaluation of performance to demonstrate compliance with the applicable regulations.

5.7 Data Reduction and Validation. The test team leader is responsible for reviewing and validating data as they are acquired. Each team leader has extensive knowledge of sampling methodology and the characteristics of the process being measured and is capable of evaluating the accuracy, representativeness, and completeness of raw data on-site, where action to replace inadequate data can be taken immediately.

Data obtained during calibrations and test runs are recorded on standardized forms which are checked twice for completeness and accuracy by the QA Director or his designated representative. Data reduction and consistency are achieved by using the standardized forms and using Entropy's in-house computer facilities.

5.8 QA/QC Summary. All chemicals used were American Chemical Society (ACS), High Purity Liquid Chromatography (HPLC), or pesticide grade. The deionized, distilled water utilized met or exceeded the American Society for Testing and Materials (ASTM) specifications for Type-I reagent water. Pretest and posttest leak checks were conducted on each sampling train.

EPA MMTL. Field blanks were prepared at the SDA inlet and stack. The field blanks were analyzed for lead with none detected.

Matrix spikes were conducted on samples 1-I MMTL-3 and 1-S-MMTL-3. The samples were analyzed with 100% recovery for both.

Duplicate analyses were conducted on samples 1-I-MMTL-2 and 1-S-MMTL-2. Refer to Table 5-3 for the results.

TABLE 5-3
LEAD DUPLICATE ANALYSES RESULTS

	----- Duplicate Analyses -----		
	<u>First</u> <u>Analysis</u>	<u>Second</u> <u>Analysis</u>	<u>Relative %</u> <u>Difference</u> *
<u>MICROGRAMS CATCH</u> *****			
<u>SDA Inlet Samples</u> -----			
Run 1-I-MMTL-2	27,900	28,600	2.5
<u>Stack Samples</u> -----			
Run 1-S-MMTL-2	< 20.0	< 20.0	NA

*Not applicable if one or both results are below the detection limit.

APPENDIX A.1

A. TEST RESULTS

1. SDA Inlet

PLANT: Camden County Resource Recovery Facility, Camden, NJ

LOCATION: Unit No. 1 SDA Inlet

RUN #		DATE	OPERATOR			
1-I-MMTL-1		10/18/91	Reginald F. Holt			
1-I-MMTL-2		10/18/91	Reginald F. Holt			
1-I-MMTL-3		10/18/91	Reginald F. Holt			
				1-I-MMTL-1	1-I-MMTL-2	1-I-MMTL-3
				0820	1500	1845
Run Start Time				1355	1734	2055
Run Finish Time				24	24	24
Net Traversing Points				120.00	120.00	120.00
Theta	Net Run Time, Minutes			0.273	0.278	0.266
Dia	Nozzle Diameter, Inches			0.840	0.840	0.840
Cp	Pitot Tube Coefficient			0.9823	0.9823	0.9823
Y	Dry Gas Meter Calibration Factor			30.00	30.00	30.00
Pbar	Barometric Pressure, Inches Hg			1.31	1.20	1.15
Delta-H	Avg. Pressure Differential of Orifice Meter, Inches H ₂ O			76.117	73.326	72.097
Vm	Volume Of Metered Gas Sample, Dry ACF			95	102	99
tm	Dry Gas Meter Temperature, Degrees F			71.817	68.258	67.491
Vmstd	Volume Of Metered Gas Sample, Dry SCF*			229.5	209.5	241.5
Vlc	Total Volume of Liquid Collected in Impingers & Silica Gel, ml			10.843	9.899	11.410
Vwstd	Volume of Water Vapor, SCF*			13.1	12.7	14.5
%H ₂ O	Moisture Content, Percent by Volume			0.869	0.873	0.855
Mfd	Dry Mole Fraction			8.2	8.8	8.8
%CO ₂	Carbon Dioxide, Percent By Volume, Dry			11.0	10.3	10.2
%O ₂	Oxygen, Percent By Volume, Dry			29.75	29.82	29.82
Md	Gas Molecular Weight, lb/lb-Mole, Dry			28.21	28.32	28.11
Ms	Gas Molecular Weight, lb/lb-Mole, Wet			-2.00	-1.95	-2.05
Pg	Flue Gas Static Pressure, Inches H ₂ O			29.85	29.86	29.85
Ps	Absolute Flue Gas Pressure, Inches Hg			438	421	426
ts	Flue Gas Temperature, Degrees F			0.4528	0.3731	0.4310
Delta-p	Average Velocity Head, Inches H ₂ O			49.89	44.78	48.45
vs	Flue Gas Velocity, Feet/Second			4,536	4,536	4,536
A	Stack/Duct Area, Square Inches			48,267	44,362	46,747
Qsd	Volumetric Air Flow Rate, Dry SCFM*			94,296	84,641	91,576
Qaw	Volumetric Air Flow Rate, Wet ACFM			96.1	95.8	98.2
%I	Isokinetic Sampling Rate, Percent					

(Continued next page)

* 70° F (21° C) -- 29.92 Inches of Mercury (Hg)

ENTROPY

FIELD DATA AND RESULTS TABULATION
(Continued)

3

PLANT: Camden County Resource Recovery Facility, Camden, NJ

		1-1-MMTL-1	1-1-MMTL-2	1-1-MMTL-3
	<u>Lead</u>			
fw	Formula Weight, lb/lb-Mole	207.19	207.19	207.19
ug	Catch Weight, Micrograms	21400	28250	36500
ug/DSCM	Concentration, ug/DSCM *	10,522	14,614	19,097
ug@12%CO2	Concentration, ug/DSCM @ 12% CO2	15,398	19,928	26,041
ug@7%O2	Concentration, ug/DSCM @ 7% O2	14,731	19,121	24,755
gr/DSCF	Concentration, grains/DSCF *	0.00460	0.00639	0.00835
gr@12%CO2	Concentration, gr/DSCF @ 12% CO2	0.00673	0.00871	0.0114
gr@7%O2	Concentration, gr/DSCF @ 7% O2	0.00644	0.00836	0.0108
lb/hr	Emission Rate, lb/hr	1.90✓	2.43✓	3.34✓

* 70° F (21° C) -- 29.92 Inches of Mercury (Hg)

ENTROPY

APPENDIX A.2**A. TEST RESULTS****2. Stack**

PLANT: Camden County Resource Recovery Facility, Camden, NJ

LOCATION: Unit No. 1 Stack

RUN #		DATE	OPERATOR			
1-S-MMTL-1		10/18/91	James E. Daley			
1-S-MMTL-2		10/18/91	James E. Daley			
1-S-MMTL-3		10/18/91	James E. Daley			
				1-S-MMTL-1	1-S-MMTL-2	1-S-MMTL-3
Run Start Time				0820	1500	1845
Run Finish Time				1355	1734	2055
Net Traversing Points				24	24	24
Theta	Net Run Time, Minutes			120.00	120.00	120.00
Dia	Nozzle Diameter, Inches			0.274	0.274	0.274
Cp	Pitot Tube Coefficient			0.840	0.840	0.840
Y	Dry Gas Meter Calibration Factor			1.0095	1.0095	1.0095
Pbar	Barometric Pressure, Inches Hg			29.90	29.90	29.90
Delta-H	Avg. Pressure Differential of Orifice Meter, Inches H ₂ O			1.98	1.82	1.88
Vm	Volume Of Metered Gas Sample, Dry ACF			93.313	91.743	92.994
tm	Dry Gas Meter Temperature, Degrees F			89	92	99
Vmstd	Volume Of Metered Gas Sample, Dry SCF*			91.328	89.343	89.392
Vlc	Total Volume of Liquid Collected in Impingers & Silica Gel, ml			361.0	372.5	404.0
Vwstd	Volume of Water Vapor, SCF*			17.057	17.600	19.088
%H ₂ O	Moisture Content, Percent by Volume			15.7	16.5	17.6
Mfd	Dry Mole Fraction			0.843	0.835	0.824
%CO ₂	Carbon Dioxide, Percent By Volume, Dry			7.7	8.0	8.0
%O ₂	Oxygen, Percent By Volume, Dry			11.4	11.1	11.1
Md	Gas Molecular Weight, lb/lb-Mole, Dry			29.69	29.72	29.72
Ms	Gas Molecular Weight, lb/lb-Mole, Wet			27.85	27.79	27.66
Pg	Flue Gas Static Pressure, Inches H ₂ O			-0.32	-0.31	-0.32
Ps	Absolute Flue Gas Pressure, Inches Hg			29.88	29.88	29.88
ts	Flue Gas Temperature, Degrees F			275	278	277
Delta-p	Average Velocity Head, Inches H ₂ O			0.6127	0.5616	0.5699
vs	Flue Gas Velocity, Feet/Second			52.84	50.75	51.19
A	Stack/Duct Area, Square Inches			4,072	4,072	4,072
Qsd	Volumetric Air Flow Rate, Dry SCFM*			54,374	51,547	51,402
Qaw	Volumetric Air Flow Rate, Wet ACFM			89,635	86,092	86,833
XI	Isokinetic Sampling Rate, Percent			96.6	99.7	100.1

* 70° F (21° C) -- 29.92 Inches of Mercury (Hg)

(Continued next page)

FIELD DATA AND RESULTS TABULATION
(Continued)

6

PLANT: Camden County Resource Recovery Facility, Camden, NJ

		1-S-MMTL-1		1-S-MMTL-2		1-S-MMTL-3
	<u>Lead</u>					
fwt	Formula Weight, lb/lb-Mole	207.19		207.19		207.19
ug	Catch Weight, Micrograms	44	<	20	<	20
ug/DSCM	Concentration, ug/DSCM *	17.0	<	7.90	<	7.90
ug@12%CO2	Concentration, ug/DSCM @ 12% CO2	26.5	<	11.9	<	11.9
ug@7%O2	Concentration, ug/DSCM @ 7% O2	24.8	<	11.2	<	11.2
gr/DSCF	Concentration, grains/DSCF *	7.44E-006	<	3.45E-006	<	3.45E-006
gr@12%CO2	Concentration, gr/DSCF @ 12% CO2	1.16E-005	<	5.18E-006	<	5.18E-006
gr@7%O2	Concentration, gr/DSCF @ 7% O2	1.08E-005	<	4.89E-006	<	4.88E-006
lb/hr	Emission Rate, lb/hr	0.00347	<	0.00153	<	0.00152

* 70° F (21° C) -- 29.92 Inches of Mercury (Hg)

< Indicates the value is below the detection limit.

ENTROPY

APPENDIX A.3

A. TEST RESULTS

3. Example Calculations

NOTE

The example values shown in these calculations have been rounded for presentation purposes. Any hand calculations conducted using these example values may produce slightly different results than those presented.

EXAMPLE TEST CALCULATIONS RUN 1-S-MMTL-1

Unit No. 1 Stack

VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS

$$Vmstd = Y * Vm * \frac{Pbar + (\Delta H/13.6)}{(460 + tm)} * \frac{460 + tstd}{Pstd}$$

$$Vmstd = 1.0095 * 93.313 * \frac{29.90 + (1.980/13.6)}{(460 + 89)} * \frac{460 + 70}{29.92} = 91.328 \text{ DSCF}$$

VOLUME OF WATER VAPOR AT STANDARD CONDITIONS

$$Vwstd = 0.04707 * Vlc * (460 + tstd)/528$$

$$Vwstd = 0.04707 * 361.0 * (460 + 70)/528 = 17.057 \text{ SCF}$$

PERCENT MOISTURE, BY VOLUME, AS MEASURED IN FLUE GAS

$$\%H_2O = 100 * Vwstd / (Vwstd + Vmstd)$$

$$\%H_2O = \frac{17.057}{17.057 + 91.328} * 100 = 15.7 \%$$

ABSOLUTE FLUE GAS PRESSURE

$$Ps = Pbar + (Pg / 13.6)$$

$$Ps = 29.90 + (-0.32/13.6) = 29.88 \text{ inches Hg}$$

DRY MOLE FRACTION OF FLUE GAS

$$Mfd = 1 - \%H_2O / 100$$

$$Mfd = 1 - 15.7/100 = 0.843$$

DRY MOLECULAR WEIGHT OF FLUE GAS

$$Md = (\%CO_2/100 * 44) + (\%O_2/100 * 32) + ((100 - \%CO_2 - \%O_2)/100 * 28)$$

$$Md = (7.7/100 * 44) + (11.4/100 * 32) + ((100 - 7.7 - 11.4)/100 * 28)$$

$$Md = 29.69 \text{ lb/lb-Mole}$$

WET MOLECULAR WEIGHT OF FLUE GAS

$$Ms = (Md * Mfd) + (0.18 * \%H_2O)$$

$$Ms = (29.69 * 0.843) + (0.18 * 15.7) = 27.85 \text{ lb/lb-Mole}$$

AVERAGE FLUE GAS VELOCITY [Note: (Delta p)avg is square of average square root]

$$v_s = 85.49 * C_p * \left[\frac{(\Delta P)_{avg} * (460 + t_s)}{P_s * M_s} \right]^{\frac{1}{2}}$$

$$v_s = 85.49 * 0.840 * \left[\frac{0.6127 * (460 + 275)}{29.88 * 27.85} \right]^{\frac{1}{2}} = 52.84 \text{ ft/sec}$$

DRY VOLUMETRIC FLUE GAS FLOW RATE AT STANDARD CONDITIONS

$$Q_{sd} = \frac{60}{144} * M_{fd} * v_s * A * \frac{460 + t_{std}}{460 + t_s} * \frac{P_s}{P_{std}}$$

$$Q_{sd} = \frac{60}{144} * 0.843 * 52.84 * 4,071.5 * \frac{460 + 70}{460 + 275} * \frac{29.88}{29.92}$$

$$Q_{sd} = 54,374 \text{ DSCFM}$$

WET VOLUMETRIC FLUE GAS FLOW RATE AT ACTUAL CONDITIONS

$$Q_{aw} = 60 / 144 * v_s * A$$

$$Q_{aw} = 60 / 144 * 52.84 * 4,071.5 = 89,635 \text{ ACFM}$$

PERCENT ISOKINETIC OF SAMPLING RATE

$$\%I = \frac{P_{std}}{460 + t_{std}} * \frac{100}{60} * \frac{(t_s + 460) * V_{mstd}}{P_s * v_s * M_{fd} * \Theta * (\pi * (\text{NozzleDia}/2)^2 / 144)}$$

$$\%I = \frac{29.92}{460 + 70} * \frac{100}{60} * \frac{(275 + 460) * 91.328}{29.88 * 52.84 * 0.843 * 120.00 * (\pi * (0.274/2)^2 / 144)}$$

$$\%I = 96.6 \%$$

CONCENTRATION, MICROGRAMS PER DRY STANDARD CUBIC METER, LEAD

$$\text{ug/DSCM} = \frac{(\text{ug} / 10^6)}{V_{mstd} * 0.02832} * 10^6$$

$$\text{ug/DSCM} = \frac{(44.0/10^6)}{91.328 * 0.02832} * 10^6 = 17.0 \text{ ug/DSCM}$$

CONCENTRATION, MICROGRAMS PER DSCM CORRECTED TO 12% CO₂, LEAD

$$\text{ugDSCM@12\%} = \text{ug/DSCM} * (12 / \%CO_2)$$

$$\text{ugDSCM@12\%} = 17.0 * (12 / 7.7) = 26.5 \text{ ug/DSCM @ 12\% CO}_2$$

CONCENTRATION, MICROGRAMS PER DSCM CORRECTED TO 7% O₂, LEAD

$$\text{ugDSCM@7\%} = \text{ug/DSCM} * \frac{21.0 - 7}{21.0 - \%O_2}$$

$$\text{ugDSCM@7\%} = 17.0 * \frac{21.0 - 7}{21.0 - 11.4} = 24.8 \text{ ug/DSCM @ 7\% O}_2$$

CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT, LEAD

$$\text{gr/DSCF} = \frac{7,000}{453.592} * \frac{(\text{ug} / 10^6)}{V_{\text{mstd}}}$$

$$\text{gr/DSCF} = \frac{7,000}{453.592} * \frac{(44.0/10^6)}{91.328} = 7.44\text{E-}006 \text{ gr/DSCF}$$

CONCENTRATION, GRAINS PER DSCF CORRECTED TO 12% CO₂, LEAD

$$\text{gr@12\%} = \text{gr/DSCF} * (12 / \%CO_2)$$

$$\text{gr@12\%} = 7.44\text{E-}006 * (12 / 7.7) = 1.16\text{E-}005 \text{ gr/DSCF @ 12\% CO}_2$$

CONCENTRATION, GRAINS PER DSCF CORRECTED TO 7% O₂, LEAD

$$\text{gr@7\%} = \text{gr/DSCF} * \frac{21.0 - 7}{21.0 - \%O_2}$$

$$\text{gr@7\%} = 7.44\text{E-}006 * \frac{21.0 - 7}{21.0 - 11.4} = 1.08\text{E-}005 \text{ gr/DSCF @ 7\% O}_2$$

EMISSION RATE, POUNDS PER HOUR, LEAD

$$\text{lb/hr} = \frac{60}{453.592} * \frac{(\text{ug} / 10^6)}{V_{\text{mstd}}} * Q_{\text{sd}}$$

$$\text{lb/hr} = \frac{60}{453.592} * \frac{(44.0/10^6)}{91.328} * 54,374 = 0.00347 \text{ lb/hr}$$

APPENDIX B.1

B. FIELD AND ANALYTICAL DATA


1. SDA Inlet

METHOD 3 (ORSAT) FIELD DATA

13


Plant Name/Address CamdenJob No. 10735Sampling Location Unit 1 SDA InletFuel Type 400

Run/Sample No. 1-I-M3-1 Leak ☒ Date 10-18-91 Operator JCN

Time of Sample Collection	Time of Analysis	CO ₂ Reading (A)	O ₂ Reading (B)	CO Reading (C)	% O ₂ (B-A)	% CO (C-B)	% N ₂ (100-C)
0820	1520	8.2	19.2	—	11.0	—	
↓	1540	8.1	19.1	—	11.0	—	
1355	1550	8.2	19.2	—	11.0	—	
Avg.		8.2	Avg.		11.0	—	80.8


Orsat I.D. 1 Tedlar Bag I.D. 48 F_o

Run/Sample No. 1-I-M3-2 Leak ☒ Date 10-18 Operator JCN

Time of Sample Collection	Time of Analysis	CO ₂ Reading (A)	O ₂ Reading (B)	CO Reading (C)	% O ₂ (B-A)	% CO (C-B)	% N ₂ (100-C)
1500	1830	8.8	19.1	—	10.3	—	
↓	1840	8.8	19.0	—	10.2	—	
1734	1850	8.8	19.1	—	10.3	—	
Avg.		8.8	Avg.		10.3	—	80.9

Orsat I.D. 1 Tedlar Bag I.D. 6 F_o

Run/Sample No. 1-I-M3-3 Leak ☒ Date 10-18 Operator JCN

Time of Sample Collection	Time of Analysis	CO ₂ Reading (A)	O ₂ Reading (B)	CO Reading (C)	% O ₂ (B-A)	% CO (C-B)	% N ₂ (100-C)
1845	2125	8.8	19.0	—	10.2	—	
↓	2135	8.8	19.0	—	10.2	—	
2035	2145	8.8	19.0	—	10.2	—	
Avg.		8.8	Avg.		10.2	—	81.0

Orsat I.D. 1 Tedlar Bag I.D. 65 F_o

PLANT Foster Wheeler - Camden Co. - RRF FIELD DATA - METHOD(S) MMTL RUN NO. 1-I-MMTL-2
 CITY/STATE Camden, New Jersey JOB NO. 10535-1 DATE 10-18-91
 SAMPLING LOC. Unit 1 - Inlet TIME START 1500
 BAROMETRIC PRESSURE, IN. HG 30.0 STATIC PRESSURE, IN. H₂O -1.95 TIME FINISH 1734
 LEAK CHECK, VACUUM IN. HG 15 7 15 17 OPERATOR RFH
 LEAK RATE, CUBIC FEET/MIN. 0.002 0.002 0.003 0.003 ASST(S) WEM

EQUIPMENT CHECKS*		EQUIPMENT I.D. NUMBERS		LEAK CHECKS	
☒ PITOT, PRETEST	REAGENT BOX <u>M111</u>	METER BOX <u>N-23</u>	<u>Y 0.9823</u>	B <u>842.59</u>	B
☒ PITOT, POSTTEST	PITOT <u>8-12</u>	NOZ. <u>GL/23</u>	DIA. <u>0.278</u>	E <u>842.68</u>	E
☒ NOZZLE, PRE/POST	TC READOUT <u>F-1</u>	TC PROBE <u>R94</u>	UMBILICAL <u>U90</u>	B <u>865.327</u>	B
☒ TC <u>84</u> °F PRE	SAMPL'G BOX <u>74</u>	ORSAT PUMP <u>5</u>	TEDLAR BAG <u>6</u>	E <u>865.977</u>	E
☒ TC <u>88</u> °F POST				B	B
☒ ORSAT SYSTEM				E	E
FILTER/XAD #1 <u>Q1033</u> <u>0.5179</u> #2 <u>Q1034</u> <u>0.5260</u>		NOMOGRAPH DATA DELTA HG <u>1.827</u> <u>1.827</u> METER TEMP <u>180</u> <u>110</u> EST. XH ₂ O <u>15</u> <u>15</u> C FACTOR <u>0.880</u> <u>0.864</u> STACK TEMP <u>425</u> <u>425</u> REF DELTA P <u>0.565</u> <u>0.573</u> K FACTOR <u>3.209</u> <u>3.212</u>		FYRITES Part A <u>9.5%</u> Part B <u>9%</u>	

* PITOT: VISUAL INSPECTION/LEAK CHECK; NOZZLE: VISUAL INSPECTION; TC: AMBIENT TEMPS.; ORSAT SYSTEM: LEAK CHECK

LINE	SAMPLE POINT	CLOCK TIME MINUTES	DRY GAS METER READING CUBIC FEET	PITOT READING IN. H ₂ O	GAS METER TEMP. °F	STACK TEMP. °F	ORIFICE SETTING IN. H ₂ O		GAUGE VACUUM IN. HG	GAS TEMPERATURES °F		PROBE OR COND EXIT**	✓
							ACTUAL	IDEAL		FILTER *	IMPING. EXIT		
1	A-1	0/0N	806.390	0.23	94	420	0.72	0.72	2	251	57	NA	
2	2	5	808.78	0.33	94	420	1.04	1.04	2	250	56		
3	3	10	811.64	0.37	95	422	1.16	1.16	2	250	55		
4	4	15	814.70	0.36	97	434	1.12	1.12	3	251	55		
5	5	20	817.65	0.36	98	434	1.12	1.12	3	251	54		
6	6	25	820.63	0.37	100	432	1.16	1.16	4	252	54		
7	7	30	823.68	0.38	101	430	1.20	1.20	4	253	53		
8	8	35	826.78	0.46	102	432	1.45	1.45	5	254	54		
9	9	40	830.11	0.44	103	425	1.40	1.40	6	255	54		
10	10	45	833.47	0.36	104	412	1.16	1.16	6	255	55		
11	11	50	836.57	0.34	105	410	1.10	1.10	6	256	55		
12	12	55	839.55	0.35	105	412	1.13	1.13	7	255	56		
13	B-1	60/0	842.59	0.21	103	415	0.67	0.67	7	256	56		
14	2	5	844.84	0.28	102	414	0.90	0.90	7	255	56		
15	3	10	847.52	0.37	102	413	1.19	1.19	8	256	55		
16	4	15	850.55	0.37	103	450	1.14	1.14	8	257	54		
17	5	20	853.18	0.37	104	447	1.15	1.15	9	258	54		
18	6	25	856.20	0.41	105	447	1.28	1.28	10	258	55		
19	7	30	859.39	0.46	106	428	1.46	1.46	12	257	54		
20	8	35	862.78	0.60	108	407	1.96	1.96	17	257	54		
21	9	40	866.75	0.43	104	407	1.39	1.39	3	255	55		
22	10	45	870.12	0.42	106	400	1.38	1.38	4	253	57		
23	11	50	873.46	0.42	108	400	1.38	1.38	5	252	58		
24	12	55	876.80	0.36	109	399	1.19	1.19	5	250	58		
25		60/0N	879.896										✓

* FILTER EXIT for NJ Method 1. FILTER BOX for all others.

** PROBE EXIT & ✓ (probe & filter heat off) apply to NJ Method 1. COND EXIT applies if sampling train has a condenser.

120 73.324 0.3731 102.42 421.29 1.20
 Min. (θ) Vm (√ΔP)² tm ts ΔH

ENTROPY

PLANT Foster Wheeler - Camden Co. - RRF FIELD DATA - METHOD(S) MMTL RUN NO. 1-I-MMTL-1
 CITY/STATE Camden, New Jersey JOB NO. 10535-1 DATE 10-18-91
 SAMPLING LOC. Unit 1 - Inlet TIME START 0820
 BAROMETRIC PRESSURE, IN. HG 30.0 STATIC PRESSURE, IN. H₂O -2.0 TIME FINISH 1355
 LEAK CHECK, VACUUM IN. HG 15 9 14 14 OPERATOR RFH
 LEAK RATE, CUBIC FEET/MIN. 0.001 0.003 0.003 0.003 ASST(S) WEM

EQUIPMENT CHECKS*		EQUIPMENT I.D. NUMBERS				LEAK CHECKS	
✓ PITOT, PRETEST	REAGENT BOX <u>MILL</u>	METER BOX <u>N-23</u>	Y <u>0.9823</u>	B <u>768.084</u>	B		
✓ PITOT, POSTTEST	PITOT <u>8-5</u>	Cp <u>84</u>	NOZ. <u>GL 88</u>	DIA. <u>0.273</u>	E <u>768.170</u>	E	
✓ NOZZLE, PRE/POST	TC READOUT <u>F-1</u>	TC PROBE <u>R271</u>	UNBILICAL <u>1490</u>	B <u>789.420</u>	B		
✓ TC <u>69</u> °F PRE	SAMPL'G BOX <u>63</u>	ORSAT PUMP <u>5</u>	TEDLAR BAG <u>48</u>	E <u>789.574</u>	E		
✓ TC <u>84</u> °F POST					B		
✓ ORSAT SYSTEM					E		
		MONOGRAPH DATA					
FILTER/XAD		TARE WT.	DELTA HG <u>1.827</u>				
<u>Q1028</u>		<u>0.5089</u>	METER TEMP <u>83</u>				
<u>Q1020</u>		<u>0.5210</u>	EST. XH ₂ O <u>15</u>				
			C FACTOR <u>0.823</u>				
			STACK TEMP <u>425</u>				
			REF DELTA P <u>0.647</u>				
			K FACTOR <u>2.846</u>				
				FYRITES			
				ROCK A <u>9%</u>			
				ROCK B <u>9.5%</u>			

* PITOT: VISUAL INSPECTION/LEAK CHECK; NOZZLE: VISUAL INSPECTION; TC: AMBIENT TEMPS.; ORSAT SYSTEM: LEAK CHECK

LINE	SAMPLE POINT	CLOCK TIME MINUTES	DRY GAS METER READING CUBIC FEET	PITOT READING IN. H ₂ O	GAS METER TEMP. °F	STACK TEMP. °F	ORIFICE SETTING IN. H ₂ O		GAUGE VACUUM IN. HG	GAS TEMPERATURES °F			✓
							ACTUAL	IDEAL		FILTER *	IMPING. EXIT	OR COND. EXIT**	
1	A-1	0/DN	729.668	0.24	77	420	0.68	0.68	2	240	58	n/a	
2	2	5	732.01	0.42	82	420	1.20	1.20	2	240	56		
3	3	10	734.96	0.44	85	422	1.26	1.26	3	245	55		
4	4	15	738.04	0.50	87	439	1.41	1.41	4	246	55		
5	5	20	741.30	0.50	89	446	1.41	1.41	5	248	54		
6	6	25	744.58	0.60	91	455	1.68	1.68	6	250	55		
7	7	30	748.12	0.58	93	454	1.63	1.63	7	249	56		
8	8	35	751.55	0.50	92	438	1.43	1.43	7	248	55		
9	9	40	754.88	0.49	94	432	1.41	1.41	7	247	54		
10	10	45	758.17	0.47	97	427	1.37	1.37	8	247	55		
11	11	50	761.46	0.49	98	428	1.43	1.43	9	248	56		
12	12	55	764.78	0.47	99	431	1.37	1.37	9	248	57		
13	B-1	60/0	768.084	0.27	94	419	0.79	0.79	6	250	55		
14	2	5	770.64	0.43	96	420	1.26	1.26	9	249	56		
15	3	10	773.78	0.47	98	466	1.31	1.31	9	249	56		
16	4	15	776.97	0.34	100	466	0.95	0.95	9	248	55		
17	5	20	779.81	0.48	100	464	1.35	1.35	11	248	54		
18	6	25	783.00	0.49	101	463	1.38	1.38	12	249	55		
19	7	30	786.29	0.55	102	446	1.58	1.58	14	250	54		
20	8	35	789.91	0.50	99	446	1.43	1.43	3	250	54		
21	9	40	793.31	0.49	102	473	1.37	1.37	3	248	55		
22	10	45	796.62	0.36	102	411	1.08	1.08	3	249	54		
23	11	50	799.57	0.46	101	408	1.38	1.38	4	250	53		
24	12	55	802.83	0.43	102	408	1.29	1.29	5	250	53		
25		60/6A	806.025										

* FILTER EXIT for NJ Method 1. FILTER BOX for all others.

** PROBE EXIT & ✓ (probe & filter heat off) apply to NJ Method 1. COND. EXIT applies if sampling train has a condenser.

120 31.117 0.4528 75.04 437.58 1.31
 Min. (θ) Vm (ΔP)² tm ts ΔH

ENTROPY

[illegible][illegible]

F-1112 (Page 1) 9-

MOISTURE SAMPLING LABORATORY RESULTS

Plant Name: CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES

EEI Ref# 10535

Sampling Location: UNIT #1 SDA INLET

Date Received: 10/29/91 Date Analyzed: 10/18/91 Reagent Box(es): M111

Run Number	1-I-MMTL-1	1-I-MMTL-2	1-I-MMTL-3
Run Date	10/18/91	10/18/91	10/18/91

ANALYSIS OF MOISTURE CATCH

Reagent 1 (H2O)			
Final Weight, g.	478.5	456.5	494.0
Tared Weight, g.	269.0	267.0	270.0
	=====	=====	=====
Water Catch, g.	209.5	189.5	224.0
Reagent 2 ()			
Final Weight, g.			
Tared Weight, g.			
	=====	=====	=====
Water Catch, g.	0.0	0.0	0.0
Reagent 3 ()			
Final Weight, g.			
Tared Weight, g.			
	=====	=====	=====
Water Catch, g.	0.0	0.0	0.0
CONDENSED WATER, g.	209.5	189.5	224.0
Silica Gel:			
Final Weight, g.	220.0	220.0	217.5
Tared Weight, g.	200.0	200.0	200.0
	=====	=====	=====
ADSORBED WATER, g.	20.0	20.0	17.5
TOTAL WATER COLLECTED, g.	229.5	209.5	241.5

MOISTURE SAMPLING LABORATORY RESULTS

Plant Name: CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES

EEI Ref# 10535

Sampling Location: UNIT #1 INLET AND STACK

Date Received: 10/29/91 Date Analyzed: 10/18/91 Reagent Box(es): M136

Run Number	1-S-MMTL-FB	1-I-MMTL-FB
Run Date	10/18/91	10/18/91

ANALYSIS OF MOISTURE CATCH

Reagent 1 (H2O)

Final Weight, g.

270.5

270.5

Tared Weight, g.

271.0

271.0

=====

=====

Water Catch, g.

-0.5

-0.5

Reagent 2 ()

Final Weight, g.

Tared Weight, g.

=====

=====

Water Catch, g.

0.0

0.0

Reagent 3 ()

Final Weight, g.

Tared Weight, g.

=====

=====

Water Catch, g.

0.0

0.0

CONDENSED WATER, g.

-0.5

-0.5

Silica Gel:

Final Weight, g.

Tared Weight, g.

=====

=====

ADSORBED WATER, g.

0.0

0.0

TOTAL WATER COLLECTED, g.

-0.5

-0.5

OL: 910366

SAMPLE SUBMISSION FORM
Oxford Laboratory

1818

Submitted By		Date Submitted 10-22-91		Date Requested 11-5-91	
Company Name <i>Enron</i>		Attention <i>Rick Sullivan</i>			
Address		State		Zip Code	
Telephone		Received By			
No. of Samples & Identification: Purchase Order# <i>1781-10535</i>					
1.	<i>1-5-mm TL-1</i>	(7)	<i>1-1-mm TL-1</i>		
2.	<i>2</i>	(8)	<i>2</i>		
3.	<i>2 Duplicate</i>	(9)	<i>2 Duplicate</i>		
4.	<i>3</i>	(10)	<i>3</i>		
5.	<i>3 Spike</i>	(11)	<i>3 Spike</i>		
6.	<i>FB</i>	(12)	<i>FB</i>		

Analyses Requested and Special Instructions:

DL - 2048

Custody

[illegible]

OL# 91103667

pg 282

20

SAMPLE SUBMISSION FORM
Oxford Laboratory

Submitted By _____ Date Submitted 10-28-91 Date Requested _____
 Company Name Environ Attention _____ State _____ Zip Code _____
 Address _____ Received By _____
 Telephone _____
 No. of Samples & Identification: Purchase Order#

1. 13 Blanks
 2. 4 Method Code

3.

4.

5.

6.

Analyses Requested and Special Instructions:

Results:

adTotal13
< 20.064
7420

3

4

5

6

A.A. SUMMARY REPORT

C ENTROPY

P.D.#/PROJECT 8:1781-10535

ANALYST: KEN SMITH

DATE: 10/28/91

 X NT. STD
 CONC STD
 .100 INST LIMIT
 1 SPK LEVEL
 1.00 MAX ALIQUOT
 .1 N.D.L.

SAMPLE I.D.	EL	MEAN ABS	CONC	ALIGN	DILUTION	TOTAL ug	ANGWER	% REC OR <	SPIKE LEVEL
3667-01	Pb	.0025371	.22	1	200	44.0			
3667-02	Pb	.002185	.02	1	200 <			20.0	
3667-03	Pb	.0047468	.07	1	200 <			20.0	
3667-04	Pb	.003322	.03	1	200 <			20.0	
3667-05-004SPK	Pb	.0114054	1	1	400	400		100	1
3667-06	Pb	.0008137	.07	1	200 <			20.0	
3667-07	Pb	.0423239	5.34	1	4000	21360			
3667-08	Pb	.0819021	6.97	1	4000	27880			
3667-09	Pb	.0840422	7.14	1	4000	28560			
3667-10	Pb	.1084626	9.13	1	4000	36520			
3667-11-010SPK	Pb	.1147851	9.63	1	4000	38520		100	.5
3667-12	Pb	.0009497	.08	1	200 <			20.0	
3667-13	Pb	-.000018	0	1	200 <			20.0	

AS Position 3	Pb	.0466448	4.03	0	0				
AS Position 3	Pb	.0465021	4.01	0	0				
AS Position 3	Pb	.0464375	4.01	0	0				
A' ition 3	Pb	.0459738	3.97	0	0				
B.	Pb	-.000375	-.03	0	0				
Blank	Pb	-.000183	-.02	0	0				
Blank	Pb	.0004576	.04	0	0				
Blank	Pb	-.000409	-.05	0	0				
B.L.=	Pb	.0009497	.08	0	0				
OLI BLK	Pb	.0004436	.04	0	0				
PE KNOWN	Pb	.0124019	1.09	1	1	1.09			
Std 1=50ug/ml	Pb	.0035868	.51	0	0				
Std 2=4.0ug/ml	Pb	.0476413	4.26	0	0				
Std 3=10.0ug/ml	Pb	.1181336	8.99	0	0				
Std Blank	Pb	-.000051	0	0	0				

RECORD OF CUSTODY, CONTAINER NO. M111

22

Container Type (check) ☒ Reagent Box ☐ Cooler ☐ Other (specify) _____

Plant Name/Address CCERA

Job No. 10535 Sampling Method MMTL-Pb (EPA, NIOSH, etc.)

Seal ID	Date	Time	*	Full Signature	Reason for Breaking Seal**
638	10-10	9:15	S	Bobby L. Bell	
	10-9	1:15	B	XXXX	Chay Ham
1536	10-19		S	XXXX	
	10-20	1:15	B	XXXX	Chay Ham - in a bag
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		

* S = Sealed By; B = Broken By ** Use "REMARKS" Section if more space needed.

Received by Sample Custodian

DR P. A. 10-21-91 9:50 Seal Intact? Yes No

Signature Date Time

As Applicable:
All liquid levels at mark (check)? ☐ YES ☐ NO (Estimate loss if not at mark; describe in "REMARKS")

As Applicable:
TUBE SAMPLES put in freezer by _____ Date _____ Time _____

CONDENSATE SAMPLES put in refrige. by _____ Date _____ Time _____

REMARKS _____

FIELD SAMPLE RECOVERY QUALITY CONTROL

Box No. M111 Assembly Date 10/9/91 Assembled By dlk⁸³
 Plant Name/address CS&A Job No. 10595
 Sampling Loc. UNIT 1042T Method NMTL/A6
 Individual Tare Of Reagent 200 (Ml) (gm) Of HNO₃ / 10% H₂O₂
 Individual Tare Of Reagent _____ (Ml) (gm) Of _____
 Individual Tare Of Reagent _____ (Ml) (gm) Of _____
 Individual Tare Of Sil. Gel 200 Gm _____ other (specify) _____

Run Number	Run Date	Filter or XAD Number	Tare, grams	Liquid Tare at Mark? @	Init.	Sample Recov. Date	%Sil. Gel Spent	Liquid Level Marked?	Init.
1-I-NMTL/A6-1	10-18	N/A		✓	AS	10-18	50	✓	AS

Filter Appearance* grey-black
2 filters - many ash particles
 Reagents Appearance*
Clear

1-I-NMTL/A6-2	10-18	N/A		✓	AS	10-18	50	✓	AS
---------------	-------	-----	--	---	----	-------	----	---	----

Filter Appearance* "
2 filters -
 Reagents Appearance*
Clear

1-I-NMTL/A6-3	10-18	N/A		✓	AS	10-18	55	✓	AS
---------------	-------	-----	--	---	----	-------	----	---	----

Filter Appearance* "
1 filter -
 Reagents Appearance*
Clear

--	--	--	--	--	--	--	--	--	--

Filter Appearance* _____
 Reagents Appearance* _____

* Use "REMARKS" section if needed.

@ All liquid levels at mark? (check) YES _____ NO _____ (estimate loss if not at mark; use "REMARKS" section).

REMARKS _____

Custodian DR P.A. Date 10-21-91 Time 9:50
 9-1002 rev. 10-91

ENTROPY

.266
6287

RECORD OF CUSTODY, CONTAINER NO. M136

24

Container Type (check) ☒ Reagent Box ☐ Cooler ☐ Other (specify) _____

Plant Name/Address CEEA; Canaan, N.J.

Job No. 10585 Sampling Method MMTC/Pb (EPA, NIOSH, etc.)

Seal ID	Date	Time	*	Full Signature	Reason for Breaking Seal**
647	10-10	9:15	S	Billy L. Bell Jr.	
	10-18	8:25	B	[Signature]	Change Polarity
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		

* S = Sealed By; B = Broken By ** Use "REMARKS" Section if more space needed.

Received by Sample Custodian

[Signature]
Signature

10-21-91
Date

9:45
Time

Seal Intact?
Yes ☒ No ☐

As Applicable:

All liquid levels at mark (check)? ☐ YES ☐ NO (Estimate loss if not at mark; describe in "REMARKS")

As Applicable:

TUBE SAMPLES put in freezer by _____ Date _____ Time _____

CONDENSATE SAMPLES put in refrige. by _____ Date _____ Time _____

REMARKS _____

FIELD SAMPLE RECOVERY QUALITY CONTROL

25

Box No. M136

Assembly Date 10/9/91

Assembled By dkk

Plant Name/address CCERA

Job No. 10535

Sampling Loc. UNIT 1 STACKWELL

Method MMTL/RS

Individual Tare Of Reagent 200 (Ml) (gm) Of 5% HNO₃ / 10% H₂O₂

Individual Tare Of Reagent _____ (Ml) (gm) Of _____

Individual Tare Of Reagent _____ (Ml) (gm) Of _____

Individual Tare Of Sil. Gel ~200 Gm _____ other (specify) _____

Run Number	Run Date	Filter or XAD Number	Tare, grams	Liquid Tare at Mark? @	Init.	Sample Recov. Date	%Sil. Gel Spent	Liquid Level Marked?	Init.
1-S-MMTL-FB	10-18			✓	245	10-18	0	-	245

Filter Appearance*

Clear

Reagents Appearance*

Clear

1-I-MMTL-FB	10-18			✓	245	10-18	0	-	245
-------------	-------	--	--	---	-----	-------	---	---	-----

Filter Appearance*

Clear

Reagents Appearance*

Clear

DEADEND	10-18								
---------	-------	--	--	--	--	--	--	--	--

BLANKS

Filter Appearance*

Reagents Appearance*

--	--	--	--	--	--	--	--	--	--

Filter Appearance*

Reagents Appearance*

* Use "REMARKS" section if needed.

@ All liquid levels at mark? (check) YES _____ NO _____ (estimate loss if not at mark; use "REMARKS" section).

REMARKS _____

Custodian DRR
Q-1002 rev. 10-91

Date 10-21-91 Time 9:40

ENTROPY

REQUEST FOR ANALYSIS

PO#: 1781-10535

Customer Name: Camden Co. RRF
Camden, NJ

Laboratory: OLI


Date Transmitted: 10/21/91

Results Due By: 11/05/91

Sample Matrix: MMTL

Analysis: Analyze for Pb by MMTL method. [detection limit = 20µg]

Sample #	Sample ID	Components/Comments
1	1-S-MMTL-1	-FH,-BH,-F,-R
2	1-S-MMTL-2	-FH,-BH,-F,-R
3	1-S-MMTL-2	duplicate analysis
4	1-S-MMTL-3	-FH,-BH,-F,-R
5	1-S-MMTL-3	matrix spike
6	1-S-MMTL-FB	-FH,-BH,-F,-R
7	1-I-MMTL-1	-FH,-BH,-F,-R
8	1-I-MMTL-2	-FH,-BH,-F,-R
9	1-I-MMTL-2	duplicate analysis
10	1-I-MMTL-3	-FH,-BH,-F,-R
11	1-I-MMTL-3	matrix spike
12	1-I-MMTL-FB	-FH,-BH,-F,-R
13	Blanks	HNO3/H2O2, 0.1N HNO3, filter

Submitted By: 

APPENDIX B.2


B. FIELD AND ANALYTICAL DATA

2. Stack

METHOD 3 (ORSAT) FIELD DATA


Plant Name/Address Carden Job No. 10575²⁸
 Sampling Location Unit 1 Stack Fuel Type _____

Run/Sample No. 1-S-M3-1 Leak ☒ Date 10-18-51 Operator gcn

Time of Sample Collection	Time of Analysis	CO ₂ Reading (A)	O ₂ Reading (B)	CO Reading (C)	% O ₂ (B-A)	% CO (C-B)	% N ₂ (100-C)
0820	1600	7.7	19.1		11.4		
↓	1610	7.7	19.1		11.4		
1355	1620	7.7	19.1		11.4		
Avg.		7.7	Avg.		11.4		80.9


Orsat I.D. 1 Tedlar Bag I.D. 21 F_o _____

Run/Sample No. 1-S-M3-2 Leak ☒ Date 9-18 Operator Jcn

Time of Sample Collection	Time of Analysis	CO ₂ Reading (A)	O ₂ Reading (B)	CO Reading (C)	% O ₂ (B-A)	% CO (C-B)	% N ₂ (100-C)
1500	1900	8.0	19.1		11.1		
↓	1910	8.0	19.1		11.1		
1734	1920	8.0	19.0		11.0		
Avg.		8.0	Avg.		11.1		80.9

Orsat I.D. 1 Tedlar Bag I.D. 62 F_o _____

Run/Sample No. _____ Leak ☐ Date _____ Operator _____

Time of Sample Collection	Time of Analysis	CO ₂ Reading (A)	O ₂ Reading (B)	CO Reading (C)	% O ₂ (B-A)	% CO (C-B)	% N ₂ (100-C)
1845	2155	8.0	19.1		11.1		
↓	2205	8.0	19.0		11.0		
2055	2215	8.0	19.1		11.1		
Avg.		8.0	Avg.		11.1		80.9

Orsat I.D. 1 Tedlar Bag I.D. 50 F_o _____

FIELD DATA - METHOD(S) MMT

PLANT FOSTER WHEELER CAMDEN CO.

JOB NO. 10635

DATE 10/18/91

CITY/STATE CAMDEN NJ

TIME START 0820

SAMPLING LOC. UNIT #1 STACK

TIME FINISH 1355

BAROMETRIC PRESSURE, IN. HG 29.9

STATIC PRESSURE, IN. H₂O -.32

OPERATOR JED

LEAK CHECK, VACUUM IN. HG 15 15 15 15

ASST(S) SGD

LEAK RATE, CUBIC FEET/MIN. 0.000 0.000 0.000 0.000

EQUIPMENT CHECKS*		EQUIPMENT I.D. NUMBERS		LEAK CHECKS																													
☒ PITOT, PRETEST	REAGENT BOX <u>M114</u>	METER BOX <u>N-27</u>	Y <u>1.0095</u>	B <u>682.428</u>	B																												
☒ PITOT, POSTTEST	PITOT <u>8-15</u>	TC PROBE <u>R-187</u>	UNBILICAL <u>U-68</u>	E <u>682.830</u>	E																												
☒ NOZZLE, PRE/POST	TC READOUT <u>F-23</u>	ORSAT PUMP <u>3416</u>	TEDLAR BAG <u>21</u>	B <u>703.917</u>	B																												
☒ TC <u>78</u> °F PRE	SAMPL'G BOX <u>53</u>			E <u>704.026</u>	E																												
☒ TC <u>276</u> °F POST																																	
☒ ORSAT SYSTEM																																	
<table border="1"> <thead> <tr> <th>FILTER/XAD</th> <th>TARE WT.</th> </tr> </thead> <tbody> <tr> <td><u>Q1035</u></td> <td><u>.5276</u></td> </tr> </tbody> </table>		FILTER/XAD	TARE WT.	<u>Q1035</u>	<u>.5276</u>	<table border="1"> <thead> <tr> <th colspan="2">NOMOGRAPH DATA</th> </tr> </thead> <tbody> <tr> <td>DELTA HG</td> <td><u>1.778</u></td> </tr> <tr> <td>METER TEMP</td> <td><u>85</u></td> </tr> <tr> <td>EST. XH₂O</td> <td><u>18%</u></td> </tr> <tr> <td>C FACTOR</td> <td><u>0.761</u></td> </tr> <tr> <td>STACK TEMP</td> <td><u>270</u></td> </tr> <tr> <td>REF DELTA P</td> <td><u>0.568</u></td> </tr> <tr> <td>K FACTOR</td> <td><u>3.237</u></td> </tr> </tbody> </table>		NOMOGRAPH DATA		DELTA HG	<u>1.778</u>	METER TEMP	<u>85</u>	EST. XH ₂ O	<u>18%</u>	C FACTOR	<u>0.761</u>	STACK TEMP	<u>270</u>	REF DELTA P	<u>0.568</u>	K FACTOR	<u>3.237</u>	<table border="1"> <thead> <tr> <th colspan="2">FYRITES</th> </tr> </thead> <tbody> <tr> <td><u>6.5</u></td> <td></td> </tr> <tr> <td><u>7</u></td> <td></td> </tr> <tr> <td><u>7</u></td> <td></td> </tr> </tbody> </table>		FYRITES		<u>6.5</u>		<u>7</u>		<u>7</u>	
FILTER/XAD	TARE WT.																																
<u>Q1035</u>	<u>.5276</u>																																
NOMOGRAPH DATA																																	
DELTA HG	<u>1.778</u>																																
METER TEMP	<u>85</u>																																
EST. XH ₂ O	<u>18%</u>																																
C FACTOR	<u>0.761</u>																																
STACK TEMP	<u>270</u>																																
REF DELTA P	<u>0.568</u>																																
K FACTOR	<u>3.237</u>																																
FYRITES																																	
<u>6.5</u>																																	
<u>7</u>																																	
<u>7</u>																																	

* PITOT: VISUAL INSPECTION/LEAK CHECK; NOZZLE: VISUAL INSPECTION; TC: AMBIENT TEMPS.; ORSAT SYSTEM: LEAK CHECK

LINE	SAMPLE POINT	CLOCK TIME MINUTES	DRY GAS METER READING CUBIC FEET	PITOT READING IN. H ₂ O	GAS METER TEMP. °F	STACK TEMP. °F	ORIFICE SETTING IN. H ₂ O		GAUGE VACUUM IN. HG	GAS TEMPERATURES °F			✓
							ACTUAL	IDEAL		FILTER *	IMPING. EXIT	PROBE OR COND EXIT**	
1	A-1	0	656.525	.61	68	270	1.92	1.91	6	250	52	NA	
2		5	660.19	.64	74	274	2.01	2.01	6	250	50		
3	2	10	664.07	.65	80	274	2.07	2.07	8	250	52		
4		15	667.91	.62	85	273	1.99	1.99	10	255	50		
5	3	20	671.72	.60	88	274	1.94	1.94	12	255	48		
6		25	675.52	.60	92	275	1.95	1.95	13	255	48		
7	4	30	679.42	.68	94	277	2.21	2.21	15	250	48		1
8		35	684.79	.64	88	275	2.06	2.06	10	250	52		
9	5	40	687.85	.62	90	275	2.01	2.01	10	250	50		
10		45	691.79	.64	92	276	2.08	2.08	10	250	50		
11	6	50	695.75	.65	92	276	2.11	2.11	8	250	48		
12		55	699.83	.66	92	276	2.14	2.14	8	250	48		
13	B-1	60/0	703.917	.57	88	277	1.83	1.83	4	250	52		2
14		5	707.85	.62	90	278	2.00	2.00	4	250	50		
15	2	10	711.75	.58	92	278	1.83	1.83	4	250	48		
16		15	715.61	.52	94	278	1.69	1.69	4	250	48		
17	3	20	719.31	.52	94	277	1.69	1.69	4	250	48		
18		25	722.98	.55	94	276	1.79	1.79	4	250	50		
19	4	30	726.74	.62	94	274	2.02	2.02	4	255	50		
20		35	730.68	.60	92	274	1.95	1.95	4	255	50		
21	5	40	734.60	.62	90	272	2.01	2.01	4	255	50		
22		45	738.76	.65	92	273	2.12	2.12	4	255	52		
23	6	50	742.41	.62	90	275	2.01	2.01	4	260	50		
24		55	746.38	.64	90	276	2.07	2.07	4	260	50		
25		60/0	750.349										

* FILTER EXIT for NJ Method 1. FILTER BOX for all others.

** PROBE EXIT & / (probe & filter heat off) apply to NJ Method 1. COND EXIT applies if sampling train has a condenser.

$$\frac{120}{\text{Min. } (Q)} \frac{92.824}{V_m} \frac{.6127}{(\Delta P)^2} \frac{89}{t_m} \frac{275}{t_s} \frac{1.9008}{\Delta H}$$

ENTROPY

MMTL

RUN NO.

1-S-MMTL-2

JOB NO. 10535

DATE 10-18-91

TIME START 1500

STATIC PRESSURE, IN. H₂O - .31

TIME, FINISH 1734

15

OPERATOR JED

.00

ASST(S) SGD

* PITOT: VISUAL INSPECTION/LEAK CHECK; NOZZLE: VISUAL INSPECTION; TC: AMBIENT TEMPS.; ORSAT SYSTEM: LEAK CHECK

* FILTER EXIT for NJ Method 1. FILTER BOX for all others.

** PROBE EXIT & √ (probe & filter heat off) apply to NJ Method 1. COND EXIT applies if sampling train has a condenser.

120	91.743	$.5616$	91.5	278.5	1.8246
Min. (°)	V_m	$(\sqrt{\Delta P})^2$	t_m	t_s	ΔH

F-1112 (Page 1) 9-91

ENTROPY

FIELD DATA - METHOD(S) MMTL

31

PLANT FOSTER WHEELER CAMDEN CO. RUN NO. 1-S-MMTL-3
 CITY/STATE CAMDEN NJ. JOB NO. 10535 DATE 10/18/91
 SAMPLING LOC. UNIT #1 STACK TIME START 1845
 BAROMETRIC PRESSURE, IN. HG 29.9 STATIC PRESSURE, IN. H₂O -.32 TIME FINISH 2055
 LEAK CHECK, VACUUM IN. HG 15 5 7 --- --- --- OPERATOR SEP
 LEAK RATE, CUBIC FEET/MIN. .000 .000 .000 --- --- --- ASST(S) SGD

EQUIPMENT CHECKS*		EQUIPMENT I.D. NUMBERS		LEAK CHECKS	
☒ PITOT, PRETEST	REAGENT BOX <u>M114</u>	METER BOX <u>N-27</u>	<u>Y 1.0095</u>	B <u>887.571</u>	B <u>---</u>
☒ PITOT, POSTTEST	PITOT <u>8-19</u>	NOZ'L <u>GL-643</u>	DIA. <u>.274</u>	E <u>887.638</u>	E <u>---</u>
☒ NOZZLE, PRE/POST	TC READOUT <u>E-23</u>	TC PROBE <u>R-134</u>	UMBILICAL <u>U-68</u>	B <u>---</u>	B <u>---</u>
☒ TC <u>84</u> °F PRE	SAMPL'G BOX <u>30</u>	ORSAT PUMP <u>16</u>	TEDLAR BAG <u>50</u>	E <u>---</u>	E <u>---</u>
☒ TC <u>274</u> °F POST					B <u>---</u>
☒ ORSAT SYSTEM					E <u>---</u>
		MONOGRAPH DATA			
		DELTA HG	<u>1.776</u>		
		METER TEMP	<u>85</u>		
		EST. XH ₂ O	<u>18</u>		
		C FACTOR	<u>.761</u>		
		STACK TEMP	<u>275</u>		
		REF DELTA P	<u>0.572</u>		
		K FACTOR	<u>3.215</u>		
				FYRITES	
				<u>7.5</u> <u>7</u>	
				<u>7</u> <u>---</u>	

* PITOT: VISUAL INSPECTION/LEAK CHECK; NOZZLE: VISUAL INSPECTION; TC: AMBIENT TEMPS.; ORSAT SYSTEM: LEAK CHECK

LINE	SAMPLE POINT	CLOCK TIME MINUTES	DRY GAS METER READING CUBIC FEET	PITOT READING IN. H ₂ O	GAS METER TEMP. °F	STACK TEMP. °F	ORIFICE SETTING IN. H ₂ O		GAUGE VACUUM IN. HG	GAS TEMPERATURES °F		✓
							ACTUAL	IDEAL		FILTER #	IMPING. EXIT	PROBE OR COND EXIT**
1	A-1	0	842.415	.52	84	275	1.67	1.67	4	255	56	N/A
2		5	846.08	.55	90	277	1.78	1.78	4	255	55	
3	2	10	849.78	.59	92	277	1.92	1.92	4	254	54	
4		15	853.68	.55	94	278	1.79	1.79	4	254	54	
5	3	20	857.47	.54	96	277	1.77	1.77	4	252	52	
6		25	861.24	.51	96	277	1.67	1.67	4	252	52	
7	4	30	864.90	.50	96	276	1.64	1.64	4	250	53	
8		35	868.56	.52	97	275	1.71	1.71	4	252	53	
9	5	40	872.27	.57	98	275	1.88	1.88	4	252	53	
10		45	876.18	.59	100	276	1.95	1.95	5	252	54	
11	6	50	880.12	.56	100	277	1.84	1.84	5	252	54	
12		55	883.92	.50	101	277	1.65	1.65	4	254	52	
13	B-1	60/0	887.571	.67	99	278	2.20	2.20	5	252	55	
14		5	891.65	.70	100	279	2.30	2.30	6	254	53	
15	2	10	896.13	.60	102	279	1.98	1.98	5	254	53	
16		15	900.11	.63	102	278	2.08	2.08	5	254	52	
17	3	20	904.14	.63	103	277	2.09	2.09	5	252	52	
18		25	908.24	.61	104	277	2.02	2.02	5	252	52	
19	4	30	912.27	.66	104	276	2.19	2.19	5	250	54	
20		35	916.42	.60	104	277	1.99	1.99	5	250	54	
21	5	40	920.41	.53	104	277	1.76	1.76	5	252	56	
22		45	924.19	.54	102	276	1.79	1.79	5	252	55	
23	6	50	927.98	.52	102	275	1.72	1.72	5	252	54	
24		55	931.74	.52	101	275	1.72	1.72	5	250	54	
25		60/0	935.476									

* FILTER EXIT for NJ Method 1. FILTER BOX for all others.

** PROBE EXIT & ✓ (probe & filter heat off) apply to NJ Method 1. COND EXIT applies if sampling train has a condenser.

120 93.061 .5699 99.8 276.7 1.0796
 Min. (θ) V_m $(\sqrt{\Delta P})^2$ t_m t_s ΔH

92.774

ENTROPY

MOISTURE SAMPLING LABORATORY RESULTS

Plant Name: CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES

EEI Ref# 10535

Sampling Location: UNIT #1 STACK

Date Received: 10/29/91 Date Analyzed: 10/18/91 Reagent Box(es): M114

Run Number	1-S-MMTL-1	1-S-MMTL-2	1-S-MMTL-3
Run Date	10/18/91	10/18/91	10/18/91

ANALYSIS OF MOISTURE CATCH

Reagent 1 (5% HNO_3 /10% H_2O_2)

Final Weight, g.

609.5

618.0

632.5

Tared Weight, g.

266.5

265.0

265.5

Water Catch, g.

343.0

353.0

367.0

Reagent 2 ()

Final Weight, g.

Tared Weight, g.

Water Catch, g.

0.0

0.0

0.0

Reagent 3 ()

Final Weight, g.

Tared Weight, g.

Water Catch, g.

0.0

0.0

0.0

CONDENSED WATER, g.

343.0

353.0

367.0

Silica Gel:

Final Weight, g.

218.0

224.0

239.0

Tared Weight, g.

200.0

204.5

202.0

ADSORBED WATER, g.

18.0

19.5

37.0

TOTAL WATER COLLECTED, g.

361.0

372.5

404.0

33

MOISTURE SAMPLING LABORATORY RESULTS

Plant Name: CAMDEN COUNTY ENERGY RECOVERY ASSOCIATES

EEI Ref# 10535

Sampling Location: UNIT #1 INLET AND STACK

Date Received: 10/29/91 Date Analyzed: 10/18/91 Reagent Box(es): M136

Run Number	1-S-MMTL-FB	1-I-MMTL-FB
Run Date	10/18/91	10/18/91

ANALYSIS OF MOISTURE CATCH

Reagent 1 (H2O)	270.5	270.5
Final Weight, g.	271.0	271.0
Tared Weight, g.	=====	=====
Water Catch, g.	-0.5	-0.5
Reagent 2 ()		
Final Weight, g.		
Tared Weight, g.	=====	=====
Water Catch, g.	0.0	0.0
Reagent 3 ()		
Final Weight, g.		
Tared Weight, g.	=====	=====
Water Catch, g.	0.0	0.0
CONDENSED WATER, g.	-0.5	-0.5
Silica Gel:		
Final Weight, g.		
Tared Weight, g.	=====	=====
ADSORBED WATER, g.	0.0	0.0
TOTAL WATER COLLECTED, g.	-0.5	-0.5

OL # 9/103667

pg 182
84SAMPLE SUBMISSION FORM
Oxford Laboratory

Submitted By _____ Date Submitted 10-22-91 Date Requested 11-5-91

Company Name Enigma Attention Rik Jelicic

Address _____ State _____ Zip Code _____

Telephone _____ Received By _____

No. of Samples & Identification: Purchase Order# 1781-10535

1.	1-5-mm TL-1	(7)	1-I-mm TL-1
2.	2	(8)	2
3.	2 Duplicates	(9)	2 Duplicates
4.	3	(10)	3
5.	3 Spike	(11)	3 Spike
6.	FB	(12)	FB

Analyses Requested and Special Instructions: DL - 20 ug

Custody

Results:	(1)	(2)	(3)	(4)	(5)	(6)
Lead Total ug	44.0	< 20.0	< 20.0	< 20.0	100%	< 20.0

 $\bar{X} = 28250$

	(7)	(8)	(9)	(10)	(11)	(12)
Lead	21400	27900	28600	36500	100%	< 20.0

A.A. SUMMARY REPORT

X WT. STDS
 CONC STDS
 .100 INST LIMIT
 1 SPK LEVEL
 1.00 MAX ALIQUOT
 .1 M.D.L.

ENTROPY
 P.O.#/PROJECT #:1781-10335
 ANALYST: KEN SMITH
 DATE: 10/28/91

SAMPLE I.D.	EL	MEAN ABS	CONC	ALLOUT	F.V.	TOTAL	SPR	SPR
3667-01	Pb	.0023371	.22	1	200	44.0		
3667-02	Pb	.002185	.02	1	200	<	20.0	
3667-03	Pb	.0047468	.07	1	200	<	20.0	
3667-04	Pb	.0003322	.03	1	200	<	20.0	
3667-05-8048PK	Pb	.0114054	1	1	400	400	100	1
3667-06	Pb	.0008137	.07	1	200	<	20.0	
3667-07	Pb	.0623239	5.34	1	4000	21360		
3667-08	Pb	.0819021	6.97	1	4000	27880		
3667-09	Pb	.0040422	7.14	1	4000	28560		
3667-10	Pb	.1084626	9.13	1	4000	36520		
3667-11-8108PK	Pb	.1147851	9.63	1	4000	38520	100	.5
3667-12	Pb	.0009497	.08	1	200	<	20.0	
3667-13	Pb	-.000018	0	1	200	<	20.0	

AS Position 3	Pb	.0465448	4.03	0	0			
AS Position 3	Pb	.0465021	4.01	0	0			
AS Position 3	Pb	.0464375	4.01	0	0			
AS Position 3	Pb	.0459738	3.97	0	0			
Blank	Pb	-.000375	-.03	0	0			
Blank	Pb	-.000183	-.02	0	0			
Blank	Pb	.0004576	.04	0	0			
Blank	Pb	-.000409	-.05	0	0			
D.L.F.	Pb	.0009497	.08	0	0			
OLI BLK	Pb	.0004436	.04	0	0			
PE KNOWN	Pb	.0124019	1.09	1	1	1.09		
Std 1=.50ug/ml	Pb	.0055868	.51	0	0			
Std 2=4.0ug/ml	Pb	.0476413	4.26	0	0			
Std 3=10.0ug/ml	Pb	.1181336	8.99	0	0			
Std Blank	Pb	-.000051	0	0	0			

RECORD OF CUSTODY, CONTAINER NO. M114

37

Container Type (check) ☒ Reagent Box ☐ Cooler ☐ Other (specify) _____

Plant Name/Address CC IPA

Job No. 10535 Sampling Method MATL - Pb (EPA, NIOSH, etc.)

Seal ID	Date	Time	*	Full Signature	Reason for Breaking Seal**
315	10-10	9:15	S	<i>Ralph RDP</i>	
	10-17	1:10	B	<i>220</i>	<i>Cheng Tang</i>
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		

* S = Sealed By; B = Broken By ** Use "REMARKS" Section if more space needed.

Received by Sample Custodian

Dr. L. A. 10-21-91 9:50 Seal Intact?
Signature Date Time Yes ☒ No ☐

As Applicable:

All liquid levels at mark (check)? ☐ YES ☐ NO (Estimate loss if not at mark; describe in "REMARKS")

As Applicable:

TUBE SAMPLES put in freezer by _____ Date _____ Time _____

CONDENSATE SAMPLES put in refrige. by _____ Date _____ Time _____

REMARKS DP

FIELD SAMPLE RECOVERY QUALITY CONTROL

38

Box No. M114 Assembly Date 10/9/91 Assembled By dk
 Plant Name/address CCPA, CAMDEN NJ Job No. 10535
 Sampling Loc. STACK - UNIT 1 Method MMTL-Pb
 Individual Tare Of Reagent 200 (Ml) (gm) Of 5% HNO₃ / 10% H₂O₂
 Individual Tare Of Reagent _____ (Ml) (gm) Of _____
 Individual Tare Of Reagent _____ (Ml) (gm) Of _____
 Individual Tare Of Sil. Gel ~200 Gm _____ other (specify) _____

Run Number	Run Date	Filter or XAD Number	Tare, grams	Liquid Tare at Mark? @	Init.	Sample Recov. Date	%Sil. Gel Spent	Liquid Level Marked?	Init.
1-S-MMTL-1	10-18	2/4		/	HS	10-18	50	HS	✓

Filter Appearance*

Clear

Reagents Appearance*

Clear

1-S-MMTL-2	10-18	2/4		/	HS	10-18	45	HS	✓
------------	-------	-----	--	---	----	-------	----	----	---

Filter Appearance*

Clear

Reagents Appearance*

Clear

1-S-MMTL-3	10-18			/	HS	10-18	45	HS	✓
------------	-------	--	--	---	----	-------	----	----	---

Filter Appearance*

Clear

Reagents Appearance*

Clear

--	--	--	--	--	--	--	--	--	--

Filter Appearance*

Reagents Appearance*

* Use "REMARKS" section if needed.

@ All liquid levels at mark? (check) YES _____ NO _____ (estimate loss if not at mark; use "REMARKS" section).

REMARKS _____

Custodian DR P. A.
 Q-1002 rev. 10-91

Date 10-21-91 Time 9:50

ENTROPY

RECORD OF CUSTODY, CONTAINER NO. M136

39

Container Type (check) ☒ Reagent Box ☐ Cooler ☐ Other (specify) _____
 Plant Name/Address CEEA; Camarillo, CA
 Job No. 12535 Sampling Method MMTC/Pb (EPA, NIOSH, etc.)

Seal ID	Date	Time		Full Signature	Reason for Breaking Seal**
647	10-10	9:15	S	Betty L. Bell	
	10-18	8:25	B	[Signature]	Change - Blanks
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		
			S		
			B		

* S = Sealed By; B = Broken By ** Use "REMARKS" Section if more space needed.

Received by Sample Custodian

[Signature]
Signature

10-21-94
Date

9:45
Time

Seal Intact?
Yes ☒ No ☐

As Applicable:
All liquid levels at mark (check)? ☐ YES ☐ NO (Estimate loss if not at mark; describe in "REMARKS")

As Applicable:
TUBE SAMPLES put in freezer by _____ Date _____ Time _____

CONDENSATE SAMPLES put in refrige. by _____ Date _____ Time _____

REMARKS _____

FIELD SAMPLE RECOVERY QUALITY CONTROL

Box No. M136

Assembly Date 10/9/91

Assembled By dk 40

Plant Name/address CCERA

Job No. 10535

Sampling Loc. UNIT 1 STACKWELL

Method MMTL/PO

Individual Tare Of Reagent 200 (Ml) (gm) Of 5% HNO₃ / 10% H₂O₂

Individual Tare Of Reagent _____ (Ml) (gm) Of _____

Individual Tare Of Reagent _____ (Ml) (gm) Of _____

Individual Tare Of Sil. Gel ~200 Gm

other (specify) _____

Run Number	Run Date	Filter or XAD Number	Tare, grams	Liquid Tare at Mark? @	Init.	Sample Recov. Date	%Sil. Gel Spent	Liquid Level Marked?	Init.
1-S-MMTL-FB	10-18			✓	245	10-18	0	✓	245

Filter Appearance*

Clear

Reagents Appearance*

Clear

1-I-MMTL-FB 10-18

Filter Appearance*

Clear

Reagents Appearance*

Clear

BLANKS 10-18

Filter Appearance*

Reagents Appearance*

Filter Appearance*

Reagents Appearance*

* Use "REMARKS" section if needed.

@ All liquid levels at mark? (check) YES _____ NO _____ (estimate loss if not at mark; use "REMARKS" section).

REMARKS _____

Custodian DRS
9-1002 rev. 10-91

Date 10-21-91 Time 9:40

ENTROPY

REQUEST FOR ANALYSIS

PO#: 1781-10535

Customer Name: Camden Co. RRF
Camden, NJ

Laboratory: OLI


Date Transmitted: 10/21/91

Results Due By: 11/05/91

Sample Matrix: MMTL

Analysis: Analyze for Pb by MMTL method. [detection limit = 20µg]

Sample #	Sample ID	Components/Comments
1	1-S-MMTL-1	-FH, -BH, -F, -R
2	1-S-MMTL-2	-FH, -BH, -F, -R
3	1-S-MMTL-2	duplicate analysis
4	1-S-MMTL-3	-FH, -BH, -F, -R
5	1-S-MMTL-3	matrix spike
6	1-S-MMTL-FB	-FH, -BH, -F, -R
7	1-I-MMTL-1	-FH, -BH, -F, -R
8	1-I-MMTL-2	-FH, -BH, -F, -R
9	1-I-MMTL-2	duplicate analysis
10	1-I-MMTL-3	-FH, -BH, -F, -R
11	1-I-MMTL-3	matrix spike
12	1-I-MMTL-FB	-FH, -BH, -F, -R
13	Blanks	HNO3/H2O2, 0.1N HNO3, filter

Submitted By: 

APPENDIX C

CALIBRATION DATA

SAMPLING EQUIPMENT AUDIT

43

Plant Name Foster Wheeler Enviroresponse, Inc. Job No. 10535-1
 City/State Camden, New Jersey Auditor(s) RFH + WEM
 Test Loc. Inlet - Unit 1 Date 10-17-91

BAROMETER
 Entropy In-House Ref. Barometer 29.6 "Hg vs Field Barometer 29.7 "Hg
 Date Compared 10-17-91 Dev. 0.1 "Hg (Max. Allowable Dev.: ± 0.1 "Hg)

Ref. Therm. Initial Ambient Temp., °F	Allowable Deviation From Ambient	Ambient Temperature, °F	Audit OK (✓)
<u>71</u>			
THERMOMETERS *			
Dry Gas Meter	± 5.4 °F	<u>74</u> (Meterbox No. <u>N-23</u>)	✓
Impinger Exit	± 2.0 °F	<u>70</u>	
Filter Box	± 5.4 °F	<u>72</u>	

* Adjust thermometer until acceptable. If it cannot be adjusted, use as back-up. If no backup, record ambient temperature indicated by unadjusted thermometer and label with correction factor (indicate):

THERMOCOUPLES Allowable Deviation from Ambient: ± 8.0 °F* (± 2.0 °F)**

TC No. / °F	OK	TC No. / °F	OK	TC No. / °F	OK	TC No. / °F	OK	TC No. / °F	OK
<u>R271 / 70</u>	✓	<u>1</u>		<u>1</u>		<u>1</u>		<u>1</u>	

* ± 8.0 °F = $\pm 1.5\%$ of ambient absolute temperature.
 ** (± 2.0 °F if used in saturated or water droplet-laden gas stream.)

ISOKINETIC METERBOX I.D. N-23 Gamma (Y) 0.9823 ΔH_e 1.827
 As Applicable (check): Zero Magnehelics? ☒ Zero/Level Manometer? NA
 Barometric Pressure (P_{bar}) 29.5 Auditor RFH Date 10-17-91

Dry Gas Meter Reading (Cubic Ft.)	Meter Temperature (°F)	Lower and Upper Limits for Audit Gamma
Final <u>729.402</u>	Final <u>78</u>	$0.96 * Y = 0.943008$
Initial <u>721.784</u>	Initial <u>74</u>	$1.04 * Y = 1.021592$

Dry Gas Volume Metered (Cubic Ft.)	Average Meter Temp. (°F)	Run Time (Base = 10)	
		(Minutes)	(Seconds)
V _m = <u>7.618</u>	T _m = <u>76</u>	<u>10</u>	<u>0</u>

$$Y_c = \frac{[\text{Min.} + (\text{Sec.} / 60)]}{V_m} * \left[\frac{0.0319 (T_m + 460)}{P_{bar}} \right]^{1/2}$$

$$Y_c = \frac{[\underline{10} + (\underline{0} / 60)]}{\underline{7.618}} * \left[\frac{0.0319 (\underline{76} + 460)}{\underline{29.5}} \right]^{1/2} = \underline{0.999368739}$$

Audit Gamma

Audit Gamma Acceptable (between lower & upper limits)? (✓) ☒ Yes ☐ No

SAMPLING EQUIPMENT CHECKLIST

44

Plant Name/Address FOSTER WHEELER CAMDEN CO. Job No. 10535

Sampling Location UNIT #1 STACK Team Leader SGD

BAROMETER CHECK

Date	Entropy In-House Reference Barometer	Field Barometer	Check OK?*
10-16-91	29.8	29.8	✓

* ± 0.1 " Mercury

THERMOMETERS AND THERMOCOUPLE CHECK

Date <u>10-18-91</u>	Reference Thermometer Ambient Temperature, °F <u>78°F</u>		
	Ambient Temperature, °F	Acceptance Range, °F	Check OK?
<u>Thermometers</u>			
Impinger Exit	<u>78°F</u>	± 2.0	✓
Filter Box	<u>78°F</u>	± 5.4	✓
Dry Gas Meter	<u>77°F</u>	± 5.4	✓

Adjust thermometer until acceptable. If it cannot be adjusted, use as back-up. If no backup, record ambient temp. indicated by unadjusted thermometer.

<u>Thermocouple</u> * $\pm 1.5\%$ of Absolute Temperature. ** Acceptance range is $\pm 2.0^\circ\text{F}$ if used in saturated or water droplet-laden gas stream.	<u>78°F</u>	$\pm 8.0^*$ $(\pm 2.0)^{**}$	✓
---	-------------	---------------------------------	---

PITOT AND NOZZLE CHECK

Pitot No.	Visual Check	Nozzle No.	Visual Check
<u>8-15</u>	✓	<u>GL-692</u>	✓
<u>8-19</u>	✓	<u>GL-643</u>	✓

Calibration by: WLS

Dry Gas Meter Identification: 1017057

Date: 1-15-91 Barometric Pressure (P_b): 29.58 in. Hg



#Date: #Barometric Pressure (P_b): in. Hg

Approx. Flow Rate (Q) cfm	Spirometer		Dry Gas Meter		Pressure (Δp) in. H ₂ O	Time (t) min.	Flow Rate (Q) cfm	Meter Meter Coeff. (V_{ds})	Avg. Meter Coeff. ($\bar{V}_{ds}$)
	Gas Volume (V_g) ft ³	Temp. (t_g) °F	Gas Volume (V_{dg}) ft ³	Temp. (t_{dg}) °F					
	2.5956	77.0	2.549	70.5	-0.40	10	0.2522	1.0070	
	2.6047	77.0	2.526	72.0	-0.40	10	0.2531	1.0226	
	2.5592	77.0	2.462	73.0	-0.40	10	0.2487	1.0328	
	4.4080	77.0	4.339	74.0	-0.62	11	0.3894	1.0118	
	4.0619	77.0	3.973	74.0	-0.62	10	0.3947	1.0182	
	3.9799	77.0	3.953	75.0	-0.62	10	0.3867	1.0046	
	4.8178	77.0	4.800	75.0	-0.80	10	0.4681	1.0020	
	4.8634	77.0	4.770	75.0	-0.80	10	0.4726	1.0178	
	4.8634	77.0	4.794	76.0	-0.80	10	0.4726	1.0146	
	7.8142	77.0	7.711	76.0	-1.70	10	0.7693	1.0158	
	7.7596	77.0	7.693	76.0	-1.70	10	0.7540	1.0111	
	7.7140	77.0	7.684	76.0	-1.70	10	0.7496	1.0063	
	10.0000	77.0	9.979	76.0	-2.10	10	0.9717	1.0055	
	9.8725	77.0	9.850	76.0	-2.10	10	0.9593	1.0037	
	9.8178	77.0	9.845	76.0	-2.10	10	0.9540	1.0006	
	11.5392	77.0	11.591	76.0	-3.40	10	1.1212	1.0021	

$$Q = (17.64) \frac{(P_b)(V_s)}{(t_s + 460)(g)}$$

$$V_{ds} = \frac{(V_s)(t_{ds} + 460)(P_b)}{(V_{ds})(t_s + 460)(P_h + (P / 13.6))}$$

Date: 1-15-91

1.0083

$$Q = (17.64) \frac{(P_B)(V_S)}{(t_S + 460) (^\circ)}$$

Dry Gas Meter Identification: 1054682 Calibration by: WLS (Page 1 of 2)



Date: 7-18-90 Barometric Pressure (P_b): 30.04 in. Hg
 Date: Barometric Pressure (P_b): in. Hg

Approx. Flow Rate (Q) cfm	Spirometer		Dry Gas Meter		Pressure (ΔP) in. H ₂ O	Time (t) min.	Flow Rate (Q) cfm	Meter Meter Coeff. (Y_{ds})	Avg. Meter Coeff. ($\bar{Y}_{ds}$)
	Gas Volume (V_g) ft ³	Temp. (t_g) °F	Gas Volume (V_{ds}) ft ³	Temp. (t_{ds}) °F					
	2.6230	79	2.602	80	0.51	10	0.2579	1.0089	1.0087
	2.6503	79	2.579	80	0.51	10	0.2606	1.0283	1.0283
	2.6503	79	2.563	80	0.51	10	0.2606	1.0347	1.0347
	4.0802	79	3.989	80	0.91	10	0.4011	1.0225	1.0285
	4.0528	79	3.922	80	0.91	10	0.3984	1.0330	1.0330
	4.0164	79	3.915	80	0.91	10	0.3949	1.0255	1.0255
	4.8453	79	4.696	81	1.40	10	0.4763	1.0321	1.0320
	4.8452	79	4.669	81	1.40	10	0.4763	1.0380	1.0380
	4.7996	79	4.645	81	1.40	10	0.4719	1.0336	1.0335
	7.9235	79	7.802	81	2.60	10	0.7790	1.0129	1.0129
	7.8780	79	7.880	81	2.60	10	0.7745	0.9971	0.9971
	7.9508	79	7.922	81	2.60	10	0.7817	1.0010	1.0010
	10.146	79	10.184	82	4.40	10	0.9975	0.9911	0.9911
	10.164	79	10.224	82	4.40	10	0.9993	0.9890	0.9890
	10.127	79	10.213	82	4.40	10	0.9956	0.9865	0.9865
	11.676	79	11.874	83	5.50	10	1.1479	0.9775	0.9774

$$Y_{ds} = \frac{(V_g)(t_{ds} + 460)(P_b)}{(V_{ds})(t_g + 460)(P_b + (P / 13.6))}$$

$$Q = (17.64) \frac{(P_b)(V_g)}{(t_g + 460)(g)}$$

Dry Gas Meter Identification: 1054682 Calibration by: WLS (Page 2 of 2)

**ENTROPY
ENVIRONMENTALISTS, INC.**

Date: 7-18-90 Barometric Pressure (P_b): 30.04 in. Hg

Date: _____ Barometric Pressure (P_b): _____ in. Hg

[illegible]

$$Y_{DS} = \frac{(V_S) (t_{DS} + 460) (P_b)}{(V_{DS}) (t_S + 460) (P_b + (P / 13.6))}$$

$$Q = (17.64) \frac{(P_b)(V_g)}{(t_g + 460)(g)}$$

Dry Gas Meter Identification: 1054682 Calibration by: WLS PAGE 1 OF 2



Date: 8-14-91 Barometric Pressure (P_b): 29.82 in. Hg

Date: _____ Barometric Pressure (P_b): _____ in. Hg

Spirometer		Dry Gas Meter		Pressure (Δp) in. H ₂ O	Time (t) min.	Flow Rate (Q)	Meter Coeff. (Y_{ds})	Avg. Meter Coeff. ($\bar{Y}_{ds}$)
Gas Volume (V_g) ft ³	Temp. (t_g) °F	Gas Volume (V_{dg}) ft ³	Temp. (t_{dg}) °F					
2.76	75	2.808	74	-0.26	10	.23	.9874	NA
2.75		2.783	74	-0.26		.23	.9869	
2.76		2.788	74	-0.26		.23	.9845	
4.098		4.172	76	-0.74		.55	.9859	
4.089		4.149	76	-0.74		.55	.9892	
4.089		4.139	76	-0.74		.55	.9916	
4.927		4.988	76	-0.60		.80	.9911	
5.009		5.039	76	-0.60		.80	.9974	
4.964		5.024	76	-0.60		.80	.9914	
8.097		8.161	77	-1.4		2.10	1.0040	
8.078		8.183	77	-1.4		2.10	.9970	
7.987		8.110	77	-1.4		2.10	.9919	
10.383		10.507	77	-2.1		3.45	.9971	
10.300		10.423	77	-2.1		3.45	.9971	
10.300		10.426	77	-2.1		3.45	.9968	
12.523		12.685	78	-3.2		4.70	1.0007	

$$(V_g) (t_{ds} + 460) (P_b)$$

$$Y_{ds} = \frac{(V_{dg}) (t_g + 460) (P_b + (P / 13.6))}{(V_g) (t_{ds} + 460) (P_b)}$$

Dry Gas Meter Identification: 1054682

Calibration by: WLS

PAGE 2 OF 2

Date: 8-14-91 Barometric Pressure (P_b): 29.82 in. Hg

ENTROPY ENVIRONMENTALISTS, INC.

Barometric Pressure (P_b): _____ in. Hg

[illegible]

$$Y_{DS} = \frac{(V_S) (t_{DS} + 460) (P_b)}{(V_{DS}) (t_S + 460) (P_b + (P / 13.6))}$$

ISOKINETIC METERBOX FULL TEST CALIBRATION

51

Meterbox No. N23

Calibrated By mbc/sws

Date 9-13-91

Barometric Pressure (P_b) 29.58 (In. Hg)

Date _____

Barometric Pressure (P_b) _____ (In. Hg)

Standard Meter No. 1017057

Standard Meter Coefficient 1.0083

STANDARD METER			METERBOX METERING SYSTEM				
Gas Volume (V_{ds}) cf	Temp. (t_{ds}) °F	Time (θ) Min.	Orifice Setting (ΔH) In. H ₂ O	Gas Volume (V_d) cf	Temp. (t_d) °F	Coeff. (Y_d)	ΔH_E In. H ₂ O
4.679	78	12	0.5	4.901	86	.9757	1.838
6.193	78	16	0.5	6.518	88	.9746	1.858
7.794	77		2.0	8.152	91	.9843	1.816
7.811			2.0	8.210	95	.9830	1.802
12.007			4.8	12.512	93	.9882	1.824
12.042	✓	✓	4.8	12.459	91	.9882	1.826
Average						.9823	1.827

1. Coefficient range: 0.97-1.03.
2. Coefficient tolerance: for individual runs, ± 0.02 from average.
3. ΔH_E range: 1.6-2.0.
4. ΔH_E tolerance: ± 0.15 In. H₂O over ΔH range of 0.4 In.-4.0 In.

$$Y_d = \frac{Y_{ds} \cdot V_{ds} \cdot (t_d + 460) \cdot P_b}{V_d \cdot (t_{ds} + 460) \cdot (P_b + (\Delta H / 13.6))}$$

$$\Delta H_E = \frac{0.0317 \cdot \Delta H}{P_b \cdot (t_d + 460)} \cdot \left[\frac{(t_{ds} + 460) \cdot \theta}{Y_{ds} \cdot V_{ds}} \right]^2$$

ISOKINETIC METERBOX POSTTEST CALIBRATION

52

METERBOX NO. N27

Date 11-5-91 Calibrated By MBG/SWS Job Number 10535

Barometric Pressure (P_b) 29.79 (In. Hg) Meterbox Vacuum 15 (In. Hg)

Standard Meter No. 1054682 Standard Meter Coefficient .9940

STANDARD METER			METERBOX METERING SYSTEM				
Gas Volume (V_{ds}) cf	Temp. (t_{ds}) °F	Time (•) Min.	Orifice Setting (ΔH) In. H ₂ O	Gas Volume (V_d) cf	Temp. (t_d) °F	Coeff. (Y_d)	ΔH_e In. H ₂ O
7.714	70	10	1.9	7.968	88	.9904	1.763
7.707	↓	↓	↓	8.061	99	.9977	1.731
7.722	↓	↓	↓	8.104	101	.9979	1.718
Average						.9953	1.737

Fulltest Y_d 1.0095 Date 5-8-91 % Dev. 1.4 Allowed Dev.: $\pm 5\%$

$$Y_d = \frac{Y_{ds} * V_{ds} * (t_d + 460) * P_b}{V_d * (t_{ds} + 460) * (P_b + \{\Delta H / 13.6\})}$$

$$\Delta H_e = \frac{0.0319 * \Delta H}{P_b * (t_d + 460)} * \left[\frac{(t_{ds} + 460) * \bullet}{Y_{ds} * V_{ds}} \right]^2$$

ISOKINETIC METERBOX FULLTEST CALIBRATION

53

Meterbox No. N27

Calibrated By MBU/LWS

Date 5-8-91

Barometric Pressure (P_b) 29.9 (In. Hg)

Date _____

Barometric Pressure (P_b) _____ (In. Hg)*

Standard Meter No. 1054682

Standard Meter Coefficient 1.0026

STANDARD METER			METERBOX METERING SYSTEM				
Gas Volume (V_{ds}) cf	Temp. (t_{ds}) °F	Time (θ) Min.	Orifice Setting (ΔH) In. H ₂ O	Gas Volume (V_d) cf	Temp. (t_d) °F	Coeff. (Y_d)	$\Delta H\theta$ In. H ₂ O
3.965	72	10	0.5	4.071	86	1.0010	1.739
3.958	1	10	0.5	4.070	88	1.0031	1.739
15.604		20	2.0	15.901	92	1.0159	1.777
7.711		10	2.0	7.962	96	1.0098	1.806
11.948		10	4.8	12.294	99	1.0119	1.796
11.861	↓	10	4.8	12.232	102	1.0150	1.812
Average						1.0095	1.778

1. Coefficient range: 0.97-1.03.
2. Coefficient tolerance: for individual runs, ± 0.02 from average.
3. $\Delta H\theta$ range: 1.6-2.0.
4. $\Delta H\theta$ tolerance: ≤ 0.15 In. H₂O over ΔH range of 0.4 In.-4.0 In.

$$Y_d = \frac{Y_{ds} \cdot V_{ds} \cdot (t_d + 460) \cdot P_b}{V_d \cdot (t_{ds} + 460) \cdot (P_b + (\Delta H / 13.6))}$$

$$\Delta H\theta = \frac{0.0317 \cdot \Delta H}{P_b \cdot (t_d + 460)} \cdot \left[\frac{(t_{ds} + 460) \cdot \theta}{Y_{ds} \cdot V_{ds}} \right]^2$$

ISOKINETIC METERBOX POSTTEST CALIBRATION

54

METERBOX NO. N23

Date 11-5-91 Calibrated By MBJ/PJS Job Number 10535
 Barometric Pressure (P_b) 29.76 (In. Hg) Meterbox Vacuum 17 (In. Hg)
 Standard Meter No. 1054682 Standard Meter Coefficient .9940

STANDARD METER			METERBOX METERING SYSTEM				
Gas Volume (V_{ds}) cf	Temp. (t_{ds}) °F	Time (•) Min.	Orifice Setting (ΔH) In. H ₂ O	Gas Volume (V_d) cf	Temp. (t_d) °F	Coeff. (Y_d)	ΔH_e In. H ₂ O
6.813	70	11	1.2	7.146	84	.9698	1.741
6.177	↓	10	↓	6.546	88	.9670	1.738
6.140	↓	10	↓	6.519	91	.9704	1.749
Average						.9691	1.743

Fulltest Y_d .9823 Date 9-13-91 % Dev. 1.4 Allowed Dev.: $\pm 5\%$

$$Y_d = \frac{Y_{ds} * V_{ds} * (t_d + 460) * P_b}{V_d * (t_{ds} + 460) * (P_b + \{\Delta H / 13.6\})}$$

$$\Delta H_e = \frac{0.0319 * \Delta H}{P_b * (t_d + 460)} * \left[\frac{(t_{ds} + 460) * \bullet}{Y_{ds} * V_{ds}} \right]^2$$

ON-SITE DRY GAS METER AUDIT

55

Plant Name FOSTER WHEELER CAMDEN CO. Job Number 102535
 Date 10/17/91 Meter Box Identification Number N-27
 Time 1420 Fulltest Gamma (Y) 1.0095 ΔH_g 1.778
 Auditor SGD Barometric Pressure (P_{bar}) 29.4 In. Hg

As Applicable:

Zero Magnehelics? (check) ☒

Zero/Level Manometer? (check) ☒ N/A

Dry Gas Meter Reading (ft ³)	Meter Temperature (°F)	Upper and Lower Limits for Audit Gamma
Initial <u>648.218</u>	Initial <u>76</u>	$0.96 * Y =$ <u>.96912</u>
Final <u>655.726</u>	Final <u>76</u>	$1.04 * Y =$ <u>1.04988</u>

Dry Gas Volume Metered (ft ³)	Average Meter Temperature (°F)	Run Time (Base = 10)	
		(Min.)	(Sec.)
V _m = <u>7.508</u>	T _m = <u>76</u>	<u>10</u>	<u>0</u>


$$Y_c = \frac{[\text{Min.} + (\text{Sec.} / 60)]}{V_m} * \left[\frac{0.0319 (T_m + 460)}{P_{\text{bar}}} \right]^{0.5}$$

$$Y_c = \frac{[10 + (0 / 60)]}{7.508} * \left[\frac{0.0319 (76 + 460)}{29.4} \right]^{0.5} = \frac{1.01573}{\text{Calculated Audit Y}}$$

Audit Gamma Within Acceptable Limits? Yes ☒ No ☐

PITOT TUBE INSPECTION DATA SHEET

56



level?	Yes
obstructions?	None
damaged?	None
$-10^\circ < \alpha_1 < +10^\circ$	1
$-10^\circ < \alpha_2 < +10^\circ$	1
$-5^\circ < \beta_1 < +5^\circ$	2
$-5^\circ < \beta_2 < +5^\circ$	1
γ	0
θ	0
A	1.040
$1.05 D_t < P_a < 1.5 D_t$	.531
$1.05 D_t < P_b < 1.5 D_t$	.509
$3/16" < D_t < 3/8"$	.375
$A \tan \gamma < 0.125"$	0
$A \tan \theta < 0.03125"$	0
$P_a = P_b \pm 0.063"$	Yes

Comments:

I certify that pitot tube/probe number 8-9 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.

Signature W. B. Shull






Date 8-2-99

*SEE 40 CFR 60, VOL. 42 NO. 160 METHOD 2. VERIFY THE MINIMUM 2 INCH SETBACK OF THE THERMOCOUPLE AND THE MINIMUM 3/4 INCH SEPARATION BETWEEN THE PITOT TUBE AND THE NOZZLE AS SHOWN AT THE TOP OF THIS PAGE.

ENTROPY

PITOT TUBE INSPECTION

57



DEGREE INDICATING LEVEL POSITION FOR DETERMINING B1 AND B2.

level?	YES
obstructions?	NO/NE
damaged?	NO/NE
$-10^\circ < \alpha < +10^\circ$	0
$-10^\circ < \alpha_2 < +10^\circ$	0
$-5^\circ < B1 < +5^\circ$	0
$-5^\circ < B2 < +5^\circ$	0
T	0
0	0
A	.991
$1.05 D_1 < P_1 < 1.5 D_1$	.495
$1.05 D_2 < P_2 < 1.5 D_2$	.496
$3/16^\circ < D_1 < 36^\circ$	.375
$A \tan \gamma < 0.125^\circ$	.017
$A \tan \theta < 0.03125^\circ$	0
$P_1 = P_2 \pm 0.063^\circ$	YES .001

See 40 CFR 60, Vol. 42 No. 160 EPA Method 2. Verify the minimum 2-inch setback of the thermocouple and the minimum 3/4-inch separation between the pitot tube and the nozzle as shown at the top of this page.

Comments: Nut - fixed NEW






I certify that pitot tube/probe number 8-15 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.

Signature Chad C. Linsch

Date 5-2-91

PITOT TUBE INSPECTION

58



level?	YES
obstructions?	NONE
damaged?	NONE
$-10^\circ < \alpha_1 < +10^\circ$	0
$-10^\circ < \alpha_2 < +10^\circ$	0
$-5^\circ < B_1 < +5^\circ$	0
$-5^\circ < B_2 < +5^\circ$	0
T	1.0
0	0
A	.925
$1.05 D_1 < P_0 < 1.5 D_1$	.462
$1.05 D_2 < P_0 < 1.5 D_2$	.463
$3/16^\circ < D_1 < 3/8^\circ$	.375
$A \tan \gamma < 0.125^\circ$	.016
$A \tan \theta < 0.03125^\circ$	0
$P_0 = P_0 \pm 0.003^\circ$	YES 101


See 40 CFR 60, Vol. 42 No. 160 EPA Method 2. Verify the minimum 2-inch setback of the thermocouple and the minimum 3/4-inch separation between the pitot tube and the nozzle as shown at the top of this page.

Comments: not fixed NEW

I certify that pitot tube/probe number 8-16 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.

Signature Charles C. Lunsden

Date 5-2-91



level?	YES
obstructions?	NONE
damaged?	NONE
$-10^\circ < \alpha_1 < +10^\circ$	0
$-10^\circ < \alpha_2 < +10^\circ$	0
$-5^\circ < \beta_1 < +5^\circ$	1°
$-5^\circ < \beta_2 < +5^\circ$	1°
Y	1°
θ	0
A	.836
$1.05 D_t < P_a < 1.5 D_t$	.411
$1.05 D_t < P_b < 1.5 D_t$	.425
$3/16" < D_t < 3/8"$	.375
$A \tan \gamma < 0.125"$	.014
$A \tan \theta < 0.03125"$	0
$P_a = P_b \pm 0.063"$	.014

Comments:

I certify that pitot tube/probe number PPT-61 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.






Signature W.L. Shull

Date 3-5-90

*SEE 40 CFR 60, VOL. 42 NO. 180 METHOD 2. VERIFY THE MINIMUM 2 INCH SETBACK OF THE THERMOCOUPLE AND THE MINIMUM 3/4 INCH SEPARATION BETWEEN THE PITOT TUBE AND THE NOZZLE AS SHOWN AT THE TOP OF THIS PAGE.

PITOT TUBE INSPECTION

60



level?	YES
obstructions?	NONE
damaged?	NONE
$-10^\circ < \alpha_1 < +10^\circ$	0
$-10^\circ < \alpha_2 < +10^\circ$	0
$-5^\circ < B1 < +5^\circ$	0
$-5^\circ < B2 < +5^\circ$	0
γ	0
θ	0
A	1.042
$1.05 D_i < P_i < 1.5 D_i$	.521
$1.05 D_i < P_i < 1.5 D_i$	.521
$3/16^\circ < D_i < 3/8^\circ$	.375
$A \tan \gamma < 0.125^\circ$	.016
$A \tan \theta < 0.03125^\circ$	0
$P_i = P_o \pm 0.063^\circ$	YES.

See 40 CFR 60, Vol. 42 No. 160 EPA Method 2. Verify the minimum 2-inch setback of the thermocouple and the minimum 3/4-inch separation between the pitot tube and the nozzle as shown at the top of this page.

Comments:

I certify that pitot tube/probe number PPT-83 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.

Signature

Date

62

NOTE: All diameters measured in inches.

NOZZLE NUMBER: GL-123

[illegible]

NOTE: All diameters measured in inches.

NOZZLE CALIBRATION

NOZZLE NUMBER 6L 643

64

[illegible]

Note:

1. All diameters measured in inches.
2. Maximum 0.004 inches from lowest to highest diameter.

NOZZLE NUMBER GL 692

65

Note: 1. All diameters measured in inches.
2. Maximum 0.004 inches from lowest to highest diameter.

THERMOCOUPLE CALIBRATION

66

Thermocouple No.: R094

Date: 8/28/90

Calibrated By: RDS/WLS

Barometric Pressure, Inches Hg: 29.51

Ambient Temperature, °F: 72.0

Mercury-In-Glass Thermometer I.D. No.: 7121K

Calibration System Used	Potentiometer I.D. Number	Reference Thermometer Temperature		Mean Temperature of Hg Column T_m °F	Thermocouple Thermometer Temperature T_t °F	Temperature Diff., % (Allowable: ≤ 1.5 %)
		T_o °F	T_c °F			
Ice Bath	F-9	32.0	31.96	72.0	29.4	.52
		32.0	31.96	72.0	29.8	.44
		32.0	31.96	72.0	29.7	.46
Boiling Water	F-9	214.0	215.82	110.0	212.4	.51
		214.0	215.82	110.0	212.6	.48
		214.0	215.82	110.0	212.2	.54
Boiling Oil	F-9	388.0	396.88	120.0	387.0	1.15
		388.0	396.88	120.0	386.6	1.20
		388.0	396.88	120.0	386.6	1.20

$$\text{Corrected Temperature} = T_c = T_o + [(.00009) * (T_o - 20) * (T_o - T_m)]$$

$$\text{Temperature Difference} = \frac{[(T_c + 460) - (T_t + 460)]}{(T_c + 460)} * 100$$

THERMOCOUPLE CALIBRATION

67

Thermocouple No.: R134

Date: 3/13/90

Calibrated By: TAB

Barometric Pressure, Inches Hg: 29.64

Ambient Temperature, °F: 74.0

Mercury-In-Glass Thermometer I.D. No.: 7121K

Calibration System Used	Potentiometer I.D. Number	Reference Thermometer Temperature		Mean Temperature of Hg Column T_m °F	Thermocouple Thermometer Temperature T_t °F	Temperature Diff., % (Allowable: ≤ 1.5 %)
		T_o °F	T_c °F			
Ice Bath	F24	32.0	31.96	72.0	33.0	-.21
		32.0	31.96	72.0	33.0	-.21
		32.0	31.96	72.0	34.0	-.42
Boiling Water	F24	214.0	215.82	110.0	210.0	.86
		214.0	215.82	110.0	211.0	.71
		214.0	215.82	110.0	211.0	.71
Boiling Oil	F24	382.0	390.54	120.0	380.0	1.24
		384.0	392.65	120.0	383.0	1.13
		386.0	394.76	120.0	386.0	1.03

$$\text{Corrected Temperature} = T_c = T_o + [(.00009) * (T_o - 20) * (T_o - T_m)]$$

$$\text{Temperature Difference} = \frac{[(T_c + 460) - (T_t + 460)]}{(T_c + 460)} * 100$$

THERMOCOUPLE CALIBRATION

68

Thermocouple No.: R187

Date: 6/08/90

Calibrated By: CCB

Barometric Pressure, Inches Hg: 29.66

Ambient Temperature, °F: 72.0

Mercury-In-Glass Thermometer I.D. No.: 7121K

Calibration System Used	Potentiometer I.D. Number	Reference Thermometer Temperature		Mean Temperature of Hg Column T_m °F	Thermocouple Thermometer Temperature T_t °F	Temperature Diff., % (Allowable: ≤ 1.5 %)
		T_o °F	T_c °F			
Ice Bath	F28	32.0	31.96	72.0	31.6	.07
		32.0	31.96	72.0	31.6	.07
		32.0	31.96	72.0	31.6	.07
Boiling Water	F28	214.0	215.82	110.0	212.6	.48
		214.0	215.82	110.0	212.6	.48
		214.0	215.82	110.0	211.8	.59
Boiling Oil	F28	388.0	396.88	120.0	387.0	1.15
		388.0	396.88	120.0	386.8	1.18
		388.0	396.88	120.0	386.8	1.18

$$\text{Corrected Temperature} = T_c = T_o + [(.00009) * (T_o - 20) * (T_o - T_m)]$$

$$\text{Temperature Difference} = \frac{[(T_c + 460) - (T_t + 460)]}{(T_c + 460)} * 100$$

THERMOCOUPLE CALIBRATION

69

Thermocouple No.: R315

Date: 5/27/91

Calibrated By: WLS

Barometric Pressure, Inches Hg: 29.74

Ambient Temperature, °F: 71.0

Mercury-In-Glass Thermometer I.D. No.: 7121K

Calibration System Used	Potentiometer I.D. Number	Reference Thermometer Temperature		Mean Temperature of Hg Column T_m °F	Thermocouple Thermometer Temperature T_t °F	Temperature Diff., % (Allowable: ≤ 1.5 %)
		T_o °F	T_c °F			
Ice Bath	F41	32.0	31.96	69.0	32.4	-.09
		32.0	31.96	70.0	33.1	-.23
		32.0	31.96	70.0	33.0	-.21
Boiling Water	F41	212.0	213.80	108.0	211.6	.33
		212.0	213.76	110.0	210.8	.44
		212.0	213.75	111.0	211.4	.35
Boiling Oil	F41	386.0	392.65	184.0	384.8	.92
		388.0	394.66	187.0	383.9	1.26
		388.0	394.62	188.0	384.0	1.24

$$\text{Corrected Temperature} = T_c = T_o + [(.00009) * (T_o - 20) * (T_o - T_m)]$$

$$\text{Temperature Difference} = \frac{[(T_c + 460) - (T_t + 460)]}{(T_c + 460)} * 100$$

APPENDIX D**SAMPLING AND ANALYTICAL PROCEDURES**

METHOD 1—SAMPLE AND VELOCITY TRAVERSES FOR STATIONARY SOURCES

1. Principle and Applicability

1.1 Principle. To aid in the representative measurement of pollutant emissions and/or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. A traverse point is then located within each of these equal areas.

1.2 Applicability. This method is applicable to flowing gas streams in ducts, stacks, and flues. The method cannot be used when: (1) flow is cyclonic or swirling (see Section 2.4), (2) a stack is smaller than about 0.30 meter (12 in.) in diameter, or 0.071 m² (113 in.²) cross-sectional area, or (3) the measurement site is less than two stack or duct diameters downstream or less than a half diameter upstream from a flow disturbance.

The requirements of this method must be considered before construction of a new facility from which emissions will be measured: failure to do so may require subsequent alterations to the stack or deviation from the standard procedure. Cases involving variants are subject to approval by the Administrator, U.S. Environmental Protection Agency.

2. Procedure

2.1 Selection of Measurement Site. Sampling or velocity measurement is performed at a site located at least eight stack or duct diameters downstream and two diameters upstream from any flow disturbance such as a bend, expansion, or contraction in the stack, or from a visible flame. If necessary, an alternative location may be selected, at a position at least two stack or duct diameters downstream and a half diameter upstream from any flow disturbance. For a rectangular cross section, an equivalent diameter (*D_e*) shall be calculated from the following equation, to determine the upstream and downstream distances:

$$D_e = \frac{2LW}{(L+W)}$$

where *L* = length and *W* = width.

An alternative procedure is available for determining the acceptability of a measurement location not meeting the criteria above. This procedure, determination of gas flow angles at the sampling points and comparing the results with acceptability criteria, is described in Section 2.5.

2.2 Determining the Number of Traverse Points.

2.2.1 Particulate Traverses. When the eight- and two-diameter criterion can be met, the minimum number of traverse points shall be: (1) twelve, for circular or rectangular stacks with diameters (or equivalent diameters) greater than 0.61 meter (24 in.); (2) eight, for circular stacks with diameters between 0.30 and 0.61 meter (12-24 in.); (3) nine, for rectangular stacks with equivalent diameters between 0.30 and 0.61 meter (12-24 in.).

When the eight- and two-diameter criterion cannot be met, the minimum number of traverse points is determined from Figure 1-1. Before referring to the figure, however, determine the distances from the chosen

measurement site to the nearest upstream and downstream disturbances, and divide each distance by the stack diameter or equivalent diameter, to determine the distance in terms of the number of duct diameters. Then, determine from Figure 1-1 the minimum number of traverse points that corresponds: (1) to the number of duct diameters upstream; and (2) to the number of diameters downstream. Select the higher of the two minimum numbers of traverse points, or a greater value, so that for circular stacks the number is a multiple of 4, and for rectangular stacks, the number is one of those shown in Table 1-1.

TABLE 1-1. CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of traverse points	Stack layout
9	3x3
12	4x3
16	4x4
20	5x4
25	5x5
30	6x5
36	6x6
42	7x6
48	7x7




Figure 1-1. Minimum number of traverse points for particulate traverses.




Figure 1-2. Minimum number of traverse points for velocity (nonparticulate) traverses.

2.3.1.2 Stacks With Diameters Equal to or Less Than 0.61 m (24 in.). Follow the procedure in Section 2.3.1.1, noting only that any "adjusted" points should be relocated away from the stack walls to: (1) a distance of 1.3 cm (0.50 in.); or (2) a distance equal to the nozzle inside diameter, whichever is larger.

2.3.2 Rectangular Stacks. Determine the number of traverse points as explained in Sections 2.1 and 2.2 of this method. From Table 1-1, determine the grid configuration. Divide the stack cross-section into as many equal rectangular elemental areas as traverse points, and then locate a traverse point at the centroid of each equal area according to the example in Figure 1-4.

If the tester desires to use more than the minimum number of traverse points, expand the "minimum number of traverse points" matrix (see Table 1-1) by adding the extra traverse points along one or the other or both legs of the matrix; the final matrix need not be balanced. For example, if a 4x3 "minimum number of points" matrix were expanded to 36 points, the final matrix could be 9x4 or 12x3, and would not necessarily have to be 6x6. After constructing the final matrix, divide the stack cross-section into as many equal rectangular, elemental areas as traverse points, and locate a traverse point at the centroid of each equal area.

The situation of traverse points being too close to the stack walls is not expected to arise with rectangular stacks. If this problem should ever arise, the Administrator must be contacted for resolution of the matter.

2.4 Verification of Absence of Cyclonic Flow. In most stationary sources, the direction of stack gas flow is essentially parallel to the stack walls. However, cyclonic flow may exist (1) after such devices as cyclones and inertial demisters following venturi scrubbers, or (2) in stacks having tangential inlets or other duct configurations which tend to induce swirling; in these instances, the presence or absence of cyclonic flow at the sampling location must be determined. The following techniques are acceptable for this determination.




Figure 1-4. Example showing rectangular stack cross section divided into 12 equal areas, with a traverse point at centroid of each area.

Level and zero the manometer. Connect a Type S pitot tube to the manometer. Position the Type S pitot tube at each traverse point, in succession, so that the planes of the face openings of the pitot tube are perpendicular to the stack cross-sectional plane; when the Type S pitot tube is in this position, it is at "0° reference." Note the differential pressure (Δp) reading at each traverse point. If a null (zero) pitot reading is obtained at 0° reference at a given traverse point, an acceptable flow condition exists at that point. If the pitot reading is not zero at 0° reference, rotate the pitot tube (up to $\pm 90^\circ$ yaw angle), until a null reading is obtained. Carefully determine and record the value of the rotation angle (α) to the nearest degree. After the null technique has been applied at each traverse point, calculate the average of the absolute values of α ; assign a value of 0° to those points for which no rotation was required, and include these in the overall average. If the average value of α is greater than 20°, the overall flow condition in the stack is unacceptable and alternative methodology, subject to the approval of the Administrator, must be used to perform accurate sample and velocity traverses.

The alternative procedure described in Section 2.5 may be used to determine the rotation angles in lieu of the procedure described above. The limit of acceptability for the average value of α would remain 20°.

2.5 Alternative Measurement Site Selection Procedure. This alternative applies to sources where measurement locations are less than 2 equivalent stack or duct diameters downstream or less than 1/4 duct diameter upstream from a flow disturbance. The alternative should be limited to ducts larger than 24 in. in diameter where blockage and wall effects are minimal. A directional flow-sensing probe is used to measure pitch and yaw angles of the gas flow at 40 or more traverse points; the resultant angle is calculated and compared with acceptable criteria for mean and standard deviation.

Note.—Both the pitch and yaw angles are measured from a line passing through the traverse point and parallel to the stack axis. The pitch angle is the angle of the gas flow component in the plane that INCLUDES the traverse line and is parallel to the stack axis. The yaw angle is the angle of the gas flow component in the plane PERPENDICULAR to the traverse line at the traverse point and is measured from the line passing through the traverse point and parallel to the stack axis.

2.5.1 Apparatus

2.5.1.1 Directional Probe. Any directional probe, such as United Sensor Type DA Three-Dimensional Directional Probe, capable of measuring both the pitch and yaw angles of gas flows is acceptable. (Note: Mention of trade name or specific products does not constitute endorsement by the U.S. Environmental Protection Agency.) Assign an identification number to the directional

probe, and permanently mark or engrave the number on the body of the probe. The pressure holes of directional probes are susceptible to plugging when used in particulate-laden gas streams. Therefore, a system for cleaning the pressure holes by "back-purging" with pressurized air is required.

2.5.1.2 Differential Pressure Gauges. Inclined manometers, U-tube manometers, or other differential pressure gauges (e.g., magnetic gauges) that meet the specifications described in Method 2, § 2.2.

Note.—If the differential pressure gauge produces both negative and positive readings, then both negative and positive pressure readings shall be calibrated at a minimum of three points as specified in Method 2, § 2.2.

2.5.2 Traverse Points. Use a minimum of 40 traverse points for circular ducts and 42 points for rectangular ducts for the gas flow angle determinations. Follow § 2.3 and Table 1-1 or 1-2 for the location and layout of the traverse points. If the measurement location is determined to be acceptable according to the criteria in this alternative procedure, use the same traverse point number and location for sampling and velocity measurements.

2.5.3 Measurement Procedure

2.5.3.1 Prepare the directional probe and differential pressure gauges as recommended by the manufacturer. Capillary tubing or surge tanks may be used to dampen pressure fluctuations. It is recommended, but not required, that a pressure leak check be conducted. To perform a leak check, pressurize or use suction on the impact opening until a reading of at least 7.5 cm (3 in.) H₂O registers on the differential pressure gauge, then plug the impact opening. The pressure of a leak-free system will remain stable for at least 15 seconds.

2.5.3.2 Level and zero the manometers. Since the manometer level and zero may drift because of vibrations and temperature changes, periodically check the level and zero during the traverse.

2.5.3.3 Position the probe at the appropriate locations in the gas stream, and rotate until zero deflection is indicated for yaw angle pressure gauge. Determine and record the yaw angle. Record the pressure gauge readings for the pitch angle, and determine the pitch angle from the calibration curve. Repeat this procedure for each traverse point. Complete a "back-purge" of the pressure lines and the impact openings prior to measurements of each traverse point.

A post-test check as described in § 2.5.3.1 is required. If the criteria for a leak-free system are not met, repair the equipment, repeat the flow angle measurements.

2.5.4 Calculate the resultant angle at each traverse point, the average resultant angle, and the standard deviation using the following equations. Complete the calculations retaining at least one extra significant figure beyond that of the acquired data. Round the values after the final calculations.

METHOD 2—DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE (TYPE S PITOT TUBE)

1. Principle and Applicability

1.1 Principle. The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Stauscheibe or reverse type) pitot tube.

1.2 Applicability. This method is applicable for measurement of the average velocity of a gas stream and for quantifying gas flow.

This procedure is not applicable at measurement sites which fail to meet the criteria of Method 1, Section 2.1. Also, the method cannot be used for direct measurement in cyclonic or swirling gas streams; Section 2.4 of Method 1 shows how to determine cyclonic or swirling flow conditions. When unacceptable conditions exist, alternative procedures, subject to the approval of the Administrator, U.S. Environmental Protection Agency, must be employed to make accurate flow rate determinations; examples of such alternative procedures are: (1) to install straightening vanes; (2) to calculate the total volumetric flow rate stoichiometrically, or (3) to move to another measurement site at which the flow is acceptable.

2. Apparatus

Specifications for the apparatus are given below. Any other apparatus that has been demonstrated (subject to approval of the Administrator) to be capable of meeting the specifications will be considered acceptable.

2.1 Type S Pitot Tube. The Type S pitot tube (Figure 2-1) shall be made of metal tubing (e.g. stainless steel). It is recommended that the external tubing diameter (dimension D, Figure 2-2b) be between 0.48 and 0.95 centimeters ($\frac{1}{8}$ and $\frac{3}{16}$ inch). There shall be an equal distance from the base of each leg of the pitot tube to its face-opening plane (dimensions P₁ and P₂, Figure 2-2b); it is recommended that this distance be between 1.05 and 1.50 times the external tubing diameter. The face openings of the pitot tube shall, preferably, be aligned as shown in Figure 2-2; however, slight misalignments of the openings are permissible (see Figure 2-3).

The Type S pitot tube shall have a known coefficient, determined as outlined in Section 4, an identification number shall be assigned to the pitot tube; this number shall be permanently marked or engraved on the body of the tube.




Figure 2-1. Type S pitot tube manometer assembly.




Figure 2-3. Types of face-opening misalignment that can result from field use or improper construction of Type S pitot tubes. These will not affect the baseline value of $C_p(s)$ so long as α_1 and α_2 10° , β_1 and β_2 5° , z 0.32 cm (1/8 in.) and w 0.08 cm (1/32 in.) (citation 11 in Bibliography).

A standard pitot tube may be used instead of a Type S, provided that it meets the specifications of Sections 2.7 and 4.2; note, however, that the static and impact pressure holes of standard pitot tubes are susceptible to plugging in particulate-laden gas streams. Therefore, whenever a standard pitot tube is used to perform a traverse, adequate proof must be furnished that the openings of the pitot tube have not plugged up during the traverse period; this can be done by taking a velocity head (Δp) reading at

the final traverse point, cleaning out the impact and static holes of the standard pitot tube by "back-purging" with pressurized air, and then taking another Δp reading. If the Δp readings made before and after the air purge are the same (± 5 percent), the traverse is acceptable. Otherwise, reject the run. Note that if Δp at the final traverse point is unsuitably low, another point may be selected. If "back-purging" at regular intervals is part of the procedure, then comparative Δp readings shall be




Figure 2-4. Standard pitot tube design specifications.

3. Procedure

3.1 Set up the apparatus as shown in Figure 2-1. Capillary tubing or surge tanks installed between the manometer and pitot tube may be used to dampen Δp fluctuations. It is recommended, but not required, that a pretest leak-check be conducted, as follows: (1) blow through the pitot impact opening until at least 7.6 cm (3 in.) H₂O velocity pressure registers on the manometer; then, close off the impact opening. The pressure shall remain stable for at least 15 seconds; (2) do the same for the static pressure side, except using suction to obtain the minimum of 7.6 cm (3 in.) H₂O. Other leak-check procedures, subject to the approval of the Administrator may be used.


3.2 Level and zero the manometer. Because the manometer level and zero may

drift due to vibrations and temperature changes, make periodic checks during the traverse. Record all necessary data as shown in the example data sheet (Figure 2-5).


3.3 Measure the velocity head and temperature at the traverse points specified by Method 1. Ensure that the proper differential pressure gauge is being used for the range of Δp values encountered (see Section 2.2). If it is necessary to change to a more sensitive gauge, do so, and remeasure the Δp and temperature readings at each traverse point. Conduct a post-test leak-check (mandatory), as described in Section 3.1 above, to validate the traverse run.

3.4 Measure the static pressure in the stack. One reading is usually adequate.

3.5 Determine the atmospheric pressure.



A. BOTTOM VIEW: SHOWING MINIMUM PITOT-NOZZLE SEPARATION.



B. SIDE VIEW: TO PREVENT PITOT TUBE FROM INTERFERING WITH GAS FLOW STREAMLINES APPROACHING THE NOZZLE, THE IMPACT PRESSURE OPENING PLANE OF THE PITOT TUBE SHALL BE EVEN WITH OR ABOVE THE NOZZLE ENTRY PLANE.

Figure 2-6. Proper pitot tube-sampling nozzle configuration to prevent aerodynamic interference: bottomhook-type nozzle; centers of nozzle and pitot opening aligned; D_t between 0.48 and 0.95 cm (3/16 and 3/8 in.).

4.1.1 Type S Pitot Tube Assemblies. During sample and velocity traverses, the isolated Type S pitot tube is not always used; in many instances, the pitot tube is used in combination with other source-sampling components (thermocouple, sampling probe, nozzle) as part of an "assembly." The presence of other sampling components can sometimes affect the baseline value of the Type S pitot tube coefficient (Citation 9 in Bibliography); therefore an assigned or otherwise known baseline coefficient value may or may not be valid for a given assembly. The baseline and assembly coefficient values will be identical only when the relative placement of the components in the assembly is such that aerodynamic interference effects are eliminated. Figures 2-6 through 2-8 illustrate interference-free component arrangements for Type S pitot tubes having external tubing diameters between 0.48 and 0.95 cm (3/16 and 3/8 in.). Type S pitot tube assemblies that fail to meet any or all of the specifications of Figures 2-6 through 2-8 shall be calibrated according to the procedure outlined in Sections 4.1.2 through 4.1.5 below, and prior to calibration, the values of the intercomponent spacings (pitot-nozzle, pitot-thermocouple, pitot-probe sheath) shall be measured and recorded.

NOTE: Do not use any Type S pitot tube assembly which is constructed such that the impact pressure opening plane of the pitot tube is below the entry plane of the nozzle (see Figure 2-6b).

4.1.2 Calibration Setup. If the Type S pitot tube is to be calibrated, one leg of the tube shall be permanently marked A, and the other, B. Calibration shall be done in a flow system having the following essential design features:




Figure 2-7. Proper thermocouple placement to prevent interference; D_t between 0.48 and 0.95 cm (3/16 and 3/8 in.).




Figure 2-8. Minimum pitot-sample probe separation needed to prevent interference; D_t between 0.48 and 0.95 cm (3/16 and 3/8 in.).

$$C_{p(A)} = C_{p(Std)} \sqrt{\frac{\Delta p_{Std}}{\Delta p_s}}$$

Equation 2-2

where:

$C_{p(Std)}$ = Type S pitot tube coefficient

$C_{p(Std)}$ = Standard pitot tube coefficient; use 0.99 if the coefficient is unknown and the tube is designed according to the criteria of Sections 2.7.1 to 2.7.5 of this method.

Δp_{Std} = Velocity head measured by the standard pitot tube, cm H₂O (in. H₂O)

Δp_s = Velocity head measured by the Type S pitot tube, cm H₂O (in. H₂O)

4.1.4.2 Calculate $\bar{C}_p$ (side A), the mean A-side coefficient, and $\bar{C}_p$ (side B), the mean B-side coefficient; calculate the difference between these two average values.

4.1.4.3 Calculate the deviation of each of the three A-side values of $C_{p(A)}$ from $\bar{C}_p$ (side A), and the deviation of each B-side value of $C_{p(B)}$ from $\bar{C}_p$ (side B). Use the following equation:

$$\text{Deviation} = C_{p(A)} - \bar{C}_p(A \text{ or } B)$$

Equation 2-3

4.1.4.4 Calculate σ , the average deviation from the mean, for both the A and B sides of the pitot tube. Use the following equation:

$$\sigma(\text{side A or B}) = \frac{\sum_{i=1}^3 |C_{p(A)} - \bar{C}_p(A \text{ or } B)|}{3}$$

Equation 2-4

4.1.4.5 Use the Type S pitot tube only if the values of σ (side A) and σ (side B) are less than or equal to 0.01 and if the absolute value of the difference between C_p (A) and C_p (B) is 0.01 or less.

4.1.5 Special considerations.

4.1.5.1 Selection of calibration point.

4.1.5.1.1 When an isolated Type S pitot tube is calibrated, select a calibration point at or near the center of the duct, and follow the procedures outlined in Sections 4.1.3 and 4.1.4 above. The Type S pitot coefficients so obtained, i.e., C_p (side A) and C_p (side B), will be valid, so long as either: (1) the isolated pitot tube is used; or (2) the pitot tube is used with other components (nozzle, thermocouple, sample probe) in an arrangement that is free from aerodynamic interference effects (see Figures 2-6 through 2-8).

4.1.5.1.2 For Type S pitot tube-thermocouple combinations (without sample probe), select a calibration point at or near the center of the duct, and follow the procedures outlined in Sections 4.1.3 and 4.1.4 above. The coefficients so obtained will be valid so long as the pitot tube-thermocouple combination is used by itself or with other components in an interference-free arrangement (Figures 2-6, and 2-8).

4.1.5.1.3 For assemblies with sample probes, the calibration point should be located at or near the center of the duct; however, insertion of a probe sheath into a small duct may cause significant cross-sectional area blockage and yield incorrect coefficient values (Citation 9 in Bibliography). Therefore, to minimize the blockage effect, the calibration point may be a few inches

off-center if necessary. The actual blockage effect will be negligible when the theoretical blockage, as determined by a projected-area model of the probe sheath, is 2 percent or less of the duct cross-sectional area for assemblies without external sheaths (Figure 2-10a), and 3 percent or less for assemblies with external sheaths (Figure 2-10b).

4.1.5.2 For those probe assemblies in which pitot tube-nozzle interference is a factor (i.e., those in which the pitot-nozzle separation distance falls to meet the specification illustrated in Figure 2-8a), the value of $C_{p(A)}$ depends upon the amount of free-space between the tube and nozzle, and therefore is a function of nozzle size. In these instances, separate calibrations shall be performed with each of the commonly used nozzle sizes in place. Note that the single-velocity calibration technique is acceptable for this purpose, even though the larger nozzle sizes (>0.635 cm or 1/4 in.) are not ordinarily used for isokinetic sampling at velocities around 915 m/min (3,000 ft/min), which is the calibration velocity; note also that it is not necessary to draw an isokinetic sample during calibration (see Citation 19 in Section 6).

4.1.5.3 For a probe assembly constructed such that its pitot tube is always used in the same orientation, only one side of the pitot tube need be calibrated (the side which will face the flow). The pitot tube must still meet the alignment specifications of Figure 2-2 or 2-3, however, and must have an average deviation (σ) value of 0.01 or less (see Section 4.1.4.4).




Figure 2-10. Projected-area models for typical pitot tube assemblies.

METHOD 3—GAS ANALYSIS FOR CARBON DIOXIDE, OXYGEN, EXCESS AIR, AND DRY MOLECULAR WEIGHT

1. Principle and Applicability

1.1 Principle. A gas sample is extracted from a stack, by one of the following methods: (1) single-point, grab sampling; (2) single-point, integrated sampling; or (3) multi-point, integrated sampling. The gas sample is analyzed for percent carbon dioxide (CO_2), percent oxygen (O_2), and, if necessary, percent carbon monoxide (CO). If a dry molecular weight determination is to be made, either an Orsat or a Pyrite analyzer may be used for the analysis; for excess air or emission rate correction factor determination, an Orsat analyzer must be used.

1.2 Applicability. This method is applicable for determining CO_2 and O_2 concentrations, excess air, and dry molecular weight of a sample from a gas stream of a fossil-fuel combustion process. The method may also be applicable to other processes where it has been determined that compounds other than CO_2 , O_2 , CO , and nitrogen (N_2) are not present in concentrations sufficient to affect the results.

Other methods, as well as modifications to the procedure described herein, are also applicable for some or all of the above determinations. Examples of specific methods and modifications include: (1) a multi-point sampling method using an Orsat analyzer to analyze individual grab samples obtained at each point; (2) a method using CO_2 or O_2 and stoichiometric calculations to determine dry molecular weight and excess air; (3) assigning a value of 30.0 for dry molecular weight, in lieu of actual measurements, for processes burning natural gas, coal, or oil. These methods and modifications may be used, but are subject to the approval of the Administrator, U.S. Environmental Protection Agency.

2. Apparatus

As an alternative to the sampling apparatus and systems described herein, other sampling systems (e.g., liquid displacement) may be used provided such systems are capable of obtaining a representative sample and maintaining a constant sampling rate, and are otherwise capable of yielding acceptable results. Use of such systems is subject to the approval of the Administrator.

2.1 Grab Sampling (Figure 3-1).

2.1.1 Probe. The probe should be made of stainless steel or borosilicate glass tubing and should be equipped with an in-stack or out-stack filter to remove particulate matter (a plug of glass wool is satisfactory for this purpose). Any other materials inert to O_2 , CO_2 , CO , and N_2 and resistant to temperature at sampling conditions may be used for the probe; examples of such material are aluminum, copper, quartz glass and Teflon.

2.1.2 Pump. A one-way squeeze bulb, or equivalent, is used to transport the gas sample to the analyzer.

2.2 Integrated Sampling (Figure 3-2).

2.2.1 Probe. A probe such as that described in Section 2.1.1 is suitable.

2.2.2 Condenser. An air-cooled or water-cooled condenser, or other condenser that will not remove O_2 , CO_2 , CO , and N_2 , may be used to remove excess moisture which would interfere with the operation of the pump and flow meter.

2.2.3 Valve. A needle valve is used to adjust sample gas flow rate.

2.2.4 Pump. A leak-free, diaphragm-type pump, or equivalent, is used to transport sample gas to the flexible bag. Install a small surge tank between the pump and rate meter to eliminate the pulsation effect of the diaphragm pump on the rotameter.

2.2.5 Rate Meter. The rotameter, or equivalent rate meter, used should be capable of measuring flow rate to within ± 2 percent of the selected flow rate. A flow rate range of 500 to 1000 cm^3/min is suggested.

2.2.6 Flexible Bag. Any leak-free plastic (e.g., Tedlar, Mylar, Teflon) or plastic-coated aluminum (e.g., aluminized Mylar) bag, or equivalent, having a capacity consistent with the selected flow rate and time

length of the test run, may be used. A capacity in the range of 55 to 90 liters is suggested.

To leak-check the bag, connect it to a water manometer and pressurize the bag to 5 to 10 cm H_2O (2 to 4 in. H_2O). Allow to stand for 10 minutes. Any displacement in the water manometer indicates a leak. An alternative leak-check method is to pressurize the bag to 5 to 10 cm H_2O (2 to 4 in. H_2O) and allow to stand overnight. A deflated bag indicates a leak.

2.2.7 Pressure Gauge. A water-filled U-tube manometer, or equivalent, of about 30 cm (12 in.) is used for the flexible bag leak-check.

2.2.8 Vacuum Gauge. A mercury manometer, or equivalent, of at least 760 mm Hg (30 in. Hg) is used for the sampling train leak-check.

2.3 Analysis. For Orsat and Pyrite analyzer maintenance and operation procedures, follow the instructions recommended by the manufacturer, unless otherwise specified herein.




Figure 3-1. Grab sampling train.




Figure 3-2. Integrated gas-sampling train.

Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.

4.2.5 To insure complete absorption of the CO₂, O₂, or if applicable, CO, make repeated passes through each absorbing solution until two consecutive readings are the same. Several passes (three or four) should be made between readings. (If constant readings cannot be obtained after three consecutive readings, replace the absorbing solution.)

4.2.6 Repeat the analysis until the following criteria are met:

4.2.6.1 For percent CO₂, repeat the analytical procedure until the results of any three analyses differ by no more than (a) 0.3 percent by volume when CO₂ is greater than 4.0 percent or (b) 0.2 percent by volume when CO₂ is less than or equal to 4.0 percent. Average the three acceptable values of percent CO₂ and report the results to the nearest 0.1 percent.

4.2.6.2 For percent O₂, repeat the analytical procedure until the results of any three analyses differ by no more than (a) 0.3 percent by volume when O₂ is less than 15.0 percent or (b) 0.2 percent by volume when O₂ is greater than or equal to 15.0 percent. Average the three acceptable values of percent O₂ and report the results to the nearest 0.1 percent.

4.2.6.3 For percent CO, repeat the analytical procedure until the results of any three analyses differ by no more than 0.3 percent. Average the three acceptable values of percent CO and report the results to the nearest 0.1 percent.

4.2.7 After the analysis is completed, leak-check (mandatory) the Orsat analyzer once again, as described in Section 5. For the results of the analysis to be valid, the Orsat analyzer must pass this leak test before an after the analysis.

NOTE: Although in most instances only CO₂ or O₂ is required, it is recommended that both CO₂ and O₂ be measured, and that Section 4.4.1 be used to validate the analytical data.

4.3 Multi-Point, Integrated Sampling and Analytical Procedure.

4.3.1 Both the minimum number of sampling points and the sampling point location shall be as specified in Section 3.3.1 of this method. The use of fewer points than specified is subject to the approval of the Administrator.

4.3.2 Follow the procedures outlined in Sections 4.2.2 through 4.2.7, except for the following: Traverse all sampling points and sample at each point for an equal length of time. Record sampling data as shown in Figure 3-3.

4.4 Quality Control Procedures.

4.4.1 Data Validation When Both CO₂ and O₂ Are Measured. Although in most instances, only CO₂ or O₂ measurement is required, it is recommended that both CO₂ and O₂ be measured to provide a check on the quality of the data. The following quality control procedure is suggested.

NOTE: Since the method for validating the CO₂ and O₂ analyses is based on combustion of organic and fossil fuels and dilution of the gas stream with air, this method does not apply to sources that (1) remove CO₂ or O₂ through processes other than combustion, (2) add O₂ (e.g., oxygen enrichment) and N₂ in proportions different from that of air, (3) add CO₂ (e.g., cement or lime kilns), or (4) have no fuel factor, F_u, values obtainable (e.g., extremely variable waste mixtures). This method validates the measured concentrations of CO₂ and O₂ for the fuel type.

for samples collected downstream of most lime or limestone flue-gas desulfurization units as the CO₂ added or removed from the gas stream is not significant in relation to the total CO₂ concentration. The CO₂ concentrations from other types of scrubbers using only water or basic slurry can be significantly affected and would render the F_u check minimally useful.

4.4.1.1 Calculate a fuel factor, F_u, using the following equation:

$$F_u = \frac{20.9 - \%O_2}{\%CO_2}$$

Eq. 3-3

Where:

%O₂ = Percent O₂ by volume (dry basis).

%CO₂ = Percent CO₂ by volume (dry basis).

20.9 = Percent O₂ by volume in ambient air.

If CO is present in quantities measurable by this method, adjust the O₂ and CO₂ values before performing the calculation for F_u as follows:

$$\%CO_2(\text{adj}) = \%CO_2 + \%CO$$

$$\%O_2(\text{adj}) = \%O_2 - 0.5 \%CO$$

Where: %CO = Percent CO by volume (dry basis).

4.4.1.2 Compare the calculated F_u factor with the expected F_u values. The following table may be used in establishing acceptable ranges for the expected F_u, if the fuel being burned is known. When fuels are burned in combination, calculate the combined fuel F_u and F_u factors (as defined in Method 19) according to the procedure in Method 19 Section 5.2.3. Then calculate the F_u factor as follows:

$$F_u = \frac{0.209 F_u}{F_u}$$

Eq. 3-4

Fuel type	F _u range
Coal:	
Anthracite and lignite	1.016-1.130
Subbituminous	1.063-1.230
Oil:	
Distillate	1.260-1.413
Residual	1.210-1.370
Gas:	
Natural	1.600-1.636
Propane	1.434-1.566
Butane	1.406-1.563
Wood	1.000-1.120
Wood bark	1.003-1.130

Calculated F_u values beyond the acceptable ranges shown in this table should be investigated before accepting the test results. For example, the strength of the solutions in the gas analyzer and the analyzing technique should be checked by sampling and analyzing a known concentration, such as air; the fuel factor should be reviewed and verified. An acceptability range of ±12 percent is appropriate for the F_u factor of mixed fuels with variable fuel ratios. The level of the emission rate relative to the compliance level should be considered in determining if a retest is appropriate, i.e., if the measured emissions are much lower or much greater than the compliance limit, repetition of the test would not significantly

5. Leak-Check Procedure for Orsat Analyzers

Moving an Orsat analyzer frequently causes it to leak. Therefore, an Orsat analyzer should be thoroughly leak-checked on site before the flue gas sample is introduced into it. The procedure for leak-checking an Orsat analyzer is:

5.1.1 Bring the liquid level in each pipette up to the reference mark on the capillary tubing and then close the pipette stopcock.

5.1.2 Raise the leveling bulb sufficiently to bring the confining liquid meniscus onto the graduated portion of the burette and then close the manifold stopcock.

5.1.3 Record the meniscus position.

5.1.4 Observe the meniscus in the burette and the liquid level in the pipette for movement over the next 4 minutes.

5.1.5 For the Orsat analyzer to pass the leak-check, two conditions must be met.

5.1.5.1 The liquid level in each pipette must not fall below the bottom of the capillary tubing during this 4-minute interval.

5.1.5.2 The meniscus in the burette must not change by more than 0.2 ml during this 4-minute interval.

5.1.6 If the analyzer fails the leak-check procedure, all rubber connections and stopcocks should be checked until the cause of the leak is identified. Leaking stopcocks must be disassembled, cleaned, and re-greased. Leaking rubber connections must be replaced. After the analyzer is reassembled, the leak-check procedure must be repeated.

6. Calculations

6.1 Nomenclature.

M_u = Dry molecular weight, g/g-mole (lb/lb-mole).

%EA = Percent excess air.

%CO₂ = Percent CO₂ by volume (dry basis).

%O₂ = Percent O₂ by volume (dry basis).

%CO = Percent CO by volume (dry basis).

%N₂ = Percent N₂ by volume (dry basis).

0.264 = Ratio of O₂ to N₂ in air, v/v.

0.280 = Molecular weight of N₂ or CO, divided by 100.

0.320 = Molecular weight of O₂, divided by 100.

0.440 = Molecular weight of CO₂, divided by 100.

6.2 Percent Excess Air. Calculate the percent excess air (if applicable), by substituting the appropriate values of percent O₂, CO₂, and N₂ (obtained from Section 4.1.3 or 4.2.4) into Equation 3-1.

%EA =

$$\frac{\%O_2 - 0.5\%CO}{0.264\%N_2 - (\%O_2 - 0.5\%CO)} \times 100$$

Equation 3-1

NOTE: The equation above assumes that ambient air is used as the source of O₂, and that the fuel does not contain appreciable amounts of N₂ (as do coke oven or blast furnace gases). For those cases when appreciable amounts of N₂ are present (coal, oil, and natural gas do not contain appreciable amounts of N₂) or when oxygen enrichment is used, alternate methods, subject to approval of the Administrator, are required.

6.3 Dry Molecular Weight. Use Equation 3-2 to calculate the dry molecular weight of the stack gas

$$M_u = 0.440(\%CO_2) + 0.320(\%O_2) + 0.280(\%N_2 + \%CO)$$

Equation 3-2

METHODOLOGY FOR THE DETERMINATION OF METALS EMISSIONS IN EXHAUST GASES FROM HAZARDOUS WASTE INCINERATION AND SIMILAR COMBUSTION PROCESSES

1. Applicability and Principle

1.1 Applicability. This method is being developed for applicability for the determination of total chromium (Cr), cadmium (Cd), arsenic (As), nickel (Ni), manganese (Mn), beryllium (Be), copper (Cu), zinc (Zn), lead (Pb), selenium (Se), phosphorus (P), thallium (Tl), silver (Ag), antimony (Sb), barium (Ba), and mercury (Hg) stack emissions from hazardous waste incinerators and similar combustion processes. This method may also be used for the determination of particulate emissions following the procedures and precautions described. Modifications to the sample recovery and analysis procedures described in this protocol for the purpose of determining particulate emissions may potentially impact the front-half mercury determination.

1.2 Principle. The stack sample is withdrawn isokinetically from the source, with particulate emissions collected in the probe and on a heated filter and gaseous emissions collected in a series of chilled impingers containing an aqueous solution of dilute nitric acid combined with dilute hydrogen peroxide in each of two impingers, and acidic potassium permanganate solution in each of two impingers. Sampling train components are recovered and digested in separate front- and back-half fractions. Materials collected in the sampling train are digested with acid solutions to dissolve inorganics and to remove organic constituents that may create analytical interferences. Acid digestion is performed using conventional Parr[®] Bomb or microwave digestion techniques. The nitric acid and hydrogen peroxide impinger solution, the acidic potassium permanganate impinger solution, the HCl rinse solution, and the probe rinse and digested filter solutions are analyzed for mercury by cold vapor atomic absorption spectroscopy (CVAAS). The nitric acid and hydrogen peroxide solution and the probe rinse and digested filter solutions of the train catches are analyzed for Cr, Cd, Ni, Mn, Be, Cu, Zn, Pb, Se, P, Tl, Ag, Sb, Ba, and As by inductively coupled argon plasma emission spectroscopy (ICAP) or atomic absorption spectroscopy (AAS). Graphite furnace atomic absorption spectroscopy (GFAAS) is used for analysis of antimony, arsenic, cadmium, lead, selenium, and thallium, if these elements require greater analytical

for the following metals: Sb (3 ng/mL), As (1 ng/mL), Be (0.2 ng/mL), Cd (0.2 ng/mL), Cr (1 ng/mL), Pb (1 ng/mL), Se (2 ng/mL), and Tl (1 ng/mL).

Using (1) the procedures described in this method, (2) the analytical detection limits described in the previous paragraph, (3) a volume of 300 mL Fraction 1, for the front half and 150 mL Fraction 2A, for the back-half samples, and (4) a stack gas sample volume of 1.25 m³, the corresponding in-stack method detection limits are presented in Table A-1 and calculated as shown:

$$\frac{A \times B}{C} = D$$

where: A = analytical detection limit, ug/mL.
B = volume of sample prior to aliquot for analysis, mL.
C = stack sample volume, dscm (dscm³).
D = in-stack detection limit, ug/m³.

Values in Table A-1 are calculated for the front and back half and/or the total train.

To ensure optimum sensitivity in obtaining the measurements, the concentrations of target metals in the solutions are suggested to be at least ten times the analytical detection limits. Under certain conditions, and with greater care in the analytical procedure, this concentration can be as low as approximately three times the analytical detection limit. In all cases, on at least one sample (run) in the source test and for each metal analyzed, repetitive analyses, method of standard additions (MSA), serial dilution, or matrix spike addition, etc., shall be used to establish the quality of the data.

Actual in-stack method detection limits will be determined based on actual source sampling parameters and analytical results as described above. If required, the method in-stack detection limits can be made more sensitive than those shown in Table A-1 for a specific test by using one or more of the following options:

- o A 1-hour sampling run may collect a stack gas sampling volume of about 1.25 m³. If the sampling time is increased and 5 m³ are collected, the in-stack method detection limits would be one fourth of the values shown in Table A-1 (this means that with this change, the method is four times more sensitive than a 1-hour run. Larger sample volumes (longer runs) would make it even more sensitive).

- o When both of the above two improvements are used on one sample at the same time, the resultant improvements are multiplicative. For example, where stack gas volume is increased by a factor of five and the total liquid sample digested volume of both the front and back halves is reduced by factor of six, the in-stack method detection limit is reduced by a factor of thirty (the method is thirty times more sensitive).
- o Conversely, reducing stack gas sample volume and increasing sample liquid volume will increase in-stack detection limits (the method would then be less sensitive). The front-half and back-half samples (Fractions 1A plus and 2A) can be combined proportionally (see Section 1.2 of this methodology) prior to analysis. The resultant liquid volume (excluding the mercury fractions, which must be analyzed separately) is recorded. Combining the sample as described does not allow determination (whether front or back half) of where in the train the sample was captured. The in-stack method detection limit then becomes a single value for all metals except mercury, for which the contribution of the mercury fractions must be considered.
- o The above discussion assumes no blank correction. Blank corrections are discussed later in this method.

2.3 Precision. The precisions (relative standard deviation) for each metal detected in a method development test at a sewage sludge incinerator, are as follows: Sb (12.7%), As (13.5%), Ba (20.6%), Cd (11.5%), Cr (11.2%), Cu (11.5%), Pb (11.6%), P (14.6%), Se (15.3%), Tl (12.3%), and Zn (11.8%). The precision for nickel was 7.7% for another test conducted at a source simulator. Beryllium, manganese and silver were not detected in the tests; however, based on the analytical sensitivity of the ICAP for these metals, it is assumed that their precisions should be similar to those for the other metals, when detected at similar levels.

2.4 Interferences. Iron can be a spectral interference during the analysis of arsenic, chromium, and cadmium by ICAP. Aluminum can be a spectral interference during the analysis of arsenic and lead by ICAP. Generally, these interferences can be reduced by diluting the sample, but this increases the method detection limit (in-stack detection limit). Refer to EPA Method 6010 (SW-846) or the other analytical methods used for details on potential interferences for this method. The analyst must eliminate or reduce




Figure A-1. Schematic of multiple metals sampling train configuration.

3.3.1 Volumetric Flasks, 100-mL, 250-mL, and 1000-mL. For preparation of standards and sample dilution.

3.3.2 Graduated Cylinders. For preparation of reagents.

3.3.3 Parr[®] Bombs or Microwave Pressure Relief Vessels with Capping Station (CEM Corporation model or equivalent).

3.3.4 Beakers and Watchglasses. 250-mL beakers for sample digestion with watchglasses to cover the tops.

3.3.5 Ring Stands and Clamps. For securing equipment such as filtration apparatus.

3.3.6 Filter Funnels. For holding filter paper.

3.3.7 Whatman 541 Filter Paper (or equivalent). For filtration of digested samples.

3.3.8 Disposable Pasteur Pipets and Bulbs.

3.3.9 Volumetric Pipets.

3.3.10 Analytical Balance. Accurate to within 0.1 mg.

3.3.11 Microwave or Conventional Oven. For heating samples at fixed power levels or temperatures.

3.3.12 Hot Plates.

3.3.13 Atomic Absorption Spectrometer (AAS). Equipped with a background corrector.

3.3.13.1 Graphite Furnace Attachment. With antimony, arsenic, cadmium, lead, selenium, thallium, and hollow cathode lamps (HCLs) or electrodeless discharge lamps (EDLs). Same as EPA SW-846 Methods 7041 (antimony), 7060 (arsenic), 7131 (cadmium), 7421 (lead), 7740 (selenium), and 7841 (thallium).

3.3.13.2 Cold Vapor Mercury Attachment. With a mercury HCL or EDL. The equipment needed for the cold vapor mercury attachment includes an air recirculation pump, a quartz cell, an aerator apparatus, and a heat lamp or desiccator tube. The heat lamp should be capable of raising the ambient temperature at the quartz cell by 10°C such that no condensation forms on the wall of the quartz cell. Same as EPA Method 7470.

3.3.14 Inductively Coupled Argon Plasma Spectrometer. With either a direct or sequential reader and an alumina torch. Same as EPA Method 6010.

4. Reagents

The complexity of this methodology is such that to obtain reliable results, the testers (including analysts) should be experienced and knowledgeable in

of water, and then add carefully with stirring 333 mL of 30 percent H_2O_2 . Dilute to volume with water. Mix well. The reagent shall contain less than 2 ng/mL of each target metal.

4.2.2 Acidic Potassium Permanganate ($KMnO_4$) Absorbing Solution, 4 Percent $KMnO_4$ (W/V), 10 Percent H_2SO_4 (V/V). Prepare fresh daily. Mix carefully, with stirring, 100 mL of concentrated H_2SO_4 into 800 mL of water, and add water with stirring to make a volume of 1 L: this solution is 10 percent H_2SO_4 (V/V). Dissolve, with stirring, 40 g of $KMnO_4$ into 10 percent H_2SO_4 (V/V) and add 10 percent H_2SO_4 (V/V) with stirring to make a volume of 1 L: this is the acidic potassium permanganate absorbing solution. Prepare and store in glass bottles to prevent degradation. The reagent shall contain less than 2 ng/mL of Hg.

Precaution: To prevent autocatalytic decomposition of the permanganate solution, filter the solution through Whatman 541 filter paper. Also, due to the potential reaction of the potassium permanganate with the acid, there may be pressure buildup in the sample storage bottle; these bottles shall not be fully filled and shall be vented both to relieve potential excess pressure and prevent explosion due to pressure buildup. Venting is required, but should not allow contamination of the sample; a No. 70-72 hole drilled in the container cap and Teflon liner has been used.

4.2.3 Nitric Acid, 0.1 N. Add with stirring 6.3 mL of concentrated HNO_3 (70 percent) to a flask containing approximately 900 mL of water. Dilute to 1000 mL with water. Mix well. The reagent shall contain less than 2 ng/mL of each target metal.

4.2.4 Hydrochloric Acid (HCl), 8 N. Make the desired volume of 8N HCl in the following proportions. Carefully add with stirring, 690 mL of concentrated HCl to a flask containing 250 mL of water. Dilute to 1000 mL with water. Mix well. The reagent shall contain less than 2 ng/mL of Hg.

4.3 Glassware Cleaning Reagents.

4.3.1 Nitric Acid, Concentrated. Fisher ACS grade or equivalent.

4.3.2 Water. To conform to ASTM Specifications D1193-77, Type II.

4.3.3 Nitric Acid, 10 Percent (V/V). Add with stirring 500 mL of concentrated HNO_3 to a flask containing approximately 4000 mL of water. Dilute to 5000 mL with water. Mix well. Reagent shall contain less than 2 ng/mL of each target metal.

4.4.31 AAS Grade Al Standard, 1000 ug/mL.

4.4.32 AAS Grade Fe Standard, 1000 ug/mL.

4.4.33 The metals standards may also be made from solid chemicals as described in EPA Method 200.7. EPA SW-846 Method 7470 or Standard Methods for the Analysis of Water and Wastewater, 15th Edition, Method 303F should be referred to for additional information on mercury standards.

4.4.34 Mercury Standards and Quality Control Samples. Prepare fresh weekly a 10 ug/mL intermediate mercury standard by adding 5 mL of 1000 ug/mL mercury stock solution to a 500-mL volumetric flask; dilute with stirring to 500 mL by first carefully adding 20 mL of 15 percent HNO₃ and then adding water to the 500-mL volume. Mix well. Prepare a 200 ng/mL working mercury standard solution fresh daily: add 5 mL of the 10 ug/mL intermediate standard to a 250-mL volumetric flask and dilute to 250 mL with 5 mL of 4 percent KMnO₄, 5 mL of 15 percent HNO₃, and then water. Mix well. At least six separate aliquots of the working mercury standard solution should be used to prepare the standard curve. These aliquots should contain 0.0, 1.0, 2.0, 3.0, 4.0, and 5.0 mL of the working standard solution containing 0, 200, 400, 600, 800, and 1000 ng mercury, respectively. Quality control samples should be prepared by making a separate 10 ug/mL standard and diluting until in the range of the calibration.

4.4.35 ICAP Standards and Quality Control Samples. Calibration standards for ICAP analysis can be combined into four different mixed standard solutions as shown below.

MIXED STANDARD SOLUTIONS FOR ICAP ANALYSIS

Solution	Elements
I	As, Be, Cd, Mn, Pb, Se, Zn
II	Ba, Cu, Fe
III	Al, Cr, Ni
IV	Ag, P, Sb, Tl

Prepare these standards by combining and diluting the appropriate volumes of the 1000 ug/mL solutions with 5 percent nitric acid. A minimum of one standard and a blank can be used to form each calibration curve. However, a separate quality control sample spiked with known amounts of the target metals in quantities in the midrange of the calibration curve should be prepared. Suggested standard levels are 25 ug/mL for Al, Cr and Pb, 15 ug/mL for Fe, and 10 ug/mL for the remaining elements. Standards containing less than 1 ug/mL of

Method 5, Section 4.1.1, except that, unless particulate emissions are to be determined, the filter need not be desiccated or weighed. All sampling train glassware should first be rinsed with hot tap water and then washed in hot soapy water. Next, glassware should be rinsed three times with tap water, followed by three additional rinses with water. All glassware should then be soaked in a 10 percent (V/V) nitric acid solution for a minimum of 4 hours, rinsed three times with water, rinsed a final time with acetone, and allowed to air dry. All glassware openings where contamination can occur should be covered until the sampling train is assembled for sampling.

5.1.2 Preliminary Determinations. Same as Method 5, Section 4.1.2.

5.1.3 Preparation of Sampling Train. Follow the same general procedures given in Method 5, Section 4.1.3, except place 100 mL of the nitric acid/hydrogen peroxide solution (Section 4.2.1) in each of the two $\text{HNO}_3/\text{H}_2\text{O}_2$ impingers as shown in Figure A-1 (normally the second and third impingers), place 100 mL of the acidic potassium permanganate absorbing solution (Section 4.2.2) in each of the two permanganate impingers as shown in Figure A-1, and transfer approximately 200 to 300 g of preweighed silica gel from its container to the last impinger. Alternatively, the silica gel may be weighed directly in the impinger just prior to train assembly.

Several options are available to the tester based on the sampling requirements and conditions. The use of an empty first impinger can be eliminated if the moisture to be collected in the impingers will be less than approximately 100 mL. If necessary, use as applicable to this methodology the procedure described in Section 7.1.1 of EPA Method 101A, 40 CFR Part 61, Appendix B, to maintain the desired color in the last permanganate impinger.

Retain for reagent blanks volumes of the nitric acid/hydrogen peroxide solution per Section 5.2.9 of this method and of the acidic potassium permanganate solution per Section 5.2.10. These reagent blanks should be labeled and analyzed as described in Section 7. Set up the sampling train as shown in Figure A-1, or if mercury analysis is not to be performed in the train, then it should be modified by removing the three impingers which are the two permanganate impingers and the impinger preceding the permanganate impingers. If necessary to ensure leak-free sampling train connections, Teflon tape or other non-contaminating material should be used instead of silicone grease to prevent contamination.

stirring into Container No. 1.A. Analyze the HCl rinse separately by carefully diluting with stirring the contents of Container No. 1.A. to 500 mL with deionized distilled water. Filter (if necessary) through Whatman 40 filter paper, and then analyze for mercury according to Section 7.4, except limit the aliquot size to a maximum of 10 mL. Prepare and analyze a water diluted blank 8 N HCL sample by using the same procedure as that used by Container No. 1.A., except add 5 mL of 8 N HCl with stirring to 40 mL of water, and then dilute to 100 mL with water. Then analyze as instructed for the sample from Container No. 1.A. Because the previous separate permanganate solution rinse (Section 7.2.1) and water rinse (as modified in these guidelines) have the capability to recover a very high percentage of the mercury from the permanganate impingers, the amount of mercury in the HCl rinse in Container No. 1.A. may be very small, possibly even insignificantly small. However, add the total of any mercury analyzed and calculated for the HCl rinse sample Container No. 1.A. to that calculated from the mercury sample from Section 7.3.2 which contains the separate permanganate rinse (and water rinse as modified herein) for calculation of the total sample mercury concentration.]


5.1.4 Leak-Check Procedures. Follow the leak-check procedures given in Method 5, Section 4.1.4.1 (Pretest Leak-Check), Section 4.1.4.2 (Leak-Checks During the Sample Run), and Section 4.1.4.3 (Post-Test Leak-Checks).

5.1.5 Sampling Train Operation. Follow the procedures given in Method 5, Section 4.1.5. For each run, record the data required on a data sheet such as the one shown in Figure 5-2 of Method 5.

5.1.6 Calculation of Percent Isokinetic. Same as Method 5, Section 4.1.6.

5.2 Sample Recovery. Begin cleanup procedures as soon as the probe is removed from the stack at the end of a sampling period.

The probe should be allowed to cool prior to sample recovery. When it can be safely handled, wipe off all external particulate matter near the tip of the probe nozzle and place a rinsed, non-contaminating cap over the probe nozzle to prevent losing or gaining particulate matter. Do not cap the probe tip tightly while the sampling train is cooling. This normally causes a vacuum



• Number in parentheses indicates container number

Figure A-2. Sample recovery scheme.

and particulate matter have been collected in the sample container, tighten the lid on the sample container so that acetone will not leak out when it is shipped to the laboratory. Mark the height of the fluid level to determine whether or not leakage occurred during transport. Label the container clearly to identify its contents.

5.2.3 Container No. 3 (Probe Rinse). Keep the probe assembly clean and free from contamination as described in Section 5.2.2 of this method during the 0.1 N nitric acid rinse described below. Rinse the probe nozzle and fitting, probe liner, and front half of the filter holder thoroughly with 100 mL of 0.1 N nitric acid and place the wash into a sample storage container. Note: The use of exactly 100 mL is necessary for the subsequent blank correction procedures. Perform the rinses as applicable and generally as described in Method 12, Section 5.2.2. Record the volume of the combined rinse. Mark the height of the fluid level on the outside of the storage container and use this mark to determine if leakage occurs during transport. Seal the container and clearly label the contents. Finally, rinse the nozzle, probe liner, and front half of the filter holder with water followed by acetone and discard these rinses.

5.2.4 Container No. 4 (Impingers 1 through 3, $\text{HNO}_3/\text{H}_2\text{O}_2$ Impingers and Moisture Knockout Impinger, when used, Contents and Rinses). Due to the potentially large quantity of liquid involved, the tester may place the impinger solutions from impingers 1 through 3 in more than one container. Measure the liquid in the first three impingers volumetrically to within 0.5 mL using a graduated cylinder. Record the volume of liquid present. This information is required to calculate the moisture content of the sampled flue gas. Clean each of the first three impingers, the filter support, the back half of the filter housing, and connecting glassware by thoroughly rinsing with 100 mL of 0.1 N nitric acid using the procedure as applicable and generally as described in Method 12, Section 5.2.4. Note: The use of exactly 100 mL of 0.1 N nitric acid rinse is necessary for the subsequent blank correction procedures. Combine the rinses and impinger solutions, measure and record the volume. Mark the height of the fluid level on the outside of the container to determine if leakage occurs during transport. Seal the container and clearly label the contents.

5.2.5 Container Nos. 5A, 5B, and 5C. 5A (0.1 N HNO_3), 5B ($\text{KMnO}_4/\text{H}_2\text{SO}_4$ absorbing solution), and 5C (8 N HCl rinse and dilution). (As described

impinger on its side and rotating it so that the HCl contacts all inside surfaces. Use a total of only 25 mL of 8 N HCl for rinsing both permanganate impingers combined. Rinse the first impinger, then pour the actual rinse used for the first impinger into the second impinger for its rinse. Finally, pour the 25 mL of 8 N HCl rinse carefully with stirring into Container No. 5C. Mark the height of the fluid level on the outside of the bottle to determine if leakage occurs during transport.


5.2.6 Container No. 6 (Silica Gel). Note the color of the indicating silica gel to determine whether it has been completely spent and make a notation of its condition. Transfer the silica gel from its impinger to its original container and seal. The tester may use a funnel to pour the silica gel and a rubber policeman to remove the silica gel from the impinger. The small amount of particles that may adhere to the impinger wall need not be removed. Do not use water or other liquids to transfer the silica gel since weight gained in the silica gel impinger is used for moisture calculations. Alternatively, if a balance is available in the field, record the weight of the spent silica gel (or silica gel plus impinger) to the nearest 0.5 g.

5.2.7 Container No. 7 (Acetone Blank). If particulate emissions are to be determined, at least once during each field test, place a 100-mL portion of the acetone used in the sample recovery process into a labeled container for use in the front-half field reagent blank. Seal the container.

5.2.8 Container No. 8A (0.1 N Nitric Acid Blank). At least once during each field test, place 300 mL of the 0.1 N nitric acid solution used in the sample recovery process into a labeled container for use in the front-half and back-half field reagent blanks. Seal the container. Container No. 8B (water blank). At least once during each field test, place 100 mL of the water used in the sample recovery process into a labeled Container No. 8B. Seal the container.

5.2.9 Container No. 9 (5% Nitric Acid/10% Hydrogen Peroxide Blank). At least once during each field test, place 200 mL of the 5% nitric acid/10% hydrogen peroxide solution used as the nitric acid impinger reagent into a labeled container for use in the back-half field reagent blank. Seal the container.

5.2.10 Container No. 10 (Acidified Potassium Permanganate Blank). At least once during each field test, place 100 mL of the acidified potassium permanganate solution used as the impinger solution and in the sample recovery



¹ Analysis by AAS for metals found at less than 2 ug/mL in digestate solution, if desired. Or analyze for each metal by AAS, if desired.

Figure A-3. Sample preparation and analysis scheme.

solution to within 0.1 mL. Quantitatively remove a 50-mL aliquot and label as Fraction 1B. Label the remaining 250-mL portion as Fraction 1A. Fraction 1A is used for ICAP or AAS analysis. Fraction 1B is used for the determination of front-half mercury.

5.3.4 Container No. 4 (Impingers 1-3). Measure and record the total volume of this sample (Fraction 2) to within 0.5 mL. Remove a 75- to 100-mL aliquot for mercury analysis and label as Fraction 2B. Label the remaining portion of Container No. 4 as aliquot Fraction 2A. Aliquot Fraction 2A defines the volume of 2A prior to digestion. All of aliquot Fraction 2A is digested to produce concentrated Fraction 2A. Concentrated Fraction 2A defines the volume of 2A after digestion which is normally 150 mL. Only concentrated Fraction 2A is analyzed for metals (except that it is not analyzed for mercury). The Fraction 2B aliquot should be prepared and analyzed for mercury as described in Section 5.4.3. Aliquot Fraction 2A shall be pH 2 or lower. If necessary, use concentrated nitric acid by careful addition and stirring to lower aliquot Fraction 2A to pH 2. The sample should be rinsed into a beaker with water and the beaker should be covered with a ribbed watchglass. The sample volume should be reduced to approximately 20 mL by heating on a hot plate at a temperature just below boiling. Then follow either of the digestion procedures described in Sections 5.3.4.1 and 5.3.4.2, below.

5.3.4.1 Conventional Digestion Procedure. Add 30 mL of 50 percent nitric acid and heat for 30 minutes on a hot plate to just below boiling. Add 10 mL of 3 percent hydrogen peroxide and heat for 10 more minutes. Add 50 mL of hot water and heat the sample for an additional 20 minutes. Cool, filter the sample, and dilute to 150 mL (or the appropriate volume for the expected metals concentrations) with water. This dilution is concentrated Fraction 2A. Measure and record the volume of the Fraction 2A solution to within 0.1 mL.

5.3.4.2 Microwave Digestion Procedure. Add 10 mL of 50 percent nitric acid and heat for 6 minutes in intervals of 1 to 2 minutes at 600 Watts. Allow the sample to cool. Add 10 mL of 3 percent hydrogen peroxide and heat for 2 more minutes. Add 50 mL of hot water and heat for an additional 5 minutes. Cool, filter the sample, and dilute to 150 mL (or the appropriate volume for the expected metals concentrations) with water. This dilution is concentrated Fraction 2A. Measure and record the volume of the Fraction 2A solution to within 0.1 mL.

Note: All microwave heating times given are approximate and are

5.4.1 ICAP Analysis. Fraction 1A and Fraction 2A are analyzed by ICAP using EPA SW-846 Method 6010 or Method 200.7 (40 CFR 136, Appendix C). Calibrate the ICAP, and set up an analysis program as described in Method 6010 or Method 200.7. The quality control procedures described in Section 7.3.1 of this method shall be followed. Recommended wavelengths for use in the analysis are listed below.

Element	Wavelength (nm)
Aluminum	308.215
Antimony	206.833
Arsenic	193.696
Barium	455.403
Beryllium	313.042
Cadmium	226.502
Chromium	267.716
Copper	324.754
Iron	259.940
Lead	220.353
Manganese	257.610
Nickel	231.604
Phosphorous	214.914
Selenium	196.026
Silver	328.068
Thallium	190.864
Zinc	213.856

The wavelengths listed are recommended because of their sensitivity and overall acceptance. Other wavelengths may be substituted if they can provide the needed sensitivity and are treated with the same corrective techniques for spectral interference.

Initially, analyze all samples for the desired target metals (except mercury) plus iron and aluminum. If iron and aluminum are present in the sample, the sample may have to be diluted so that each of these elements is at a concentration of less than 50 ppm to reduce their spectral interferences on arsenic, cadmium, chromium, and lead.

Note: When analyzing samples in a hydrofluoric acid matrix, an alumina torch should be used; since all front-half samples will contain hydrofluoric acid, use an alumina torch.

5.4.2 AAS by Direct Aspiration and/or Graphite Furnace. If analysis of metals in Fraction 1A and Fraction 2A using graphite furnace or direct aspiration AAS is desired, Table A-2 should be used to determine which techniques and methods should be applied for each target metal. Table A-2

T. : A-2 (Continued)

Metal	Technique	SW-846 Method No.	Wavelength (nm)	Interference	
				Cause	Minimization
Fe	Aspiration	7380	248.3	Contamination	Great care taken to avoid contamination
Pb	Aspiration	7420	283.3	217.0 nm alternate	Background correction required
Pb	Furnace	7421	283.3	Poor recoveries	Matrix modifier, add 10 uL of phosphorus acid to 1 mL of prepared sample in sampler cup
Mn	Aspiration	7460	279.5	403.1 nm alternate	Background correction required
Ni	Aspiration	7520	232.0	352.4 nm alternate Fe, Co, and Cr	Background correction required Matrix matching or a nitrous-oxide/acetylene flame
Se	Furnace	7740	196.0	Nonlinear response	Sample dilution or use 352.3 nm line
				Volatility	Spike samples and reference materials and add nickel nitrate to minimize volatilization
				Adsorption & scatter	Background correction is required and Zeeman background correction can be useful
Ag	Aspiration	7760	328.1	Adsorption & scatter AgCl insoluble	Background correction is required Avoid hydrochloric acid unless silver is in solution as a chloride complex
Tl	Aspiration	7840	276.8	Viscosity	Sample and standards monitored for aspiration rate
	Furnace	7841	276.8	Hydrochloric acid or chloride	Background correction is required Hydrochloric acid should not be used
Zn	Aspiration	7950	213.9	High Si, Cu, & P Contamination	Background correction is required Verify that losses are not occurring for volatilization by spiked samples or standard addition; Palladium is a suitable matrix modifier Strontium removes Cu and phosphates Great care taken to avoid contamination

6. Calibration

Maintain a laboratory log of all calibrations.

6.1 Sampling Train Calibration. Calibrate the sampling train components according to the indicated sections of Method 5: Probe Nozzle (Section 5.1); Pitot Tube (Section 5.2); Metering System (Section 5.3); Probe Heater (Section 5.4); Temperature Gauges (Section 5.5); Leak-Check of the Metering System (Section 5.6); and Barometer (Section 5.7).

6.2 Inductively Coupled Argon Plasma Spectrometer Calibration. Prepare standards as outlined in Section 4.4. Profile and calibrate the instrument according to the instrument manufacturer's recommended procedures using the above standards. The instrument calibration should be checked once per hour. If the instrument does not reproduce the concentrations of the standard within 10 percent, the complete calibration procedures should be performed.

6.3 Atomic Absorption Spectrometer - Direct Aspiration, Graphite Furnace and Cold Vapor Mercury Analyses. Prepare the standards as outlined in Section 4.4. Calibrate the spectrometer using these prepared standards. Calibration procedures are also outlined in the EPA methods referred to in Table A-2 and in SW-846 Method 7470 or Standard Methods for Water and Wastewater, 15th Edition, Method 303F (for mercury). Each standard curve should be run in duplicate and the mean values used to calculate the calibration line. The instrument should be recalibrated approximately once every 10 to 12 samples.

7. Quality Control

7.1 Sampling. Field Reagent Blanks. When analyzed, the blank samples in Container Numbers 7 through 12 produced previously in Sections 5.2.7 through 5.2.12, respectively, shall be processed, digested, and analyzed as follows. Digest and process one of the filters from Container No. 12 per Section 5.3.1. 100 mL from Container No. 7 per Section 5.3.2, and 100 mL from Container No. 8A per Section 5.3.3. This produces Fraction Blank 1A and Fraction Blank 1B from Fraction Blank 1. [If desired, the other two filters may be digested separately according to Section 5.3.1, diluted separately to 300 mL each, and analyzed separately to produce a blank value for each of the two additional filters. If these analyses are performed, they will produce two additional values for each of Fraction Blank 1A and Fraction Blank 1B. The three Fraction Blank 1A values will be calculated as three values of $M_{r,h}$ in Equation 3 of Section 8.4.3, then the three values shall be totalled and divided by 3 to become the value $M_{r,h}$ to

(must be within 25% of calibration), and one duplicate analysis (must be within 10% of average or repeat all analyses).

7.3.2 Direct Aspiration and/or Graphite Furnace AAS Analysis for antimony, arsenic, barium, beryllium, cadmium, copper, chromium, lead, nickel, manganese, mercury, phosphorus, selenium, silver, thallium, and zinc. All samples should be analyzed in duplicate. Perform a matrix spike on at least one front-half sample and one back-half sample or one combined sample. If recoveries of less than 75 percent or greater than 125 percent are obtained for the matrix spike, analyze each sample by the method of additions. A quality control sample should be analyzed to check the accuracy of the calibration standards. The results must be within 10% or the calibration repeated.

7.3.3 Cold Vapor AAS Analysis for Mercury. All samples should be analyzed in duplicate. A quality control sample should be analyzed to check the accuracy of the calibration standards (within 15% or repeat calibration). Perform a matrix spike on one sample from the nitric impinger portion (must be within 25% or samples must be analyzed by the method of standard additions). Additional information on quality control can be obtained from EPA SW-846 Method 7470 or in Standard Methods for Water and Wastewater, 15th Edition, Method 303F.

8. Calculations

8.1 Dry Gas Volume. Using the data from this test, calculate $V_{s(std)}$, the dry gas sample volume at standard conditions as outlined in Section 6.3 of Method 5.

8.2 Volume of Water Vapor and Moisture Content. Using the data obtained from this test, calculate the volume of water vapor $V_{v(std)}$ and the moisture content $B_{v,}$ of the stack gas. Use Equations 5-2 and 5-3 of Method 5.

8.3 Stack Gas Velocity. Using the data from this test and Equation 2-9 of Method 2, calculate the average stack gas velocity.

8.4 Metals (Except Mercury) in Source Sample.

8.4.1 Fraction 1A, Front Half, Metals (except Hg). Calculate separately the amount of each metal collected in Fraction 1 of the sampling train using the following equation:

$$M_{fh} = C_{s1} F_d V_{s(std).1}$$

Eq. 1*

*If Fractions 1A and 2A are combined, proportional aliquots must be used. Appropriate changes must be made in Equations 1-3 to reflect this approach.

Note: If the measured blank value for the front half (m_{rnb}) is in the range 0.0 to A ug [where A ug equals the value determined by multiplying 1.4 ug per square inch (1.4 ug/in.²) times the actual area in square inches (in.²) of the filter used in the emission sample], m_{rnb} may be used to correct the emission sample value (m_{rn}); if m_{rnb} exceeds A ug, the greater of the two following values (either I. or II.) may be used:

- I. A ug, or
- II. the lesser of (a) m_{rnb} , or (b) 5 percent of m_{rn} .

If the measured blank value for the back half (m_{bnb}) is in the range 0.0 to 1 ug, m_{bnb} may be used to correct the emission sample value (m_{bn}); if m_{bnb} exceeds 1 ug, the greater of the two following values may be used: 1 ug or 5 percent of m_{bn} .

8.5 Mercury in Source Sample.

8.5.1 Fraction 1B, Front Half, Hg. Calculate the amount of mercury collected in the front half, Fraction 1, of the sampling train using the following equation:

$$Hg_{rn} = \frac{Q_{rn}}{V_{r1B}} \times V_{s01n.1} \quad \text{Eq. 4}$$

where:

- Hg_{rn} = total mass of mercury collected in the front half of the sampling train (Fraction 1), ug.
- Q_{rn} = quantity of mercury in analyzed sample, ug.
- $V_{s01n.1}$ = total volume of digested sample solution (Fraction 1), mL.
- V_{r1B} = volume of Fraction 1B analyzed, mL. See the following Note.

Note: V_{r1B} is the actual amount of Fraction 1B analyzed. For example, if 1 mL of Fraction 1B were diluted to 100 mL to bring it into the proper analytical range, and 1 mL of the 100-mL dilution were analyzed, V_{r1B} would be 0.01.

8.5.2 Fraction 2B and Fractions 3A, 3B, and 3C, Back Half, Hg. Calculate the amount of mercury collected in Fractions 2 using Equation 5 and in Fractions 3A, 3B, and 3C using Equation 6. Calculate the total amount of mercury collected in the back half of the sampling train using Equation 7.

where:

Hg_t = total mass of mercury collected in the sampling train, ug.
 $Hg_{r,h}$ = blank correction value for mass of mercury detected in front-half field reagent blank, ug.
 $Hg_{b,h}$ = blank correction value for mass of mercury detected in back-half field reagent blanks, ug.

Note: If the total of the measured blank values ($Hg_{r,h} + Hg_{b,h}$) is in the range of 0 to 6 ug, then the total may be used to correct the emission sample value ($Hg_{r,h} + Hg_{b,h}$); if it exceeds 6 ug, the greater of the following two values may be used: 6 ug or 5 percent of the emission sample value ($Hg_{r,h} + Hg_{b,h}$).

8.6 Metal Concentration of Stack Gas. Calculate each metal separately for the cadmium, total chromium, arsenic, nickel, manganese, beryllium, copper, lead, phosphorus, thallium, silver, barium, zinc, selenium, antimony, and mercury concentrations in the stack gas (dry basis, adjusted to standard conditions) as follows:

$$C_s = K_A (M_t / V_{n(std)}) \quad \text{Eq.9}$$

where:

C_s = concentration of each metal in the stack gas, ng/dscm.
 K_A = 10^{-3} ng/ug.
 M_t = total mass of each metal collected in the sampling train, ug;
(substitute Hg_t for M_t for the mercury calculation).
 $V_{n(std)}$ = volume of gas sample as measured by the dry gas meter, corrected to dry standard conditions, dscm.

8.7 Isokinetic Variation and Acceptable Results. Same as Method 5, Sections 6.11 and 6.12, respectively.

9. Bibliography

9.1 Method 303F in Standard Methods for the Examination of Water Wastewater, 15th Edition, 1980. Available from the American Public Health Association, 1015 18th Street N.W., Washington, D.C. 20036.

9.2 EPA Methods 6010, 7000, 7041, 7060, 7131, 7421, 7470, 7740, and 7841. Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. SW-846. Third Edition. September 1988. Office of Solid Waste and Emergency Response. U. S. Environmental Protection Agency, Washington, D.C. 20460.