

Commonwealth of Pennsylvania
Environmental Resources
January 23, 1992

Subject: Source Test Review

To: 
SCA Services of Pennsylvania, Inc.
Stove Power Production Plant
Pottstown Landfill

From: Richard St. Louis, Chief *RSL*
Source Testing Unit
Division of Technical Services and Monitoring

Through: Chief, Source Testing and Monitoring Section *LJC*

SCA Services of Pennsylvania, Inc., operates a 9,000 KW Centaur Model No. T-4500 gas turbine (Turbine No. 2) used to burn on-site landfill gas for the production of electrical power. The turbine has a design rating of 4.3 MMBTU/HR. Landfill gas is conditioned by an Air Pol, Inc., Gray scrubber prior to firing in the turbine. Emissions from the turbine are vented to the atmosphere through a single exhaust stack.

ECM Engineers, Inc., conducted NO_x , heavy metals, and SO_2 stack emission tests on September 30 and October 1, 2 and 3, 1991, to satisfy the requirements of Plan Approval 44-399-063A. Heavy metals and SO_2 emissions were conducted while the turbine was performing at 100 percent load. NO_x emissions were determined at 100, 75, 50 and 25 percent of full load.

All the tests were conducted in accordance with a preapproved test protocol and are acceptable to the Department. The following test results were extracted from the reports:

NO_x EMISSIONS

Turbine Load, %	Run No.	Test Date	ppmv (3) 15% O ₂ , dry basis	
			Measured	EC Condition
100	1	10/3/91	28.8	28.7
100	2	10/3/91	27.7	29.0
100	3	10/3/91	27.6	28.7

BCEg RECHARGEABLE

Tarebottle Label, g	Bun No.	Test Date	ppmv (b) 1596 Cg, dry bottle	
			Measured	BCE Condilbun
75	1	10/3/91	34.3	36.2
75	2	10/3/91	33.1	33.7
75	3	10/3/91	32.7	36.8
50	1	10/3/91	33.7	39.4
50	2	10/3/91	39.3	43.8
50	3	10/3/91	32.8	35.1
30	1	10/3/91	36.6	36.0
30	2	10/3/91	27.0	28.5
30	3	10/3/91	24.9	27.8

BCEg RECHARGEABLE

Bun No.	Test Date	BCEg Rechargeable		
		ppmv	ppmv (b) 1596 Cg	lb./hr.
1	9/30/91	1.7	3.1	0.412
2	10/1/91	1.0	1.2	0.393
3	10/2/91	3.4	3.1	0.909

HEAVY METALS CONCENTRATION (pp/dust)

Metal	Run No. 1	Run No. 2	Run No. 3	Avg.
Arsenic	8.10×10^{-5}	8.94×10^{-5}	8.47×10^{-5}	8.50×10^{-5}
Beryllium	2.04×10^{-6}	2.15×10^{-6}	2.15×10^{-6}	2.11×10^{-6}
Cadmium	2.04×10^{-6}	2.15×10^{-6}	2.15×10^{-6}	2.11×10^{-6}
Chromium	4.08×10^{-6}	4.08×10^{-6}	4.31×10^{-6}	4.15×10^{-6}
Mercury	6.17×10^{-7}	6.93×10^{-7}	6.94×10^{-7}	7.05×10^{-7}
Nickel	1.61×10^{-5}	1.66×10^{-5}	1.67×10^{-5}	1.65×10^{-5}
Lead	4.04×10^{-5}	4.16×10^{-5}	4.24×10^{-5}	4.15×10^{-5}

Notes: All results (except Run No. 1, Mercury) were below detection limit.
Detection limit used to calculate results.

cc: Ed Brown, Southeast Regional Office
48-399-003A
AHC
EPA/BSL
Reading File - Source Testing

BSL:dlg


REPORT
FOR
COMPLIANCE EMISSION EVALUATION
OF THE
STOWE POWER PRODUCTION PLANT TURBINE NO. 2 AT THE
POTTSTOWN LANDFILL

FOR
SCA SERVICES OF PENNSYLVANIA, INCORPORATED
A DIVISION OF
WASTE MANAGEMENT OF NORTH AMERICA, INCORPORATED


OCTOBER 1991

BCM PROJECT NO. 00-5743-19

PREPARED BY


PHILIP C. BURG
PROJECT MANAGER


PAUL D. ROSENSTOCK, Ph.D., CEM
VICE PRESIDENT



6277y

Engineers, Planners, Scientists and Laboratory Services
One Plymouth Meeting • Plymouth Meeting, PA 19452 • Phone (215) 625-3800

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000





CONTENTS

1.0	EXECUTIVE SUMMARY	1
2.0	SCOPE AND OBJECTIVES	3
3.0	PROCEDURES	4
3.1	Field Work	4
3.2	Analytical Methods	4
3.3	Calculations	4
3.4	Equipment Calibration	4
4.0	TEST RESULTS	5
4.1	Gas Flow Rate Data	5
4.2	Oxides of Nitrogen Emission Results	5
4.3	Sulfur Dioxide Emission Results	5
4.4	Sulfur Content of Fuel	5
4.5	Metals Emission and Air Dispersion Modeling Results	6
4.6	Turbine Operating Data	6
5.0	DISCUSSION OF RESULTS	14
5.1	General	14
5.2	Test Results	14

APPENDICES


Appendix A	Intent-To-Test Protocol and Correspondence
Appendix B	Field Sampling Program
Appendix C	Laboratory Procedures
Appendix D	Calculations
Appendix E	Equipment Calibration
Appendix F	Air Dispersion Analysis





TABLES

Table A	Summary of Emissions Monitoring Data	2
Table 1	Gas Flow Rate Data	7
Table 2	Oxides of Nitrogen Emission Results	8
Table 3	SO ₂ Emission Results	9
Table 4	Sulfur Content of Fuel	10
Table 5	Metal Emission Concentrations	11
Table 6	Metal Emission Rates	11
Table 7	Dispersion Analysis Results	12
Table 8	Turbine Operating Conditions	13





1.0 EXECUTIVE SUMMARY

SCA Services of Pennsylvania, Incorporated (SCA Services), a division of Waste Management of North America, Inc. (Waste Management) operates a newly installed 3000 KW gas turbine power production plant (termed Turbine No. 2) located at the Pottstown, Pennsylvania, landfill. The turbine is used to burn onsite landfill gas for the production of electrical power. Turbine No. 2 is the second of two identical gas turbines operated at the site.

Turbine No. 2 is a Centaur Model No. T-4500, manufactured by Solar Turbines, Inc., with a rating of 42 MW BTU/hr. The gas burned in the turbine is conditioned by an Air Pol, Inc. tray scrubber prior to firing in the turbine. Air emissions from the turbine are vented to the atmosphere through a single exhaust stack.

Waste Management, on behalf of SCA Services, retained BCM Engineers Inc. (BCM) to determine the compliance status of the turbine with respect to air emission standards. These standards were outlined in the turbine's Temporary Operating Permit No. 46-399-063A that was issued by the Pennsylvania Department of Environmental Resources (PADER).

Testing was performed to determine stack emissions of oxides of nitrogen (NO_x), metals, and sulfur dioxide (SO_2). NO_x emissions were determined with the turbine operating at 100, 75, 50, and 30 percent of full load. All other determinations were performed at 100 percent load only. Metals testing included emission determinations of arsenic (As), beryllium (Be), cadmium (Cd), total chrome (Cr), mercury (Hg), nickel (Ni), and lead (Pb). The measured stack emission rates were used to determine ground level concentrations of each metal by dispersion modeling.

Table A summarizes the results of the testing program, and shows turbine emissions meet permit conditions. Included in the Table are emission parameters, the turbine load condition at which testing was performed, and the emission testing results as compared to the allowable standards contained in the Temporary Operating Permit. Complete results are presented in Section 4.0 of this report.

During each SO_2 emission test run, a grab sample of the fuel gas was collected and submitted to the laboratory for total sulfur analysis. The average of the three analyses performed showed the sulfur content of the fuel to be 0.0052 percent by weight. Subpart GG, Section 60.33, paragraph (b), of the U.S. Environmental Protection Agency (EPA) New Source Performance Standards (NSPS), limits the sulfur content of the gas burned in the turbine to 0.8 percent by weight. Results of the sulfur in fuel analyses show the fuel meet NSPS standards.






TABLE A
SUMMARY OF EMISSIONS MONITORING
DATA FOR TURBINE NO. 2

Emission Parameter	Turbine Load (%)	Emission Results	Allowable Limit
Arsenic	100	<0.0035 ug/m ³	0.024 ug/m ³
Beryllium	100	<0.00060 ug/m ³	0.01 ug/m ³
Cadmium	100	<0.00060 ug/m ³	0.0556 ug/m ³
Hexavalent Chromium	100	<0.0012 ug/m ³	0.00633 ug/m ³
Mercury	100	<0.00021 ug/m ³	0.24 ug/m ³
Nickel	100	<0.0047 ug/m ³	0.24 ug/m ³
Lead	100	<0.012 ug/m ³	1.5 ug/m ³
SO ₂	100	2.1 ppmv @ 15% O ₂	150 ppmv @ 15% O ₂
NO _x	100	28.8 ppmv	50 ppmv
NO _x	75	35.6 ppmv	50 ppmv
NO _x	50	39.4 ppmv	50 ppmv
NO _x	30	31.4 ppmv	50 ppmv

- Notes:
- 1) All metals results include metals and their compounds
 - 2) Metals emission results and allowable limits represent maximum annual ambient ground level concentrations
 - 3) Chromium emission results represent total chrome
 - 4) SO₂ results and allowable limits represent ppmv at 15% O₂
 - 5) NO_x results and allowable limits represent ppmv at 15% O₂ and ISO standard ambient conditions

6277y

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000



2.0 SCOPE AND OBJECTIVES

The scope of the project was outlined in BCM's Intent-To-Test Protocol submitted to Mr. N. Rao Kona of the PADER on July 10, 1991. Copies of the Intent-To-Test Protocol and related correspondence are included as Appendix A of this report. The objective of the sampling program was to determine the following parameters:

- Gas Flow - acfm and scfm
- Gas temperature - °F
- Gas moisture content - percent by volume
- Combustion gas analysis - percent by volume CO₂, O₂, CO, and N₂ (by difference)
- NO_x emission concentration - ppmv at 15 percent O₂ expressed at ISO conditions
- O₂ emission concentration - percent by volume
- Sulfur content of fuel - percent by weight
- Metals emissions - gr/dscf and lb/hr
- Sulfur dioxide emissions - ppmv at 15 percent O₂ and lb/hr
- Ground level concentration of metals - ug/m³



3.0 PROCEDURES

3.1 FIELD WORK

Field testing was conducted on September 30, October 1, 2, and 3, 1991. The sampling team consisted of the following BCM personnel:

Philip C. Burg, Project Manager
Karl Brenton, Technician
Nick Charno, Technician

NO_x emission testing was conducted according to procedures as outlined in U.S. Environmental Protection Agency (EPA) Reference Method 20 of the Federal Register, Volume 42, Number 160. Emissions of SO₂ were determined by PADER procedures. Metals emissions were determined by the PADER "Heavy Metals Test Method." Metals and SO₂ emission determinations were conducted simultaneously. Descriptions of test methodologies can be found in Appendix B of this report.

3.2 ANALYTICAL METHODS


All samples generated during the sampling program were returned to the laboratory for analysis. The analytical methodologies and the laboratory data are contained in Appendix C.

3.3 CALCULATIONS

Descriptions of the calculations performed to determine test results are contained in Appendix D. Appendix D also lists equations and all reduced field data used to obtain test results.

3.4 EQUIPMENT CALIBRATION

In accordance with accepted procedures published by the EPA, all gas velocity measuring equipment, gas volume metering equipment, and temperature measuring equipment was calibrated prior to the test program. Appendix E provides the calibration data.





4.0 TEST RESULTS

4.1 GAS FLOW RATE DATA

Gas flow rate data obtained during the metals testing are contained in Table 1. Gas flow rate determinations were conducted with the turbine operating at the 100 percent load condition.

4.2 OXIDES OF NITROGEN EMISSION RESULTS

Oxides of nitrogen emission results are contained in Table 2. Results include the measured O_2 and NO_x emission concentrations, the measured NO_x emissions corrected to 15-percent O_2 , and the NO_x emissions expressed at ISO standard ambient conditions.

4.3 SULFUR DIOXIDE EMISSION RESULTS

Emissions of SO_2 were determined simultaneously with metals sampling. Results of the SO_2 testing are contained in Table 3.

Oxygen concentrations were determined for each test run by collecting an integrated sample of the stack effluent in a gas sample bag followed by Orsat analysis. These results were utilized in calculating SO_2 emission concentrations at 15 percent oxygen.

4.4 SULFUR CONTENT OF FUEL

During each SO_2 test run, a single grab sample of the fuel was collected in a Tedlar sample bag. The gas sample was taken from the system at a point after the tray scrubber. The samples were submitted to Atlantic Analytical Laboratory (AAL), Whitehouse, New Jersey, for total sulfur analysis. Results of these analyses are contained in Table 4.

4.5 METALS EMISSION AND AIR DISPERSION MODELING RESULTS

Results of the metals emission determinations are contained in Table Nos. 5 and 6. Table 5 contains metals emission concentrations and Table 6 contains metals emission rates.

Results of the metals air dispersion modeling are contained in Table No. 7. These results represent the annual average ground level concentrations of metals with Turbine No. 2 operating at 100 percent load.

4.6 TURBINE OPERATING DATA

Turbine operating data recorded during all test runs are contained in Table No. 8. The values presented were obtained by averaging all readings recorded for each test run.

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000

00000




TABLE 1
GAS FLOW RATE DATA

Run No.	Test Date	Gas Temperature (°F)	Gas Moisture (%)	Velocity (fpm)	Gas Flow	
					(acfm)	(dscfm)
1	9/30/91	736	4.3	7,629	95,863	41,086
2	10/1/91	731	5.7	7,323	92,027	38,652
3	10/2/91	741	5.5	7,191	90,362	37,903
Average		736	5.2	7,381	92,751	39,214

All flows determined with turbine at 100% load condition.

6277y






TABLE 2
OXIDES OF NITROGEN EMISSION RESULTS

Turbine Load	Run No.	Test Date	Measured Emission Concentration on Dry Basis		NO _x Emissions	
			O ₂ %	NO _x ppmv	Measured	15% O ₂ Dry Basis
100	1	10/3/91	16.7	19.1	26.8	28.7
100	2	10/3/91	16.9	18.8	27.7	29.0
100	3	10/3/91	16.8	19.2	27.6	28.7
Average	---	-----	16.8	19.0	27.3	28.8
75	1	10/3/91	17.6	18.3	34.8	36.2
75	2	10/3/91	17.6	18.5	33.1	33.7
75	3	10/3/91	17.8	17.2	32.7	36.8
Average	--	-----	17.7	18.0	33.5	35.6
50	1	10/3/91	18.4	14.3	33.7	39.4
50	2	10/3/91	18.8	14.0	39.3	43.8
50	3	10/3/91	18.2	15.0	32.8	35.1
Average	---	-----	18.5	14.4	35.4	39.4
30	1	10/2/91	18.9	12.4	35.5	38.0
30	2	10/2/91	18.8	9.6	27.0	28.5
30	3	10/2/91	18.6	9.7	24.9	27.8
Average	--	-----	18.8	10.6	29.0	31.4

6297y

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000




TABLE 3
SULFUR DIOXIDE EMISSION RESULTS

Run No.	Test Date	Gas Flow Rate (dscfm)	O ₂ Concentration (%)	SO ₂ Emissions		
				(ppmv)	(ppmv @ 15% O ₂)	(lb/hr)
1	9/30/91	41,063	16.1	1.7	2.1	0.712
2	10/1/91	38,652	16.1	1.0	1.2	0.393
3	10/2/91	37,903	16.3	2.4	3.1	0.909
Average	-----	39,214	16.2	1.7	2.1	0.671

Notes: ppmv at 15% O₂ = (ppmv) (5.9/20.9-%O₂)

6277y

Page 1

Page 2

Page 3

Page 4

Page 5

Page 6

Page 7

Page 8

Page 9

Page 10

Page 11

Page 12

Page 13

Page 14

Page 15

Page 16

Page 17

Page 18

Page 19



TABLE 4
SULFUR CONTENT OF FUEL

SO ₂ Run No.	Test Date	Total Sulfur Content	
		(ppmv)	(% by wt.)
1	9/30/91	19	0.0022
2	10/1/91	72	0.0083
3	10/2/91	43	0.0050
Average	-----	45	0.0052

Notes: 1. Allowable sulfur content of fuel = 0.8% by weight
2. ppmv expressed as H₂S

6277y

.....

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page

Page



TABLE 5
METAL EMISSION CONCENTRATIONS (gr/dscf)

Metal	Run No.			
	1	2	3	Average
Arsenic	8.10×10^{-5}	8.34×10^{-5}	8.47×10^{-5}	8.30×10^{-5}
Beryllium	2.04×10^{-6}	2.15×10^{-6}	2.15×10^{-6}	2.11×10^{-6}
Cadmium	2.04×10^{-6}	2.15×10^{-6}	2.15×10^{-6}	2.11×10^{-6}
Chromium	4.08×10^{-6}	4.06×10^{-6}	4.31×10^{-6}	4.15×10^{-6}
Mercury	8.17×10^{-7}	6.93×10^{-7}	6.94×10^{-7}	7.35×10^{-7}
Nickel	1.61×10^{-5}	1.66×10^{-5}	1.57×10^{-5}	1.65×10^{-5}
Lead	4.04×10^{-5}	4.16×10^{-5}	4.24×10^{-5}	4.15×10^{-5}

1 All results (except Run 1, Mercury) are less than values, sample concentrations were below detection limit, used detection limit to calculate results

2 All results represent metals and their compounds

TABLE 6
METAL EMISSION RATES (lb/hr)

Metal	Run No.			
	1	2	3	Average
Arsenic	2.85×10^{-2}	2.76×10^{-2}	2.75×10^{-2}	2.79×10^{-2}
Beryllium	7.19×10^{-4}	7.13×10^{-4}	7.00×10^{-4}	7.11×10^{-4}
Cadmium	7.19×10^{-4}	7.13×10^{-4}	7.00×10^{-4}	7.11×10^{-4}
Chromium	1.44×10^{-3}	1.35×10^{-3}	1.40×10^{-3}	1.40×10^{-3}
Mercury	2.38×10^{-4}	2.30×10^{-4}	2.25×10^{-4}	2.48×10^{-4}
Nickel	5.67×10^{-3}	5.51×10^{-3}	5.44×10^{-3}	5.54×10^{-3}
Lead	1.42×10^{-2}	1.38×10^{-2}	1.38×10^{-2}	1.39×10^{-2}

1 All results (except Run 1, Mercury) are less than value, sample concentrations were below detection limit, used detection limit to calculate results

2 All results represent metals and their compounds




TABLE 7
DISPERSION ANALYSIS RESULTS
FOR CENTAUR GAS TURBINE

Metal	Metal Emission Rate (lb/hr)	Maximum Annual Ambient Ground Level Concentration (ug/m ³)	PADER Annual Ambient Guideline (ug/m ³)
Arsenic	$<2.79 \times 10^{-2}$	<0.0235	0.024
Beryllium	$<7.11 \times 10^{-4}$	<0.00060	0.01
Cadmium	$<7.11 \times 10^{-4}$	<0.00060	0.556
Chromium	$<1.40 \times 10^{-3}$	<0.0012	0.00633
Mercury	$<2.48 \times 10^{-4}$	<0.00021	0.24
Nickel	$<5.54 \times 10^{-3}$	<0.0047	0.24
Lead	$<1.39 \times 10^{-2}$	<0.012	1.5

6277y

Page 1

Page 2

Page 3

Page 4

Page 5

Page 6

Page 7

Page 8

Page 9

Page 10

Page 11

Page 12

Page 13

Page 14

Page 15

Page 16

Page 17

Page 18

Page 19

00	00
01	01
02	02
03	03
04	04
05	05
06	06
07	07
08	08
09	09
10	10
11	11
12	12
13	13
14	14
15	15
16	16
17	17
18	18
19	19
20	20
21	21
22	22
23	23
24	24
25	25
26	26
27	27
28	28
29	29
30	30
31	31
32	32
33	33
34	34
35	35
36	36
37	37
38	38
39	39
40	40
41	41
42	42
43	43
44	44
45	45
46	46
47	47
48	48
49	49
50	50
51	51
52	52
53	53
54	54
55	55
56	56
57	57
58	58
59	59
60	60
61	61
62	62
63	63
64	64
65	65
66	66
67	67
68	68
69	69
70	70
71	71
72	72
73	73
74	74
75	75
76	76
77	77
78	78
79	79
80	80
81	81
82	82
83	83
84	84
85	85
86	86
87	87
88	88
89	89
90	90
91	91
92	92
93	93
94	94
95	95
96	96
97	97
98	98
99	99

[illegible]

Page 1

Page 2

Page 3

Page 4

Page 5

Page 6

Page 7

Page 8

Page 9

Page 10

Page 11

Page 12

Page 13

Page 14

Page 15

Page 16

Page 17

Page 18

Page 19

Page 20

5.0 DISCUSSION OF RESULTS

5.1 GENERAL

Testing went well and few problems were encountered. All leak checks conducted during the SO₂ and metals testing were within the allowable limit. Isokinetic derivations during the metals testing were within the 90 to 110 percent acceptable range. All calibration and zero drift checks of the NO_x and O₂ analyzers were within the ±2 percent allowable range. One exception, however, occurred during Run No. 3 at the 75 percent load condition where the NO_x analyzer exhibited a zero drift of 2.4 percent. As specified in 6.2.3 of EPA Method 20, NO_x results were calculated for that run utilizing the initial and recalibration data. An NO_x emission concentration of 36.8 ppmv at 15 percent O₂ ISO standard conditions represents the higher value obtained (Table 2).

The NO_x emissions at 15 percent O₂ ISO standard conditions are calculated to be 35.3 ppmv utilizing initial calibration data.

5.2 TEST RESULTS

All emission results as well as the sulfur content of the fuel obtained during the testing program were well within the allowable limits. The average measured SO₂ emission concentration was 2.1 ppmv at 15 percent O₂ which is 1.4 percent of the 150 ppmv allowable limit. The average sulfur content of the fuel was 0.0052 percent by weight, which is 0.65 percent of the allowable limit of 0.8 percent by weight. The highest NO_x emission concentration (39.4 ppm) was measured at 50 percent turbine load, and is 78.8 percent of the 50 ppm allowable limit. Finally, dispersion modeling of test results showed that the turbine meets permit operating conditions with respect to allowable ground level concentrations of metals.

Page 1

Page 2

Page 3

Page 4

Page 5

Page 6

Page 7

Page 8

Page 9

Page 10

Page 11

Page 12

Page 13

Page 14

Page 15

Page 16


Page 17

Page 18

Page 19



APPENDIX B
FIELD SAMPLING PROGRAM





APPENDIX B

FIELD SAMPLING PROGRAM

1.0 SAMPLING PROCEDURES

1.1 Test Station and Traverse Location

The Turbine No. 2 exhaust stack is round with an internal diameter of 4 feet. Two test ports are located on the same cross sectional plane, 90 degrees apart. The nearest upstream and downstream flow disturbances are located 1.25 and 6.75 duct diameters, respectively, from the test ports. A schematic drawing of the stack and port locations is at the end of this Appendix.

The number of traverse points used for the metals emission testing, as well as the preliminary oxygen traverse of the NO_x emission testing (as determined by EPA Method 1), was 24 (12 per port).

According to 6.1.2.1 of EPA Method 20, the minimum number of traverse points for NO_x sampling for stacks with cross-sectional areas less than 16.1 ft^2 is eight. The cross-sectional area of the exhaust stack was 12.6 ft^2 ; therefore, eight traverse points were utilized.

1.2 Gas Flow and Gas Temperature Determinations

The gas flow rate and temperature profiles were measured by conducting a velocity and temperature traverse simultaneous with the metals and SO_2 sampling. The gas velocity head was measured with a "S" type pitot tube connected to an inclined manometer. A Chromel-Alumel thermocouple connected to a potentiometer was used to determine the gas temperature.

1.3 Moisture Content

Sampling was conducted employing the principles presented in EPA Method 4 and concurrently with metals sampling. The parameters evaluated to determine the gas stream's moisture content were: sample gas volume, sample gas temperature, sample gas pressure, impinger moisture gain, and silica gel moisture gain.

1.4 Stack Gas Molecular Weight Determinations

Integrated samples of the exhaust gas were collected during each run by extracting a portion of stack gas at each traverse point and collecting them in a sample bag. Each sample was analyzed according to the following procedure.

A Fisher Type B No. 10-605 Orsat gas analyzer was used to determine the molecular weight of the flue gas. The following parameters were measured to calculate the molecular weight: volume percent carbon dioxide (CO_2), volume percent oxygen (O_2), and volume percent carbon monoxide (CO). The volume percentage of nitrogen (N_2) was determined by difference.

These parameters were measured using the principle of gas absorption in specific absorbing solutions. A 100-ml flue gas sample was drawn through the glass manifold to the sample chamber using the levelling bottle after the sampling line had been purged. The system was then closed by adjusting the absorbing solutions, which selectively collected different gaseous components of the stack gas. Carbon dioxide was collected in a potassium hydroxide solution in the first absorber, oxygen was collected in a potassium pyrogallate solution in the second absorber, and carbon monoxide was collected in a cupric chloride solution in the third absorber.

The volume of a specific gaseous component collected in an individual absorbing solution was determined by the change in volume of sample gas in the sample chamber after the bubbling through of that solution was complete. Because the original sample volume was 100 ml, any change in volume also represented the percentage of the specific gaseous component found in the stack gas stream. Temperature changes of the sample were minimized by using a jacket filled with isopropyl alcohol, which surrounded the sample chamber.

Results of the Orsat analyses are contained in Table A-1 of this Appendix. For the purpose of a quality control check, the oxygen concentrations obtained by the instrumentation analyses during the NO_x testing are included in the table.

1.5 Metals Sampling

All sampling procedures and sampling equipment employed were those outlined in the PADER "Heavy Metals Test Method."

The nozzle size required to maintain isokinetic sampling was calculated from the results of the previously completed velocity and temperature traverses. The sampling train used a glass-lined stainless steel probe that was heated to 250 degrees Fahrenheit by an internal heating element. The front of the glass liner had a glass nozzle of a calculated size required to maintain isokinetic sampling. An "S" type pitot tube and a Chromel-Alumel thermocouple were clamped to the probe in order to monitor the velocity head and the temperature at the traverse points during the sampling period. Sampled gas passed through the glass nozzle/probe liner to a prepacked glass fiber filter for the removal of the suspended particulates and metals. The filter was housed in a heated chamber with a temperature maintained at 250 degrees Fahrenheit. From the filter, the

stack gas passed to the impinger train. The first three impingers each contained 150 ml of 0.1 N nitric acid (HNO_3). The fourth impinger contained approximately 200 grams of coarse silica gel, which collected any moisture and/or vapors that were not captured in the preceding impingers.

The second impinger was a 500-ml Greenburg-Smith impinger; the first, third, and fourth were 500-ml impingers of the Greenburg-Smith design, modified by replacing the tip with a 1/2-inch inside diameter (I.D.) glass tube. The impinger train was immersed in an ice bath for the entire test period in order to prevent the exit gas temperature from exceeding 70 degrees Fahrenheit.

From the impinger train, the gas was conducted through an umbilical cord to the control console (an Anderson Universal Stack Sampler) that contained the following pieces of equipment (listed in the order in which sampled gas passed through them): a main valve, bypass valve for flow adjustment, an airtight vacuum pump, a dry gas meter, and a calibrated orifice. The orifice was equipped with pressure taps that were connected across the inclined manometer used to ensure that isokinetic conditions were being maintained. A schematic diagram of the EPA Method 12 sampling train is depicted at the end of this Appendix.

The sampling train was subjected to a leak check prior to and after each sample run. The inlet of the nozzle was plugged, and the pump vacuum was held at the highest vacuum attained during the testing period. In all cases, the leakage rate was minimal, not exceeding the maximum allowable leakage rate of 0.02 cfm.

The minimum sample volume collected for each sample run was 50 dscf.

Upon completion of a test, the soiled glass fiber filter was removed from its filter holder and placed in a petri dish that was subsequently sealed. The probe liner and nozzle were washed internally with 0.1 N HNO_3 ; the residual matter remaining in the probe was removed with a nylon brush attached to a polyethylene line. The front half of the glass filter holder was rinsed with 0.1 N HNO_3 , and the washings obtained were added to those collected from the nozzle and probe. All washings were stored in sealed amber glass bottles for transfer to the laboratory. The silica gel used in the fourth impinger was removed and stored in a sealed sample bottle. The contents of the first, second, and third impingers were combined and measured volumetrically. The impingers were then rinsed with 0.1 N HNO_3 and the washings added to the impinger solution.

1.6 Sulfur Dioxide Emission Determinations

Sampling procedures as outlined in the Pennsylvania "Source Test Manual" for oxides of sulfur testing were utilized for the SO_2 sampling. The methodology was modified by the addition of an impinger containing an 80 percent solution of isopropyl alcohol (IPA). The IPA scrubbed any sulfur trioxide present in the sample, making the methodology specific for SO_2 .

Sampling was conducted by extracting gas at the mid-point of the stack through a nozzle; a heated, stainless steel probe; and then conducting it to an impinger train that consisted of five separate impingers. The first and third impingers were of the Greenburg-Smith design. The second, fourth, and fifth impingers were of the Greenburg-Smith design modified by replacing the impactor end with an approximately 13-mm (0.5-in) I.D. glass tube. The first impinger contained 150 ml of 80-percent (isopropyl) alcohol (IPA). The second, third, and fourth impingers contained a total of 400 ml of 5-percent sodium hydroxide (NaOH). The fifth impinger contained approximately 200 grams of coarse silica gel to collect any moisture or vapors not captured in the preceding impingers. A filter holder containing a glass fiber filter was placed between the first and second impingers. The impinger train was immersed in an ice bath for the entire sampling period.

A diagram illustrating the sample train is included at the end of this Appendix.

From the impinger train, the gas was conducted through an umbilical cord to the control console, an Anderson Universal Stack Sampler that contained the following pieces of equipment (listed in the order in which gas passed through them): a main valve, bypass valve for flow adjustment, an airtight vacuum pump, a dry gas meter, and a calibrated orifice. The orifice was equipped with pressure taps which were connected across an inclined manometer to measure sample gas flows through the sample train. Sampling rate was maintained at approximately 0.75 cubic feet per minute (cfm).

The sampling train was checked for leaks before and after each sample run. The inlet of the nozzle was plugged and the pump vacuum was held at the highest vacuum attained during that period of testing. In all cases, the leakage rate was minimal and did not exceed the maximum allowable leakage rate of 0.02 cfm.

Upon completion of the test, the sample train was purged for 15 minutes with ambient air at the approximate average flow rate used for sampling. This ensured that any oxides of sulfur remaining in the first impinger were purged from the 80-percent IPA solution.

The contents of the second and third impingers were placed in a clean, sealed sample bottle. The contents of the fourth impinger were placed in a separate sample bottle. The impingers were each thoroughly rinsed with 5-percent NaOH solution and the washings were added to the respective impinger solutions. Both the contents of the first impinger and the filter between the first and second impingers were discarded. All samples were kept on ice until reaching the laboratory for analysis.

1.7 Oxides of Nitrogen Emission Determinations

The sampling procedures and equipment used for oxides of nitrogen (NO_x) emission determinations are those outlined in Method 20 of the Federal Register, Volume 42, No. 160, January 29, 1988.

Testing was conducted by continuously extracting gas sample from the exhaust stream through a heated probe, a heated glass fiber filter, and conducting it through a conditioning system to the gas analyzers. All sample lines, prior to the conditioning system, were heated in order to prevent condensation. The conditioning system contained a refrigerator dryer, a water trap, and a secondary filter. Any condensate was continuously removed from the sampling system by the water trap, which minimized the contact between the condensate and sample gas.

The analyzers used were a Thermo Electron Corporation Model 10 AR chemiluminescent NO/NO_x analyzer and a Beckman Model 775 paramagnetic oxygen analyzer. The model 10 AR contains an NO_2 to NO converter and eight linear, full-scale ranges from 2.5 to 10,000 parts per million (ppm). The Beckman 775 has four linear, full-scale ranges from 5 to 25 percent. A schematic diagram of the sampling and calibration system is included at the end of this Appendix.

The following sections describe the measurement system performance checks, preliminary sampling procedures, and the NO_x emission determination procedures that were utilized.

1.7.1 Calibration Checks

Calibration gas used for the Model 10 AR had a concentration of 146.9 ppm NO_x in nitrogen and was documented traceable to National Bureau of Standards (NBS) Reference Materials. The oxygen calibration gas was 21.4 percent in nitrogen certified to ± 2 -percent accuracy. The mid- and low-level concentrations were achieved with a gas divider.

Prior to each individual test run, the zero- and mid-level gases were introduced to the analyzers and the responses set to the appropriate levels. Then the low-level and high-level calibration gases were introduced, and the instrument responses were recorded on the Calibration Data Sheets. After each test run, the gases were again introduced and the responses recorded on the Calibration Data Sheets.

1.7.2 Interference Response

Gaseous components were introduced separately into the measurement system and the responses noted. These gases contained components that may have acted as interferences to the analyzers.

In all cases, the response to the gases was less than the 2-percent allowable response for both instruments.

1.7.3 Response Time Determination

The response time of the sampling system was determined as follows:

Zero-level gas was introduced to the sampling system. After a stable reading was obtained, the system was switched to monitor the stack effluent. The upscale response time was measured and recorded on a data sheet. Then high-level gas was introduced. After a stable reading was obtained, the system was switched to monitor stack effluent. The downscale response time was measured and also recorded on a data sheet. This procedure was repeated three times. A stable value was equivalent to a change of less than 1 percent of span value for 30 seconds, or less than 5 percent of the measured average concentration for 2 minutes.

1.7.4 NO_x to NO Conversion Efficiency Check

The 146.9 ppm NO_x calibration gas and 21.4-percent O₂ gas were mixed 1:1 and introduced into the NO_x analyzer. The sampling system was operated for 35 minutes with the NO_x responses recorded. The instrument response was stable over the 35-minute period and did not decrease more than 2 percent of the highest peak value.

1.7.5 Preliminary Oxygen Traverse

A preliminary oxygen traverse was conducted for the purpose of selecting sampling points for the NO_x emission determinations. With the turbine operating at 30 percent of peak load, the oxygen concentration at each of the 24 traverse points was determined. Results were recorded on the Method 20 Preliminary Diluent Traverse Data Sheet. Eight points with the lowest oxygen concentration were selected for the NO_x emission testing.

1.7.6 Oxides of Nitrogen and Oxygen Measurements

Oxides of nitrogen and oxygen concentrations were measured at each of the eight traverse points. The minimum sampling time at each point was at least 1 minute plus the longest average system response time. The average steady state concentration of NO_x and O₂ were determined and recorded on the Method 20 Field Data Sheets.

At the beginning of each NO_x test run and approximately every 10 minutes during the run, the turbine operating data was recorded.

2.0 FIELD DATA SHEETS

Copies of all field data sheets generated during the field testing are contained at the end of this Appendix.



TABLE B-1
ORSAT TEST RESULTS

Test Parameter	Run No.	Turbine Load (%)	Instrument O ₂ (%)	Orsat Results (%)		
				O ₂	CO ₂	CO
NO _x	1	100	16.7	15.8	3.5	0.0
NO _x	2	100	16.9	15.4	3.6	0.0
NO _x	3	100	16.8	15.4	3.0	0.0
NO _x	1	75	17.8	17.1	2.2	0.0
NO _x	2	75	17.6	17.8	2.1	0.0
NO _x (1)	3	75	17.8	-----	-----	-----
NO _x	1	50	18.4	18.5	1.8	0.0
NO _x	2	50	18.8	18.2	2.0	0.0
NO _x	3	50	18.2	18.1	1.9	0.0
NO _x	1	30	18.9	19.0	2.0	0.0
NO _x	2	30	18.8	18.7	1.6	0.0
NO _x	3	30	18.6	18.6	1.6	0.0
Metals/ SO ₂	1	100	---	15.1	3.8	0.0
Metals/ SO ₂	2	100	---	15.1	3.9	0.0
Metals/ SO ₂	3	100	---	15.3	3.6	0.0

(1) NO_x Run 3 at 75 percent load, orsat sample was lost.



COMPUTATION SHEET

Sheet Number _____ of _____

Date 6/21/91

J. O. Number 5263 - 1


Computed by P. Gandy


Checked by _____

Name of Client Waste Management


Project Sample Set Installation, Gas Turbine

Description Sample Set Installation Description





EPA METHOD 5





TRAVERSE POINT LOCATION AND
GAS FLOW RATE DATA SHEETS



INSTRUMENT RESPONSE TIME

Date 12-2-91

Facility WASTE MANAGEMENT

Operator DC (PCB)

Location TAIL PILE #2 AREA

Analyzer BECKMAN 755 CO₂

Span Gas Concentration 21.4 ppm or %

Analyzer Range 0 - 25 %

Analyzer Span Setting _____ ppm or %

Upscale:

1 91 seconds

2 92 seconds

3 93 seconds

Average upscale response 92.1 seconds = SYSTEM RESPONSE TIME

Downscale:

1 55 seconds

2 58 seconds

3 60 seconds

Average downscale response 57.7 seconds



NO_x TESTING DATA SHEETS

WELDON CREEK DEER HARBORLAND TRUCKS

Address: West Management : Sample Port Location

.....
 The event is on: Thursday, Nov. 2, 1967


Date: 9/30/91

Stack Prepared 154

Representative Procedures

Project: F-63038-8

References



BCM

INSTRUMENT RESPONSE TIME

Date 10-2-91

Facility WASTE MANAGEMENT

Operator NS/PCB

Location PILE # 2 EXT

Analyzer NO_x

Span Gas Concentration 146.9 ppm or %

Analyzer Range X 250

Analyzer Span Setting _____ ppm or %

Upscale:

1 50 seconds

2 42 seconds

3 45 seconds

Average upscale response 45 seconds

Downscale:

1 65 seconds

2 69 seconds

3 67 seconds

Average downscale response 67 seconds



METHOD 20 - PRELIMINARY DILUENT TRAVERSE

Date 10-2-91Operator ARCFacility WASTE MANAGEMENTLocation TRASH PILE #2 CONT 38

Turbine Identification

Manufacturer SOLA-62

Model _____

Serial No. _____

Sample Point		Diluent Concentration	
No.		(gram per 10)	
A 15	B 10	19.13	19.59
A 9	B 9	19.04	19.19
A 8	B 8	18.95	19.03
A 7	B 7	18.88	18.95
A 6	B 6	18.72	18.88
A 5	B 5	18.77	18.85
A 4	B 4	18.93	18.92
A 3	B 3	18.98	18.95
A 2	B 2	19.08	19.00
A 1	B 1	19.13	19.03



METHOD 20 FIELD DATA SHEET

Facility W. M. G. M. T. Location _____
Test Operator MC Test Date 12-3-91
Turbine Type _____ Serial No. _____
Fuel _____ Operating Load 100% Test Run No. ONE

TURBINE OPERATION RECORD

Ambient Temperature 70°, Humidity 74%, Barometric Pressure 29.86
Test Time Start 18:21 Time Finish 18:57
Fuel Flow Rate _____ Water or Steam Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type _____ Serial No. _____
Nox Instrument Type _____ Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
B1	18:21	17.1	18.1
B6	18:24	16.7	19.7
B5	18:30	16.5	20.0
B4	18:35	16.3	18.2
B3	18:40	16.3	16.1
B5	18:44	16.5	19.6
B6	18:48	16.6	19.4
B7	18:53	16.6	19.3
	18:57	16.7	19.1
	37		

ECM

METHOD 20 FIELD DATA SHEET

Facility WALTON

Location TRAIL BLVD #2

Test Operator NC

Test Date 10-3-91

Turbine Type _____

Serial No. _____

Fuel _____ Operating Load 100%

Test Run No. 740

TURBINE OPERATION RECORD

Ambient Temperature 70, Humidity 66%, Barometric Pressure 29.96

Test Time Start 1924 Time Finish 1957

Fuel Flow Rate _____ Water or Steam Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type _____

Serial No. _____

Nox Instrument Type _____

Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A7	2 1924	17.0	17.9
B6	6 1928	16.9	18.8
A5	5 1932	16.6	20.1
A4	5 1937	16.3	19.8
B4	5 1942	16.8	18.7
B5	3 1947	16.8	18.8
B6	3 1950	16.9	18.8
B7	1953	16.9	18.7
	1957		
	29	16.95	18.93



METHOD 20 FIELD DATA SHEET

Facility W M G M T Location TURBINE #2
Test Operator NC Test Date 10-3-91
Turbine Type _____ Serial No. _____
Fuel _____ Operating Load 100% Test Run No. THREE

TURBINE OPERATION RECORD

Ambient Temperature 68°F Humidity 69% Barometric Pressure 29.96
Test Time Start 2013 Time Finish 2045
Fuel Flow Rate _____ Water or Stream Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type _____ Serial No. _____
NOx Instrument Type _____ Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A-7	2013	16.9	18.2
A-6	2016	16.9	18.7
A-5	2020	16.9	18.7
A-4	2025	16.5	20.2
B-4	2031	16.5	20.2
B-5	2035	16.9	18.7
B-6	2039	16.9	18.7
B-7	2045	16.5	20.2
		16.8	19.2



METHOD 20 FIELD DATA SHEET

Facility WAST PLANTLocation TENNESSEE #2Test Operator NCTest Date 10-3-74

Turbine Type _____

Serial No. _____

Fuel _____ Operating Load 75%Test Run No. ONETURBINE OPERATION RECORDAmbient Temperature 73, Humidity 48%, Barometric Pressure 29.74

Test Time Start _____ Time Finish _____

Fuel Flow Rate _____ Water or Stream Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type _____

Serial No. _____

Nox Instrument Type _____

Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A7	1420	14.0	17.5
A6	1424	12.8	19.0
A5	1427	11.8	18.5
A4	1430	12.8	17.7
B7	1439	12.8	18.1
B6	1442	12.6	19.1
B5	1449	12.6	18.9
B4	1451	12.8	17.7
	31	12.73	18.31

ECM

METHOD 20 FIELD DATA SHEET

Facility WASTE LOG-OUT

Location TRIPLE DE 2

Test Operator NC

Test Date 10-3-91

Turbine Type _____

Serial No. _____

Fuel _____

Operating Load 75%

Test Run No. 100

TURBINE OPERATION RECORD

Ambient Temperature 81, Humidity 42%, Barometric Pressure 29.90

Test Time Start 1546

Time Finish 1625

Fuel Flow Rate _____

Water or Steam Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type _____

Serial No. _____

Nox Instrument Type _____

Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A7	1552	17.8	18.1
A6	1556	17.7	18.8
A5	1600	17.7	18.8
A4	1604	17.8	17.7
B7	1612	17.5	18.7
B6	1614	17.6	19.0
B5	1617	17.5	18.7
B4	1621	17.7	17.9
	29	17.64	18.45



METHOD 20 FIELD DATA SHEET

Facility WEST MOUNTAIN Location TURBINE #2
Test Operator NC Test Date 10-3-91
Turbine Type _____ Serial No. _____
Fuel _____ Operating Load 75% Test Run No. THREE

TURBINE OPERATION RECORD

Ambient Temperature 70, Humidity 74, Barometric Pressure 29.86
Test Time Start 1720 Time Finish 1757
Fuel Flow Rate _____ Water or Stream Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type _____ Serial No. _____
Nox Instrument Type _____ Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)	
A7	1720	17.9	16.5	✓
A6	1725	17.7	17.1	
A5	1730	17.7	16.3	
A4	1734	17.8	16.7	✓
B7	1745	17.0	16.4	
B6	1748	17.8	16.3	
B5	1752	17.7	16.6	
B4	1754	17.6	16.5	
	34	17.78	16.5	

✓ 0.0 ppm test calibration



METHOD 20 FIELD DATA SHEET

Facility Waste ManagementLocation Turbine #2Test Operator MCTest Date 10-3-97

Turbine Type _____

Serial No. _____

Fuel _____ Operating Load 752 Test Run No. ThreeTURBINE OPERATION RECORDAmbient Temperature 72, Humidity 74, Barometric Pressure 29.86

Test Time Start _____ Time Finish _____

Fuel Flow Rate _____ Water or Steam Flow Rate _____

SAMPLE POINT RECORD


Diluent Instrument Type _____ Serial No. _____

Nox Instrument Type _____ Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A 7	1720	12.9	17.2
6	1725	12.7	18.0
5	1730	12.7	17.7
4	1734	12.8	16.5
67	1745	12.0	17.2
6	1748	12.8	17.2
5	1751	12.7	17.2
4	1754	12.6	16.2

11.9

OK No per prot - test calibration



METHOD 20 FIELD DATA SHEET

Facility WISCONSIN MANUFACTURING Location TURBINE #2 OUTLET
Test Operator NC Test Date 10-3-91
Turbine Type _____ Serial No. _____
Fuel _____ Operating Load 50 1/2 Test Run No. ONE

TURBINE OPERATION RECORD

Ambient Temperature 67, Humidity 76, Barometric Pressure 30.10
Test Time Start 1005 Time Finish 1026
Fuel Flow Rate _____ Water or Stream Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type DOAN PA200 O₂ Serial No. _____
Nox Instrument Type TECO CO chem Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A7	1005	18.4	14.1
AC	1007	19.3	14.4
AS	1010	18.5	13.9
AY	1012	18.7	13.9
B7	1016	18.4	13.8
BY	1020	18.3	14.6
BS	1022	18.3	14.5
BH	1026	18.4	13.9
	11	18.4	14.25



METHOD 20 FIELD DATA SHEET

Facility WEST MANHATTANLocation TURBINES #2 OUTTest Operator NCTest Date 10-3-91

Turbine Type _____

Serial No. _____

Fuel _____ Operating Load 50% Test Run No. TWOTURBINE OPERATION RECORDAmbient Temperature 72, Humidity 69, Barometric Pressure 30.05Test Time Start 1059 Time Finish 1127

Fuel Flow Rate _____ Water or Steam Flow Rate _____

SAMPLE POINT RECORDDiluent Instrument Type Model 755 04224 Serial No. _____NOx Instrument Type Model 10 04224 Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A1	1059	18.3	13.7
A2	1102	18.7	14.5
A5	1107	18.9	14.3
A4	1112	18.9	13.6
B7	1115	18.9	13.1
B6	1118	18.7	14.6
B5	1124	18.7	14.5
B4	1129	18.9	13.6
	1127		
	25	18.79	13.96



METHOD 20 FIELD DATA SHEET

Facility WEST WATKINS Location TOULOUSE #2
Test Operator ARC Test Date 10-3-91
Turbine Type _____ Serial No. _____
Fuel _____ Operating Load 50% Test Run No. TH02E

TURBINE OPERATION RECORD

Ambient Temperature 75, Humidity 52%, Barometric Pressure 30.00
Test Time Start 1248 Time Finish 1325
Fuel Flow Rate _____ Water or Steam Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type 2400A 245 Serial No. _____
Nox Instrument Type TECO 10 602244 Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A 7	1248	18.2	14.5
A 6	1251	18.1	15.3
A 5	1254	18.1	15.1
A 4	1257	18.2	14.6
B 7	1307	18.2	14.7
B 6	1310	18.1	15.5
B 5	1316	18.1	15.4
B 4	1321	18.2	14.9
33		18.15	14.99

ECM

METHOD 20 FIELD DATA SHEET

Facility WASTE MANAGEMENT Location TURBINE #2 OUT
 Test Operator ALC/DEB Test Date 10-2-91
 Turbine Type _____ Serial No. _____
 Fuel LANDELL GAS Operating Load 30% Test Run No. ONE

TURBINE OPERATION RECORD

Ambient Temperature 96°F, Humidity 35%, Barometric Pressure 29.98
 Test Time Start 16:57 Time Finish 17:5
 Fuel Flow Rate _____ Water or Steam Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type PARAMAC-VENT O₂ Serial No. _____
 NOx Instrument Type CHEMIL TEC2 12 Serial No. _____

30% Load 10-2-91


Sample Point	Time	O ₂ (%)	NO _x (ppm)
A10 B10	1732	19.13	11.2
A9 B9	1707	19.00	11.0
A8 B8	1704	19.95	11.0
A7 B7	1708	19.98	11.9
A6 B6	1710	19.77	11.9
A5 B5	1713	19.77	11.2
A4 B4	1715	19.93	11.0
A3 B3	1717	19.98	11.0
A2 B2	1722	19.08	11.0
A1 B1	1725	19.13	11.0

O₂ Avg = 19.86%

NO_x Avg = 11.4

(19.86-7)

(11.4-7)



METHOD 20 FIELD DATA SHEET

Facility WATER MANAGEMENT Location TURBINE #2 OUT
Test Operator ATC Test Date 12-2-94
Turbine Type _____ Serial No. _____
Fuel _____ Operating Load 30% Test Run No. 1220

TURBINE OPERATION RECORD

Ambient Temperature 79°F, Humidity 42%, Barometric Pressure 30.02
Test Time Start 1934 Time Finish 2001
Fuel Flow Rate _____ Water or Stream Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type MMI 755 PORT Serial No. _____
Nox Instrument Type TECO 10 CHINA Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
B 7	3 1934	18.75	9.4
B 6	3 1937	18.75	10.0
B 5	3 1940	19.75	9.8
B 4	3 1942	19.88	9.4
A 7	3 1954	18.93	9.4
A 6	3 1956	18.69	10.2
A 5	3 1959	19.85	9.8
A 4	2001	16.93	9.0
	27	18.82	9.63

ECM

METHOD 20 FIELD DATA SHEET

Facility WASTE MANAGEMENT Location TURBINE #2 SWT
 Test Operator NC (PCB) Test Date 10-2-91
 Turbine Type _____ Serial No. _____
 Fuel _____ Operating Load 30 1/2 Test Run No. THREE

TURBINE OPERATION RECORD

Ambient Temperature 76 °F, Humidity 52%, Barometric Pressure 30.10
 Test Time Start 2052 Time Finish _____
 Fuel Flow Rate _____ Water or Stream Flow Rate _____

SAMPLE POINT RECORD

Diluent Instrument Type BRAND PAS-100 Serial No. _____
 NOx Instrument Type TECO 10 C-6000A Serial No. _____

Sample Point	Time	O ₂ (%)	NO _x (ppm)
A 7	2052	18.88	8.0
A 6	2055	18.44	10.4
A 5	2058	18.52	10.2
A 4	2101	18.61	9.4
B 7	2055	18.85	9.2
B 6	2110	18.44	10.4
B 5	2114	19.54	10.0
B 4	2119		
	22	18.64	9.66



NO_x TESTING CALIBRATION DATA

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91


Analyzer TECO 10 NO₂c

Operator NY

Test Number ONE

100%				
Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	100	0	0	0
Low - Level Gas	100	14.7	12.5	
Mid - Level Gas	100	29.9	28.7	0.7 / 142%
High - Level Gas	100	44.1	44.2	

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

0 - 1.5

 10.5 = 51.6
 RF = 0.50



INSTRUMENT CALIBRATION DATA

DATE 10-3-91Analyzer PGMA 755 O₂Operator NCTest Number ONE

100%					
Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)	
Zero Gas	25	0	0	0	0
Low - Level Gas					
Mid - Level Gas	25	12.84	12.84	12.87	.03 / 100%
High - Level Gas	25	21.40	21.66		

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

$$d = 1.8$$

$$MLS = 90.7$$

$$RF = 1.2533$$



INSTRUMENT CALIBRATION DATA

DATE 10-3-91Analyzer TECO 10 NO_xOperator UCTest Number 1100

100% O ₂				
Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	100	0	0	0
Low - Level Gas	100	14.7	14.7	0
Mid - Level Gas	100	29.4	29.4	0
High - Level Gas	100	44.1	44.1	0

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

$$\phi = 2.3$$

$$MCS = 59.2$$

$$RF = .4966$$

BCM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer RAE 4401 755 O₂

Operator MC

Test Number TWO

100%

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	25	0	0	0
Low - Level Gas	25			
Mid - Level Gas	25	1284	1284	1278 09/24
High - Level Gas	25	2140	2161	

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

$$\phi = 18$$

$$MCS = 50.6$$

$$A_p = .2528$$

BCM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer TECO NOx

Operator MC

Test Number 110EE

100%

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	100	0	0	-6.2
Low - Level Gas	100	14.7		0.3
Mid - Level Gas	100	29.4	29.4	29.4
High - Level Gas	100	44.7	44.7	

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

$$\phi = 2.8$$

$$\text{MLS} = 59.3$$

$$\text{LF} = .4958$$

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer BAKMAN 755 O₂

Operator NC

Test Number THREE

100%

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	25	0	0	0
Low - Level Gas				
Mid - Level Gas	25	12.84	12.84	12.72 ± 0.12 / 0.6%
High - Level Gas	25	21.40		

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

$$Q = 1.8$$

$$MCS = 50.6$$

$$R_p = 25.38$$

ECM

INSTRUMENT CALIBRATION DATA

DATE 12-3-91

Analyzer Teco 10 NOx

Operator AKC

Test Number 046

75% Load

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	100	0	0.9	0.9 / 1.34%
Low - Level Gas	100	19.7	18.4	0.1 / .20%
Mid - Level Gas	100	29.4	29.9	0.5 / 1.02%
High - Level Gas	100	44.1	43.9	0.2 / 1.02%

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

$\phi = 3.3$

$WLS = 0.00005646$

$RF = .5213$

BCM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer BECKMAN 255 O₂

Operator WZ

Test Number 2241E

25% O ₂				
Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	25	0	0	0
Low - Level Gas				
Mid - Level Gas	25	22.89	22.90	0.01
High - Level Gas	25	21.90	22.06	0.16

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

0.01%

0.5%

0.75%

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer TECO 10 NO_x

Operator NJC

Test Number 1100

75% LOAD

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	100	0	0.67	0.67 / 1.37%
Low - Level Gas	100	14.7	15.11	
Mid - Level Gas	100	29.9	29.5	0.4 / 1.36%
High - Level Gas	100	44.4	43.4	

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

$\phi = 5.5$

MLS = 57.3

RF = 5.131

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

ANALYZER BECKMAN 755 O₂

Operator MC

Test Number 770

75%

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	<u>25</u>	<u>0</u>	<u>0</u>	<u>0</u> / <u>0</u>
Low - Level Gas				
Mid - Level Gas	<u>25</u>	<u>12.84</u>	<u>12.79</u>	<u>.05</u> / <u>1.23</u> %
High - Level Gas	<u>25</u>	<u>21.40</u>	<u>21.31</u>	<u>.09</u> / <u>1.19</u> %

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

$$\phi = (-8)$$

$$\text{MIS} = 50.2$$

$$\text{AP} = 1.2558$$

BCM

INSTRUMENT CALIBRATION DATA

DATE 12-3-91

Analyzer BEAVAL 755 O₂

Operator MC

Test Number 114265

75%				
Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	25	0	0	0
Low - Level Gas	25			
Mid - Level Gas	25	12.84	12.84	0.00
High - Level Gas	25	21.40	21.73	0.33%

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

$\phi = 1.3$
 $MC = 50.0$
 $RF = 2.968$



INSTRUMENT CALIBRATION DATA

DATE 10-3-91Analyzer TECO 130AOperator KCTest Number 164252

15 %				
Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	100	0	1.2	1.2 / 2.39 %
Low - Level Gas	100	14.7	15.0	.3 / 0.32 %
Mid - Level Gas	100	29.4	30.0	.6 / 1.2 %
High - Level Gas	100	44.1	44.7	

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

b = 6.8

MS = 52.5

LF = .513

BOV

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer TECO 10 NO_x

Operator NE

Test Number ONE

50 % Load

	Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)	
Zero Gas	<u>100</u>	<u>0</u>	<u>0</u>	<u>0.5</u>	<u>0.5</u>	<u>1.0</u>
Low - Level Gas	<u>100</u>	<u>14.7</u>	<u>15.0</u>	<u>15.5</u>	<u>0.5</u>	<u>1.0</u>
Mid - Level Gas	<u>100</u>	<u>29.4</u>	<u>29.4</u>	<u>29.7</u>	<u>0.3</u>	<u>0.1</u>
High - Level Gas	<u>100</u>	<u>44.1</u>	<u>44.0</u>	<u>44.0</u>	<u>0</u>	<u>0</u>

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

Span = 44.1 ppm



INSTRUMENT CALIBRATION DATA

DATE 10-3-91Analyzer BEAN 755 O₂Operator NCTest Number 00650% Load

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)	
Zero Gas	25	0	0	0	0
Low - Level Gas					
Mid - Level Gas	25	12.84	12.84	12.55	0.29 13
High - Level Gas	25	21.40	21.73	21.63	0.10 0

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

Span = 21.4%



INSTRUMENT CALIBRATION DATA

DATE 10-3-91Analyzer TECO 10 NO_xOperator NCTest Number 70050% Load

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	<u>100</u> <u>0</u>	<u>0.5</u>	<u>0.5</u>	<u>0</u> %
Low - Level Gas	<u>100</u> <u>14.7</u>	<u>15.85</u>	<u>15.2</u>	<u>0.1</u> %
Mid - Level Gas	<u>100</u> <u>29.4</u>	<u>29.7</u>	<u>28.8</u>	<u>0.6</u> %
High - Level Gas	<u>100</u> <u>44.1</u>	<u>44.8</u>	<u>43.2</u>	<u>0.6</u> %

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

491.50376 = 2.0100.5 = 50.4

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer MAC 755 O₂

Operator NCE

Test Number 1100

50% Lead

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	25	0	0	0 / 0
Low - Level Gas				
Mid - Level Gas	25	12.84	12.95	0.11
High - Level Gas	25	21.40	21.97	0.57

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer TECO NO_x

Operator MC

Test Number 11025

50% LOA

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	100	0	0.9	.9 / 1.8%
Low - Level Gas	100	14.7	15.5	.8 / 1.02
Mid - Level Gas	100	29.4	29.9	.5 / 1.02%
High - Level Gas	100	44.1	44.3	.2 / .44%

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$

49 ppm (.2%)

MC 52 57.1

RC 5 57.9

BCM

INSTRUMENT CALIBRATION DATA

DATE 10-3-91

Analyzer BCM 755 O₂

Operator MC

Test Number 74-225

50% Load

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	25 0	0	0.05	.05 / .25
Low - Level Gas				
Mid - Level Gas	25 12.84	12.84	12.56	.28 / 1.34
High - Level Gas	25 21.90	21.90	21.52	.37 / 1.00

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

12.84
12.56
21.90
21.52

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-2-91

Analyzer TECO 10 NO_x

Operator NC

Test Number 5NE

30% O₂ Load

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	<u>250</u>	<u>0</u>	<u>0</u>	<u>0</u>
Low - Level Gas	<u>250</u>	<u>29.4</u>	<u>29.6</u>	<u>0.2</u>
Mid - Level Gas	<u>250</u>	<u>73.5</u>	<u>74.9</u>	<u>1.4</u> (3%)
High - Level Gas	<u>250</u>	<u>146.9</u>	<u>147.0</u>	

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

0.40 = 0.5%



INSTRUMENT CALIBRATION DATA

DATE 10-2-91Analyzer BCM 755 O₂Operator NFCTest Number ONE30% Rough

Instrument Range	Cylinder Value (ppm-%)	Initial Analyzer Response (ppm-%)	Final Analyzer Response (ppm-%)	Differential: Initial-Final (ppm-%)
Zero Gas	<u>25</u>	<u>0</u>	<u>0</u>	<u>0.05</u>
Low - Level Gas	<u>25</u>	<u>—</u>	<u>—</u>	<u>—</u>
Mid - Level Gas	<u>25</u>	<u>12.8</u>	<u>12.8</u>	<u>0.3</u>
High - Level Gas	<u>25</u>	<u>21.9</u>	<u>21.9</u>	<u>0.4</u>

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

23.3% (22.2, 476)

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-2-91

Analyzer NOx

Operator NC

Test Number 11410

30%

	Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	250	22	0	0	0
Low - Level Gas	250	29.4	29.6	29.2	0.4
Mid - Level Gas	250	73.5	74.9	75.1	0.2
High - Level Gas	250	146.9	153.0	153.0	0

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

175

BCM

INSTRUMENT CALIBRATION DATA

DATE 10-2-91

Analyzer O₂

Operator MC

Test Number 7760

30% O₂ Level

	Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	<u>25</u>	<u>0</u>	<u>0.05</u>	<u>0.41</u>	<u>0.36</u>
Low - Level Gas	<u>25</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
Mid - Level Gas	<u>25</u>	<u>12.8</u>	<u>12.5</u>	<u>12.8</u>	<u>0.3</u>
High - Level Gas	<u>25</u>	<u>21.4</u>	<u>21.9</u>	<u>21.7</u>	<u>0.2</u>

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

ECM

INSTRUMENT CALIBRATION DATA

DATE 10-2-91

Analyzer TECO NO_x

Operator MC/PCB

Test Number 74265

30% Load

Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	250	0	0	0
Low - Level Gas	250	29.4	29.2	
Mid - Level Gas	250	73.5	75.1	74.3 0.8%
High - Level Gas	250	146.9	153.0	

Percent drift = $\frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$

BCM

INSTRUMENT CALIBRATION DATA

DATE 10-2-91

Analyzer O₂

Operator JSC / PCB

Test Number THP 23

30 % Load

	Instrument Range	Cylinder Value (ppm or %)	Initial Analyzer Response (ppm or %)	Final Analyzer Response (ppm or %)	Differential: Initial-Final (ppm or %)
Zero Gas	<u>25</u>	<u>0</u>	<u>0.5</u>	<u>0.5</u>	<u>0.5</u>
Low - Level Gas	<u>25</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
Mid - Level Gas	<u>25</u>	<u>12.8</u>	<u>12.8</u>	<u>12.8</u>	<u>0.0</u>
High - Level Gas	<u>25</u>	<u>21.4</u>	<u>21.7</u>		

$$\text{Percent drift} = \frac{\text{Absolute Difference}}{\text{Span Value}} \times 100$$



METALS TESTING DATA SHEETS

TRANSVERSE POINT NUMBER	CLOCK TIME	CAR METER READING (ft.)	VELOCITY (ft./sec)	SURFACE PRESSURE DIFFERENTIAL (psi)		STACK TEMPERATURE (°F)	OXY GAS METER TEMPERATURE (°F)		PUMP VOLUME (in. Hg)	SAMPLE BOX TEMPERATURE (°F)	HUMIDITY TEMPERATURE (°F)
				DESIGNED	ACTUAL		INLET	OUTLET			
1055	1542	122.4	2.30	1.50	1.50	737	101	90	3	250	60
1060	1547	127.1	2.30	1.50	1.50	737	102	92	3	250	60
1065	1552	133.4	2.30	1.50	1.50	741	101	95	4	250	55
1070	1557	138.0	2.30	1.70	1.90	747	102	97	5	250	60
1075	1601	141.1	2.30	1.70	1.70	742	102	97	5	250	60
1080	1607	145.5	2.30	1.50	1.50	745	103	100	3	250	60
1085	1612	149.1	1.80	1.30	1.30	746	107	102	3	250	64
1090	1617	151.9	1.50	0.70	0.90	727	100	106	3	250	64
1095	1621	154.9	1.30	0.91	0.92	713	101	103	3	250	64
1100	1627	157.8	1.10	0.92	0.92	704	121	104	2	250	60
1105	1631	161.4	0.91	0.92	0.92	704	121	104	2	250	60
1110	1637	164.7	0.91	0.92	0.92	704	121	104	2	250	60
1115	1641	167.9	0.91	0.92	0.92	704	121	104	2	250	60
1120	1647	171.2	0.91	0.92	0.92	704	121	104	2	250	60
1125	1651	174.5	0.91	0.92	0.92	704	121	104	2	250	60
1130	1657	177.8	0.91	0.92	0.92	704	121	104	2	250	60
1135	1661	181.1	0.91	0.92	0.92	704	121	104	2	250	60
1140	1667	184.4	0.91	0.92	0.92	704	121	104	2	250	60
1145	1671	187.7	0.91	0.92	0.92	704	121	104	2	250	60
1150	1677	191.0	0.91	0.92	0.92	704	121	104	2	250	60
1155	1681	194.3	0.91	0.92	0.92	704	121	104	2	250	60
1160	1687	197.6	0.91	0.92	0.92	704	121	104	2	250	60
1165	1691	200.9	0.91	0.92	0.92	704	121	104	2	250	60
1170	1697	204.2	0.91	0.92	0.92	704	121	104	2	250	60
1175	1701	207.5	0.91	0.92	0.92	704	121	104	2	250	60
1180	1707	210.8	0.91	0.92	0.92	704	121	104	2	250	60
1185	1711	214.1	0.91	0.92	0.92	704	121	104	2	250	60
1190	1717	217.4	0.91	0.92	0.92	704	121	104	2	250	60
1195	1721	220.7	0.91	0.92	0.92	704	121	104	2	250	60
1200	1727	224.0	0.91	0.92	0.92	704	121	104	2	250	60
1205	1731	227.3	0.91	0.92	0.92	704	121	104	2	250	60
1210	1737	230.6	0.91	0.92	0.92	704	121	104	2	250	60
1215	1741	233.9	0.91	0.92	0.92	704</					



SO₂ TESTING DATA SHEETS



Wade Management

10/2/81

Trailer No. 2

Mobile Run 3

Time 4:00 PM

Run PB/KR

3028 Run PB/KR - 83

16.50

0

163.4

100

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

100

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

100

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

Plant Waste Management

Run 9/20/91 Run 008/K0

Sampling Location T-1100 No. 2 Outlet



ENTER JOB NUMBER A-2 A6

SAMPLE BOX NUMBER(S) 1

PROJECT NUMBER TYPE

METHOD 5 FIELD DATA SHEET

SO₂ Run 1

TRAVEL TIME MIN.	CLOCK TIME HH:MM:SS	BAROMETER READING (in. Hg)	WIND DIRECTION	WIND SPEED (mi/hr)	WIND TEMPERATURE (°F)	WIND RELATIVE HUMIDITY (%)	WIND DIRECTION	WIND SPEED (mi/hr)	WIND TEMPERATURE (°F)	WIND RELATIVE HUMIDITY (%)
00	1533	128.770	19	60	83	83	3	63		
05	1543	132.7	19	60	102	83	3	64		
10	1547	136.2	19	70	110	85	3	64		
15	1553	140.0	19	70	114	87	4	64		
20	1558	143.6	19	70	120	91	4	64		
25	1603	147.7	19	76	118	94	4	64		
30	1608	151.2	19	74	127	97	4	64		
35	1613	155.0	19	73	133	98	3	65		

CO₂
CO₂
CO₂
H₂ 30/12

40	1618	158.9	19	72	139	100	3	65		
45	1623	161.6	19	72	136	100	3	65		
50	1628	165.460	19	72	138	100	3	65		
55	1634	169.4	19	72	140	100	3	65		
60	1639	173.3	19	72	143	100	3	64		
65	1644	177.0	19	72	146	100	3	64		

CO₂
CO₂
CO₂
H₂

70	1649	180.0	19	70	147	107	3	64		
75	1654	184.5	19	70	147	107	3	63		
80	1659	189.0	19	70	147	107	3	63		
85	1664	193.0	19	70	147	107	3	64		
90	1669	197.0	19	70	147	107	3	64		
95	1674	201.0	19	70	147	107	3	64		
100	1679	205.0	19	70	147	107	3	64		

CO₂
CO₂
CO₂
H₂

Run 74.7/13.7 A6, Tm = 107

ALL INFORMATION CONTAINED
HEREIN IS UNCLASSIFIED
DATE 10-11-2000 BY 60321
UCBAW/BJA




Year	1980	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093	2094	2095	2096	2097	2098	2099	2100
1980	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093	2094	2095	2096	2097	2098	2099	2100	

JUN
JUL
AUG
SEP
OCT

NOV
DEC
JAN
FEB
MAR

APR
MAY
JUN
JUL
AUG

[illegible]

96	167	227.4	703	126	98	4	69
51	127	226.6	704	127	97	3	69
100	147	229.512	703	128	100	3	69
 							

[illegible]

Date 10/1/91 10/1/91
 Location Truckee, Mo. 2
 Method 3



Date and time A-2
 Date and time A-2
 Date and time A-2


METHOD 4 FIELD DATA SHEET

TRANSVERSE POINT NUMBER	DATE TIME OF OBSERVATION	GAS METER READING (L.F.)	WIND DIRECTION	WIND SPEED (MPH)		WIND TEMPERATURE (°F)	WIND DIRECTION	WIND SPEED (MPH)	WIND TEMPERATURE (°F)
				MAX	MIN				
001	0911	301.584	AW	73	65	5	5	5	65
002	0917	301.5	AW	87	66	5	5	5	64
003	0919	301.0	AW	94	69	5	5	5	63
004	0927	301.5	AW	94	71	5	5	5	63
005	0941	301.3	AW	104	74	4	4	4	63
006	0947	300.2	AW	107	77	4	4	4	63
007	0951	300.8	AW	107	79	4	4	4	63
008	0957	300.6	AW	111	82	4	4	4	64

009	1002	301.4	AW	114	84	4	4	4	64
010	1007	301.1	AW	116	86	4	4	4	64
011	1012	300.73	AW	116	86	4	4	4	64
012	1015	300.73	AW	116	86	4	4	4	64
013	1018	300.73	AW	116	86	4	4	4	64
014	1020	300.73	AW	116	86	4	4	4	64
015	1022	300.73	AW	116	86	4	4	4	64
016	1024	300.73	AW	116	86	4	4	4	64
017	1026	300.73	AW	116	86	4	4	4	64
018	1028	300.73	AW	116	86	4	4	4	64

019	1030	300.73	AW	116	86	4	4	4	64
020	1032	300.73	AW	116	86	4	4	4	64
021	1034	300.73	AW	116	86	4	4	4	64
022	1036	300.73	AW	116	86	4	4	4	64
023	1038	300.73	AW	116	86	4	4	4	64
024	1040	300.73	AW	116	86	4	4	4	64
025	1042	300.73	AW	116	86	4	4	4	64
026	1044	300.73	AW	116	86	4	4	4	64
027	1046	300.73	AW	116	86	4	4	4	64
028	1048	300.73	AW	116	86	4	4	4	64

Date 10/1/91 10/1/91
 Location Truckee, Mo. 2
 Method 3



TURBINE OPERATING DATA SHEETS



TURBINE OPERATING DATA

Facility WASTE MGMTLocation TURBINE #2Test Operator PCBTest Date 7-30-91Fuel Liquid gasTest Run No. 201E Metal/SCA100% load

	Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
16	1535	1291	3100	129	1170	67
10	1551	1285	3000	129	1170	67
15	1601	1281	3100	129	1170	67
13	1616	1279	3100	129	1170	67
22	1627	1275	3100	129	1170	67
13	1651	1285	3100	129	1170	65
17	1704	1288	3100	129	1170	65
11	1721	1280	3100	129	1170	64
	1732	1285	3100	129	1170	63
	1757	1292.7	3100	129	1170	65.8

Barometric
Pressure 30.92⁶Relative Humidity 35% @ 80°F

BCM

TURBINE OPERATING DATA

Facility WEST MANHATTAN Location TORRANCE #2 COF
 Test Operator NC/KR Test Date 10-1-91
 Fuel Liquid Gas Test Run No. 1000 MFLAS/50

100% LOAD

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (hp)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
1035	1273	3100	129	1170	67
1045	1285	3100	129	1170	67
1059	1286	3100	129	1170	67
1114	1277	3100	129	1170	67

STOP : TURBINE DOWN

1516	1252	2950	125	1170	76
1539	1239	2950	125	1170	75
1554	1238	2950	125	1170	75
1604	1246	2950	125	1170	75
1618	1242	2950	124	1170	75
1641	1252.8	3016.7	126.7	1170	71.6
	1106.4	3007.9	125.3		

Barometric Pressure 30.15 Relative Humidity 62% @ 65°F

ECM

TURBINE OPERATING DATA

Facility Waste Management

Location Turbine No. 1

Test Operator PCB/KC

Test Date 10/1/91

Fuel Compressed Gas

Test Run No. Metalby/SC₂ Run 3

100% Load

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (hp)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (°F)
0910	3050	3050	127	1170	65
0930	990	3050	126	1170	67
0945	990	3050	126	1170	68
0955	990	3000	126	1170	70
1015	990	3000	126	1170	72
1035	990	3000	126	1170	72
1045	990	2950	125	1170	77
110	990	2950	125	1170	77
1128	990	2950	124	1170	78
1144	990	2950	124	1170	80
1156	990	2950	124	1170	80
2:46	1290	2991	125.4	1170	73.3

Barometric Pressure 30.26
30.14 End

Relative Humidity 81% @ 66°
52% @ 84° End



TURBINE OPERATING DATA

Facility W. J. Hall Location Turbine 2
Test Operator W. C. Test Date 10-3-71
Fuel _____ Test Run No. Run one

100%

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
131326	1232	2950	12.4	1170	70
171839	1239	2950	12.5	1170	68
1856	1241	2950	12.5	1170	67
30	1237.3	2950	12.47	1170	68.3

Barometric Pressure 29.96 Relative Humidity 74% @ 70°F



TURBINE OPERATING DATA

Facility Waste Management Location Tandem No. 2
Test Operator MC Test Date 10/3/91
Fuel _____ Test Run No. 7140

100%

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (hp)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
20 1925	1245	2980	124	1170	67
1945	1241	2980	125	1170	67
20 1243		2980	124.5	1170	67

Barometric
Pressure _____

Relative Humidity _____

BOM

TURBINE OPERATING DATA

Facility W. M. G. M. T.Location TURBINE #2Test Operator NCTest Date 10-3-91

Fuel _____

Test Run No. 1003 Run 3

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (hp)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
11 2015	1249	3000	125	1170	65
20 1026	1260	3000	125	1170	64
20 46	1250	3000	125	1170	64
131	1255	3000	125	1170	64.5

Barometric
Pressure _____

Relative Humidity _____



TURBINE OPERATING DATA

Facility 11445TH Academy Capital Center Location TORONTO, IL 2017

Test Operator MC / KB

Test Date 10-3-91

Fuel

Test Run No. 946

75% load

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (°F)
12 1472	1010	2250	119	1030	73
21 1434	1010	2250	118	1030	73
1454	1009	2250	118	1030	73
33	1009.7	2250	113.3	1030	73

Barometric Pressure 29.99

Relative Humidity 48% @ 78°F



TURBINE OPERATING DATA

Facility W45TH MAGNETLocation TURBINE #2Test Operator NCLTest Date 10-3-91

Fuel _____

Test Run No. Two75%

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
13 1547	1010	2250	119	1030	73
16 1600	1020	2250	118	1020	73
19 1616	1017	2250	117	1020	76
22 1625	1017	2250	117	1015	80
33	1016.3	2250	117.9	1021.3	76

Barometric
Pressure 29.90Relative Humidity 42% @ 81°



TURBINE OPERATING DATA

Facility 100077 1000000000Location 771250 0000 344 22Test Operator WRCTest Date 10-30-91Fuel Test Run No. 77125000075%

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
23 1724	1018	2250	113	1020	77
1 1745	1015	2250	113	1015	75
1756	1014	2250	113	1015	75
34	1015.7	2250	113	1016.7	75.7

Barometric
Pressure Relative Humidity



TURBINE OPERATING DATA

Facility WASTES MANAGEMENTLocation TURBINE #2 SWTTest Operator NCTest Date 10-3-91

Fuel _____

Test Run No. 600E50% LOAD

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (°F)
1003	770	1450	110	830	72
1013	774	1450	110	850	72
1024	767	1450	110	850	70
1030	772	1450	110	850	70
27	770.8	1450	110	855	71

Barometric
Pressure _____

Relative Humidity _____



TURBINE OPERATING DATA

Facility WPTT PA 045047 Location PA 045047
Test Operator MSC Test Date 12-3-91
Fuel _____ Test Run No. 1000

50% Load

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
13 1100	713	1450	110	860	70
13 1113	712	1450	110	860	70
1126	769	1450	110	860	73
26	770.7	1450	110	860	71

Barometric
Pressure _____ Relative Humidity _____



TURBINE OPERATING DATA

Facility WEST MOUNTAINLocation TRUCKEE ST 2Test Operator NC PCBTest Date 10-3-11

Fuel _____

Test Run No. THREE50% LOAD

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (°F)
					
18 1249	761	1450	110	860	73
17 1307	763	1450	110	860	73
1324	763	1450	110	860	72
35	762.3	1450	110	860	72.7

Barometric
Pressure30.00

Relative Humidity

52% @ 75°F



TURBINE OPERATING DATA

Facility WASTE MANAGEMENT Location TURBINE # 2 OUTLET
Test Operator NE/PCB Test Date 10-2-91
Fuel LANDFILL GAS Test Run No. NO_x 20% RUN 1
(DIRECT)

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (F)
21 1658	617	950	104	780	73
16 1719	624	1000	104	780	77
23 1737	627	1000	104	780	77
16 1800	616	950	104	775	75
18 1810	616	950	104	780	75
17 1712	620	970	104	779	76.4

Barometric Pressure 29.98 Relative Humidity 35% @ 86°F

ECM

TURBINE OPERATING DATA

Facility WASTE MGMT

Location TURBINE #2

Test Operator MC

Test Date 10-2-91

Fuel

Test Run No. TWO

30% LOAD

Clock Time	Gas Flow Rate (scfm)	Turbine Output Power (kw)	Combustor Inlet Pressure (psi)	Turbine Air Temp. Outlet (F)	Ambient Temperature (°F)
19 1930	628	1000	104	760	65
11 1949	623	1000	104	760	63
8 2000	637	1000	104	760	63
2001	633	1000	104	760	62
38	6303	1000	104	760	633

Barometric
Pressure 30.02

Relative Humidity 42% @ 79°F



30% Load

Barometric Pressure 30.10 Relative Humidity 52% @ 76°F

001 01

FL 008

TIME

AUGCH4

AUGC02

AUGC02

AUGC02

0	56.54726	42.46294	1.9793794	2.97741-02
1	56.51232	42.45542	1.97951098	3.1034E-02
2	56.49854	42.44726	1.9796998	3.3545E-02
3	56.48921	42.43859	1.979994	3.4232E-02
4	56.4831	42.42882	1.980149	3.6708E-02
5	56.41695	42.41161	1.980265	3.7905E-02
6	56.49512	42.40536	1.979954	4.8479E-02
7	56.4891	42.39465	1.979976	4.3225E-02
8	56.46911	42.3843	1.979618	4.4123E-02
9	56.46052	42.3743	1.979618	4.5617E-02
10	56.45424	42.3643	1.979618	4.6981E-02
11	56.44729	42.3543	1.979618	4.8412E-02
12	56.44591	42.3443	1.979618	4.1959E-02
13	56.44324	42.3343	1.979618	4.1333E-02
14	56.44325	42.3243	1.979618	4.1705E-02
15	56.44171	42.3143	1.979618	4.0233E-02
16	56.43919	42.3043	1.979618	4.0651E-02
17	56.4389	42.2943	1.979618	4.0651E-02
18	56.43774	42.2843	1.979618	3.9833E-02
19	56.43303	42.2743	1.979618	4.0748E-02
20	56.44659	42.2643	1.979618	
21	56.44551	42.2543	1.979618	4.1955E-02
22	56.44325	42.2443	1.979618	4.1217E-02
23	56.44098	42.2343	1.979618	4.1798E-02

TIME

AUGCH4

AUGCH4

AUGPRE3

AUGTEMP

0	0.9707531	573.1529	165.8763	92.94876
1	0.9708521	573.8482	165.8353	90.91887
2	0.9709364	573.8232	165.9629	87.92529
3	0.9709193	573.3578	165.9069	85.46303
4	0.970993	573.0412	165.9331	84.30216
5	0.9710293	572.8165	165.9277	83.46682
6	0.970981	573.5156	165.9258	81.67647
7	0.9699538	573.5538	165.9469	81.31636
8	0.9699852	573.3397	165.9671	82.96719
9	0.9699557	573.2616	165.9177	92.69476
10	0.9699564	573.0969	165.9572	95.96971
11	0.9698496	573.1165	165.9676	98.36468
12	0.9698158	573.2133	165.7979	101.4573
13	0.9699087	573.1885	165.6845	104.9363
14	0.9699309	573.2135	165.6813	106.8596
15	0.9699639	573.2749	165.7435	103.1464
16	0.9699558	573.2749	165.7435	103.0816
17	0.9699558	573.2749	165.7435	103.0816

22 21 0.9702419 573.0086 165.4332 90.84593
 23 22 0.9702774 573.0086 165.4332 90.84593
 24 23 0.9703732 573.0045 165.4422 90.8473

Rec No	TIME	AUGSTR	BTU	SCF	RUNTIME
1	0	66221.23	37991	66172	60
2		66402.91	38109	66408	62
3	1	66412.14	38212	66427	62
4	2	66438.23	38122	66427	62
5	3	66512.51	38250	66421	60
6	4	66561.96	38311	66352	59
7	5	66693.7	38281	66736	64
8	6	66683.72	38221	66642	60
9	7	66636.53	38221	66631	60
10	8	66623.87	38133	66623	62
11	9	66525.27	38126	66527	62
12	10	66329.45	37999	66301	59
13	11	71547.36	43767	71155	60
14	12	77525.64	44432	77523	60
15	13	77416.07	44322	77396	62
16	14	77135.24	44212	77123	60
17	15	76921.1	44114	76923	60
18	16	76922.44	44123	76956	60
19	17	77254.62	44274	77223	60
20	18	77425.23	44376	77436	60
21	19	77689.51	44542	77713	60
22	20	77624.26	44487	77624	60
23	21	77916.55	44573	77736	60
24	22	77362.24	44616	77639	60

9/30/91

reached
 5000
 6000

7707

765

RIFSCALE 2 RIFSCALE 3
 31 31666

Unit 00000 ALARM SUMMARY OCT 21 1991 00:22

Rec No	LO
1	OFF
2	OFF
3	OFF
4	OFF

NOTE

10/1/91

Unit: 0000

DAILY TUBE 2

RECDATE 1
100191

H1002

Rec No	TIME	000004	000102	000202	000302
1	1	56.44377	42.29367	1.222717	4.2466E-01
2	2	56.44673	42.29327	1.213273	4.1749E-02
3	3	56.44651	42.33507	1.26775	4.2467E-01
4	4	56.44732	42.3103	1.200366	4.1516E-02
5	5	56.44554	42.31601	1.18348	3.9895E-01
6	6	56.44943	42.32631	1.164704	3.9991E-02
7	7	56.39746	42.38423	1.170151	3.9923E-02
8	8	56.39942	42.39235	1.174631	3.1914E-02
9	9	56.38828	42.39547	1.176911	3.9346E-02
10	10	56.38619	42.40111	1.171106	3.9433E-02
11	11	56.38363	42.41331	1.168531	3.9443E-02
12	12	56.13811	42.62341	1.147313	3.997E-02
13	13	56.56031	42.4411	1.9614-01	3.911E-01
14	14	56.13807	42.13617	1.9444111	3.1291E-02
15	15	56.65632	42.34801	0.91491	3.0473E-02
16	16	56.60030	42.44801	0.9100-01	3.1231E-02
17	17	56.58430	42.47337	0.9177E-01	3.1341E-02
18	18	56.57334	42.48338	1.9106733	3.1148E-01
19	19	56.57103	42.51734	1.9061301	3.1211E-01
20	20	56.56332	42.53112	1.9073232	3.1273E-02
21	21	56.51905	42.51907	1.9134-04	3.1133E-01
22	22	56.49034	42.54967	1.9235337	3.1403E-02
23	23	56.47631	42.5521	0.9409541	3.0743E-02
24	24	56.45331	42.5516-	1.9508742	3.1103E-02

Turbidity
Cavity

Rec No	TIME	000004	000102	000202	000302
1	1	0.9703212	573.3127	165.4452	92.4903
2	2	0.9703233	573.1241	165.4427	92.2817
3	3	0.9703034	573.1226	165.4219	92.7127
4	4	0.9703356	573.1303	165.4386	91.0753
5	5	0.9703319	573.213	165.4358	93.1603
6	6	0.9704219	573.142	165.5071	94.2337

8					165.6292	96.75001
9		8	0.9710519	572.5308	165.5576	99.45326
10		9	0.97111279	572.4926	165.6247	102.1908
11		10	0.9711574	572.4769	165.6796	106.3254
12	Methods	11	0.973169	573.5034	164.6111	105.6191
13	SO ₂	12	2.9600371	574.0134	166.4177	101.7534
14	Flow	13	0.9650747	573.0738	167.1163	107.2834
15	2	14	0.9633603	573.2642	165.9136	113.2833
16		15	0.9704317	574.4571	166.0685	110.212
17		16	0.97067	574.2351	166.1436	119.2734
18		17	0.9707832	574.4505	166.1986	117.5871
19		18	0.9710444	574.1936	166.1493	111.9509
20		19	0.9711915	574.0332	166.0317	106.2001
21		20	0.9713306	573.8731	165.974	103.4753
22		21	0.9714807	573.5838	165.9273	121.9433
23		22	0.9715579	573.4248	165.8872	103.7231
24		23	0.9716001	573.281	165.8394	100.6533

Technical down

Rec No	TIME	PLASTER	STU	SCF	RUN TIME
1	8	77665.14	44503	77663	61
2	1	77670.06	44506	77658	61
3	2	77479.72	44406	77483	60
4	3	77561.39	44446	77545	60
5	4	77487.86	44401	77468	60
6	5	77448.	44389	77448	60
7	6	77451.76	44383	77507	61
8	7	77763.7	44491	77700	62
9	8	77540.22	44427	77593	62
10	9	77355.81	44352	77297	63
11	10	76865.82	44023	76893	60
12	11	7688.81	43862	76801	61
13	12	48938.71	4383	4893	61
14	13	34500.11	43724	27339	54
15	14	75203.11	43251	75190	60
16	15	74807.47	43024	74861	62
17	16	74634.44	42890	74668	62
18	17	74734.37	42901	74683	62
19	18	75131.11	43671	75717	62
20	19	75061.13	43601	75207	62
21	20	77091.1	44134	77304	64
22	21	77338.33	44460	77347	62
23	22	77761.11	44501	77741	60
24	23	77072.66	44111	77124	62

Technical down

SOFFFACE	STABO-LE	L
	17036	

10/2/91

Unit: 0000

DAILY TIME

OCT 02 1991 07:14

RECDATE 1
100891

HL002

Rec No	TIME	AVGCR4	AVGCR2	AVGCR1	AVGCR0
1	0	56.44364	42.55365	0.5562483	3.24062-02
2	1	56.43342	42.56432	0.5567801	3.36462-02
3	2	56.42352	42.57136	0.5570041	3.38190-02
4	3	56.41183	42.57632	0.5573756	3.44682-02
5	4	56.40012	42.57868	0.5585886	3.54051-02
6	5	56.38638	42.57812	0.5585914	3.57840-02
7	6	56.38962	42.55742	1.014266	3.84851-02
8	7	56.38328	42.55659	1.022809	3.73591-02
9	8	56.36935	42.55391	1.0400269	3.79431-02
10	9	56.35634	42.54591	1.057600	3.95441-02
11	10	56.35228	42.54037	1.066962	3.99321-02
12	11	56.34759	42.54079	1.072126	3.95700-02
13	12	56.34304	42.54613	1.067308	3.83191-02
14	13	56.34376	42.53119	1.061905	3.81170-02
15	14	56.3323	42.43267	1.020042	3.69551-02
16	15	56.33032	42.39835	0.9703823	3.24110-02
17	16	56.32521	42.41001	0.912118	2.75341-02
18	17	56.32537	42.42363	0.8734733	2.37641-02
19	18	56.32846	42.40834	0.8376035	2.16780-02
20	19	56.32651	42.41361	0.7923501	2.35822-02
21	20	56.32534	42.44389	0.7647564	2.06421-02
22	21	56.34333	42.49691	0.7337382	1.98552-02
23	22	56.31042	42.51967	0.7472254	1.67091-02
24	23	56.29975	42.5218	0.7592491	2.13460-02

Rec No	TIME	AVGCR4	AVGCR2	AVGCR1	AVGCR0
1	0	0.9717139	572.1648	165.3564	133.4156
2	1	0.9717978	572.0131	165.5704	132.117
3	2	0.9718873	572.0987	165.565	131.3139
4	3	0.9719628	572.2734	165.7391	99.13239
5	4	0.9722233	572.6611	165.7807	97.33664
6	5	0.9720045	572.5321	165.7534	92.33411
7	6	0.9719531	572.3337	165.6976	95.61671
8	7	0.9719737	572.4885	165.6945	93.63032
9	8	0.9720173	572.3302	165.7247	93.747
10	9	0.972025	572.2203	165.8544	100.5727
11	10	0.9720107	572.1777	165.9888	113.7436

13	13	0.9700000	573.695	167.3716	122.8031
14	14	0.9700000	573.695	167.3716	125.3956
15	15	0.9700000	573.695	167.3716	124.3279
16	16	0.9700000	573.695	167.3716	124.5971
17	17	0.9700000	573.695	167.3716	123.5912
18	18	0.9700000	573.695	167.3716	123.6063
19	19	0.9698573	573.9133	167.5315	114.3795
20	20	0.9698573	573.9133	167.4431	107.118
21	21	0.9698573	573.9133	167.3362	103.9662
22	22	0.9701246	574.169	168.4266	101.5105
23	23	0.9713512	574.8425	169.9444	103.7914
24	24	0.9714361	574.8425	169.9512	103.6456

Rec No	TIME	ACCT	BT	SCF	REP TIME
1	0	77879.79	44216	77144	62
2	1	77867.05	44413	77515	60
3	2	77891.67	44580	77816	60
4	3	77848.88	44717	78069	60
5	4	77838.38	44564	77821	60
6	5	77841.33	44373	77492	62
7	6	77868.99	44551	77862	60
8	7	77834.69	44447	77633	62
9	8	77855.83	44434	77638	60
10	9	76932.66	43861	76631	62
11	10	75753.46	43344	75753	62
12	11	75813.69	42897	74977	60
13	12	74436.17	42686	74474	60
14	13	73959.2	42318	71366	60
15	14	70548.79	41444	38497	60
16	15	37167.0	21366	37173	62
17	16	37151.11	21361	37140	60
18	17	37471.14	21462	37501	60
19	18	37002.41	21337	37081	60
20	19	37503.12	21599	37407	60
21	20	37557.11	21681	37575	60
22	21	36166.1	20874	36473	60
23	22	76894.71	41141	76744	60
24	23	76757.37	41111	76745	60

SCHEDULE 1
 SCHEDULE 2
 SCHEDULE 3

12/23/91
 10/2/91

10/3/91

DATE 11/0000 DAILY TUBE E OCT 24 1991 00:00

DATE 1

199391

BL002

Doc No	TIME	BL00004	BL00006	BL00008	BL00002
1	0	56.58082	42.6275	0.7654633	2.3288E-01
2	1	56.73338	42.47933	0.7607291	2.6612E-02
3	2	56.82333	42.46458	0.6936497	2.0797E-02
4	3	56.62851	42.53609	0.7132708	1.0138E-02
5	4	56.59416	42.65621	0.7253581	2.2277E-02
6	5	56.5821	42.63994	0.7338585	1.4821E-02
7	6	56.51188	42.66239	0.7503795	2.7251E-02
8	7	56.55271	42.66384	0.737795	2.6476E-02
9	8	56.61573	42.58756	0.7641456	2.8195E-02
10	9	56.65389	42.56644	0.7536223	2.6821E-02
11	10	56.68442	42.54052	0.7344483	2.4348E-02
12	11	56.71337	42.54885	0.7140644	2.4346E-02
13	12	56.73617	42.57336	0.6916634	2.3245E-01
14	13	56.73083	42.58334	0.6611341	1.9777E-02
15	14	56.73806	42.64163	0.6507166	1.9332E-01
16	15	56.68761	42.61586	0.6371271	1.9405E-02
17	16	56.68056	42.6634	0.6246623	1.8573E-02
18	17	56.67894	42.67312	0.6239073	2.0511E-02
19	18	56.68837	42.76311	0.6176481	1.6549E-02
20	19	56.69221	42.77961	0.6463711	1.6797E-02
21	20	56.51763	42.74223	0.6669465	1.5675E-02
22	21	56.54699	42.73723	0.6691133	1.6506E-02
23	22	56.52374	42.73256	0.7151515	1.6088E-02
24	23	56.49979	42.73023	0.7423756	1.9988E-02

Doc No	TIME	BL00004	BL00006 / sec	BL00008	BL00002
1	2	0.9718261	574.831	165.9557	104.3172
2	3	0.9720354	576.0461	165.8777	102.5601
3	4	0.9696212	576.5665	165.2376	102.9751
4	5	0.9710561	574.9664	165.5683	103.2877
5	6	0.9716354	574.4374	165.3866	104.3211
6	7	0.9717136	574.5151	165.9351	104.1564
7	8	0.9718333	574.3897	165.8994	103.8234
8	9	0.9718583	574.2161	165.8862	104.6691
9	10	0.9711655	574.8954	166.7634	106.5896
10	11	0.9711655	574.8954	166.7634	104.4283


11 50% Run 1	11	0.970467	576.0777	167.1572	108.9534
12 50% Run 1	11	0.970467	576.0777	167.1572	110.9041
13 50% Run 1	12	0.970467	576.0777	167.1572	113.2996
14 50% Run 3	13	0.970466	576.0248	166.8638	117.4837
15 50% Run 1	14	0.9711732	576.5193	166.8636	120.8098
16 50% Run 1	15	0.9712541	576.5894	166.842	122.5763
17 50% Run 1	16	0.9713333	576.5305	166.9113	123.5517
18 50% Run 3	17	0.9713822	576.4282	166.9114	113.8216
19 100% Run 1	18	0.9718759	574.9868	166.3314	114.3531
20 100% Run 2	19	0.9721233	574.6035	166.3422	111.3725
21 100% Run 3	20	0.9722184	574.3921	166.385	108.1919
22	21	0.9722976	574.1609	166.1307	106.2109
23	22	0.9723691	573.9244	166.093	105.2714
24	23	0.9724597	573.6802	166.0575	104.575

REC NO	TIME	ROGSTER	BTU	SCF	RUNTIME
1	2	76824.75	44125	76802	60
2	3	76812.33	44144	76634	60
3	4	76424.38	44263	76487	60
4	5	76613.58	44071	76648	60
5	6	76572.77	43996	76562	60
6	7	76699.33	44042	76650	60
7	8	76701.67	44057	76712	60
8	9	76683.43	44033	76684	60
9	10	51029.34	31012	51543	60
10	11	51032.6	29355	51029	60
11 100% Run 1	10	46237.49	26595	46157	60
12 100% Run 2	11	46265.02	26632	46248	60
13	12	46234.87	26573	46341	60
14 50% Run 3	13	55842.91	31765	55121	60
15 75% Run 1	14	60786.43	34961	60743	60
16	15	60923.88	35075	60937	60
17 75% Run 2	16	61056.1	35145	61061	60
18 75% Run 3	17	60974.79	35130	60930	60
19 100% Run 1	18	73280.66	42893	73103	60
20 100% Run 2	19	73764.91	42968	73778	60
21 100% Run 3	20	73607.97	43271	73625	60
22	21	73442.46	43192	73523	60
23	22	76218.01	43735	76191	60
24	23	76464.22	43851	76450	60

SCFSCALE BTUSCALE L
 1 1000



APPENDIX C
LABORATORY PROCEDURES



APPENDIX C

LABORATORY PROCEDURES

1.0 TOTAL SULFUR IN FUEL ANALYSES

The fuel samples collected during the testing project were submitted to Atlantic Analytical Laboratory (AAL) in Whitehouse, New Jersey, for total sulfur analyses. Copies of the AAL reports can be found following this page.

A gas chromatograph (GC) equipped with a Hall detector was used to determine the total sulfur content of the samples.

Total sulfur concentrations were determined on a volume basis as hydrogen sulfide. Results of these analyses are presented in Table 4 of Section 4.0 of this report.

2.0 METAL ANALYSIS

Analysis of the metal samples was conducted in accordance with the PADER Heavy Metals Test Methodology.

A copy of the analytical procedures contained in this test method appear at the end of this Appendix. Laboratory results of the metal analyses are summarized in Table C-1 which can be found following the AAL reports. A complete copy of the metals laboratory report follows Table C-1.

3.0 SULFUR DIOXIDE ANALYSES

Samples from the SO₂ emission testing were submitted to Air Quality Services, Inc. located in Pittsburgh, Pennsylvania. Sample analyses were conducted in accordance with PADER methodology. Copies of these procedures are included in this Appendix following the metals analytical procedures.

A copy of Air Quality Services, Inc. report containing SO₂ analytical results follows the metals laboratory report.

ATLANTIC
ANALYTICAL
LABORATORY

Mr. Philip C. Burg
BCM Engineers
One Plymouth Meeting Mall
Plymouth Meeting, PA 19462

Report No. ATL-5444
Date Requested 10-01-91
Date Reported 10-04-91
P.O. No.

Material Submitted: One Gas Sample in a Tedlar Bag
Project 5743-19 Waste Management

Information Requested: Gas Chromatography Analysis

Notebooks: CK051, p42

Sample Identification: Turbine #2 Run 1 9/30/91 1700


Results of Analysis

Concentration by Volume

Total sulfur as H₂S

1.9

01004


Victor H. Given

[illegible]

Mr. Phillip C. Burg
BCM Engineers
One Plymouth Meeting Mall
Plymouth Meeting, PA 19062

Report No. DAL-5452
Date Requested 10-02-91
Date Reported 10-04-91
P.O. No.

Material Submitted: One Gas Sample in a Tedlar Bag
Project: 5743-19 BC34

Information Requested: Gas Chromatography Analysis

Notebooks: CRR51, p42

Results are reported on the following page.

61.004

Victor H. Glover.

Page 2 of 2

Sample Identification: Turbine #2 Outlet 10/1/91

Raw Data Analysis

Concentration Analysis

Total sulfur as H₂S 72

Total non-methane hydrocarbons as hexane * 2000

* Excludes C₂ and C₃ compounds, value is approximate.

The majority of constituents are heavier than C₈.

[illegible]

Mr. Phillip C. Burg
BCM Engineers
One Plymouth Meeting Mall
Plymouth Meeting, PA 19462

Report No. AAL-5468
Date Requested 10-03-91
Date Reported 10-04-91
P.O. No. 22222

Material Submitted: One Gas Sample in a Tedlar Bag
Project: 5743-19 BCM

Information Requested: Gas Chromatography Analysis

Noted on file: CR051, p50

Sample Identification: Turbine #2 Inlet 10/2/91

Personal Use and Distribution

CONFIDENTIALITY WARNING:

Total Available as H2S

43

CH₃COOH

Victor H. Glover



TABLE C-1
METALS LABORATORY RESULTS (mg)

Run No.	Metal	Impinger Catch (mg)	Filter Catch (mg)	Total Catch (mg)
1	As	<0.320	<0.037	<0.357
1	Be	<0.008	<0.001	<0.009
1	Cd	<0.008	<0.001	<0.009
1	Cr	<0.016	<0.002	<0.018
1	Hg [*]	0.0034	0.0002	0.0036
1	Ni	<0.064	<0.007	<0.071
1	Pb	<0.160	<0.018	<0.178
2	As	<0.308	<0.041	<0.349
2	Be	<0.008	<0.001	<0.009
2	Cd	<0.008	<0.001	<0.009
2	Cr	<0.015	<0.002	<0.017
2	Hg ^{**}	<0.0026	<0.0003	<0.0029
2	Ni	<0.062	<0.008	<0.0696
2	Pb	<0.154	<0.020	<0.174
3	As	<0.312	<0.042	<0.354
3	Be	<0.008	<0.001	<0.009
3	Cd	<0.008	<0.001	<0.009
3	Cr	<0.016	<0.002	<0.018
3	Hg ^{**}	<0.0026	<0.0003	<0.029
3	Ni	<0.062	<0.008	<0.070
3	Pb	<0.156	<0.021	<0.177
Blank	As	<0.304	<0.038	-----
Blank	Be	<0.008	<0.0009	-----
Blank	Cd	<0.008	<0.0009	-----
Blank	Cr	<0.015	<0.002	-----
Blank	Hg	0.0026	0.0003	-----
Blank	Ni	<0.061	<0.008	-----
Blank	Pb	<0.152	<0.019	-----

* Results blank corrected.

** Blank values were higher than sample results, blank results expressed as less than values were reported as sample results.



BCM Laboratory Division

1850 Gravers Road
Norristown, PA 19401
(215) 275-0281

ANAL REPORT

This is a final report.

The results have been checked and authorized for release.

PAGE 1

CLIENT

WASTE MANAGEMENT OF
ATTN: PHIL BURG
BCM MAIL

00-5743-19

Date : 10/22/91
BCM # : 00-5743-19
P.C.# :
Order# : 43433

BCM Sample # : 102564
Location : METALS RCN 1
Client ID : 1203

Date Sampled : 09/30/91
Date Received : 10/02/91
Sampler :

Test Description	Results	Units	Test Method
Arsenic by ICP by G. HARPEL on 10/15/91 Arsenic	< 0.320	mg	EPA # 6010
Beryllium by G. HARPEL on 10/15/91 Beryllium	< 0.008	mg	EPA # 200.7
Cadmium by G. HARPEL on 10/15/91 Cadmium	< 0.008	mg	EPA # 200.7
Chromium as Cr by G. HARPEL on 10/15/91 Chromium	< 0.015	mg	EPA # 200.7
Mercury by DIANE RYALLS on 10/16/91 Mercury	0.006	mg	EPA # 245.1
Mercury Digestion by DIANE RYALLS on 10/16/91 Mercury Digestion	10/16/91	M/D/Y	EPA # 245.1
Metal Digestion (No Charge) by DIANE RYALLS on 10/08/91 Metal Digestion	10/8/91	M/D/Y	EPA - METALS
Nickel by G. HARPEL on 10/15/91 Nickel	< 0.064	mg	EPA # 200.7
Lead by G. HARPEL on 10/15/91 Lead	< 0.160	mg	EPA # 200.7
Completion of Accelerated TAT Analysis by L. COX on 10/21/91 Date Quick Turn-Around Analyses Complete	10/21/91 P	M/D/Y	



BCM Laboratory Division

1850 Gravers Road
Norristown, PA 19401
(215) 275-0281

FINAL REPORT

This is a final report.
The results have been checked and authorized for release.

PAGE : 2

CLIENT

WASTE MANAGEMENT OF
ATTN: PHIL BURG
BCM MALL

00-5743-19

Date : 10/22/91
BCM # : 00-5743-19
P.O.# :
Order# : 43433

BCM Sample #: 132365
Location : METALS RUN 2
Client ID : H03

Date Sampled : 10/01/91
Date Received : 10/02/91
Sampler :

Test Description

Test Description	Results	Units	Test Method
Arsenic by ICP by G. HARPEL on 10/15/91			EPA # 6010
Arsenic	< 0.308	mg	
Beryllium by G. HARPEL on 10/15/91			EPA # 200.7
Beryllium	< 0.006	mg	
Cadmium by G. HARPEL on 10/15/91			EPA # 200.7
Cadmium	< 0.008	mg	
Chromium as Cr by G. HARPEL on 10/15/91			EPA # 200.7
Chromium	< 0.015	mg	
Mercury by DIANE RYALLS on 10/16/91			EPA # 245.1
Mercury	0.0019	mg	
Mercury Digestion by DIANE RYALLS on 10/16/91			EPA # 245.1
Mercury Digestion	10/16/91	ML/DY	
Metal Digestion (No Charge) by DIANE RYALLS on 10/08/91			EPA - METALS
Metal Digestion	10/8/91	ML/DY	
Nickel by G. HARPEL on 10/15/91			EPA # 200.7
Nickel	< 0.061	mg	
Lead by G. HARPEL on 10/15/91			EPA # 200.7
Lead	< 0.154	mg	



BCM Laboratory Division

1850 Gravers Road
Norristown, PA 19401
(215) 275-0281

FINAL REPORT

PAGE : 3

This is a final report.

The results have been checked and authorized for release.

CLIENT

WASTE MANAGEMENT OF
ATTN: PHIL BURG
BCM MALL

CO-5743-19

Date : 10/22/91
BCM # : 00-5743-19
P.O.# :
Order# : 43433

BCM Sample #: 132386
Location : METALS ROOM 3
Client ID : HM03

Date Sampled : 10/02/91
Date Received : 10/02/91
Sampler :

Test Description	Results	Units	Test Method
Arsenic by ICP by G. HARPEL on 10/15/91 Arsenic	< 0.312	mg	EPA # 6010
Beryllium by G. HARPEL on 10/15/91 Beryllium	< 0.008	mg	EPA # 200.7
Cadmium by G. HARPEL on 10/15/91 Cadmium	< 0.006	mg	EPA # 200.7
Chromium as Cr by G. HARPEL on 10/15/91 Chromium	< 0.016	mg	EPA # 200.7
Mercury by DIANE RYALLS on 10/16/91 Mercury	0.0012	mg	EPA # 245.1
Mercury Digestion by DIANE RYALLS on 10/16/91 Mercury Digestion	10/16/91	M/D/Y	EPA # 245.1
Metal Digestion (No Charge) by DIANE RYALLS on 10/08/91 Metal Digestion	10/8/91	M/D/Y	EPA - METALS
Nickel by G. HARPEL on 10/15/91 Nickel	< 0.062	mg	EPA # 200.7
Lead by G. HARPEL on 10/15/91 Lead	< 0.156	mg	EPA # 200.7



BCM Laboratory Division

1850 Gravers Road
Norristown, PA 19381
(215) 275-0881

FINAL REPORT

This is a final report.

The results have been checked and authorized for release.

PAGE : 4

CLIENT

WASTE MANAGEMENT OF
ATTN: PHIL BURG
BCM MAIL

00-5743-19

Date : 10/22/91
BCM # : 00-5743-19
P.O.# :
Order# : 43433

BCM Sample #: 132387
Location : METALS FIELD
Client ID : BLANK

Date Sampled : 10/02/91
Date Received : 10/02/91
Sampler :

Test Description	Results	Units	Test Method
Arsenic by ICP by G. HARPEL on 10/15/91 Arsenic	< 0.304	mg	EPA # 6010
Beryllium by G. HARPEL on 10/15/91 Beryllium	< 0.008	mg	EPA # 200.7
Cadmium by G. HARPEL on 10/15/91 Cadmium	< 0.008	mg	EPA # 200.7
Chromium as Cr by G. HARPEL on 10/15/91 Chromium	< 0.015	mg	EPA # 200.7
Mercury by DIANE RYALLS on 10/16/91 Mercury	0.0026	mg	EPA # 245.1
Mercury Digestion by DIANE RYALLS on 10/16/91 Mercury Digestion	10/16/91	M/D/Y	EPA # 245.1
Metal Digestion (No Charge) by DIANE RYALLS on 10/08/91 Metal Digestion	10/8/91	M/D/Y	EPA - METALS
Nickel by G. HARPEL on 10/15/91 Nickel	< 0.061	mg	EPA # 200.7
Lead by G. HARPEL on 10/15/91 Lead	< 0.152	mg	EPA # 200.7



BCM Laboratory Division
1850 Gravers Road
Norristown, PA 19381
(215) 275-0281

FINAL REPORT

This is a final report.
The results have been checked and authorized for release.

PAGE : 5

CLIENT

WASTE MANAGEMENT OF
ACTN: PHIL BURG
BCM HALL

00-5743-19

Date : 10/22/91
BCM # : 00-5743-19
P.O.# :
Order# : 43433

BCM Sample #: 132556
Location : FILTER RUN 1
Client ID :

Date Sampled : 10/02/91
Date Received : 10/02/91
Sampler : PB

Cont Description	Results	Units	Test Method
Arsenic by ICP by G. HARPEL on 10/15/91 Arsenic	< 0.0037	mg	EPA # 6010
Beryllium by G. HARPEL on 10/15/91 Beryllium	< 0.0009	mg	EPA # 200.7
Cadmium by G. HARPEL on 10/15/91 Cadmium	< 0.0008	mg	EPA # 200.7
Chromium as Cr by G. HARPEL on 10/15/91 Chromium	< 0.002	mg	EPA # 200.7
Mercury by DIANE RYALLS on 10/18/91 Mercury	0.0005	mg	EPA # 7471
Mercury Digestion by DIANE RYALLS on 10/18/91 Mercury Digestion	10/18/91	M/D/Y	EPA # 245.1
Metal Digestion (No Charge) by DIANE RYALLS on 10/08/91 Metal Digestion	10/8/91	M/D/Y	EPA - METALS
Nickel by G. HARPEL on 10/15/91 Nickel	< 0.007	mg	EPA # 200.7
Lead by G. HARPEL on 10/15/91 Lead	< 0.018	mg	EPA # 200.7



BCM Laboratory Division

1850 Gravers Road
Norristown, PA 19401
(215) 275-0281

FINAL REPORT

This is a final report.

The results have been checked and authorized for release.

PAGE : 5

CLIENT

WASTE MANAGEMENT OF
ATTN: PHIL BURG
BCM MALL

CO-5743-19

Date : 10/22/91
BCM # : 00-5743-19
P.O.# :
Order# : 43433

BCM Sample #: 132567
Location : FILTER RUN 2
Client ID :

Date Sampled : 10/02/91
Date Received : 10/02/91
Sampler : PB

Test Description	Results	Units	Test Method
Arsenic by ICP by G. HARPEL on 10/15/91 Arsenic	< 0.041	mg	EPA # 6010
Beryllium by G. HARPEL on 10/15/91 Beryllium	< 0.001	mg	EPA # 200.7
Cadmium by G. HARPEL on 10/15/91 Cadmium	< 0.001	mg	EPA # 200.7
Chromium as Cr by G. HARPEL on 10/15/91 Chromium	< 0.002	mg	EPA # 200.7
Mercury by DIANE RYALLS on 10/18/91 Mercury	< 0.0001	mg	EPA # 7471
Mercury Digestion by DIANE RYALLS on 10/18/91 Mercury Digestion	10/18/91	M/D/Y	EPA # 245.1
Metal Digestion (No Charge) by DIANE RYALLS on 10/08/91 Metal Digestion	10/8/91	M/D/Y	EPA - METALS
Nickel by G. HARPEL on 10/15/91 Nickel	< 0.003	mg	EPA # 200.7
Lead by G. HARPEL on 10/15/91 Lead	< 0.020	mg	EPA # 200.7



BCM Laboratory Division

1850 Graven Road
Norristown, PA 19401
(215) 275-0281

FINAL REPORT

PAGE : 7

This is a final report.

The results have been checked and authorized for release.

CLIENT

WASTE MANAGEMENT OF
ATTN: PHIL BURG
BCM MALL

00-5743-19

Date : 10/22/91
BCM # : 00-5743-19
P.O.# :
Order# : 43433

BCM Sample #: 132568
Location : FILTER RUN 5
Client ID :

Date Sampled : 10/02/91
Date Received : 10/02/91
Sampler : PB

Test Description	Results	Units	Test Method
Arsenic by ICP by G. HARPEL on 10/15/91			EPA # 6010
Arsenic	< 0.042	mg	
Beryllium by G. HARPEL on 10/15/91			EPA # 200.7
Beryllium	< 0.001	mg	
Cadmium by G. HARPEL on 10/15/91			EPA # 200.7
Cadmium	< 0.001	mg	
Chromium as Cr by G. HARPEL on 10/15/91			EPA # 200.7
Chromium	< 0.002	mg	
Mercury by DEANE RYALLS on 10/18/91			EPA # 1631
Mercury	0.0001	mg	
Mercury Digestion by DEANE RYALLS on 10/18/91			EPA # 245.1
Mercury Digestion	10/18/91	N/D/Y	
Metal Digestion (No Charge) by DEANE RYALLS on 10/08/91			EPA - METALS
Metal Digestion	10/8/91	N/D/Y	
Nickel by G. HARPEL on 10/15/91			EPA # 200.7
Nickel	< 0.005	mg	
Lead by G. HARPEL on 10/15/91			EPA # 200.7
Lead	< 0.021	mg	



BCM Laboratory Division

1850 Gravers Road
Norristown, PA 19001
(215) 275-0281

FINAL REPORT

This is a final report.

The results have been checked and authorized for release.

PAGE : 8

CLIENT

WASTE MANAGEMENT OF
ATTN: PHIL BURG
BCM MALL

00-5743-19

Date : 10/22/91
BCM # : 00-5743-19
P.O. # :
Order# : 43435

BCM Sample #: 132569

Location : FILTER BLANK

Client ID :

Date Sampled : 10/02/91

Date Received : 10/02/91

Sampler : PB

Test Description	Results	Units	Test Method
Arsenic by ICP by G. HARPEL on 10/15/91 Arsenic	< 0.038	mg	EPA # 6010
Beryllium by G. HARPEL on 10/15/91 Beryllium	< 0.0009	mg	EPA # 200.7
Cadmium by G. HARPEL on 10/15/91 Cadmium	< 0.0009	mg	EPA # 200.7
Chromium as Cr by G. HARPEL on 10/15/91 Chromium	< 0.001	mg	EPA # 200.7
Mercury by DIANE RYALLS on 10/18/91 Mercury	0.0001	mg	EPA # 7471
Mercury Digestion by DIANE RYALLS on 10/18/91 Mercury Digestion	10/18/91	MOD/1	EPA # 245.1
Metal Digestion (No Charge) by DIANE RYALLS on 10/08/91 Metal Digestion	10/8/91	M/D/1	EPA # METALS
Nickel by G. HARPEL on 10/15/91 Nickel	< 0.008	mg	EPA # 200.7
Lead by G. HARPEL on 10/15/91 Lead	< 0.019	mg	EPA # 200.7



BCM Laboratory Division

1850 Grays Road
Norristown, PA 19301
(215) 275-0281

FINAL REPORT

PAGE : 9

This is a final report.
The results have been checked and authorized for release.

CLIENT

WASTE MANAGEMENT OF
ATTN: PHIL BURG
BCM MALL

Date : 10/22/91
BCM # : 00-5743-19
P.O.# :
Order# : 43433

00-5743-19


BCM Sample #: 132569
Location : FILTER BLANK
Client ID :

Date Sampled : 10/02/91
Date Received : 10/02/91
Sampler : PB

Test Description

Results	Units	Test Method
---------	-------	-------------

Certified by :


End of Report

BCM Laboratory Director

Lab Certifications:

PA - 66-007

NJ - 77175

MA

AL - 40300

ME - 136

VA - 00023

SC - 89005

WV

DE

RI

NYDOE - 11136

ATHA - 19491

AIR QUALITY SERVICES, INC.

4527 Clairton Boulevard
Pittsburgh, PA 15236
(412) 881-5630




TABLE II
ANALYSIS OF SODIUM HYDROXIDE SAMPLES FOR SO₂ PER DER METHOD
BCM ENGINEERS
ONE PLYMOUTH MEETING MALL
PLYMOUTH MEETING, PENNSYLVANIA 19462
PURCHASE ORDER #32241
SAMPLES RECEIVED: OCTOBER 3, 1991

BCM SAMPLE IDENTIFICATION	AQS LABORATORY NUMBER	SAMPLE VOLUME MILLILITERS	TOTAL SO ₂ MILLIGRAMS
RUN #1 IMPINGERS 2-3	59755	390	9.10
RUN #1 IMPINGER 4	59756	135	0.41
RUN #2 IMPINGERS 2-3	59757	435	5.13
RUN #2 IMPINGER 4	59758	165	0.27
RUN #3 IMPINGERS 2-3	59759	384	12.97
RUN #3 IMPINGER 4	59760	137	0.49
SODIUM HYDROXIDE BLANK	59761	196	ALREADY SUBTRACTED


SAMPLES WERE ANALYZED AND CALCULATED ACCORDING TO THE DER METHOD.
THE SAMPLES HAVE BEEN CORRECTED FOR THE BLANK.


John J. Gellera
AIR QUALITY SERVICES, INC.

JOB 3097



APPENDIX D
CALCULATIONS





APPENDIX D

CALCULATIONS

1.0 OXIDES OF NITROGEN EMISSION CALCULATIONS

Emission concentrations of NO_x at 15 percent oxygen and at ISO conditions were calculated in accordance with EPA Method 20 and according to New Source Performance Standards (NSPS) Subpart GG - Standards of Performance for Stationary Gas Turbines as described in the following sections. Table D-1, which appears at the end of this Appendix, contains the average measured NO_x and O_2 concentrations, all results of the NO_x emission calculations, and all ambient test condition data and turbine operating data used to calculate the results.

1.1 Oxides of Nitrogen at 15 Percent Oxygen

The NO_x pollutant concentrations were corrected to 15 percent oxygen (O_2) according to equation 20-4 of EPA Method 20. This equation appears in Method 20 as follows:

$$C_{adj} = C_d \frac{5.9}{20.9 - \%O_2}$$

Where:


C_{adj} = Pollutant concentration corrected to 15 percent O_2 , ppm.
 C_d = Pollutant concentration measured, dry basis, ppm.
 $\%O_2$ = Measured O_2 concentration dry basis, percent.

The measured NO_x concentration (C_d) and the measured O_2 concentration ($\%O_2$) for each test run were obtained by averaging the individual measurements obtained at each traverse point. This data, as well as the NO_x concentrations corrected to 15 percent O_2 , are contained in Table D-1 of this Appendix.

1.2 Oxides of Nitrogen Emission at ISO Conditions

The NO_x emission concentration at ISO standard conditions (ppmv) for each test run was calculated according to 60.334(c)(1) of NSPS Subpart GG. This paragraph lists the following equation:

$$\text{NO}_x = (\text{NO}_{x0}) (P_r/P_0)^{0.5} (e)^{19CB_0 - 0.00633} (288^\circ\text{K}/T_a)^{1.53}$$



Where:

NO_x = Emission rate of NO_x at 15 percent O_2 and ISO standard ambient conditions, ppm by volume.

NO_{xO} = Observed NO_x concentration at 15 percent O_2 , ppm by volume.

P_r = Reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg.

P_O = Observed combustor inlet absolute pressure at test, mm Hg.

H_O = Observed humidity of ambient air, g H_2O /g air.

e = Transcendental constant, 2.718.

T_a = Ambient temperature, °K.

Table D-1, presented at the end of this Appendix, contains all ambient test condition data (observed combustor inlet pressures, and the observed NO_x concentrations (ppmv at 15 percent O_2) used to calculate the NO_x concentrations at ISO conditions.

1.2.1 Combustor Inlet Pressure

The reference combustor inlet absolute pressure (P_r) at standard atmospheric pressure (101.3 kilopascals) was determined from the manufacturer to be 141.7 psi (7326 mm Hg) at 100 percent load.

The observed combustor inlet absolute pressure at test (P_O) expressed as psia was calculated as follows:

$$P_O = \text{psig} + (P_{\text{bar}}/760)(14.70)$$

Where:

P_O = observed combustor inlet absolute pressure (psia)

psig = recorded combustor inlet pressure

P_{bar} = Barometric pressure, mm Hg

760 = mm Hg/atmosphere

14.70 = psi/atmosphere

P_O expressed as mm Hg was then calculated as follows:

$$P_O = (\text{psia}/14.70)(760)$$



Where:

P_0 = observed combustor inlet absolute pressure (mm Hg)
14.70 = psi/atmosphere
760 = mm Hg/atmosphere

1.2.2 Observed Humidity

The observed humidity (H_0) of the ambient air during each test run was calculated according to the following equation:

$$H_0 = (ZRH/100)(H_{sat})$$

Where:

H_0 = Observed humidity, g water/g dry air
ZRH = Relative humidity, percent
 H_{sat} = Saturation humidity, g water/g dry air

The relative humidity was determined by wet bulb/dry bulb measurements taken during each test run. The saturation humidity was determined from a psychrometric table utilizing the ambient temperature and barometric pressure. A copy of the psychrometric table used can be found following Table D-1.

2.0 METALS AND SO_2 EMISSION CALCULATIONS

Metals and SO_2 emissions were calculated according to equations contained in EPA Methods 2, 3, 4, and 5 of 40 CFR 60, Appendix 1. These equations were programmed into a personal computer to facilitate the calculation of the test program results. The equations can be found following the psychrometric table.

Complete results of the computer analyses are presented on the computer output sheets which follow the equations. Also contained on the sheets are all input data used to calculate the results.

2.1 BCM Computation Sheets

The conversion of ppmv total sulfur content of the fuel expressed as H_2S to percent by weight sulfur was carried out by hand. This calculation is described on the BCM Computation Sheets that follow the computer output sheets.

TABLE 9-1

NOX EMISSIONS CORRECTED TO 15-PERCENT O₂
AND ISO STANDARD AMBIENT CONDITION

Run No.	Turbine Load (%)	Compressor		Ambient Temperature		Barometric Pressure		Relative Humidity (%)	Saturation Humidity g H ₂ O/g dry H ₂ O	Observed Humidity g H ₂ O/g dry H ₂ O	NO _x observed		NO _x corrected to 15% O ₂ (ppm)	ISO condition (ppm)
		Inlet Pressure (psia)	Outlet Pressure (psia)	(°C)	(°F)	(in Hg)	(mm Hg)				at 15% O ₂	at 15% O ₂ and 60°C		
1	100	124.7	139.37	68	205.0	29.28	788.48	74	0.01470	0.01088	19.1	16.7	22.9	28.7
2	100	124.5	139.22	67	202.4	29.06	781.82	68	0.01449	0.00937	18.8	16.9	27.7	29.6
3	100	125.6	139.72	64	206.8	29.08	781.82	68	0.01278	0.00880	19.2	16.8	27.6	28.7
4	75	119.5	133.01	78	207.4	29.04	789.31	48	0.01941	0.00332	18.2	17.8	28.8	33.3
5	75	117.8	132.49	76	207.4	29.08	789.49	42	0.01624	0.00515	19.5	17.8	33.1	37.7
6	75	118.6	132.67	72	205.0	29.06	788.48	74	0.01701	0.01388	17.2	17.9	32.7	36.9
7	50	118.6	132.72	75	205.0	29.18	784.57	78	0.01791	0.01331	16.5	18.4	33.7	38.8
8	50	119.6	134.78	71	204.7	29.06	783.88	84	0.01633	0.01018	18.5	19.9	38.3	43.9
9	50	119.6	134.74	71	204.7	29.08	782.85	82	0.01823	0.00849	18.9	18.2	32.8	37.1
10	25	124.0	136.79	82	209.2	29.08	781.82	88	0.01187	0.00418	17.4	19.9	28.8	33.3
11	25	124.0	136.75	83	207.2	29.02	782.54	42	0.01180	0.00417	9.6	18.8	27.9	33.3
12	25	124.0	136.79	78	207.4	29.10	782.57	82	0.01041	0.01038	9.7	18.6	26.9	32.9

THE

[illegible]

ENGINEERING FOR PARTICULATE MASS, MOISTURE, AND FLOW CALCULATIONS
(BASED ON STANDARD CONDITIONS OF 68°F AND 29.92"Hg)

1. $V_m(\text{std}) = 0.0471 V_{wc}$
2. $V_m(\text{std}) = 17.64 V_m \frac{P_{\text{bar}} + .07355 \Delta H}{T_m - 460} \left(\frac{1}{P} \right)^{1.4}$
3. $B_{wc} = \frac{V_w(\text{std})}{V_m(\text{std}) + V_w(\text{std})}$
4. $M_d = 0.44(\text{HCO}_2) + 0.28(\text{HCO}) + 0.32(\text{HCO}_2) + 0.28(\text{HNO}_2)$
5. $M_g = M_d (1 - B_{wc}) + 1.8 B_{wc}$
6. $EB = \frac{(HCO_2) + 0.5(HCO)}{0.364(HNO_2) + (HCO_2) + 0.5(HCO)} \cdot 100$
7. $V_g = (85.49)(60)(C_p) \sqrt{\Delta P} \sqrt{\frac{T_g + 460}{(P_g)(M_g)}}$
8. $Q_m = \frac{(V_g)(M_g)}{1.44}$
9. $Q_m(\text{std}) = Q_m (1 - B_{wc}) \cdot 17.64 \frac{P}{T_g + 460}$
10. $C'_s = 0.0154 \frac{W_t}{V_m(\text{std})}$
11. $C'_w = 0.0154 \frac{W_t}{V_m(\text{std}) + V_w(\text{std})}$
12. $C''_c = \frac{1.2 C'_s}{\text{HCO}_2}$
13. $C'_B = W_w \frac{(T_g + 460)(29.92)}{(528)(P_g)}$
14. $B = 0.00857 Q_s(\text{std}) C'_s$
15. $A_m = \frac{(TT)(P_g)^2}{(1.44)(T_g)}$
16. $I = \frac{(60)(1.667)(T_g + 460)(0.00857 V_{wc} + V_m(\text{std})/17.64)}{(6)(V_g)(P_g)(M_g)}$

LEGEND

A_n	=	Area of nozzle, ft^2
A_s	=	Area of stack, in^2
B_{wc}	=	Moisture content of gas stream, dimensionless
C_p	=	Pitot correction factor, dimensionless
C'_a	=	Particulate concentration (stack conditions), gr/ft^3
C'_c	=	Particulate concentration at 12% CO_2 (dry), gr/dscf
C'_s	=	Particulate concentration (dry), gr/dscf
C'_w	=	Particulate concentration (wet), gr/scf
D_n	=	Diameter of nozzle, in.
E	=	Particulate emission rate, lb/hr
EA	=	Excess air, percent
ΔE	=	Orifice pressure drop, in. H_2O
I	=	Isokinetic ratio, percent
M_d	=	Dry molecular weight of stack gas, $\text{lb}/\text{lb-mole}$
M_s	=	Molecular weight of stack gas, $\text{lb}/\text{lb-mole}$
P_{bar}	=	Barometric pressure, in. Hg
P_s	=	Stack pressure (absolute), in. Hg
$\sqrt{\Delta P}$	=	Average of square roots of pitot pressure differential, in. H_2O
Q_s	=	Stack gas flow, acfm
$Q_{s(\text{std})}$	=	Stack gas flow, scfm
T_m	=	Average dry gas meter temperature, $^{\circ}\text{F}$
T_s	=	Average stack temperature, $^{\circ}\text{F}$
V_m	=	Dry sample volume (meter conditions), ft^3
$V_{m(\text{std})}$	=	Dry sample volume (standard conditions), ft^3

V_s	=	Stack velocity, ft/min
V_{wc}	=	Volume of liquid collected in impingers and silica gel, ml
$V_{w(std)}$	=	Volume of liquid collected, ft ³
W_t	=	Total weight of particulates collected, mg
θ	=	Duration of test, min.

Metal Emission Determination

Project Summary

BCM Project #	8743-10
Plant	Waste Management
Location	Turbine No. 2
Test Date	9/30/91
Run Number	One
Operator	PCB/TCB

ORSAF

Barometric Pressure:	30.42 " Hg			Duct Diameter	48.0 inches
		CO ₂ :	3.8 %	Duct Width	0.0 inches
Stack Pressure:	-0.05 " H ₂ O	CO:	10.1 %	Duct Length	0.0 inches
Stack Pressure:	30.35 " Hg	CO:	0.0 %	Duct Area	13.57 sq.ft.
Water Pickup				Flue Factor	0.04
oil/gal	18.4 grams	N ₂ :	80.1 %	Motor Elec. P	480
imp/gal	48 ml			Motor Elec. Factor	0.005
				Nozzle In. Dia.	0.160 inches
Scat. Thro	18.30			Nozzle Area	1.07E-04 sq.ft.
Orifice	100 (psi)			Isokinetic Ratio	105.43

Average Stack Temp	736 °F
Average Gas Motor Temperature	165 °F
Avg Square Root of Velocity/Pressure	1.513 inches water
Critical Pressure Drop	1.513 inches water

Sample Volume	71.548 GSCF
Sample Volume, corrected to standard conditions (dry)	67.060 GSCF

Molecular Weight of Stack Gas (dry)	28.25 lb/lb-mole
Molecular Weight of Stack Gas (wet)	28.77 lb/lb-mole

Stack Gas Velocity	7620 ft/min
Stack Gas Flow Rate	88880 ACFM
Stack Gas Flow Rate, standard conditions (dry)	41088 DSCFM
Stack Gas Flow Rate, standard conditions (wet)	43528 SCFM

Volume of Moisture Collected	3.033 SCF
Moisture Collected	Calculated: 4.28 %
	Standard: 10.0 %

Mass of Ar Collected	0.357 mg
Emission Concentration of Ar	8.10E-05 gr/dscf
Mass Emission Rate of Ar	2.85E-02 lb/hr

Mass of Ba collected	0.000 mg
Emission Concentration of Ba	2.04E-05 gr/dscf
Mass Emission Rate of Ba	7.16E-04 lb/hr

Mass of Cd collected	0.000 mg
Emission Concentration of Cd	2.04E-05 gr/dscf
Mass Emission Rate of Cd	7.16E-04 lb/hr

Model Emission Concentration

Fluegas Summary

BCOM Project #	5743-10
Plant	Waste Management
Location	Tulsa, Ok, 2
Test Date	9/30/80
Run Number	000
Operator	PCB/PCB

Mass of Cr collected	0.018 mg
Emission Concentration of Cr	4.00E-03 gr/dscf
Mass Emission Rate of Cr	1.44E-03 lb/hr
Mass of Hg collected	0.0030 mg
Emission Concentration of Hg	8.17E-02 gr/dscf
Mass Emission Rate of Hg	2.88E-04 lb/hr
Mass of Ni collected	0.021 mg
Emission Concentration of Ni	1.01E-03 gr/dscf
Mass Emission Rate of Ni	5.07E-03 lb/hr
Mass of Pb collected	0.173 mg
Emission Concentration of Pb	4.00E-03 gr/dscf
Mass Emission Rate of Pb	1.42E-03 lb/hr

Model Emission Determination

Facility Summary

BCMI Project #	5743-98
Plant	Winn-Dixie Supermarket
Location	Turkey No. 2
Test Date	10/1/91
Run Number	Two
Operator	PCB/JCB

ORSAT:

Barometric Pressure:	30.12 " Hg				Duct Diameter	43.0 Inches
Static Pressure:	-0.05 " H ₂ O	CO:	3.7 %		Duct Width	0.0 Inches
Stack Pressure:	30.08 " Hg	CE:	16.1 %		Duct Length	0.0 Inches
Water Pileup		CO:	0.0 %		Duct Area	12.57 sq.ft.
Wet gas:	17 grams	NO:	0.0 %		Flue Factor	0.94
Dry gas:	05 cal				Moisture Factor	4.20
Start Time	10:40				Moisture in Flue	0.150 Inches
Duration	100 (min)				Moisture Area	1.07E+04 sq.ft.
					Isobaric Ratio	1.0E+07

Average Stack Temp	734 °F
Average Gas Water Temperature	88 °F
Avg Square Foot of Velocity Pressure	1.644 Inches water
Grille Pressure Drop	1.438 Inches water

Sample Volume	87.740 DSCF
Sample Volume, corrected to standard conditions (dry)	84.437 DSCF

Molecular Weight of Stack Gas (dry)	28.24 lb/lb-mole
Molecular Weight of Stack Gas (wet)	28.80 lb/lb-mole

Stack Gas Velocity	7323 ft/min
Stack Gas Flow Rate	82027 ACFM
Stack Gas Flow Rate, standard conditions (dry)	80652 DSCFM
Stack Gas Flow Rate, standard conditions (wet)	80650 SCFM

Volume of Moisture Collected	3.651 SCF
Moisture Content	Calculated: 4.00 %
	Assumed: 4.00 %

Mass of Ar Collected	0.345 mg
Endmole Concentration of Ar	8.34E-05 g/gmol
Mass Endmole Rate of Ar	2.76E-02 lb/hr

Mass of He Collected	0.000 mg
Endmole Concentration of He	2.10E-05 g/gmol
Mass Endmole Rate of He	7.13E-04 lb/hr

Model Emission Determination

Process Summary

BCMO Project #	6743-16
Plant	Waste Management
Location	Trabuco Ncs. 2
Test Date	10/1/01
Plan Number	Two
Operator	PCB/101

Mass of Cd collected	0.000 mg
Emission Concentration of Cd	2.15E-08 g/dscf
Mass Emission Rate of Cd	7.13E-04 lb/hr
Mass of Cr collected	0.017 mg
Emission Concentration of Cr	4.08E-08 g/dscf
Mass Emission Rate of Cr	1.36E-03 lb/hr
Mass of Hg collected	0.0039 mg
Emission Concentration of Hg	6.83E-07 g/dscf
Mass Emission Rate of Hg	2.30E-04 lb/hr
Mass of Ni collected	0.0008 mg
Emission Concentration of Ni	1.66E-08 g/dscf
Mass Emission Rate of Ni	5.51E-03 lb/hr
Mass of Pb collected	0.174 mg
Emission Concentration of Pb	4.18E-05 g/dscf
Mass Emission Rate of Pb	1.38E-02 lb/hr

Mobile Emission Determination

Analysis Summary

BCMA Project #	5743-10
Plant	Wabco Wheelgummed
Location	Turbine No. 2
Test Date	10/2/94
Run Number	Three
Operator	PCB/TCB

CFE/ATE

Exhaustive Procedure:	30.20	1	Eq	CO2	3.6	%	Duct Diameter	43.0	inches
Static Pressure:	-0.03	1	inches	CO	10.3	%	Duct Width	0.0	inches
Stack Pressure:	30.22	1	Eq	CO	0.0	%	Duct Length	0.0	inches
Water Pickup				CO	0.0	%	Duct Area	12.57	sq.ft.
offical gals:	16.5	gpm		NO	80.4	%	Flat Factor	0.84	
Impingement:	43	in					Motor Box #	420	
Start Time	00:22						Motor Box Factor	0.695	
Duration	100	min					Nozzle In. Clam.	0.150	inches
							Nozzle Area	1.87E-04	sq.ft.
							Isokinetic Ratio	100.43	

Average Stack Temp	741	°F
Average Gas Motor Temperature	40	°F
Avg Square Root of Velocity Pressure	1.410	inches water
Orifice Pressure Drop	1.350	inches water

Sample Volume	88.740	CCCF
Sample Volume, corrected to standard conditions (dry)	84.551	CCCF

Molecular Weight of Stack Gas (dry)	28.23	lb/lb-mole
Molecular Weight of Stack Gas (wet)	28.61	lb/lb-mole

Stack Gas Velocity	7150	ft/min
Stack Gas Flow Rate	60362	ACCFM
Stack Gas Flow Rate, standard conditions (dry)	32603	SCCFM
Stack Gas Flow Rate, standard conditions (wet)	40107	SCCFM

Volume of Molasses Collected	3.743	SCF
Molasses Content	0.00	%
Saturated:	0.00	%

Mass of Ar Collected	0.384	mg
Emission Concentration of Ar	8.47E-05	gr/dscf
Mass Emission Rate of Ar	2.79E-02	lb/hr

Mass of Be Collected	0.000	mg
Emission Concentration of Be	2.18E-05	gr/dscf
Mass Emission Rate of Be	7.00E-04	lb/hr

Waste Emission Characterization

Facility Summary

BCHM Project #	B743-19
Plant	Waste Management
Location	Tarboro, N.C. 2
Test Date	10/02/81
Run Number	Three
Operator	PCB/KB

Mass of Cd collected	0.006 mg
Emission Concentration of Cd	2.19E-03 gr/dscf
Mass Emission Rate of Cd	7.00E-04 lb/hr
Mass of Cr collected	0.010 mg
Emission Concentration of Cr	4.31E-03 gr/dscf
Mass Emission Rate of Cr	1.40E-03 lb/hr
Mass of Hg collected	0.0086 mg
Emission Concentration of Hg	6.64E-03 gr/dscf
Mass Emission Rate of Hg	2.29E-04 lb/hr
Mass of Ni collected	0.070 mg
Emission Concentration of Ni	1.07E-05 gr/dscf
Mass Emission Rate of Ni	6.44E-03 lb/hr
Mass of Pb collected	0.177 mg
Emission Concentration of Pb	4.34E-05 gr/dscf
Mass Emission Rate of Pb	1.38E-02 lb/hr

Butter Cooled Evaporator Demonstration

Analysis Summary

BCDA Project # 8703-10
 Plant Waste Management
 Location Turbine No. 2
 Test Date 6/30/84
 Run Number 050
 Operator PCBY/BB

CRS/AT:

Evaporator Pressure:	30.42 " Hg	CO ₂ :	9.8 %	Duct Diameter:	48.0 inches
Stack Pressure:	-0.00 " Hg	CO:	10.1 %	Duct Width:	0.0 inches
Stack Pressure:	30.40 " Hg	CO:	0.0 %	Duct Length:	0.0 inches
Water Pickup:		N ₂ :	80.1 %	Duct Area:	18.37 sq.ft.
oil/gal:	18.4 gpm			Flare Factor:	0.04
Impinger:	40 ml			Motor Box #:	72
				Motor Box Factor:	1.000
Start Time:	18:30			Nozzle In. diam.	0.150 inches
Duration:	130 (min)			Nozzle Area:	1.87E-04 sq.ft.

Average Stack Temp:	738 °F
Average Gas Motor Temperature:	107 °F
Avg Square Root of Velocity Pressure:	1.353 inches water
Orifice Pressure Drop:	1.00 inches water

Sample Volume:	24.763 DSCF
Sample Volume, corrected to standard conditions (dry):	22.454 DSCF

Molecular Weight of Stack Gas (dry):	35.28 lb/lb-mole
Molecular Weight of Stack Gas (wet):	35.77 lb/lb-mole

Stack Gas Velocity:	7520 ft/min
Stack Gas Flow Rate:	85884 ACFM
Stack Gas Flow Rate, standard conditions (dry):	41000 DSCFM
Stack Gas Flow Rate, standard conditions (wet):	42523 SCFM

Volume of Molasses Collected:	3.093 SCF
Moisture Content:	Calculated: 4.28 %
	Subtracted: 100 %

Mass of SO ₂ Collected:	8.51 mg
Evaporator Concentration of SO ₂ :	1.74 ppmv
Mass Evaporator Rate of SO ₂ :	0.7117 lb/hr

Soil Gas Emission Concentration

Results Summary

BCM Project # 8743-16
 Plant Waste Management
 Location Trench No. 2
 Test Date 10/1/01
 Run Number Two
 Operator PCB/KB

CRISAT:

Barometric Pressure:	30.12 " Hg	CO2:	3.0 %	Coat Diameter	48.0 Inches
Soil Pressure:	-0.85 " Hg	CO:	18.1 %	Coat Width	0.0 Inches
Stack Pressure:	30.00 " Hg	CH4:	0.0 %	Coat Length	0.0 Inches
Water Pickup				Coat Area	12.57 sq.ft.
suction gals:	17 gpm			Moist Factor	0.04
temp/gals:	85 °F	HC:	86.1 %	Moist Rec. F	02
				Moist Rec Factor	1.000
				Nozzle In. Dia.	0.160 Inches
				Nozzle Area	1.67E-04 sq.ft.
Start Time	10:40				
Duration	100 (min)				

Average Stack Temp	731 °F
Average Gas Water Temperature	80 °F
Avg Square Foot Velocity Pressure	1.444 Inches water
Orifice Pressure Drop	1.000 Inches water

Sample Volume	71.002 DSCF
Sample Volume, corrected to standard conditions (dry)	70.167 DSCF

Molecular Weight of Stack Gas (dry)	28.25 lb/lb-mole
Molecular Weight of Stack Gas (wet)	28.62 lb/lb-mole

Stack Gas Velocity	7323 ft/min
Stack Gas Flow Rate	83027 ACFM
Stack Gas Flow Rate, standard conditions (dry)	38852 DSCFM
Stack Gas Flow Rate, standard conditions (wet)	40080 SCFM

Volume of Methane Collected	3.081 SCF
Methane Content	Calculated: 5.98 %
	Substant: 0.4 %

Mass of SO2 collected	8.40 mg
Emission Concentration of SO2	1.02 ppmv
Mass Emission Rate of SO2	0.3628 lb/hr

Stack Gas Emission Determination

Facility Summary

BCMI Project #	8743-10
Plant	Waste Management
Location	Turbine No. 2
Test Date	10/2/81
Run Number	Three
Operator	PCB/BB

ORISAT

Stack Gas Pressure:	30.32 " Hg	CO ₂	3.6 %	Duct Diameter	48.0 inches
Stack Pressure:	-0.03 " Hg	CO	10.3 %	Duct Width	0.0 inches
Stack Pressure:	30.32 " Hg	CO	0.0 %	Duct Length	0.0 inches
Water Pickup				Duct Area	18.37 sq.ft.
Water Pickup				Flue Factor	0.80
Water Pickup				Motor Box #	42
Water Pickup				Motor Box Factor	1.000
Water Pickup				Moisture in Flue	0.150 inches
Water Pickup				Moisture Area	1.875-00 sq.ft.
Stack Mass	00.32				
Duration	100 (min)				

Average Stack Temp	741 °F
Average Gas Motor Temperature	88 °F
Avg Square Root of Velocity Pressure	1.478 inches water
Critical Pressure Drop	1.500 inches water

Sample Volume	25.123 DSCF
Sample Volume, corrected to standard conditions (dry)	24.000 DSCF

Molecular Weight of Stack Gas (dry)	28.83 lb/lb-mole
Molecular Weight of Stack Gas (wet)	28.81 lb/lb-mole

Stack Gas Velocity	71.81 ft/min
Stack Gas Flow Rate	8000 DSCFM
Stack Gas Flow Rate, standard conditions (dry)	3700 DSCFM
Stack Gas Flow Rate, standard conditions (wet)	401.07 DSCFM

Volume of Moisture Collected	3.743 DSCF
Moisture Content	Calculated: 5.50 %
	Measured: 10.4 %

Mass of SO ₂ collected	13.40 mg
Emission Concentration of SO ₂	3.40 ppmv
Mass Emission Rate of SO ₂	0.0000 lb/hr



COMPUTATION SHEET

Name of Client Waste ManagementProject Leachate No. 2Description Molecular weight of Landfill Gas

Sheet Number	1	of	2
Date			
Job Number			
Computed by	Checked by		

$$MW_{\text{of Landfill Gas}} = \left(\text{Vol. fraction}_{\text{CH}_4} \right) \left(\frac{MW}{\text{CH}_4} \right) + \left(\text{Vol. fraction}_{\text{CO}_2} \right) \left(\frac{MW}{\text{CO}_2} \right) + \left(\text{Vol. fraction}_{\text{N}_2} \right) \left(\frac{MW}{\text{N}_2} \right)$$

where: MW = molecular weight

$$\text{Vol. fraction CH}_4 = 0.565$$

$$MW \text{ CH}_4 = 16.04 \text{ lb/mole}$$

$$\text{Vol. fraction CO}_2 = 0.423$$

$$MW \text{ CO}_2 = 44.01 \text{ lb/mole}$$

$$\text{Vol. fraction N}_2 = 0.012$$

$$MW \text{ N}_2 = 14.01 \text{ lb/mole}$$

$$MW_{\text{Landfill Gas}} = 27.85 \text{ lb/mole}$$



COMPUTATION SHEET

Name of Client Waste Management
Project Trachlet No. 2
Description 2a by wt. S content of fuel

Sheet Number 2 of 2
Date _____
Job Number _____
Computed by _____ Checked by _____

$$\% \text{ by wt. Sulfur content} = \frac{(\text{ppmv H}_2\text{S}) (\text{mol. wt. of S})}{(10^6) (\text{mol. wt. of landfill gas})} \times 100$$

where: 1) ppmv H₂S, Run 1 =

2) ppmv H₂S, Run 2 =

3) ppmv H₂S, Run 3 =

4) mol. wt. of S = 32.06

5) Mol. wt. of landfill gas = 27.85 lb/mole

Run 1

$$\frac{(19 \text{ ppmv H}_2\text{S}) (32.06 \text{ lb/mole})}{(10^6) (27.85 \text{ lb/mole})} \times 100 = 0.0012$$

% by wt.

Run 2

$$\frac{(72 \text{ ppmv H}_2\text{S}) (32.06 \text{ lb/mole})}{(10^6) (27.85 \text{ lb/mole})} \times 100 = 0.0083$$

% by wt.

Run 3

$$\frac{(43 \text{ ppmv H}_2\text{S}) (32.06 \text{ lb/mole})}{(10^6) (27.85 \text{ lb/mole})} \times 100 = 0.0050$$

% by wt.

1990

1991

1992

1993

1994

1995

1996

1997

1998

1999

2000

2001

2002

2003

2004

2005

2006


2007

2008



APPENDIX E

EQUIPMENT CALIBRATION



1.0 DRY GAS METER AND ORIFICE METER

The dry gas meter and orifice were calibrated using a wet test meter. Gases were moved through the dry gas meter at orifice pressure differentials (ΔH 's) of 0.5, 1.0, and 2.0 inches of water. With the information obtained, β , the ratio of accuracy of wet test meter to dry test meter; and ΔH_0 , the orifice pressure differential that gives 0.75 cfm of air at 68°F and 29.92 inches of mercury, were calculated. The β has a tolerance of 1.00 ± 0.01 and the ΔH_0 has a tolerance of $1.64 \pm 0.26 \pm 0.24$. The β and ΔH_0 are determined as follows:

$$\beta = \frac{V_w P_b (t_d + 460)}{V_d [P_b + 1.07353 (\Delta H)] (t_w + 460)}$$

$$\Delta H_0 = \frac{0.0317 (\Delta H)}{P_b (t_d + 460)} \left(\frac{(t_w + 460) \beta}{V_w} \right)^2$$

Where:

ΔH = Orifice pressure differential, in H_2O

P_b = Barometric pressure, in Hg

t_d = Average temperature of dry gas meter, °F

t_w = Average temperature of wet test meter, °F

θ = Duration of test, min.

V_d = Dry gas meter volume, ft³

V_w = Wet test meter volume, ft³

2.0 POTENTIOMETER CALIBRATION

The Thermo - Electron potentiometers were calibrated by using a known voltage source as an input to the potentiometer.

3.0 PROBE CALIBRATION

The probes were calibrated by measuring the outlet temperatures at various variable transformer settings while passing air through at approximately 0.75 cubic feet per minute.

[illegible]

1999

100-4-66 100-4-66



METER BOX CALIBRATION SHEET

Date 6-10-91 Box No. 428 Inspector Joe L. S.
Pump 1000 Oil Field Wichita OK Pump Serial No. 1000
Meters OK Meter OK All OK Meter OK
Quick Connect OK Meter OK Meter OK
Dry Gas Meter OK Volume 0.75 L/S Serial No. 75
Meters OK In 74 g out 74 g Meter 75 g
Optional ✓ Meters OK Meter OK
Leak Check - Max. Volume 28 in. Hg Leak Rate 0.00 gpm
Meters OK - placed active unit. Metered air
- tested OK cleared all tests. Be-slice-12-9
pump. Be-slice-12-9
Box No. 28.04 0.00 7 1.01

Box No.	Oil Field	Volume	Pressure	Leak Rate	Time
0.5	5.000	5.171	74	1.00	92
1.0	5.000	5.171	74	0.75	88.2
2.0	10.000	10.342	75	1.00	107.5

Tolerance: $1.65 \Delta V \pm 2.1$

ΔV	$\frac{(0.0017)(\Delta V)}{(P_1)(V_1 + 460)} \left[\frac{(P_2)(V_2 + 460)}{(P_1)(V_1 + 460)} \right]^2$	$\frac{(P_2)(V_2 + 460)}{(P_1)(V_1 + 460)} \left[\frac{(P_2)(V_2 + 460)}{(P_1)(V_1 + 460)} \right]^2$	$\frac{(P_2)(V_2 + 460)}{(P_1)(V_1 + 460)} \left[\frac{(P_2)(V_2 + 460)}{(P_1)(V_1 + 460)} \right]^2$
1.65	$\frac{(0.0017)(1.65)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$	$\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$	$\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$
1.77	$\frac{(0.0017)(1.77)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$	$\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$	$\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$
1.85	$\frac{(0.0017)(1.85)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$	$\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$	$\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \left[\frac{(5.171)(74 + 460)}{(5.171)(74 + 460)} \right]^2$

1.01 AVE

995 AVE

127 (1000) 495 Y 1.015



Scott Specialty Gases, Inc.

E. P. A. PROTOCOL CERTIFICATE OF ANALYSIS

Shipped from:
Scott Specialty Gases
Route 611
Plumsteadville, PA 18949
Purchase order:
21976

Shipped to:
BCM
ATTN: RICK CHORUB
1850 GRAVERS ROAD
HOBOKEN, NJ 07030

Project no: 31249

Certified per E.P.A. Protocol # 1 Procedure 001 Section 8 3.0.4
Certified accuracy +/- 1 E.NIST Traceable

Cylinder number	6AL-1594	Cylinder pressure	Date of assay:	9-25-91
		2500 psig		
Component:		Certified concentration	Expiration dates:	9-25-93
NITRIC OXIDE		145.1 ppm		
OXIDES OF NITROGEN		145.6		
NITROGEN		Balance		

Standard		Analyzer	
Type	CRM-1485	Make	: PECS
Concentration	250.0 ppm	Model	: 10
Cylinder #	ADM-100727	Serial number	: 9741-111-3
		Analytical principle	: Chemiluminescence
		Date of calibration	: 7-10-91

Test data units:	ppm	:	Concentration	:
		:	of Customer	:
		:	Cylinder	:
First analysis	9-18-91	:		:
		:		:
Z1=0.0000	S1=785.3	T1=458.3	: 145.1 ppm	:
R2=775.3	Z2=0.0000	T2=455.1	: 145.2 ppm	:
Z3=0.0001	T3=460.3	R3=777.3	: 145.1 ppm	:
		:		:
Second analysis:	9-25-91	:		:
		:		:
Z1=0.0000	S1=847.5	T1=455.3	: 147.1 ppm	:
R2=853.6	Z2=0.0000	T2=500.1	: 145.3 ppm	:
Z3=0.0000	T3=497.9	R3=854.3	: 145.3 ppm	:


Analyst

[Signature]

Approved by

[Signature]

Per E. P. A. Procedure



CERTIFICATE OF ANALYSIS

Date: September 24, 1991

Customer: EICMI Field Ser-
vices

Order Number: 1099650

P.O.#: 22201

Serial No: CC101359

Lot Number: 978-9-23-91

COMPONENT

REQUESTED

ACTUAL

Oxygen

21.9 %

21.4 %

Nitrogen

Balance

Balance

Cylinder: 30AL

Pressure: 2000 psig

CGA: 590

Contents: 4135 liters

Chemist: *mm*



TABLE E-1
GAS DIVIDER
ACCURACY CHECK(1)

Gas Divider Setting	PPMv Propane	FID Response (%)	Response Factor
0	0.0	0.0	0.0
10	9.5	8.5	1.12
20	19.0	17.0	1.12
30	28.5	25.4	1.12
40	38.0	34.0	1.12
50	47.5	42.5	1.12
60	57.0	51.2	1.11
70	66.5	60.0	1.11
80	76.0	68.7	1.11
90	85.5	77.7	1.10
100	95.0	86.1	1.10
SD(2)			0.01
RSD(3)			0.74%

(1) Accuracy check performed on 10/7/91 utilizing 95.0 ppmv propane standard and Beckman Model 400 Flame Ionization Detector (FID)
(2) SD = Standard Deviation
(3) RSD = Relative Standard Deviation

6277y

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000

10000