

Client: Suez Tunnel Report #: 89-017
Location: Suez Marine Landfill
Operator: R. Loran
Date: 6-27-89
Run No: 3
Pump No.: 315T
Meter Box No.: 1004 Factor: _____
Meter A.H. #: 1.078
Pilot Tube No.: 6T

Post Test Leak Chk.


Leak Rate: _____ cfm
Vacuum: _____ (in Hg)

Ambient Temp: 78°
Barometric Pressure: Z
Static Pressure, (in Hg): —
Assumed Moisture %: —
Nozzle Ident. No.: —
Aver. Calib. Nozzle Diam.: —
Probe Liner Material: —
Filter Number: —
Duct Diam. (in): —

2 Port

[illegible]

Solar Turbines - San Marcos Turbine #1 & #2



The illustration shows some of the points and their location at the centroid of equal areas of the sampled cross-section

General view of sampled source.
Diameter = 30"
A = 4 dia.
B = 6 dia

Distances to sampled points from inside of stack wall

Point	Calculated	Actual
1	0.6	6.6
2	2.0	8.0
3	3.5	9.5
4	5.3	11.3
5	7.5	13.5
6	10.7	16.7
7	19.3	25.3
8	22.3	28.3
9	14.7	30.7
10	26.5	32.5
11	28.0	34.0
12	29.4	35.4

Point	Calculated	Actual
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		

1-21-64
OFFICE OF THE
DIRECTOR

Report No: 89-017

San Marcos : Inlet #1

[illegible]

Report No: 87-017

San Marcos Landfill - outlet #1

[illegible]

CHAIN of CUSTODYDATE: 6-26:27-89unit/site: Turbine #1-2Client: SolarDetermination: HydrocarbonReport No: 89-07Outlets

CUSTODIAN	4/26/89 TIME	PERFORMANCE	RECEIVING CUSTODIAN
RPL	1320	Finished Run #1 outlet Turbine #1	CAS
CAS	6/27/89 1800	Delivered samples to lab	FM
FM	6-28-89	Run analysis	
RPL	1430	Finished Run #2 Turbine #1	CAS
CAS	6/27/89 1900	Delivery sample to Lab	FM
FM	6-28-89	Run analysis	
RPL/PP	1635	Finished Run #3 Turbine #1	CAS
CAS	6/27/89 1900	Delivered sample to lab	FM
FM	6-28-89	Run Analysis	
	6-27-89		
RPL/PP	1000	Finished Run #1 Turbine #2	CAS
CAS	1900	Delivered sample to lab	FM
FM	6-28-89	Run Analysis	
PP/	1225	Finished Run #2 Turbine #2	CAS
CAS	1900	Delivered sample to lab	FM
FM	6-28-89	Run analysis	
PP	1400	Finished Run #3 Turbine #2	CAS
CAS	1900	Delivered sample to lab	FM
FM	6-28-89	Run Analysis	

THE UNIVERSITY OF CHICAGO
PRESS

QA

PETRO-CHEM ENVIRONMENTAL
 DRY GAS METER CALIBRATION

DATE:3-13-89
 OPERATOR:FVR
 METER ID 1004

AMBIENT TEMP. 65
 BAROMETRIC Pbar 30.40
 TEST METER ID#: SSM104564
 TEST METER Mcf: 1.0253

APPROXIMATE CFM	1	.75	.5	.3
STD TEST METER				
INT.	0.00	0.00	0.00	0.00
VOLUME CF				
FINAL	20.325	14.342	14.868	35.578
TOTAL	20.325	14.34	14.87	35.58
ELD GAS METER				
INT.	304.00	328.34	288.94	343.40
VOLUME CF				
FINAL	325.70	343.40	304.00	379.70
TOTAL	21.70	15.06	15.06	36.30
STD TEST METER				
TEMP F'				
	67	69	65	71
ELD GAS METER				
TEMP F'				
IN	96	97	90	95
OUT	76	78	73	78
AVERAGE	86	87.5	81.5	86.5
TD TEST METER				
PRES.(in H2O)	-1.30	-0.60	-0.30	-0.15
ELD GAS METER				
PRES.(in H2O)	1.55	1	.75	.5
ELD GAS METER				
Mcf	.9912396	1.008126	1.042151	1.032991
ELD AVERAGE Mcf:	1.018627			



SCOTT-MARRIN, INC.
 2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
 TELEPHONE (714) 784-1240

RECEIVED

JUN 26 1989

REPORT OF ANALYSIS

TO: Tim Brennan
 Petrochem Environmental
 P.O. Box 5126
 Bakersfield, CA 93388

DATE: 21 June 1989

CUSTOMER ORDER NUMBER: 50-000-00108

CYLINDER NUMBER CC51183

COMPONENT CONCENTRATION(v/v)

Nitric Oxide 49.6 ± 0.5 ppm

Carbon Monoxide 50.4 ± 0.5 ppm

Sulfur Dioxide 80.7 ± 1.6 ppm

Nitrogen Balance

Replicate	5/16/89	50.1 ppm	6/19/89	49.2 ppm
Analysis		49.5 ppm		49.1 ppm
Data On		<u>50.1 ppm</u>		<u>49.3 ppm</u>
NO:	Mean	49.9 ppm		49.2 ppm

Expiration Date NO: 12/19/89

Replicate	5/11/89	50.2 ppm	6/21/89	50.7 ppm
Analysis		49.9 ppm		50.6 ppm
Data On		<u>50.2 ppm</u>		<u>50.8 ppm</u>
CO:	Mean	50.1 ppm		50.7 ppm

Expiration Date CO: 12/21/89

Replicate	5/19/89	80.6 ppm	6/21/89	80.9 ppm
Analysis		81.0 ppm		80.2 ppm
Data On		<u>80.6 ppm</u>		<u>80.4 ppm</u>
SO ₂ :	Mean	80.8 ppm		80.5 ppm

Expiration Date SO₂: 12/21/89

Cylinder Pressure: 2000 psig

ANALYST

J. W. Gay

APPROVED

J. T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

SCOTT-MARRIN, INC.

2001 THIRD ST., UNIT 1

RIVERSIDE, CALIFORNIA 92507

REPORT OF ANALYSIS

CUSTOMER ORDER NUMBER: 50-000-00108

CYLINDER NUMBER CC51183

CYLINDER NUMBER _____

COMPONENT CONCENTRATION(v/v)

COMPONENT CONCENTRATION(v/v)

(The Nitric Oxide analysis was performed in accordance with Section 3.0.4 of the)
(revised EPA traceability protocol No. 1 dated June 9, 1987. The analysis is)
(traceable to the National Bureau of Standards by direct intercomparison with GMIS,)
(cylinder number CC49657 at 50.6 ppm Nitric Oxide in Nitrogen. The analysis was)
(performed using a Monitor Labs Model 8440, S/N 136 analyzer with continuous)
(chemiluminescence detection. The last multipoint calibration was performed)
(5/22/89.)

CYLINDER NUMBER CC51183

CYLINDER NUMBER _____

COMPONENT CONCENTRATION(v/v)

COMPONENT CONCENTRATION(v/v)

(The Carbon Monoxide analysis was performed in accordance with Section 3.0.4 of the)
(revised EPA traceability protocol No. 1 dated June 9, 1987. The analysis is)
(traceable to the National Bureau of Standards by direct intercomparison with GMIS,)
(cylinder number CAL5180 at 98.6 ppm Carbon Monoxide in Nitrogen. The analysis was)
(performed using a Carle Model 8000 gas chromatograph with catalytic methanation/)
(flame ionization detection. The last multipoint calibration was performed 6/1/89.)

CYLINDER NUMBER CC51183

CYLINDER NUMBER _____

COMPONENT CONCENTRATION(v/v)

COMPONENT CONCENTRATION(v/v)

(The Sulfur Dioxide analysis was performed in accordance with Section 3.0.4 of the)
(revised EPA traceability protocol No. 1 dated June 9, 1987. The analysis is)
(traceable to the National Bureau of Standards by direct intercomparison with GMIS,)
(cylinder number CC28557 at 101.8 ppm Sulfur Dioxide in Nitrogen. The analysis was)
(performed using an Interscan Model RM2450P, S/N 72138 gas chromatograph with)
(electrochemical detection. The last multipoint calibration was performed 6/22/89.)

CYLINDER NUMBER _____

CYLINDER NUMBER _____

COMPONENT CONCENTRATION(v/v)

COMPONENT CONCENTRATION(v/v)



PETRO
CHEM
ENVIRONMENTAL
SERVICES

CALIBRATION GAS CERTIFICATE

DATE: FEBRUARY 10, 1989
ANALYSIST: Leslie A. Johnson
TANK: LK 273312
CONTENTS: Oxygen in Nitrogen

	<u>SET #1</u>	<u>SET #2</u>	<u>SET #3</u>
RUN #1	15.01	15.00	15.00
RUN #2	15.00	15.00	14.99
RUN #3	<u>15.01</u>	<u>14.99</u>	<u>15.01</u>
AVERAGE -	15.01	15.00	15.00

Average Concentration 15.00% O₂

Expires August 10, 1989