

Johnston RI 1/90

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

*7 data to be
catalyst problems
found during the*

test.

REPORT OF EMISSION LEVELS
AND
FUEL ECONOMIES
FOR
EIGHT WAUKESHA 12V-AT25GL UNITS
LOCATED AT THE
JOHNSTON, RHODE ISLAND CENTRAL LANDFILL

REPORT PREPARED FOR: WAUKESHA PEARCE INDUSTRIES, INC.
HOUSTON, TEXAS

REPORT PREPARED BY: ROBERT STACHOWICZ
SENIOR PROJECT ENGINEER
WAUKESHA ENGINE DIVISION
DRESSER INDUSTRIES, INC.
WAUKESHA, WISCONSIN 53188

TEST DATES: OCTOBER 9 THRU OCTOBER 16, 1990
SUPPLEMENTAL TEST DATE: NOVEMBER 6, 1990

REPORT DATE: NOVEMBER 30, 1990

EXECUTIVE SUMMARY

During the periods October 9-16, 1990 and November 6, 1990 the Waukesha Engine Division of Dresser Industries, Inc. performed emission tests on eight 12V-AT25GL Waukesha engines located at the Johnston, Rhode Island Central Landfill powerhouse.

Permit requirements for emission certification of the units are:

Nitrogen oxides (as NO_2) - 1.25 gr/BHP-HR or 6.6 Lb/HR maximum, whichever is more stringent.

Carbon monoxide - 1.125 gr/BHP-HR or 5.9 Lb/HR maximum, whichever is more stringent.

Nonmethane hydrocarbons - 0.5 gr/BHP-HR or 2.6 Lb/HR maximum, whichever is more stringent.

Initial testing yielded average stack emission rates from the eight units at rated conditions of .50 gr/BHP-HR NO_x , 1.70 gr/BHP-HR CO, and .08 gr/BHP-HR NMHC. All units failed permit requirements for CO emission due to a low average oxidizing catalyst efficiency of 9%. NO_x and NMHC emission levels were well below permit requirements.

The low catalyst CO conversion efficiency was traced to silicon contamination. A mechanical cleaning of the #1 unit catalyst raised its efficiency to 21.5% and lowered the stack CO level to 1.66 gr/BHP-HR. A thorough chemical cleaning of the #8 unit catalyst raised its efficiency to 78.6% and lowered the stack CO level to .36 gr/BHP-HR.

Average fuel consumption at rated conditions was found to be 6917 BTU/BHP-HR.

TABLE OF CONTENTS

	<u>PAGE</u>
TITLE PAGE	i
EXECUTIVE SUMMARY	ii
TABLE OF CONTENTS	iii
1.0 INTRODUCTION	1
2.0 EQUIPMENT DESCRIPTION	2
3.0 TEST PROCEDURES	3
3.1 FUEL ECONOMY	3
3.2 GASEOUS EMISSIONS	3
4.0 FUEL ANALYSES	3
5.0 RESULTS	4
5.1 FUEL ECONOMY	4
5.2 GASEOUS EMISSIONS	4
5.2.1 ORIGINAL TESTING	4
5.2.2 SUPPLEMENTAL TESTING.....	4
6.0 CONCLUSIONS	5

FIGURES

	<u>PAGE</u>
FIGURE 1 POWERHOUSE UNIT ARRANGEMENT	2

TABLES

TABLE I	FUEL PARAMETERS	6
TABLE II	ENGINE TEST CONDITIONS	7
TABLE III	FUEL CONSUMPTION	8
TABLE IV-a	PRE-CATALYST EMISSION SUMMARY	9
TABLE IV-b	POST-CATALYST EMISSION SUMMARY	10
TABLE IV-c	STACK (CERTIFICATION) EMISSION SUMMARY.....	11

APPENDICES

APPENDIX A	TEST PROTOCOL AND SUPPLEMENT
APPENDIX B	EXCERPTS FROM 40CFR86
APPENDIX C	ANALYZER CALIBRATIONS
APPENDIX D	FUEL ANALYSES
APPENDIX E	RAW DATA
APPENDIX F	"AIR-FUEL RATIOS FROM EXHAUST GAS ANALYSIS" SAE PAPER #650507
APPENDIX G	CALCULATED RESULTS
APPENDIX H	SAMPLE CALCULATION

1.0: INTRODUCTION

The Johnston, Rhode Island Central Landfill powerhouse contains eight (8) engine/generator units whose purpose is to convert the gas generated by the landfill into useful electrical energy. The engines are Waukesha 12V-AT25GL lean combustion, low emission models.

The State of Rhode Island, Department of Environmental Management (RIDEM) approval #999-1014 requires performance testing be conducted for nitrogen oxides ($\text{NO}_x = \text{NO} + \text{NO}_2$ as NO_2), carbon monoxide (CO), and total non-methane hydrocarbons² (NMHC). As part of the conditions of sale of these engines, the Waukesha Engine Division of Dresser Industries, Inc. (WED) was contracted to perform this testing utilizing the capabilities of our mobile emissions testing laboratory.

The emission limitations per permit #999-1014 are:

1. NO_x : the emission rate from each engine shall not exceed 1.25 gr/BHP-HR or a maximum of 6.6 Lb/HR, whichever is more stringent.
2. CO: the emission rate from each engine shall not exceed 1.125 gr/BHP-HR or a maximum of 5.9 Lb/HR, whichever is more stringent.
3. NMHC: the emission rate from each engine shall not exceed 0.5 gr/BHP-HR or a maximum of 2.6 Lb/HR, whichever is more stringent.

Additional permit requirements are:

1. Visible emissions from each engine exhaust shall not exceed 10% opacity except for a period or periods aggregating no more than three minutes in any one hour.
2. Only landfill gas shall be used as an engine fuel.
3. The oxygen content of the exhaust gas entering the CO oxidation catalyst shall not be less than 7.0% by volume.
4. The CO oxidation catalyst exit temperature shall not exceed 1350°F.
5. The CO oxidation catalyst inlet temperature shall be a minimum of 750°F.

Factory engine-out emission guarantees were 1.25 gr/BHP-HR NO_x , 2.25 gr/BHP-HR CO, and 0.5 gr/BHP-HR NMHC. The low CO permit limitation required the addition of a Johnson-Matthey model CO 1750-20 oxidation catalyst to each exhaust system. Engine-out and permit CO levels indicate a required minimum catalyst CO conversion efficiency of 50%.

The required emissions performance testing was performed during the period October 9, 1990 to October 16, 1990. Mr. Richard Evans of RIDEM was present during three days of this testing. A supplemental test was performed on November 6, 1990.

2.0: EQUIPMENT DESCRIPTION

The Central Landfill powerhouse contains eight identical engine/generator units. The engines are Waukesha 12V-AT25GL lean combustion, low emission units of 9.84" bore x 11.81" stroke with 10784 cubic inches displacement. Each engine is rated at 1700 KWe at 900 RPM. At 96% generator efficiency this is 2375 BHP. The engines are adjusted to run on landfill gas. Specified engine settings are 17° BTDC spark timing and 8.6% ± .2% exhaust oxygen level pre-catalyst. Crankcase breather gases are injected into the exhaust stream downstream of the catalyst using compressor bleed air.

Each engine drives a Kato model A24862001 generator rated at 1700 kilowatts at 4160 volts. Switchgear was manufactured by Point Eight and voltage regulators by Basler.

The exhaust stream from each engine passes through a Johnson Matthey oxidizing catalytic converter model CO 1750-20. After leaving the building each exhaust stream is directed upward through a 60" O.D. silencer.

Figure 1 shows powerhouse unit arrangement.




FIGURE 1

Fuel gas treatment is accomplished with a Bio Gas Development (BGD) of Atlanta, Georgia system.

3.0: TEST PROCEDURES

The test procedures used for both fuel economy and gaseous emissions testing followed the test protocol (and supplement) approved by the RIDEM. See Appendix A. Further elaboration is provided below.

3.1: FUEL ECONOMY

During the emission test sequence, five separate measurements were made of the volumetric fuel gas flow rate using a calibrated positive displacement Roots meter. See Appendix C for calibration data. Temperature and pressure of the fuel gas were measured at the meter itself to enhance accuracy.

The high and low readings were discarded and an average of the remaining readings was used for all calculations. See Appendix E for raw data sheets.

3.2: GASEOUS EMISSIONS

Procedures outlined in the approved protocol were followed exactly. Analyzers used are described in Appendix A and calibration data is given in Appendix C. A basic schematic of the sample train used is shown in Appendix B. Probes used in all three test locations conformed to 40 CFR 86 section 86.310-79 (b) as presented in Appendix B.

Raw data is presented in Appendix E.

4.0: FUEL ANALYSES

During the original test program, three fuel samples were taken at intervals. Samples were taken on October 9, 11, and 15 during the certification testing. In addition, a fourth sample was taken during the supplemental test on November 6.

These samples were analyzed by IGT Analytical Laboratory of Chicago. Further fuel properties, to allow emission calculation, were calculated at Waukesha from IGT component analyses. These data are given in Appendix D.

Since samples 1 and 2 of October 9 and 11 were nearly identical, an average of these fuel properties was used for calculations spanning that time period. Table I summarizes the three sets of fuel properties used for final fuel consumption and emission calculations. Their applicability is given in Table II.

5.0: RESULTS

Calculated results are detailed in Appendix G. A sample calculation is given in Appendix H. Significant results are summarized in Tables II, III, and IV. Table II summarizes engine test conditions. Table III summarizes the results of the fuel consumption testing. Table IV summarizes the results of the emission testing.

5.1: FUEL ECONOMY

Average engine loads for fuel economy (and emission) calculations were obtained from the raw data computer printouts presented in Appendix E. The mean brake specific fuel consumption (BSFC) is 6917 BTU/BHP-HR with a low of 6648 BTU/BHP-HR and a high of 7145 BTU/BHP-HR. Note that these values are not all directly comparable because of small load differences between the eight engines.

5.2: GASEOUS EMISSIONS

In order to calculate brake specific or mass emission rates, the total exhaust mass flow rate must be known. The general exhaust system layout and large exhaust silencers do not allow a pitot tube measurement of exhaust flow without significant modification. Instead, fuel flow rate was precisely measured as previously noted. Then air-fuel ratio was calculated using the Spindt method, see Appendix F, as modified for the large CO₂ concentration in the fuel gas. See Appendix H, sample calculation, for further elaboration on this point. The air flow rate is calculated as the product of the fuel flow rate and the air-fuel ratio. The total exhaust mass flow rate is the sum of the fuel and air flow rates.

5.2.1: ORIGINAL TESTING

Emission test results are presented in Tables IV-a, -b, and -c for pre-catalyst, post-catalyst, and stack (certification) locations, respectively.

Mean stack emission rates from the eight units as originally tested at rated conditions were found to be .50 gr/BHP-HR NO_x, 1.70 gr/BHP-HR CO, and .08 gr/BHP-HR NMHC. These NO_x and NMHC levels are well below the permit requirements of 1.25 gr/BHP-HR NO_x and 0.5 gr/BHP-HR NMHC. All units failed the 1.125 gr/BHP-HR CO permit requirement due to a low average oxidizing catalyst efficiency of 9%.

5.2.2: SUPPLEMENTAL TESTING

The catalyst from unit #1 was removed and examined. It was found to be covered with a grey/black crusty material. Core samples were removed and forwarded to Johnson Matthey for analysis. In the meantime, the catalyst was mechanically cleaned using high pressure air and replaced. A retest of this unit showed a lowered CO level of 1.66 gr/BHP-HR and a catalyst efficiency of 21.5%.

Analysis by Johnson Matthey of the core samples from unit #1, and additional core samples from unit #8, indicated that by far the major contaminant was silicon. This silicon was almost certainly entering the combustion chamber in some form with the fuel gas.

The #8 catalyst was then chemically cleaned using a sodium hydroxide solution following a procedure recommended by Johnson Matthey. The cleaned catalyst was replaced and the unit retested on November 6. This time the catalyst efficiency was found to be 78.6% and the stack CO level of .36 gr/BHP-HR was well under the permit maximum of 1.125 gr/BHP-HR.

6.0: CONCLUSIONS

As found, all eight units at the Central Landfill powerhouse easily met operating permit requirements for NO_x and NMHC emission levels. However, none of the units was able to meet the permit required CO level. The high CO level was determined to be due to low oxidizing catalyst efficiency which was, in turn, caused by silicon contamination of the catalyst material.

A supplemental test on a unit with a chemically cleaned catalyst yielded a CO level well under the permit maximum.


With properly functioning oxidizing catalysts, the Central Landfill units should easily pass operating permit #999-1014 emission requirements.

Written by:


R.W. Stachowicz

Senior Project Engineer/Engineering Support

Approved by:


J.M. Derra

Manager/Engineering Support

TABLE I
FUEL PARAMETERS

<u>FUEL DESIGNATION</u>	<u>SAMPLE DATE(S)</u>	<u>CHARACTERISTICS</u>	
A	10-09-90 10-11-90 (AVERAGE)	SLHV	502 BTU/FT ³
		SPECIFIC GRAVITY	.980
		DENSITY	.07477 LB/FT ³
		F _C	.23742
		F _{H2}	.07975
		F _{O2}	0
		F _{N2}	.00213
		F _{CO2}	.68115
		F _{IN}	0
B	10-15-90	SLHV	473 BTU/FT ³
		SPECIFIC GRAVITY	.977
		DENSITY	.07455 LB/FT ³
		F _C	.22371
		F _{H2}	.07517
		F _{O2}	.01054
		F _{N2}	.05476
		F _{CO2}	.63550
		F _{IN}	0
C	11-06-90	SLHV	480 BTU/FT ³
		SPECIFIC GRAVITY	.994
		DENSITY	.07584 LB/FT ³
		F _C	.22318
		F _{H2}	.07504
		F _{O2}	.00078
		F _{N2}	.01647
		F _{CO2}	.68480
		F _{IN}	0

NOTE: REFERENCE APPENDIX D - F_i TERMS ARE MASS FRACTION VALUES.

TABLE II

ENGINE TEST CONDITIONS

UNIT	DATE	AVERAGE LOAD		TEST BAROMETER	TEST HUMIDITY	FUEL PARAMETERS ²	SPARK TIMING	CARBURETOR ADJUSTMENT ³	
		KWe	BHP ¹		gr/Lb			AIR/FUEL RATIO	EXCESS AIR (%)
1	10-09-90	1725	2410	29.87	75	A	17°	8.935	64.0
2	10-09-90	1806	2523	29.79	103	A	17°	9.230	69.0
3	10-16-90	1693	2365	29.86	43	B	17°	8.445	65.5
4	10-12-90	1692	2363	29.89	111	A	17°	9.200	68.5
5	10-14-90	1598	2232	29.40	95	B	17°	8.655	69.5
6	10-11-90	1675	2340	30.04	97	A	17°	9.145	67.5
7	10-11-90	1693	2365	30.12	71	A	17°	9.135	67.5
8	10-10-90	1707	2385	30.06	67	A	17°	9.305	71.0
MEAN		1700	2373					9.006	67.8
STANDARD DEVIATION		54	75					.288	2.2
1	10-13-90	1665	2326	29.70	102	A	17°	9.210	69.0
RERUN									
8	11-06-90	1718	2400	29.28	44	C	17°	8.480	65.5
RERUN									

NOTES: 1) BHP FIGURES ASSUME 96% GENERATOR EFFICIENCY

2) SEE TABLE I FOR FUEL PARAMETERS

3) TWO RUN AVERAGE - REFERENCE TEST PROTOCOL

TABLE III
FUEL CONSUMPTION

<u>UNIT</u>	<u>AVERAGE LOAD</u>		<u>FUEL SLHV</u> <u>BTU/FT³</u>	<u>AVERAGE</u> <u>BSFC</u> <u>BTU/BHP-HR</u>	<u>AVERAGE FUEL</u> <u>RATE</u> <u>LB/MIN</u>
	<u>KWe</u>	<u>BHP</u>			
1	1725	2410	502	6829	40.855
2	1806	2523	502	6753	42.295
3	1693	2365	473	6648	41.301
4	1692	2363	502	7145	41.912
5	1598	2232	473	6857	40.203
6	1675	2340	502	7124	41.382
7	1693	2365	502	7073	41.525
8	1707	2385	502	6908	40.899
MEAN STANDARD DEVIATION				6917 170	
1 RERUN	1665	2326	502	7236	41.781
8 RERUN	1718	2400	480	6888	43.532

TABLE IV-a
PRE-CATALYST EMISSION SUMMARY

<u>UNIT</u>	<u>BRAKE SPECIFIC EMISSIONS - g/BHP-HR</u>		
	<u>NO_x</u>	<u>CO</u>	<u>NMHC</u>
1	.485	1.835	.080
2	.435	1.960	.095
3	.660	1.790	.060
4	.400	1.940	.080
5	.390	1.915	.070
6	.570	2.005	.080
7	.515	1.830	.070
8	.475	1.825	.070
MEAN	.491	1.888	.076
STANDARD DEVIATION	.090	.073	.010
1 RERUN	.355	2.070	.090
8 RERUN	.680	1.890	.050

NOTES: 1) TWO RUN AVERAGE - REFERENCE TEST PROTOCOL
 2) NO_x AS NO₂

TABLE IV-b
POST-CATALYST EMISSION SUMMARY

<u>UNIT</u>	<u>BRAKE SPECIFIC EMISSIONS - g/BHP-HR</u>			<u>CO CATALYST EFFICIENCY-%</u>
	<u>NO_x</u>	<u>CO</u>	<u>NMHC</u>	
1	.500	1.610	.070	12.3
2	.450	1.840	.090	6.1
3	.650	1.510	.060	15.6
4	.410	1.660	.080	14.4
5	.375	1.780	.080	7.0
6	.565	2.015	.090	0
7	.510	1.680	.070	8.2
8	.475	1.660	.060	9.0
MEAN	.492	1.719	.075	9.08
STANDARD DEVIATION	.084	.146	.012	4.71
1 RERUN	.365	1.625	.080	21.5
8 RERUN	.695	.405	.050	78.6

NOTES: 1) TWO RUN AVERAGE - REFERENCE TEST PROTOCOL
2) NO_x AS NO₂

TABLE IV-C

STACK (CERTIFICATION) EMISSION SUMMARY

<u>UNIT</u>	<u>BRAKE SPECIFIC EMISSIONS - g/BHP-HR</u>		
	<u>NO_x</u>	<u>CO</u>	<u>NMHC</u>
1	.51	1.57	.07
2	.49	1.84	.08
3	.67	1.39	.06
4	.41	1.66	.09
5	.38	1.80	.09
6	.57	2.00	.09
7	.52	1.67	.08
8	.47	1.64	.06
MEAN	.503	1.696	.078
STANDARD DEVIATION	.085	.173	.012
1 RERUN	.34	1.66	.06
8 RERUN	.70	.36	.05

NOTE: NO_x AS NO₂

**PROPOSED TEST PROTOCOL FOR EMISSIONS CERTIFICATION TESTING
AT THE JOHNSTON, RHODE ISLAND CENTRAL LANDFILL SITE**

Site Equipment

Eight (8) Waukesha 12V-AT25GL lean combustion, low emission reciprocating internal combustion engines driving Kato electric generators. Each unit is rated at 1700 KW at 900 RPM. Exhaust from the engines is passed through an oxidizing catalyst for further reduction of carbon monoxide and unburned hydrocarbons. These engines are fueled solely with landfill gas.

Emission Requirements (Reference permit conditions and emissions limitations approvals 999-1014)

1. Nitrogen Oxides (NO_x as NO_2)

The emission rate of nitrogen oxides from each engine exhaust shall not exceed 1.25 grams per brake horsepower - hour (gm/BHP-HR) or a maximum of 6.6 lbs. per hour, whichever is more stringent.

2. Carbon Monoxide (CO)

The emission rate of carbon monoxide from each engine exhaust shall not exceed 1.125 gm/BHP-HR or a maximum of 5.9 lbs. per hour, whichever is more stringent.

3. Total Nonmethane Hydrocarbons (NMHC)

The emission rate of total nonmethane hydrocarbons from each engine exhaust shall not exceed 0.5 gm/BHP-HR or a maximum of 2.6 lbs. per hour, whichever is more stringent.

NOTE: These emission limits apply to the post-catalytic converter exhaust.

Test Methods

Waukesha proposes to use U. S. Environmental Protection Agency (EPA) test methods to demonstrate compliance with the specified emission requirements. These methods are detailed in Title 40 of the Code of Federal Regulations, Part 86, Subpart D (40CFR86, Subpart D).

Waukesha also specifies the following additions and exceptions to 40CFR86, Subpart D:

1. Section 86.301-79. Waukesha extends the applicability of this Subpart to gaseous fuels including landfill gas.
2. For heavy duty stationary engines the test cycles outlined in sections 86.335-79 and 86.336-79 are not used. Instead, all testing is done at steady state conditions at discrete, specified points.

3. Specified dynamometer runs, e.g. sections 86.340-79 and 86.341-79, do not apply literally to this field test. The outlined procedure will be followed as far as practical for the specified test points.
4. Section 86.345-79 - Emission Calculations. Waukesha does not calculate the dry fuel/air ratio (f/a) using the formula in (d). Instead dry (f/a) is calculated using the Spindt method. Reference Society of Automotive Engineers paper #650507, "Air-Fuel Ratios from Exhaust Gas Analysis".
5. Total nonmethane hydrocarbons will be measured with a Byron gas chromatograph.

Test Instrumentation

The instruments and systems in the Waukesha Mobile Engine Exhaust Emission measurement Laboratory (MEEEML) van were selected and designed to comply with USEPA 40CFR86, Subpart D and the gas sampling and analytical train given in figure D79-1, section 86.309-79.

The MEEEML instrumentation is further detailed in Appendix I.

Instrument Calibration

All analyzer calibrations comply with the applicable procedures of 40CFR86, Subpart D. All analyzers will be calibrated at the factory no more than thirty (30) days prior to the scheduled start test date. A copy of all calibration sheets will be provided to the Rhode Island DEM as part of the final report.

Fuel Composition

An average fuel composition based on data taken by Waukesha between 2/4/90 and 2/11/90 will be used for any preliminary calculations performed on site. This fuel composition and analysis is given in Appendix II.

During the test program three fuel samples will be taken at intervals by Waukesha. These samples will provide the fuel characteristics to be used for final emission certification and fuel consumption calculations.

Sample Locations

Emissions entering the catalyst will be sampled at the position marked "A" in photograph "A" in Appendix III. Stack emissions for compliance will be sampled at the position marked "B" in photograph "B" in Appendix III.

Test Procedure

The test procedure followed for each engine will be:

- Engines will be tested fully warmed and stabilized at rated conditions of 1700 KW at 900 RPM (about 2375 BHP). Engines will be adjusted at rated conditions to $8.6\% \pm .2\%$ exhaust oxygen level pre-catalyst, 17° BTDC ignition timing and $9" \text{ Hg} \pm 1" \text{ Hg}$ prechamber gas pressure.
- Each stack certification test will consist of a 15 minute run at rated conditions of 1700 KW at 900 RPM. During this time NO_x , CO, CO_2 , THC, CH_4 , NMHC, and O_2 levels will be measured and permanently recorded. Maximum, minimum and average values will be determined for each specie and recorded. LB/HR and gm/BHP-HR emittant rates will be calculated from the average specie values.

Pre-catalyst emission levels will also be measured to determine compliance with WED and catalyst manufacturer performance warranties. NO_x , CO, CO_2 , THC and O_2 emissions will be measured and permanently recorded for a minimum of three minutes both before and after the 15 minute stack compliance test. These emission levels will be averaged for all calculation purposes.

All analyzers will be zeroed and spanned before and after sampling in accordance with 40CFR86, Subpart D procedures.

- During the emission test sequence, five separate measurements will be made of the volumetric fuel flow rate using a positive displacement Rootsmeter. The high and low readings will be discarded. The remaining three readings will be averaged to yield the fuel flow rate for calculation purposes. The ideal, saturated low heat value of the gas will be used to calculate final brake specific fuel consumption rates.

Repeat Data

A decision to repeat any test run may be made by either Waukesha or Rhode Island DEM representatives after the test run is completed. The Waukesha representative may elect to repeat a run if the data are found to be inaccurate or technically deficient. The Rhode Island DEM representative may elect to repeat a run for any valid reason.

After the test instrumentation has been removed from a unit, testing on that unit will be deemed complete. Such a unit will only be retested if agreement is reached between Waukesha and Rhode Island DEM personnel that existing data are significantly deficient in some manner.

Final Report

A final report on the results of the stack testing will be submitted to the Rhode Island DEM no later than sixty (60) days following completion of the testing.

Certification by Concentration

To save time and expense, yet provide high quality certification data, Waukesha proposes the following:

Units 1, 2 and 3 would be tested for emissions and fuel rate to determine preliminary figures in LB/HR and gm/BHP-HR units. These values and significant operating parameters such as intake manifold pressure, intake manifold temperature and exhaust stack temperature will be compared. If sufficiently similar, a correlation based on these three tests would be used to certify the remaining five units using specie concentration measurements only.

The decision to accept concentration measurements for certification will rest solely with the Rhode Island DEM representative on site observing the test program.

March 22, 1990

APPENDIX I

EMISSION MEASUREMENT INSTRUMENTATION

Waukesha Mobile Engine Exhaust Emission Measurement Laboratory (MEEEML)

The instruments and systems in Waukesha's MEEEML van were selected and designed to comply with the Environmental Protection Agency (EPA) heavy duty engine test requirements - reference 40CFR86 and 42FR45132 - and EPA test method 20, reference 44FR52798, as modified for use in internal combustion engines, reference 44FR43169.

ANALYZERS:

- NO/NO₂/NO_x
Thermo-Electron model 10 chemiluminescent
S/N 10AR-13640-140
Ranges 0-2½, 10, 25, 100, 250, 1000, 2500,
10000 ppm
- CO
Horiba model AIA-23 Non-dispersive infrared
S/N 4824705
Ranges 0-.25, 1.0, 5.0%
- THC
Horiba model FIA-22A Flame ionization detector
S/N 4812908
Ranges 0-10, 30, 100, 300, 1000, 3000, 10000,
30000 ppm
- CO₂
Horiba model AIA-23 Non-dispersive infrared
S/N 48498112
Range 0-16%
- O₂
Teledyne model 326AX Electrochemical
S/N 38817
Ranges 0-2, 5, 25%
- M/NMHC
Byron model 304 Gas chromatograph
S/N 0317
Ranges (methane and non-methane)
0-2, 5, 10, 20, 50, 100, 200, 500, 1000, 2000,
5000, 10000 ppm
- Standard Gas Divider model 75

APPENDIX II

FUEL COMPOSITION

FUEL GAS ANALYSIS WITH ASTM CORRECTION

METHANE	<u>52.60</u> %	HYDROGEN	<u>0.17</u> %
ETHANE	<u>0.00</u> %	HYDROGEN SULFIDE	<u>0.00</u> %
ETHENE	<u>0.00</u> %	CARBON MONOXIDE	<u>0.00</u> %
PROPANE	<u>0.00</u> %		
PROPYLENE	<u>0.00</u> %	NITROGEN	<u>3.01</u> %
ISO BUTANE	<u>0.00</u> %	OXYGEN	<u>0.11</u> %
NORMAL BUTANE	<u>0.00</u> %	AIR	<u>0.00</u> %
ISO PENTANE	<u>0.00</u> %	CARBON DIOXIDE	<u>44.10</u> %
NORNAL PENTANE	<u>0.00</u> %	WATER	<u>0.00</u> %
HEXANE	<u>0.00</u> %	HELIUM	<u>0.00</u> %
HEPTANE	<u>0.00</u> %	ARGON	<u>0.00</u> %

SUM OF THE FUEL PERCENTAGES 99.99%

SATURATED LHV 472.05 BTU/CU.FT

SPECIFIC GRAVITY 0.99422

OCTANE RATING 119.61


DENSITY 0.07606

MOLECULAR WEIGHT 28.73180

STOICHIOMETRIC SPINDT AFR IS 5.06:1 BY MASS

THE ATOMIC H/C RATIO FOR THIS FUEL IS 4.006

APPENDIX III
EMISSIONS SAMPLING LOCATIONS



Photograph "A"
PRE-CATALYST SAMPLE LOCATION



Photograph "B"
STACK SAMPLE LOCATION

Waukesha



WAUKESHA ENGINE DIVISION

DRESSER INDUSTRIES, INC.

1000 WEST ST. PAUL AVENUE • WAUKESHA, WISCONSIN 53188

August 10, 1990

Mr. Richard Evans
State of Rhode Island and Providence Plantations
Division of Air and Hazardous Materials
291 Promenade Street
Providence, RI 02908-5767

Dear Mr. Evans:

I have received your letter of July 23 requesting additional information for our proposed test protocol for the engines at the Central Landfill in Johnston, RI.

Attachment I (two pages) summarizes Waukesha's and the test team's qualification and experience with regard to engine emission sources and test methodology.

Attachment II (four sheets) is a partial response to your second query. I am attaching sketches and blueprints which describe the engine exhaust system and our two (2) proposed test locations. Note that the upstream location, before catalyst, is different from my March proposal in the protocol. This is caused by expected difficulty in placing the probe port in the original location.

You will note that neither test port is in an ideal location regarding flow obstructions. The overall layout of the exhaust system severely limits the available options for port placement. Since Waukesha does not plan to measure flow with a pitot tube (See Protocol, Test Methods, Item #4) we do not feel this is a major concern. We will use a multi-hole probe extending across the exhaust pipe for emissions measurement. This will result in a representative sample for analysis.

The plan showing location of source and the floor plan of the facility (2 sheets) will be provided by Waukesha-Pearce to you directly.

Since particulate matter in a gas engine exhaust is nil, exhaust opacity is negligible. Waukesha does not feel Method 9 readings are needed. Also, we do not have a technician certified to perform that test. Should a Method 9 test be mandatory, it would be ideal if the Rhode Island observer were certified and could run that test. If this is not feasible, arrangements will have to be made for a separate party to run the Method 9 test.

We currently have no plans for a factory representative to attend the near future site visit. However, Waukesha-Pearce may elect to have a representative present. I suggest that Rhode Island personnel present at this visit observe the clarity of the exhaust from the engines. This may lead to a determination that the Method 9 test is unnecessary unless mandated by statute.

Finally, Waukesha proposes an eight day block of time for the testing. Our first choice would be October 1-October 8, inclusive. If Columbus Day, October 8, is an observed holiday, the last day of testing would be October 9. If this is unacceptable, other alternatives, in order of preference are:

October 9-October ¹⁵~~17~~
November 5-November 12

For the time being, I have assumed that the October 1-8 period will be acceptable and have begun planning accordingly.

If you need to discuss any part of this, or our earlier submission, please contact me at (414) 549-2753.

Sincerely,

WAUKESHA ENGINE DIVISION
DRESSER INDUSTRIES, INC.


R.W. Stachowicz
Senior Project Engineer

RWS/bes

cc: C. Hoefflin - W.E.D.
R. Kakoczki - W.E.D.
J. Derra - W.E.D.
W. Briggs - W.E.D.
E. Brumbaugh - W.P.I.
R. Pollock - W.P.I.

Attachments

ATTACHMENT I

The Waukesha Engine Division of Dresser Industries, Inc., located in Waukesha, Wisconsin, is a leading manufacturer of gaseous fueled internal combustion engines. Since its founding in 1906, the Company has always strived to be at the leading edge of industry technology. For example, we currently offer, or are developing, several electronic controls to make our products more fuel efficient and environmentally acceptable.

The Company recognized early that emissions control and reduction would be an important design parameter and began testing and control programs in 1972. Over the years we have tested, developed, and marketed catalyst, exhaust gas recirculation, and lean combustion (both prechamber and open chamber) systems for emission control of our products. We hold one U.S. patent in emission control technology and currently market a lean burn combustion control with a proprietary oxygen sensor which can function in the 26-32:1 air/fuel ratio regime.

Our understanding of our product line and our long history of involvement with emission measurement has resulted in Waukesha periodically being asked to critique or troubleshoot emissions tests run by independent testing firms. This was particularly true in the early period of stationary source testing in California when local testing firms had little or no internal combustion engine experience.

Waukesha currently operates five full function emissions test benches in our development laboratory. Any research or development work now includes emissions measurement.

Our mobile engine exhaust emission measurement laboratory (test van) includes a full function emissions test bench. It was built for the purposes of offering a testing service to our customers, allowing us to personally monitor the emissions of field test engines, and as a means of troubleshooting emissions problems with field engines if necessary. It has been in service since 1982.


Using this van, Waukesha has performed emissions tests in California, Texas, Iowa, Rhode Island, and other states. We have always employed 40CFR86, heavy duty engine test requirements, methodology as opposed to Method 20 because the former was designed specifically for reciprocating internal combustion engines.

The test team will be composed of three participants:

- Engineer: Robert Stachowicz - Senior Project Engineer. BSME and MSME from the University of Wisconsin system. Nineteen years of engine experience; the last ten of which have been in the emissions legislation, measurement, and reduction areas.
- Technician: Dennis Perkins - Experimental Technician II. Associate degree in engine technology. Eleven years of engine experience; the last 6 1/2 of which have been in the emissions measurement area.
- Serviceman: A factory serviceman will be part of the team. His main functions will be to assist with hardware operation, particularly installation and movement of the fuel meter, and to ascertain that each engine is properly adjusted and in good operating condition prior to certification testing.

ATTACHMENT 11


PREPARED BY STACHOWICZ	Waukesha GREISER	PAGE 1 - 4
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMINAL NO.	SUBJECT EMISSIONS TEST PORT	DATE APRIL 9, 1990



INSTALL $\frac{1}{2}$ " NPT FULL PIPE COUPLING FOR EMISSIONS TEST PORT. TWO LOCATIONS IN EACH EXHAUST SYSTEM. SEE ATTACHED DRAWINGS FOR LOCATIONS.

INSTALL PIPE PLUG WITH "NEVER SEIZE" (OR EQUIVALENT) WHEN NOT IN USE.

SCALE: HALF



PLAN VIEW
TYP. WEST SIDE OF BLDG.
OPPOSITE HAND FOR EAST
SIDE OF BLDG.

(II) R2 and R5—back pressure regulators to control sample pressure at inlet to flow control valves.

886.310-79 Sampling and analytical system: component specifications.

(2) For Diesel engines any heated component;

(ii) In the NO_x sample path must be maintained above 60°C (140°F) and shall not exceed 230°C (446°F).




Figure D79-1 HEAVY-DUTY EXHAUST GAS SAMPLING AND ANALYTICAL TRAIN

of the radial planes for each hole in the probe must be such that they cover approximately equal cross-sectional areas of the exhaust duct. The angular spacing of the holes must be approximately equal. The angular spacing of any two holes in one plane may not be $180^\circ \pm 20^\circ$ (i.e., section C-C of Figure D79-2). The holes should be sized such that each has approximately the same flow. If only three holes are used, they may not all be in the same radial plane. See Figure D79-2.

(3) The probe shall extend radially across the exhaust duct. The probe must pass through the approximate center and must extend across at least 80 percent of the diameter of the duct.

(c) *Sample transfer.* (1) The maximum I.D. of the sample line shall not exceed 0.52 inch.

(2) If valve V2 is used, the sample probe must connect directly to valve V2. The location of optional valve V2 may not be greater than 4 feet from the exhaust duct.

(3) The location of optional valve V16 may not be greater than 24 inches from the sample pump. The leakage rate for this section on the pressure side of the sample pump may not exceed the leakage rate specification for the vacuum side of the pump.


(d) *Venting.* All vents including analyzer vents, bypass flow, and pressure relief vents of regulators should be vented in such a manner to avoid endangering personnel in the immediate area.

(42 FR 45154, Sept. 8, 1977, as amended at 46 FR 50495, Oct. 13, 1981, and 47 FR 49807, Nov. 2, 1982)

§ 86.311-79 Miscellaneous equipment; specifications.

(a) *Chart recorders.* (1) The minimum chart speed allowed is 3 inches per minute for gasoline-fueled engines and 0.5 inches per minute for Diesel engines.

(2) When testing gasoline-fueled engines all chart recorders (analyzers, torque, rpm, etc.) shall be provided with Automatic markers which indicate one second intervals. Preprinted chart paper (one second intervals) may be used in lieu of the automatic



(3) The sample line outside wall temperature must be maintained at the graph. An exception is made for the first 4 feet of sample line from the exhaust duct. The upper temperature tolerance for this 4 foot section is waived and only the minimum temperature specification applies.

(b) *Sample probe.* (1) The sample probe shall be a straight, closed end, stainless steel, multi-hole probe. The Inside Diameter (I.D.) shall not be greater than the I.D. of the sample line (+0.010 in.). The wall thickness of the probe shall not be greater than .040 inch. The fitting that attaches the probe to the exhaust pipe shall be as small as practical in order to minimize heat loss from the probe.

(2) There shall be a minimum of three holes in the probe. The spacing

markers provided the correct chart speed is used.

(b) *Accuracy of temperature measurements.* (1) The following temperature measurements shall be accurate to within 1.2° C:

(i) Temperature measurements used in calculating the engine intake humidity;

(ii) The temperature of the fuel in volume measuring flow rate devices;

(iii) The temperature of the sample within the water trap(s).

(2) All other temperature measurements shall be accurate within 2.5° C.

(c) *Intake air humidity and temperature measurements.* (1) Humidity conditioned air supply. Air that has had its absolute humidity altered is considered humidity-conditioned air. For this type of intake air supply, the humidity measurements must be made within the intake air supply system, and after the humidity conditioning has taken place.

(2) Nonconditioned air supply. Humidity measurements in non-conditioned intake air supply systems must be made in the intake air stream entering the supply system. Alternatively, the humidity measurements can be measured within the intake air supply stream.

(3) Engine intake air temperature measurement must be made within 48 inches of the engine. The measurement location must be made either in the supply system or in the air stream entering the supply system.

(d) *Sample component surface temperature.* For each component (pump, sample line section, filters, etc.) in the heated portion of the sampling system that has a separate source of power or heating element, use engineering judgment to locate the coolest portion of that component and monitor the temperature at that location. If several components are within an oven, then only the surface temperature of the component with the largest thermal mass and the oven temperature need be measured.

(e) If water is removed by condensation, the sample gas temperature or sample dew point must be monitored either within the water trap or downstream. It may not exceed 7°C (45°F).

(42 FR 45154, Sept. 8, 1977, as amended at 46 FR 50495, Oct. 13, 1981; 47 FR 49807, Nov. 2, 1982)

§ 86.312-79 Dynamometer and engine equipment specifications.

(a) *Dynamometer.* (1) The dynamometer test stand and other instruments for measurement of power output shall be accurate to within 2 percent of point at all power settings above 10 percent of full-scale. Below 10 percent of full-scale the accuracy shall be within 5 percent of point. The dynamometer must be capable of performing the test cycle described in § 86.335 or § 86.336. Dynamometers used for testing gasoline-fueled engines must have sufficient motoring capability to meet the test requirements. A 60-tooth wheel in combination with a frequency counter shall be considered an absolute standard for engine speed.

(2) *Dynamometer calibration weights.* A minimum of 6 calibration weights for each range used are required. The weights must be equally spaced and traceable to within 0.5 percent of NBS weights. Laboratories located in foreign countries may certify calibration weights to local government bureau standards.

(b) *Engine cooling.* Means of engine cooling which will maintain the engine operating temperatures (e.g., intake air, oil, water, etc.) at approximately the same temperature as specified by the manufacturer shall be used. Auxiliary fan(s) may be used to maintain engine cooling during operation on the dynamometer.

(c) *Exhaust system.* (1) When testing gasoline-fueled engines:

(i) A chassis-type exhaust system including muffler(s) shall be used. The exhaust system must have a single tail pipe. For engines designed for a dual exhaust system, a standard or specially fabricated "Y" pipe may be used. The "Y" pipe may be located upstream of a single muffler or downstream of dual mufflers. The potential increase in backpressure due to the use of a single tail pipe instead of dual pipes may be compensated for by using larger than standard exhaust system components downstream of the

ANALYZER NOISE CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315.79)

Date: 9-26-90 Analysis Bench: 4

Operator: D.A.P.

Analyzer: NO

Analyzer Serial No. 10AR-13640-140

Analyzer Range: 250 PPM

Analyzer Range: 1000 PPM

Span Gas Conc.: 236 PPM

Span Gas Conc.: 963 PPM

Bottle No.: CC 17410

Bottle No.: CC 49793

Analyzer PTP Response with Zero Gas.
Chart Deflection: 0

Analyzer PTP Response with Zero Gas.
Chart Deflection: 0

Analyzer PTP Response with Span Gas.
Chart Deflection: 94.2 to 94.7

Analyzer PTP Response with Span Gas.
Chart Deflection: 96.2 to 96.6

Noise: .53 % FSCD

Noise: .415 % FSCD

Analyzer Range: 2500 PPM

Analyzer Range: 10,000 PPM

Span Gas Conc.: 2409 PPM

Span Gas Conc.: 9539 PPM

Bottle No.: CC 49806

Bottle No.: CC 49803

Analyzer PTP Response with Zero Gas.
Chart Deflection: 0

Analyzer PTP Response with Zero Gas.
Chart Deflection: 0

Analyzer PTP Response with Span Gas.
Chart Deflection: 96.0 to 96.4

Analyzer PTP Response with Span Gas.
Chart Deflection: 95.2 to 95.8

Noise: .415 % FSCD

Noise: .629 % FSCD

1. Zero and span analyzer on all analyzer ranges.
2. Note analyzer peak-to-peak (PTP) response to zero and span gas over a ten second interval.
3. Noise shall not exceed 2% of full scale chart deflection (FSCD) on all ranges used.

ANALYZER RESPONSE TIME CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: 9-27-90

Analysis Bench: 4

Operator: D.A.P

Analyzer: NO

Analyzer Serial No.: 10AR-13640-140

Analyzer Range: 250 PPM

Analyzer Range: 1000 PPM

Step Gas Conc.: 236

Step Gas Conc.: 963

Chart Deflection for
95% of Step Gas: 89.7

Chart Deflection for
95% of Step Gas: 91.5

Time to Respond to
95% of Step Gas: 11.8 sec.

Time to Respond to
95% of Step Gas: 11.9 sec.

Analyzer Gas Flow: 2 scfh

Analyzer Gas Flow: 2 scfh

Analyzer Range: 2500 PPM

Analyzer Range: _____

Step Gas Conc.: 2409

Step Gas Conc.: _____

Chart Deflection for
95% of Step Gas: 91.5

Chart Deflection for
95% of Step Gas: _____

Time to Respond to
95% of Step Gas: 16.2 sec.

Time to Respond to
95% of Step Gas: _____ sec.

Analyzer Gas Flow: 2 scfh

Analyzer Gas Flow: _____ scfh

1. Set chart speed at 60 cm/min. to record the following data:
2. Zero/span analyzer on respective range.
3. Introduce to inlet, step change gas of at least 60% of full scale chart deflection. (Step gas in W.E.D. lab is equivalent to span gas.)
4. Begin timing moment analyzer begins to respond to gas and stop timing when analyzer has responded to 95% of step gas concentration. (Chart recorder may be used as a timer, i.e. each cm division = 1 sec.)
5. Analyzer response time may not exceed 6.0 seconds for any analyzer range used.
6. Condensate bath may be by-passed when performing NO analyzer response time.

ANALYZER ZERO AND SPAN DRIFT

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: 10-1-90 Analysis Bench: 4

Operator: D.A.P.

Analyzer: NO

Analyzer Serial No.: 10AR-13640-140

Analyzer Range: 250 PPM

Zero Gas: X N 2 Zero Air

Span Gas Bottle No.: CC17410

Zero Gas Response: 0 (% FSCD/30 SEC.)

Span Gas Response: .015 (% FSCD/30 SEC.)

Zero Drift: 0 % FSCD/HR.

Span Drift: 1.801 % FSCD/HR.

1. Zero and span analyzer on lowest range used.
2. Set chart speed at 10 ~~cm/min~~ 4.
3. Offset zero reading on chart, introduce zero gas over a 1 hour time period.
4. Determine average zero gas response over a 30 second time interval. Evaluate average zero gas response for 1 hour time period to determine drift.
5. Zero gas drift must be not more than 2% of full scale chart deflection (FSCD) over a 1 hour time period.
6. Rezero analyzer, check zero and span points.
7. Introduce span gas over a 1 hour time period.
8. Continue with steps 3 and 4 for span gas.
9. Retain chart paper to file with this page.

CHEMILUMINESCENT ANALYZER QUENCH CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.327-79)

Date: 9-28-90 Analysis Bench: .4
Operator: D.A.P. Barometer: 29.19 In. Hg.
Wet Bulb: 62 °F. Dry Bulb: 74 °F.
Analyzer Serial No.: 10AR-13640-140
Analyzer Range: 250 PPM
CO₂ Cal. Gas Conc.: 15.20 NO Cal. Gas Conc.: 236
Bottle No.: 421806 Bottle No.: CC17410
CO₂ Anal. Response: 9.16 ppm
Blend Ratio = $\frac{\text{CO}_2 \text{ AR}}{\text{CO}_2 \text{ Gas Conc.}}$ = .602
Calculated NO Conc. = NO Calc. Gas Conc. X (1 - Blend Ratio) = 93.9 ppm
Chemi. Anal. Response: 97.0 ppm
% Response Difference = $\frac{\text{Calculated NO Conc.} - \text{Chemi AR}}{\text{Full Scale NO Conc.}} \times 100$ = -1.24 %

1. Zero and span analyzer on lowest range used.
2. Blend CO₂ cal. gas and NO cal. gas using divider.
3. Analyze CO₂/NO mixture for CO₂ conc.
4. Determine true NO concentration.
5. CO₂ concentration of blended mixture should equal approximately 12%.
6. Record Chemi. analyzer response.
7. Recheck zero and span if changed more than ± 1% of full scale, repeat Steps 1-7.
8. Determine % response difference.
9. % response difference must not be greater than 3%.

"Rev. 4/85"

NO_x CONVERTER EFFICIENCY DATA

(F.R. VOL. 42, NO. 174, 10/8/77 86.332-79)

Date: 10-1-90 Bench No.: 4

Operator: D.A.P.

NO Analyzer Range: 1000 PPM Converter Temp: 391

NO Bottle Conc: 963 PPM O₂ Bottle Conc.: 99.9%

NO Bottle No.: CC 49793

1. Supply 100% O₂ to "DRY AIR" input on NO generator.
2. Select most common NO analyzer range not over 1000 ppm. Supply zero and span gas to rear of the bench (span port).
3. Set up as follows:
 - A. Bench switched to "COND BYPASS" ("BATH BYPASS").
 - B. Bench switched to "BYPASS CONVERTER".
 - C. Bench "NO Generator" solenoid switch on.
 - D. Bench NO analyzer main and bypass flow controls full open.
 - E. Adjust zero and span flowrates to 8 scfh using the NO generator "NITRIC OXIDE" flowmeter. Switch between "NO_x" and "NO" mode (converter bypassed) balancing flows with bypass needle valve.
 - F. Set NO_x generator "DRY AIR" and "OZONE BYPASS" flowmeters to 0 (off).
 - G. Verify that the "OZONE & AIR SHUTOFF" valve is closed.
 - H. Turn on temp controller for converter and NO sample lines.
4. With NO_x generator "POWER" switch OFF, zero and span the analyzer (analyzer is now in "NO" mode). Record NO reading.

DVM	PPM
<u>96.3</u>	<u>963</u>
5. Open the "OZONE & AIR SHUTOFF" valve.
6. Adjust "DRY AIR" flowrate so that the NO indicated by the analyzer is about 10% less than that in Step 4. Record the concentration of this NO + O₂ mixture.

<u>86.5</u>	<u>865</u>
-------------	------------
7. Turn on the NO generator "POWER" switch.
8. Adjust "OZONE BYPASS" to about 1 scfh.

9. Adjust "OZONE FLOW" needle valve so that the NO measured by the analyzer is about 20% of that in Step 4. There must be at least 10% unreacted NO at this point. Record the concentration of NO. 19.3 193
10. Switch the bench to the "NO_x" mode (NO_x converter NOT bypassed), and measure total NO_x; record this value. 80.0 800
11. Turn off the NO_x generator "POWER". The analyzer will now indicate the Total NO_x in the NO + O₂ mixture. Record this value. 82.2 822
12. Close the "OZONE & AIR SHUTOFF" valve. The analyzer will now indicate the NO_x in the original NO/N₂ mixture (span gas). This value should be no more than 5% above the value in Step 4.
13. Calculate the efficiency by substituting the appropriate concentrations (ppm) into the following equation:

$$\text{efficiency} = 1 + \frac{10 - 11}{6 - 9} \times 100 = \underline{96.73 \%}$$

The efficiency must be at least 90%. If not recheck and/or adjust converter temperature.

See HORIBA NO_x generator manual.

ANALYZER LINEARITY CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.330, 331, 332-79)

DATE: 9-27-90 ANALYSIS BENCH: 4 OPERATOR: D.A.P. BAROMETER: 29.13 IN.HG.
ANALYZER: NO ANALYZER SERIAL NO.: 10AB-13640-140 WET BULB: 66 °F DRY BULB: 78 °F
PRESSURES: FID FUEL: _____ KG/CM² FID AIR: _____ KG/CM² FID REG. AIR: _____ KG/CM²
REGULATOR AIR: _____ PSI FID BYPASS: _____ BENCH MANIFOLD: _____

Analyzer Range: <u>2500 PPM</u>	Analyzer Range: <u>1000 PPM</u>	Analyzer Range: <u>2500 PPM</u>	Analyzer Range: _____
Bottle No.: <u>CC17410</u>	Bottle No.: <u>CC49793</u>	Bottle No.: <u>CC49806</u>	Bottle No.: _____
Gas Concentration	Gas Concentration	Gas Concentration	Gas Concentration
<u>236</u>	<u>96.3</u>	<u>2409</u>	_____
<u>188.8</u>	<u>770.4</u>	<u>1927.2</u>	_____
<u>141.6</u>	<u>577.8</u>	<u>1445.4</u>	_____
<u>94.4</u>	<u>385.2</u>	<u>963.6</u>	_____
<u>47.2</u>	<u>192.6</u>	<u>481.8</u>	_____
<u>0</u>	<u>0</u>	<u>0</u>	_____
Response (mv)	Response (mv)	Response (mv)	Response (mv)
<u>94.4</u>	<u>96.3</u>	<u>96.4</u>	_____
<u>75.9</u>	<u>77.3</u>	<u>78.2</u>	_____
<u>56.9</u>	<u>58.4</u>	<u>59.1</u>	_____
<u>38.0</u>	<u>39.3</u>	<u>39.7</u>	_____
<u>19.1</u>	<u>19.9</u>	<u>20.3</u>	_____
<u>.3</u>	<u>.4</u>	<u>.6</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

1. Zero and span analyzer via calibration port.
2. Introduce N₂ and span gas to divider inlets at specified pressures.
3. Introduce divider output to analyzer via calibration port, verifying previously set span point (divider set at 100%). If span readings do not agree, adjust divider bypass flow.
4. Record analyzer mv output above, save chart paper for files.
5. Repeat Steps 1-4 for each range used.

ANALYZER PRECISION CHECK

(F.R. VOL. 44, NO. 174, 3/29/79, 86.315.79)

ANALYSIS BENCH: 4 ANALYZER: 9-26-90 ANALYZER SERIAL NO.: 10A-F-13640-1740 OPERATOR: D.A.P.ANALYZER: NOAnalyzer Range: 250 PPM
Gas Conc.: 236 PPM
Point: 94.4 mv
Bottle No.: CC 17410

No.	Response (mv)
1	<u>94.4</u>
2	<u>94.4</u>
3	<u>94.4</u>
4	<u>94.4</u>
5	<u>94.2</u>
6	<u>94.3</u>
7	<u>94.4</u>
8	<u>94.5</u>
9	<u>94.5</u>
10	<u>94.4</u>

Analyzer Range: 1000 PPM
Span Gas Conc.: 963 PPM
Span Point: 96.3 mv
Bottle No.: CC 49793

Test No.	Response (mv)
1	<u>96.3</u>
2	<u>96.3</u>
3	<u>96.2</u>
4	<u>96.1</u>
5	<u>96.4</u>
6	<u>96.3</u>
7	<u>96.3</u>
8	<u>96.1</u>
9	<u>96.2</u>
10	<u>96.1</u>

Analyzer Range: 2500
Span Gas Conc.: 2409
Span Point: 96.4 mv
Bottle No.: CC 49806

Test No.	Response (mv)
1	<u>96.4</u>
2	<u>96.5</u>
3	<u>96.4</u>
4	<u>96.5</u>
5	<u>96.3</u>
6	<u>96.2</u>
7	<u>96.4</u>
8	<u>96.4</u>
9	<u>96.5</u>
10	<u>96.5</u>

Analyzer Range: 10,000
Span Gas Conc.: 9539
Span Point: 95.4 mv
Bottle No.: CC 49803

Test No.	Response (mv)
1	_____
2	_____
3	_____
4	_____
5	_____
6	_____
7	_____
8	_____
9	_____
10	_____

Zero and span analyzer 10 times. (Do not readjust zero and span after initial adjustments.)
Record span response (mv), also retain chart paper for files.
Repeat steps 1 and 2 for each range used.
Input data into computer program to determine precision of analyzer.

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/27/90

BENCH: 4

OPERATOR'S INITIALS: DAP

BAROMETER: 29.13 IN HG

DRY BULB: 78 F

WET BULB: 66 F

ANALYZER: CHEMI

RANGE: 250 PPM

CONCENTRATION & CYLINDER NUMBER: 236/CC17410

PRECISION CHECK ANALYZER RESPONSES: 94.4 94.4 94.4
94.4 94.2 94.3 94.4 94.5 94.5 94.4

ANALYZER RANGE PRECISION IS : +.22% OF FULL SCALE

ANALYZER RANGE LINEARITY CHECK

ANALYZER RESPONSE	ACTUAL PPM	PREDICTED PPM	PERCENT LINEARITY
94.4	236.00	235.32	.27
75.9	188.80	189.20	-.16
56.9	141.60	141.84	-.10
38.0	94.40	94.73	-.13
19.1	47.20	47.61	-.17
.3	0.00	.75	-.30

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/27/90

BENCH: 4
OPERATOR'S INITIALS: DAP
BAROMETER: 29.13 IN HG
DRY BULB: 78 F
WET BULB: 66 F

ANALYZER: CHEMI
RANGE: 1000 PPM
CONCENTRATION & CYLINDER NUMBER: 963/CC49793

PRECISION CHECK ANALYZER RESPONSES: 96.3 96.3 96.2
6.1 96.4 96.3 96.3 96.1 96.2 96.1

ANALYZER RANGE PRECISION IS : +.26% OF FULL SCALE

ANALYZER RANGE LINEARITY CHECK

ANALYZER RESPONSE	ACTUAL PPM	PREDICTED PPM	PERCENT LINEARITY
96.3	963.00	958.33	.47
77.3	770.40	769.25	.12
58.4	577.80	581.17	-.34
39.3	385.20	391.09	-.59
19.9	192.60	198.04	-.55
.4	0.00	3.98	-.40

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/27/90

BENCH: 4

OPERATOR'S INITIALS: DAP

BAROMETER: 29.13 IN HG

DRY BULB: 78 F

WET BULB: 66 F

ANALYZER: CHEMI

RANGE: 2500 PPM

CONCENTRATION & CYLINDER NUMBER: 2409/CC49806

PRECISION CHECK ANALYZER RESPONSES: 96.4 96.5 96.4
96.5 96.3 96.2 96.4 96.4 96.5 96.5

ANALYZER RANGE PRECISION IS : +.25% OF FULL SCALE

ANALYZER RANGE LINEARITY CHECK

ANALYZER RESPONSE	ACTUAL PPM	PREDICTED PPM	PERCENT LINEARITY
96.4	2409.00	2383.02	1.05
78.2	1927.20	1933.12	-.24
59.1	1445.40	1460.96	-.63
39.7	963.60	981.39	-.72
20.3	481.80	501.82	-.81
.6	0.00	14.83	-.60

ANALYZER NOISE CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315.79)

Date: 9-24-90 Analysis Bench: 4

Operator: D.A.P.

Analyzer: CO

Analyzer Serial No. 4824705

Analyzer Range: 2500 PPM

Span Gas Conc.: 22.00

Bottle No.: 527884

Analyzer PTP Response with Zero Gas.
Chart Deflection: -2 to 0

Analyzer PTP Response with Span Gas.
Chart Deflection: 88.6 to 88.9

Noise: .56 % FSCD

Analyzer Range: 5%

Span Gas Conc.: 4.5%

Bottle No.: 58150

Analyzer PTP Response with Zero Gas.
Chart Deflection: 0

Analyzer PTP Response with Span Gas.
Chart Deflection: 95.6 to 95.7

Noise: .104 % FSCD

Analyzer Range: 1%

Span Gas Conc.: .95%

Bottle No.: J03007

Analyzer PTP Response with Zero Gas.
Chart Deflection: 0 to .1

Analyzer PTP Response with Span Gas.
Chart Deflection: 96.8 to 96.9

Noise: .207 % FSCD

Analyzer Range: _____

Span Gas Conc.: _____

Bottle No.: _____

Analyzer PTP Response with Zero Gas.
Chart Deflection: _____

Analyzer PTP Response with Span Gas.
Chart Deflection: _____

Noise: _____ % FSCD

1. Zero and span analyzer on all analyzer ranges.
2. Note analyzer peak-to-peak (PTP) response to zero and span gas over a ten second interval.
3. Noise shall not exceed 2% of full scale chart deflection (FSCD) on all ranges used.

ANALYZER RESPONSE TIME CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: 9-25-90

Analysis Bench: 4

Operator: D.A.P.

Analyzer: CO

Analyzer Serial No.: 4824705

Analyzer Range: 2500 PPM

Analyzer Range: 5%

Step Gas Conc.: 2200

Step Gas Conc.: 4.5%

Chart Deflection for
95% of Step Gas: 84.7

Chart Deflection for
95% of Step Gas: 93.5

Time to Respond to
95% of Step Gas: 4.1 sec.

Time to Respond to
95% of Step Gas: 3.7 sec.

Analyzer Gas Flow: 3 scfh

Analyzer Gas Flow: 3 scfh

Analyzer Range: 1%

Analyzer Range: _____

Step Gas Conc.: .95%

Step Gas Conc.: _____

Chart Deflection for
95% of Step Gas: 93.2

Chart Deflection for
95% of Step Gas: _____

Time to Respond to
95% of Step Gas: 3.9 sec.

Time to Respond to
95% of Step Gas: _____ sec.

Analyzer Gas Flow: 3 scfh

Analyzer Gas Flow: _____ scfh

1. Set chart speed at 60 cm/min. to record the following data:
2. Zero/span analyzer on respective range.
3. Introduce to inlet, step change gas of at least 60% of full scale chart deflection. (Step gas in W.E.D. lab is equivalent to span gas.)
4. Begin timing moment analyzer begins to respond to gas and stop timing when analyzer has responded to 95% of step gas concentration. (Chart recorder may be used as a timer, i.e. each cm division = 1 sec.)
5. Analyzer response time may not exceed 6.0 seconds for any analyzer range used.
6. Condensate bath may be by-passed when performing NO analyzer response time.

ANALYZER ZERO AND SPAN DRIFT

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: 10-1-90 Analysis Bench: 4

Operator: D.A.P.

Analyzer: CO

Analyzer Serial No.: 4824705

Analyzer Range: 2500 PPM

Zero Gas: X N 2 Zero Air

Span Gas Bottle No.: 527884

Zero Gas Response: .002 (% FSCD/30 SEC.)

Span Gas Response: .003 (% FSCD/30 SEC.)

Zero Drift: -.2 % FSCD/HR.

Span Drift: .338 % FSCD/HR.

1. Zero and span analyzer on lowest range used.
2. Set chart speed at 10 cm/min. 4.
3. Offset zero reading on chart, introduce zero gas over a 1 hour time period.
4. Determine average zero gas response over a 30 second time interval. Evaluate average zero gas response for 1 hour time period to determine drift.
5. Zero gas drift must be not more than 2% of full scale chart deflection (FSCD) over a 1 hour time period.
6. Rezero analyzer, check zero and span points.
7. Introduce span gas over a 1 hour time period.
8. Continue with steps 3 and 4 for span gas.
9. Retain chart paper to file with this page.

NDIR WATER REJECTION RATIO CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.316, 86.318, 86.331-79)

Date: 9-24-90 Analysis Bench: 4

Operator: D.A.P. Barometer: 29.17

Analyzer: CO

Analyzer Range: 2500

Analyzer Serial No.: 4824705

1. Zero/span on lowest range used.
2. Bubble zero gas through distilled water and introduce water/gas mixture directly to analyzer inlet.
3. Record water/gas mixture temperature: 74 °F.
4. Record analyzer operating pressure: 3 In. H₂O, 10839 PSI (gage).
5. Record analyzer response to water/gas mixture: 4.85 ppm.
6. Determine the water concentration using:

$$W.C. = \frac{\text{Saturation Vapor Pressure (SVP, psi)}}{\text{Absolute Gage Pressure (AGP, psi)}} \times 10^6$$

SVP is found from saturation vapor pressure table @ water/gas mixture temperature: .4155 psi.

AGP is the gage pressure (psi) + the barometer (psi): 14.436694 psi.

(0.03613 psi/in H₂O, 0.4912 psi/in. Hg)

W.C. 28780.82752.

7. Determine water rejection ratio using:

$$WRR = \frac{\text{Water Concentration}}{\text{Anal. Response in ppm}} = \underline{5934.191242}$$

8. Minimum WRR CO Analyzer - 1000:1.
9. Minimum WRR CO₂ Analyzer - 100:1.
10. Minimum WRR NO Analyzer - 5000:1.

NDIR CO₂ REJECTION RATIO CHECK

F.R. VOL. 42, NO. 174, 10/8/79, 86.316, 86.318, 86.332-79)

Date: 9-24-90 Analysis Bench: 4

Operator: D.A.P.

Analyzer: CO Serial No.: 4824705

Analyzer Range: 2500

CO₂ Concentration: 14.89

1. Zero/span on lowest range used.

2. Introduce a CO₂ calibration gas of at least 10% CO₂ to the analyzer.

3. Record analyzer response to CO₂: 24 ppm.

4. Calculate CO₂ rejection ratio using:

$$\text{CO}_2\text{RR} = \frac{\text{CO}_2 \text{ Conc. in ppm}}{\text{Anal. Resp. in ppm}} = \underline{6204.166667}$$

5. Minimum CO₂RR CO analyzer - 5000.

6. Minimum CO₂RR NO analyzer - 30,000.

NDIR ANALYZER CALIBRATION

(F.R. VOL. 42, NO. 174, 10/8/77, 86.330-79)

DATE: 9-25-90 ANALYSIS BENCH: 4 OPERATOR: D.A.P. BAROMETER: 28.79 IN.HG
 ANALYZER: C0 ANALYZER SERIAL NO.: 4824705 WET BULB: 59 °F DRY BULB: 74 °F

Bottle No.: <u>527884</u>			Bottle No.: <u>58150</u>			Bottle No.: _____		
Analyzer Range: <u>2500 PPM</u>			Analyzer Range: <u>5%</u>			Analyzer Range: _____		
Gas Concentration	Response (mv)		Gas Concentration	Response (mv)		Gas Concentration	Response (mv)	
<u>2200</u>	<u>88.7</u>		<u>4.50</u>	<u>95.7</u>				
<u>1760</u>	<u>72.3</u>		<u>3.60</u>	<u>86.0</u>				
<u>1320</u>	<u>55.1</u>		<u>2.70</u>	<u>74.0</u>				
<u>880</u>	<u>37.3</u>		<u>1.80</u>	<u>58.3</u>				
<u>440</u>	<u>18.9</u>		<u>.90</u>	<u>35.9</u>				
<u>0</u>	<u>0</u>		<u>0</u>	<u>0</u>				

1. Zero and span analyzer via calibration port.
 2. Introduce N2 and span gas to divider inlets at specified pressures.
 3. Introduce divider output to analyzer via calibration port, verifying previously set span point (divider set at 100%).
 4. If span readings do not agree, adjust divider bypass flow.
 5. Record analyzer mv output* above, save chart paper for files.
- * Repeat Steps 1-4 for each range used.
- * Correct CO2 values per gas divider CO2 correction chart.

ANALYZER PRECISION CHECK

(F.R. VOL. 44, NO. 174, 3/29/79, 86.315.79)

ANALYZER: 9-24-90 ANALYSIS BENCH: 4 OPERATOR: D.A.P.

ANALYZER: CO ANALYZER SERIAL NO.: 4824705

No.	Response (mv)	Test No.	Response (mv)	Test No.	Analyzer Range:	Analyzer Range:
1	88.7	1	95.7	1	5%	5%
2	88.7	2	95.7	2	Span Gas Conc.: 4.5%	Span Gas Conc.: 4.5%
3	88.7	3	95.7	3	Span Point: 95.7 mv	Span Point: 95.7 mv
4	88.6	4	95.7	4	Bottle No.: 58150	Bottle No.: 58150
5	88.7	5	95.6	5		
6	88.8	6	95.6	6		
7	88.8	7	95.6	7		
8	88.7	8	95.6	8		
9	88.8	9	95.6	9		
10	88.9	10	95.7	10		

Zero and span analyzer 10 times. (Do not readjust zero and span after initial adjustments.)
 Record span response (mv), also retain chart paper for files.
 Repeat steps 1 and 2 for each range used.
 Input data into computer program to determine precision of analyzer.

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/25/90

BENCH: 4

OPERATOR'S INITIALS: DAF

BAROMETER: 28.79 IN HG

DRY BULB: 74 F

WET BULB: 59 F

ANALYZER: NDIR CO

RANGE: 2500 PPM

CONCENTRATION & CYLINDER NUMBER: 2200/527884

ANALYZER PERFORMANCE BASED UPON OLD REGRESSION DATA OF 8/22/88

OLD REGRESSION COEFFICIENTS

+1.98645E-001 +2.38793E+001 -1.50581E-002 +3.58099E-004 -8.07689E-007

ANALYZER ERROR TABLE

OLD REGRESSION DATA OF: 8/22/88

ANALYZER RESPONSE	ACTUAL PPM	PREDICTED PPM	% ERROR OF POINT	% ERROR OF FULL SCALE
88.7	2200.00	2199.73	-.01	-.01
72.3	1760.00	1761.23	.07	.05
55.1	1320.00	1322.69	.20	.11
37.3	880.00	886.97	.79	.28
18.9	440.00	448.45	1.92	.34
0.0	0.00	.20	0.00	.01

NEW REGRESSION MODEL DATE: 9/25/90

$$\text{PPM NDIR CO} = +2.86387\text{E}-002 + (+2.29295\text{E}+001) * (\text{AR}) + (+1.87880\text{E}-002) * (\text{AR}^2) + (-5.60854\text{E}-005) * (\text{AR}^3) + (+9.27330\text{E}-007) * (\text{AR}^4)$$

ANALYZER ERROR TABLE

NEW REGRESSION DATA OF: 9/25/90

ANALYZER RESPONSE	ACTUAL PPM	PREDICTED PPM	% ERROR OF POINT	% ERROR OF FULL SCALE
88.7	2200.00	2199.96	-.00	-.00
72.3	1760.00	1760.19	.01	.01
55.1	1320.00	1319.65	-.03	-.01
37.3	880.00	880.32	.04	.01
18.9	440.00	439.85	-.03	-.01
0.0	0.00	.03	0.00	.00

PRECISION CHECK ANALYZER RESPONSES: 88.7 88.7 88.7
88.6 88.7 88.8 88.8 88.7 88.8 88.9

ANALYZER RANGE PRECISION IS : +.23% OF FULL SCALE

"Rev. 4/85"

EMISSION INSTRUMENT CALIBRATION CHART

ANALYZER: NDIR CO 2500 PPM
DATE OF CALIBRATION REGRESSION: 9/25/90
DATE OF LATEST CALIBRATION CHECK: 9/25/90

ANALYZER RESPONSE VERSUS CONCENTRATION

.5	11.50	25.5	596.41	50.5	1204.69	75.5	1844.30
1.0	22.98	26.0	608.34	51.0	1217.14	76.0	1857.51
1.5	34.47	26.5	620.27	51.5	1229.59	76.5	1870.74
2.0	45.96	27.0	632.21	52.0	1242.06	77.0	1883.99
2.5	57.47	27.5	644.16	52.5	1254.54	77.5	1897.26
3.0	68.98	28.0	656.12	53.0	1267.04	78.0	1910.55
3.5	80.51	28.5	668.09	53.5	1279.54	78.5	1923.86
4.0	92.04	29.0	680.07	54.0	1292.06	79.0	1937.19
4.5	103.59	29.5	692.06	54.5	1304.60	79.5	1950.53
5.0	115.14	30.0	704.06	55.0	1317.14	80.0	1963.90
5.5	126.70	30.5	716.07	55.5	1329.70	80.5	1977.29
6.0	138.27	31.0	728.09	56.0	1342.27	81.0	1990.70
6.5	149.85	31.5	740.11	56.5	1354.86	81.5	2004.13
7.0	161.44	32.0	752.15	57.0	1367.46	82.0	2017.58
7.5	173.04	32.5	764.19	57.5	1380.07	82.5	2031.06
8.0	184.64	33.0	776.25	58.0	1392.70	83.0	2044.55
8.5	196.26	33.5	788.31	58.5	1405.34	83.5	2058.07
9.0	207.88	34.0	800.39	59.0	1417.99	84.0	2071.61
9.5	219.51	34.5	812.47	59.5	1430.66	84.5	2085.16
10.0	231.16	35.0	824.56	60.0	1443.34	85.0	2098.75
10.5	242.81	35.5	836.67	60.5	1456.04	85.5	2112.35
11.0	254.47	36.0	848.78	61.0	1468.75	86.0	2125.98
11.5	266.13	36.5	860.91	61.5	1481.48	86.5	2139.63
12.0	277.81	37.0	873.04	62.0	1494.22	87.0	2153.30
12.5	289.50	37.5	885.18	62.5	1506.97	87.5	2166.99
13.0	301.19	38.0	897.34	63.0	1519.74	88.0	2180.71
13.5	312.89	38.5	909.50	63.5	1532.53	88.5	2194.46
14.0	324.61	39.0	921.68	64.0	1545.33	89.0	2208.22
14.5	336.33	39.5	933.86	64.5	1558.15	89.5	2222.01
15.0	348.06	40.0	946.06	65.0	1570.98	90.0	2235.83
15.5	359.80	40.5	958.26	65.5	1583.83	90.5	2249.66
16.0	371.54	41.0	970.48	66.0	1596.69	91.0	2263.53
16.5	383.30	41.5	982.70	66.5	1609.57	91.5	2277.42
17.0	395.06	42.0	994.94	67.0	1622.47	92.0	2291.33
17.5	406.84	42.5	1007.19	67.5	1635.38	92.5	2305.27
18.0	418.62	43.0	1019.45	68.0	1648.31	93.0	2319.23
18.5	430.41	43.5	1031.72	68.5	1661.25	93.5	2333.22
19.0	442.21	44.0	1044.00	69.0	1674.21	94.0	2347.23
19.5	454.02	44.5	1056.29	69.5	1687.19	94.5	2361.27
20.0	465.83	45.0	1068.60	70.0	1700.19	95.0	2375.34
20.5	477.66	45.5	1080.91	70.5	1713.20	95.5	2389.44
21.0	489.50	46.0	1093.24	71.0	1726.23	96.0	2403.56
21.5	501.34	46.5	1105.57	71.5	1739.28	96.5	2417.70
22.0	513.19	47.0	1117.92	72.0	1752.34	97.0	2431.88
22.5	525.05	47.5	1130.28	72.5	1765.42	97.5	2446.08
23.0	536.92	48.0	1142.65	73.0	1778.52	98.0	2460.31
23.5	548.80	48.5	1155.04	73.5	1791.64	98.5	2474.57
24.0	560.69	49.0	1167.43	74.0	1804.78	99.0	2488.85
24.5	572.59	49.5	1179.84	74.5	1817.93	99.5	2503.17
25.0	584.50	50.0	1192.26	75.0	1831.11	100.0	2517.51

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/25/90

BENCH: 4
OPERATOR'S INITIALS: DAP
BAROMETER: 28.79 IN HG
DRY BULB: 74 F
WET BULB: F

ANALYZER: NDIR CO
RANGE: 1%
CONCENTRATION & CYLINDER NUMBER: .95%/J03007

ANALYZER PERFORMANCE BASED UPON OLD REGRESSION DATA OF 11/17/89

OLD REGRESSION COEFFICIENTS

+2.42000E-002 +7.14846E+001 +2.61365E-001 -9.61423E-004 +1.14716E-005

ANALYZER ERROR TABLE

OLD REGRESSION DATA OF: 11/17/89

ANALYZER RESPONSE	ACTUAL PPM	PREDICTED PPM	% ERROR OF POINT	% ERROR OF FULL SCALE
96.8	9500.00	9503.96	.04	.04
81.8	7600.00	7583.71	-.21	-.16
64.8	5700.00	5670.37	-.52	-.30
45.8	3800.00	3780.38	-.52	-.20
24.4	1900.00	1889.95	-.53	-.10
0.0	0.00	.02	0.00	.00

PRECISION CHECK ANALYZER RESPONSES: 96.8 96.8 96.8
96.8 96.8 96.8 96.9 96.8 96.8 96.9

ANALYZER RANGE PRECISION IS : +.14% OF FULL SCALE

EMISSION INSTRUMENT CALIBRATION CHART

ANALYZER: NDIR CO 1%

DATE OF CALIBRATION REGRESSION: 11/17/89

DATE OF LATEST CALIBRATION CHECK: 9/25/90

ANALYZER RESPONSE VERSUS CONCENTRATION

.5	35.83	25.5	1981.74	50.5	4227.33	75.5	6845.94
1.0	71.77	26.0	2023.65	51.0	4275.62	76.0	6903.17
1.5	107.84	26.5	2065.68	51.5	4324.06	76.5	6960.63
2.0	144.03	27.0	2107.82	52.0	4372.65	77.0	7018.31
2.5	180.35	27.5	2150.07	52.5	4421.38	77.5	7076.22
3.0	216.81	28.0	2192.45	53.0	4470.26	78.0	7134.34
3.5	253.38	28.5	2234.94	53.5	4519.30	78.5	7192.70
4.0	290.09	29.0	2277.55	54.0	4568.49	79.0	7251.29
4.5	326.91	29.5	2320.28	54.5	4617.83	79.5	7310.11
5.0	363.87	30.0	2363.12	55.0	4667.32	80.0	7369.16
5.5	400.95	30.5	2406.09	55.5	4716.97	80.5	7428.44
6.0	438.15	31.0	2449.17	56.0	4766.78	81.0	7487.97
6.5	475.47	31.5	2492.37	56.5	4816.74	81.5	7547.73
7.0	512.92	32.0	2535.69	57.0	4866.87	82.0	7607.74
7.5	550.49	32.5	2579.14	57.5	4917.15	82.5	7667.99
8.0	588.18	33.0	2622.70	58.0	4967.60	83.0	7728.48
8.5	626.00	33.5	2666.38	58.5	5018.20	83.5	7789.23
9.0	663.93	34.0	2710.18	59.0	5068.98	84.0	7850.22
9.5	701.99	34.5	2754.10	59.5	5119.91	84.5	7911.47
10.0	740.16	35.0	2798.15	60.0	5171.02	85.0	7972.97
10.5	778.45	35.5	2842.32	60.5	5222.29	85.5	8034.73
11.0	816.87	36.0	2886.61	61.0	5273.73	86.0	8096.74
11.5	855.40	36.5	2931.03	61.5	5325.35	86.5	8159.02
12.0	894.05	37.0	2975.56	62.0	5377.13	87.0	8221.56
12.5	932.82	37.5	3020.23	62.5	5429.09	87.5	8284.37
13.0	971.71	38.0	3065.01	63.0	5481.22	88.0	8347.44
13.5	1010.72	38.5	3109.93	63.5	5533.53	88.5	8410.79
14.0	1049.84	39.0	3154.97	64.0	5586.02	89.0	8474.41
14.5	1089.08	39.5	3200.13	64.5	5638.69	89.5	8538.30
15.0	1128.44	40.0	3245.43	65.0	5691.53	90.0	8602.47
15.5	1167.91	40.5	3290.85	65.5	5744.56	90.5	8666.92
16.0	1207.50	41.0	3336.40	66.0	5797.78	91.0	8731.65
16.5	1247.21	41.5	3382.08	66.5	5851.18	91.5	8796.67
17.0	1287.03	42.0	3427.89	67.0	5904.77	92.0	8861.97
17.5	1326.97	42.5	3473.83	67.5	5958.54	92.5	8927.56
18.0	1367.03	43.0	3519.91	68.0	6012.51	93.0	8993.45
18.5	1407.20	43.5	3566.11	68.5	6066.66	93.5	9059.62
19.0	1447.48	44.0	3612.45	69.0	6121.01	94.0	9126.10
19.5	1487.89	44.5	3658.92	69.5	6175.56	94.5	9192.87
20.0	1528.41	45.0	3705.53	70.0	6230.30	95.0	9259.95
20.5	1569.04	45.5	3752.27	70.5	6285.24	95.5	9327.33
21.0	1609.79	46.0	3799.15	71.0	6340.38	96.0	9395.02
21.5	1650.66	46.5	3846.16	71.5	6395.72	96.5	9463.01
22.0	1691.64	47.0	3893.32	72.0	6451.27	97.0	9531.32
22.5	1732.73	47.5	3940.61	72.5	6507.02	97.5	9599.94
23.0	1773.94	48.0	3988.04	73.0	6562.98	98.0	9668.88
23.5	1815.27	48.5	4035.61	73.5	6619.14	98.5	9738.14
24.0	1856.72	49.0	4083.33	74.0	6675.52	99.0	9807.73
24.5	1898.28	49.5	4131.19	74.5	6732.11	99.5	9877.64
25.0	1939.95	50.0	4179.19	75.0	6788.92	100.0	9947.87

PPM NDIR CO = +2.42000E-002 +(+7.14846E+001)*(AR) +(+2.61365E-001)*(AR^2) +
 (-9.61423E-004)*(AR^3) +(+1.14716E-005)*(AR^4)

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/25/90

BENCH: 4
 OPERATOR'S INITIALS: DAP
 BAROMETER: 28.79 IN HG
 DRY BULB: 74 F
 WET BULB: F

ANALYZER: NDIR CO
 RANGE: 5%
 CONCENTRATION & CYLINDER NUMBER: 4.5%/58150

ANALYZER PERFORMANCE BASED UPON OLD REGRESSION DATA OF 11/17/89

OLD REGRESSION COEFFICIENTS

+2.18004E-005 +1.63868E-002 +2.79306E-004 -1.93603E-006 +2.46785E-008

ANALYZER ERROR TABLE					
OLD REGRESSION DATA OF: 11/17/89					
ANALYZER RESPONSE	ACTUAL %	PREDICTED %	% ERROR OF POINT	% ERROR OF FULL SCALE	
95.7	4.50	4.50	-.01	-.01	
86.0	3.60	3.59	-.18	-.13	
74.0	2.70	2.70	-.09	-.05	
58.3	1.80	1.81	.34	.12	
35.9	.90	.90	-.03	-.01	
0.0	0.00	.00	0.00	.00	

PRECISION CHECK ANALYZER RESPONSES: 95.7 95.7 95.7
 95.7 95.6 95.6 95.6 95.6 95.6 95.7

ANALYZER RANGE PRECISION IS : +.27% OF FULL SCALE

EMISSION INSTRUMENT CALIBRATION CHART

ANALYZER: NDIR CO 5%

DATE OF CALIBRATION REGRESSION: 11/17/89

DATE OF LATEST CALIBRATION CHECK: 9/25/90

ANALYZER RESPONSE VERSUS CONCENTRATION

.5	.01	25.5	.58	50.5	1.45	75.5	2.80
1.0	.02	26.0	.59	51.0	1.47	76.0	2.83
1.5	.03	26.5	.61	51.5	1.49	76.5	2.87
2.0	.03	27.0	.62	52.0	1.52	77.0	2.90
2.5	.04	27.5	.64	52.5	1.54	77.5	2.94
3.0	.05	28.0	.65	53.0	1.56	78.0	2.97
3.5	.06	28.5	.67	53.5	1.58	78.5	3.01
4.0	.07	29.0	.68	54.0	1.60	79.0	3.04
4.5	.08	29.5	.70	54.5	1.63	79.5	3.08
5.0	.09	30.0	.71	55.0	1.65	80.0	3.12
5.5	.10	30.5	.73	55.5	1.67	80.5	3.16
6.0	.11	31.0	.74	56.0	1.70	81.0	3.19
6.5	.12	31.5	.76	56.5	1.72	81.5	3.23
7.0	.13	32.0	.77	57.0	1.74	82.0	3.27
7.5	.14	32.5	.79	57.5	1.77	82.5	3.31
8.0	.15	33.0	.80	58.0	1.79	83.0	3.35
8.5	.16	33.5	.82	58.5	1.82	83.5	3.39
9.0	.17	34.0	.84	59.0	1.84	84.0	3.43
9.5	.18	34.5	.85	59.5	1.87	84.5	3.47
10.0	.19	35.0	.87	60.0	1.89	85.0	3.51
10.5	.20	35.5	.89	60.5	1.92	85.5	3.55
11.0	.21	36.0	.90	61.0	1.94	86.0	3.59
11.5	.22	36.5	.92	61.5	1.97	86.5	3.64
12.0	.23	37.0	.94	62.0	1.99	87.0	3.68
12.5	.25	37.5	.95	62.5	2.02	87.5	3.72
13.0	.26	38.0	.97	63.0	2.05	88.0	3.77
13.5	.27	38.5	.99	63.5	2.07	88.5	3.81
14.0	.28	39.0	1.01	64.0	2.10	89.0	3.85
14.5	.29	39.5	1.02	64.5	2.13	89.5	3.90
15.0	.30	40.0	1.04	65.0	2.15	90.0	3.95
15.5	.32	40.5	1.06	65.5	2.18	90.5	3.99
16.0	.33	41.0	1.08	66.0	2.21	91.0	4.04
16.5	.34	41.5	1.10	66.5	2.24	91.5	4.08
17.0	.35	42.0	1.11	67.0	2.27	92.0	4.13
17.5	.36	42.5	1.13	67.5	2.30	92.5	4.18
18.0	.38	43.0	1.15	68.0	2.32	93.0	4.23
18.5	.39	43.5	1.17	68.5	2.35	93.5	4.28
19.0	.40	44.0	1.19	69.0	2.38	94.0	4.33
19.5	.41	44.5	1.21	69.5	2.41	94.5	4.38
20.0	.43	45.0	1.23	70.0	2.44	95.0	4.43
20.5	.44	45.5	1.25	70.5	2.47	95.5	4.48
21.0	.45	46.0	1.27	71.0	2.51	96.0	4.53
21.5	.47	46.5	1.29	71.5	2.54	96.5	4.58
22.0	.48	47.0	1.31	72.0	2.57	97.0	4.64
22.5	.49	47.5	1.33	72.5	2.60	97.5	4.69
23.0	.51	48.0	1.35	73.0	2.63	98.0	4.74
23.5	.52	48.5	1.37	73.5	2.66	98.5	4.80
24.0	.54	49.0	1.39	74.0	2.70	99.0	4.85
24.5	.55	49.5	1.41	74.5	2.73	99.5	4.91
25.0	.56	50.0	1.43	75.0	2.76	100.0	4.96

% NDIR CO = +2.18004E-005 +(+1.63868E-002)*(AR) +(+2.79306E-004)*(AR^2) +
 (-1.93603E-006)*(AR^3) +(+2.46785E-008)*(AR^4)

ANALYZER NOISE CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315.79)

Date: <u>1-29-90</u>	Analysis Bench: <u>4</u>
Operator: <u>D.A.P.</u>	
Analyzer: <u>HC</u>	
Analyzer Serial No. <u>4812908</u>	
Analyzer Range: <u>1000</u>	Analyzer Range: <u>3000</u>
Span Gas Conc.: <u>909 PPMC</u>	Span Gas Conc.: <u>2661 PPMC</u>
Bottle No.: <u>N-340880</u>	Bottle No.: <u>72131</u>
Analyzer PTP Response with Zero Gas. Chart Deflection: <u>0</u>	Analyzer PTP Response with Zero Gas. Chart Deflection: <u>0</u>
Analyzer PTP Response with Span Gas. Chart Deflection: <u>90.9</u>	Analyzer PTP Response with Span Gas. Chart Deflection: <u>88.7</u>
Noise: <u>0</u> % FSCD	Noise: <u>0</u> % FSCD
Analyzer Range: _____	Analyzer Range: _____
Span Gas Conc.: _____	Span Gas Conc.: _____
Bottle No.: _____	Bottle No.: _____
Analyzer PTP Response with Zero Gas. Chart Deflection: _____	Analyzer PTP Response with Zero Gas. Chart Deflection: _____
Analyzer PTP Response with Span Gas. Chart Deflection: _____	Analyzer PTP Response with Span Gas. Chart Deflection: _____
Noise: _____ % FSCD	Noise: _____ % FSCD

1. Zero span analyzer on all analyzer ranges.
2. Note analyzer peak-to-peak (PTP) response to zero and span gas over a ten second interval.
3. Noise will not exceed 2% of full scale chart deflection (FSCD) on all ranges.

"Rev. 4/85"

ANALYZER RESPONSE TIME CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: 9-29-90

Analysis Bench: 4

Operator: D.A.P.

Analyzer: HC

Analyzer Serial No.: 4812908

Analyzer Range: 1000

Analyzer Range: 3000

Step Gas Conc.: 909 PPMC

Step Gas Conc.: 2661

Chart Deflection for
95% of Step Gas: 86.4

Chart Deflection for
95% of Step Gas: 84.3

Time to Respond to
95% of Step Gas: 3.1 sec.

Time to Respond to
95% of Step Gas: 3.1 sec.

Analyzer Gas Flow: 5 scfh

Analyzer Gas Flow: 5 scfh

Analyzer Range: _____

Analyzer Range: _____

Step Gas Conc.: _____

Step Gas Conc.: _____

Chart Deflection for
95% of Step Gas: _____

Chart Deflection for
95% of Step Gas: _____

Time to Respond to
95% of Step Gas: _____ sec.

Time to Respond to
95% of Step Gas: _____ sec.

Analyzer Gas Flow: _____ scfh

Analyzer Gas Flow: _____ scfh

1. Set chart speed at 60 cm/min. to record the following data:
2. Zero/span analyzer on respective range.
3. Introduce to inlet, step change gas of at least 60% of full scale chart deflection. (Step gas in W.E.D. lab is equivalent to span gas.)
4. Begin timing moment analyzer begins to respond to gas and stop timing when analyzer has responded to 95% of step gas concentration. (Chart recorder may be used as a timer, i.e. each cm division = 1 sec.)
5. Analyzer response time may not exceed 6.0 seconds for any analyzer range used.
6. Condensate bath may be by-passed when performing NO analyzer response time.

ANALYZER ZERO AND SPAN DRIFT

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: 10-1-90 Analysis Bench: 4

Operator: D.A.P.

Analyzer: HC

Analyzer Serial No.: 4812908

Analyzer Range: 1000 PPMC

Zero Gas: N₂ X Zero Air

Span Gas Bottle No.: N-340880

Zero Gas Response: 0 (% FSCD/30 SEC.)

Span Gas Response: .005 (% FSCD/30 SEC.)

Zero Drift: 0 % FSCD/HR.

Span Drift: .55 % FSCD/HR.

1. Zero and span analyzer on lowest range used.
2. Set chart speed at 10 cm/min. 4.
3. Offset zero reading on chart, introduce zero gas over a 1 hour time period.
4. Determine average zero gas response over a 30 second time interval. Evaluate average zero gas response for 1 hour time period to determine drift.
5. Zero gas drift must be not more than 2% of full scale chart deflection (FSCD) over a 1 hour time period.
6. Rezero analyzer, check zero and span points.
7. Introduce span gas over a 1 hour time period.
8. Continue with steps 3 and 4 for span gas.
9. Retain chart paper to file with this page.

HYDROCARBON ANALYZER O₂ INTERFERENCE

(F.R. VOL. 42, NO. 174, 10/8/77 86.331-79)

Date: 9-29-90 Analyzer Bench: 4

Operator: D.A.P.

Analyzer Serial No.: 4812908

Type of Sampling: Diesel Gasoline X Gaseous

FID Temperature: 369 Fuel Bottle No.: 5A 1431

Regulator Air Press: 6 psi Burner Air Bottle No.: CC56178

O ₂ Conc. (%)	HC Conc. (PPMC)	Bottle No.
20.99	943.2	CAL-8565
10.15	880.2	CAL-2976
5.03	887.55	CAL-4435

A = HC conc., PPMC of span gas used in Step 3.

B = HC conc., PPMC of O₂ interference gases used in Step 5.

Analyzer Response (ARPPM) A X % OF FSCD due to B.

% of FSCD due to A

(FSCD = Full Scale Chart Deflection)

% O₂ Interference (%O₂I) = $\frac{B-ARPPM}{B} \times 100$.

FUEL PRESS. (kg/cm ²)	AIR PRESS. (kg/cm ²)	BY-PASS PRESS.	FSCD A	FSCD B ₅	FSCD B ₁₀	ARPPM ₅	ARPPM ₁₀	%O ₂ I ₅	%O ₂ I ₁₀
.75	.75	6	94.3	87.9	87.7	879.19	877.19	.942	.342

1. Connect "Shop Air" to bench sample inlet (to simulate sample flow).
2. Zero analyzer.
3. Span analyzer with 21% O₂/propane blend for diesel, gaseous; 0% O₂ for gasoline.
4. Record mv output for 21% O₂ or 0% O₂ span gas.
5. Introduce 5 and 10% O₂ interference gases.
6. Record Full Scale Chart Deflection for 5 and 10% O₂ interference gases.
7. Determine analyzer response in PPM (ARPPM) for each gas, 5 and 10%.
8. Determine oxygen interference (%O₂I) for each gas, 5 and 10%.
9. % O₂I must be less than $\pm 3.0\%$ for all gases.
10. If %O₂I is not within specification, vary air flow, then fuel flow, and thereafter sample by-pass flow, repeating Steps 1 through 7 for each flow.

(F.R. VOL. 42, NO. 174, 10/8/77, 86.330, 331, 332-79)

Analyzer Range: 1000	Analyzer Range:	Analyzer Range:
Bottle No.: N-340880	Bottle No.: 72131	Bottle No.:

Gas Concentration	Response (mv)	Gas Concentration	Response (mv)	Gas Concentration	Response (mv)	Gas Concentration	Response (mv)
909	90.9	2661	88.7				
727.2	72.8	2128.8	71.2				
545.4	54.8	1596.6	53.4				
363.6	36.4	1064.4	35.6				
181.8	18.2	532.2	17.8				
0	0	0	1				

1. Zero and span analyzer via calibration port.
2. Introduce N₂ and span gas to divider inlets at specified pressures.
3. Introduce divider output to analyzer via calibration port, verifying previously set span point (divider set at 100%). If span readings do not agree, adjust divider bypass flow.
4. Record analyzer mv output above, save chart paper for files.
5. Repeat Steps 1-4 for each range used.

ANALYZER PRECISION CHECK

(F.R. VOL. 44, NO. 174, 3/29/79, 86.315.79)

DATE: 9-29-90 ANALYSIS BENCH: 4 OPERATOR: D.A.P.ANALYZER: HC ANALYZER SERIAL NO.: 4812908

Analyzer Range: 1000 PPMC
Span Gas Conc.: 909 PPMC
Span Point: 90.9 mv
Bottle No.: N-340880

Test No.	Response (mv)
1	<u>90.9</u>
2	<u>90.8</u>
3	<u>90.9</u>
4	<u>90.8</u>
5	<u>90.9</u>
6	<u>90.8</u>
7	<u>90.8</u>
8	<u>90.9</u>
9	<u>90.9</u>
10	<u>90.9</u>

Analyzer Range: 3000
Span Gas Conc.: 2661 PPMC
Span Point: 88.7 mv
Bottle No.: 72131

Test No.	Response (mv)
1	<u>88.7</u>
2	<u>88.7</u>
3	<u>88.8</u>
4	<u>88.7</u>
5	<u>88.8</u>
6	<u>88.7</u>
7	<u>88.7</u>
8	<u>88.8</u>
9	<u>88.8</u>
10	<u>88.7</u>

Analyzer Range: _____
Span Gas Conc.: _____
Span Point: _____ mv
Bottle No.: _____

Test No.	Response (mv)
1	_____
2	_____
3	_____
4	_____
5	_____
6	_____
7	_____
8	_____
9	_____
10	_____

1. Zero and span analyzer 10 times. (Do not readjust zero and span after initial adjustments.)
2. Record span response (mv), also retain chart paper for files.
3. Repeat steps 1 and 2 for each range used.
4. Input data into computer program to determine precision of analyzer.

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/29/90

BENCH: 4
OPERATOR'S INITIALS: DAF
BAROMETER: 29.44 IN HG
DRY BULB: 75 F
WET BULB: 63 F

ANALYZER: FID
RANGE: 1000 PPM
CONCENTRATION & CYLINDER NUMBER: 909/N-340880

PRECISION CHECK ANALYZER RESPONSES: 90.9 90.8 90.9
90.8 90.9 90.8 90.8 90.9 90.9 90.9

ANALYZER RANGE PRECISION IS : +.13% OF FULL SCALE

ANALYZER RANGE LINEARITY CHECK

ANALYZER RESPONSE	ACTUAL PPM	PREDICTED PPM	PERCENT LINEARITY
90.9	909.00	907.91	.11
72.8	727.20	727.13	.01
54.8	545.40	547.34	-.19
36.4	363.60	363.56	.00
18.2	181.80	181.78	.00
0.0	0.00	0.00	0.00

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/29/90

BENCH: 4

OPERATOR'S INITIALS: DAF

BAROMETER: 29.44 IN HG

DRY BULB: 75 F

WET BULB: 63 F

ANALYZER: FID

RANGE: 3000 PPM

CONCENTRATION & CYLINDER NUMBER: 2661/72131

PRECISION CHECK ANALYZER RESPONSES: 88.7 88.7 88.8
88.7 88.8 88.7 88.7 88.8 88.8 88.7

ANALYZER RANGE PRECISION IS : +.13% OF FULL SCALE

ANALYZER RANGE LINEARITY CHECK

ANALYZER RESPONSE	ACTUAL PPM	PREDICTED PPM	PERCENT LINEARITY
88.7	2661.00	2656.09	.16
71.2	2128.80	2132.06	-.11
53.4	1596.60	1599.04	-.08
35.6	1064.40	1066.03	-.05
17.8	532.20	533.01	-.03
.1	0.00	2.99	-.10

ANALYZER NOISE CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315.79)

Date: 9-25-90

Analysis Bench: 4

Operator: D.A.P.

Analyzer: CO2

Analyzer Serial No. 48498112

Analyzer Range: 16%

Analyzer Range: _____

Span Gas Conc.: 15.2%

Span Gas Conc.: _____

Bottle No.: 42 1806

Bottle No.: _____

Analyzer PTP Response with Zero Gas.
Chart Deflection: 0

Analyzer PTP Response with Zero Gas.
Chart Deflection: _____

Analyzer PTP Response with Span Gas.
Chart Deflection: 97.0

Analyzer PTP Response with Span Gas.
Chart Deflection: _____

Noise: 0 % FSCD

Noise: _____ % FSCD

Analyzer Range: _____

Analyzer Range: _____

Span Gas Conc.: _____

Span Gas Conc.: _____

Bottle No.: _____

Bottle No.: _____

Analyzer PTP Response with Zero Gas.
Chart Deflection: _____

Analyzer PTP Response with Zero Gas.
Chart Deflection: _____

Analyzer PTP Response with Span Gas.
Chart Deflection: _____

Analyzer PTP Response with Span Gas.
Chart Deflection: _____

Noise: _____ % FSCD

Noise: _____ % FSCD

1. Zero and span analyzer on all analyzer ranges.

2. Note analyzer peak-to-peak (PTP) response to zero and span gas over a ten second interval.

3. Noise shall not exceed 2% of full scale chart deflection (FSCD) on all ranges used.

ANALYZER RESPONSE TIME CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: <u>9-25-90</u>	Analysis Bench: <u>4</u>
Operator: <u>D.A.P.</u>	
Analyzer: <u>CO2</u>	Analyzer Serial No.: <u>48498112</u>
Analyzer Range: <u>16%</u>	Analyzer Range: _____
Step Gas Conc.: <u>15.2%</u>	Step Gas Conc.: _____
Chart Deflection for 95% of Step Gas: <u>93.2</u>	Chart Deflection for 95% of Step Gas: _____
Time to Respond to 95% of Step Gas: <u>2.6</u> sec.	Time to Respond to 95% of Step Gas: _____ sec.
Analyzer Gas Flow: <u>3</u> scfh	Analyzer Gas Flow: _____ scfh
Analyzer Range: _____	Analyzer Range: _____
Step Gas Conc.: _____	Step Gas Conc.: _____
Chart Deflection for 95% of Step Gas: _____	Chart Deflection for 95% of Step Gas: _____
Time to Respond to 95% of Step Gas: _____ sec.	Time to Respond to 95% of Step Gas: _____ sec.
Analyzer Gas Flow: _____ scfh	Analyzer Gas Flow: _____ scfh

1. Set chart speed at 60 cm/min. to record the following data:
2. Zero/span analyzer on respective range.
3. Introduce to inlet, step change gas of at least 60% of full scale chart deflection. (Step gas in W.E.D. lab is equivalent to span gas.)
4. Begin timing moment analyzer begins to respond to gas and stop timing when analyzer has responded to 95% of step gas concentration. (Chart recorder may be used as a timer, i.e. each cm division = 1 sec.)
5. Analyzer response time may not exceed 6.0 seconds for any analyzer range used.
6. Condensate bath may be by-passed when performing NO analyzer response time.

ANALYZER ZERO AND SPAN DRIFT

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: 10-1-90 Analysis Bench: 4

Operator: D.A.P.

Analyzer: CO₂

Analyzer Serial No.: 48498112

Analyzer Range: 16%

Zero Gas: X N₂ Zero Air

Span Gas Bottle No.: 421806

Zero Gas Response: 0 (% FSCD/30 SEC.)

Span Gas Response: 0 (% FSCD/30 SEC.)

Zero Drift: - .1 % FSCD/HR.

Span Drift: + .1 % FSCD/HR.

1. Zero and span analyzer on lowest range used.
2. Set chart speed at 10 cm/min. 4.
3. Offset zero reading on chart, introduce zero gas over a 1 hour time period.
4. Determine average zero gas response over a 30 second time interval. Evaluate average zero gas response for 1 hour time period to determine drift.
5. Zero gas drift must be not more than 2% of full scale chart deflection (FSCD) over a 1 hour time period.
6. Rezero analyzer, check zero and span points.
7. Introduce span gas over a 1 hour time period.
8. Continue with steps 3 and 4 for span gas.
9. Retain chart paper to file with this page.

NDIR WATER REJECTION RATIO CHECK

(F.P. 101) 42, NO. 174, 10/8/77, 86.316, 86.318, 86.331-79

Date: 9-25-90 Analysis Bench: 4
Operator: V.A.P. Barometer: 28.80

Analyzer: CO2
Analyzer Range: 16%
Analyzer Serial No.: 48498112

1. Zero/span on lowest range used.
2. Bubble zero gas through distilled water and introduce water/gas mixture directly to analyzer inlet.
3. Record water/gas mixture temperature: 78 °F.
4. Record analyzer operating pressure: 3 In. H₂O, 10839 PSI (gage).
5. Record analyzer response to water/gas mixture: 3.6 ppm.
6. Determine the water concentration using:

$$W.C. = \frac{\text{Saturation Vapor Pressure (SVP, psi)} \times 10^6}{\text{Absolute Gage Pressure (AGP, psi)}}$$

SVP is found from saturation vapor pressure table @ water/gas mixture temperature: 47461 psi.

AGP is the gage pressure (psi) + the barometer (psi): 14,25495 psi.

(0.03613 psi/in H₂O, 0.4912 psi/in. Hg)

W.C. 13294.39949

7. Determine water rejection ratio using:

$$WRR = \frac{\text{Water Concentration}}{\text{Anal. Response in ppm}} = \underline{9248.444303}$$

8. Minimum WRR CO Analyzer - 1000:1.
9. Minimum WRR CO₂ Analyzer - 100:1.
10. Minimum WRR NO Analyzer - 5000:1.

NDIR ANALYZER CALIBRATION

(F.R. VOL. 42, NO. 174, 10/8/77, 86.330-79)

DATE: 9-26-90 ANALYSIS BENCH: 4 OPERATOR: D.A.P. BAROMETER: 29.02 IN.HG
 ANALYZER: CO2 ANALYZER SERIAL NO.: 48498112 WET BULB: 62 °F DRY BULB: 75 °F

Bottle No.: <u>421806</u>			Bottle No.: _____			Bottle No.: _____		
Analyzer Range: <u>16%</u>		Response (mv)	Analyzer Range: _____		Response (mv)	Analyzer Range: _____		Response (mv)
Gas Concentration	Gas Concentration		Gas Concentration	Gas Concentration				
<u>15.2</u>	<u>97.0</u>							
<u>12.16</u>	<u>81.3</u>							
<u>9.12</u>	<u>63.9</u>							
<u>6.08</u>	<u>44.7</u>							
<u>3.04</u>	<u>23.4</u>							
<u>0</u>	<u>0</u>							

1. Zero and span analyzer via calibration port.
2. Introduce N2 and span gas to divider inlets at specified pressures.
3. Introduce divider output to analyzer via calibration port, verifying previously set span point (divider set at 100%).
4. If span readings do not agree, adjust divider bypass flow.
5. Record analyzer mv output* above, save chart paper for files.
6. Repeat Steps 1-4 for each range used.
7. * Correct CO2 values per gas divider CO2 correction chart.

EMISSION INSTRUMENT CALIBRATION CHART

ANALYZER: NDIR CO2 16%

DATE OF CALIBRATION REGRESSION: 11/17/89

DATE OF LATEST CALIBRATION CHECK: 9/26/90

ANALYZER RESPONSE VERSUS CONCENTRATION

.5	.06	25.5	3.33	50.5	6.97	75.5	11.12
1.0	.13	26.0	3.40	51.0	7.05	76.0	11.21
1.5	.19	26.5	3.47	51.5	7.13	76.5	11.30
2.0	.25	27.0	3.54	52.0	7.21	77.0	11.39
2.5	.31	27.5	3.61	52.5	7.28	77.5	11.48
3.0	.38	28.0	3.68	53.0	7.36	78.0	11.57
3.5	.44	28.5	3.75	53.5	7.44	78.5	11.66
4.0	.50	29.0	3.82	54.0	7.52	79.0	11.75
4.5	.57	29.5	3.89	54.5	7.60	79.5	11.84
5.0	.63	30.0	3.96	55.0	7.68	80.0	11.93
5.5	.69	30.5	4.03	55.5	7.76	80.5	12.02
6.0	.76	31.0	4.10	56.0	7.84	81.0	12.11
6.5	.82	31.5	4.17	56.5	7.92	81.5	12.21
7.0	.89	32.0	4.24	57.0	8.00	82.0	12.30
7.5	.95	32.5	4.31	57.5	8.08	82.5	12.39
8.0	1.01	33.0	4.38	58.0	8.16	83.0	12.48
8.5	1.08	33.5	4.45	58.5	8.24	83.5	12.58
9.0	1.14	34.0	4.52	59.0	8.32	84.0	12.67
9.5	1.21	34.5	4.59	59.5	8.40	84.5	12.76
10.0	1.27	35.0	4.67	60.0	8.48	85.0	12.86
10.5	1.34	35.5	4.74	60.5	8.56	85.5	12.95
11.0	1.40	36.0	4.81	61.0	8.64	86.0	13.05
11.5	1.47	36.5	4.88	61.5	8.73	86.5	13.14
12.0	1.53	37.0	4.95	62.0	8.81	87.0	13.24
12.5	1.60	37.5	5.03	62.5	8.89	87.5	13.33
13.0	1.66	38.0	5.10	63.0	8.97	88.0	13.43
13.5	1.73	38.5	5.17	63.5	9.06	88.5	13.52
14.0	1.79	39.0	5.24	64.0	9.14	89.0	13.62
14.5	1.86	39.5	5.32	64.5	9.22	89.5	13.72
15.0	1.92	40.0	5.39	65.0	9.31	90.0	13.81
15.5	1.99	40.5	5.46	65.5	9.39	90.5	13.91
16.0	2.06	41.0	5.54	66.0	9.48	91.0	14.01
16.5	2.12	41.5	5.61	66.5	9.56	91.5	14.11
17.0	2.19	42.0	5.69	67.0	9.64	92.0	14.20
17.5	2.25	42.5	5.76	67.5	9.73	92.5	14.30
18.0	2.32	43.0	5.83	68.0	9.81	93.0	14.40
18.5	2.39	43.5	5.91	68.5	9.90	93.5	14.50
19.0	2.45	44.0	5.98	69.0	9.98	94.0	14.60
19.5	2.52	44.5	6.06	69.5	10.07	94.5	14.70
20.0	2.59	45.0	6.13	70.0	10.16	95.0	14.80
20.5	2.66	45.5	6.21	70.5	10.24	95.5	14.90
21.0	2.72	46.0	6.28	71.0	10.33	96.0	15.00
21.5	2.79	46.5	6.36	71.5	10.42	96.5	15.10
22.0	2.86	47.0	6.44	72.0	10.50	97.0	15.20
22.5	2.93	47.5	6.51	72.5	10.59	97.5	15.30
23.0	2.99	48.0	6.59	73.0	10.68	98.0	15.40
23.5	3.06	48.5	6.67	73.5	10.77	98.5	15.51
24.0	3.13	49.0	6.74	74.0	10.85	99.0	15.61
24.5	3.20	49.5	6.82	74.5	10.94	99.5	15.71
25.0	3.27	50.0	6.90	75.0	11.03	100.0	15.81

% NDIR CO2 = +3.40841E-004 +(+1.25141E-001)*(AR)+(+1.83049E-004)*(AR^2) +
 (+1.42858E-006)*(AR^3)+(+3.94499E-010)*(AR^4)

ANALYZER PRECISION CHECK

(F.R. VOL. 44, NO. 174, 3/29/79, 86.315.79)

DATE: 9-25-90 ANALYSIS BENCH: 4 OPERATOR: D.A.P.

ANALYZER: CO2 ANALYZER SERIAL NO.: 98498112

Test No.	Response (mv)	Test No.	Response (mv)	Test No.	Response (mv)	Test No.	Response (mv)
1	<u>97.0</u>	1	<u>97.0</u>	1	<u>97.0</u>	1	<u>97.0</u>
2	<u>97.0</u>	2	<u>97.0</u>	2	<u>97.0</u>	2	<u>97.0</u>
3	<u>97.0</u>	3	<u>97.0</u>	3	<u>97.0</u>	3	<u>97.0</u>
4	<u>97.0</u>	4	<u>97.0</u>	4	<u>97.0</u>	4	<u>97.0</u>
5	<u>97.0</u>	5	<u>97.0</u>	5	<u>97.0</u>	5	<u>97.0</u>
6	<u>97.0</u>	6	<u>97.0</u>	6	<u>97.0</u>	6	<u>97.0</u>
7	<u>97.0</u>	7	<u>97.0</u>	7	<u>97.0</u>	7	<u>97.0</u>
8	<u>97.0</u>	8	<u>97.0</u>	8	<u>97.0</u>	8	<u>97.0</u>
9	<u>97.0</u>	9	<u>97.0</u>	9	<u>97.0</u>	9	<u>97.0</u>
10	<u>97.0</u>	10	<u>97.0</u>	10	<u>97.0</u>	10	<u>97.0</u>

1. Zero and span analyzer 10 times. (Do not readjust zero and span after initial adjustments.)
2. Record span response (mv), also retain chart paper for files.
3. Repeat steps 1 and 2 for each range used.
4. Input data into computer program to determine precision of analyzer.

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/26/90

BENCH: 4
OPERATOR'S INITIALS: DAF
BAROMETER: 29.02 IN HG
DRY BULB: 75 F
WET BULB: 62 F

ANALYZER: NDIR CO2
RANGE: 16%
CONCENTRATION & CYLINDER NUMBER: 15.2%/421806

ANALYZER PERFORMANCE BASED UPON OLD REGRESSION DATA OF 11/17/89

OLD REGRESSION COEFFICIENTS

+3.40841E-004 +1.25141E-001 +1.83049E-004 +1.42858E-006 +3.94499E-010

ANALYZER ERROR TABLE

OLD REGRESSION DATA OF: 11/17/89					
ANALYZER RESPONSE	ACTUAL %	PREDICTED %	% ERROR OF POINT	% ERROR OF FULL SCALE	
97.0	15.20	15.20	.00	.00	
81.3	12.16	12.17	.07	.06	
63.9	9.12	9.12	.04	.02	
44.7	6.08	6.09	.15	.06	
23.4	3.04	3.05	.24	.05	
0.0	0.00	.00	0.00	.00	

PRECISION CHECK ANALYZER RESPONSES: 97.0 97.0 97.0
97.0 97.0 97.0 97.0 97.0 97.0 97.0

ANALYZER RANGE PRECISION IS : +0.00% OF FULL SCALE

ANALYZER NOISE CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315.79)

Date: <u>9-28-90</u>	Analysis Bench: <u>4</u>
Operator: <u>D.A.P.</u>	
Analyzer: <u>02</u>	
Analyzer Serial No. <u>38817</u>	
Analyzer Range: <u>2%</u>	Analyzer Range: <u>5%</u>
Span Gas Conc.: <u>1.9%</u>	Span Gas Conc.: <u>4.75%</u>
Bottle No.: <u>487291</u>	Bottle No.: <u>634241</u>
Analyzer PTP Response with Zero Gas. Chart Deflection: <u>.8</u>	Analyzer PTP Response with Zero Gas. Chart Deflection: <u>.4</u>
Analyzer PTP Response with Span Gas. Chart Deflection: <u>95.0</u>	Analyzer PTP Response with Span Gas. Chart Deflection: <u>95.0</u>
Noise: <u>0</u> % FSCD	Noise: <u>0</u> % FSCD
Analyzer Range: <u>25%</u>	Analyzer Range: _____
Span Gas Conc.: <u>24.97%</u>	Span Gas Conc.: _____
Bottle No.: <u>5398</u>	Bottle No.: _____
Analyzer PTP Response with Zero Gas. Chart Deflection: <u>.3 to .4</u>	Analyzer PTP Response with Zero Gas. Chart Deflection: _____
Analyzer PTP Response with Span Gas. Chart Deflection: <u>99.9</u>	Analyzer PTP Response with Span Gas. Chart Deflection: _____
Noise: <u>.1</u> % FSCD	Noise: _____ % FSCD

1. Zero and span analyzer on all analyzer ranges.
2. Note analyzer peak-to-peak (PTP) response to zero and span gas over a ten second interval.
3. Noise shall not exceed 2% of full scale chart deflection (FSCD) on all ranges used.

"Rev. 4/85"

ANALYZER RESPONSE TIME CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: <u>9-28-90</u>	Analysis Bench: <u>4</u>
Operator: <u>D.A.P.</u>	
Analyzer: <u>O2</u>	Analyzer Serial No.: <u>38817</u>
Analyzer Range: <u>2%</u>	Analyzer Range: <u>5%</u>
Step Gas Conc.: <u>1.9%</u>	Step Gas Conc.: <u>4.75%</u>
Chart Deflection for 95% of Step Gas: <u>90.3</u>	Chart Deflection for 95% of Step Gas: <u>90.3</u>
Time to Respond to 95% of Step Gas: <u>3.4</u> sec.	Time to Respond to 95% of Step Gas: <u>9.0</u> sec.
Analyzer Gas Flow: <u>4</u> scfh	Analyzer Gas Flow: <u>4</u> scfh
Analyzer Range: <u>2.5%</u>	Analyzer Range: _____
Step Gas Conc.: <u>24.97</u>	Step Gas Conc.: _____
Chart Deflection for 95% of Step Gas: <u>94.9</u>	Chart Deflection for 95% of Step Gas: _____
Time to Respond to 95% of Step Gas: <u>9.2</u> sec.	Time to Respond to 95% of Step Gas: _____ sec.
Analyzer Gas Flow: <u>4</u> scfh	Analyzer Gas Flow: _____ scfh

1. Set chart speed at 60 cm/min. to record the following data:
2. Zero/span analyzer on respective range.
3. Introduce to inlet, step change gas of at least 60% of full scale chart deflection. (Step gas in W.E.D. lab is equivalent to span gas.)
4. Begin timing moment analyzer begins to respond to gas and stop timing when analyzer has responded to 95% of step gas concentration. (Chart recorder may be used as a timer, i.e. each cm division = 1 sec.)
5. Analyzer response time may not exceed 6.0 seconds for any analyzer range used.
6. Condensate bath may be by-passed when performing NO analyzer response time.

ANALYZER ZERO AND SPAN DRIFT

(F.R. VOL. 42, NO. 174, 10/8/77, 86.315-79)

Date: 10-1-90 Analysis Bench: 4

Operator: D.A.P.

Analyzer: 02

Analyzer Serial No.: 38817

Analyzer Range: 25%

Zero Gas: X N 2 Zero Air

Span Gas Bottle No.: 5398

Zero Gas Response: 0 (% FSCD/30 SEC.)

Span Gas Response: .004 (% FSCD/30 SEC.)

Zero Drift: 0 % FSCD/HR.

Span Drift: .501 % FSCD/HR.

1. Zero and span analyzer on lowest range used.
2. Set chart speed at 10 cm/min. 4.
3. Offset zero reading on chart, introduce zero gas over a 1 hour time period.
4. Determine average zero gas response over a 30 second time interval. Evaluate average zero gas response for 1 hour time period to determine drift.
5. Zero gas drift must be not more than 2% of full scale chart deflection (FSCD) over a 1 hour time period.
6. Rezero analyzer, check zero and span points.
7. Introduce span gas over a 1 hour time period.
8. Continue with steps 3 and 4 for span gas.
9. Retain chart paper to file with this page.

ANALYZER LINEARITY CHECK

(F.R. VOL. 42, NO. 174, 10/8/77, 86.330, 331, 332-79)

DATE: 9-28-90 ANALYSIS BENCH: 4 OPERATOR: D.A.P. BAROMETER: 29.25 IN.HG.
 ANALYZER: 02 ANALYZER SERIAL NO.: 38817 WET BULB: 62 °F DRY BULB: 74 °F.
 PRESSURES: FID FUEL: _____ KG/CM² FID REG. AIR: _____ KG/CM²
 REGULATOR AIR: _____ PSI BENCH MANIFOLD: _____

Analyzer Range: <u>2%</u>	Analyzer Range: <u>5%</u>	Analyzer Range: <u>25%</u>	Analyzer Range: _____
Bottle No.: <u>487291</u>	Bottle No.: <u>634241</u>	Bottle No.: <u>5398</u>	Bottle No.: _____
Gas Concentration	Gas Concentration	Gas Concentration	Gas Concentration
<u>1.9</u>	<u>4.75</u>	<u>24.97</u>	_____
<u>1.52</u>	<u>3.80</u>	<u>19.976</u>	_____
<u>1.14</u>	<u>2.85</u>	<u>14.982</u>	_____
<u>1.76</u>	<u>1.90</u>	<u>9.988</u>	_____
<u>1.38</u>	<u>.95</u>	<u>4.994</u>	_____
<u>0</u>	<u>0</u>	<u>0</u>	_____
Response (mv)	Response (mv)	Response (mv)	Response (mv)
<u>95.0</u>	<u>95.0</u>	<u>99.9</u>	_____
<u>76.8</u>	<u>76.4</u>	<u>80.0</u>	_____
<u>58.0</u>	<u>57.6</u>	<u>59.9</u>	_____
<u>39.0</u>	<u>38.8</u>	<u>39.9</u>	_____
<u>20.0</u>	<u>19.6</u>	<u>19.9</u>	_____
<u>.9</u>	<u>0</u>	<u>.3</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Zero and span analyzer via calibration port.
 Introduce N₂ and span gas to divider inlets at specified pressures.
 Introduce divider output to analyzer via calibration port, verifying previously set span point (divider set at 100%).
 If span readings do not agree, adjust divider bypass flow.
 Record analyzer mv output above, save chart paper for files.
 Repeat Steps 1-4 for each range used.

ANALYZER PRECISION CHECK

Repeat steps 1-4 for each range used.

Set span point (divider set at 100%).

ANALYZER PRECISION CHECK

(F.R. VOL. 44, NO. 174, 3/29/79, 86.315.79)

DATE: 9-28-90 ANALYSIS BENCH: 4 OPERATOR: D.A.P.

ANALYZER: 02 ANALYZER SERIAL NO.: 38817

Analyzer Range: <u>2%</u>		Analyzer Range: <u>5%</u>		Analyzer Range: <u>25%</u>		Analyzer Range: _____	
Span Gas Conc.: <u>1.9%</u>		Span Gas Conc.: <u>4.75%</u>		Span Gas Conc.: <u>24.97</u>		Span Gas Conc.: _____	
Span Point: <u>95.0</u> mv		Span Point: <u>95.0</u> mv		Span Point: <u>99.9</u> mv		Span Point: _____ mv	
Bottle No.: <u>487291</u>		Bottle No.: <u>634241</u>		Bottle No.: <u>5398</u>		Bottle No.: _____	
Test No.	Response (mv)	Test No.	Response (mv)	Test No.	Response (mv)	Test No.	Response (mv)
1	<u>95.0</u>	1	<u>95.0</u>	1	<u>99.9</u>	1	_____
2	<u>95.0</u>	2	<u>95.0</u>	2	<u>99.8</u>	2	_____
3	<u>95.1</u>	3	<u>95.0</u>	3	<u>99.8</u>	3	_____
4	<u>95.1</u>	4	<u>95.0</u>	4	<u>99.7</u>	4	_____
5	<u>95.0</u>	5	<u>95.0</u>	5	<u>99.7</u>	5	_____
6	<u>95.1</u>	6	<u>95.0</u>	6	<u>99.6</u>	6	_____
7	<u>95.1</u>	7	<u>95.1</u>	7	<u>99.7</u>	7	_____
8	<u>95.2</u>	8	<u>95.1</u>	8	<u>99.7</u>	8	_____
9	<u>95.2</u>	9	<u>95.2</u>	9	<u>99.7</u>	9	_____
10	<u>95.2</u>	10	<u>95.2</u>	10	<u>99.7</u>	10	_____

1. Zero and span analyzer 10 times. (Do not readjust zero and span after initial adjustments.)
2. Record span response (mv), also retain chart paper for files.
3. Repeat steps 1 and 2 for each range used.
4. Input data into computer program to determine precision of analyzer.

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/28/90

BENCH: 4

OPERATOR'S INITIALS: DAF

BAROMETER: 29.25 IN HG

DRY BULB: 74 F

WET BULB: 62 F

ANALYZER: OXYGEN

RANGE: 2%

CONCENTRATION & CYLINDER NUMBER: 1.9%/487291

PRECISION CHECK ANALYZER RESPONSES: 95.0 95.0 95.1
95.1 95.0 95.1 95.1 95.2 95.2 95.2

ANALYZER RANGE PRECISION IS : +.20% OF FULL SCALE

ANALYZER RANGE LINEARITY CHECK

ANALYZER RESPONSE	ACTUAL %	PREDICTED %	PERCENT LINEARITY
95.0	1.90	1.88	.85
76.8	1.52	1.52	-.12
58.0	1.14	1.15	-.49
39.0	.76	.77	-.66
20.0	.38	.40	-.83
.9	0.00	.02	-.90

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/28/90

BENCH: 4

OPERATOR'S INITIALS: DAF

BAROMETER: 29.25 IN HG

DRY BULB: 74 F

WET BULB: 62 F

ANALYZER: OXYGEN

RANGE: 5%

CONCENTRATION & CYLINDER NUMBER: 4.75%/634241

PRECISION CHECK ANALYZER RESPONSES: 95.0 95.0 95.0
95.0 95.0 95.0 95.1 95.1 95.2 95.2

ANALYZER RANGE PRECISION IS : +.21% OF FULL SCALE

ANALYZER RANGE LINEARITY CHECK

ANALYZER RESPONSE	ACTUAL %	PREDICTED %	PERCENT LINEARITY
95.0	4.75	4.72	.51
76.4	3.80	3.80	.01
57.6	2.85	2.86	-.29
38.8	1.90	1.93	-.59
19.6	.95	.97	-.50
0.0	0.00	0.00	0.00

EMISSION ANALYZER CALIBRATION

CALIBRATION DATE: 9/28/90

BENCH: 4
OPERATOR'S INITIALS: DAP
BAROMETER: 29.25 IN HG
DRY BULB: 74 F
WET BULB: 62 F

ANALYZER: OXYGEN
RANGE: 25%
CONCENTRATION & CYLINDER NUMBER: 24.97%/5398

PRECISION CHECK ANALYZER RESPONSES: 99.9 99.8 99.8
99.7 99.7 99.6 99.7 99.7 99.7 99.7

ANALYZER RANGE PRECISION IS : +.21% OF FULL SCALE

ANALYZER RANGE LINEARITY CHECK

ANALYZER RESPONSE	ACTUAL %	PREDICTED %	PERCENT LINEARITY
99.9	24.97	24.97	.00
80.0	19.98	20.00	-.08
59.9	14.98	14.97	.04
39.9	9.99	9.97	.06
19.9	4.99	4.97	.08
.3	0.00	.07	-.30

Root's
DRESSER
DMF-184

ROOTS® PROVER DATA SHEET

LOCATION <u>CELL 10 (LAB)</u>	ROOTS PROVER SERIAL <u>1651</u>
FIELD METER SIZE <u>11M</u>	OPERATOR <u>JR</u>
FIELD METER SERIAL <u>8512972</u>	DATE <u>9-25-90</u>

CALIBRATION FOR REUSE											
ISLAND CAMPFILL SITE											
RUN NUMBER	TIME OF DAY	MASTER METER PRESET	INDICATED FLOW RATE CFH	AVERAGE FLOW RATE CFH	% PRESS. CORR.	% TEMP. CORR.	% PROOF. UNCORR.	% PROOF. CORR.	% ACCURACY CORR.	COMMENTS	
		22	1000	995	-0.0	0.1	99.8	99.9	100.1	ROOTS MTR CALIBRATED	
		"	"	994	-0.0	0.0	99.8	99.8	100.2	WHILE RUNNING IN THE	
		"	"	996	-0.0	-0.1	99.9	99.8	100.2	OPPOSITE DIRECTION	
		19	2500	2552	-0.1	-0.1	99.8	99.6	100.4		
		"	"	2543	-0.1	-0.1	99.7	99.5	100.5		
		"	"	2552	-0.1	-0.1	99.8	99.6	100.4		
		18	5000	4995	-0.3	-0.1	99.9	99.5	100.5		
		"	"	4975	-0.3	-0.1	100.0	99.6	100.4		
		"	"	5000	-0.3	-0.1	100.0	99.6	100.4		
		17	7500	7578	-0.6	-0.1	100.8	100.1	99.9		
		"	"	7578	-0.6	-0.1	100.8	100.1	99.9		
		"	"	7586	-0.6	-0.1	100.9	100.2	99.8		
		17	10,000	9941	-1.0	-0.1	101.4	100.3	99.7		
		"	"	10,039	-1.0	-0.1	101.4	100.3	99.7		
		"	"	10,039	-1.0	-0.1	101.4	100.3	99.7		

NOV 16 '90 09:32 IGT CHICAGO IL

P.2/6

Page 1

IGT_ANALYTICAL

REPORT

Work Order # 90-11-026

Received: 11/12/90

11/16/90 09:27:02

Work Not Complete

REPORT Waukesha Engine Division
TO Dresser Industries, Inc.
1000 West Saint Paul Avenue
Waukesha, WI, 53188-4899
ATTEN Mr. Bob Stachowicz Exp. Lab.

PREPARED Chemical Research Services
BY Institute of Gas Technology
3424 S. State Street
Chicago, IL 60616-3696
ATTEN S. S. Chao Business Phone
PHONE 312-567-5739 : 312-567-3650

CERTIFIED BY

CONTACT KONCAR 3815

CLIENT WAUKESHA ENG SAMPLES 4
COMPANY Waukesha Engine Division
FACILITY Dresser Industries, Inc.
Waukesha, WI, 53188-4899

(For additional information, phone the CONTACT above.)

NEITHER IGT NOR ANY PERSON ACTING ON BEHALF OF IGT ASSUMES ANY
LIABILITY WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING
FROM THE USE OF, ANY INFORMATION PRESENTED IN THIS REPORT.

WORK ID Landfill gases 10/9 - 11/5/90

TAKEN

FAX results to Bob Stachowicz at 414-549-2705

TRANS by United Parcel Service

TYPE Landfill Gas Samples

P.O. # 95582-J55 (VR No. 59988)

INVOICE under separate cover

SAMPLE IDENTIFICATION

TEST CODES and NAMES used on this workorder

01 Sample #1 56psi, 90F
02 Sample #2 58psi, 93F
03 Sample #3 57psi, 90F
04 Sample #4 55psi, 70F

GAS2 GAS ANALYSIS

Received: 11/12/90

Results by Sample

SAMPLE ID Sample #1 86psi, 80F FRACTION Q1A TEST CODE QA82 NAME GAS ANALYSIS
 Date & Time Collected 10/08/90 Category

<u>COMPONENT</u>	<u>MOLEX</u>	<u>D. L.</u>	<u>WEIGHTX</u>
Helium	ND		
Hydrogen	0.18	0.01	0.01
Oxygen & Argon	BDL	0.01	
Nitrogen	0.33	0.01	0.33
Carbon Dioxide	43.8	0.01	88.1
Carbon Monoxide	BDL	0.01	
Methane	55.8	0.01	31.5
Ethane	BDL	0.01	
Ethane	BDL	0.01	
Ethyne (Acetylene)	BDL	0.01	
Propane	BDL	0.01	
Propene	BDL	0.01	
Propyne	BDL	0.01	
Propadiene	BDL	0.01	
i-Butane	BDL	0.01	
n-Butane	BDL	0.01	
1-Butene	BDL	0.01	
iso-Butene	BDL	0.01	
trans-2-Butene	BDL	0.01	
cis-2-Butene	BDL	0.01	
Butadiene	BDL	0.01	
neo-Pentane	BDL	0.01	
i-Pentane	BDL	0.01	
n-Pentane	BDL	0.01	
Pentenes	BDL	0.01	
Pentadienes	BDL	0.01	
C-6 & Heavier	0.02	0.01	0.07
Hydrogen sulfide	ND		
Total	100.0		100.0

CALCULATED PROPERTIES at 60 F / 14.73 psia (ASTM 3588)

Specific Gravity : 0.980
 Compressibility [z] : 0.9973
 Gross Heating Value (BTU/SCF) Net Heating Value (BTU/SCF)
 -- dry -- : 568 -- dry -- : 510
 -- sat.-- : 557 -- sat.-- : 501

Analyst : Robert Sigwood

NOTES: BDLs below detection limit (D.L.); ND= Component not determined

NOTICE: Neither IGT nor any person acting on behalf of IGT assumes any liability with respect to the use of, or for damages resulting from the use of, any information presented in this report.

Received: 11/12/90

Results by Sample

SAMPLE ID Sample 82 55091.93F FRACTION 02A TEST CODE GAS2 NAME GAS ANALYSIS
 Date & Time Collected 10/11/90 Category

<u>COMPONENT</u>	<u>MOLEX</u>	<u>D. L.</u>	<u>WEIGHTX</u>
Helium	ND		
Hydrogen	0.17	0.01	0.01
Oxygen & Argon	BDL	0.01	
Nitrogen	0.10	0.01	0.10
Carbon Dioxide	43.8	0.01	88.1
Carbon Monoxide	BDL	0.01	
Methane	55.9	0.01	31.7
Ethane	BDL	0.01	
Ethene	BDL	0.01	
Ethyne (Acetylene)	BDL	0.01	
Propane	BDL	0.01	
Propene	BDL	0.01	
Propyne	BDL	0.01	
Propadiene	BDL	0.01	
i-Butane	BDL	0.01	
n-Butane	BDL	0.01	
1-Butene	BDL	0.01	
iso-Butene	BDL	0.01	
trans-2-Butene	BDL	0.01	
cis-2-Butene	BDL	0.01	
Butadiene	BDL	0.01	
neo-Pentane	BDL	0.01	
i-Pentane	BDL	0.01	
n-Pentane	BDL	0.01	
Pentenes	BDL	0.01	
Pentadienes	BDL	0.01	
C-5 & Heavier	0.03	0.01	0.09
Hydrogen sulfide	ND		
Total	100.0		100.0

CALCULATED PROPERTIES at 60 F / 14.73 psia (ASTM 3588)

Specific Gravity : 0.980
 Compressibility [z] : 0.9972
 Gross Heating Value (BTU/SCF) Net Heating Value (BTU/SCF)
 -- dry -- : 569 -- dry -- : 512
 -- sat. -- : 559 -- sat. -- : 503

Analyst : Robert Sigwood

NOTES: BDL= below detection limit (D.L.); ND= Component not determined

NOTICE: Neither IGT nor any person acting on behalf of IGT assumes any liability with respect to the use of, or for damages resulting from the use of, any information presented in this report.

NOV 16 '90 09:34 IGT CHICAGO IL

P.5/6

Page 4

IGT_ANALYTICAL

REPORT

Work Order # 90-11-026

Received: 11/12/90

Results by Sample

MPLE ID Sample #3 87psi, 90F FRACTION Q3A TEST CODE QAS2 NAME GAS ANALYSIS
 Date & Time Collected 10/15/90 Category

<u>COMPONENT</u>	<u>MOLEX</u>	<u>D. L.</u>	<u>WEIGHTX</u>
Helium	ND		
Hydrogen	0.10	0.01	0.01
Oxygen & Argon	0.93	0.01	1.06
Nitrogen	5.52	0.01	5.47
Carbon Dioxide	40.8	0.01	83.6
Carbon Monoxide	BDL	0.01	
Methane	52.6	0.01	29.9
Ethane	BDL	0.01	
Ethene	BDL	0.01	
Ethyns (Acetylene)	BDL	0.01	
Propane	BDL	0.01	
Propene	BDL	0.01	
Propyne	BDL	0.01	
Propadiene	BDL	0.01	
i-Butane	BDL	0.01	
n-Butane	BDL	0.01	
1-Butene	BDL	0.01	
iso-Butene	BDL	0.01	
trans-2-Butene	BDL	0.01	
cis-2-Butene	BDL	0.01	
Butadiene	BDL	0.01	
neo-Pentane	BDL	0.01	
i-Pentane	BDL	0.01	
n-Pentane	BDL	0.01	
Pentenes	BDL	0.01	
Pentadienes	BDL	0.01	
C-6 & Heavier	BDL	0.01	
Hydrogen sulfide	ND		
Total	100.0		100.0

CALCULATED PROPERTIES at 60 F / 14.73 psia (ASTM 3588)

Specific Gravity :	0.877		
Compressibility [z] :	0.9975		
Gross Heating Value (BTU/SCF)		Net Heating Value (BTU/SCF)	
-- dry -- :	534	-- dry -- :	481
-- sat. -- :	525	-- sat. -- :	473

Analyst : Robert Sigwood

NOTES: BDL= below detection limit (D.L.); ND= Component not determined

NOTICE: Neither IGT nor any person acting on behalf of IGT assumes any liability with respect to the use of, or for damages resulting from the use of, any information presented in this report.

NOV 16 '90 09:34 IGT CHICAGO IL

Page 5

IGT_ANALYTICAL

REPORT

Work Order # 90-11-028

Received: 11/12/90

Results by Sample

SAMPLE ID Sample 94 55psi, 70F FRACTION Q4A TEST CODE GAS2 NAME GAS ANALYSIS
 Date & Time Collected 11/08/90 Category

COMPONENT	MOLES	D. L.	WEIGHT%
Helium	ND		
Hydrogen	0.18	0.01	0.01
Oxygen & Argon	0.07	0.01	0.07
Nitrogen	1.69	0.01	1.65
Carbon Dioxide	44.7	0.01	68.5
Carbon Monoxide	BDL	0.01	
Methane	53.4	0.01	29.8
Ethane	BDL	0.01	
Ethene	BDL	0.01	
Ethyne (Acetylene)	BDL	0.01	
Propane	BDL	0.01	
Propene	BDL	0.01	
Propyne	BDL	0.01	
Propadiene	BDL	0.01	
i-Butane	BDL	0.01	
n-Butane	BDL	0.01	
1-Butene	BDL	0.01	
iso-Butene	BDL	0.01	
trans-2-Butene	BDL	0.01	
cis-2-Butene	BDL	0.01	
Butadiene	BDL	0.01	
neo-Pentane	BDL	0.01	
i-Pentane	BDL	0.01	
n-Pentane	BDL	0.01	
Pentenes	BDL	0.01	
Pentadienes	BDL	0.01	
C-6 & Heavier	BDL	0.01	
Hydrogen sulfide	ND		
Total	100.0		100.0

CALCULATED PROPERTIES at 60 F / 14.73 psia (ASTM 3586)

Specific Gravity : 0.994
 Compressibility [z] : 0.9973
 Gross Heating Value (BTU/SCF) Net Heating Value (BTU/SCF)
 -- dry -- : 542 -- dry -- : 488
 -- sat. -- : 533 -- sat. -- : 480

Analyst : Robert Sigwood

NOTES: BDL= below detection limit (D.L.); ND= Component not determined

NOTICE: Neither IGT nor any person acting on behalf of IGT assumes any liability with respect to the use of, or for damages resulting from the use of, any information presented in this report.

10-9-90

***** GAS FUEL ANALYSIS *****

FUEL COMPOSITION IN MOLE FRACTIONS:

CH4: 0.5580		N2: 0.0033
C2H6: 0.0000	C2H4: 0.0000	O2: 0.0000
C3H8: 0.0000	C3H6: 0.0000	AIR: 0.0000
IC4H10: 0.0000	H2: 0.0018	CO2: 0.4380
NC4H10: 0.0000	H2S: 0.0000	H2O: 0.0000
IC5H12: 0.0000	CO: 0.0000	He: 0.0000
NC5H12: 0.0002		Ar: 0.0000
C6H14: 0.0000		
C7H16: 0.0000		

THE SUM OF THE FUEL MOLE FRACTIONS IS 1.00130

THE APPARENT FUEL MOLECULAR WEIGHT IS 28.30209

THE FOLLOWING MASS PERCENTAGES ARE TO BE USED FOR 'EAP' PROGRAM
CALCULATIONS. THEY INCLUDE THE CARBON IN CO2 AND THE HYDROGEN
IN H2O IN THE FUEL CARBON AND HYDROGEN VALUES.

THE TOTAL FUEL CARBON PERCENTAGE IS	42.257 %
THE TOTAL FUEL HYDROGEN PERCENTAGE IS	7.960 %
THE FUEL OXYGEN PERCENTAGE IS	49.457 %
THE FUEL NITROGEN PERCENTAGE IS	.326 %
THE FUEL SULFUR PERCENTAGE IS	0.000 %
IE FUEL He AND Ar INERTS PERCENTAGE IS	0.000 %

THE SUMMATION OF MASS PERCENTAGES IS 100.000 %

THE FOLLOWING MASS PERCENTAGES ARE TO BE USED FOR SPINDT AIR/FUEL
RATIO CALCULATIONS ONLY. THEY DO NOT INCLUDE THE CARBON IN CO2
OR THE HYDROGEN IN H2O IN THE FUEL CARBON AND HYDROGEN VALUES.

THE BURNABLE CARBON PERCENTAGE IS	23.693 %
THE BURNABLE HYDROGEN PERCENTAGE IS	7.960 %

THE ATOMIC HYDROGEN/CARBON RATIO OF THE BURNABLE FUEL FRACTION IS 4.004

THE STOICHIOMETRIC SPINDT AFR IS 5.45:1 BY MASS.

THE UNSATURATED HIGH HEATING VALUE IS	565.5 BTU/FT3
THE UNSATURATED LOW HEATING VALUE IS	509.0 BTU/FT3
THE SATURATED LOW HEATING VALUE IS	500.2 BTU/FT3

THE FUEL SPECIFIC GRAVITY IS	.9771
THE FUEL DENSITY IS	.0748 LB/FT3
THE MOTOR OCTANE NUMBER OF THE FUEL IS	119.6
THE IDEAL STOICHIOMETRIC FLAME TEMPERATURE IS	3588 DEG F.

10-11-90

***** GAS FUEL ANALYSIS *****

FUEL COMPOSITION IN MOLE FRACTIONS:

CH4: 0.5590		N2: 0.0010
C2H6: 0.0000	C2H4: 0.0000	O2: 0.0000
C3H8: 0.0000	C3H6: 0.0000	AIR: 0.0000
IC4H10: 0.0000	H2: 0.0017	CO2: 0.4380
NC4H10: 0.0000	H2S: 0.0000	H2O: 0.0000
IC5H12: 0.0000	CO: 0.0000	He: 0.0000
NC5H12: 0.0003		Ar: 0.0000
C6H14: 0.0000		
C7H16: 0.0000		

THE SUM OF THE FUEL MOLE FRACTIONS IS 1.00000

THE APPARENT FUEL MOLECULAR WEIGHT IS 28.29750

 THE FOLLOWING MASS PERCENTAGES ARE TO BE USED FOR 'EAP' PROGRAM
 CALCULATIONS. THEY INCLUDE THE CARBON IN CO2 AND THE HYDROGEN
 IN H2O IN THE FUEL CARBON AND HYDROGEN VALUES.

THE TOTAL FUEL CARBON PERCENTAGE IS	42.382 %
THE TOTAL FUEL HYDROGEN PERCENTAGE IS	7.990 %
THE FUEL OXYGEN PERCENTAGE IS	49.529 %
THE FUEL NITROGEN PERCENTAGE IS	.099 %
THE FUEL SULFUR PERCENTAGE IS	0.000 %
THE FUEL He AND Ar INERTS PERCENTAGE IS	0.000 %

THE SUMMATION OF MASS PERCENTAGES IS 100.000 %

 THE FOLLOWING MASS PERCENTAGES ARE TO BE USED FOR SPINDT AIR/FUEL
 RATIO CALCULATIONS ONLY. THEY DO NOT INCLUDE THE CARBON IN CO2
 OR THE HYDROGEN IN H2O IN THE FUEL CARBON AND HYDROGEN VALUES.

THE BURNABLE CARBON PERCENTAGE IS	23.791 %
THE BURNABLE HYDROGEN PERCENTAGE IS	7.990 %

THE ATOMIC HYDROGEN/CARBON RATIO OF THE BURNABLE FUEL FRACTION IS 4.002

THE STOICHIOMETRIC SPINDT AFR IS 5.47:1 BY MASS.

THE UNSATURATED HIGH HEATING VALUE IS	566.9 BTU/FT3
THE UNSATURATED LOW HEATING VALUE IS	510.3 BTU/FT3
THE SATURATED LOW HEATING VALUE IS	501.4 BTU/FT3

THE FUEL SPECIFIC GRAVITY IS	.9770
THE FUEL DENSITY IS	.0747 LB/FT3
THE MOTOR OCTANE NUMBER OF THE FUEL IS	119.6
THE IDEAL STOICHIOMETRIC FLAME TEMPERATURE IS	3590 DEG F.

10-15-90

***** GAS FUEL ANALYSIS *****

FUEL COMPOSITION IN MOLE FRACTIONS:

CH4: 0.5260		N2: 0.0552
C2H6: 0.0000	C2H4: 0.0000	O2: 0.0093
C3H8: 0.0000	C3H6: 0.0000	AIR: 0.0000
IC4H10: 0.0000	H2: 0.0010	CO2: 0.4080
NC4H10: 0.0000	H2S: 0.0000	H2O: 0.0000
IC5H12: 0.0000	CO: 0.0000	He: 0.0000
NC5H12: 0.0000		Ar: 0.0000
C6H14: 0.0000		
C7H16: 0.0000		

THE SUM OF THE FUEL MOLE FRACTIONS IS 0.99950

THE APPARENT FUEL MOLECULAR WEIGHT IS 28.25491

THE FOLLOWING MASS PERCENTAGES ARE TO BE USED FOR 'EAP' PROGRAM
CALCULATIONS. THEY INCLUDE THE CARBON IN CO2 AND THE HYDROGEN
IN H2O IN THE FUEL CARBON AND HYDROGEN VALUES.

THE TOTAL FUEL CARBON PERCENTAGE IS	39.724 %
THE TOTAL FUEL HYDROGEN PERCENTAGE IS	7.517 %
THE FUEL OXYGEN PERCENTAGE IS	47.283 %
THE FUEL NITROGEN PERCENTAGE IS	5.476 %
THE FUEL SULFUR PERCENTAGE IS	0.000 %
THE FUEL He AND Ar INERTS PERCENTAGE IS	0.000 %

THE SUMMATION OF MASS PERCENTAGES IS 99.999 %

THE FOLLOWING MASS PERCENTAGES ARE TO BE USED FOR SPINDT AIR/FUEL
RATIO CALCULATIONS ONLY. THEY DO NOT INCLUDE THE CARBON IN CO2
OR THE HYDROGEN IN H2O IN THE FUEL CARBON AND HYDROGEN VALUES.

THE BURNABLE CARBON PERCENTAGE IS	22.371 %
THE BURNABLE HYDROGEN PERCENTAGE IS	7.517 %

THE ATOMIC HYDROGEN/CARBON RATIO OF THE BURNABLE FUEL FRACTION IS 4.004

THE STOICHIOMETRIC SPINDT AFR IS 5.15:1 BY MASS.

THE UNSATURATED HIGH HEATING VALUE IS	532.1 BTU/FT3
THE UNSATURATED LOW HEATING VALUE IS	478.9 BTU/FT3
THE SATURATED LOW HEATING VALUE IS	470.6 BTU/FT3

THE FUEL SPECIFIC GRAVITY IS	.9755
THE FUEL DENSITY IS	.0746 LB/FT3
THE MOTOR OCTANE NUMBER OF THE FUEL IS	119.8
THE IDEAL STOICHIOMETRIC FLAME TEMPERATURE IS	3584 DEG F.

11-6-90

***** GAS FUEL ANALYSIS *****

FUEL COMPOSITION IN MOLE FRACTIONS:

CH4: 0.5340		N2: 0.0169
C2H6: 0.0000	C2H4: 0.0000	O2: 0.0007
C3H8: 0.0000	C3H6: 0.0000	AIR: 0.0000
IC4H10: 0.0000	H2: 0.0018	CO2: 0.4470
NC4H10: 0.0000	H2S: 0.0000	H2O: 0.0000
IC5H12: 0.0000	CO: 0.0000	He: 0.0000
NC5H12: 0.0000		Ar: 0.0000
C6H14: 0.0000		
C7H16: 0.0000		

THE SUM OF THE FUEL MOLE FRACTIONS IS 1.00040

THE APPARENT FUEL MOLECULAR WEIGHT IS 28.72743

 THE FOLLOWING MASS PERCENTAGES ARE TO BE USED FOR 'EAP' PROGRAM
 CALCULATIONS. THEY INCLUDE THE CARBON IN CO2 AND THE HYDROGEN
 IN H2O IN THE FUEL CARBON AND HYDROGEN VALUES.

THE TOTAL FUEL CARBON PERCENTAGE IS	41.000 %
THE TOTAL FUEL HYDROGEN PERCENTAGE IS	7.504 %
THE FUEL OXYGEN PERCENTAGE IS	49.848 %
THE FUEL NITROGEN PERCENTAGE IS	1.647 %
THE FUEL SULFUR PERCENTAGE IS	0.000 %
THE FUEL He AND Ar INERTS PERCENTAGE IS	0.000 %

THE SUMMATION OF MASS PERCENTAGES IS 100.000 %

 THE FOLLOWING MASS PERCENTAGES ARE TO BE USED FOR SPINDT AIR/FUEL
 RATIO CALCULATIONS ONLY. THEY DO NOT INCLUDE THE CARBON IN CO2
 OR THE HYDROGEN IN H2O IN THE FUEL CARBON AND HYDROGEN VALUES.

THE BURNABLE CARBON PERCENTAGE IS	22.318 %
THE BURNABLE HYDROGEN PERCENTAGE IS	7.504 %

THE ATOMIC HYDROGEN/CARBON RATIO OF THE BURNABLE FUEL FRACTION IS 4.007

THE STOICHIOMETRIC SPINDT AFR IS 5.14:1 BY MASS.

THE UNSATURATED HIGH HEATING VALUE IS	540.5 BTU/FT3
THE UNSATURATED LOW HEATING VALUE IS	486.4 BTU/FT3
THE SATURATED LOW HEATING VALUE IS	478.0 BTU/FT3

THE FUEL SPECIFIC GRAVITY IS	.9918
THE FUEL DENSITY IS	.0759 LB/FT3
THE MOTOR OCTANE NUMBER OF THE FUEL IS	119.6
THE IDEAL STOICHIOMETRIC FLAME TEMPERATURE IS	3560 DEG F.

Engine Spec. 12V-AT256L	Clearance, Int.	Ex.	Injector Spec.	Air Cleaner
Serial No. 401567	Piston Mat'l		Ignition 17° BTDC	Manifolds
Bore	Stroke	Disp.	Spark Plug	Lub. oil
Disp. 1 Cyl.	BMEP Const.		Radiator	Fuel
Cyl. Head	Fittings	Model	Size	Oct.
Clear Vol.	C.R.		Fan No.	Cet.
Comp. Press	@	rpm	Pitch	Specials:
			Bld.	WB 60°F
			Drive Ratio	DB 62°F
				Hum 75% / 68 89% RH

READING	SPEED: RPM	LOAD: KWe	BHP @ 96%	GAS TEMP. °F	GAS PRESS. PSIG	OBS. FT 3	OBS. TIME MIN.	SLHV	SCFM	B5FC	EXH. TEMP. °F	G/A	IN TAKE MANIF. PRESS. PSIG	OIL PRESS. PSIG	OIL TEMP °F	WATER TEMP °F	AUX WATER TEMP °F	IN TAKE TEMP °F	FUEL RATE LB/MIN	TIME
1	900/1700 2375			77° 55.0	200	1.68	472	6502			940°	16.5	46	180°	222°	117°	123°		41.47	9:33
2	900/1700 2375			77° 55.0	200	1.68	472	6502			940°	16.5	46	180°	217°	117°	123°		41.47	9:40
3	900/1700 2375			77° 55.5	200	1.68	472	6545			940°	16.5	46	180°	217°	117°	123°		41.75	9:44
4	900/1700 2375			77.5° 55.5	200	1.678	472	6551			940°	16.5	46	180°	218°	118°	124°		41.79	9:55 OUT
5	900/1700 2375			78° 55.5	200	1.686	472	6468			940°	16.5	46	180°	219°	118°	124°		41.26	10:00 OUT
								Σ 6514											41.57	
								ENGINE	CLOCK : 2383	HOWES										
								PANEL	CLOCK : 2483											

OBSERVERS STACHOWICZ

ROOM NO.

BAROMETER 29.87

SUBJECT JOHNSTON LAMPELL CERTIFICATION - UNIT #1

SHEET NO. 1

TEST

ENGINEERING DEPARTMENT

Engine Spec.	12V-AT25G6	Clearance, Int.	Ex.	Injector Spec.	Air Cleaner
Serial No.	40/56B	Piston Mat'l		Ignition	Manifolds
Bore	Stroke	Carb. or Pump, No.		Spark Plug	Lub. oil
Displ. 1 Cyl.	BMEP Const	Make	Model	Radiator	Fuel
Cyl. Head		Fittings		Size	Oct.
Clear Vol.	C.R.			Fan No.	Grade
Comp. Press	e			Pitch	Cet.
	rpm			Drive Ratio	Specials:
				Blds.	W/B
				D	71°
					DB
					78°
					Hum
					103 gr/lb
					71% RH

READING	SPEED: RPM	LOAD: KW	BHP @ 96%	GAS TEMP OF PSTG	OBS. TIME MIN	SLHV	SCFM	FUEL RATE LB/MIN	BSEC	EXT. TEMP OF FUEL	"H ₂ O" IN TAKE MANIF.	OIL PRESS PSIG	OIL TEMP OF	WATER TEMP OF	AUX WATER TEMP. °F	TEMP. °F IN TAKE MANIF.	TEMP: °F	TIME		
1	903	1700	2375	88.5° 57.0	200	1610	472	43.57	1830	86.0°	9.2	19.3	42	186°	224°	125°	132°	2:32		
2	903	1700	2375	90.0° 56.5	200	1608	472	43.20	1772	86.0°		19.5	42	188°	224°	125°	132°	2:40		
3	903	1700	2375	90.5° 55.5	200	1604	472	43.45	187	86.0°	9.2	19.5	42	188°	224°	125°	133°	2:50		
4	903	1700	2375	91.0° 55.5	200	1599	472	43.75	1702	86.0°		19.5	42	187°	223°	125°	134°	3:00		
5	903	1700	2375	91.5° 56.0	200	1595	472	43.13	1761	86.0°	9.2	19.5	42	185°	224°	117°	130°	3:05		
										$\Sigma = 4302.6745$										
										ENGINE	CLOCK	:	3102							
										PANEL	CLOCK	:	3052							

OBSERVERS STACHOWICZ ROOM NO. BAROMETER 29.79 DATE 10-9-90 AM
SUBJECT JOHNSTON LANDFILL CERTIFICATION - UNIT #2 SHEET NO. 2 TEST NO. PM

DB 71°

OBSERVERS STACHOWICZ ROOM NO. _____ DATE 10-16-90 AM
BAROMETER 29.86
SHEET NO. 9 TEST NO. _____ PM
SUBJECT JOHNSTON LANDFILL CERTIFICATION - UNIT #3

Air Cleaner _____
 Manifolds _____
 Lub. oil _____ Grade _____
 Fuel _____ Oct. _____ Cet. _____
 Specials: _____
 W/B 71° _____
 DB 73° _____
 HUM 11/90/Lb : 20% RH

[illegible]

OBSERVERS STACHOWICZ ROOM NO. _____ DATE 10-12-90 AM
SUBJECT FUNSTON LANDELL CERTIFICATION - UNIT # 4 BAROMETER 29.89 SHEET NO. 6 TEST NO. _____ PM

Engine Spec.	12V-AT25GL	Clearance, Int.	Ex.	Injector Spec.		Air Cleaner	
Serial No.	40/451	Piston Mat'l		Ignition	17° BTDC	Manifolds	
Bore	Stroke	Carb. or Pump, No.		Spark Plug	No.	Lub. oil	Grade
Disp. 1 Cyl.	BMEP Const	Make	Model	Radiator		Fuel	Oct. Cet.
Cyl. Head		Fittings		Size		Specials:	
Clear Vol.	C.R.			Fan No.	Blds.	WB	68
Comp. Press	@			Pitch	Drive Ratio	DB	73
	rpm						HUM 95 g/Lb. - 78° 20 RH

[illegible]

OBSERVERS STACHOWICZ ROOM NO. _____ DATE 10-14-90 AM
SHEET NO. 8 TEST NO. _____ PM
SUBJECT JOHNSTON LANDFILL CERTIFICATION ; UNIT # 5

Engine Spec.	12V-AT25GL	Clearance, Int.	Ex.	Injector Spec.		Air Cleaner	
Serial No.	401706	Piston Mat'l		Ignition	17° BTDC	Manifolds	
Bore		Carb. or Pump, No.		Spark Plug	No.	Lub. oil	Grade
Stroke		Make	Model	Radiator		Fuel	Oct. Cet.
Hsp. 1 Cyl.		Fittings		Size		Specials:	
Cyl. Head				Fan No.	Blds. D W	WB	72°
Gear Vol.				Pitch	Drive Ratio	DB	85°
Comp. Press	@					HUM.	97 gm/46 ; 54 1/2 RH

[illegible]

OBSERVERS STACHOWICZ
SUBJECT JOHNSTON LANDFILL CERTIFICATION - UNIT # 6
ROOM NO. _____ BAROMETER 30.04 DATE 10-11-90 AM
SHEET NO. 5 TEST NO. _____ PM

ENGINEERING DEPARTMENT

[illegible]

OBSERVERS STACHOWICZ

ROOM NO.

OBSERVERS STACHOWICZ ROOM NO. 7
SUBJECT JOHNSTON LANDELL CERTIFICATION -- UNIT

BAROMETRE
SHEET NO.

BAROMETER 30.12 DATE 10-11-90

AM PM

ENGINEERING DEPARTMENT

[illegible]

Waukesha Motor Company		Clearance, Int. _____ Ex. _____	
Engine Spec. <u>12V-AT25GL</u>	Piston Mat'l _____	Fittings _____	
Serial No. <u>401567</u>	Carb. or Pump, No. _____	_____	
Bore _____	Stroke _____	Make _____	Model _____
Disp. 1 Cyl. _____	Dispos. _____	BMEP Const _____	
Cyl. Head _____	_____		
Clear Vol. _____	C.R. _____		
Comp. Press _____	_____ @ _____ rpm		

Injector Spec. _____	Air Cleaner _____
Ignition <u>17° BDC</u>	Manifolds _____
Spark Plug _____	Lub. oil _____
No. _____	Grade _____
Radiator _____	Fuel _____
Size _____	Oct. _____
Cet. _____	Specials: _____
Fan No. _____	<u>WB 69</u>
Blds. _____	<u>DB 72</u>
Drive Ratio _____	<u>HUM 102 g/Lb ; 86% RH</u>
Pitch _____	

READING	SPEED: RPM	LOAD: KWE	BHP @ 96%	GAS TEMP-OF PRESS	OBS. FT ³	OBS. TIME MIN	SLHV	SCFM	FUEL RATE LB/MIN	BSFC	EXT. TEMP-OF FUEL "H ₂ "	INT. MANIF. PRESS. - PSIG	OIL PRESS - PSIG	OIL TEMP OF WATER TEMP OF AUX WATER TEMP - OF INT. MANIF. TEMP - OF CRANKCASE AP - "H ₂ O"	TIME
1	900/1650	2305		97.0° 57.5	200	1.635	472	42.74	6904		92.5° 9.0	18.0	46.5	178° 215° 120° 130° - .5	10:45
2	900/1650	2305		96.5° 57.0	200	1.632	472	42.33	6838		92.5°	17.5	46.5	178° 215° 120° 130° - .1	10:50
3	900/1650	2305		96.0° 57.0	200	1.630	472	42.42	6852		92.5° 9.0	18.0	46.5	178° 215° 120° 130°	11:00
4	900/1650	2305		96.0° 57.5	200	1.637	472	42.53	6871		92.5°	17.5	46.5	178° 215° 120° 130°	11:05
5	900/1650	2305		97.0° 57.6	200	1.634	472	42.53	6871		92.5° 9.0	17.5	46.5	178° 215° 120° 131° - .2	11:15
									$\bar{\Sigma} = 42.50$	6865					
								PANEL HOURS = 2485							
								ENGINE HOURS = 2394							

OBSERVERS STACHOWICZ ROOM NO. BAROMETER 29.70 DATE 10-13-90 AM

SUBJECT JOHNSTON LANDELL CERTIFICATION - UNIT #1 RERUN SHEET NO. 7 TEST NO. PM

Engine Spec. <i>12V-A 35L</i>	Clearance, Int. _____ Ex. _____	Injector Spec. _____	Air Cleaner _____
Serial No. <i>401970</i>	Piston Mat'l _____	Ignition <i>17° BTDC</i>	Manifolds _____
Bore _____ Stroke _____ Disp. _____	Carb. or Pump, No. _____	Spark Plug _____ No. _____	Lub. oil _____ Grade _____
Disp. 1 Cyl. _____ BMEP Const _____	Make _____ Model _____	Radiator _____	Fuel _____ Oct. _____ Cet. _____
Cyl. Head _____	Fittings _____	Size _____	Specials: _____
Clear Vol. _____ C.R. _____		Fan No. _____ Blds. _____ D _____ W _____	<i>WB 49</i>
Comp. Press _____ e _____ rpm _____		Pitch _____ Drive Ratio _____	<i>DB 54</i>
			<i>Hum 44 gr/lb 70% RH</i>

[illegible]

OBSERVERS: STACHOWICZ

ROOM NO.

•

BAROMETER 29.


DATE 11-6-90

A


SUBJECT JOHNSTON LANDFILL - CLEANED CATALYST - UNIT #8

SHEET NO. 10




PM




UNIT # 1 1 OF 2




UNIT #1 2 OF 2









2017 11 22 2:43 5






UNIT #3 1 OF 2




4070




UNIT #4 1 of 2




UNIT # 4 2 OF 2



UNIT 45 1 OF 2



April 13 2012



100 90 80 70 60 50 40 30 20 10 0

← NM ← O₂ ← H₂O ← CO₂

3:17 Ice C

3:12

Bog C

← NM

↑ H₂O

2:56

G

2:37







C

← O₂


← CO₂

2:45


Pre ✓




UNIT # 6 2 OF 2




UNIT # 7 1 OF 2






UNIT # 8 2 OF 2




UNIT #1 - RERUN 1 of 2




2011 1 - KKKUU

Reccheck #1



Recheck #8

Pre C 10:48



UNIT # 2 - KKKK

X 51.1

NM/Meth HC
PPM

[illegible]

#2

11/4/14 Heth. PPM

Pre 1

A/F SPINDT	CO	CO % 2	O % 2	PPM HC	PPM NO	PPM NOX	NOX GRAMS BHP-HR
8.978	484	11.25	8.70	1920	39	75	35/2140
8.976	454	11.25	8.70	1956	39	76	35/2115
9.227	442	10.90	9.08	2205	32	71	31/2575
9.042	454	11.12	8.80	2130	25	60	33/2665
9.041	484	11.12	8.80	2115	26	55	38/2440

Post 2

3 3

Post 4

Pre 5

NM/Meth PPM

[illegible]

NM/Meth. PPM

[illegible]

NM/Meth. PPM

[illegible]

NM/Meth. PPM

[illegible]

NM/Meth PPM

[illegible]


NH/
Meth. PPA

[illegible]

NM/Meth PP

[illegible]

UN #1




GENERATOR
ONE
KW

OIL PRESS
PSIG

ENGINE 1
INT MAN
TEMP

ENGINE #1
INT MAN PR
UAC/PRESS

ENG 1
JCKT WTR
TEMP



Rhode Island Landfill

Tue, Oct 9, 1990

10:24:12 AM

UNIT #1

FUEL GAS
PRESSURE
PSIG


TEMPERATURE
°F

OIL PRESS
PSIG

ENGINE #1
INT MAN
TEMP

ENGINE #1
INT MAN PR
VAC/PRESS

ENG 1
JCKT WTR
TEMP



PSIG
2200
2112
2024
1936
1848
1760
1672
1584
1496
1408
1320
1232
1144
1056
968
880
792
704
616
528
440
352
264
176
88
0

1723.6

MINUTES


Rhode Island Landfill

Tue, Oct 9, 1990

10:26:34 AM

PS16

100
96
92
88
84
80
76
72
68
64
60
56
52
48
44
40
36
32
28
24
20
16
12
8
4
0



MINUTES

45.8

60 55 50 45 40 35 30 25 20 15 10 5 0

FUEL GAS
PRESSURE
PSIG

GENERATOR
ONE
KW

OUT PRESS
PSIG

ENGINE 1
INT MAN
TEMP

ENGINE #1
INT MAN PR
UAC/PRESS

ENG 1
JCKT WTR
TEMP

Rhode Island Landfill

Tue, Oct 9, 1990

10:28:55 AM

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50

122.5

0

5

10

15

20

25

30

35

40

45

50

55

60

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
ONE
KV

OIL PRESS
PSIG

ENGINE #1
INT MAN PR
UFC/PRESS

ENG 1
JCKT WTR
TEMP

Tue, Oct 9, 1990

10:31:13 AM

Rhode Island Landfill

FUEL GAS
PRESSURE
PSIG


GENERATOR
ONE
KW

OIL PRESS
PSIG

ENGINE 1
INT MAN
TEMP

ENGINE 1
INT MAN
TEMP

ENG 1
JCKT WTR
TEMP



60 55 50 45 40 35 30 25 20 15 10 5 0

MINUTES

16.5

Rhode Island Landfill Tue, Oct 9, 1990 10:33:33 AM

300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50

227.8

MINUTES

10:35:56 AM


Tue, Oct 9, 1990

Rhode Island Landfill

UNIT #2

PSIG

70
65
60
55
50
45
40
35
30
25
20
15
10
5
0



56.7

MINUTES

FUEL OIL PRESSURE
PSIG

GENERATOR
TWO
KH

OIL PRESS
PSIG

ENGINE 2
INT MAN
TEMP

ENGINE #2
INT MAN PR
UAC/PRESS

ENG 2
JCKT WTR
TEMP

Rhode Island Landfill

Tue, Oct 9, 1990

3:34:51 PM

UNIT #2

FUEL GAS
PRESSURE
PSIG


GENERATOR
TEMP
KH

OIL PRESS
PSIG

ENGINE #2
INT MAN
TEMP

ENGINE #2
INT MAN PR
VAC/PRESS

ENG 2
JCKT WTR
TEMP




Rhode Island Landfill

Tue, Oct 9, 1990

3:37:10 PM

PSIG

100
96
92
88
84
80
76
72
68
64
60
56
52
48
44
40
36
32
28
24
20
16
12
8
4
0



MINUTES

40.9

FUEL GAS
PRESSURE
PSIG

GENERATOR
TWO
KW

OIL PRESS
PSIG

ENGINE #2
INT MAN
TEMP

ENGINE #2
INT MAN PR
VAC/PRESS

ENG 2
JCKT WTR
TEMP


Rhode Island Landfill

Tue, Oct 9, 1990

3:39:24 PM

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50



124.3

MINUTES

0

5

10

15

20

25

30

35

40

45

50

55

60

3:41:37 PM

Tue, Oct 9, 1990

Rhode Island Landfill

EL GAS
PRESSURE
PSIG

VERTOR
TWO
KJ

L PRESS
PSIG

ENGINE #2
T MAN PR
C/PRESS

ENG 2
CKT WTR
TEMP

UAC/PREI

UAC/PRES

FUEL GAS
PRESSURE
PSIG


GENERATOR
TWO
KW

OIL PRESS
PSIG

ENGINE 2
INT MAN
TEMP

ENGINE 2
INT MAN
TEMP

ENG 2
JCKT WTR
TEMP



Rhode Island Landfill

Tue, Oct 9, 1990

3:43:53 PM

300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50

	60	55	50	45	40	35	30	25	20	15	10	5	0
--	----	----	----	----	----	----	----	----	----	----	----	---	---

Rhode Island Landfill	Tue, Oct 9, 1990	3:46:09 PM
------------------------------	-------------------------	-------------------

ELITE
JULY 1976
TEIP

PSIG

UNIT #3

FUEL OIL
PRESSURE
PSIG


GENERATOR
THREE
KW

OIL PRESS
PSIG

ENGINE 3
INT MAN
TEMP

ENGINE #3
INT MAN PR
URC/PRESS

ENG 3
JCKT WTR
TEMP



59.6

Rhode Island Landfill

Tue, Oct 16, 1990


10:17:24 AM

UNIT #3

KU

2200
2112
2024
1936
1848
1760
1672
1584
1496
1408
1320
1232
1144
1056
968
880
792
704
616
528
440
352
264
176
88
0

1693



1689.9

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
THREE

OIL PRESS
PSIG

ENGINE 3
NT MAN
TEMP

ENGINE #3
AT MAN PR
AC/PRESS

ENG 3
JCKT WTR
TEMP

Rhode Island Landfill Tue, Oct 16, 1990 10:19:41 AM

FUEL GAS
PRESSURE
PSIG

GENERATOR
THREE
KW

OIL PRESS
PSIG


ENGINE 3
INT MAN
TEMP

ENGINE #3
INT MAN PR
VAC/PRESS

ENG 3
JCKT WTR
TEMP

PSIG

100
96
92
88
84
80
76
72
68
64
60
56
52
48
44
40
36
32
28
24
20
16
12
8
4
0




MINUTES

32.8

Rhode Island Landfill Tue, Oct 16, 1990 10:22:07 AM

TEMP



121.1

60 55 50 45 40 35 30 25 20 15 10 5 0

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
THREE
KH

OIL PRESS
PSIG


ENGINE #3
INT MAN
TEMP

ENGINE #3
INT MAN PR
URC/PRESS

ENG 3
JCKT NTR
TEMP

Rhode Island Landfill Tue, Oct 16, 1990 10:25:11 AM

VAC/PRES



FUEL GAS
PRESSURE
PSIG

GENERATOR
THREE
KV

OIL PRESS
PSIG

ENGINE 3
INT MAN
TEMP

ENGINE 3
INT MANIF
VAC/PRES

ENG 3
JCKT WTR
TEMP


Rhode Island Landfill

Tue, Oct 16, 1990

10:27:29 AM

TEMP

300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50



60 55 50 45 40 35 30 25 20 15 10 5 0

209.0

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
THREE
KW

OIL PRESS
PSIG

ENGINE 3
INT MAN
TEMP

ENGINE #3
INT MAN PR
URC/PRESS

ENGINE 3
JET HTA
TEMP

10:29:51 AM

UNIT # 4

PSIG

FUEL GAS
PRESSURE
PSIG


GENERATOR
FOUR
KV

ENGINE 4
OIL PRESS
PSIG

ENGINE 4
INT MAN
TEMP

ENGINE #4
INT MAN PR
VAC/PRESS

ENG 4
JCKT WTR
TEMP



57.0

MINUTES

Rhode Island Landfill

Fri, Oct 12, 1990

3:33:32 PM

UNIT # 4

K01

2200

2112

2024

1936

1848

1760

1672

1584

1496

1408

1320

1232

1144

1056

968

880

792

704

616

528

440

352


264

176

88

0

1692



1710.4

FUEL GAS
PRESSURE
PSIG

ENGINE #4
OIL PRESS
PSIG

ENGINE #4
INT MAN
TEMP

ENGINE #4
INT MAN PR
PAC/PRESS

ENG 4
JCKT MTR
TEMP

**FUEL GAS
PRESSURE
PSIG**

GENERATOR
FOUR
KH

ENGINE 4
INT MAN
TEMP

ENGINE #4
INT MAN PR
VAC/PRESS

ENG 4
JCKT WTR
TEMP

42

100 96 92 88 84 80 76 72 68 64 60 56 52 48 44 40 36 32 28 24 20 16 12 8 4 0

9.6


Rhode Island Landfill

Fri, Oct 12, 1990

3:38:17 PM

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50



122.6

MINUTES

60 55 50 45 40 35 30 25 20 15 10 5 0

FUEL GAS
PRESSURE
PSIG

GENERATOR
FOUR
KH

ENGINE 4
OIL PRESS
PSIG

ENGINE 4
INT MAN PR
VAC/PRESS

ENGINE 4
JCKT WTR
TEMP

ENGINE 4
JCKT WTR
TEMP

FUEL GAS
PRESSURE
PSIG


GENERATOR
FOUR
KV

ENGINE 4
OIL PRESS
PSIG

ENGINE 4
INT MAN
TEMP


ENGINE 4
INT MTR
TEMP

ENG 4
JCKT MTR
TEMP



TEMP

300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50



221.8

60 55 50 45 40 35 30 25 20 15 10 5 0
MINUTES

EL GAS
PRESSURE
PSIG

GENERATOR
FOUR
KW

ENGINE 4
PRESS
PSIG

ENGINE 4
TEMP

ENGINE 4
MAN PR
C/PRESS

ENGINE 4
TEMP


Rhode Island Landfill

Fri, Oct 12, 1990

3:45:12 PM

PSIG

UNIT #5



57.9

MINUTES

FUEL OIL
PRESSURE
PSIG

GENERATOR
FIVE
KW

ENGINE 5
OIL PRESS
PSIG

ENGINE 5
INT MAN
TEMP


ENGINE #5
INT MAN PR
VRC/PRESS

ENG 5
JCKT MTR
TEMP

Rhode Island Landfill Sun, Oct 14, 1990 11:34:09 AM

UNIT #5

KU 2200 2112 2024 1936 1848 1760 1672 1594/598 1496 1408 1320 1232 1144 1056 968 880 792 704 616 528 440 352 264 176 88 0



FUEL GAS
PRESSURE
PSIG

ENGINE #5
INT MAN PR
UAC/PRESS

ENGINE 5
OIL PRESS
PSIG

ENGINE 5
INT MAN
TEMP

ENGINE #5
INT MAN PR
UAC/PRESS


ENG 5
JCKT WTR
TEMP

60 55 50 45 40 35 30 25 20 15 10 5 0
MINUTES
1592.7

Phoca Island Landfill Sun, Oct 14, 1990 11:36:24 AM

PSIG

100
96
92
88
84
80
76
72
68
64
60
56
52
48
44
40
36
32
28
24
20
16
12
8
4
0



42.6

MINUTES

60 55 50 45 40 35 30 25 20 15 10 5 0

Rhode Island Landfill

Sun, Oct 14, 1990

11:38:41 AM

FUEL GAS
PRESSURE
PSIG

GENERATOR
FIVE
KW

ENGINE 5
INT MAN PR
PSIG


ENGINE 5
INT MAN
TEMP

ENGINE #5
INT MAN PR
UAC/PRESS

ENG 5
JCKT UTR
TEMP

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50



125.1

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
FIVE
KW

ENGINE 5
OIL PRESS
PSIG

ENGINE 5
INT MAN
TEMP

ENGINE #5
INT MAN PR
URC/PRESS


ENG 5
JCKT WTR
TEMP

Rhodes Island Landfill

1 Jan Oct 14 1990

11:40:59 AM

/PRE1



FUEL GAS
PRESSURE
PSIG

GENERATOR
FIVE
KW

ENGINE 5
OIL PRESS
PSIG

ENGINE 5
INT MAN
TEMP

ENGINE #5
INT MAN PR
PS PRESS

ENG 5
JCKT WTR
TEMP

Rhode Island Landfill


Sun, Oct 14, 1990

11:43:21 AM

19.8

TEMP

300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50



210.1

MINUTES

60 55 50 45 40 35 30 25 20 15 10 5 0

FUEL GAS
PRESSURE
PSIG

GENERATOR
FIVE
KW

ENGINE 5
OIL PRESS
PSIG

ENGINE 5
INT MAN
TEMP


ENGINE #5
INT MAN PR
UAC/PRESS

ENGINE 5
INT MAN
TEMP

Phode Island Landfill | Sun, Oct 14, 1990 | 11:45:40 AM

PSIG

UNIT #6




57.6

MINUTES

Rhode Island Landfill Thu, Oct 11, 1990 3:32:33 PM

UNIT #6



FUEL GAS
PRESSURE
PSIG

GENERATOR
S
PH

OIL PRESS
PSIG

ENGINE 6
INT MAN
TEMP

ENGINE #6
NT MAN PR
VAC/PRESS

ENG 6
JCKT WTR
TEMP

PSIG 100 96 92 88 84 80 76 72 68 64 60 56 52 48 44 40 36 32 28 24 20 16 12 8 4 0

FUEL GAS
PRESSURE
PSIG


GENERATOR
SIX
KW



ENGINE #6
INT MAN
TEMP

ENGINE #6
INT MAN PR
UAC/PRESS

ENG 6
JCKT WTR
TEMP



MINUTES

45.1


Rhode Island Landfill

Thu, Oct 11, 1990

3:37:23 PM

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50



135.5

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
SIX
KVA


OIL PRESS
PSIG

ENGINE #6
INT MAN PR
UAC/PRESS

ENGINE #6
JCKT WTR
TEMP

NO. 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100

UNC/PREI



FUEL GAS
PRESSURE
PSIG

GENERATOR
SIX
KW

OIL PRESS
PSIG


ENGINE 6
INT MAN
TEMP

ENGINE 75
OIL PRESS

ENG 6
JCKT WTR
TEMP

Rhode Island Landfill Thu, Oct 11, 1990 3:41:58 PM

TEMP



224.3

FUEL GAS
PRESSURE
PSIG

GENERATOR
SIX
KW

OIL PRESS
PSIG


ENGINE 6
INT MAN
TEMP

ENGINE #6
INT MAN PR
URC/PRESS

ENGINE
INT MAN
TEMP

PSIG

UNIT #7



57.2

MINUTES

Rhode Island Landfill

Thu, Oct 11, 1990

10:35:56 AM

UNIT #7

GENERATOR
SEVEN
KI

OIL PRESS
PSIG

ENGINE 7
INT MAN
TEMP

ENGINE #7
INT MAN PR
URC/PRESS

ENG 7
JCKT ITR
TEMP

KU

2200

2112

2024

1936

1848

1760

1672

1584

1496

1408

1320

1232

1144

1056

968

880

792

704

616

528

440

352


264

176

88

0

1623



1686.0

MINUTES

FUEL GAS
PRESSURE
PSIG

TEMPERATURE
°F

OIL PRESS
PSIG

ENGINE 7
INT MAN
TEMP

ENGINE #7
INT MAN PR
VAC/PRESS

ENG 7
JCKT WTR
TEMP

MADE IN U.S.A.

PSIG

100
96
92
88
84
80
76
72
68
64
60
56
52
48
44
40
36
32
28
24
20
16
12
8
4
0

43.6

MINUTES

60 55 50 45 40 35 30 25 20 15 10 5 0

FUEL GAS
PRESSURE
PSIG

GENERATOR
SEVEN
KW

OIL PRESS
PSIG

ENGINE 7
INT MAN
TEMP

ENGINE #7
INT MAN PR
UAC/PRESS

ENG 7
JCKT WTR
TEMP


Rhode Island Landfill

Thu, Oct 11, 1990

10:41:19 AM

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50



MINUTES

119.7

FUEL GAS
PRESSURE
PSIG

GENERATOR
SEVEN
KV

OIL PRESS
PSIG

ENGINE 7
INT MAN PR
TEMP

ENGINE #7
INT MAN PR
UAC/PRESS

ENG 7
JCKT WTR
TEMP

Rhode Island Landfill Thu, Oct 11, 1990 10:43:37 AM

UAC/PRES

FUEL GAS
PRESSURE
PSIG


GENERATOR
SEVEN
KN

OIL PRESS
PSIG

ENGINE 7
INT MAN
TEMP

ENGINE 7
INT MAN
TEMP

ENG 7
JCKT WTR
TEMP



15.4

MINUTES


Rhode Island Landfill

Thu, Oct 11, 1990

10:46:12 AM

TEMP

300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50



217.3

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
SEVEN
KW

OIL PRESS
PSIG

ENGINE 7
INT MAN
TEMP

ENGINE #7
INT MAN PR
URC/PRESS

ENGINE #7
INT MAN PR
URC/PRESS

Rhode Island Landfill

Thu, Oct 11, 1990

10:48:33 AM

PSIG

UNIT #8

FUEL GAS
PRESSURE
PSIG


GENERATOR
EIGHT
KW

OIL PRESS
PSIG

ENGINE 8
INT MAN
TEMP

ENGINE #8
INT MAN PR
VAC/PRESS

ENG 8
JCKT WTR
TEMP



57.6


Rhode Island Landfill

Wed, Oct 10, 1990

4:49:59 PM

UNIT #8

KU 2200 2112 2024 1936 1848 1760 1672 1584 1496 1408 1320 1232 1144 1056 968 880 792 704 616 528 440 352 264 176 88 0



1686.9

FUEL GAS
PRESSURE
PSIG

GENERATOR
ELECT
VOLT

OIL PRESS
PSIG

ENGINE 8
INT MAN
TEMP

ENGINE #8
INT MAN PR
UAC/PRESS

ENG 8
JCKT WTR
TEMP

60

55

50

45

40

35

30

25

20

15

10


5

0

MINUTES

PSIG

100
96
92
88
84
80
76
72
68
64
60
56
52
48
44
40
36
32
28
24
20
16
12
8
4
0



MINUTES

60 55 50 45 40 35 30 25 20 15 10 5 0

42.5

FUEL GAS
PRESSURE
PSIG

GENERATOR
EIGHT
KW

ENGINE #8
INT MAN PR
UAC/PRESS
PSIG

ENGINE #8
INT MAN PR
TEMP


ENGINE #8
INT MAN PR
UAC/PRESS

ENG 8
JCKT WTR
TEMP

Rhode Island Landfill Wed, Oct 10, 1990 4:54:31 PM

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50



116.7

MINUTES

FUEL GAS
PRESSURE
PSIG


GENERATOR
EIGHT
KV

OIL PRESS
PSIG

ENGINE #8
INT MAN PR
UAC/PRESS

ENGINE #8
JCKT WTR
TEMP

UNC/PRE



FUEL GAS
PRESSURE
PSIG

GENERATOR
EIGHT
KW

OIL PRESS
PSIG

ENGINE 8
INT MAN
TEMP

ENGINE 8
INT MAN
TEMP

ENG 8
JCKT NTR
TEMP

Rhode Island Landfill

Wed, Oct 10, 1990

4:58:57 PM

100
90
80
70
60
50
40
30
20
10
00
90
80
70
60
50
40
30
20
10
00
90
80
70
60
50

END OF
JULY 1971
TEMP

216.5

MINUTES

Rhode Island Landfill

5-01-13 PM

510

70

65

60

55

50

45

40

35

30

25

20

15

10

5

0

UNIT #1 - RERUN

FUEL PRESS
PRESSURE
PSIG


GENERATOR
ONE
KW

OIL PRESS
PSIG

ENGINE #1
INT MAN
TEMP

ENGINE #1
INT MAN PR
VAC/PRESS

ENG 1
JCKT WTR
TEMP



MINUTES

57.3


Rhode Island Landfill

Sat, Oct 13, 1990

11:35:08 AM

UNIT #1 - RERUN

KN 2200 2112 2024 1936 1848 1760 1672 1584 1496 1408 1320 1232 1144 1056 968 880 792 704 616 528 440 352 264 176 88 0



1662.5

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
OIL
PRESS

OIL PRESS
PSIG

ENGINE 1
INT MAN
TEMP

ENGINE #1
INT MAN PR
VAC/PRESS

ENG 1
JCKT WTR
TEMP


Rhode Island Landfill

Sat, Oct 13, 1990

11:37:35 AM

PSIG

100
96
92
88
84
80
76
72
68
64
60
56
52
48
44
40
36
32
28
24
20
16
12
8
4
0



46.5

MINUTES

60 55 50 45 40 35 30 25 20 15 10 5 0

FUEL GAS
PRESSURE
PSIG

GENERATOR
ONE
KW

OIL PRESS
PSIG

ENGINE #1
INT MAN
TEMP


ENGINE #1
INT MAN PR
UAC/PRESS

ENG 1
JCKT WTR
TEMP

Rhode Island Landfill Sat, Oct 13, 1990 11:39:58 AM

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50



129.0

FUEL GAS
PRESSURE
PSIG

GENERATOR
ONE
KW

OIL PRESS
PSIG

ENGINE #1
INT MAN PR
TEMP

ENGINE #1
INT MAN PR
URC/PRESS

ENG 1
JCKT WTR
TEMP

MINUTES

VOL/PRES

FUEL GAS
PRESSURE
PSIG


GENERATOR
ONE
KW

OIL PRESS
PSIG

ENGINE 1
INT MAN
TEMP

ENGINE 1
INT MAN PS
PRESS

ENG 1
JCKT WTR
TEMP



17.5

MINUTES


Rhode Island Landfill

Sat, Oct 13, 1990

11:44:32 AM

TEMP

300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50



219.7

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
ONE
KW

OIL PRESS
PSIG

ENGINE 1
INT MAN
TEMP

ENGINE #1
INT MAN PR
URC/PRESS

ENGINE 1
OUT UTR
TEMP

Rhode Island Landfill

Sat, Oct 13, 1990

11:46:54 AM

PSIG

UNIT #8 - RERUN

FUEL OIL
PRESSURE
PSIG


GENERATOR
EIGHT
KW

OIL PRESS
PSIG

ENGINE 8
INT MAN
TEMP

ENGINE #8
INT MAN PR
VAC/PRESS

ENG 8
JCKT WTR
TEMP



53.9

Rhode Island Landfill

Tue, Nov 6, 1990

11:52:55 AM

UNIT #8 - RERUN

KW

2200

2112

2024

1936

1848

1760 1718

1672

1584

1496

1408

1320

1232

1144

1056

968

880

792

704

616

528

440


352

264

176

88

0



1726.0

FUEL GAS
PRESSURE
PSIG

GENERATOR
EIGHT
HOURS

OIL PRESS
PSIG

ENGINE 8
INT MAN
TEMP

ENGINE #8
INT MAN PR
VAC/PRESS

ENG 8
JCKT WTR
TEMP

MINUTES

60 55 50 45 40 35 30 25 20 15 10 5 0

FUEL GAS
PRESSURE
PSIG


GENERATOR
EIGHT
KW

OIL PRESS
PSIG

ENGINE #8
INT MAN
TEMP

ENGINE #8
INT MAN PR
UAC/PRESS

ENG 8
JCKT WTR
TEMP




Rhode Island Landfill

Tue, Nov 6, 1990

11:59:57 AM

TEMP

200
195
190
185
180
175
170
165
160
155
150
145
140
135
130
125
120
115
110
105
100
95
90
85
80
75
70
65
60
55
50



124.2

MINUTES

FUEL GAS
PRESSURE
PSIG

GENERATOR
EIGHT
KW

OIL PRESS
PSIG

ENGINE #8
INT MAN PR
TEMP

ENGINE #8
INT MAN PR
UAC/PRESS

ENG 8
JCKT WTR
TEMP

120223100

120223100

120223100

120223100

FUEL GAS
PRESSURE
PSIG


GENERATOR
EIGHT
KH

OIL PRESS
PSIG

ENGINE 8
INT MAN
TEMP

ENGINE #8
INT MAN PR
OIL PRESS

ENG 8
JCKT WTR
TEMP



21.5

MINUTES

Rhode Island Landfill

Tue, Nov 6, 1990

12:04:50 PM

TEMP

300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50

216.8

MINUTES

60 55 50 45 40 35 30 25 20 15 10 5 0

Rhode Island Landfill

Tue, Nov 6, 1990

12:07:57 PM

FUEL GAS
PRESSURE
PSIG

GENERATOR
EIGHT
KW

OIL PRESS
PSIG

ENGINE 8
INT MAN
TEMP

ENGINE #8
INT MAN PR
VRC/PRESS

ENG 8
JOINT WTR
TEMP

ABSTRACT

The composition of a burned mixture of air and hydrocarbons must reflect the air-fuel ratio of the original mixture. This paper shows that the air-fuel ratio can be calculated by an equation that involves only fuel composition and exhaust gas composition. For this calculation, the hydrocarbon content of the combusted mixture has been measured with a flame ionization detector as a carbon counter.

Air-Fuel Ratios from Exhaust Gas Analysis

R. S. Spindt

Gulf Research & Development Co.

ENGINEERS HAVE been aware since the days of the first gasoline engine that the composition of the exhaust gas reflects the composition of fuel and air that is inducted into the engine. Since air-fuel ratio is very important to engine performance and exhaust gas analysis is deceptively simple, a correlation of exhaust gas analysis and air-fuel ratio has long been sought. This paper presents yet another way of correlating these compositions. The method is based on ratios of the component concentrations and it is not sensitive to small errors in analysis.

One of the first intensive studies to correlate air-fuel ratio with exhaust gas analysis was reported by D'Alleva and Lovell (1).^{*} In the discussion of this paper, H. C. Dickenson (2) cautioned that the results reported were accurate and usable only when combustion is complete; that is, the fuel is burned to equilibrium products. When misfiring or incomplete combustion occurred, no meaningful results could be obtained. Assumptions made by these authors were that:

1. Combustion was complete.
2. A "water-gas" equilibrium constant of 3.8 was appropriate.

3. 0.15 mole of methane was formed per mole of fuel.

Even at that time, other hydrocarbons were known to be present in the exhaust but their analysis was difficult.

L. S. Leonard (3) has described a system for evaluating air-fuel ratio from exhaust gas analysis. He assumes complete combustion and an empirical correlation of hydrogen and methane concentrations with carbon monoxide concentration. The fuel stoichiometry necessary for a study of fuel distribution problems can be calculated from his charts. However, when combustion is not complete, erroneous results will be obtained. Incomplete combustion occurs under some common conditions.

In recent years the study of exhaust gases for their hydrocarbon content has become very important for understanding their contribution to air pollution. While methane is an important exhaust constituent, almost all the constituents in

the original gasoline, as well as light cracked products are also present. Only under good combustion conditions does methane occur at a larger concentration than any other single hydrocarbon. Figs. 1-3 illustrate how the exhaust gas hydrocarbons resemble those of the original fuel. These figures were obtained by gas chromatography using a capillary column coated with squalene.

Fig. 1 is obtained from the original fuel. Fig. 2 is the exhaust from a single-cylinder engine running at 15/1 air-fuel ratio, 1800 rpm, and 10 in. Hg manifold vacuum. Fig. 3 is the exhaust from the same engine under the same conditions except at 20 in. Hg manifold vacuum. Obviously, the exhaust gas contains significant amounts of unburned fuel.




Fig. 1 - Chromatographic record of hydrocarbon components -- original fuel

^{*}Numbers in parentheses designate References at end of paper.

of this constant have only a small effect on the calculated air-fuel ratio.

Now, air-fuel ratio is defined as lb air/lb fuel. Therefore,

$$A/F = \frac{28.97 \times 100}{12.01X + 2.016Y} \quad (6)$$

Also, the fractions of carbon (F_c) and hydrogen (F_h) in a hydrocarbon fuel are defined as:

$$F_c = \frac{12.01X}{12.01X + 2.016Y} \quad F_h = \frac{2.016Y}{12.01X + 2.016Y} \quad (7)$$

~~Of course, the above equations can be rearranged to~~
~~readily adjusted without affecting the analysis~~ Eqs. 6 and 7 can be solved for X and Y:

$$X = \frac{2897F_c}{12.01(A/F)} = 241.2 \frac{F_c}{(A/F)} \quad (8)$$

$$Y = \frac{2897F_h}{2.016(A/F)} = 1437.0 \frac{F_h}{(A/F)} \quad (9)$$

Now, the moles of exhaust gas is equal to the moles of the original charge times the fraction unburned plus the moles of the combustion products times the fraction burned.

Also, if F_b = fraction burned and F_u = fraction unburned

Moles Exh = $F_u \times$ Moles Reactants + $F_b \times$ Moles Products

$$F_b + F_u = 1 \quad (10)$$

The total moles of exhaust gas per 100 moles of air are, therefore,

$$T = F_u(100 + X/n) + F_b(A + B + C + D + E + 79.01) \quad (11)$$

where:

X/n = Number of moles of fuel present per 100 moles of air.

T is the total moles of exhaust produced by combustion per 100 moles of air. T is not necessarily equal to the actual number of moles in the exhaust analyzed since water may be condensed from the gases. In any event, it is not necessary to know T, since air-fuel ratio will be calculated by ratio measurements from the relative concentrations usually expressed as a per cent.

By definition the following percentage relations hold:

$$P_{CO_2} = \frac{A \times 100 F_b}{T} \quad (12)$$

$$P_{CO} = \frac{B \times 100 F_b}{T} \quad (13)$$

$$P_{CH} = \frac{X \times 100 F_u}{T} \quad (14)$$

where:

P_{CH} = Per cent carbon in hydrocarbons on a per carbon basis

$$P_{O_2} = \frac{(20.99 F_u + E \times F_b) 100}{T} \quad (15)$$

$$\text{Let } R = \frac{P_{CO}}{P_{CO_2}} = \frac{A}{B} \quad 1/2/A \quad (16)$$

$$Q = \frac{P_{O_2}}{P_{CO_2}} = \frac{20.99 F_u + E \times F_b}{A \times F_b} \quad (17)$$

Now from Eqs. 2, 12, 13, and 14:

$$\frac{P_{CH}}{P_{CO_2} + P_{CO}} = \frac{X \times F_u}{(A + B) F_b} = \frac{F_u}{F_b} \quad (18)$$

Therefore, from Eqs. 10 and 18:

$$F_u = \frac{P_{CH}}{P_{CO} + P_{CO_2} + P_{CH}} \quad (19)$$

$$F_b = \frac{P_{CO} + P_{CO_2}}{P_{CO} + P_{CO_2} + P_{CH}} \quad (20)$$

Solving Eq. 17 for E gives:

$$E = A \times Q - 20.99 F_u / F_b \quad (21)$$

From Eqs. 2, 3, 5, and 16:

$$A = \frac{X}{1 + R} \quad (22)$$

$$B = \frac{X \times R}{(1 + R)} \quad (23)$$

$$C = \frac{K \times Y}{(K + R)} \quad (24)$$

Substituting Eqs. 21, 22, 23, 24, and 4, gives:

$$20.99 = \frac{X}{1+R} + \frac{X \times R/2}{1+R} + \frac{K \times Y/2}{K+R} + \frac{X \times Q}{1+R} - 20.99 F_u / F_b \quad (25)$$

Substituting Eqs. 5, 8, 9, and 10 into Eq. 25 and solving for A/F gives:

$$\begin{aligned} A/F &= \frac{F_b}{20.99} \left[\frac{F_c}{12.01} \left(\frac{1+R/2+Q}{1+R} \right) + \frac{K(F_h)}{4.032(K+R)} \right] \\ &= F_b \left[11.492 F_c \left(\frac{1+R/2+Q}{1+R} \right) + \left(\frac{120 \times F_h}{3.5+R} \right) \right] \quad (26) \end{aligned}$$

The air-fuel ratio is calculated only from ratios of the percentage components. Therefore, it is not necessary to know the extent of water condensed from the system nor the completeness of combustion as such.

EXPERIMENTAL

Data required to solve Eq. 26 are the percentage concentrations of CO, CO₂, CH (per carbon atom), and O₂. Instruments are available for continuous measurement of each of the components (6). Carbon monoxide and carbon dioxide were measured using Beckman nondispersive infrared analyzers with 1/8 in. thick sample cells and quartz windows. Oxygen was determined using a Beckman F-3 paramagnetic analyzer. Hydrocarbons were determined on a per carbon basis with a hydrogen flame detector.

To verify the use of the proposed equation, data were collected from a modified CFR engine. The engine was run at 1800 rpm, with a variety of air-fuel ratios and manifold pressures and with several fuels. Since fuel composition is very important, four hydrocarbons of widely varying carbon content were used: isooctane, diisobutylene, toluene, and a 50-50 blend of isooctane and toluene. In addition, four experimental commercial type fuels were also tested. Their carbon content varied from 84.55-87.03 weight %. Test parameters are given in Table 1.

Data were recorded on a Visicorder, an optical galvanometer. Chart width was 5-1/2 in. and readings were taken to the closest 0.02 in.

The data were collected at 4-8 different air-fuel ratios for each fuel and manifold pressure. No attempt was made to select any particular air-fuel ratio so long as a range from at least 10/1 to 15/1 was covered. Fuel was measured directly by timing the consumption of 0.1 lb. Airflow was measured by three techniques. Above 20 in. Hg MAP a calibrated orifice was used. For low MAP (11-12 in. Hg) as well as at higher MAP of 28 in. Hg a dry gas meter and a Meriam laminar flow meter were used in series. Since

Table 1 - Test Parameters

CFR engine with RDH head	8:1 Compression Ratio
Coolant temperature, F	210
Oil temperature, F	180
Speed ^{a, b}	1800 rpm
Spark advance, deg btc	(20) (25) (35)
MAP, in. Hg Absolute ^c	(12) (20) (28, 30)
Air-fuel ratio	Variable
Total number of A/F ratio observations	243
Fuels	Isooctane Diisobutylene Toluene Isooctane } Equal Parts Toluene }
	4 Commercial-type fuels

^a One set of air-fuel ratios were run at 900 rpm, 12 in. Hg MAP with diisobutylene.

^b One set of air-fuel ratios were run at 900 rpm, 28.7 in. Hg MAP with diisobutylene.

^c One set of air-fuel ratios were run at 1800 rpm, 11 in. Hg MAP with isooctane.

absolute airflow is not an easy thing to measure accurately the three devices used provided a system for self-checking.

Experimentally, the engine was run under specified conditions. While the fuel and airflow were being measured, exhaust gas analysis data were obtained. Air-fuel ratios were computed from both the measured air and fuel flow and the exhaust gas analysis. The data were analyzed by taking the difference between calculated and measured air fuel ratio. Table 2 gives some typical results. These data were chosen to show the effect of fuel carbon-hydrogen ratio and operating conditions.

RESULTS

This study, of necessity, compares air-fuel ratios measured directly with those calculated from exhaust gas composition. Fuel flow was measured by one method while airflow was measured by three techniques. All three methods gave very nearly the same results relative to the value calculated from exhaust analysis, with the Meriam meter perhaps most accurate.

Table 3 gives the average deviation between calculated and measured air-fuel ratios for the three methods of air measurement. The Meriam and dry gas meter were used simultaneously while the orifice meter was used with a different set of measurements.

The standard deviation of an observation with the Mer-

Table 2 - Typical Exhaust Gas Analyses Results

Per Cent							Air-Fuel Ratio						
CO ₂	CO	Hydro-carbon	O ₂	100F _u	Calc.	Meas-ured	CO ₂	CO	Hydro-carbon	O ₂	100F _u	Calc.	Meas-ured
Fuel: Toluene - MAP 12 in. Hg							Fuel B - Map 12 in. Hg						
11.06	8.70	0.584	0.73	2.87	10.69	10.46	6.15	9.85	2.638	2.82	14.14	10.37	10.39
13.70	4.35	0.421	0.72	2.28	12.10	11.78	8.59	8.70	0.760	1.20	4.21	11.56	11.37
14.63	2.98	0.350	0.75	1.95	12.62	12.50	10.31	6.54	0.400	0.37	2.32	12.25	12.75
15.10	0.67	0.412	1.40	2.55	13.78	13.68	12.73	1.91	0.273	0.72	1.83	14.37	14.37
13.36	0.23	0.68	3.77	4.79	15.50	15.29	13.26	0.73	0.400	1.30	2.86	15.15	15.12
Fuel: Toluene - MAP 20 in. Hg							Fuel B - MAP 28 in. Hg						
11.45	8.54	0.518	0.49	2.53	10.69	10.56	7.82	10.85	0.396	0.0	2.08	10.48	10.83
12.97	6.27	0.387	0.63	1.97	11.51	11.27	10.65	5.54	0.232	0.17	1.40	12.63	12.91
13.85	4.17	0.324	0.90	1.77	12.33	12.02	12.08	3.52	0.137	0.78	0.87	13.88	13.91
14.89	0.12	0.126	2.61	0.834	15.12	14.66	14.11	0.43	0.120	0.49	0.82	15.03	15.31
13.65	0.37	0.096	3.97	0.683	16.17	16.32	12.36	0.07	0.075	3.04	0.60	17.25	17.44
Fuel: Isooctane - MAP 12 in. Hg							Fuel C - MAP 12 in. Hg						
9.44	6.88	0.587	1.22	3.47	12.39	11.61	7.72	11.31	1.600	1.50	7.85	10.11	9.90
10.64	6.13	0.408	0.65	2.37	12.62	12.36	9.18	9.61	1.004	0.95	5.05	10.80	10.95
13.06	2.26	0.366	1.11	2.33	14.47	14.06	12.40	5.36	0.690	0.56	3.75	12.29	12.44
13.06	0.77	0.719	2.17	4.94	15.44	14.82	13.26	2.12	0.636	0.86	4.00	13.56	13.47
Fuel: Isooctane - MAP 20 in. Hg							Fuel C - MAP 28 in. Hg						
9.75	7.09	0.250	0.0	1.46	11.94	12.39	9.75	10.71	0.456	0.08	2.18	10.58	10.58
11.06	5.13	0.210	0.0	1.28	12.76	13.33	11.59	8.01	0.360	0.22	1.81	11.57	11.55
12.87	2.14	0.158	0.15	1.04	14.10	14.41	11.99	5.86	0.258	0.65	1.43	12.44	12.47
13.36	0.44	0.116	0.45	0.83	15.07	15.44	15.27	0.15	0.119	1.93	0.77	15.51	15.76
11.28	0.16	0.060	3.54	0.53	17.88	17.98	13.96	0.10	0.106	3.51	0.75	16.77	17.06
Fuel A - MAP 12 in. Hg							Fuel D - MAP 12 in. Hg						
7.16	10.67	3.208	1.84	15.31	9.49	9.83	6.39	9.35	2.698	2.30	14.62	10.14	10.19
9.18	9.75	0.979	0.0	4.92	10.35	10.83	8.37	7.83	0.840	0.84	4.94	11.32	11.17
11.54	6.24	0.621	0.41	3.38	11.96	12.07	11.50	3.69	0.390	0.48	2.50	13.18	13.41
13.75	1.81	0.438	0.42	2.74	13.64	13.65	12.64	0.85	0.703	0.98	1.48	14.91	15.16
13.96	0.30	0.270	1.90	1.86	15.41	15.44	11.63	0.17	0.750	4.00	6.00	16.98	16.75
11.94	0.27	0.999	4.70	7.56	16.82	17.22							
Fuel A - MAP 28 in. Hg							Fuel D - MAP 28 in. Hg						
8.99	10.36	0.558	0.0	2.80	10.42	10.69	6.57	11.56	0.540	0.0	2.89	9.74	9.91
12.78	4.52	0.336	0.18	1.91	12.64	12.88	8.52	8.92	0.382	0.0	2.14	10.93	11.20
14.73	1.22	0.230	0.62	1.34	14.20	14.29	9.71	6.71	0.310	0.0	1.85	11.77	12.14
14.73	0.21	0.173	1.29	1.14	15.10	15.24	11.94	2.76	0.204	0.59	1.37	13.80	13.83
13.36	0.12	0.011	3.00	0.08	16.65	16.82	13.16	0.16	0.120	1.26	0.89	15.53	15.75

iam gage and the dry gas meter is ± 0.23 air-fuel ratio units. This measure of error, however, contains the error in the analysis of exhaust composition and the error in "true" air and fuel-flow. A brief study of the effect of reading errors was made using some of the experimental results as a base

point. In each case the readings of each component were arbitrarily increased or decreased by 0.05 in. in a statistical pattern to give a $2 \times 2 \times 2 \times 2$ orthogonal array. The net change in reading of 0.1 in. for any one component gave a maximum deviation in air-fuel ratio of 0.08 and of all com-

Table 3 - Analysis of Data
Air-Fuel Ratio

Air Measure- ment	Average Deviation Measured- Calculated	Standard Deviation Measured- Calculated
Orifice meter	0.114	0.177
Meriam meter	-0.023	0.228
Dry Gas meter	-0.134	0.231

ponents of 0.21 under the most extreme conditions (each component in the direction of maximum error). Since the readings are not likely to be in error by more than 0.05 in. of chart, air-fuel ratios from exhaust gas analysis are about as accurate as those from direct measurement of air and fuel flow. This analysis shows that small errors in measurement do not significantly affect the air-fuel ratio determination.

The analyses so far discussed are for results obtained with good combustion, 95% complete or better. This equation will give reasonably accurate results even with poor combustion.

Table 4 gives some results of operating the engine at 11 in. Hg. Even under conditions where only 65% of the mixture burns the equation gives a reasonable measure of the air-fuel ratio. While these results do not appear to be as good as those obtained with better combustion, they are better than can be obtained with any other method of calculation. For example, the first result of Table 4 calculates to 20 air-fuel ratio by the Leonard method and is completely ambiguous by the D'Alleva charts.

The principal error in these measurements, and this is true for all of the data, may be in the hydrocarbon results. Hydrocarbons were measured with a flame ionization detector which is a carbon counter, nearly independent of the type of hydrocarbon burned. This detector gives low results in the presence of oxygen. With low hydrocarbon concentrations, this has little influence on the calculated air-fuel ratio since the hydrocarbon concentration enters only in the fraction burned calculation.

In the case of poor combustion with large concentrations of unburned hydrocarbon, there is a consistently large oxygen concentration. The effect of the oxygen is to underestimate the amount of hydrocarbon present which results in a calculated air-fuel ratio leaner than measured.

The use of an equation as complex as the one proposed, does not lend itself readily to hand computation. With the increasing use of computers for the analysis of exhaust gas data, calculation of air-fuel ratio can be simply another computer step to give more complete and meaningful interpretation of the data.

CONCLUSIONS

The analysis of exhaust gases can give a reliable measure of air-fuel ratio. The method can be applied to exhaust gases without regard to the degree of combustion encoun-

Table 4 - Exhaust Gas Analysis with
Incomplete Combustion

Per Cent					Air-Fuel Ratio	
CO ₂	CO	Hydro- carbon	O ₂	100F _u	Calc.	Meas- ured
Fuel: Isooctane - MAP 11 in. Hg						
4.89	6.97	6.40	7.50	35.05	10.91	10.47
7.96	6.85	2.16	3.28	12.75	12.16	11.62
10.23	4.61	1.43	2.56	8.79	13.35	12.90
11.63	1.48	1.47	3.86	10.10	15.46	14.55
7.65	0.17	3.55	9.95	31.32	18.64	16.79

tered in the engine. It is not sensitive to small errors in analysis.

In summary, to calculate air-fuel ratio determine the percentage concentrations of CO, CO₂, O₂, and hydrocarbons (per carbon atom). With these percentages and the known fraction of carbon in the fuel (F_c), calculate the following ratios:

$$R = P_{CO} / P_{CO_2}$$

$$Q = \frac{P_{O_2}}{P_{CO_2}}$$

$$F_b = (P_{CO} + P_{CO_2}) / (P_{CO} + P_{CO_2} + P_{CH})$$

Then:

$$A/F = F_b \left[11.492 F_c \left(\frac{1 + R/2 + Q}{1 + R} \right) + \frac{120(1 - F_c)^*}{3.5 + R} \right]$$

REFERENCES

- * ONLY IF $F_c + F_h = 1.0$
SEE EQUATION (26) ON PAGE 4.
1. B. A. D'Alleva and W. G. Lovell, SAE Journal, Vol. 38, (1936), 90.
 2. L. S. Leonard, "Fuel Distribution by Exhaust Gas Analysis." Paper 379A presented at SAE Summer Meeting, St. Louis, June 1961.
 3. Unpublished data from R. Hurn, U. S. Bureau of Mines, Bartlesville, Okla.
 4. R. D. Kopa, B. R. Hollander, and H. Kimura, "Combustion Temperature, Pressure, and Products at Chemical Equilibrium." SAE Progress in Technology, Vol. 7, "Digital Calculations of Engine Cycles," 1964.
 5. W. A. Daniel and J. T. Wentworth, paper "Exhaust Gas Hydrocarbons - Genesis and Exodus." SAE Progress in Technology, Vol. 6, "Vehicle Emissions," 1964.
 6. B. M. Sturgis, W. F. Biller, J. W. Bozek, and S. B. Smith, "The Application of Continuous Infrared Instruments to the Analysis of Exhaust Gas." SAE Progress in Technology, Vol. 6, "Vehicle Emissions," 1964.

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-1:D700
ENGINE MODEL: 12VAT25GL
REF.LOG.NUMBER: 0001
TEST NUMBER: 0001
LOG SHEET NUMBER: 0001
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS
CARBON: .23742 HYDROGEN: .07975
OXYGEN: 0 CARBON DIOXIDE: .6811

DATE: 10-9-90
BENCH NUMBER: TRUCK

NITROGEN: .00213
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.458

TEST NAME: FIRST

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	196.7	2410	75	40.855	6829	357.36
2	900	196.7	2410	75	40.855	6829	356.71
3	900	196.7	2410	75	40.855	6829	372.19
4	900	196.7	2410	75	40.855	6829	357.24
5	900	196.7	2410	75	40.855	6829	357.07

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NMHC PPM
1	460	37	74	11.57	8.35	31
2	407	63	76	11.59	8.30	30
3	377	44	75	11.07	8.93	26
4	407	59	78	11.59	8.33	25
5	466	34	76	11.57	8.33	30

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.017	8.65	8.94	1.64	1.147	.998
2	1.017	8.64	8.92	1.63	1.147	.999
3	1.017	9.01	9.36	1.71	1.141	.999
4	1.017	8.65	8.93	1.64	1.147	.999
5	1.017	8.65	8.93	1.64	1.147	.998

AKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NMHC	METHANE	NON METHANE	NO PPM
1	1.82	.24	.48	.48	.08	0.00	0.00	17
2	1.61	.41	.49	.49	.08	0.00	0.00	30
3	1.57	.30	.51	.51	.07	0.00	0.00	22
4	1.61	.38	.51	.51	.06	0.00	0.00	28
5	1.85	.22	.49	.49	.08	0.00	0.00	16

NOX
PPM

35
36
37
37
36

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-2:D700
ENGINE MODEL: 12VAT256L
REF.LOG.NUMBER: 0002
TEST NUMBER: 0002
LOG SHEET NUMBER: 0002
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS

CARBON: .23742 HYDROGEN: .07975
OXYGEN: 0 CARBON DIOXIDE: .6811

5

DATE: 10-9-90
BENCH NUMBER: TRUCK

NITROGEN: .00213
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.458

TEST NAME: ENGINE #2

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	205.9	2523	103	42.295	6753	379.72
2	900	205.9	2523	103	42.295	6753	379.64
3	900	205.9	2523	103	42.295	6753	390.26
4	900	205.9	2523	103	42.295	6753	382.43
5	900	205.9	2523	103	42.295	6753	382.39

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NM HC PPM
1	484	39	75	11.25	8.70	35
2	454	39	76	11.25	8.70	35
3	442	32	71	10.90	9.08	31
4	454	25	60	11.12	8.80	33
5	484	26	55	11.12	8.80	38

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.006	8.85	9.19	1.68	1.150	.998
2	1.006	8.84	9.19	1.68	1.150	.998
3	1.006	9.09	9.48	1.74	1.146	.998
4	1.006	8.91	9.28	1.70	1.149	.998
5	1.006	8.91	9.27	1.70	1.149	.998

WAKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NMHC	METHANE	NON METHANE	NO PPM
1	1.95	.26	.50	.54	.09	0.00	0.00	19
2	1.83	.26	.50	.54	.09	0.00	0.00	19
3	1.84	.22	.49	.52	.08	0.00	0.00	16
4	1.85	.17	.40	.43	.09	0.00	0.00	12
5	1.97	.17	.37	.40	.10	0.00	0.00	13

10X
PM

36
37
35
29
27

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-9:D700
ENGINE MODEL: 12VAT256L
REF.LOG.NUMBER: 0009
TEST NUMBER: 0009
LOG SHEET NUMBER: 0009
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS

CARBON: .22371 HYDROGEN: .07517
OXYGEN: .01054 CARBON DIOXIDE: .6355

DATE: 10-16-90
BENCH NUMBER: TRUCK

NITROGEN: .05476
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.098

TEST NAME: ENGINE #3

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	193.0	2365	43	41.301	6648	341.72
2	900	193.0	2365	43	41.301	6648	341.19
3	900	193.0	2365	43	41.301	6648	356.35
4	900	193.0	2365	43	41.301	6648	341.81
5	900	193.0	2365	43	41.301	6648	341.56

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NM HC PPM
1	460	42	99	11.39	8.43	24
2	389	61	99	11.41	8.38	23
3	342	58	100	10.90	9.00	21
4	389	63	105	11.39	8.40	23
5	460	49	108	11.39	8.40	24

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.048	8.22	8.45	1.66	1.138	.998
2	1.048	8.21	8.43	1.65	1.139	.999
3	1.048	8.58	8.84	1.73	1.133	.999
4	1.048	8.23	8.44	1.66	1.138	.999
5	1.048	8.22	8.44	1.65	1.139	.998

BRAKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NM HC	METHANE	NON METHANE	NO PPM
1	1.79	.27	.63	.58	.06	0.00	0.00	20
2	1.51	.39	.63	.58	.06	0.00	0.00	29
3	1.39	.39	.67	.62	.06	0.00	0.00	29
4	1.51	.40	.67	.62	.06	0.00	0.00	30
5	1.79	.31	.69	.64	.06	0.00	0.00	23

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-6:D700
ENGINE MODEL: 12VAT25GL
REF.LOG.NUMBER: 0006
TEST NUMBER: 0006
LOG SHEET NUMBER: 0006
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS

CARBON: .23742 HYDROGEN: .07975
OXYGEN: 0 CARBON DIOXIDE: .6811

DATE: 10-12-90
BENCH NUMBER: TRUCK

NITROGEN: .00213
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.458

TEST NAME: ENGINE #4

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	192.8	2363	111	41.912	7145	377.50
2	900	192.8	2363	111	41.912	7145	377.33
3	900	192.8	2363	111	41.912	7145	392.04
4	900	192.8	2363	111	41.912	7145	375.53
5	900	192.8	2363	111	41.912	7145	375.99

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NM HC PPM
1	454	28	56	11.17	8.70	30
2	389	27	58	11.17	8.68	29
3	372	22	56	10.68	9.20	30
4	389	26	59	11.19	8.60	29
5	454	27	58	11.19	8.63	30

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.064	8.86	9.22	1.69	1.151	.998
2	1.064	8.86	9.21	1.69	1.152	.999
3	1.064	9.21	9.62	1.76	1.146	.999
4	1.064	8.82	9.17	1.68	1.152	.999
5	1.064	8.83	9.18	1.68	1.152	.998

WAKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NMHC	METHANE	NON METHANE	NO PPM
1	1.94	.20	.39	.43	.08	0.00	0.00	14
2	1.66	.19	.41	.45	.08	0.00	0.00	13
3	1.66	.16	.41	.45	.09	0.00	0.00	11
4	1.66	.18	.41	.46	.08	0.00	0.00	12
5	1.94	.19	.41	.45	.08	0.00	0.00	13

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-8:D700
ENGINE MODEL: 12VAT25GL
REF.LOG.NUMBER: 0008
TEST NUMBER: 0008
LOG SHEET NUMBER: 0008
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS

CARBON: .22371 HYDROGEN: .07517
OXYGEN: .01054 CARBON DIOXIDE: .6355

0

DATE: 10-14-90
BENCH NUMBER: TRUCK

NITROGEN: .05476
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.098

TEST NAME: ENGINE #5

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	182.1	2232	95	40.203	6857	338.03
2	900	182.1	2232	95	40.203	6857	338.47
3	900	182.1	2232	95	40.203	6857	352.94
4	900	182.1	2232	95	40.203	6857	340.60
5	900	182.1	2232	95	40.203	6857	340.40

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NM HC PPM
1	466	20	61	11.17	8.70	26
2	430	26	57	11.17	8.73	29
3	419	18	54	10.63	9.30	31
4	436	23	55	11.08	8.80	29
5	466	18	55	11.08	8.80	26

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.081	8.29	8.62	1.69	1.148	.998
2	1.081	8.30	8.64	1.69	1.147	.998
3	1.081	8.66	9.06	1.78	1.142	.998
4	1.081	8.36	8.69	1.71	1.147	.998
5	1.081	8.35	8.69	1.70	1.147	.998

AKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NMHC	METHANE	NON METHANE	NO PPM
1	1.91	.13	.41	.43	.07	0.00	0.00	10
2	1.76	.18	.38	.40	.08	0.00	0.00	13
3	1.80	.13	.38	.40	.09	0.00	0.00	9
4	1.80	.16	.37	.39	.08	0.00	0.00	11
5	1.92	.12	.37	.39	.07	0.00	0.00	9

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-5:D700
ENGINE MODEL: 12VAT25GL
REF.LOG.NUMBER: 0005
TEST NUMBER: 0005
LOG SHEET NUMBER: 0005
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS
CARBON: .23742 HYDROGEN: .07975
OXYGEN: 0 CARBON DIOXIDE: .6811

DATE: 10-11-90
BENCH NUMBER: TRUCK

NITROGEN: .00213
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.458

TEST NAME: ENGINE #6

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	190.9	2340	97	41.382	7124	370.53
2	900	190.9	2340	97	41.382	7124	369.29
3	900	190.9	2340	97	41.382	7124	378.89
4	900	190.9	2340	97	41.382	7124	368.34
5	900	190.9	2340	97	41.382	7124	368.47

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NMHC PPM
1	472	33	80	11.30	8.70	30
2	477	35	85	11.30	8.63	33
3	460	33	80	10.99	8.98	31
4	477	39	78	11.30	8.58	33
5	477	31	84	11.30	8.58	30

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.061	8.83	9.17	1.68	1.149	.998
2	1.061	8.80	9.14	1.67	1.149	.998
3	1.061	9.03	9.40	1.72	1.146	.998
4	1.061	8.78	9.12	1.67	1.150	.998
5	1.061	8.78	9.12	1.67	1.150	.998

WAKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NM HC	METHANE	NON METHANE	NO PPM
1	2.00	.23	.56	.59	.08	0.00	0.00	16
2	2.02	.24	.59	.63	.09	0.00	0.00	17
3	2.00	.24	.57	.61	.09	0.00	0.00	16
4	2.01	.27	.54	.57	.09	0.00	0.00	19
5	2.01	.22	.58	.62	.08	0.00	0.00	15

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-4:D700
ENGINE MODEL: 12VAT25GL
REF.LOG.NUMBER: 0004
TEST NUMBER: 0004
LOG SHEET NUMBER: 0004
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS

CARBON: .23742 HYDROGEN: .07975
OXYGEN: 0 CARBON DIOXIDE: .6811

5

DATE: 10-11-90
BENCH NUMBER: TRUCK

NITROGEN: .00213
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.458

TEST NAME: ENGINE #7

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	193.0	2365	71	41.525	7073	371.81
2	900	193.0	2365	71	41.525	7073	370.61
3	900	193.0	2365	71	41.525	7073	387.47
4	900	193.0	2365	71	41.525	7073	370.61
5	900	193.0	2365	71	41.525	7073	370.57

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NMHC PPM
1	436	30	75	11.35	8.68	26
2	401	43	74	11.37	8.63	25
3	378	31	72	10.83	9.25	27
4	401	43	74	11.37	8.63	25
5	436	31	74	11.37	8.63	26

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.053	8.86	9.15	1.68	1.143	.998
2	1.053	8.83	9.12	1.67	1.144	.999
3	1.053	9.24	9.58	1.76	1.137	.999
4	1.053	8.83	9.12	1.67	1.144	.999
5	1.053	8.83	9.12	1.67	1.144	.998

AKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA
POINT

CO

NO

NOX

COR.
NOXTOTAL
NM HC

METHANE

NON
METHANENO
PPMNO
PPM

1	1.83	.21	.52	.51	.07	0.00	0.00	14
2	1.68	.30	.51	.50	.07	0.00	0.00	21
3	1.67	.22	.52	.52	.08	0.00	0.00	16
4	1.68	.30	.51	.50	.07	0.00	0.00	21
5	1.83	.21	.51	.50	.07	0.00	0.00	15

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-3:D700
ENGINE MODEL: 12VAT25GL
REF.LOG.NUMBER: 0003
TEST NUMBER: 0003
LOG SHEET NUMBER: 0003
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS

CARBON: .23742 HYDROGEN: .07975
OXYGEN: 0 CARBON DIOXIDE: .6811

5

DATE: 10-10-90
BENCH NUMBER: TRUCK

NITROGEN: .00213
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.458

TEST NAME: ENGINE #8

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	194.6	2385	67	40.899	6908	369.32
2	900	194.6	2385	67	40.899	6908	372.79
3	900	194.6	2385	67	40.899	6908	384.86
4	900	194.6	2385	67	40.899	6908	373.41
5	900	194.6	2385	67	40.899	6908	373.20

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NM HC PPM
1	442	39	74	11.19	8.80	26
2	395	34	68	11.08	8.93	23
3	377	31	66	10.72	9.38	22
4	395	31	69	11.08	8.95	23
5	430	30	63	11.12	9.00	26

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.029	8.94	9.25	1.70	1.141	.998
2	1.029	9.03	9.35	1.71	1.139	.999
3	1.029	9.32	9.69	1.77	1.135	.999
4	1.029	9.04	9.36	1.71	1.139	.999
5	1.029	9.04	9.36	1.72	1.139	.998

AKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NM HC	METHANE	NON METHANE	NO PPM	NOX PPM
1	1.84	.27	.51	.49	.07	0.00	0.00	19	36
2	1.66	.23	.47	.46	.06	0.00	0.00	17	34
3	1.64	.22	.47	.46	.06	0.00	0.00	16	34
4	1.66	.21	.48	.47	.06	0.00	0.00	15	34
5	1.81	.21	.44	.43	.07	0.00	0.00	15	31

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-7:D700
ENGINE MODEL: 12VAT25GL
REF.LOG.NUMBER: 0007
TEST NUMBER: 0007
LOG SHEET NUMBER: 0007
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS

CARBON: .23742 HYDROGEN: .07975
OXYGEN: 0 CARBON DIOXIDE: .6811

5

DATE: 10-13-90
BENCH NUMBER: TRUCK

NITROGEN: .00213
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.458

TEST NAME: ENGINE #1 RECHECK

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	189.8	2326	102	41.781	7236	374.82
2	900	189.8	2326	102	41.781	7236	374.98
3	900	189.8	2326	102	41.781	7236	390.49
4	900	189.8	2326	102	41.781	7236	375.03
5	900	189.8	2326	102	41.781	7236	374.94

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NM HC PPM
1	478	15	49	11.17	8.70	30
2	378	28	49	11.17	8.70	28
3	366	25	45	10.66	9.25	20
4	372	29	53	11.17	8.68	28
5	478	16	51	11.17	8.70	30

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.078	8.84	9.21	1.69	1.149	.998
2	1.078	8.84	9.22	1.69	1.149	.999
3	1.078	9.21	9.65	1.77	1.144	.999
4	1.078	8.85	9.21	1.69	1.149	.999
5	1.078	8.84	9.21	1.69	1.149	.998

WAKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NMHC	METHANE	NON METHANE	NO PPM	NOX PPM
1	2.07	.11	.35	.38	.09	0.00	0.00	7	24
2	1.64	.20	.35	.38	.08	0.00	0.00	14	24
3	1.66	.19	.34	.36	.06	0.00	0.00	13	23
4	1.61	.21	.38	.41	.08	0.00	0.00	14	26
5	2.07	.11	.36	.39	.09	0.00	0.00	8	25

WAUKESHA ENGINE DIVISION EMISSIONS ANALYSIS PROGRAM

FILE NAME: JLF-10:D700
ENGINE MODEL: 12VAT25GL
REF.LOG.NUMBER: 0010
TEST NUMBER: 0010
LOG SHEET NUMBER: 0010
OPERATOR: D.A.PERKINS

FUEL DESCRIPTION: LANDFILL GAS

WEIGHT FRACTIONS

CARBON: .22318 HYDROGEN: .07504
OXYGEN: .00078 CARBON DIOXIDE: .6846

DATE: 11-6-90
BENCH NUMBER: TRUCK

NITROGEN: .01647
HYDROGEN TO CARBON RATIO: 4.006
STOICHIOMETRIC A/F: 5.130

TEST NAME: ENGINE #8 RECHECK

RAW DATA PRINT OUT:

DATA POINT	SPEED RPM	BMEP PSI	BHP	HUMIDITY GR/LB	FUEL FLOW LB/MIN	BSFC BTU/BHP-HR	AIR FLOW LB/MIN
1	900	195.8	2400	44	43.532	6888	359.79
2	900	195.8	2400	44	43.532	6888	359.97
3	900	195.8	2400	44	43.532	6888	377.07
4	900	195.8	2400	44	43.532	6888	364.15
5	900	195.8	2400	44	43.532	6888	363.32

DATA POINT	CO PPM	NO PPM	NOX PPM	CO2 %	O2 %	NMHC PPM
1	466	49	104	11.79	8.35	19
2	98	84	105	11.84	8.33	18
3	86	88	101	11.25	8.98	19
4	104	78	104	11.61	8.43	18
5	466	51	100	11.61	8.43	19

EMISSIONS ANALYSIS:

DATA POINT	BSFC LBS/BHP-HR	MEASURED DRY A/F	SPINDT A/F	LAMBDA (SPINDT)	WET EXH/ DRY EXH	COMBUSTION EFFICIENCY
1	1.088	8.21	8.44	1.65	1.139	.999
2	1.088	8.22	8.44	1.64	1.139	1.000
3	1.088	8.61	8.88	1.73	1.132	1.000
4	1.088	8.31	8.54	1.67	1.137	1.000
5	1.088	8.29	8.52	1.66	1.137	.998

WAKE SPECIFIC EMISSIONS FOR DRY EXHAUST GAS
GRAMS/BHP-HR

EPA HUM.

CORRECTED
TO 15% OXYGEN

DATA POINT	CO	NO	NOX	COR. NOX	TOTAL NMHC	METHANE	NON METHANE	NO PPM	NOX PPM
1	1.88	.32	.69	.64	.05	0.00	0.00	23	49
2	.39	.56	.69	.64	.05	0.00	0.00	39	49
3	.36	.61	.70	.65	.05	0.00	0.00	44	50
4	.42	.52	.70	.64	.05	0.00	0.00	37	49
5	1.90	.34	.67	.62	.05	0.00	0.00	24	47

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 1 OF 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

SAMPLE CALCULATION FOR FUEL CONSUMPTION AND BRAKE SPECIFIC EMISSION RATES.
CALCULATION WILL BE FOR UNIT #1, LINE #1 - PRE-CATALYST CONDITION.
SEE APPENDIX E FOR RAW DATA.

NOTE: TO SIMPLIFY THIS EXAMPLE, ITERATIVE CALCULATIONS WILL NOT BE DONE. INSTEAD, FINAL RESULTS FROM COMPUTER PRINTOUT WILL BE USED.

A. BRAKE SPECIFIC FUEL CONSUMPTION (BSFC)

AVERAGE HORSEPOWER 2410 BHP

FUEL PROPERTIES:

SATURATED LOW HEAT VALUE 502 BTU/FT³

SPECIFIC GRAVITY .980

FUEL GAS DENSITY = .980 x .0763
= .07477 LB/FT³

$$BSFC = 1040.0 \left(\frac{SLHV}{BHP} \right) \left(\frac{FT^3}{MIN} \right) \left(\frac{BP + P_{GAS}}{T_{GAS} + 460^{\circ}F} \right)$$

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 2 OF 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

WHERE : 1040.0
 SLHV
 BHP
 FT³
 MIN
 BP
 P_{GAS}
 T_{GAS}

UNIT CONVERSION FACTOR
 SATURATED LOW HEAT VALUE
 BRAKE HORSEPOWER
 CUBIC FEET MEASURED
 MINUTES TO MEASURE FT³
 BAROMETRIC PRESSURE IN. Hg
 MEASURED FUEL GAS PRESSURE
 MEASURED FUEL GAS TEMPERATURE

FOR UNIT #1, READINGS 4 AND 5 ARE DISCARDED
 PER THE TEST PROTOCOL BASED ON PRELIMINARY
 CALCULATIONS.

READING #1

$$BSFC = \frac{(1040)(502)}{2410} \left(\frac{200}{1.680} \right) \left(\frac{29.87 + \frac{55 \text{ psi}}{.491}}{77^\circ + 460^\circ} \right)$$

$$= 6814.1 \text{ BTU/BHP-HR}$$

READING #2

$$BSFC = \frac{(1040)(502)}{2410} \left(\frac{200}{1.680} \right) \left(\frac{29.87 + \frac{55 \text{ psi}}{.491}}{77^\circ + 460^\circ} \right)$$

$$= 6814.1 \text{ BTU/BHP-HR}$$

READING #3

$$BSFC = \frac{(1040)(502)}{2410} \left(\frac{200}{1.681} \right) \left(\frac{29.87 + \frac{55.5 \text{ psi}}{.491}}{77^\circ + 460^\circ} \right)$$

$$= 6858.9 \text{ BTU/BHP-HR}$$

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 3 OF 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

$$\begin{aligned} \text{AVERAGE BSFC} &= \frac{6814.1 + 6814.1 + 6858.9}{3} \\ &= 6829 \text{ BTU / BHP-HR} \end{aligned}$$

B. FUEL FLOW

$$\begin{aligned} \text{FUEL FLOW} &= \text{BSFC} \frac{\text{BTU}}{\text{BHP-HR}} \times \frac{1}{60 \frac{\text{HR}}{\text{MIN}}} \times 2410 \text{ BHP} \times \frac{1}{502 \frac{\text{BTU}}{\text{FT}^3}} \times \\ & \quad .07477 \frac{\text{Lb}}{\text{FT}^3} \end{aligned}$$

$$\begin{aligned} \text{FUEL FLOW} &= (6829) \left(\frac{1}{60} \right) (2410) \left(\frac{1}{502} \right) (.07477) \\ &= 40.855 \text{ Lb / MIN} = 2451.3 \text{ Lb / HR} \end{aligned}$$

C. AIR - FUEL RATIO

FROM APPENDIX F, EQUATION (26) THE AIR-FUEL RATIO IS:

$$\text{AFR} = F_b \left[11.492 F_c \left(\frac{1 + R/2 + Q}{1 + R} \right) + \left(\frac{120 \times F_{H_2}}{3.5 + R} \right) \right]$$

THIS EQUATION MUST BE MODIFIED FOR FUELS CONTAINING SIGNIFICANT LEVELS OF CO₂ SINCE CO₂ IS A PRODUCT OF COMBUSTION. IF A CORRECTION WERE NOT MADE THE CO₂ ENTERING WITH THE FUEL GAS WOULD BE ASSUMED TO HAVE

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 4 OF 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

BEEN FORMED BY COMBUSTION. THIS WOULD GIVE AN ERRONEOUS AIR-FUEL RATIO VALUE. SUBTRACTING THE FUEL-BORNE CO_2 :

$$AFR = F_b \left[(11.492 F_c + 3.136 F_{CO_2}) \left(\frac{1 + \frac{R}{2} + Q}{1 + R} \right) + \left(\frac{120 \times F_{H_2}}{3.5 + R} \right) - 3.136 F_{CO_2} \right]$$

THE EQUATION PARAMETERS ARE DEFINED IN APPENDIX F.

TAKING THE APPROPRIATE VALUES FOR FUEL "A" FROM TABLE I:

CARBON FRACTION = F_c = .23742
 HYDROGEN FRACTION = F_{H_2} = .07975
 CARBON DIOXIDE FRACTION = F_{CO_2} = .68115

FROM APPENDIX E FOR LINE #1, UNIT #1:

CO IN EXHAUST = P_{CO} = 460 ppm = .046 %
 CO₂ IN EXHAUST = P_{CO_2} = 11.57 %
 O₂ IN EXHAUST = P_{O_2} = 8.35 %
 CH IN EXHAUST = 1860 ppm = .186 %

THIS LATTER VALUE IS MEASURED "WET". TO CONVERT TO AN EQUIVALENT "DRY" VALUE IT IS MULTIPLIED BY THE WET/DRY RATIO. THIS IS DETERMINED BY AN ITERATIVE PROCESS. TAKING THE VALUE 1.147 FROM APPENDIX G:

$$P_{CH} = (.186 \%)(1.147) = .2133 \%$$

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 5 OF 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

WE CAN NOW CALCULATE

$$R = P_{CO} / P_{CO_2} = .046 / 11.57 = .003976$$

$$Q = P_{O_2} / P_{CO_2} = 8.35 / 11.57 = .72169$$

$$F_b = \frac{P_{CO} + P_{CO_2}}{P_{CO} + P_{CO_2} + P_{CH}} = \frac{.046 + 11.57}{.046 + 11.57 + .2133} = .9820$$

AND

$$AFR = .982 \left[((11.492)(.23742) + (3.136)(.68115)) \left(\frac{1 + \frac{.003976}{2} + .72169}{1 + .003976} \right) + \left(\frac{(120)(.07975)}{3.5 + .003976} \right) - (3.136)(.68115) \right]$$

$$AFR = 8.947 : 1$$

D. AIR FLOW

$$\begin{aligned} \text{AIR FLOW} &= \text{FUEL FLOW} \times \text{AFR} \\ &= (2451.3 \text{ LB/HR})(8.947) \\ &= 21931.8 \text{ LB/HR} \end{aligned}$$

E. EXHAUST FLOW

THE TOTAL EXHAUST FLOW IS THE SUM OF THE AIR AND FUEL FLOWS.

$$\text{EXHAUST FLOW} = 2451.3 + 21931.8 = 24,383.1 \text{ LB/HR}$$

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 6 OF 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

F. BRAKE SPECIFIC EMISSION RATES.

FROM APPENDIX E

NO _x	74 ppm	VOLUME	"DRY"	MEASURED
CO	460 ppm	VOLUME	"DRY"	MEASURED
THC	1860 ppm	VOLUME	"WET"	MEASURED
NMHC	31 ppm	VOLUME	"WET"	MEASURED

THE WET/DRY RATIO FROM APPENDIX G IS USED TO CONVERT THE MEASURED NO_x AND CO VALUES TO EQUIVALENT "WET" READINGS.

$$\begin{aligned}
 \text{NO}_x &= 74 \text{ ppm} / 1.147 = 64.5 \text{ ppm "WET" volume} \\
 \text{CO} &= 460 \text{ ppm} / 1.147 = 401.0 \text{ ppm "WET" volume}
 \end{aligned}$$

WE MUST DETERMINE MASS FRACTIONS AS OPPOSED TO THE MEASURED VOLUME FRACTIONS (ppm).

TO DO THIS WE MUST DETERMINE THE APPARENT MOLECULAR WEIGHT OF THE EXHAUST STREAM.

FROM APPENDIX E THE MEASURED EXHAUST ANALYSIS IS:

NO _x	= 74 ppm	= .0074%	= .000074	"DRY"
CO	= 460 ppm	= .0460%	= .000460	"DRY"
THC	= 1860 ppm	= .1860%	= .001860	"WET"
CO ₂	=	11.57%	= .115700	"DRY"
O ₂	=	8.35%	= .083500	"DRY"

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 7 of 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

FROM APPENDIX G THE WET/DRY RATIO IS 1.147

$$\frac{1}{1.147} = .8718$$

THEREFORE $1 - .8718 = .1282$ OR 12.82% OF THE EXHAUST STREAM IS WATER VAPOR.

CONVERTING TO AN ENTIRE "WET" ANALYSIS:

$NO_x = .0000645$
 $CO = .0004010$
 $THC = .001860$
 $CO_2 = .100872$
 $O_2 = .072799$
 $H_2O = .128200$
 BALANCE $N_2 = .695803$

THE APPARENT MOLECULAR WEIGHT OF THE EXHAUST STREAM IS CALCULATED AS:

SPECIE	VOLUME FRACTION	SPECIE MOL. WT.	MOLECULAR WEIGHT FRACTION
NO_x (AS NO_2)	.0000645	46.01	.003
CO	.000401	28.01	.011
THC (AS CH_4)	.001860	16.04	.030
CO_2	.100872	44.01	4.439
O_2	.072799	32.00	2.330
H_2O	.128200	18.02	2.310
N_2	.695803	28.02	19.496
SUM =	.9999995		28.619

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 8 OF 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

TO CONVERT MEASURED VOLUME FRACTIONS TO MASS FRACTIONS MULTIPLY THE VOLUME FRACTION BY THE RATIO OF SPECIE MOLECULAR WEIGHT TO APPARENT EXHAUST MOLECULAR WEIGHT.

SPECIE	VOLUME FRACTION	SPECIE MOL. WT.	SPECIE MOL. WT 28.619	MASS FRACTION
NO _x (AS NO ₂)	.0000645	46.01	1.6077	.0001037
CO	.000401	28.01	.9787	.0003925
THC (AS CH ₄)	.001860	16.04	.5605	.0010425
CO ₂	.100872	44.01	1.5378	.1551199
O ₂	.072799	32.00	1.1181	.0813994
H ₂ O	.128200	18.02	.6296	.0807213
N ₂	.695803	28.02	.9791	.6812397
SUM =	.9999995			1.0000190

FINALLY, EACH BRAKE SPECIFIC EMISSION RATE IS CALCULATED AS:

$$E_i = \frac{(\text{TOTAL EXHAUST MASS FLOW RATE}) \times (\text{MASS FRACTION}_i)}{\text{BHP}}$$

$$E_i = 24383.1 \frac{\text{LB}}{\text{HR}} \times 453.6 \frac{\text{gram}}{\text{LB}} \times \frac{1}{2410 \text{ BHP}} \times MF_i$$

$$E_i = 4589.2839 \times MF_i \quad \text{gr/BHP-HR}$$

PREPARED BY STACHOWICZ	Waukesha DRESSER	PAGE 9 OF 9
CHECKED BY	ENGINEERING CALCULATION FORM	PROGRAM & PROJECT NO. JOHNSTON
TERMATREX NO.	SUBJECT SAMPLE CALCULATION	DATE 28 NOV 90

$$\text{NO}_x : 4589.2839 \times .0001037 = .476 \text{ gr/BHP-HR}$$

$$\text{CO} : 4589.2839 \times .0003925 = 1.801 \text{ gr/BHP-HR}$$

$$\text{THC} : 4589.2839 \times .0010425 = 4.784 \text{ gr/BHP-HR}$$

FOR NON-METHANE HYDROCARBONS :

$$1860 \text{ ppm} - 31 \text{ ppm} = 1829 \text{ ppm} = .001829 \text{ (volume)}$$

$$.001829 \times .5605 = .0010252 \text{ (MASS)}$$

$$\begin{aligned} \text{NMHC} &= 4.784 - 4589.2839 \times .0010252 = 4.784 - 4.705 \\ \text{NMHC} &= .079 \text{ gr/BHP-HR} \end{aligned}$$