

Bethlehem, 12/96

BID
107

AP-42
73

NOx
NMOC--DE

(A)

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/


The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.


AirRecon[®]

Division of
RECON Environmental Corp.

5 Johnson Drive, P.O. Box 130
Raritan, NJ 08869-0130
(908) 526-1000
FAX (908) 526-7886

13




INTRODUCTION

AirRECON, a division of Levine•Fricke•Recon Inc., was contracted by LFG Specialties Inc. to perform a destruction efficiency evaluation on an enclosed landfill gas flare located at Bethlehem Landfill, Bethlehem PA.

The inlet and outlet were sampled concurrently for emissions of total hydrocarbons (as methane) and nitrogen oxides (NO_x as NO_2). Destruction efficiency of total hydrocarbons was calculated and compared to the permit application levels listed in *Section D*. The permit application is in Appendix I.

During the testing program, one process interruption occurred during Run 3. There was power outage for approximately 10 minutes. The testing was stopped immediately and resumed shortly after power was restored. Due to this interruption, one less GC-FID injection was performed for Run 3 than for Runs 1 and 2. There were no other process interruptions during the testing program.

Testing was performed in accordance with an approved protocol, which is presented in Appendix I. Sampling dates and times are detailed, along with emissions values, in the *SUMMARY* section of this report.




The logo features a horizontal rectangular bar with a textured, stippled pattern. Below this bar, the word "AirRecon" is written in a large, bold, serif font. The word "Air" is in an italicized style, while "Recon" is in a standard weight. A registered trademark symbol (®) is positioned to the upper right of the word "Recon".

AirRecon®

*Division of
RECON Environmental Corp.*

*5 Johnson Drive, P.O. Box 130
Raritan, NJ 08869-0130
(908) 526-1000
FAX (908) 526-7886*



COMPLIANCE STACK TEST REPORT

FOR THE LANDFILL GAS FLARE
INLET & OUTLET AT
BETHLEHEM LANDFILL
2335 APPLEBUTTER ROAD
BETHLEHEM PA

Prepared for
LFG SPECIALTIES INC.
705 South Friendship Drive
New Concord OH 43762
Attn: Tim Telepak

In Fulfillment of Purchase Order No. 1292

AirRECON Project AR5-6922

Test Dates: October 8 & 9, 1996

Report Date: December 3, 1996

D.93

COMPLIANCE STACK TEST REPORT

ON THE

LANDFILL GAS FLARE INLET & OUTLET
AT BETHLEHEM LANDFILL, BETHLEHEM PA

INTRODUCTION	1
EMISSIONS SUMMARY	2
PERSONNEL AND CERTIFICATIONS	4
SAMPLING LOCATIONS	5
STACK CONDITIONS	7
CYCLONIC FLOW CHECK	9
SAMPLING DATA	10
PROCEDURES	11
NOMENCLATURE & LABORATORY INFORMATION	12
APPENDICES	
I	APPROVED PROTOCOL
II	EMISSION CALCULATIONS
III	CEM DATA SUMMARIES
IV	FIELD DATA SHEETS
V	CALIBRATION DATA & CYLINDER GAS CERTIFICATES
VI	CEM STRIP CHARTS
VII	LABORATORY DATA

INTRODUCTION

AirRECON, a division of Levine•Fricke•Recon Inc., was contracted by LFG Specialties Inc. to perform a destruction efficiency evaluation on an enclosed landfill gas flare located at Bethlehem Landfill, Bethlehem PA.

The inlet and outlet were sampled concurrently for emissions of total hydrocarbons (as methane) and nitrogen oxides (NO_x as NO_2). Destruction efficiency of total hydrocarbons was calculated and compared to the permit application levels listed in *Section D*. The permit application is in Appendix I.

During the testing program, one process interruption occurred during Run 3. There was power outage for approximately 10 minutes. The testing was stopped immediately and resumed shortly after power was restored. Due to this interruption, one less GC-FID injection was performed for Run 3 than for Runs 1 and 2. There were no other process interruptions during the testing program.

Testing was performed in accordance with an approved protocol, which is presented in Appendix I. Sampling dates and times are detailed, along with emissions values, in the *SUMMARY* section of this report.

EMISSIONS SUMMARY

RUN	1	2	3
DATE	10/09/96	10/09/96	10/09/96
TIME	1006-1106	1220-1320	1405-1514
NITROGEN OXIDES (NO_x as NO₂) / OUTLET			
PPMV (wet)	6.4	7.7	7.7
PPMV (dry)	6.8	8.5	8.4
POUNDS/HOUR	0.37	0.45	0.39
PPMV (dry @ 7% O ₂)	9.4	11.5	11.2
TOTAL NON-METHANE HYDROCARBONS (as METHANE) / INLET			
PPMV (wet)	890	750	750
PPMV (dry)	910	770	770
POUNDS/HOUR	2.5	2.1	2.1
TOTAL NON-METHANE HYDROCARBONS (as METHANE) / OUTLET			
PPMV (wet)	ND < 1.0	ND < 1.0	ND < 1.0
PPMV (dry)	ND < 1.1	ND < 1.1	ND < 1.1
POUNDS/HOUR	ND < 0.02	ND < 0.02	ND < 0.02
TOTAL NON-METHANE HYDROCARBONS DESTRUCTION EFFICIENCY			
PERCENT	> 99.2	> 99.0	> 99.2

Any remaining project sample will be kept for 60 days from report date unless directed otherwise.

ALLOWABLE EMISSIONS SUMMARY

The following allowable emissions are based on our understanding of the applicable regulatory rules and regulations. Since we are not always privy to the situation, these should not be accepted without confirmation from relevant sources.

RUN 1	RUN 2	RUN 3	STATE PERMIT ALLOWABLE (Log No. 48-322-002A)	UNITS
TOTAL NON-METHANE HYDROCARBONS (as methane)				
<0.02	<0.02	<0.02	1.75	lb/hr
NITROGEN OXIDES				
0.37	0.45	0.39	1.30	lb/hr

PERSONNEL AND CERTIFICATIONS

FIELD SAMPLING ON THIS PROJECT WAS PERFORMED BY:

John R. Geissler

David P. Forbes

Barry Savar

CALCULATIONS AND REPORT PREPARATION WERE PERFORMED BY:


John R. Geissler

C. Daniel Miesse


THE TESTING WAS OBSERVED BY:

Tom Lechene PAVEX

THIS REPORT IS SUBMITTED BY:



John R. Geissler, CIH
Scientific Associate

APPROVED BY:


Thomas F. Mattei
Manager, Special Projects


PROFESSIONAL ENGINEER OR CERTIFIED INDUSTRIAL HYGIENIST CERTIFICATION

I CERTIFY THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION DEVELOPED OR ACQUIRED BY RECON PERSONNEL IN THIS REPORT AND, TO THE BEST OF MY KNOWLEDGE, THIS INFORMATION IS TRUE, ACCURATE AND COMPLETE.


NORMAN J. WEINSTEIN, P.E.
PENNSYLVANIA LICENSE 19270-E

CDM/vjm (D.93/6922.S)


INLET



TOP VIEW

PLAN
SCALE: 1/2" = 1'-0"

USEPA Distance A = >25
USEPA Distance B = 9
Duct ID = 12"




SIDE VIEW



SECTION
N.T.S.

OUTLET

6



USEPA Distance A = 0.5
 USEPA Distance B = 4.4
 STACK ID = 7'



STACK CONDITIONS: INLET

RUN	1	2	3
DATE	10/09/96	10/09/96	10/09/96
TIME	1006-1106	1220-1320	1405-1514
STACK DIAMETER (in)	12.0	12.0	12.0
STACK CROSS SECTION (sq ft)	0.79	0.79	0.79
BAROMETRIC PRESSURE ("Hg)	29.73	29.72	29.72
AVG. STACK TEMP (°F)	91	93	92
STACK PRESSURE ("H ₂ O-gage)	1.8	1.8	1.8
MOISTURE (% vol)	2.2	1.8	1.9
O ₂ (% vol)	1.8	1.4	1.2
CO ₂ (% vol)	25.4	25.8	26.2
CH ₄ (% vol)	24.2	24.3	24.7
N ₂ (% vol by difference)	48.6	48.5	47.9
AVG. VELOCITY (ft/sec)	25.2	25.2	25.0
ACTUAL FLOW RATE (acfm)	1,190	1,190	1,180
STD FLOW RATE (scfm)	1,140	1,140	1,130
DRY STD FLOW RATE (dscfm)	1,110	1,120	1,110

Standard Conditions are 70°F, 29.92 "Hg.

STACK CONDITIONS: OUTLET

RUN	1	2	3
DATE	10/09/96	10/09/96	10/09/96
TIME	1006-1106	1220-1320	1405-1514
STACK DIAMETER (in)	84	84	84
STACK CROSS SECTION (sq ft)	38.5	38.5	38.5
BAROMETRIC PRESSURE ("Hg)	29.73	29.72	29.72
AVG. STACK TEMP (°F)	1,470	1,480	1,500
STACK PRESSURE ("H ₂ O-gage)	-0.06	-0.06	-0.06
MOISTURE (% vol)	5.7	9.0	8.3
O ₂ (% vol)	10.8	10.7	10.5
CO ₂ (% vol)	9.1	9.3	9.4
N ₂ (% vol by difference)	80.1	80.0	80.1
AVG. VELOCITY (ft/sec)	13.0	13.2	11.4
ACTUAL FLOW RATE (acfm)	29,900	30,400	26,300
STD FLOW RATE (scfm)	8,160	8,250	7,080
DRY STD FLOW RATE (dscfm)	7,700	7,510	6,490

Standard Conditions are 70°F, 29.92 "Hg.

CYCLONIC FLOW

POINT	ANGLE, DEGREES	
	OUTLET	
	PORT A	PORT B
1	2	0
2	4	3
3	8	5
4	5	2
5	2	6
6	0	8
7	4	6
8	2	8
AVERAGE	3.4	4.8
OVERALL AVG.	4.1	

The absence of cyclonic flow is verified if the average value of the rotation angle is less than 20 degrees.

SAMPLING DATA

RUN	1	2	3
DATE	10/09/96	10/09/96	10/09/96
TIME	1006-1106	1220-1320	1405-1514
INLET & OUTLET HYDROCARBONS (as METHANE)			
No. OF SAMPLING POINTS	1	1	1
SAMPLING TIME (min)	60	60	60
SAMPLE RATE (ℓ/min)	1	1	1
INLET & OUTLET MOISTURE			
No. OF SAMPLING POINTS	1	1	1
SAMPLING TIME (min)	60	60	60
SAMPLE RATE (cfm)	0.5	0.5	0.5
OUTLET NITROGEN OXIDES (as NO₂)			
No. OF SAMPLING POINTS	1	1	1
SAMPLING TIME (min)	60	60	60
SAMPLE RATE (ℓ/min)	1	1	1

SELECTED NOMENCLATURE

Time	= military time
min	= minutes
°F	= degrees Fahrenheit
°C	= degrees Centigrade
"H ₂ O	= inches water (pressure or vacuum)
"Hg	= inches mercury (pressure or vacuum)
mm Hg	= millimeters of mercury (pressure or vacuum)
psig	= pounds of pressure per square inch-gage
sq ft	= square feet
in	= inches
micron	= 10 ⁻⁶ meters
ft/sec	= feet per second
ft/min	= feet per minute
acfm	= cubic feet per minute of total gas flow at flowing conditions
scfm	= cubic feet per minute of total gas flow at 70°F, 29.92"Hg
dscfm	= dry cubic feet per minute of dry gas flow at 70°F, 29.92"Hg
pounds/hour	= pounds per hour
pounds/hour	= pounds per hour
BTU/hr	= British thermal units per hour
%	= volume per cent when referred to gases and water vapor
	= weight percent for solids, liquids
% vol	= volume per cent
% wgt	= weight percent
ppmv	= volumes of gaseous contaminants per million volumes of total gas
grains	= grams x 15.4
ug	= micrograms = 10 ⁻⁶ grams
mg	= milligrams = 10 ⁻³ grams
grains/dscf	= grains of pollutants per cubic foot of dry stack gas at 70°F, 29.92 "Hg
gr/dscf	= grains/dscf
ug/m ³	= micrograms of pollutants per cubic meter of total stack gas at 25°C, 760 mm Hg
mg/l	= milligrams/liter of liquid = ppm by weight if specific gravity of liquid = 1.0
C	= elemental carbon
CO ₂	= carbon dioxide
H	= elemental hydrogen
H ₂	= molecular hydrogen
H ₂ O	= water
N	= elemental nitrogen
N ₂	= molecular nitrogen
NO _x = NO + NO ₂	= nitrogen oxides = nitric oxide plus nitrogen dioxide reported as equivalent nitrogen dioxide
S	= elemental sulfur
SO ₂	= sulfur dioxide
SO ₃	= sulfur trioxide
SO ₄	= sulfate
H ₂ SO ₄	= sulfuric acid
H ₂ S	= hydrogen sulfide
Cl	= elemental chlorine or chloride
Cl ₂	= molecular chlorine
HCl	= hydrogen chloride
F	= elemental fluorine or fluoride
CH ₄	= methane
O	= elemental oxygen
O ₂	= molecular oxygen
A	= argon
<	= less than; represents the minimum detectability limits
≤	= equal to or less than
ND	= none detected

Front half (dry catch particulate) = particulate matter collected in/on nozzle, probe, cyclone, flask heated hose, and filter of EPA sampling train

Back Half (wet catch particulate) = material collected in impingers after filter of EPA sampling train

Organic wet catch = residue after low temperature (70°F) evaporation of ether/chloroform used to extract soluble materials from the wet catch

Aqueous wet catch = residue after high temperature (220°F) evaporation of water left after ether/chloroform extraction

Combustibles = volatiles = loss on heating @ 550°C after drying @ 100°C

Ash = residue after heating @550°C

LABORATORY
INFORMATION SHEET

12

5 Johnson Drive
PO Box 130
Raritan, NJ 08869-0130

908-725-7744 / FAX 908 526-7886
ANALYTICAL REMARKS

- a = possibly significant, unidentified peaks observed during normal run time
b = possibly significant, unidentified peaks observed subsequent to normal run time
dx = minimum detection limits are x times those listed; e.g. d10 indicates that the minimum detection limits are 10 times those listed

INSTRUMENT ABBREVIATIONS

FID	=	Flame Ionization Detector
TCO	=	Thermal Conductivity Detector
ECO	=	Electron Capture Detector
PID	=	Photoionization Detector
HECD	=	Hall Electrolytic Conductivity Detector
MS	=	Mass Spectrometer Detector
IR	=	Infrared Spectrometer
GC	=	Gas Chromatograph


UNITS

ug/l	=	micrograms per liter
mg/l	=	milligrams per liter
ml/l	=	milliliters per liter
ug/kg	=	micrograms per kilogram, dry weight basis (unless otherwise noted)
mg/kg	=	milligrams per kilogram, dry weight basis (unless otherwise noted)
m ³	=	cubic meter
in/yr	=	inches per year
lbs/yr ³	=	pounds per cubic yard
pCi/l	=	picocuries per liter
ppm	=	parts per million
ppmv	=	parts per million by volume, dry basis (unless otherwise noted)
ppbv	=	parts per billion by volume, dry basis (unless otherwise noted)
°F	=	degrees Fahrenheit
°C	=	degrees Celsius
vol %	=	percent by volume
wt %	=	percent by weight
cc	=	cubic centimeter
ug	=	microgram
mg	=	milligram
g	=	gram
kg	=	kilogram
ul	=	microliter
ml	=	milliliter
l	=	liter
su	=	standard units
cu	=	color units
NTU	=	nephelometric turbidity units
MF	=	Million Fibers

Samples for this project will be retained for sixty (60) days from the date of this report unless otherwise noted.

New Jersey State Certified Laboratory Certification No. 18196

New York State Certified Laboratory Certification No. 11239



5 Johnson Drive
PO Box 130
Raritan, NJ 08869-0130

LABORATORY INFORMATION SHEET

13


908 725-7744 / FAX 908 526-7886

METHODOLOGY

ASTM = American Society for Testing Materials
EPA = United States Environmental Protection Agency SW-846 3rd Edition; or EPA 600/4-79-020 Methods for Chemical Analysis of Water and Wastes; or 40 CFR, most recent edition; or Methods for the Determination of Organic Compounds in Finished Drinking Water and Raw Source Water
Method No. = EPA Methods unless otherwise noted
Mod = Modified; e.g. 8015Mod indicates that the 8015 method has been modified by the lab
NIOSH = National Institute for Occupational Safety and Health
NJDEPE = New Jersey Department of Environmental Protection and Energy
RECON = RECON SYSTEMS, Inc. in-house method
SM = Standard Methods for the Examination of Water and Wastewater 16th Edition

COMMON NOMENCLATURE (including Data Qualifiers)

A = tentatively identified compound is a suspected aldol-condensation product
B = compound was found in laboratory blank
C = probable lab contamination
E = estimated value; concentration exceeds instrument calibration range
G = surrogated recoveries not reported because of required sample dilutions
H = compound is target compound that was analyzed for a different analytical fraction. It's presence is "inappropriate" in this fraction and is probable lab contamination
I = compound is target compound that was analyzed for and detected in a different analytical fraction. It's presence is "inappropriate" in this fraction and may be negated. (NJDEPE-BEMQA SOP No. 5.A.131, 10/91)
J = compound was detected but below the MDL
M = surrogate recoveries out of limits due to matrix interference, verified by reanalysis
Q = data qualifiers
X = compound was probable background due to solvent or CO₂
++ = as measured on site
+ = analysis performed by subcontract laboratory, report attached
< = less than detection limit
≤ = less than or equal to detection limit
> = greater than detection limit
≥ = greater than or equal to detection limit
= column used to flag recoveries that have exceeded limits
bdL = compound was detected but below the MDL
nd = none detected
nd< = none detected, less than detection limit
GPM = gallons per minute
GPD = gallons per day
MPN = most probable number
MDL = minimum detection limit
MGD = million gallons per day
MBAS = Methylene Blue Active Substances
NJDEPE = New Jersey Department of Environmental Protection and Energy
NI = not ignitable solid
NA = not applicable
NR = not requested
NL = no limits set
RPD = relative percent deviation
RCRA = Resource Conservation and Recovery Act
ECRA = Environmental Cleanup Responsibility Act
TCLP = Toxicity Characteristic Leaching Procedure
USEPA = United States Environmental Protection Agency
ZHE = Zero Headspace Extraction



APPENDIX I

APPROVED PROTOCOL

AirRecon
Division of
RECON Environmental Corp.

5 Johnson Drive, PO Box 130
Raritan, NJ 08869-0130
(908) 526-1000
FAX (908) 526-7886

Boston (617) 337-7887
New York (212) 545-7440
Los Angeles (714) 752-1818
San Francisco (415) 742-9900

015

ENTRY 2  DELIVERING TRACKING NUMBER
1Z 079 331 08 9995 225 3

November 30, 1995

Mr. Tim Telepak
LFG SPECIALTIES INC.
7550 Lucerne Drive
Suite 110
Cleveland OH 44130

Re: Compliance stack test protocol for
Landfill gas flare to be installed @
BETHLEHEM LANDFILL, Bethlehem PA
AirRECON Project No. AR5-6922


Dear Mr. Telepak:

Enclosed please find three revised copies of the test protocol for the above-referenced project. One copy is for your records, and the others are for GANNETT FLEMING and the CITY OF BETHLEHEM.


We have also sent two copies to the PA-DEP for their review and comments.

Please do not hesitate to call me at extension 519 with any questions or comments you may have.

Submitted by,


John R. Geissler, IHIT
Sr Air Quality Chemist

Approved By:


Frank W. Sweetits
Vice President
AirRECON Division

JRG/vjm (D.53)
Enclosure

November 30, 1995



1Z 079 331 08 9995 227 1

Mr. Michael Safko
Bureau of Air Quality
PENNSYLVANIA DEPARTMENT OF
ENVIRONMENTAL PROTECTION
Cross Valley Centre
667 North River Street
Plains PA 18705-1099

Re: Compliance stack test protocol for
Landfill gas flare to be installed @
BETHLEHEM LANDFILL, Bethlehem PA
AirRECON Project No. AR5-6922


Dear Mr. Safko:

Enclosed, please find a compliance stack test protocol for the above-referenced source.

A copy of the protocol is also being forwarded to Mr. St. Louis of your office for his technical comments.

If you have any questions, feel free to call me at extension 519.

Submitted by:


John R. Geissler, IHIT
Sr Air Quality Chemist

Approved by:


Frank W. Swetits
Vice President
AirRECON Division

JRG/vjm (D.53)
Enclosure

cc: T. Telepak/LFG Specialties
R. St. Louis/PADEP



1Z 079 331 08 9995 226 2

**COMPLIANCE STACK
TEST PROTOCOL**

Prepared For:

LFG SPECIALTIES INC.
7550 Lucerne Drive, Suite 110
Cleveland OH 44130
Attn: Tim Telepak

Source:

Bethlehem Landfill
Flare Inlet/Outlet

Submitted to:

Mr. Michael Safko
Bureau of Air Quality
PENNSYLVANIA DEPARTMENT OF
ENVIRONMENTAL RESOURCES
Cross Valley Centre
667 North River Street
Plains PA 18705-1099

Prepared by:

John R. Geissler, IHIT (Ext. 519)
Senior Air Quality Chemist

AirRECON Project No. AR5-6922

November 30, 1995

D.53

TABLE OF CONTENTS

	<u>PAGE</u>
1.0 INTRODUCTION	1
1.1 JOB SITE	1
1.2 SOURCE INFORMATION	1
1.3 PERMIT INFORMATION	1
1.4 PLANT SAFETY REQUIREMENTS	1
2.0 PROCESS INFORMATION	2
2.1 SOURCE DESCRIPTION	2
2.2 CONTROL DEVICE	2
2.3 CONTINUOUS EMISSION MONITORS	2
3.0 SAMPLING LOCATION(s)	3
3.1 INLET	3
3.2 OUTLET	3
3.3 ACCESSIBILITY	3
4.0 TEST METHODOLOGIES	4
5.0 SAMPLING PROCEDURES	5
5.1 NITROGEN OXIDES	5
5.2 TOTAL NON-METHANE HYDROCARBONS AND METHANE	6
5.3 AirRECON'S REAL TIME MONITORING SYSTEM	9
6.0 QUALITY ASSURANCE	
6.1 CHAIN OF CUSTODY	12
6.2 CALIBRATION DATA	12
6.3 CALIBRATION PROCEDURES	12
6.4 FINAL REPORT	13

ATTACHMENTS

1	-	AIR PERMIT
2	-	SAMPLE LOCATION DIAGRAMS

1.0 INTRODUCTION

An emission test program will be performed at the BETHLEHEM LANDFILL, Bethlehem PA. An enclosed landfill gas flare system is currently being constructed at this site. The purpose of the test program is to demonstrate compliance with applicable PADEP flare emission regulations.

LFG Specialties of Cleveland OH, retained AirRECON, a division of RECON ENVIRONMENTAL CORP. (RECON), to author a test protocol and conduct the actual testing onsite. The goal of the test program is to determine destruction efficiency of total non-methane hydrocarbons and to quantify emissions of non-methane hydrocarbons and nitrogen oxides (NO_x as NO₂).

1.1 JOB-SITE

BETHLEHEM LANDFILL
2335 Applebutter Road
Bethlehem PA 18015
Contact: Chris Campman, Landfill Manager
Phone: 610-865-7103
Fax: 610-865-7224

1.2 SOURCE INFORMATION

LANDFILL GAS ENCLOSED GROUND FLARE

LFG SPECIALTIES INC.
7550 Lucerne Drive, Suite 110
Cleveland OH 44130
Contact: Tim Telepak
Phone: 216-891-0305
Fax: 216-891-8288

1.3 PERMIT INFORMATION

A copy of the permit information is included in Attachment I.

1.4 PLANT SAFETY REQUIREMENTS

It is recommended that all personnel wear safety shoes, hard hats and hearing protection.

2.0 PROCESS INFORMATION

The process will be operated at maximum permit conditions ($\pm 5\%$). The flare's operating temperature will be monitored and continuously recorded during the test period.

2.1 SOURCE DESCRIPTION

Landfill decomposition gases are negative draft ducted to a vertically arranged, enclosed flare. Diagrams detailing the inlet and outlet sources are included in Attachment 2.

2.2 CONTROL DEVICE

Emission control is achieved through an LFG landfill flare. The flare's specifications are included in the permit information included in Attachment 1.

2.3 CONTINUOUS EMISSION MONITORS

There are no continuous emission monitors associated with this source.

Inlet flow and the outlet temperature are continuously measured and recorded.

3.0 SAMPLING LOCATIONS

Sample diagrams of the test locations are presented in Attachment 2. All measurements will be field-verified and conform to US EPA Reference Method 1 (outlet).

3.1 INLET

*See left
Fig 26?
2001-4*

Measurement will take place in a horizontally arranged circular stack with an inside diameter of twelve inches (12"). No velocity traverses shall be conducted on this source. Inlet velocities for the testing program shall be provided by the on-site flowmeter; a PANAMETRICS Model-GP68 ultrasonic. The output from this flow meter is continuously recorded by a DAHS.

3.2 OUTLET

Measurement will take place in a vertically arranged circular stack with an inside diameter of seven feet (84"). Four test ports are located 31 feet downstream (EPA Distance "B" = 4.4 duct diameters) and 3.5 feet upstream (EPA Distance "A" = 0.5 duct diameters) from the nearest flow disturbances. For velocity measurements, sixteen traverse points (eight points/port, using two ports located at 90°) will be measured.

3.3 ACCESSIBILITY

The inlet test location is accessible from the ground. The outlet test location is only accessible from an elevated platform or scaffolding.

4.0 TEST METHODOLOGIES

The parameters and methods used for this proposed emission test program are specified in Table 1. Three tests of at least one hour duration will be performed.

All proposed test methods conform to Title 40, Code of Federal Regulations, Part 60, Appendix A test procedures or those of the PADEP.

TABLE 1 TEST METHODOLOGIES

PARAMETER	METHOD
Flow rates (outlet)	US EPA Method 1, "Sample and Velocity Traverse for Stationary Sources"
	US EPA Method 2, "Determination of Stack Gas Velocity and Volumetric Flow Rate (Type-S Pitot Tube)"
Oxygen & carbon dioxide (Outlet)	US EPA Reference Method 3A, "Determination of Oxygen and Carbon Dioxide Concentrations in Emissions From Stationary Sources" (Instrumental Analyzer Procedure).
Moisture (outlet)	US EPA Reference Method 4, "Determination of Moisture Content in Stack Gases."
Nitrogen Oxides (as NO ₂) (Outlet)	USEPA Method 7E, "Determination of Nitrogen Oxide Emissions From Stationary Sources (Instrumental Analyzer Procedure)"
Total non-methane hydrocarbons (as methane) (Inlet/Outlet)	USEPA Method 18, "Measurement of Gaseous Organic Compound Emissions by Gas Chromatography."

5.0 SAMPLING PROCEDURES

Nitrogen oxides and total non-methane hydrocarbon (as methane) emissions will be calculated using the additional information outlined below:

- Location of the sampling points within the stack (using USEPA Method 1 and 1A).
- Volumetric flow rate measurements taken prior to and after each test run for average flow rate (using USEPA Method 2 on the outlet and the output from the on-site flow monitor for the inlet).
- Molecular composition by weight of flue gases (using USEPA Method 3A on the outlet only).
- Moisture content of flue gas by gravimetric analysis (using USEPA Method 4 on the inlet and outlet).
- Absence of cyclonic flow (outlet location only).

5.1 NITROGEN OXIDES

SUMMARY: Nitrogen oxides (NO_x) emissions will be determined in accordance with EPA Method 7E. A continuous gas sample is extracted from a single sampling point near the centroid of the stack, and analyzed for NO_x using a chemiluminescent analyzer.

CALIBRATION GASES: A zero gas and three certified master standards ($\pm 2\%$) of nitrogen oxide (NO) in nitrogen will be used to calibrate the instrument.

The concentration of the low-, mid- and high-range standards will be approximately 20-30, 50-60 and 80-90 percent of the selected instrument operating range.

OPERATING RANGE: The NO_x monitor will be operated at a range of 0-200 ppmv. If NO_x concentrations exceed this range, then an appropriate, higher range will be selected.

SAMPLE VOLUMES AND DETECTION LIMITS: For each test, the instrument will run at approximately one liter per minute.

Using a chemiluminescent analyzer, the analytical method detection limit for NO_x (as NO_2) is 1 ppmv. Based on an estimated outlet stack gas flow rate of 24,000 standard cubic feet/minute, the analytical method detection limit mentioned above yields an in-stack detection limit for NO_x (as NO_2) of 0.17 pounds/hour.

SAMPLE TRAIN OPERATION: A representative exhaust gas sample is extracted from the emission source through a stainless steel probe and a heated Teflon sample line. Within the laboratory trailer, the gas is passed through a chilled semi non-contact condenser for moisture removal prior to being introduced to the instrument for immediate analysis.

The principle of the analyzer is the following reaction



The intensity of the chemiluminescence ($h\nu$) is proportional to the concentration of NO present in the gas stream.

The $h\nu$ is measured by a photomultiplier tube and is directly proportional to the NO concentration; therefore the measured value for $h\nu$ is recorded as the concentration for NO.

NO_x is comprised of NO and NO_2 . Any NO_2 present in the sample gas is converted into NO prior to entering the measurement cavity by a NO_2 to NO converter.

5.2 TOTAL NON-METHANE HYDROCARBONS AND METHANE

SUMMARY: Total non-methane hydrocarbon emissions will be determined in accordance with EPA Method 18 - "Measurement of Gaseous Organic Compound Emissions by Gas Chromatography".

Methane and total hydrocarbons (as methane) at the flare outlet as well as total non-methane hydrocarbons (as methane) at the flare inlet will be determined in accordance with Method 18, using the "Direct Interface Sampling Procedure." Sample gas will be drawn from the stack by a pump through a stainless steel probe, a heated Teflon sample line and a heated gas sampling valve interfaced to a portable GC.

Periodically, the gas sampling valve shall be opened, and the sample flushed onto the GC column with carrier gas. After elution of the methane peak, the column will be back-flushed into the detector to quantify the non-methane hydrocarbons. Upon elution of the non-methane components, the back-flush valve will be closed and the procedure repeated. At least four cycles shall be completed during each 1 hour test.

CALIBRATION GASES (OUTLET METHANE, INLET/OUTLET TOTAL HYDROCARBONS): A zero gas and three certified master standards ($\pm 2\%$) of methane in air will be used to calibrate the instrument.

The concentration of the low-, mid- and high-range standards will be approximately 20-30, 50-60 and 80-90 percent of the working GC operating range.

OPERATING RANGE: To quantify the outlet methane and total hydrocarbons, the GC will be calibrated and operated on a range of 0-100 ppmv. For quantify the inlet non-methane hydrocarbons, the GC shall be calibrated and operated on a range of 0-10,000 ppmv. The inlet methane concentrations will exceed this range, and therefore will not be quantified. Only the non-methane organic compounds shall be quantified on the inlet. If analyte concentrations exceed any of these ranges, then an appropriate, higher range will be selected, or a smaller sample loop installed on the GC to facilitate a sample dilution.

SAMPLE VOLUMES AND DETECTION LIMITS (OUTLET METHANE, INLET/OUTLET TOTAL HYDROCARBONS): For each test, the pump will run at approximately one liter per minute. The gas sample loops used in the GC shall be 1 ml in size.

Using an FID, the analytical method detection limit for methane and total hydrocarbons (as methane) is approximately 3 ppmv. Based on an estimated outlet stack gas flow rate of 24,000 dry standard cubic feet/minute, the analytical method detection limit mentioned above yields an approximate in-stack detection limit for total hydrocarbons (as methane) and methane of 0.2 pounds/hour. The in-stack detection limit for non-methane hydrocarbons on the flare inlet is 0.006 pounds/hour, based on a flow rate of 800 dry standard cubic feet/minute.

SAMPLE TRAIN OPERATION (OUTLET METHANE, INLET/OUTLET TOTAL HYDROCARBONS): A representative exhaust gas sample is extracted from the emission source through a stainless steel probe, heated Teflon sample line and into a heated gas sample valve prior to being introduced to the GC for immediate analysis.

The analytical columns to be used in the GC shall be 60 m long with an ID of 0.53 mm. The stationary phase shall be 5u, RTX-1. The GC column oven shall be operated at 125°C. Helium shall be used as the carrier gas, with a column head pressure of approximately 20 psi. The hydrogen detector gas shall be run at approximately 20 ml/min., and the air run at approximately 120 ml/min. These parameters may be modified in the field to optimize the analysis.

After elution of the methane peak, the column is back-flushed into the detector. Any peaks eluting after the back-flush are non-methane hydrocarbons, and are quantified using the methane calibration curve for that detector. For the inlet samples, the methane peak will go off-scale, allowing only the non-methane hydrocarbons to be quantified.

The FID uses a well controlled flame to combust the hydrocarbons eluting from the column. Hydrocarbons are ionized by the flame, and the detector (typically a thin, platinum wire) measures the ionization energy of the carbon-hydrogen bonds which are broken.

The detector's response is directly related to the number of carbon atoms contained in each organic molecule of the sample. Output from the detector is electronically converted into a concentration based on the compounds used to calibrate the instrument. Compound identification is based upon the elution time of a peak with regard to a known standard.

5.3 AirRECON's REAL-TIME MONITORING SYSTEM

RECON's real time monitoring system (RTMS) consists of a sampling interface system (SIS) and instrument control panel, which has several continuous emission monitors. All monitors conform to the design and performance criteria outlined in the 40 CFR 60 Appendix A.

The sampling interface system consists of the following components:

1. Three-point averaging, stainless steel probe
2. Particulate filter
3. Calibration overflow assembly
4. Heated sampling line
5. Calibration gas line
6. VIA MAK2 Thermoelectric

The SIS allows for transporting filtered stack gases to the individual instruments while maintaining the temperature well above the dew point of the gases. All instrument output signals are recorded by a Model 3702 data logger and conveyed to a portable computer.

The analyzer calibration error test, also called rack calibration, is performed to establish the linearity and accuracy of the reference method analyzer. A total of four standards will be used to perform the rack calibration: a zero- and low- range standard (20 to 30 percent of the selected operating range), a mid-range standard (50-60 percent), and a high-range standard (80-95 percent).

The zero standard is introduced to the analyzer, (not to the probe) and any necessary adjustments are made, and the zero potentiometer is then locked in place. The mid-range standard is introduced next. Any necessary adjustments are made and the span potentiometer is locked in place. The analyzer is now calibrated. No further adjustments will be made during the test program.

The low-range standard is introduced, and then the high-range standard is introduced.

If the response of the analyzer to either the low or high standard deviates from the reference value of the respective standard by more than 2 percent of the span, the analyzer is not acceptable. The problem is addressed and corrected, and the rack calibration procedure is re-initiated.

Once the analyzer calibration error check has been successfully completed, the sampling system bias check (stack calibration) is performed. First, the zero standard is introduced to the entire sampling system at the junction of the probe and the heated sample line.

The mid-range standard is then introduced to the entire sampling system. If the response to either the zero or mid-range standard deviates by more than 5 percent of the span from the response recorded for the respective analyzer calibration error test, the sampling system is unacceptable. The problem is addressed and corrected, and the sampling system bias check is repeated.

The interference response check is performed by introducing the gaseous components into the entire sampling system either as a combination gas or separately. The response from the measuring system is observed and recorded. If the sum of interference of the measuring system is greater than two percent of the applicable span value, testing will be delayed until the interference can be removed.

After the system performance tests are completed, the testing will begin. Immediately proceeding and following each test run, a calibration drift test will be performed in the same manner as the sampling system bias check was performed.

Whenever possible, the instrument operating range will be as indicated in the appropriate reference method. However, should concentration exceed range, an appropriate higher range shall be selected.

The specific instrument type and model number are identified on the following pages and will conform to the following criteria, as outlined in 40 CFR 60, Appendix A.

Analyzer Calibration Error: $\pm 2\%$ of the instrument span for zero, low-range, mid-range, and high-range calibration gases.

Analyzer Calibration Error (Hydrocarbon Instrument Only): $\pm 5\%$ of the low-range, mid-range and high-range calibration gas concentration value.

Sampling System Bias: $\pm 5\%$ of the instrument span for the zero, and an upscale calibration gas relative to the recorded response during the analyzer calibration-error test.

Zero Drift: $\pm 3\%$ of the instrument span relative to the respective system bias response over the period of each run.

Calibration Drift: $\pm 3\%$ of the instrument span relative to the respective system bias response over the period of each run.

6.0 QUALITY ASSURANCE

This test protocol was developed in accordance with and closely follows the principles and recommendations outlined in the EPA Quality Assurance Handbook for Air Pollution Measurement Systems.

6.1 CHAIN-OF-CUSTODY

Each sample requires its own chain-of-custody (COC)/request for analysis form. The COC is completed to ensure the integrity of the samples collected. Before relinquishing the sample, the project manager must complete a COC with his/her name, the name of the person receiving the results, the RECON project number, the sample description (media), the sample date/time, and who performed the sampling.

The source is also identified. A description of the container holding the sample and the preservative is also listed. Additional comments or notes can be placed at the bottom of the page. Samples will be stored in-house at RECON.

6.2 CALIBRATION DATA

All pre-test calibration data for sampling and equipment will be made available onsite, at the time of testing to any regulatory representatives. Copies of all calibration data will be included in the final report.

6.3 CALIBRATION PROCEDURES

Detailed standard operating procedures (SOPs) for applicable equipment and instrumentation are documented in the AirRECON Quality Assurance/ Quality Control Plan.

PITOT TUBES: All standard pitot tubes are given a baseline coefficient of 0.99. A standard pitot tube design shall conform to EPA Reference Method 2, sections 2.7.1-2.7.5.

All S-Type pitot tubes are initially provided from the manufacturer in accordance with the specifications listed in EPA Reference Method 2.1.

Before each use, a visual inspection of the pitot tube is made to verify the face openings to be in alignment within the specifications illustrated in figure 2-2 and 2-3. All pitot tubes are calibrated annually in accordance with sections 4.1.3 through 4.1.5.

An identification number is assigned to a calibrated pitot tube. If the pitot tube is not marked, a baseline coefficient of 0.84 is assigned.

DRY GAS METERS: Field-use gas meter calibration is checked prior to use and at the end of each test program against a reference gas meter in accordance with USEPA Method 5, Section 7.

The calibration meter, kept in the laboratory solely for the purpose of checking the calibration of dry gas meters used in the field, is re-calibrated against a bell prover annually.

If the dry gas meter coefficient obtained before and after the test series differ by more than five percent, the calculations for the test series shall be performed using whichever coefficient gives the lower value for sample volume.

THERMOCOUPLES: Thermocouples are calibrated by immersing them side-by-side with a reference mercury-in-glass thermometer. The thermocouples are immersed in an ice bath, boiling water and a hot oil bath. If the absolute temperature reading between the thermocouple and the reference thermometer agree within $\pm 1.5\%$ at all three calibration points, the actual thermocouple reading is considered acceptable.

SPAN GAS CERTIFICATIONS: Span gas certifications are provided by the supplier and copies will be included in the final test report.


6.4 FINAL REPORT

Emissions of nitrogen oxides (as NO_2) and total non-methane hydrocarbons (as CH_4) will be reported as ppmv (wet), ppmv (dry), pounds/hour. Emissions of CO_2 and O_2 will be reported as a percent by volume. Non-methane hydrocarbon destruction efficiency will be reported as a percentage of the mass emission rate.

AirRECON's final test report for this project will include the following items:


- Summary
- Personnel and Certifications
- Sampling location diagrams
- Velocity and flow rate data
- Gas composition data
- Emissions data
- Process information
- Approved test protocol
- Procedures
- Selected nomenclature
- Equipment calibration data
- Original test data
- Calculations
- Laboratory analysis reports with labeled chromatographs
- Chain of Custody forms

Submitted by:



John R. Geissler, IHIT
Sr. Air Quality Chemist

Approved by:



Thomas F. Mattei
Manager, Special Projects
AirRECON Division

JRG/vjm (D.53)

Air Recon

Division of
RECON Environmental Corp.

Raritan, NJ 08869-0130

033

ATTACHMENT 1

PERMIT INFORMATION

RECEIVED
SEP 12 1995

GANNETT FLEMING
ENGINEERS & PLANNERS

File 29607.12-
cc: GHB
034
City of Bethlehem

INDUSTRY • EDUCATION • RELIGION • MUSIC • RECREATION
AN EQUAL OPPORTUNITY EMPLOYER

DEPARTMENT OF PUBLIC WORKS
LANDFILL BUREAU

Tel (610) 865-7103
Fax (610) 865-7224

September 8, 1995

Babu H. Patel
Pennsylvania Department of Environmental Protection
Air Quality Program
Northeast Regional Office
2 Public Square
Wilkes-Barre, PA 18711-0797

Re: 48-322-002A
Approval to Construct a Landfill Gas
Extraction System
Lower Saucon Township
Northampton County

Dear Mr. Patel:

Please find the enclosed information to supplement our existing Plan Approval for a landfill gas flare:

1. Application for Issuance of an Air Quality Plan Approval Extension with condition to Authorize Temporary Operation.
2. Modified Application for Plan Approval.
3. A check for \$200 made out to the Commonwealth of Pennsylvania, Clean Air Fund.

The requested extension of time for the Plan Approval is required because the contractor hired by the City will not install the gas flare unit until the landfill is capped. An extension of 180 days, until March 29, 1996, is expected to provide the City with sufficient time to install the flare.

We have modified the original permit application to reflect the change from a Model #TO-F flare manufactured by John Zinc, to a Model EF 740I12 flare manufactured by LFG Specialties, Inc.



September 8, 1995


Page 2

035

Please do not hesitate to contact me if you have any questions.

Very truly yours,

CITY OF BETHLEHEM



Christopher K. Campman
Manager Landfill Operations

CKC:lmh

Enclosures

cc: W. Sherman
M. Everett
FILE0908952C.DOC

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES

036

APPLICATION FOR
ISSUANCE OF AN AIR QUALITY PLAN APPROVAL EXTENSION
WITH CONDITION TO AUTHORIZE TEMPORARY OPERATION

Application is hereby made for a plan approval extension to allow temporary operation to facilitate the shake-down of sources and/or air cleaning devices or to permit the evaluation of the source(s) for compliance with all applicable regulations and requirements.

APPROVAL/PERMIT NO. 48-322-002A

Owner/ Operator: City of Bethlehem
Department of Public WorksAddress: 10 East Church Street
Bethlehem, PA 18018Attention: Mr. Wendall Sherman
Director of Public Works

Source &: Landfill Gas Flare

Air: ~~Model #ZTC-F~~ MODEL
EF740I12

Cleaning:

Device:

Location: Lower Saucon Township
Northampton CountyCurrent Approval/Permit:

Issue Date: November 7, 1994

Expiration Date: September 30, 1995

Operation Commenced (Is to Commence):

Specify reason(s) for this request for temporary operation (include the reasons compliance with all applicable regulations and Plan Approval requirements has not been established, a projected schedule for completion of any needed equipment changes and a detailed schedule for achieving full compliance). Attach additional sheets as necessary.

See Attachment A

FEE

A fee of two hundred dollars (\$200.00) is enclosed pursuant to 25 Pa. Code §127.34 and Section 6.3(j) of the Pennsylvania Air Pollution Control Act.

Application for Issuance of an Air Quality
Approval Extension with Condition to
Authorize Temporary Operation

Page 2 of 2 037

AFFIDAVIT

I, WENDELL S. SHERMAN, being duly sworn according to law, depose and state,
under penalty of law as provided in 18 Pa. C.S. §4904 and Section 9(b)(2) of the Air
Pollution Control Act, 35 P.S. §4009(b)(2), that I am the representative of the Applicant,
identified above, authorized to make this affidavit. I further state that the information
provided with this application is true and complete.

Sworn to and subscribed before me
this 11th day of September, 1995

Cynthia A. Schick
Notary Public

Notarial Seal
Cynthia A. Schick, Notary Public
Bethlehem, Northampton County
My Commission Expires Aug. 15, 1998

Wendell Sherman
Signature

WENDELL S. SHERMAN
Name (typed)

DIRECTOR OF PUBLIC WORKS
Title

At the time this completed form, check(s) and completed Compliance History Form to:

Department of Environmental Resources
Air Quality Program
Northeast Regional Office
Cross Valley Centre
667 North River Street
Plains, PA 18705-1099
Attn.: Chief, Engineering Services

We are looking for ways to improve our service to the public and the regulated community. Please take a few moments to respond to the following questions and statements about your recent experience in applying for a DER permit. If the permitting process required you to submit a bond, please answer the questions in the Bonding Survey portion, and enclose it with the completed DER Permit Questionnaire. Your comments and recommendations are important to us. A postage-paid return envelope is enclosed for your use. If you have any questions regarding this questionnaire, please call Brian Showalter at (717) 787-8102. We thank you for providing us with this information.

DEPARTMENT OF ENVIRONMENTAL RESOURCES LICENSING/PERMIT QUESTIONNAIRE

130

1. For what type of license or permit did you apply? Please see the reverse for license/permit types and enter the number that precedes the appropriate permit type.
 2. Are you the Applicant X Consultant Applicant Both
 3. Was the permit application prepared by the Applicant X Consultant Both
 4. Please indicate the county in which the facility or activity exists. NORTHAMPTON County
 5. How long did it take to get your license/permit? Please specify. 120 DAYS
 6. Do you think this was: X Too Long Reasonable Faster Than Expected
 7. Did you have to resubmit or revise your application? Yes X No
 - If yes, why? Administratively Incomplete Technically Incomplete Other (Explain)
 - Administrative Errors Technical Errors
 8. During the Department's review of your application, did you have to supply additional information? Yes Number of Times X No
 9. Did you participate in any type of pre-application review? X Yes No
 10. Did DER staff visit the site or facility during the course of the permit review? Yes Number of Visits No X Unknown
 11. Had you previously applied for any DER permit? X Yes No
 12. Do you plan to apply for other DER permits in the future? X Yes No
- The following set of statements concern your feelings about certain aspects of DER's permitting process. Please circle the one response that best describes your feelings.
13. The Department provides a reasonable explanation of all administrative requirements of the application.
Strongly Agree 1 Agree 2 Disagree 3 Strongly Disagree 4
 14. The Department provides a reasonable explanation of all technical requirements of the application.
Strongly Agree 1 Agree 2 Disagree 3 Strongly Disagree 4
 15. DER staff presented a professional appearance when performing on-site visits.
Strongly Agree 1 Agree 2 Disagree 3 Strongly Disagree 4
 16. I was treated courteously and professionally by DER staff.
Strongly Agree 1 Agree 2 Disagree 3 Strongly Disagree 4
 17. The Department performed professionally in processing this application.
Strongly Agree 1 Agree 2 Disagree 3 Strongly Disagree 4
 18. If you or your company do business throughout Pennsylvania, do you find that the different DER regional offices are generally consistent in their requirements and procedures for permits?
Yes 1 Usually 2 Seldom 3 Never 4
 19. If you or your company do business outside of Pennsylvania, how does DER's service compare with that of regulatory bodies in other states?
Better 1 Roughly Equal 2 Slightly Worse 3 Much Worse 4
 20. Do you have suggestions for improvements to the licensing or permit application process? If yes, please attach them to this survey.


ATTACHMENT A

039

The City of Bethlehem requests a 180 day extension of time.

The request for extension has been made because the City contractor completing the work will not install the gas flare until the landfill is capped. Pavex, Inc. is under contract to the City to complete capping of the Original Landfill area. This work includes all work associated with the gas management system. The schedule for compiling this work is attached.

**CLOSURE CONSTRUCTION
ACTIVITY SCHEDULE
PAVE**



Submit in Triplicate

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES
BUREAU OF AIR QUALITY CONTROL

INCINERATION W/CONTROL

041 of 5

Application for Plan Approval to Construct, Modify or
Reactivate an Air Contamination Source and/or Air Cleaning Device and for a Permit to Operate

Section A - Identity and Location of Air Contamination Source

1A. Application is being made for: ☐ Construction of New Source/Operating Permit ☐ Reactivation of a Source/Operating Permit ☐ Modification of Existing Source/Operating Permit ☒ Installation of Air Cleaning Device/Operating Permit ☐ Amendment to a Previous Application Previous Application No. _____ ☐ Other _____		OFFICIAL USE ONLY Application No. _____ Plant Code _____ Unit ID _____ Date Received _____ Reviewed By _____ Potential Emissions (TPY) PM _____ SO ₂ _____ VOC _____ NO _x _____ CO _____ Other _____ Actual Emissions (TPY) PM _____ SO ₂ _____ VOC _____ NO _x _____ CO _____ Other _____ Change in Actual Emissions (+ or -) PM _____ SO ₂ _____ VOC _____ NO _x _____ CO _____ Other _____	
1B. Type of source LANDFILL GAS EXTRACTION SYSTEM			
1C. Plant in which source is located ☐ NEW ☒ EXISTING			
1D. If source is new, does it replace another source ☐ YES ☐ NO (describe source replaced) NA		1E. Expected date of completion March 29, 1996	
2A. Owner of source CITY OF BETHLEHEM DEPARTMENT OF PUBLIC WORKS		2B. Employer I.D. No. (Federal IRS No.) 24-6000689	
3A. Owners designation of source and/or plant if any CITY OF BETHLEHEM LANDFILL	3B. Location of source Political Subdivision County (Street address or Route No.) (Township, etc.) APPLEBUTTER ROAD LOWER SAUCON NORTHAMPTON		
3C. Mailing address (Street or P.O. Box, City, Zip Code) 10 EAST CHURCH STREET, BETHLEHEM, PA 18018		3D. Telephone No. (610) 865-7103	
4A. Person to contact regarding this Application (name and title) WENDELL SHERMAN, P.E.	4B. Mailing address (Street or P.O. Box, City, State, Zip Code) 10 E. CHURCH ST., BETHLEHEM, PA 18018		4C. Telephone No. (610) 865-7050
5. Official signing application must be an agent of the Company having primary responsibilities for operation of the facility to which this application applies. Although he may not have participated in the design of the facility he should be responsible for approval of the design.			

AFFIDAVIT

I, WENDELL SHERMAN, being duly sworn according to law depose and say that I am the official having primary responsibility for the design and operation of the facilities to which this application applies and that the information included in the foregoing application is true to the best of my knowledge, information and belief.

Sworn to and subscribed before me this 11th day

of September, 1995.

Cynthia A. Schick
Notary Public

Notarial Seal
Cynthia A. Schick, Notary Public
Bethlehem, Northampton County
My Commission Expires Aug. 15, 1998

Signature

Title

Wendell Sherman
DIRECTOR OF PUBLIC WORKS

Section B.1 - Incinerators and Flares

1. INCINERATOR AND WASTE

N/A

A. Manufacturer N/A	B. Model	C. Class	D. ☐ Multiple chambered ☐ Controlled air
E. Rated capacity	F. Type of waste	G. Btu content as fired	
H. If type 5.6 or special waste attach proximate and ultimate analysis.	I. Density of waste (lbs/cu. yd.)	J. Daily amount ☐ Estimated ☐ Actual	

2. PRIMARY COMBUSTION CHAMBER N/A

A. Volume (cu. ft.)	B. Effective grate area (sq. ft.)	C. % Excess air
D. % Air applied as overfire air	E. % As underfire	
F. Ignition burner type and fuel	G. Number of burners	H. Capacity of each (Btu/hr.)

3. SECONDARY COMBUSTION CHAMBER AND/OR AFTERBURNERS N/A

A. Volume (cu. ft.)	B. Maximum gas velocity (ft./sec.)	C. Temperature (°F)
D. Estimated hold time of gases (sec). Show calculations		
E. Burner type and fuel	F. Number of burners	G. Capacity of each (Btu/hr.)

4. DRAFT CONTROLS N/A

☐ A. Barometric damper	Windshielding ☐ YES ☐ NO
☐ B. Guillotine or sliding damper	
☐ C. Induced draft fan Capacity (SCFM)	

5. TOTAL HEAT RELEASE (if multiple chambered) EXCLUDING AH PIT IN Btu/hr/cu. ft. N/A

6. MISCELLANEOUS DEVICES AND CONTROLS N/A

☐ A. Automatic loading device (Describe)
☐ B. Self-closing doors
☐ C. Spark arrestor
☐ D. Flame failure protection equipment
☐ E. Method of creating turbulence for combustion gases (Describe)
☐ F. Method of cleaning secondary or settling chamber (Describe)
☐ G. Other interlocking devices or controls (Describe)

7. ☐ Outdoor
☐ Indoor installation (Describe method of supplying combustion air) N/A

Section B.1 - Incinerators and Flares, Continued

043

8. FLARES

A. Maximum and average SCFM burned

1500 SCFM MAXIMUM 800 SCFM AVERAGE

B. % Sulfur of waste gas

0.01% ESTIMATED

☒ C. Automatic ignition system ELECTRONIC SPARK IGNITION, FLAME SCANNER, AND AUTO RESTART☒ D. Controls to prevent snoking AUTO/MANUAL SYSTEM CONTROLS IGNITION, GAS FLOW, COMBUSTION AIR SUPPLY,☐ E. Steam injection NONE

& COMBUSTION TEMPERATURE

☒ F. Noise reducing device REFRACTORY LINED STACK

9. OPERATING SCHEDULE

24

hours/day

7

days/week

52

weeks/year

10. SEASONAL PERIODS (MONTHS) N/A

Operating

to

YEAR-ROUND OPERATION

Non-Operating

to

11. If incinerator is rated at 50 tons per day or more, describe fully the facilities provided to record the daily burning rate and hours of operation.

N/A

12. Describe modifications to incinerator in detail

NONE

13. Has application been made for a Solid Waste Disposal Permit? NOT REQUIRED FOR FLARE

☐ YES☐ NO

SOLID WASTE PERMIT NO. 100020 ISSUED TO LANDFILL

14. Briefly describe the method of handling any waste water from this installation and associated air pollution control equipment (Is a Water Quality Management Permit req.)

☐ YES☒ NO

CONDENSATE WILL BE COLLECTED AND COMBINED WITH LEACHATE FOR DISCHARGE TO CITY'S POTW

15. Attach any and all additional information necessary to perform a thorough evaluation of the extent and nature of emissions from this incinerator.

SEE ATTACHMENT 1 - LANDFILL GAS FLARE SYSTEM

Section D - Flue and Air Contaminant Emission Information

04

I. STACK AND EXHAUSTER

A. Exhauster Static Pressure _____ in w.g. _____ HP @ _____ RPM		N/A NATURAL DRAFT
B. Stack height above grade (ft) <u>40 FT.</u>	C. Stack diameter (ft) or outlet duct area (sq. ft.) <u>7 FT. DIAMETER</u>	D. Weather Cap ☐ YES ☒ NO
Grade elevation (ft) <u>624 FT.</u>		

E. Indicate on an attached sheet the location of sampling ports with respect to exhaust fans, breeching, etc. Give all necessary dimensions.

SEE ATTACHMENT 2 - SAMPLING PORT LOCATION

F. Can the control equipment be bypassed: (If Yes, explain) ☐ YES ☒ NO

2. ATMOSPHERIC EMISSIONS

A. Particulate matter emissions (lbs/hr or g/SCF Dry)

< 0.04 GR/DSCF

B. Gaseous contaminant emissions

Contaminant	Concentration	VOC	Contaminant	Concentration
(1) SO ₂	_____ ppm (Vol.) <u>0.73</u> lbs/hr	(4) <u>VOC'S</u>	_____ ppm (Vol.) <u>1.75</u> lbs/hr	
(2) NO _x	_____ ppm (Vol.) <u>1.30</u> lbs/hr	(5) _____	_____ ppm (Vol.) _____ lbs/hr	
(3) CO	_____ ppm (Vol.) <u>6.5</u> lbs/hr	(6) _____	_____ ppm (Vol.) _____ lbs/hr	

C. Outlet volume of exhaust gases

9400 _____ DS CFM
@ 1500 _____ °F
10 _____ % Moisture

Section E - Miscellaneous Information

1. Describe fully facilities to monitor and record the emission of air contaminants. Provide detailed information to show that the facilities provided are adequate. Include cost and maintenance information. Periodic maintenance reports are to be submitted to the Department.

- ☐ Opacity monitor
☐ SO_x monitor
☐ Other _____

NONE

If checked, provide manufacturer name, model no. and pertinent technical specifications.

2. Attach Air Pollution Episode Strategy (if applicable)

N/A

3. The following requirements are applicable only to construction of a new source.

- a. Briefly describe the nature of the area in which the proposed source is located. Attach a copy of the appropriate portion of the quadrangle map (7 1/2" scale) published by the U.S. Geological Survey and identify the location of proposed source.

SEE ATTACHMENT 3

- b. Demonstrate that the establishment of the new source is justifiable as a result of necessary economic or social development.

N/A

4. Attach calculations and any additional information necessary to thoroughly evaluate compliance with all the applicable requirements of Article III of the rules and regulations of the Department of Environmental Resources and those requirements promulgated by the Administrator of the United States Environmental Protection Agency pursuant to the provisions of the Clean Air Act.

5. List all attachments made to this Application.

- | ATTACHMENT | |
|------------|--------------------------------|
| 1 | LANDFILL GAS FLARE DESCRIPTION |
| 2 | SAMPLE PORT LOCATION |
| 3 | SITE MAP |
| 4 | NOTIFICATION OF MUNICIPALITIES |
| 5 | COMPLIANCE HISTORY |

CITY OF BETHLEHEM LANDFILL

ATTACHMENT 1 - SYSTEM DESCRIPTION FOR A LANDFILL GAS FLARE

INTRODUCTION

The City of Bethlehem Landfill has been in operation since the late 1940's. The City proposes to control landfill gases in existing and future disposal areas of the landfill by installing an active gas extraction system. The existing disposal areas of the landfill that are affected by the gas extraction system are the "original landfill area", the Phase I and Phase II Disposal Area. The Phase III disposal area is a new disposal area currently being developed.

Extracted gases will be burned in a flare resulting in the destruction of volatile organics contained in the gases.

LANDFILL GAS FEED TO THE FLARE

The extraction system is designed to accommodate the maximum predicted gas generation from both existing and proposed disposal areas. The landfill gas generation and recovery calculations are summarized in Table 3 of the Application for Permit Modification - Phase III Disposal Area Gas Management System attached to this document as Exhibit 1. This table shows that for the year 1994, LFG will be generated at a peak rate of 693 SCFM, of which 644 SCFM or 93% is estimated to be recovered by the gas collection system. This generation rate is based on gases produced from a combination of all existing disposal areas. Landfill gas generation will decline until the Phase III disposal area is completed and operational. Disposal in the Phase III area will begin in 1994 and is not expected to be completed until the year 2005. At that time gas generation will again peak to a maximum flow of 1,324 SCFM, of which 1,237 SCFM or 93% is estimated to be recovered by the collection system.

The flare system design and emission estimates contained in this document are based on a present maximum gas flow rate of 800 SCFM. Prior to the first stage of closure for the Phase III area in the year 2005, an air permit modification will be submitted to PADER modifying the emissions to accommodate the projected maximum flow rate of 1,260 SCFM (or future adjusted rates). A conservative design value of 1,500 SCFM has been assumed to provide sufficient flexibility for future gas generation rates.

The following is a summary of the landfill gas characteristics used as a basis of design for the flare system "Application for Plan Approval to Construct and Permit to Operate":

047

Flow Rate:	800 SCFM
Moisture:	Saturated
Temperature:	70-85 °F
Composition (volume):	
Methane	50 %
Carbon Dioxide	42 %
Oxygen	1 %
Nitrogen	4 %
Water	3 %
VOC's	8,000 ppm
Sulfur	100 ppm
Particulates	Negligible

GAS FLARING SYSTEM DESCRIPTION

The flare has been designed as an enclosed flare Model EF740I12 as manufactured by LFG Specialties, Inc., or approved equal, and will incorporate burners to accommodate current as well as future landfill gas requirements. The Piping & Instrumentation and the Assembly Plan drawings for the flare are found in Attachment 1, Appendices A and B. The flame will be enclosed at maximum design flow rates and hydrocarbon concentrations. The flare stack will be equipped with two rows of sample ports for compliance testing. One row of ports will be located to facilitate testing at the present landfill gas flow rate of 800 SCFM as applied for in this application. The other row of sample ports will be located to facilitate testing to accommodate a future gas flow rate 1,500 SCFM.

The burners supplied with the flare system are designed for a landfill gas flow of 800 SCFM and will also accommodate gas flows down to 200 SCFM without auxiliary fuel as long as the methane content is greater than 30 % by volume.

The flare stack will incorporate three thermocouple connections located to monitor and control outlet gas temperature.

The landfill gas flare system will be supplied with two blowers designed to maintain a negative pressure in the gas collection system. Only one blower will be required for the initial gas flow of between 200 to 800 SCFM. Operation of the blowers will be alternated to extend the blower life and provide for continuous system operation in the event one of the blowers is taken out of service for maintenance. The system will be designed to accommodate a third blower to be used as an inline standby should future gas volumes require constant operation of the original blowers.

Combustion air will be supplied to the enclosed flare through controlled air dampers. The flare will be supplied with both manual and automatic dampers to control the combustion air requirements for initial design through potential future increases.

048

SYSTEM PERFORMANCE

The flare will operate at a gas temperature of 1600 °F for a minimum retention of 0.3 seconds at the design gas flow rates. The destruction/removal efficiency (DRE) at these conditions for nonmethane organic compounds will be greater than 98 %.

The following is a summary of the anticipated flue gas conditions (supporting calculations are contained in Attachment 1, Appendix C):

Destruction/Removal Efficiency (minimum):	98 %
Exhaust Gas Volume:	10,500 SCFM
Exhaust Gas Temperature:	1500 °F
Exhaust Gas Conditions (volume):	
CO2	7 %
N2	72 %
O2	11 %
H2O	10 %
Stack Emissions:	
NOx	5.7 TPY
CO	28.5 TPY
VOC's	7.7 TPY
SO2	3.2 TPY
Particulates (maximum)	0.04 grains/DSCF

EQUIPMENT DESCRIPTION

The following is a summary of the typical landfill gas system components.

A. Enclosed Flare Stack Assembly

The following is a general summary of the equipment supplied with the flare.

- *** Constructed of ½ in. A-36 carbon steel
- *** All seams welded inside and out
- *** 2 each 2½ in. x 2½ in. x ½ in. angle iron supports, at top of flare and at ¼ OAH, to add strength to flare stack and control resonant vibrations

- *** 2 each lifting lugs, 180° apart at top of stack for ease of installation
- *** $\frac{1}{2}$ in. A-36 carbon steel 9 in. wide full circumference bottom (baseplate) anchor flange with eight pre-drilled anchor bolt holes and sixteen support gussets
- *** 2 rows of 4 each 3 in. NPT sample ports with caps installed at 90° spacing for emission measurement at landfill gas flows of 800 SCFM and 1500 SCFM
- *** 3 each 1 in. NPT thermal well connections installed at 10 ft. vertical spacing down the flare stack starting at $\frac{1}{2}$ diameter from the flare top
- *** 12 in. 150# flanged LFG inlet connection
- *** 3 each 48 in. high x 36 in. wide galvanized air intake louvers with stainless steel bearings, opposed blade design, providing 6:1 turndown
- *** Fully lined with 2 in. of A.P. Green or equal refractory blanket (2400 °F hot face) fixed with Inconel pins and keepers
- *** $\frac{1}{4}$ in. x 3 in. 304 stainless steel plate retainer around all open edges of the insulation refractory blanket
- *** Air plenum chamber is lined with 1 in. of refractory insulation to provide safe exterior skin temperature
- *** The exterior of the flare stack will be sandblasted, primed and finished with a coat of heat resistant heavy duty enamel
- *** 10 in. center burner tip flange connected to LFG inlet piping, top 6 in. of tip is 304 stainless steel
- *** 4 each 4 in. burner arms designed to produce optimum swirl, obtaining high efficiency mixing and maximum retention time. Arms flange connected to center burner tip and constructed of 304 stainless steel
- *** Full access for repair or replacement of burner assembly components through air intake louver ports
- *** 2 in. diameter 304 stainless steel pilot tip with integral spark plug connection/housing
- *** Electric spark plug ignitor, eliminates gap problems often incurred with straight rod type ignitors

- *** 110/5,000V single pole transformer
- *** High temperature ignitor leads in $\frac{1}{2}$ in. conduit
- *** Pilot nozzle (60,000 BTU/hr design; propane) in $\frac{1}{2}$ in. stainless steel pipe
- *** Gas flowmeter system including microprocessor, preamplifier, and ultrasonic transducers. Unit will transmit a 4-20 mA linear output signal to the PLC and operator display.
- *** All aluminum horizontal flame arrestor with clean out cover to facilitate in place maintenance

B. Base Case Control Features

The following general controls will be included with the flare:

- *** 2 each temperature operated automatic louver with controller to maintain optimum operating temperature and
1 each manually operated louver
- *** Chromel-Alumel (Type K) thermocouple in stainless steel thermal well to give pilot confirmation
- *** Ultraviolet flame scanner to give flame confirmation and provide flare safety shutdown
- *** All control wiring is prefitted to the flare stack and run to a NEMA 4 junction box located at a convenient tie-in location at the base of the flare.
- *** Purge air blower with pressure proved switch to evacuate gases remaining in flare stack prior to ignition cycle
- *** Three Chromel-Alumel (Type K) thermocouple elements with high temperature Inconel protection tubes will be installed at different elevations down the flare stack. All three thermocouples will be connected to the flare controller through an isothermal, low resistance rotary selector switch. The switch will allow the operator to select the appropriate elevation for temperature sensing depending on actual landfill gas flow
- *** Calibrated current transformers and ammeters for flow indication with surge and overload protection

*** Bubble-tight wafer type butterfly valve with a Bettis pneumatic actuator and 3-way solenoid valve. Unit will have a spring operated "fail safe" closing in case of a power failure. Valve will have location limit switches to be used for permissives in flare control system

*** Miscellaneous equipment including required vacuum and pressure gauges or transmitters, and temperature gauges as specified in Contract Documents

C. Control System Operation

The system will incorporate a technically advanced fully integrated, 100% automatic flare controller. The flare controller provides the operator full flexibility to set or change any process variable utilized in the automatic operation of the flare.

All control sequences and strategies associated with the operation of the flare/blower system, as well as all other required field input/outputs, shall be programmed into a programmable logic controller (PLC) unit. The control system will include a graphical operator control interface to allow the monitoring of all field input signals. It also provides full flexibility to set or change any temperature and/or time setting used in the automatic operation of the flare system.

The following is a brief outline of the control system operational features:

PILOT TEMPERATURE CONTROLLER

This PLC based controller senses the pilot temperature and utilizes one event setting, determined by the operator, to begin operation of the landfill gas blower. This setting is referred to as the "blower on" temperature. Once the automatic pilot has been proven by obtaining the blower on temperature the header valve will slowly open and the landfill gas blower will start.

PILOT TIMER

This PLC based timer begins the instant the ignition cycle begins. It is set by the operator at the maximum time required for the pilot to achieve the blower on temperature and the gas supply to be ignited. This time will typically be 3 to 5 minutes. At the end of this time, the pilot gas supply valve will be closed and the pilot flame extinguished, if not already shut-off by the temperature sensor.

PILOT FAILURE INDICATOR AND SHUT-DOWN

The PLC based pilot timer also controls the "pilot failure" function. Upon initiation of the automatic ignition cycle this timer begins timing down. Should the pilot not achieve the "blower on" temperature (set in the pilot temperature controller) in the time set in the pilot timer, the entire system will be shut down. The "pilot failure" indicator light will then come on. The system will not attempt to reignite until the pilot problem has been remedied. If it is determined that the pilot gas supply has not been exhausted or another problem with the pilot system cannot be found the operator may attempt automatic reignition by pushing the "reset" button.

IGNITOR TIMER

The PLC based ignitor timer allows the operator to set the time the ignitor will spark during the ignition cycle. This allows for the adjustment of the spark duration to compensate for the distance of the pilot gas supply from the flare; thus extending the life of the ignitor plug, transformer and other pilot components.

FLARE CHAMBER TEMPERATURE CONTROLLER

The flare controller will constantly monitor the flare combustion chamber temperature through the thermocouple elements on the flare stack. The system will utilize two temperature alarm settings which are:

High temperature safety shutdown - this setting simply shuts down the flare if the temperature should rise to a point of being unsafe or potentially damaging to the flare chamber.

Low temperature shutdown - this setting establishes the minimum acceptable operating temperature for the flare. During operation, if the temperature should fall below this setting, the system will shutdown and then attempt an automatic restart.

ULTRAVIOLET FLAME SCANNER

The ultraviolet scanner and associated controller provide flame confirmation and initiate "flare safety shutdown". Upon loss of flame, the scanner will automatically shutdown the blowers and close the automated header valve. The flame scanner has a maximum response time of 4 seconds, providing almost immediate system shutdown. On completion of the flame out shutdown the flare will attempt an automatic restart. The scanner also provides a safety lockout on the start up of the blowers and opening of the header valve, until confirmation of the pilot flame.

PURGE TIMER

053

This PLC based timer controls the length of time the purge blower runs prior to the ignition cycle commencing. Again the operator has the option to set this timer at the length of time determined to be sufficient but not unnecessarily lengthy to accomplish a complete purge of the flare chamber.

MAIN HEADER VALVE INDICATORS

The automatic landfill gas header valve is equipped with position switches to indicate when fully closed and fully open.

The fully closed indicator is used as a permissive for automatic start.

The fully open indicator is used for a valve operation check. Should the valve not completely open for any reason, the light will continuously blink to indicate a valve malfunction.

KEY LOCK SWITCH

The controller utilizes a key lock switch as a primary safety, cutting the power supply to the panel in the locked position.

EMERGENCY SHUT-DOWN

An easily accessible emergency shut-down button is mounted on the face of the controller. Pushing the button will immediately shut-down the flare, stop the blower and shut the automatic header valve. The system will be locked out until the shut-down is manually reset.

CONTROL RACK

The automatic flare controller, associated motor starters, main control power supply and pilot supply controls will all be mounted on a free standing control rack. The rack will be fabricated from 6 in. x 2 in. channel A-36, sandblasted and painted with rust resistant zinc oxide primer and overcoat of heavy duty industrial enamel.

The following will be fully mounted, piped and wired on the control rack.

- *** Automatic flare controller in NEMA 4X enclosure

- *** Induction motor starters, 3 pole, 460 VAC magnetic, full voltage type, with normally open holding circuit, manual reset and overload relay, installed in NEMA 4 enclosure (for landfill gas blower motors)

- *** AC ammeters on gas blower motor circuit with 200% scale
- *** Hour meters on gas blower motor circuit
- *** Purge blower motor starter, full voltage type, with normally open holding circuit, manual reset and overload relay, installed in NEMA 4 enclosure
- *** Main power panel for 460V, 3 phase, 60HZ power supply with solid copper neutral and ground bus connections, multi-pole circuit breaker with common trip, installed in a weatherproof enclosure
- *** 460V to 120V transformer with terminal board installed in a weatherproof enclosure
- *** 170W mercury vapor security light with photocell and on/off switch (shipped loose for field installation)
- *** 120V, 15A duplex outlet in a weatherproof NEMA 5-20R receptacle box with covers
- *** Pilot gas control system including: strainer, pressure control regulator, pressure gauge with isolation valve, fail-close solenoid valve, bypass around solenoid valve with manual block valve and main manual shut off valve
- *** Landfill gas flowmeter which provides a 4-20 mA signal to the chart recorder and also gives a total flow readout
- *** Alarm beacon mounted on top of controller enclosure operates as a local warning device

1-2221

RESTRICTION AND
LAYOUT GAS DISCHARGE FLARE SYSTEM
CITY OF BETHLEHEM, PENNSYLVANIA
NORTHAMPTON COUNTY, PENNSYLVANIA


DATE: 05/21/95
BY: [Signature]
CHECKED BY: [Signature]
APPROVED BY: [Signature]


HEAD OFFICE
2050 LUCERNE DRIVE #110
CLEVELAND, OHIO 44130
NEW FORDSHIP DRIVE
PLANT

LFG SPECIALTIES, INC.

REV. REVISION
DATE: 8

This drawing and the information contained herein is the property of LFG SPECIALTIES, INC. and is not to be reproduced in whole, or in part, or used to further information to others, without the written consent of LFG SPECIALTIES, INC.





COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
AIR QUALITY PROGRAM

PLAN APPROVAL

Permit No.	48-322-002A	Source &	Landfill Gas Flare
Owner	City of Bethlehem Department of Public Works	Air	Model EF740I12
Address	10 East Church Street Bethlehem, PA 18018	Cleaning	
Attention:	Mr. Wendall Sherman Director of Public Works	Device	
		Location	Lower Saucon Township Northampton County

In accordance with provisions of the Air Pollution Control Act, the Act of January 8, 1967, P. L. 2119, as amended, and with Chapter 127 of the rules and regulations of the Department of Environmental Protection, the Department on SEP 25 1995 approved plan for construction of the above indicated air contamination source.

This PLAN APPROVAL expires March 30, 1996

The plan Approval is subject to the following conditions:

- (1) The source is to be
constructed in accordance with the plans submitted with the
application (as approved herein).

(SEE ATTACHED)

Notify the person noted below when the installation is completed so that the source can be inspected for issuance of an OPERATING PERMIT.

NOTE: Babu H. Patel
Chief, Engineering Services
Air Quality Program
Department of Environmental Protection
2 Public Square
Wilkes-Barre, PA 18711-0790

Thomas A. DiLazaro
Program Manager
Air Quality Program

RECEIVED

SEP 27 1995

**CITY OF BETHLEHEM
DIRECTOR OF PUBLIC WORKS**

- (2) Nothing in this permit shall be construed to supercede, amend or authorize violation of the provisions of any valid and applicable local law, ordinance or regulation, provided that said local law, ordinance or regulation is not preempted by the Pennsylvania Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, 35 P.S. §§4001-4015, et seq.
- (3) The permittee shall comply with the Pennsylvania Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, 35 P.S. §§4001-4015, et seq. and Title 25, Rules and Regulations, Article III, Air Resources promulgated thereunder.
- (4) This Plan Approval authorizes temporary operation of the source(s) covered by this Plan Approval provided the following conditions are met.
 - (a) Operation is authorized only to facilitate the shake-down of sources and air cleaning devices, to permit operations pending the issuance of an Operating Permit or to permit the evaluation of the source(s) for the compliance with all applicable regulations and requirements.
 - (b) This condition authorizes temporary operation of the source(s) for a period of 120 days from the date of issuance of this Plan Approval extension.
 - (c) The Owner/Operator may request an extension if compliance with all applicable regulations and Plan Approval requirements has not been established. The extension request shall be submitted in writing at least 15 days prior to the end of this period of temporary operation and shall provide a description of the compliance status of the source, a detailed schedule for establishing compliance, and the reasons compliance has not been established.

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

059

APPLICATION FOR A PERMIT TO OPERATE

Application is hereby made for a permit to operate the following air contamination source(s) which was/were constructed and operating in accordance with a valid plan approval.

PLAN APPROVAL NO. 48-322-002A

Permittee:	City of Bethlehem Department of Public Works	Source &:	Landfill Gas Flare
Address:	10 East Church Street Bethlehem, PA 18018	Air:	Model EF740I12
Attention:	Mr. Wendall Sherman Director of Public Works	Cleaning:	
		Device:	
		Location:	Lower Saucon Township Northampton County

Plan Approval:

Issue Date: SEP 25 1995

Expiration Date: March 30, 1996

FEES

In accordance with Sections 6.3(d) and 6.3(j) of the Pennsylvania Air Pollution Control Act (as amended) the following fees shall be submitted along with this application:

1. Two hundred fifty dollars (\$250.00) for processing the application;
2. Two hundred fifty dollars (\$250.00) for the annual operating permit administration fee.

A check in the amount of five hundred dollars (\$500.00) payable to the "Commonwealth of Pennsylvania - Clean Air Fund" is enclosed with the application.

060

AFFIDAVIT

I, _____, being duly sworn according to law, depose and state under penalty of law as provided in 18 Pa. C.S. §4904 and Section 9(b)(2) of the Air Pollution Control Act, 35 P.S. §4009(b)(2), that I am the representative of the Permittee identified above, authorized to make this affidavit. I further state that the sources covered by the application are being operated in accordance with the terms and conditions of the operating permit (if any), plan approval, Air Pollution Control Act, and rules and regulations adopted under the Air Pollution Control Act. I understand, acknowledge and agree that the conditions of the plan approval, the Air Pollution Control Act, and the rules and regulations adopted under the Air Pollution Control Act are incorporated by reference into the operating permit.

Sworn to and subscribed before me
this _____ day of _____, 199_

Signature

Notary Public

Name (typed)

Title

Return this completed form, check(s) and completed Compliance History Form to:

Department of Environmental Protection
Air Quality Program
Northeast Regional Office
2 Public Square
Wilkes-Barre, PA 18711-0790
Attn.: Chief, Engineering Services

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

061

APPLICATION FOR
ISSUANCE OF AN AIR QUALITY PLAN APPROVAL EXTENSION
WITH CONDITION TO AUTHORIZE TEMPORARY OPERATION

Application is hereby made for a plan approval extension to allow temporary operation to facilitate the shake-down of sources and/or air cleaning devices or to permit the evaluation of the source(s) for compliance with all applicable regulations and requirements.

APPROVAL/PERMIT NO. 48-322-002A

Owner/ City of Bethlehem
Operator: Department of Public WorksAddress: 10 East Church Street
Bethlehem, PA 18018Attention: Mr. Wendall Sherman
Director of Public Works

Source &: Landfill Gas Flare

Air: Model EF740I12

Cleaning:

Device:

Location: Lower Saucon Township
Northampton CountyCurrent Approval/Permit:

Issue Date: SEP 25 1995

Expiration Date: March 30, 1996

Operation Commenced (Is to Commence):

Specify reason(s) for this request for temporary operation (include the reasons compliance with all applicable regulations and Plan Approval requirements has not been established, a projected schedule for completion of any needed equipment changes and a detailed schedule for achieving full compliance). Attach additional sheets as necessary

FEE

A fee of two hundred dollars (\$200.00) is enclosed pursuant to 25 Pa. Code §127.34 and Section 6.3(j) of the Pennsylvania Air Pollution Control Act.

Application for Issuance of an Air Quality
Plan Approval Extension with Condition to
Authorize Temporary Operation

Page 2 of 1

062

AFFIDAVIT

I, _____, being duly sworn according to law, depose and state under penalty of law as provided in 18 Pa. C.S. §4904 and Section 9(b)(2) of the Air Pollution Control Act, 35 P.S. §4009(b)(2), that I am the representative of the Applicant identified above, authorized to make this affidavit. I further state that the information provided with this application is true and complete.

Sworn to and subscribed before me
this _____ day of _____, 199_

Notary Public

Signature

Name (typed)

Title

Return this completed form, check(s) and completed Compliance History Form to:

Department of Environmental Protection
Air Quality Program
Northeast Regional Office
2 Public Square
Wilkes-Barre, PA 18711-0790
Attn.: Chief, Engineering Services

Air Recon

Division of
RECON Environmental Corp.

Raritan, NJ 08869-0130


063

ATTACHMENT 2

SAMPLE LOCATION DIAGRAMS


INLET

064



TOP VIEW

PLAN
SCALE: 1/2" = 1'-0"





SIDE VIEW


SECTION
SCALE: 1/2" = 1'-0"


OUTLET

065

NOZZLE ORIENT
SCALE 1/2" = 1'

TOP VIEW

DETAIL
SCALE 1" = 1'-0"



APPENDIX II

EMISSION CALCULATIONS

✓

**Linear Regression Calculations
Gas Chromatography Analyses**

CALIBRATION STANDARDS									
Methane, GC Channel 2									
Conc. (ppmv)	Injection-1 Area Counts	Injection-1 Area Counts	Injection-2 Area Counts	Average Area Counts	% From Mean	Sample ID	Run Number	Sample Area Counts	DIL Factor
0.0	0.00	0.00	0.00	0.00	0.00	Flare Inlet	Run 1-1	528.19	1.0
2617	1488.92	1453.05	1470.79	1470.79	1.21	Flare Inlet	Run 1-2	468.36	1.0
4916	3282.87	3176.26	3230.57	3230.57	1.62	Flare Inlet	Run 1-3	509.80	1.0
9175	5020.23	5132.36	5076.31	5076.31	1.10	Flare Inlet	Run 1-4	504.86	1.0
						Flare Inlet	Run 1-5	487.86	1.0
						Flare Inlet	Run 1-6	480.37	1.0
								Average: MDL:	
								851.91	
								844.00	
								916.77	
								909.87	
								870.23	
								845.91	
								892	
								10.0	
								783	
								732.26	
								762.54	
								733.34	
								725.36	
								765.15	
								752	
								10.0	
								686	
								718	
								829	
								815	
								718.35	
								Average: MDL:	
								753	
								10.0	
								699	
								731	
								845	
								830	
								730	
								767	
								10.2	

Coefficient of Determination: 0.992081									
Coefficient of Correlation: 0.991293									
Standard Error of Estimate: 3.512E+02									
Amount / Area Ratio: 1.002E+00									

Stack Emission Rate (lbs/hr)	2,002	2,397	2,598	2,573	2,488	2,392	2,521	2,112	0,028
Stack Flow Rate (DSCFM)	1112	1112	1112	1112	1112	1112	1112	1112	1112
Actual Conc. (ppmv)	973	863	939	910	899	895	912	10.2	10.2
Stack Gas Moisture (%)	2.20	2.20	2.20	2.20	2.20	2.20	2.20	2.20	2.20
DIL Samp. Conc. (ppmv)	951.91	844.00	916.77	909.87	870.23	845.91	892	10.0	10.0
DIL Factor	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Sample Area Counts	528.19	468.36	509.80	504.86	487.86	480.37			
Run Number	Run 1-1	Run 1-2	Run 1-3	Run 1-4	Run 1-5	Run 1-6			
Sample ID	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet			
Sample Area Counts	439.78	406.32	423.11	406.01	402.48	424.58			
Run Number	Run 1-1	Run 2-2	Run 2-3	Run 2-4	Run 2-5	Run 2-6			
Sample ID	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet			
Sample Area Counts	380.87	398.15	459.87	452.19	397.48				
Run Number	Run 3-1	Run 3-2	Run 3-3	Run 3-4	Run 3-5	Run 3-6			
Sample ID	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet	Flare Inlet			

CLIENT:	LFG Specialties
JOB NO.:	ARS-0922
COMPOUND:	Total Non-Methane Hydrocarbons
M.W. (grams/mole):	16.04
SAMPLING DATE:	10/09/98
ANALYSIS DATE:	10/09/98
REPORT DATE:	11/20/98
SAMPLE MATRIX:	GAS
VOLUME INJ. (cc):	1
NO. SAMPLES RUN:	17
ANALYST:	JRG
MDL (ppmv):	10
LOCATION:	Bethlehem Landfill
METHOD NO.:	US EPA-10 On-Line GC/FID

Linear Regression Calculations Gas Chromatography Analyses

CALIBRATION STANDARDS					Sample ID	Run Number	Sample Area Counts	DIL Factor	DIL Samp Conc. (ppmv)	Actual Conc. (ppmv)	Stack Gas Moisture (%)	Actual Conc. (ppmv)	Stack Flow Rate (USCF/M)	Stack Emission Rate (lb/hr)	AIRCON: Division of REIDON ENVIRONMENTAL CORP. Mobile Laboratory - 2
Conc. (ppmv)	Injection-1 Area Counts	Injection-2 Area Counts	Injection-3 Area Counts	Average Area Counts											
0.0	0.00	0.00	0.00	0.00	Flare Outlet	Run 1-1	0.00	1.0	0.00	nd	5.85	0	7698	0.000	CLIENT: IFG Specialties
21.3	118.31	119.16	117.74	117.74	Flare Outlet	Run 1-2	0.00	1.0	0.00	nd	5.85	0	7698	0.000	JOB NO.: ARS-8822
61.3	288.40	287.57	286.99	286.99	Flare Outlet	Run 1-3	0.00	1.0	0.00	nd	5.85	0	7698	0.000	COMPOUND: Total Non-Methane Hydrocarbons
88.7	535.96	500.73	518.36	518.36	Flare Outlet	Run 1-4	0.00	1.0	0.00	nd	5.85	0	7698	0.000	M.W. (grams/mole): 16.04
Coefficient of Determination: 0.997624					Flare Outlet	Run 1-5	0.00	1.0	Average: 0.00	0	5.85	0	7698	0.000	SAMPLING DATE: 10/09/06
Coefficient of Correlation: 0.998511					Flare Outlet	Run 1-6	0.00	1.0	MDL: 0.00	1.1	5.85	1.1	7698	0.020	ANALYSIS DATE: 10/09/06
Standard Error of Estimate: 1.390E+01					Flare Outlet	Run 2-1	0.00	1.0	0.00	nd	8.98	0	7606	0.000	REPORT DATE: 10/16/06
Amount / Area Ratio: 1.050E-01					Flare Outlet	Run 2-2	0.00	1.0	0.00	nd	8.98	0	7606	0.000	SAMPLE MATRIX: GAS
					Flare Outlet	Run 2-3	0.00	1.0	0.00	nd	8.98	0	7606	0.000	VOLUME INJ. (cc): 1
					Flare Outlet	Run 2-4	0.00	1.0	0.00	nd	8.98	0	7606	0.000	NO. SAMPLES RUN: 18
					Flare Outlet	Run 2-5	0.00	1.0	Average: 0.00	0	8.98	0	7606	0.000	ANALYST: JRG
					Flare Outlet	Run 2-6	0.00	1.0	MDL: 0.00	1.1	8.98	1.1	7606	0.021	MDL (ppmv): 1
					Flare Outlet	Run 3-1	0.00	1.0	0.00	nd	8.34	0	6491	0.000	LOCATION: Bethlehem Landfill
					Flare Outlet	Run 3-2	0.00	1.0	0.00	nd	8.34	0	6491	0.000	METHOD NO.: US EPA-18
					Flare Outlet	Run 3-3	0.00	1.0	0.00	nd	8.34	0	6491	0.000	On-Line GC/FID
					Flare Outlet	Run 3-4	0.00	1.0	0.00	nd	8.34	0	6491	0.000	
					Flare Outlet	Run 3-5	0.00	1.0	0.00	nd	8.34	0	6491	0.000	
					Flare Outlet	Run 3-6	0.00	1.0	Average: 0.00	0	8.34	0	6491	0.000	
					Flare Outlet	Run 3-6	0.00	1.0	MDL: 0.00	1.1	8.34	1.1	6491	0.018	

AirRECON Destruction Efficiency Summary

069

PROJECT NAME:	LFG Specialties
SAMPLE LOCATION:	Bethlehem Landfill
PROCESS DESCRIPTION:	Enclosed Ground Flare
COMBUSTION FUEL:	Landfill Gas
AirRECON PROJECT NO.:	AR5-6922
LAB TRAILER NO.:	Two

AirRECON Stack Test ID Number:	1	2	3	4	5
Test Date:	10/09/96	10/09/96	10/09/96		
Test Start-End Times:	1006-1106	1220-1320	1405-1515		

Analyte:	Total Hydrocarbons (as Methane) via EPA Method 25A				
Molar Mass = 18.04 (E)					
Inlet Emission Rate (lbs/hr) (A):					
Outlet Emission Rate (lbs/hr) (B):					
Destruction Efficiency (%) (C):					

Analyte:	Methane via EPA Method 18 (Remote Gas Bag Analysis)				
Molar Mass = 18.04 (E)					
Inlet Emission Rate (lbs/hr) (A):					
Outlet Emission Rate (lbs/hr) (B):					
Destruction Efficiency (%) (C):					

Analyte:	Total Non-Methane Hydrocarbons (as CH4) by GC/FID				
Molar Mass = 18.04 (E)					
Inlet Emission Rate (lbs/hr) (A):	2.521	2.126	2.112		
Outlet Emission Rate (lbs/hr) (B):	< 0.020	< 0.021	< 0.018		
Destruction Efficiency (%) (C):	> 99.21	> 99.01	> 99.15		

The Following Calculation Equation Is Used In This Spreadsheet:

Destruction Efficiency (%) (C):	$(A - B) / (A) * 100$
---------------------------------	-----------------------

Reference CEMS Calibration Drift Corrections

Client Name:	LFG Specialties
Jobsite:	Bethlehem landfill
Emission Source(s):	Enclosed Ground Flare Outlet
AirRECON Project Number:	AR5-6922

Gas Tested	Sample Location	Sample Run Identification	Run Date	Certified Calibration Standard A	Pre-Test Standard Response B	Post-Test Standard Response C	Pre-Test Zero Response D	Post-Test Zero Response E	Average Raw Test Result F	Corrected Test Result G
O2	Flare Outlet	Run-1	10/09/96	11.0	11.0	11.0	11.0	0.1	10.835	10.833
O2	Flare Outlet	Run-2	10/09/96	11.0	11.0	11.0	11.0	0.1	10.683	10.680
O2	Flare Outlet	Run-3	10/09/96	11.0	11.0	11.0	11.1	0.1	10.570	10.518
CO2	Flare Outlet	Run-1	10/09/96	10.0	9.9	9.9	9.9	0.0	9.055	9.146
CO2	Flare Outlet	Run-2	10/09/96	10.0	9.9	9.9	9.9	0.0	9.184	9.277
CO2	Flare Outlet	Run-3	10/09/96	10.0	9.9	9.9	9.8	0.0	9.259	9.400
NOx	Flare Outlet	Run-1	10/09/96	54.8	52.5	53.3	53.3	-0.4	6.704	6.809
NOx	Flare Outlet	Run-2	10/09/96	54.8	53.3	54.5	54.5	-0.4	8.077	8.470
NOx	Flare Outlet	Run-3	10/09/96	54.8	54.5	55.6	55.6	-0.1	8.266	8.355

The Following Calculations Are Used In This Spreadsheet:
 $G = (F - ((D+E)/2)) \times A / ((B+C)/2) - ((D+E)/2)$

AirRECON CEMS Emission Calculation Summary

071

PROJECT NAME:	LFG Specialties
SAMPLE LOCATION:	Bethlehem Landfill
PROCESS DESCRIPTION:	Enclosed Ground Flare Outlet
COMBUSTION FUEL:	Landfill Gas
AirRECON PROJECT NO.:	AR5-6922
LAB TRAILER NO.:	Two (2)

AirRECON Stack Test ID Number:	1	2	3	4	5
Test Date:	10/09/96	10/09/96	10/09/96		
Test Start-End Times:	1006-1106	1220-1320	1405-1514		
Measured Stack Flowrate (DSCFM) (A):	7698	7508	6491		
Measured Stack Moisture (%) (B):	5.65	8.96	8.34		
Measured Stack Oxygen (%) (C):	10.833	10.680	10.518		
Fuel Factor Constant (dscf/mmBTU) (D):					
Results Corrected To % O2 (L):	7	7	7		

Analyte:	Nitrogen Oxides (as NO2) via EPA Method 7E				
Molar Mass = 46.01 (E)					
ppmv, dry (F):	6.809	8.470	8.355		
ppmv, wet (G):	6.424	7.711	7.658		
pounds/hour (H):	0.3738	0.4534	0.3868		
pounds/mmBTU (J):					
ppmv, dry @ 7 % O2 (K):	9.40	11.52	11.19		

Analyte:	Carbon Monoxide via EPA Method 10				
Molar Mass = 28.01 (E)					
ppmv, dry (F):					
ppmv, wet (G):					
pounds/hour (H):					
pounds/mmBTU (J):					
ppmv, dry @ 7 % O2 (K):					

Analyte:	Total Hydrocarbons (as Methane) via EPA Method 25A				
Molar Mass = 16.04 (E)					
ppmv, wet (F):					
ppmv, dry (G):					
pounds/hour (H):					
pounds/mmBTU (J):					
ppmv, dry @ 7 % O2 (K):					

Analyte:	Sulfur Dioxide via EPA Method 6C				
Molar Mass = 64.06 (E)					
ppmv, dry (F):					
ppmv, wet (G):					
pounds/hour (H):					
pounds/mmBTU (J):					
ppmv, dry @ 7 % O2 (K):					

The Following Emission Calculation Equations Are Used In This Spreadsheet:

ppmv, wet:	(G) = (F)(100 - B) / 100
ppmv, dry (For THC):	(F) = (G) / ((100 - B) / 100)
pounds/hour:	(H) = (A)(F)(0.15505)(10 ⁻⁶)
pounds/mmBTU:	(J) = (20.9 / (20.9 - C))(D)(E)(F)(2.585)(10 ⁻⁹)
ppmv, dry @ X% Oxygen:	(K) = ((20.9 - L) / (20.9 - C)) (F)

Stack Flowrate Calculator

Company:	LFG Specialties	Date:	10/09/96
Unit:	Enclosed Flare Inlet	Time:	1006-1106
Location:	Beinhelhem Landfill	Run No.:	One (1)

Input Data

Beginning Meter Setting (cubic feet):	758.634
Ending Meter Setting (cubic feet):	754.667
Metered Volume (cubic feet) [V _m]:	36.033
Water Caught (grams) [W _g]:	16.8
Stack Static Pressures ("H ₂ O)	
Pre-Test (Ps1):	1.8
Post-Test (Ps2):	1.8
Barometric Pressure ("Hg) [P _b]:	29.73
Stack Carbon Dioxide Content (%) [CO ₂]:	25.4
Stack Oxygen Content (%) [O ₂]:	1.8
Stack Methane Content (%) [CH ₄]:	24.2
Delta-H ("H ₂ O) [H]:	1.00
Pilot Tube Factor [Cp]:	0.99
Meter Correction Factor [Y]:	1.01
Stack Cross-Section (square feet) [CSA]:	0.785

Output Data

Metered Volume (Dry cubic feet @STP) [V _{ms}]:	35.214
Moisture Volume (cubic feet @STP) [V _{ws}]:	0.792
Stack Moisture Content (%) [Bws]:	2.20
Gas Dry Molecular Weight (lb/lb - Mol) [MW _d]:	29.23
Gas Wet Molecular Weight (lb/lb - Mol) [MW _w]:	28.98
Absolute Stack Pressure ("Hg) [Pa]:	29.86
Stack Gas Velocities (feet/second)	
Pre-Test, Actual (ft/sec) [V _{as1}]:	25.14
Post-Test, Actual (ft/sec) [V _{as2}]:	25.16
Average, Actual (ft/sec) [V _{as} -Avg]:	25.16
Standard, Average (SFS) [V _{as}]:	24.15
Stack Flowrate (cubic feet/minute)	
Average Actual (ACFM):	1185
Standard Average (SCFM):	1137
Dry, Standard Avg. (DSCFM):	1112
Stack Temperature, Average (Deg. F):	91

This Spreadsheet Uses The Following Calculations/Equations:

$$V_{ms} = (17.71)(V_m)((H/13.6) + P_b) / (T_m + 460)$$

$$V_{ws} = W_g / 21.2$$

$$Bws = (100)(V_{ws}) / (V_{ms} + V_{ws})$$

$$MW_d = (CO_2)(0.44) + (O_2)(0.32) + (CH_4)(0.16) + (100 - (CO_2 + O_2 + CH_4))(28)$$

$$MW_w = (Bws)(0.16) + (MW_d)(100 - Bws) / 100$$

$$P_a = P_b + ((P_{s1} + P_{s2}) / 2) / 13.6$$

$$V_{as1} = ((T_{s1} + 460) / ((P_{s1} / 13.6) + P_b)(MW_w)) \sim 0.6(Cp)(dP1)(85.48)$$

$$V_{as2} = ((T_{s2} + 460) / ((P_{s2} / 13.6) + P_b)(MW_w)) \sim 0.6(Cp)(dP2)(85.48)$$

$$V_{as-Avg} = (V_{as1} + V_{as2}) / 2$$

$$V_{as} = (((V_{as1}) / ((P_{s1} / 13.6) + P_b) / (T_{s1} + 460)) + ((V_{as2}) / ((P_{s2} / 13.6) + P_b) / (T_{s2} + 460))) / ((17.71) / 2)$$

$$ACFM = (V_{as} - avg)(CSA)(60)$$

$$SCFM = (V_{as})(CSA)(60)$$

$$DSCFM = ((100 - Bws) / 100)(SCFM)$$

STP = Standard Conditions = 70 deg. F, 29.92" Hg.

POINT	Pre-Test Traverse			Post-Test Traverse		
	Delta-P ("H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P	Delta-P ("H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P
1	0.09	87	0.300	0.07	94	0.265
2	0.08	88	0.283	0.15	94	0.387
3	0.12	88	0.346	0.16	94	0.400
4	0.15	88	0.387	0.17	94	0.412
5	0.17	88	0.412	0.16	94	0.400
6	0.16	88	0.400	0.14	94	0.374
7	0.12	88	0.346	0.06	94	0.245
8	0.17	88	0.412	0.11	94	0.332
9	0.19	88	0.436	0.15	94	0.387
10	0.19	88	0.436	0.18	94	0.424
11	0.14	88	0.374	0.18	94	0.424
12	0.12	88	0.346	0.17	94	0.412
13			0.000			0.000
14			0.000			0.000
15			0.000			0.000
16			0.000			0.000
17			0.000			0.000
18			0.000			0.000
19			0.000			0.000
20			0.000			0.000
21			0.000			0.000
22			0.000			0.000
23			0.000			0.000
24			0.000			0.000
Avg.:	0.142	88	0.379	0.142	94	0.372

AIRRECON, Division of RECON ENVIRONMENTAL CORP.

P.O. Box 130
5 Johnson Drive
Raritan, NJ 08869

Phone: (908) 526-1000
Fax: (908) 526-7586

(Boston, New Jersey, New York, San Francisco, Los Angeles)

11.68
0.58
3.872
3.61

Stack Flowrate Calculator

Company:	LFG Specialties	Date:	10/09/96
Unit:	Enclosed Flare Inlet	Time:	1220-1320
Location:	Bethlehem Landfill	Run No.:	Two (2)

Input Data	
Beginning Meter Setting (cubic feet):	794.771
Ending Meter Setting (cubic feet):	830.486
Metered Volume (cubic feet) [Vm]:	35.715
Water Caught (grams) [Wg]:	13.6
Stack Static Pressure (in H ₂ O)	
Pre-Test [Ps1]:	1.8
Post-Test [Ps2]:	1.8
Barometric Pressure (in Hg) [Pb]:	29.72
Stack Carbon Dioxide Content (%) [CO2]:	25.8
Stack Oxygen Content (%) [O2]:	1.4
Stack Methane Content (%) [CH4]:	24.3
Delta-H (in H ₂ O) [H]:	1.00
Pilot Tube Factor [Cp]:	0.98
Meter Correction Factor [Y]:	1.01
Stack Gross - Section (square feet) [CSA]:	0.785

Output Data	
Metered Volume: Dry cubic feet @STP [Vms]:	34.307
Moisture Volume (cubic feet @STP) [Vws]:	0.642
Stack Moisture Content (%) [Bws]:	1.84
Gas Dry Molecular Weight (lb/lb - Mol) [MWd]:	29.27
Gas Wet Molecular Weight (lb/lb - Mol) [MWw]:	29.06
Absolute Stack Pressure (in Hg) [Pa]:	29.85
Stack Gas Velocities (feet/second)	
Pre-Test, Actual (ft/sec) [Vsa1]:	25.15
Post-Test, Actual (ft/sec) [Vsa2]:	25.32
Average, Actual (ft/sec) [Vsa - Avg]:	25.23
Standard, Average (SFS) [Vsa]:	24.14
Stack Flowrate (cubic feet/minute)	
Average Actual (ACFM):	1189
Standard Average (SCFM):	1137
Dry, Standard Avg. (DSCFM):	1116
Stack Temperature, Average (Deg. F):	93

This Spreadsheet Uses The Following Calculations/Equations:	
$Vms = (17.1)(V)(Vm) / ((H / 13.6) + Pb) / ((m + 460))$	
$Vws = Wg / 21.2$	
$Bws = (100)(Vws) / (Vms + Vws)$	
$MWd = (CO2)(0.44) + (O2)(0.32) + (CH4)(0.16) + (100 - (CO2 + O2 + CH4))(28)$	
$MWw = (Bws)(0.18) + ((MWd)(100 - Bws) / 100)$	
$Pa = Pb + ((Ps1 + Ps2) / 2) / 13.6$	
$Vsa1 = (((Ps1 + 460) / ((Ps1 / 13.6) + Pb)(MWw))) ^ 0.5 (Cp)(dP1)(65.48)$	
$Vsa2 = (((Ps2 + 460) / ((Ps2 / 13.6) + Pb)(MWw))) ^ 0.5 (Cp)(dP2)(65.48)$	
$Vsa - Avg = (Vsa1 + Vsa2) / 2$	
$Vss = (((Vsa1)((Ps1 / 13.6) + Pb) / ((Ps1 + 460)) + (Vsa2)((Ps2 / 13.6) + Pb) / ((Ps2 + 460)))(17.1 / 2)$	
$ACFM = (Vsa - avg)(CSA)(60)$	
$SCFM = (Vss)(CSA)(60)$	
$DSCFM = ((100 - Bws) / 100)(SCFM)$	

STP = Standard Conditions = 70 deg. F, 29.92" Hg.

POINT	Pre-Test Traverse			Box			Post-Test Traverse		
	Delta-P (in H ₂ O)	Stack Temp (Deg. F)	Square Root Delta-P	Temp. In	Temp. Out	Box Temp. In	Delta-P (in H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P
1	0.07	94	0.265	88	88	88	0.09	91	0.300
2	0.15	94	0.387	94	89	94	0.13	92	0.361
3	0.16	94	0.400	97	89	97	0.17	92	0.412
4	0.17	94	0.412	100	90	100	0.19	92	0.436
5	0.16	94	0.400	101	92	101	0.18	92	0.424
6	0.14	94	0.374	101	92	101	0.14	92	0.374
7	0.08	94	0.245	100	92	100	0.07	90	0.265
8	0.11	94	0.332	101	92	101	0.11	91	0.332
9	0.15	94	0.387	102	93	102	0.16	91	0.400
10	0.18	94	0.424	101	93	101	0.17	92	0.412
11	0.18	94	0.424	99	92	99	0.16	91	0.400
12	0.17	94	0.412	98	91	98	0.15	91	0.387
13			0.000						0.000
14			0.000						0.000
15			0.000						0.000
16			0.000						0.000
17			0.000						0.000
18			0.000						0.000
19			0.000						0.000
20			0.000						0.000
21			0.000						0.000
22			0.000						0.000
23			0.000						0.000
24			0.000						0.000
Avg:	0.142	94	0.372		94.8		0.143	91	0.375
		[Ts1]	[dP1]		[Tm]			[Ts2]	[dP2]

AIRRECON, Division of RECON ENVIRONMENTAL CORP.

P.O. Box 130
5 Johnson Drive
Raritan, NJ 08869

Phone: (908) 526-1000
Fax: (908) 526-7886

(Boston, New York, New Jersey, San Francisco, Los Angeles)

Stack Flowrate Calculator

Company:	LFQ Specialties	Date:	10/09/96
Unit:	Enclosed Flare Inlet	Time:	1405-1515
Location:	Bethlehem Landfill	Run No.:	Three (3)

Input Data:	
Beginning Meter Setting (cubic feet):	830.620
Ending Meter Setting (cubic feet):	867.080
Metered Volume (cubic feet) [Vmf]:	36.470
Water Caught (grams) [Wcl]:	14.4
Stack Static Pressure ("H ₂ O)	
Pre-Test [Ps1]:	1.8
Post-Test [Ps2]:	1.8
Barometric Pressure ("Hg) [Pb]:	29.72
Stack Carbon Dioxide Content (%) [CO2]:	26.2
Stack Oxygen Content (%) [O2]:	1.2
Stack Methane Content (%) [CH4]:	24.7
Delta-H ("H ₂ O) [H]:	1.00
Pitot Tube Factor [Cp]:	0.99
Meter Correction Factor [V]:	1.01
Stack Cross-Section (square feet) [CSA]:	0.765

Output Data:	
Metered Volume (Dry cubic feet @STP) [Vms]:	35.652
Moisture Volume (cubic feet @STP) [Vms]:	0.878
Stack Moisture Content (%) [Bws]:	1.87
Gas Dry Molecular Weight (lb/lb - Mol) [MWd]:	29.28
Gas Wet Molecular Weight (lb/lb - Mol) [MWw]:	29.07
Absolute Stack Pressure ("Hg) [Pa]:	29.85
Stack Gas Velocities (feet/second)	
Pre-Test, Actual (ft/sec) [Vsa1]:	25.32
Post-Test, Actual (ft/sec) [Vsa2]:	24.67
Average, Actual (ft/sec) [Vsa-Avg]:	24.99
Standard, Average (SFS) [Vsa]:	23.95
Stack Flowrate (cubic feet/minute)	
Average Actual (ACFM):	1177
Standard Average (SCFM):	1128
Dry, Standard Avg (DSCFM):	1107
Stack Temperature, Average (Deg. F):	92

This Spreadsheet Uses The Following Calculations/Equations:

$Vms = (17.71)(Vmf) / ((H / 13.6) + Pb) / ((Tm + 460))$
$Vws = Wc / 21.2$
$Bws = (100)(Vws) / (Vms + Vws)$
$MWd = (CO2)(0.44) + (O2)(0.32) + (CH4)(0.16) + (100 - (CO2 + O2 + CH4))(28)$
$MWw = (Bws)(0.18) + ((MWd)(100 - Bws) / 100)$
$Pa = Pb + ((Ps1 + Ps2) / 2) / 13.6$
$Vsa1 = (((Ts1 + 460) / ((Ps1 / 13.6) + Pb)(MWw))) \sim 0.5(Cp)(dP1)(66.48)$
$Vsa2 = (((Ts2 + 460) / ((Ps2 / 13.6) + Pb)(MWw))) \sim 0.5(Cp)(dP2)(66.48)$
$Vsa-Avg = (Vsa1 + Vsa2) / 2$
$Vas = (((Vsa1)((Ps1 / 13.6) + Pb) / (Ts1 + 460)) + ((Vsa2)((Ps2 / 13.6) + Pb) / (Ts2 + 460))) / ((17.71 / 2))$
$ACFM = (Vas - avg)(CSA)(60)$
$SCFM = (Vas)(CSA)(60)$
$DSCFM = ((100 - Bws) / 100)(SCFM)$

STP = Standard Conditions = 70 deg. F, 29.92" Hg.

POINT	Pre-Test Traverse			Box Temp.		Post-Test Traverse		
	Delta-P (H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P	Temp. In	Temp. Out	Delta-P (H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P
1	0.09	91	0.300	82	80	0.07	92	0.265
2	0.13	92	0.361	85	81	0.11	92	0.332
3	0.17	92	0.412	89	81	0.16	92	0.400
4	0.19	92	0.436	89	81	0.17	92	0.412
5	0.18	92	0.424	92	82	0.17	92	0.412
6	0.14	92	0.374	92	84	0.14	92	0.374
7	0.07	90	0.265	92	84	0.08	92	0.245
8	0.11	91	0.332	85	82	0.12	92	0.346
9	0.16	91	0.400	87	82	0.16	92	0.400
10	0.17	92	0.412	87	81	0.16	92	0.400
11	0.16	91	0.400	88	81	0.17	92	0.412
12	0.15	91	0.387	90	81	0.15	92	0.387
13			0.000	93	83			0.000
14			0.000					0.000
15			0.000					0.000
16			0.000					0.000
17			0.000					0.000
18			0.000					0.000
19			0.000					0.000
20			0.000					0.000
21			0.000					0.000
22			0.000					0.000
23			0.000					0.000
24			0.000					0.000
Avg.:	0.143	91	0.375		85.2	0.137	92	0.365
		[Ts1]	[dP1]		[Tm]		[Ts2]	[dP2]

AirRECON, Division of RECON ENVIRONMENTAL CORP.

P.O. Box 130
5 Johnson Drive
Raritan, NJ 08869

Phone: (908) 528-1000
Fax: (908) 528-7886

(Boston, New Jersey, New Jersey, San Francisco, Los Angeles)

Stack Flowrate Calculator

Company:	LFG Specialties	Date:	10/09/96
Unit:	Enclosed Flare Outlet	Time:	1008 - 1108
Location:	Bethlehem Landfill	Run No.:	One (1)

Input Data	
Beginning Meter Setting (cubic feet):	414.200
Ending Meter Setting (cubic feet):	445.845
Metered Volume (cubic feet) [V _m]:	31.645
Water Caught (grams) [W _g]:	36.8
Stack Static Pressure (° H ₂ O)	
Pre-Test [Pa ₁]:	-0.06
Post-Test [Pa ₂]:	-0.06
Barometric Pressure (° Hg) [P _b]:	29.73
Stack Carbon Dioxide Content (%) [CO ₂]:	9.146
Stack Oxygen Content (%) [O ₂]:	10.833
Delta- H (° H ₂ O) [H]:	1.00
Pilot Tube Factor [C _p]:	0.85
Meter Correction Factor [Y]:	0.98
Stack Cross-Section (square feet) [CSA]:	38.48

Output Data	
Measured Volume (Dry cubic feet @STP) [Vms]:	30.567
Moisture Volume (cubic feet @STP) [Vsa]:	1.830
Stack Moisture Content (%) [Bws]:	5.65
Gas Dry Molecular Weight (lb/lb-Mol) [MWd]:	29.90
Gas Wet Molecular Weight (lb/lb-Mol) [MWw]:	29.22
Absolute Stack Pressure (° Hg) [Pa]:	29.73
Stack Gas Velocities (feet/second)	
Pre - Test, Actual (ft/sec) [Vsa1]:	11.04
Post - Test, Actual (ft/sec) [Vsa2]:	14.85
Average, Actual (ft/sec) [Vsa-Avg]:	12.95
Standard, Average (SFS) [Vss]:	3.53
Stack Flowrate (cubic feet/minute)	
Average, Actual (ACFM):	29994
Standard Average (SCFM):	8159
Dry, Standard Avg (DS CFM):	7898
Stack Temperature, Average (Deg. F):	1469

This Spreadsheet Uses The Following Calculations/Equations:

$$/m_b = (17.71)(V_m) / ((H / 13.6) + Pb) / (T_m + 460))$$

$$W_B = W_C / 21.2$$

$$3w_3 = (100)(V_{ws}) / (V_{ms} + V_{ws})$$

$$W_{Wd} = (CO_2)(0.44) + (O_2)(0.32) + (100 - (CO_2 + O_2))(0.28)$$

$$MWw = (Bws)(0.18) + ((MWd)(100 - Bws) / 100)$$

$$Pa = Pb + ((Ps1 + Ps2) / 2) / 136$$

$$sa1 = (((Ts1 + 460) / (((Pb1 / 13.6) + Pb)(MWw))) ^ 0.5) [Cp] (dP1) (85.48)$$

$$/sa2 = (((Ts2 + 460) / ((Pa2 /$$

$$V_{sa} - A_{vg} = (V_{sa1} + V_{sa2})/2$$

$$CEM = \frac{((Vsa) / ((Ps) / (3.8) + 1))}{(Vsa) - (Vsa) / ((Ps) / (3.8) + 1)}$$

$$\text{ACFM} = (V_{sa} - \text{avg})(CSA)(60)$$

$$OSCEM = ((100 - Bws) / 100) / (Vss / (C5A[60])$$

$$\text{BCTM} = (100 - \text{BWS}) / 100$$

STP = Standard Conditions = 70 deg. F, 29.92" Hg.

POINT	Pre-Test Traverse			Box		Post-Test Traverse		
	Delta-P (°H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P	Box Temp. In	Box Temp. Out	Delta-P (°H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P
1	0.005	1392	0.071	57	70	0.010	1387	0.100
2	0.010	1451	0.100	65	70	0.020	1482	0.141
3	0.020	1511	0.141	65	70	0.025	1513	0.158
4	0.020	1521	0.141	67	70	0.025	1501	0.158
5	0.020	1482	0.141	75	70	0.020	1485	0.141
6	0.010	1479	0.100	78	70	0.020	1469	0.141
7	0.010	1460	0.100	82	72	0.020	1450	0.141
8	0.005	1455	0.071	85	74	0.015	1444	0.122
9	0.005	1400	0.071	88	75	0.010	1401	0.100
10	0.005	1421	0.071	90	76	0.010	1481	0.100
11	0.010	1484	0.100	92	78	0.015	1601	0.122
12	0.005	1505	0.071	93	80	0.015	1521	0.122
13	0.005	1521	0.071			0.020	1472	0.141
14	0.010	1490	0.100			0.025	1462	0.158
15	0.020	1482	0.141			0.030	1460	0.173
16	0.020	1461	0.141			0.030	1451	0.173
17			0.000					0.000
18			0.000					0.000
19			0.000					0.000
20			0.000					0.000
21			0.000					0.000
22			0.000					0.000
23			0.000					0.000
24			0.000					0.000
25			0.000					0.000
Avg.	0.011	1470	0.102		75.5	0.019	1466	0.137
		[Tst]	[dP1]		[Tm]		[T-2]	[dP2]

AIRRECON, Division of RECON ENVIRONMENTAL CORP.

**P.O. Box 130
5 Johnson Drive
Raritan, NJ 08860**

Phone: (908) 526-1000
Fax: (908) 526-7886

(Boston, New York, New Jersey, San Francisco, Los Angeles)

Stack Flowrate Calculator

Company:	LFG Speculations	Date:	10/09/88
Unit:	Enclosed Flare Outlet	Time:	1220 - 1320
Location:	Bethlehem Landfill	Run No.:	Two (2)

Input Data:	
Beginning Meter Setting (cubic feet):	445.952
Ending Meter Setting (cubic feet):	478.259
Metered Volume (cubic feet) [Vml]:	32.307
Water Caught (grams) [Wgt]:	63.7
Stack Static Pressure ("H ₂ O):	
Pre-Test (Pa1):	-0.06
Post-Test (Pa2):	-0.06
Barometric Pressure ("Hg) [Pb]:	29.72
Stack Carbon Dioxide Content (%) [CO2]:	9.277
Stack Oxygen Content (%) [O2]:	10.880
Data-H ("H ₂ O) [H]:	1.00
Pilot Tube Factor [Cp]:	0.85
Meter Correction Factor [V]:	0.98
Stack Gross Section (square feet) [CSA]:	38.48

Output Data:	
Metered Volume (Dry cubic feet @STP) [Vms]:	30.517
Moisture Volume (cubic feet @STP) [Vws]:	3.005
Stack Moisture Content (%) [Bws]:	8.96
Gas Dry Molecular Weight (lb/lb Mol) [MWd]:	29.91
Gas Wet Molecular Weight (lb/lb Mol) [MWw]:	28.64
Absolute Stack Pressure ("Hg) [Pa]:	29.72
Stack Gas Velocities (feet/second):	
Pre-Test, Actual (ft/sec) [Vea1]:	14.95
Post-Test, Actual (ft/sec) [Vea2]:	11.37
Average, Actual (ft/sec) [Vea-Avg]:	13.16
Standard, Average (SFA) [Vse]:	3.57
Stack Flowrate (cubic feet/minute)	
Average Actual (ACFM):	30390
Standard Average (SCFM):	8246
Dry Standard Avg (DSCFM):	7506
Stack Temperature, Average (Deg. F):	1482

This Spreadsheet Uses The Following Calculations/Equations:

$$Vms = ((17.71)(Vml) / (H / 13.6 + Pb) / (Tm + 460))$$

$$Vws = Wc / 21.2$$

$$Bws = (100)(Vws) / (Vms + Vws)$$

$$MWd = (CO2)(0.44) + (O2)(0.32) + (100 - (CO2 + O2))(28)$$

$$MWw = (Bws)(0.18) + ((MWd)(100 - Bws) / 100)$$

$$Pa = Pb + ((Pa1 + Pa2) / 2) / 13.6$$

$$Vea1 = (((Ts1 + 460) / ((Pa1 / 13.6) + Pb)(MWw))) ^ 0.5 (Cp)(dP1)(85.48)$$

$$Vea2 = (((Ts2 + 460) / ((Pa2 / 13.6) + Pb)(MWw))) ^ 0.5 (Cp)(dP2)(85.48)$$

$$Vea-Avg = (Vea1 + Vea2) / 2$$

$$Vea = (((Vea1) / ((Pa1 / 13.6) + Pb) / (Ts1 + 460)) + ((Vea2) / ((Pa2 / 13.6) + Pb) / (Ts2 + 460))) / (17.71 / 2)$$

$$ACFM = (Vea - avg)(CSA)(60)$$

$$SCFM = (Vms)(CSA)(60)$$

$$DSCFM = ((100 - Bws) / 100)(SCFM)$$

STP = Standard Conditions = 70 deg. F, 29.92" Hg.

POINT	Pre-Test Traverse			Box			Post-Test Traverse		
	Delta-P ("H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P	Temp. In	Temp. Out		Delta-P ("H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P
1	0.010	1387	0.100	80	92		0.005	1462	0.071
2	0.020	1492	0.141	82	82		0.005	1493	0.071
3	0.025	1513	0.158	86	82		0.010	1505	0.100
4	0.025	1501	0.158	91	83		0.010	1521	0.100
5	0.020	1485	0.141	91	84		0.020	1499	0.141
6	0.020	1469	0.141	92	84		0.025	1501	0.158
7	0.020	1450	0.141	92	85		0.025	1482	0.158
8	0.015	1444	0.122	93	82		0.020	1473	0.141
9	0.010	1401	0.100	95	86		0.005	1472	0.071
10	0.010	1481	0.100	96	87		0.005	1488	0.071
11	0.015	1501	0.122	95	86		0.015	1505	0.122
12	0.015	1521	0.122	94	87		0.020	1521	0.141
13	0.020	1472	0.141				0.010	1510	0.100
14	0.025	1462	0.158				0.005	1488	0.071
15	0.030	1460	0.173				0.005	1489	0.071
16	0.030	1451	0.173				0.005	1489	0.071
17			0.000					0.000	0.000
18			0.000					0.000	0.000
19			0.000					0.000	0.000
20			0.000					0.000	0.000
21			0.000					0.000	0.000
22			0.000					0.000	0.000
23			0.000					0.000	0.000
24			0.000					0.000	0.000
25			0.000					0.000	0.000
Avg.:	0.019	1468	0.137		87.4		0.012	1495	0.104
		[Ts1]	[dP1]		[Tm]			[Ts2]	[dP2]

AIRRECON, Division of RECON ENVIRONMENTAL CORP.

P.O. Box 130
5 Johnson Drive
Raritan, NJ 08869

Phone: (908) 528-1000
Fax: (908) 528-7888

(Boston, New York, New Jersey, San Francisco, Los Angeles)

Stack Flowrate Calculator

Company:	LFG Specialties	Date:	10/09/96
Unit:	Enclosed Flare Outlet	Time:	1405-1514
Location:	Bethlehem Landfill	Run No.:	Three (3)

Input Data	
Beginning Meter Setting (cubic feet)	478.411
Ending Meter Setting (cubic feet)	510.885
Metered Volume (cubic feet) [Vmi]	32.474
Water Caught (grams) [Wet]	58.9
Stack Static Pressures ("H ₂ O)	
Pre-Test [Pa1]	-0.06
Post-Test [Pa2]	-0.06
Barometric Pressure ("Hg) [Pb]	29.72
Stack Carbon Dioxide Content (%) [CO2]	9.400
Stack Oxygen Content (%) [O2]	10.518
Delta-H ("H ₂ O) [H]	1.00
Pilot Tube Factor [Cp]	0.85
Moisture Correction Factor [Y]	0.98
Stack Cross-Section (square feet) [CSA]	38.48

Output Data	
Metered Volume (Dry cubic feet @STP) [Vms]	30.546
Moisture Volume (cubic feet @STP) [Vws]	2.776
Stack Moisture Content (%) [Bws]	8.34
Gas Dry Molecular Weight (lb/lb-Mol) [MWd]	29.92
Gas Wet Molecular Weight (lb/lb-Mol) [MWw]	28.93
Absolute Stack Pressure ("Hg) [Pa]	29.72
Stack Gas Velocities (feet/second)	
Pre-Test, Actual (ft/sec) [Vsa1]	11.35
Post-Test, Actual (ft/sec) [Vsa2]	11.45
Average, Actual (ft/sec) [Vsa-Avg]	11.40
Standard, Average (BFS) [Vsa]	3.07
Stack Flowrate (cubic feet/minute)	
Average Actual (ACFM)	26321
Standard Average (SCFM)	7081
Dry, Standard Avg (DSCFM)	6491
Stack Temperature, Average (Deg. F)	1498

This Spreadsheet Uses The Following Calculations/Equations:	
$Vms = (17.71)(Vmi) / ((H / 13.6) + Pb) / (Tm + 460)$	
$Vws = Ww / 21.2$	
$Bws = (100)(Vws) / (Vms + Vws)$	
$MWd = CO2(0.44) + O2(0.32) + (100 - CO2 - O2)(2.8)$	
$MWw = Bws(0.18) + (MWd)(100 - Bws) / 100$	
$Pa = Pb + ((Ps1 + Ps2) / 2) / 13.6$	
$Vsa1 = (((Ts1 + 460) / ((Ps1 / 13.6) + Pb)(MWw)))^{0.5} (Cp)(dP1)(85.48)$	
$Vsa2 = (((Ts2 + 460) / ((Ps2 / 13.6) + Pb)(MWw)))^{0.5} (Cp)(dP2)(85.48)$	
$Vsa-Avg = (Vsa1 + Vsa2) / 2$	
$Vsa = (((Vsa1) / ((Ps1 / 13.6) + Pb) / (Ts1 + 460)) + ((Vsa2) / ((Ps2 / 13.6) + Pb) / (Ts2 + 460))) / ((17.71) / 2)$	
$ACFM = (Vsa - avg) / CSA(60)$	
$SCFM = (Vsa) / CSA(60)$	
$DSCFM = ((100 - Bws) / 100)(SCFM)$	

STP = Standard Conditions = 70 deg. F, 29.92" Hg.


POINT	Pre-Test Traverse			Post-Test Traverse		
	Delta-P ("H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P	Delta-P ("H ₂ O)	Stack Temp. (Deg. F)	Square Root Delta-P
1	0.005	1482	0.071	0.005	1469	0.071
2	0.005	1493	0.071	0.005	1492	0.071
3	0.010	1505	0.100	0.005	1521	0.071
4	0.010	1521	0.100	0.015	1517	0.122
5	0.020	1499	0.141	0.020	1500	0.141
6	0.025	1501	0.158	0.030	1505	0.173
7	0.025	1482	0.158	0.020	1481	0.141
8	0.020	1473	0.141	0.015	1481	0.122
9	0.005	1472	0.071	0.010	1483	0.100
10	0.005	1488	0.071	0.010	1490	0.100
11	0.015	1505	0.122	0.010	1510	0.100
12	0.020	1521	0.141	0.015	1530	0.122
13	0.010	1510	0.100	0.015	1500	0.122
14	0.005	1498	0.071	0.005	1489	0.071
15	0.005	1489	0.071	0.005	1493	0.071
16	0.005	1489	0.071	0.005	1480	0.071
17			0.000			0.000
18			0.000			0.000
19			0.000			0.000
20			0.000			0.000
21			0.000			0.000
22			0.000			0.000
23			0.000			0.000
24			0.000			0.000
25			0.000			0.000
Avg's:	0.012	1495 [Ts1]	0.104 [dP1]	0.012	1498 [Ts2]	0.104 [dP2]
					84.7 [Tm]	

AIRRECON, Division of RECON ENVIRONMENTAL CORP.

P.O. Box 130
5 Johnson Drive
Raritan, NJ 08869


Phone: (908) 526-1000
Fax: (908) 526-7886

(Boston, New York, New Jersey, San Francisco, Los Angeles)



APPENDIX III

CEM DATA SUMMARIES



079

Client Name:	LFG Specialties
Location:	Bethlehem Landfill
Emission Source(s):	Enclosed Ground Flare Outlet
AIRCON Project Number:	AR5-6922
Run Number:	One (1)

Date and Time	O ₂	CO ₂	NO _x
9/Oct/96 10:6:9	10.8 %	9.1 %	6.4 ppm,d
9/Oct/96 10:6:39	11.0 %	8.9 %	6.2 ppm,d
9/Oct/96 10:7:9	11.1 %	8.9 %	6.5 ppm,d
9/Oct/96 10:7:39	11.0 %	9.0 %	6.5 ppm,d
9/Oct/96 10:8:9	10.9 %	9.0 %	6.5 ppm,d
9/Oct/96 10:8:39	10.8 %	9.0 %	6.3 ppm,d
9/Oct/96 10:9:9	10.9 %	9.0 %	6.3 ppm,d
9/Oct/96 10:9:39	10.9 %	9.0 %	6.5 ppm,d
9/Oct/96 10:10:9	10.7 %	9.1 %	6.3 ppm,d
9/Oct/96 10:10:39	11.0 %	9.0 %	6.4 ppm,d
9/Oct/96 10:11:9	10.8 %	9.0 %	6.5 ppm,d
9/Oct/96 10:11:39	10.8 %	9.0 %	6.4 ppm,d
9/Oct/96 10:12:9	10.8 %	9.1 %	6.0 ppm,d
9/Oct/96 10:12:39	11.1 %	8.8 %	6.4 ppm,d
9/Oct/96 10:13:9	11.1 %	8.8 %	6.2 ppm,d
9/Oct/96 10:13:39	11.0 %	8.9 %	6.2 ppm,d
9/Oct/96 10:14:9	10.9 %	9.0 %	6.5 ppm,d
9/Oct/96 10:14:39	10.9 %	8.9 %	6.4 ppm,d
9/Oct/96 10:15:9	10.9 %	9.1 %	6.2 ppm,d
9/Oct/96 10:15:39	10.8 %	9.1 %	6.6 ppm,d
9/Oct/96 10:16:9	11.0 %	8.9 %	6.8 ppm,d
9/Oct/96 10:16:39	10.7 %	9.3 %	6.9 ppm,d
9/Oct/96 10:17:9	10.8 %	9.1 %	6.5 ppm,d
9/Oct/96 10:17:39	10.9 %	9.0 %	6.6 ppm,d
9/Oct/96 10:18:9	10.7 %	9.4 %	7.2 ppm,d
9/Oct/96 10:18:39	11.0 %	8.9 %	6.9 ppm,d
9/Oct/96 10:19:9	10.9 %	9.0 %	6.9 ppm,d
9/Oct/96 10:19:39	11.1 %	8.8 %	6.5 ppm,d
9/Oct/96 10:20:9	10.9 %	9.0 %	6.9 ppm,d
9/Oct/96 10:20:39	10.7 %	9.2 %	7.1 ppm,d
9/Oct/96 10:21:9	10.9 %	9.0 %	6.8 ppm,d
9/Oct/96 10:21:39	10.9 %	9.1 %	6.8 ppm,d
9/Oct/96 10:22:9	11.1 %	8.9 %	6.8 ppm,d
9/Oct/96 10:22:39	10.7 %	9.1 %	6.4 ppm,d
9/Oct/96 10:23:9	10.9 %	8.9 %	6.8 ppm,d
9/Oct/96 10:23:39	10.6 %	9.2 %	6.6 ppm,d
9/Oct/96 10:24:9	10.9 %	9.1 %	6.7 ppm,d
9/Oct/96 10:24:39	10.8 %	9.1 %	6.6 ppm,d
9/Oct/96 10:25:9	11.0 %	8.8 %	6.1 ppm,d
9/Oct/96 10:25:39	10.7 %	9.1 %	6.2 ppm,d
9/Oct/96 10:26:9	10.8 %	9.1 %	6.5 ppm,d
9/Oct/96 10:26:39	10.7 %	9.1 %	6.6 ppm,d
9/Oct/96 10:27:9	10.9 %	9.0 %	6.7 ppm,d
9/Oct/96 10:27:39	10.9 %	9.1 %	6.7 ppm,d
9/Oct/96 10:28:9	10.8 %	9.1 %	6.7 ppm,d
9/Oct/96 10:28:39	10.5 %	9.2 %	6.6 ppm,d
9/Oct/96 10:29:9	11.0 %	9.0 %	6.8 ppm,d
9/Oct/96 10:29:39	10.5 %	9.3 %	6.6 ppm,d
9/Oct/96 10:30:8	10.8 %	9.0 %	6.6 ppm,d
9/Oct/96 10:30:39	11.0 %	9.1 %	6.7 ppm,d
9/Oct/96 10:31:9	10.9 %	8.9 %	6.4 ppm,d
9/Oct/96 10:31:39	11.0 %	8.9 %	6.6 ppm,d
9/Oct/96 10:32:9	11.0 %	8.9 %	6.7 ppm,d
9/Oct/96 10:32:39	10.8 %	9.1 %	6.3 ppm,d
9/Oct/96 10:33:9	10.8 %	9.1 %	6.9 ppm,d
9/Oct/96 10:33:39	11.0 %	8.9 %	6.9 ppm,d
9/Oct/96 10:34:9	10.9 %	9.1 %	6.9 ppm,d
9/Oct/96 10:34:39	10.9 %	9.1 %	6.8 ppm,d
9/Oct/96 10:35:9	10.7 %	9.2 %	6.8 ppm,d
9/Oct/96 10:35:39	10.9 %	9.0 %	6.7 ppm,d
9/Oct/96 10:36:9	10.8 %	9.2 %	6.7 ppm,d
9/Oct/96 10:36:39	10.8 %	9.1 %	6.5 ppm,d
9/Oct/96 10:37:8	11.2 %	8.8 %	6.8 ppm,d
9/Oct/96 10:37:39	10.9 %	9.1 %	7.0 ppm,d
9/Oct/96 10:38:9	10.7 %	9.2 %	7.0 ppm,d

080

9/Oct/96 10:38:39	10.7 %	9.1 %	6.9 ppm,d
9/Oct/96 10:39: 9	10.9 %	9.0 %	6.5 ppm,d
9/Oct/96 10:39:39	10.8 %	9.1 %	7.1 ppm,d
9/Oct/96 10:40: 9	10.7 %	9.1 %	7.0 ppm,d
9/Oct/96 10:40:38	10.6 %	9.2 %	6.6 ppm,d
9/Oct/96 10:41: 9	11.1 %	8.9 %	6.5 ppm,d
9/Oct/96 10:41:39	10.8 %	9.1 %	6.9 ppm,d
9/Oct/96 10:42: 9	10.7 %	9.0 %	6.5 ppm,d
9/Oct/96 10:42:39	10.6 %	9.1 %	6.5 ppm,d
9/Oct/96 10:43: 9	10.7 %	9.2 %	6.6 ppm,d
9/Oct/96 10:43:39	11.0 %	9.0 %	6.8 ppm,d
9/Oct/96 10:44: 8	10.6 %	9.2 %	6.9 ppm,d
9/Oct/96 10:44:39	10.8 %	9.1 %	6.8 ppm,d
9/Oct/96 10:45: 9	10.6 %	9.2 %	6.5 ppm,d
9/Oct/96 10:45:38	10.9 %	9.0 %	6.5 ppm,d
9/Oct/96 10:46: 9	11.0 %	8.9 %	6.9 ppm,d
9/Oct/96 10:46:39	10.8 %	9.1 %	7.0 ppm,d
9/Oct/96 10:47: 9	10.8 %	9.1 %	6.9 ppm,d
9/Oct/96 10:47:39	10.6 %	9.2 %	6.7 ppm,d
9/Oct/96 10:48: 9	11.1 %	8.9 %	7.0 ppm,d
9/Oct/96 10:48:38	10.9 %	9.1 %	6.6 ppm,d
9/Oct/96 10:49: 9	10.7 %	9.1 %	6.9 ppm,d
9/Oct/96 10:49:39	10.9 %	9.0 %	6.9 ppm,d
9/Oct/96 10:50: 9	10.8 %	9.0 %	7.1 ppm,d
9/Oct/96 10:50:39	11.1 %	8.7 %	6.7 ppm,d
9/Oct/96 10:51: 9	11.0 %	8.9 %	6.7 ppm,d
9/Oct/96 10:51:39	10.7 %	9.2 %	7.1 ppm,d
9/Oct/96 10:52: 9	10.6 %	9.3 %	6.9 ppm,d
9/Oct/96 10:52:39	10.8 %	9.0 %	6.8 ppm,d
9/Oct/96 10:53: 9	10.7 %	9.2 %	6.8 ppm,d
9/Oct/96 10:53:39	10.9 %	9.1 %	7.0 ppm,d
9/Oct/96 10:54: 8	10.7 %	9.2 %	6.8 ppm,d
9/Oct/96 10:54:39	10.8 %	8.9 %	7.3 ppm,d
9/Oct/96 10:55: 9	10.7 %	9.2 %	7.0 ppm,d
9/Oct/96 10:55:39	10.7 %	9.2 %	6.9 ppm,d
9/Oct/96 10:56: 8	11.0 %	8.9 %	6.7 ppm,d
9/Oct/96 10:56:39	10.7 %	9.1 %	6.9 ppm,d
9/Oct/96 10:57: 9	10.8 %	9.2 %	7.1 ppm,d
9/Oct/96 10:57:39	10.8 %	9.0 %	6.7 ppm,d
9/Oct/96 10:58: 9	10.6 %	9.2 %	6.8 ppm,d
9/Oct/96 10:58:38	11.0 %	9.0 %	6.8 ppm,d
9/Oct/96 10:59: 9	10.7 %	9.3 %	6.9 ppm,d
9/Oct/96 10:59:39	10.6 %	9.2 %	7.0 ppm,d
9/Oct/96 11: 0: 9	10.6 %	9.3 %	6.9 ppm,d
9/Oct/96 11: 0:39	10.7 %	9.1 %	6.9 ppm,d
9/Oct/96 11: 1: 9	10.6 %	9.2 %	7.2 ppm,d
9/Oct/96 11: 1:39	10.7 %	9.1 %	7.1 ppm,d
9/Oct/96 11: 2: 9	11.1 %	8.8 %	6.5 ppm,d
9/Oct/96 11: 2:39	10.9 %	9.0 %	6.6 ppm,d
9/Oct/96 11: 3: 8	11.0 %	9.0 %	7.4 ppm,d
9/Oct/96 11: 3:39	10.7 %	9.1 %	6.8 ppm,d
9/Oct/96 11: 4: 9	10.7 %	9.1 %	6.6 ppm,d
9/Oct/96 11: 4:39	10.8 %	9.2 %	6.6 ppm,d
9/Oct/96 11: 5: 8	11.0 %	9.0 %	6.9 ppm,d
9/Oct/96 11: 5:39	10.8 %	9.0 %	6.6 ppm,d

Client Name:	LFG Specialties
Jobsite:	Bethlehem Landfill
Emission Source(s):	Enclosed Ground Flare Outlet
AirRECON Project Number:	AR5-6922
Run Number:	One (1)

	O2	CO2	NOx
Raw Test Averages:	10.835 %	9.055 %	6.704 ppm,d

081

Client Name:	LFG Specialties
Location:	Bethlehem Landfill
Emission Source(s):	Enclosed Ground Flare Outlet
AIRRECON Project Number:	AR5-6922
Run Number:	Two (2)

Date and Time	O ₂	CO ₂	NO _x
9/Oct/96 12:20: 9	10.8 %	9.0 %	8.3 ppm,d
9/Oct/96 12:20:38	10.6 %	9.3 %	8.1 ppm,d
9/Oct/96 12:21: 8	10.6 %	9.3 %	8.3 ppm,d
9/Oct/96 12:21:38	10.7 %	9.2 %	8.5 ppm,d
9/Oct/96 12:22: 8	10.7 %	9.1 %	8.2 ppm,d
9/Oct/96 12:22:38	10.7 %	9.2 %	8.2 ppm,d
9/Oct/96 12:23: 7	10.4 %	9.4 %	8.5 ppm,d
9/Oct/96 12:23:38	10.6 %	9.3 %	8.5 ppm,d
9/Oct/96 12:24: 8	10.5 %	9.3 %	7.8 ppm,d
9/Oct/96 12:24:38	11.1 %	8.8 %	8.1 ppm,d
9/Oct/96 12:25: 8	10.6 %	9.3 %	8.1 ppm,d
9/Oct/96 12:25:38	10.5 %	9.4 %	8.8 ppm,d
9/Oct/96 12:26: 8	10.5 %	9.4 %	8.5 ppm,d
9/Oct/96 12:26:37	10.6 %	9.2 %	8.5 ppm,d
9/Oct/96 12:27: 8	10.6 %	9.3 %	8.2 ppm,d
9/Oct/96 12:27:38	10.8 %	9.1 %	8.3 ppm,d
9/Oct/96 12:28: 8	10.9 %	9.1 %	8.4 ppm,d
9/Oct/96 12:28:38	10.8 %	9.0 %	7.8 ppm,d
9/Oct/96 12:29: 8	10.6 %	9.3 %	8.0 ppm,d
9/Oct/96 12:29:38	10.7 %	9.2 %	8.1 ppm,d
9/Oct/96 12:30: 7	11.0 %	9.0 %	8.3 ppm,d
9/Oct/96 12:30:38	10.7 %	9.3 %	8.4 ppm,d
9/Oct/96 12:31: 8	10.8 %	9.1 %	8.2 ppm,d
9/Oct/96 12:31:37	10.6 %	9.2 %	8.7 ppm,d
9/Oct/96 12:32: 8	10.7 %	9.0 %	8.4 ppm,d
9/Oct/96 12:32:38	10.6 %	9.2 %	8.3 ppm,d
9/Oct/96 12:33: 7	10.7 %	9.2 %	8.3 ppm,d
9/Oct/96 12:33:38	10.8 %	9.1 %	8.4 ppm,d
9/Oct/96 12:34: 8	10.4 %	9.3 %	8.3 ppm,d
9/Oct/96 12:34:38	10.5 %	9.3 %	8.2 ppm,d
9/Oct/96 12:35: 7	10.8 %	9.2 %	8.6 ppm,d
9/Oct/96 12:35:38	10.9 %	9.1 %	7.7 ppm,d
9/Oct/96 12:36: 8	10.7 %	9.3 %	8.4 ppm,d
9/Oct/96 12:36:38	10.8 %	9.1 %	7.8 ppm,d
9/Oct/96 12:37: 8	10.7 %	9.2 %	7.7 ppm,d
9/Oct/96 12:37:38	10.8 %	9.0 %	8.1 ppm,d
9/Oct/96 12:38: 7	10.9 %	9.0 %	8.3 ppm,d
9/Oct/96 12:38:37	10.7 %	9.2 %	8.3 ppm,d
9/Oct/96 12:39: 8	10.8 %	9.1 %	8.1 ppm,d
9/Oct/96 12:39:38	10.5 %	9.4 %	8.2 ppm,d
9/Oct/96 12:40: 7	10.7 %	9.2 %	8.3 ppm,d
9/Oct/96 12:40:38	10.8 %	9.0 %	8.0 ppm,d
9/Oct/96 12:41: 8	10.9 %	9.0 %	7.7 ppm,d
9/Oct/96 12:41:37	11.0 %	8.9 %	7.7 ppm,d
9/Oct/96 12:42: 8	10.9 %	9.0 %	7.7 ppm,d
9/Oct/96 12:42:38	10.8 %	9.2 %	8.0 ppm,d
9/Oct/96 12:43: 8	10.8 %	9.2 %	8.1 ppm,d
9/Oct/96 12:43:38	10.7 %	9.1 %	8.0 ppm,d
9/Oct/96 12:44: 8	10.8 %	9.1 %	8.1 ppm,d
9/Oct/96 12:44:38	10.8 %	9.0 %	7.8 ppm,d
9/Oct/96 12:45: 8	10.6 %	9.2 %	7.7 ppm,d
9/Oct/96 12:45:38	10.7 %	9.1 %	7.9 ppm,d
9/Oct/96 12:46: 8	10.6 %	9.4 %	8.7 ppm,d
9/Oct/96 12:46:38	10.7 %	9.1 %	7.8 ppm,d
9/Oct/96 12:47: 8	10.7 %	9.2 %	8.2 ppm,d
9/Oct/96 12:47:38	10.5 %	9.4 %	8.1 ppm,d
9/Oct/96 12:48: 8	10.5 %	9.3 %	8.2 ppm,d
9/Oct/96 12:48:38	10.4 %	9.4 %	7.8 ppm,d
9/Oct/96 12:49: 8	10.6 %	9.2 %	7.8 ppm,d
9/Oct/96 12:49:38	10.8 %	9.1 %	7.9 ppm,d
9/Oct/96 12:50: 7	10.6 %	9.3 %	8.3 ppm,d
9/Oct/96 12:50:38	10.5 %	9.4 %	8.3 ppm,d
9/Oct/96 12:51: 8	10.8 %	9.1 %	7.6 ppm,d
9/Oct/96 12:51:38	10.8 %	9.2 %	7.8 ppm,d
9/Oct/96 12:52: 8	10.6 %	9.2 %	7.9 ppm,d

082

9/Oct/96 12:52:38	10.6 %	9.4 %	8.4 ppm,d
9/Oct/96 12:53: 8	10.5 %	9.3 %	8.1 ppm,d
9/Oct/96 12:53:38	10.7 %	9.2 %	8.1 ppm,d
9/Oct/96 12:54: 7	10.5 %	9.4 %	8.5 ppm,d
9/Oct/96 12:54:38	10.6 %	9.3 %	8.5 ppm,d
9/Oct/96 12:55: 8	10.5 %	9.3 %	8.2 ppm,d
9/Oct/96 12:55:38	10.7 %	9.1 %	8.3 ppm,d
9/Oct/96 12:56: 7	10.8 %	9.1 %	7.8 ppm,d
9/Oct/96 12:56:38	10.6 %	9.2 %	7.9 ppm,d
9/Oct/96 12:57: 7	10.6 %	9.1 %	7.9 ppm,d
9/Oct/96 12:57:38	10.7 %	9.1 %	8.0 ppm,d
9/Oct/96 12:58: 8	10.8 %	9.1 %	8.1 ppm,d
9/Oct/96 12:58:38	10.7 %	9.1 %	8.2 ppm,d
9/Oct/96 12:59: 7	10.9 %	9.0 %	8.0 ppm,d
9/Oct/96 12:59:38	10.7 %	9.2 %	8.3 ppm,d
9/Oct/96 13: 0: 8	10.4 %	9.4 %	8.3 ppm,d
9/Oct/96 13: 0:38	10.3 %	9.6 %	8.7 ppm,d
9/Oct/96 13: 1: 8	10.7 %	9.1 %	7.7 ppm,d
9/Oct/96 13: 1:38	10.7 %	9.1 %	7.7 ppm,d
9/Oct/96 13: 2: 8	10.8 %	9.3 %	7.8 ppm,d
9/Oct/96 13: 2:38	10.8 %	9.1 %	7.6 ppm,d
9/Oct/96 13: 3: 8	10.7 %	9.1 %	7.9 ppm,d
9/Oct/96 13: 3:38	10.7 %	9.2 %	7.8 ppm,d
9/Oct/96 13: 4: 8	10.8 %	9.0 %	7.6 ppm,d
9/Oct/96 13: 4:38	10.6 %	9.3 %	8.0 ppm,d
9/Oct/96 13: 5: 8	10.6 %	9.2 %	7.9 ppm,d
9/Oct/96 13: 5:38	10.5 %	9.3 %	8.1 ppm,d
9/Oct/96 13: 6: 7	10.6 %	9.3 %	8.2 ppm,d
9/Oct/96 13: 6:38	10.9 %	8.8 %	8.0 ppm,d
9/Oct/96 13: 7: 8	10.5 %	9.3 %	8.0 ppm,d
9/Oct/96 13: 7:38	10.8 %	9.0 %	7.7 ppm,d
9/Oct/96 13: 8: 8	10.8 %	9.1 %	8.2 ppm,d
9/Oct/96 13: 8:38	10.8 %	9.1 %	8.2 ppm,d
9/Oct/96 13: 9: 8	10.6 %	9.3 %	8.0 ppm,d
9/Oct/96 13: 9:38	10.9 %	9.1 %	7.8 ppm,d
9/Oct/96 13:10: 8	10.8 %	9.1 %	8.1 ppm,d
9/Oct/96 13:10:38	10.8 %	9.1 %	7.8 ppm,d
9/Oct/96 13:11: 8	10.7 %	9.1 %	7.7 ppm,d
9/Oct/96 13:11:38	10.6 %	9.3 %	8.0 ppm,d
9/Oct/96 13:12: 8	10.8 %	8.9 %	7.4 ppm,d
9/Oct/96 13:12:38	10.8 %	9.0 %	8.0 ppm,d
9/Oct/96 13:13: 8	10.6 %	9.3 %	7.7 ppm,d
9/Oct/96 13:13:37	10.7 %	9.1 %	7.9 ppm,d
9/Oct/96 13:14: 8	10.6 %	9.2 %	7.5 ppm,d
9/Oct/96 13:14:38	10.6 %	9.3 %	7.8 ppm,d
9/Oct/96 13:15: 7	10.7 %	9.2 %	7.8 ppm,d
9/Oct/96 13:15:37	10.8 %	9.1 %	7.6 ppm,d
9/Oct/96 13:16: 8	10.8 %	9.1 %	8.1 ppm,d
9/Oct/96 13:16:38	10.4 %	9.4 %	8.0 ppm,d
9/Oct/96 13:17: 8	10.5 %	9.4 %	8.1 ppm,d
9/Oct/96 13:17:38	10.6 %	9.2 %	7.7 ppm,d
9/Oct/96 13:18: 8	10.5 %	9.3 %	8.1 ppm,d
9/Oct/96 13:18:38	10.9 %	9.0 %	8.4 ppm,d
9/Oct/96 13:19: 7	10.6 %	9.2 %	8.1 ppm,d
9/Oct/96 13:19:38	10.4 %	9.4 %	8.6 ppm,d

Client Name:	LFG Specialties
Job Site:	Bethlehem Landfill
Emission Source(s):	Enclosed Ground Flare Outlet
AirRECON Project Number:	AR5-6922
Run Number:	Two (2)

	O ₂	CO ₂	NO _x
Raw Test Averages:	10.683 %	9.184 %	8.077 ppm,d

Client Name:	LFG Specialties
Location:	Bethlehem Landfill
Emission Source:	Enclosed Ground Flare Outlet
AIRRECON Project Number:	AR5-6922
Run Number:	Three (3)

083


Date and Time	O ₂	CO ₂	NO _x
9/Oct/96 14:05:05	10.3 %	9.5 %	8.8 ppm,d
9/Oct/96 14:05:35	10.4 %	9.3 %	8.6 ppm,d
9/Oct/96 14:06:05	10.4 %	9.4 %	8.6 ppm,d
9/Oct/96 14:06:35	10.3 %	9.5 %	8.9 ppm,d
9/Oct/96 14:07:05	10.5 %	9.3 %	8.7 ppm,d
9/Oct/96 14:07:35	10.5 %	9.4 %	8.8 ppm,d
9/Oct/96 14:08:05	10.5 %	9.3 %	8.7 ppm,d
9/Oct/96 14:08:35	10.5 %	9.3 %	8.7 ppm,d
9/Oct/96 14:09:05	10.8 %	9.1 %	8.4 ppm,d
9/Oct/96 14:09:35	10.6 %	9.3 %	8.8 ppm,d
9/Oct/96 14:10:05	10.6 %	9.2 %	8.8 ppm,d
9/Oct/96 14:10:35	10.3 %	9.4 %	9.0 ppm,d
9/Oct/96 14:11:05	10.5 %	9.3 %	8.6 ppm,d
9/Oct/96 14:11:35	10.5 %	9.3 %	8.8 ppm,d
9/Oct/96 14:12:05	10.7 %	9.1 %	8.6 ppm,d
9/Oct/96 14:12:35	10.7 %	9.2 %	8.3 ppm,d
9/Oct/96 14:13:05	10.6 %	9.2 %	8.3 ppm,d
9/Oct/96 14:13:35	10.8 %	9.1 %	8.2 ppm,d
9/Oct/96 14:14:05	10.6 %	9.3 %	8.5 ppm,d
9/Oct/96 14:14:35	10.6 %	9.2 %	8.5 ppm,d
9/Oct/96 14:15:05	10.2 %	9.5 %	9.1 ppm,d
9/Oct/96 14:15:35	10.6 %	9.2 %	8.6 ppm,d
9/Oct/96 14:16:05	10.5 %	9.3 %	8.6 ppm,d
9/Oct/96 14:16:35	10.7 %	9.2 %	8.5 ppm,d
9/Oct/96 14:17:05	10.7 %	9.1 %	8.2 ppm,d
9/Oct/96 14:17:35	10.6 %	9.3 %	8.3 ppm,d
9/Oct/96 14:18:05	10.8 %	9.1 %	8.0 ppm,d
9/Oct/96 14:18:35	10.8 %	9.1 %	8.7 ppm,d
9/Oct/96 14:19:05	10.6 %	9.3 %	8.3 ppm,d
9/Oct/96 14:19:35	10.7 %	9.2 %	8.1 ppm,d
9/Oct/96 14:20:05	10.6 %	9.2 %	8.7 ppm,d
9/Oct/96 14:20:35	10.4 %	9.5 %	8.6 ppm,d
9/Oct/96 14:21:05	10.5 %	9.3 %	8.2 ppm,d
9/Oct/96 14:21:35	10.6 %	9.2 %	8.2 ppm,d
9/Oct/96 14:22:05	10.4 %	9.4 %	8.6 ppm,d
9/Oct/96 14:22:35	10.6 %	9.3 %	8.7 ppm,d
9/Oct/96 14:23:05	10.7 %	9.1 %	8.2 ppm,d
9/Oct/96 14:23:35	10.5 %	9.3 %	8.2 ppm,d
9/Oct/96 14:24:05	10.5 %	9.3 %	8.3 ppm,d
9/Oct/96 14:24:35	10.6 %	9.4 %	8.8 ppm,d
9/Oct/96 14:25:05	10.6 %	9.2 %	8.2 ppm,d
9/Oct/96 14:25:35	10.5 %	9.2 %	8.0 ppm,d
9/Oct/96 14:26:05	10.4 %	9.3 %	8.2 ppm,d
9/Oct/96 14:26:35	10.9 %	9.1 %	8.3 ppm,d
9/Oct/96 14:27:05	10.6 %	9.2 %	7.8 ppm,d
9/Oct/96 14:27:35	11.0 %	9.0 %	8.3 ppm,d
9/Oct/96 14:28:05	10.5 %	9.3 %	8.5 ppm,d
9/Oct/96 14:28:35	10.4 %	9.4 %	8.1 ppm,d
9/Oct/96 14:29:05	10.7 %	9.2 %	7.9 ppm,d
9/Oct/96 14:29:35	10.6 %	9.3 %	8.1 ppm,d
9/Oct/96 14:30:05	10.7 %	9.2 %	8.2 ppm,d
9/Oct/96 14:30:35	10.5 %	9.3 %	7.9 ppm,d
9/Oct/96 14:31:05	10.5 %	9.3 %	8.1 ppm,d
9/Oct/96 14:31:35	10.8 %	9.1 %	8.1 ppm,d
9/Oct/96 14:32:05	10.6 %	9.2 %	7.7 ppm,d
9/Oct/96 14:32:35	10.5 %	9.4 %	8.3 ppm,d
9/Oct/96 14:33:05	10.6 %	9.3 %	7.8 ppm,d
9/Oct/96 14:33:35	10.4 %	9.4 %	8.0 ppm,d
9/Oct/96 14:34:05	10.6 %	9.2 %	8.0 ppm,d
9/Oct/96 14:34:35	10.6 %	9.3 %	8.6 ppm,d
9/Oct/96 14:43:40	10.5 %	9.3 %	8.3 ppm,d
9/Oct/96 14:44:11	10.4 %	9.5 %	8.3 ppm,d
9/Oct/96 14:44:41	10.4 %	9.3 %	7.9 ppm,d
9/Oct/96 14:45:11	10.8 %	9.1 %	8.4 ppm,d
9/Oct/96 14:45:41	10.4 %	9.3 %	8.1 ppm,d

084

9/Oct/96 14:46:11	10.4 %	9.4 %	8.4 ppm,d
9/Oct/96 14:46:41	10.2 %	9.5 %	8.3 ppm,d
9/Oct/96 14:47:11	10.5 %	9.3 %	8.5 ppm,d
9/Oct/96 14:47:41	10.4 %	9.4 %	8.3 ppm,d
9/Oct/96 14:48:11	10.5 %	9.4 %	7.9 ppm,d
9/Oct/96 14:48:41	10.5 %	9.4 %	8.3 ppm,d
9/Oct/96 14:49:11	10.7 %	9.0 %	7.8 ppm,d
9/Oct/96 14:49:40	10.7 %	9.2 %	8.2 ppm,d
9/Oct/96 14:50:11	10.7 %	9.3 %	8.7 ppm,d
9/Oct/96 14:50:41	10.9 %	9.0 %	7.9 ppm,d
9/Oct/96 14:51:11	10.6 %	9.2 %	7.9 ppm,d
9/Oct/96 14:51:41	10.5 %	9.3 %	8.2 ppm,d
9/Oct/96 14:52:11	10.6 %	9.2 %	8.3 ppm,d
9/Oct/96 14:52:41	10.5 %	9.4 %	8.2 ppm,d
9/Oct/96 14:53:10	10.7 %	9.1 %	7.9 ppm,d
9/Oct/96 14:53:41	10.6 %	9.2 %	8.0 ppm,d
9/Oct/96 14:54:11	10.6 %	9.3 %	8.2 ppm,d
9/Oct/96 14:54:41	10.8 %	9.0 %	8.0 ppm,d
9/Oct/96 14:55:11	11.0 %	9.0 %	8.2 ppm,d
9/Oct/96 14:55:41	10.7 %	9.2 %	8.4 ppm,d
9/Oct/96 14:56:11	10.6 %	9.2 %	8.1 ppm,d
9/Oct/96 14:56:41	10.7 %	9.2 %	8.2 ppm,d
9/Oct/96 14:57:11	10.5 %	9.2 %	8.4 ppm,d
9/Oct/96 14:57:41	10.7 %	9.2 %	7.7 ppm,d
9/Oct/96 14:58:11	10.6 %	9.2 %	8.2 ppm,d
9/Oct/96 14:58:40	10.7 %	9.1 %	8.2 ppm,d
9/Oct/96 14:59:11	10.6 %	9.3 %	8.6 ppm,d
9/Oct/96 14:59:40	10.6 %	9.2 %	8.4 ppm,d
9/Oct/96 15:0:11	10.5 %	9.3 %	8.2 ppm,d
9/Oct/96 15:0:41	10.4 %	9.3 %	8.2 ppm,d
9/Oct/96 15:1:10	10.3 %	9.5 %	8.4 ppm,d
9/Oct/96 15:1:41	10.2 %	9.5 %	8.8 ppm,d
9/Oct/96 15:2:11	10.2 %	9.5 %	8.8 ppm,d
9/Oct/96 15:2:41	10.4 %	9.4 %	8.6 ppm,d
9/Oct/96 15:3:11	10.6 %	9.3 %	8.0 ppm,d
9/Oct/96 15:3:41	10.3 %	9.5 %	8.8 ppm,d
9/Oct/96 15:4:10	10.3 %	9.5 %	9.0 ppm,d
9/Oct/96 15:4:41	10.5 %	9.2 %	8.2 ppm,d
9/Oct/96 15:5:11	10.6 %	9.2 %	7.9 ppm,d
9/Oct/96 15:5:41	10.6 %	9.3 %	8.0 ppm,d
9/Oct/96 15:6:11	10.5 %	9.3 %	7.7 ppm,d
9/Oct/96 15:6:40	10.6 %	9.3 %	8.5 ppm,d
9/Oct/96 15:7:11	10.5 %	9.2 %	7.5 ppm,d
9/Oct/96 15:7:41	10.7 %	9.2 %	7.7 ppm,d
9/Oct/96 15:8:11	10.7 %	9.1 %	7.5 ppm,d
9/Oct/96 15:8:41	10.9 %	8.9 %	7.8 ppm,d
9/Oct/96 15:9:10	10.9 %	9.0 %	7.8 ppm,d
9/Oct/96 15:9:40	10.6 %	9.2 %	7.5 ppm,d
9/Oct/96 15:10:11	10.7 %	9.2 %	7.9 ppm,d
9/Oct/96 15:10:40	10.7 %	9.2 %	7.8 ppm,d
9/Oct/96 15:11:10	10.6 %	9.3 %	7.9 ppm,d
9/Oct/96 15:11:41	10.6 %	9.3 %	7.8 ppm,d
9/Oct/96 15:12:11	10.6 %	9.2 %	7.9 ppm,d
9/Oct/96 15:12:41	10.5 %	9.2 %	8.1 ppm,d
9/Oct/96 15:13:11	10.5 %	9.2 %	7.6 ppm,d


Client Name:	LFG Specialties
Location:	Bethlehem Landfill
Emission Source(s):	Enclosed Ground Flare Outlet
AIRRECON Project Number:	AR5-6922
Run Number:	Three (3)

	O2	CO2	NOx
Raw Test Averages:	10.570 %	9.259 %	8.266 ppm,d



APPENDIX IV

FIELD DATA SHEETS



CEM Calibration Summaries

Project Name: LF6 Specialties - Bethlehem PA

Project No.: AK5-6722

Date: 10/8 - 10/9/96

Operator: John G. Sasser

Trailer No.: Two

AIRRECON, Div. of RECON ENVIRONMENTAL CORP.

6 Johnson Drive

P.O. Box 130

Harfian, NJ 08869

Office: (608) 526-1000

Fax: (608) 526-7886

Run Start Time (hrs):	1006	1220	1405
Run Stop Time (hrs):	1106	1320	1505

Gas Type	Rack Pos.	Standard Concentration (Units)	Starting Cylinder Pressure (psi)	Rack Calibration Response	Post Cal. Bias Response	Run 1 Cal. Drift Response	Run 2 Cal. Drift Response	Run 3 Cal. Drift Response	Run 4 Cal. Drift Response	Run 5 Cal. Drift Response	Ending Cylinder Pressure (psi)
O ₂	1	Zero		0.0	0.1	0.1	0.1	0.1			
	2	11.0	1600	11.0	11.0	11.0	11.0	11.0			
	3	20.92	400	20.7							
	4	Zero		0.0	0.0	0.0	0.0	0.0			
CO ₂	1	10.0	900	10.0	9.9	9.9	9.9	9.8			
	2	18.21	800	18.3							
	3	Zero		0.1	0.7	-0.4	-0.2	-0.1			
	4	54.8	1050	53.4	52.5	53.3	54.5	55.6			
NO _x	1	11	506	11.2							
	2	171.2	1350	173.7							
	3	Zero									
	4	21.3	1100	117.74							
Inlet CH ₄	1	51.3	1100	286.99							
	2	88.7	1350	518.36							
	3	Zero									
	4	2617	1250	1470.79							
0-10000	1	4916	550	3230.57							
	2	9175	900	5076.31							
	3	Zero									
	4										
GC						Avg. Area Counts					
						LF61	LF62	LF63	+ LF64		

NOTE: Remember to mark cylinder pressures on the tank and worksheet.

AirRecon
Division of
RECON SYSTEMS, Inc.

5 Johnson Drive, P.O. Box 130
Raritan, NJ 08869-0130
(908) 526-1000
FAX (908) 526-7887

Connecticut (203) 293-1212
Massachusetts (508) 752-4217
New Hampshire (603) 431-7500
Pennsylvania (215) 433-5511

087

VELOCITY FIELD DATA BOOKS

10/9/96


ARS-6922

Inlet

24
24
24

AIR RECON/DIV.
OF RECON SYS. INC.
5 Johnson Drive P.O. Box 130
RARITAN, NEW JERSEY 08869-0130
(908) 526-1000 FAX (908) 526-7886

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE 088
SCALE _____



PROBE MARKINGS - CIRCULAR STACK

089

STACK ID @ PORT 12" INCHES

PORT EXTENSION 15" INCHES

RIGHT-MOST COLUMN IS THE DISTANCE FROM THE PROBE TIP TO OUTSIDE OF PORT EXTENSION

EPA DISTANCE "A" 25 DIAMETERS

EPA DISTANCE "B" 9 DIAMETERS

TRAVERSE POINT NUMBER	LENGTH FACTOR FROM EPA #1, TABLE 1-2K	PRODUCT OF LENGTH FACTOR TIMES STACK INSIDE DIAMETER (INCHES) L X (STACK ID)	SUM OF PREVIOUS COLUMN AND PORT EXTENSION (INCHES) L X (STACK ID) + PORT EXTENSION	CONVERT PREVIOUS COLUMN TO INCHES AND COMMON FRACTIONS
1	4.4	0.53	2.03	2 1/4"
2	14.6	1.75	3.25	3 1/4"
3	29.6	3.55	5.05	5"
4	70.4	8.45	9.95	10"
5	85.4	10.25	11.75	11 3/4"
6	95.6	11.47	12.97	13"
7				
8				
9				
10				
11				
12				

CIRCULAR STACK CROSS SECTIONAL AREA (CSA) = $\frac{0.785}{144} (ID^2) = \frac{10^2}{183.35} = 0.785 \text{ FT}^2$

PROBE MARKINGS - RECTANGULAR STACK

STACK CROSS SECTION DIMENSIONS (L) X (W) INCHES PORT EXTENSIONS INCHES

TO DETERMINE UPSTREAM/DOWNSTREAM DISTURBANCES, THE EQUIVALENT DIAMETER IS DETERMINED USING THE FOLLOWING EQUATION $d_e = \frac{2 \text{ LW}}{(L + W)}$ $d_e =$

EPA DISTANCE "A" DIAMETERS

EPA DISTANCE "B" DIAMETERS

TRAVERSE POINT NUMBER	CENTROID OF EACH EQUAL AREA (INCHES)	SUM OF PREVIOUS COLUMN AND PORT EXTENSION
1		
2		
3		
4		
5		
6		
7		

RECTANGULAR STACK CROSS SECTIONAL AREA = $\frac{L \times W}{144} = \frac{(\text{ " }) \times (\text{ " })}{144} = \text{ } \text{ FT}^2$

AIRRECON
RARITAN, NJ

MOISTURE DETERMINATION

092

SAMPLE LOCATION Inlet RUN NO. 1 DATE 10/9/96

	GRAMS	GRAMS
IMPINGER 1	FINAL WEIGHT <u>633.4</u> INITIAL WEIGHT <u>633.2</u> INCREASE	IMPINGER 1 <u>0.2</u>
IMPINGER 2	FINAL WEIGHT <u>596.5</u> INITIAL WEIGHT <u>590.9</u> INCREASE	IMPINGER 2 <u>5.6</u>
IMPINGER 3	FINAL WEIGHT <u>492.2</u> INITIAL WEIGHT <u>490.8</u> INCREASE	IMPINGER 3 <u>1.4</u>
SILICA GEL	FINAL WEIGHT <u>766.8</u> INITIAL WEIGHT <u>757.2</u> INCREASE	SILICA GEL <u>9.6</u>
TOTAL MASS OF WATER CAUGHT		<u>16.8</u> ✓ GRAMS

CALCULATIONS

VELOCITY (ACTUAL) IN STACK

$$= 85.48 (C_p) \sqrt{\frac{T_s + 460}{P_s (MW)}} \sqrt{\Delta P}$$

$$= 85.48 () \sqrt{\frac{()}{() ()}} \sqrt{\Delta P}$$

$$V_s = () \sqrt{\Delta P} = () () \sqrt{\Delta P}$$

$$V_s = () \sqrt{\Delta P} = () () = \text{FT/SEC}$$

$$ACFM = (V_s) (CSA) (60) = () () (60) =$$

$$\text{VELOCITY @ Std } V_s - \text{std} = V_s (17.71) \frac{P_s}{T_s + 460} = \frac{() (17.71) ()}{()} = \text{FT/SEC}$$

$$SCFM = (V_s - \text{std}) (CSA) (60) = () () (60) =$$

$$\text{DSCFM} = \frac{100 - \%H_2O}{100} (SCFM) = () () =$$

MOISTURE DETERMINATION

095

SAMPLE LOCATION Inlet RUN NO. 2 DATE 10/9/76

	GRAMS	GRAMS
IMPINGER 1	FINAL WEIGHT <u>574.5</u> INITIAL WEIGHT <u>572.0</u> INCREASE	IMPINGER 1 <u>2.5</u>
IMPINGER 2	FINAL WEIGHT <u>535.2</u> INITIAL WEIGHT <u>534.2</u> INCREASE	IMPINGER 2 <u>1.0</u>
IMPINGER 3	FINAL WEIGHT _____ INITIAL WEIGHT _____ INCREASE	IMPINGER 3 _____
SILICA GEL	FINAL WEIGHT <u>705.6</u> INITIAL WEIGHT <u>695.5</u> INCREASE	SILICA GEL <u>10.1</u>
TOTAL MASS OF WATER CAUGHT <u>13.6</u>		GRAMS

CALCULATIONS

VELOCITY (ACTUAL) IN STACK

$$= 85.48 (C_p) \sqrt{\frac{T_s + 460}{P_s (MW)}} \sqrt{\Delta P}$$

$$= 85.48 () \sqrt{\frac{()}{() ()}} \sqrt{\Delta P}$$

$$V_s = () \sqrt{\Delta P} = () () \sqrt{\Delta P}$$

$$V_s = () \sqrt{\Delta P} = () () = \text{FT/SEC}$$

$$ACFM = (V_s) (CSA) (60) = () () (60) =$$

$$\text{VELOCITY at Std } V_s - \text{std} = V_s (17.71) \frac{P_s}{T_s + 460} = () (17.71) () = \text{FT/SEC}$$

$$SCFM = (V_s - \text{std}) (CSA) (60) = () () (60) =$$

$$DSCFM = \frac{100 - \%H_2O}{100} (SCFM) = () () =$$

DATE: 10/9/96

BAROMETRIC PRESSURE: 29.72 "Hg

STATIC PRESSURE PRE-/POST-TRAVERSE: +1.8, +1.8 "H₂O

SAMPLE PUMP ID _____ THERMOCOUPLE #: _____

AIRRECON
RABITAN, NJ

HYDROCARBON SAMPLING DATA

SAMPLE LOCATION

Inlet

RUN NO.

3

DATE

10/9/96

ICE DOWN IMPINGERS

PUMP CALIBRATION FLOW RATE

CALIBRATION INSTRUMENT

FLOW RATE
LITERS/MINROTAMETER
SETTINGSOAP FILM BURET
DRY GAS METER
OTHER

097

TIME	°F GAS METER TEMPERATURE	METER VOLUME CORRECTION
CORRECTING ROTAMETER VOLUME TO DRY STANDARD CONDITIONS		
EQUATION: $V_{STD} = V_m \times \frac{P_m}{T_m} \times \frac{T_{STD}}{P_{STD}}$		
WHERE:		
V_m	=	SAMPLE RATE OF ROTAMETER (L/m)
T_{STD}	=	70°F + 460°F = 530°F
P_{STD}	=	29.92" HG
P_m	=	BAROMETRIC PRESSURE DURING SAMPLING ("HG)
T_m	=	AVG. TEMPERATURE OF GAS STREAM (+460°F)
V_{STD}	=	$\frac{V_m \times (530)}{(P_m \times (29.92))}$
CFH	=	$V_{STD} (L/MIN) (3.53 \times 10^{-2} CF/L) (60 MIN/1 HR) =$ $() (3.53 \times 10^{-2}) (60)$
	=	CFH

PRE-LEAK CHECK

POST-LEAK CHECK

ICE DOWN IMPINGERS

MOISTURE SAMPLING DATA

TIME	METER READING	INLET GAS METER TEMPERATURE, °F	OUTLET GAS METER TEMPERATURE, °F	VACUUM "Hg
1405	830.620	82	80	3
10		85	81	3
15		89	81	3
20		89	81	3
25		92	82	3
30		92	84	3
35	stopped 848.422	92	84	3
45	start 848.422	85	82	3
50		87	82	3
55		87	81	3
1500		88	81	3
05		90	81	3
10		93	83	3
1515	867.040			

PRE-LEAK CHECK

POST-LEAK CHECK

DELTA H/SETTING

MOISTURE DETERMINATION

SAMPLE LOCATION Inlet RUN NO. 3 DATE 10/9/96

	GRAMS		GRAMS
IMPINGER 1	FINAL WEIGHT <u>638.2</u> INITIAL WEIGHT <u>633.4</u> INCREASE	IMPINGER 1	<u>4.8</u>
IMPINGER 2	FINAL WEIGHT <u>597.9</u> INITIAL WEIGHT <u>596.5</u> INCREASE	IMPINGER 2	<u>1.4</u>
IMPINGER 3	FINAL WEIGHT <u>492.8</u> INITIAL WEIGHT <u>492.2</u> INCREASE	IMPINGER 3	<u>0.6</u>
SILICA GEL	FINAL WEIGHT <u>713.2</u> INITIAL WEIGHT <u>705.6</u> INCREASE	SILICA GEL	<u>7.6</u>

TOTAL MASS OF WATER CAUGHT 14.4 ✓ GRAMS

CALCULATIONS

VELOCITY (ACTUAL) IN STACK

$$= 85.48 (C_p) \sqrt{\frac{T_c + 460}{P_s (MW)}} \sqrt{\Delta P}$$

$$= 85.48 () \sqrt{\frac{()}{() ()}} \sqrt{\Delta P}$$

$$V_s = () \sqrt{\Delta P} = () () \sqrt{\Delta P}$$

$$V_s = () \sqrt{\Delta P} = () () = \text{FT/SEC}$$

$$ACFM = (V_s) (CSA) (60) = () () (60) =$$

$$\text{VELOCITY @ Std. } V_s - \text{std} = V_s (17.71) \frac{P_c}{T_s + 460} = \frac{() (17.71) ()}{()} = \text{FT/SEC}$$

$$SCFM = (V_s - \text{std}) (CSA) (60) = () () (60) =$$

$$\text{DSCFM} = \frac{100 - \%H_2O}{100} (SCFM) = () () =$$

AirRecon
Division of
RECON SYSTEMS, Inc.

5 Johnson Drive, P.O. Box 130
Raritan, NJ 08869-0130
(908) 526-1000
FAX (908) 526-7887

Connecticut (203) 293-1212
Massachusetts (508) 752-4217
New Hampshire (603) 431-7500
Pennsylvania (215) 433-5511

099

VELOCITY FIELD DATA BOOKS


10/9/96

AR5-6922

Outlet

AIR RECON/DIV.
OF RECON SYS. INC.
5 Johnson Drive P.O. Box 130
RARITAN, NEW JERSEY 08869-0130
(908) 526-1000 FAX (908) 526-7886

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE 100
CHECKED BY _____ DATE _____
SCALE _____



PROBE MARKINGS - CIRCULAR STACK

STACK ID @ PORT 8 1/2" INCHES

PORT EXTENSION 0" INCHES

RIGHT-MOST COLUMN IS THE DISTANCE FROM THE PROBE TIP TO OUTSIDE OF PORT EXTENSION

EPA DISTANCE "A" 0.5 DIAMETERS

EPA DISTANCE "B" 4.4 DIAMETERS

TRAVERSE POINT NUMBER	LENGTH FACTOR FROM EPA #1, TABLE 1-2C	PRODUCT OF LENGTH FACTOR TIMES STACK INSIDE DIAMETER (INCHES) L X (STACK ID)	SUM OF PREVIOUS COLUMN AND PORT EXTENSION (INCHES) L X (STACK ID) + PORT EXTENSION	CONVERT PREVIOUS COLUMN TO INCHES AND COMMON FRACTIONS
1	3.2	2.69		2 3/4
2	10.5	8.82		8 3/4
3	19.4	16.30		16 1/4
4	32.3	27.13		27 1/4
5	67.7	56.87		56 3/4
6	80.6	67.70		67 3/4
7	89.5	75.18		75 1/4
8	96.8	81.31		81 1/4
9				
10				
11				
12				

$$\text{CIRCULAR STACK CROSS SECTIONAL AREA (CSA)} = \frac{0.785}{144} (\text{ID}^2) = \frac{\text{ID}^2}{183.35} = \frac{38.484}{183.35} \text{ FT}^2$$

PROBE MARKINGS - RECTANGULAR STACK

STACK CROSS SECTION DIMENSIONS (L) X (W) INCHES PORT EXTENSIONS INCHES

TO DETERMINE UPSTREAM/DOWNSTREAM DISTURBANCES, THE EQUIVALENT DIAMETER IS DETERMINED USING THE FOLLOWING EQUATION $d_e = \frac{2 \cdot L \cdot W}{(L + W)}$ $d_e =$

EPA DISTANCE "A" DIAMETERS

EPA DISTANCE "B" DIAMETERS

TRAVERSE POINT NUMBER	CENTROID OF EACH EQUAL AREA (INCHES)	SUM OF PREVIOUS COLUMN AND PORT EXTENSION
1		
2		
3		
4		
5		
6		
7		

$$\text{RECTANGULAR STACK CROSS SECTIONAL AREA} = \frac{L \cdot W}{144} = \frac{(\text{---}) \cdot (\text{---})}{144} = \text{---} \text{ FT}^2$$

MOISTURE DETERMINATION

105

SAMPLE LOCATION Outlet RUN NO. 1 DATE 10/9/98

	GRAMS		GRAMS
IMPINGER 1	FINAL WEIGHT <u>562.9</u> INITIAL WEIGHT <u>535.4</u> INCREASE	IMPINGER 1	<u>27.5</u>
IMPINGER 2	FINAL WEIGHT <u>573.2</u> INITIAL WEIGHT <u>571.3</u> INCREASE	IMPINGER 2	<u>1.9</u>
IMPINGER 3	FINAL WEIGHT <u>503.2</u> INITIAL WEIGHT <u>502.3</u> INCREASE	IMPINGER 3	<u>0.9</u>
SILICA GEL	FINAL WEIGHT <u>708.5</u> INITIAL WEIGHT <u>700.0</u> INCREASE	SILICA GEL	<u>8.5</u>
		TOTAL MASS OF WATER CAUGHT	<u>38.8</u> ✓

CALCULATIONS

VELOCITY (ACTUAL) IN STACK

$$= 85.48 (C_p) \sqrt{\frac{T_s + 460}{P_s (MW)}} \sqrt{\Delta P}$$

$$= 85.48 () \sqrt{\frac{()}{() ()}} \sqrt{\Delta P}$$

$$V_s = () \sqrt{\Delta P} = () () \sqrt{\Delta P}$$

$$V_s = () \sqrt{\Delta P} = () () = \text{FT/SEC}$$

$$ACFM = (V_s) (CSA) (60) = () () (60) =$$

$$\text{VELOCITY @ Std. } V_s - \text{std} = V_s (17.71) \frac{P_s}{T_s + 460} = \frac{() (17.71) ()}{()} = \text{FT/SEC}$$

$$SCFM = (V_s - \text{std}) (CSA) (60) = () () (60) =$$

$$DSCFM = \frac{100 - \%H_2O}{100} (SCFM) = () () =$$

MOISTURE DETERMINATION

108

SAMPLE LOCATION

Outlet

RUN NO.

2

DATE

10/9/96

GRAMS

IMPINGER 1

FINAL WEIGHT

623.8

INITIAL WEIGHT

571.4

INCREASE

IMPINGER 1

52.4

IMPINGER 2

FINAL WEIGHT

381.6

INITIAL WEIGHT

579.0

INCREASE

IMPINGER 2

2.6

IMPINGER 3

FINAL WEIGHT

475.9

INITIAL WEIGHT

474.8

INCREASE

IMPINGER 3

1.1

SILICA GEL

FINAL WEIGHT

822.3

INITIAL WEIGHT

814.7

INCREASE

SILICA GEL

7.6

TOTAL MASS OF WATER CAUGHT

63.7

GRAMS

CALCULATIONS

VELOCITY

(ACTUAL)

= 85.48 (C_p)

$$\sqrt{\frac{T_s + 460}{P_s (MW)}}$$

√ DELTA P

IN STACK

= 85.48 (

$$\sqrt{\frac{()}{() ()}}$$

√ DELTA P

V_s

= (

$$\sqrt{\frac{()}{()}}$$

√ DELTA P

= (

(

$$\sqrt{\frac{()}{()}}$$

√ DELTA P

V_s

= (

$$\sqrt{\frac{()}{()}}$$

√ DELTA P

= (

(

$$= \frac{()}{()} \text{ FT/SEC}$$

ACFM = (V_s) (CSA) (60) = (

(

(

(60) =

VELOCITY @ Std. V_s - std = V_s (17.71)

$$\frac{P_s}{T_s + 460} = \frac{() (17.71) ()}{()}$$

=

$$\frac{() (17.71) ()}{()} =$$

FT/SEC

SCFM = (V_s - std) (CSA) (60) = (

(

(

(60) =

DSCFM = $\frac{100 - \%H_2O}{100}$ (SCFM) = (

(

(

) =

HYDROCARBON SAMPLING DATA
 SAMPLE LOCATION Outlet RUN NO. 3 DATE 10/9/98
 ICE DOWN IMPINGERS

PUMP CALIBRATION FLOW RATE		CALIBRATION INSTRUMENT	
FLOW RATE LITERS/MIN	ROTAMETER SETTING	☐ SOAP FILM BURET ☐ DRY GAS METER ☐ OTHER _____	

110

TIME	°F GAS METER TEMPERATURE	METER VOLUME CORRECTION
CORRECTING ROTAMETER VOLUME TO DRY STANDARD CONDITIONS EQUATION: $V_{STD} = V_m \times \frac{P_m}{T_m} \times \frac{T_{STD}}{P_{STD}}$ WHERE: V_m = SAMPLE RATE OF ROTAMETER (L/m) T_{STD} = $70^{\circ}F + 460^{\circ}F = 530^{\circ}F$ P_{STD} = 29.92" HG P_m = BAROMETRIC PRESSURE DURING SAMPLING ("HG) T_m = AVG. TEMPERATURE OF GAS STREAM ($\sim 460^{\circ}F$) V_{STD} = $\frac{V_m \times (530)}{(29.92)}$ CFH = $\frac{V_{STD} (L/MIN) (3.53 \times 10^{-2} CF/L) (60 MIN/1 HR)}{(3.53 \times 10^{-2}) (60)}$ = CFH		
PRE-LEAK CHECK _____ POST-LEAK CHECK _____ ☒ ICE DOWN IMPINGERS		

MOISTURE SAMPLING DATA				
TIME	METER READING	INLET GAS METER TEMPERATURE, °F	OUTLET GAS METER TEMPERATURE, °F	VACUUM "Hg
1405	478.411	78	80	8
10		80	80	8
15		85	80	8
20		87	80	8
25		91	81	8
30		91	82	8
35	stopped 493.805	84	82	8
45	493.805	85	81	8
50		91	81	8
55		91	81	9
1500		95	82	10
05		97	84	10
10				
1515	510.585			

PRE-LEAK CHECK 0.000 @ 15" Hg POST-LEAK CHECK 0.000 @ 10" Hg DELTA H SETTING 1.20

MOISTURE DETERMINATION

SAMPLE LOCATION

Outlet

RUN NO.

3

DATE

10/9/96

GRAMS

IMPINGER 1

FINAL WEIGHT

672.5

INITIAL WEIGHT

623.8

INCREASE

IMPINGER 1

48.7

IMPINGER 2

FINAL WEIGHT

583.3

INITIAL WEIGHT

581.6

INCREASE

IMPINGER 2

1.7

IMPINGER 3

FINAL WEIGHT

476.1

INITIAL WEIGHT

475.9

INCREASE

IMPINGER 3

0.2

SILICA GEL

FINAL WEIGHT

830.6

INITIAL WEIGHT

822.3

INCREASE

SILICA GEL

8.3

TOTAL MASS OF WATER CAUGHT

58.9 ✓

GRAMS

CALCULATIONS

VELOCITY

(ACTUAL)

= 85.48 (C_p)

$$\sqrt{\frac{T_s + 460}{P_s \text{ (MW)}}} \sqrt{\Delta P}$$

IN STACK

= 85.48 (

$$\sqrt{\frac{(\quad)}{(\quad)(\quad)}} \sqrt{\Delta P}$$

V_s

= (

$$\sqrt{\Delta P} = (\quad)(\quad) \sqrt{\Delta P}$$

V_s

= (

$$\sqrt{\Delta P} = (\quad)(\quad) = \text{FT/SEC}$$

ACFM = (V_s) (CSA) (60) = (

)

(

)

(

)

(60) =

)

)

)

)

)

)

)

)

)

)

)

)

)

VELOCITY @ Stp. V_s - std = V_s (17.71)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

SCFM = (V_s - std) (CSA) (60) = (

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

DSCFM = $\frac{100 - \%H_2O}{100}$ (SCFM) = (

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

)

APPENDIX V

CALIBRATION DATA & CYLINDER GAS CERTIFICATES

NOx Monitor Converter Efficiency Check Summary

113

Project Name:	LFG Specialties
Sample Location:	Bethlehem Landfill
Emission Source(s):	Enclosed Ground Flare Outlet
AirRECON Project No.:	AR5-6922
NOx Monitor Make and Model No.:	Thermo-Environmental Model 10
NOx Monitor Serial Number:	10AR-13695-140
C.E. Check Date:	October 9, 1996

Input Data

Conc. of NOx standard added to 1:1 Mixture (ppmv, dry):	171.2
Conc. of O2 standard added to 1:1 Mixture (% by vol.):	20.92
Converter Efficiency Check Start Time:	07:15
Converter Efficiency Check End Time:	07:45
Time of Peak NOx Concentration:	07:27
NOx Concentration at Peak Time (ppmv, dry) [A]:	110.8
NOx Concentration at C.E. Completion (ppmv, dry) [B]:	110.1

Output Data

Abs. Diff. From Peak Response to End Response (ppmv, dry):	0.7
Converter Efficiency (% of Peak Response) [CE]:	0.6

Method-20, Sect. 5.6.1 Conformance

Converter Efficiency [CE] Is Less Than 2.0 %, Therefore Monitor Passes

This Spreadsheet Uses The Following Calculations/Equations:

Absolute Difference = $|A - B|$

CE = $(|A - B| \div A) \times 100$

METERING SYSTEM CALIBRATION DATA SHEET
FOR CALIBRATION AFTER USE

SYSTEM ID NO: 8 DATE: 10/10/96 BY OPF
FIELD METER S/N: 600833 STD. MTR. S/N: 5175176
INTERMEDIATE DELTA H 1.0 INCHES H₂O, MAX. VACUUM 10 INCHES Hg
BAROMETRIC PRESSURE 29.72 INCHES Hg = P_b
LEAK CHECK 0.000 CFM @ 25 INCHES Hg and PRESSURE CHECK OK

RUN NO.		STD DRY GAS METER V _s ft ³	FIELD DRY GAS METER V _f ft ³	STD METER t _{of}	FIELD METER			TIME MIN	DGM CALIB FACTOR Y NO UNITS
					IN t _{of}	OUT t _{of}	AVG t _{of}		
1	F	850.605	516.263	68	63	82	62.5	10	1.00
	I	845 405	511.135						
	D	5.200	5.128						
2	F	856.110	521.722	69	84	70	77	10.5	1.02
	I	850.605	516.263						
	D	5.505	5.459						
3	F	861.208	526.827	69	85	71	78	10	1.01
	I	856.110	521.722						
	D	5.098	5.105						

* FINAL, INITIAL & DIFFERENCE VOLUMES

AVG. 1.01

**IF THE VALUE HAS CHANGED MORE THAN FIVE PERCENT FROM PREVIOUS VALUES REFER TO U.S. EPA METHOD 5, PARAGRAPH 5.3.2.

$$Y = \frac{V_s P_b (t_s + 460)}{V_f \left(P_b + \frac{\text{DELTA H}}{13.6} \right) (t_s + 460)}$$

METERING SYSTEM CALIBRATION DATA SHEET FOR CALIBRATION PRIOR TO USE

SYSTEM ID NO: 8 DATE: 10.10.95 BY: NSK
FIELD METER S/N: 600833 STD. METER S/N: J175176
BAROMETRIC PRESSURE 30.26 INCHES Hg = Pb
LEAK CHECK 0.000 CFM @ 26 INCHES Hg and PRESSURE CHECK OK

ORIFICE MANOMETER DELTA H in H ₂ O		STD DRY GAS METER V _f ft ³	FIELD DRY GAS METER V _f ft ³	STD METER t _o F	FIELD METER			TIME MIN	DGM CALIB FACTOR Y NO UNITS	ORIFICE CALIB FACTOR DELTA H @ in H ₂ O
					IN t _i F	OUT t _o F	AVG t _o F			
0.5	F	728.453	704.560	64	78	72	75	13	0.97	1.66
	I	723.431	699.326							
	D	5.022	5.234							
1.0	F	734.696	711.117	64	88	76	82	9.75	0.98	1.87
	I	729.546	705.702							
	D	5.150	5.415							
2.0	F	742.312	719.127	64	88	80	84	9.00	0.98	1.96
	I	735.749	712.217							
	D	6.563	6.910							
3.0	F	747.838	724.914	64	88	82	85	5.50	0.98	1.88
	I	742.818	719.650							
	D	5.020	5.264							
4.0	F	753.915	731.256	64	88	82	85	4.5	0.99	1.65
	I	748.822	725.946							
	D	5.093	5.310							

* FINAL, INITIAL & DIFFERENCE VOLUMES

AVG 0.98 1.80

**INDIVIDUAL VALUES MAY VARY BY ±0.02 FROM AVG.

***INDIVIDUAL VALUES MAY VARY BY ±0.20 FROM AVG.

$$Y = \frac{V_s P_b (t_f + 460)}{V_f \left(P_b + \frac{\text{DELTA H}}{13.6} \right) (t_s + 460)}$$

$$\text{DELTA H} @ = \left[\frac{0.0317 \text{ DELTA H}}{P_b (t_o + 460)} \right] \left(\frac{(t_s + 460) \phi}{V_s} \right)^2$$

METERING SYSTEM CALIBRATION DATA SHEET
FOR CALIBRATION AFTER USE

SYSTEM ID NO: 12 DATE: 10/10/96 BY DPF
FIELD METER S/N: 5175176 STD. MTR. S/N: 300301
INTERMEDIATE DELTA H 1.0 INCHES H₂O, MAX. VACUUM 8 INCHES Hg
BAROMETRIC PRESSURE 29.72 INCHES Hg = Pb
LEAK CHECK 0.000 CFM @ 24 INCHES Hg and PRESSURE CHECK OK

RUN NO.		STD DRY GAS METER V _s ft ³	FIELD DRY GAS METER V _f ft ³	STD METER t _{of}	FIELD METER			TIME MIN	DGH CALIB FACTOR Y NO UNITS
					IN t _{of}	OUT t _{of}	AVG t _{of}		
1	F	834.333	873.010	65	64	62	63	8	0.98
	I	829.207	867.834						
	D	5.126	5.176						
2	F	839.805	878.555	66	70	69	69.5	8	0.99
	I	834.333	873.010						
	D	5.472	5.545						
	F	844.909	883.772	67	74	71	72.5	8	0.99
	I	839.805	878.555						
	D	5.104	5.217						

* FINAL, INITIAL & DIFFERENCE VOLUMES

AVG. 0.99 **

**IF THE VALUE HAS CHANGED MORE THAN FIVE PERCENT FROM PREVIOUS VALUES REFER TO U.S. EPA METHOD 5, PARAGRAPH 5.3.2.

$$Y = \frac{V_s P_b (t_f + 460)}{V_f \left(P_b + \frac{\text{DELTA H}}{13.6} \right) (t_s + 460)}$$

METERING SYSTEM CALIBRATION DATA SHEET FOR CALIBRATION PRIOR TO USE

SYSTEM ID NO: 12 DATE: 8.7.96 BY NSK
FIELD METER S/N: 300301 STD. METER S/N: J175176
BAROMETRIC PRESSURE 30.23 INCHES Hg = Pb
LEAK CHECK 0.000 CFM @ 26 INCHES Hg and PRESSURE CHECK OK

ORIFICE MANOMETER DELTA H in H ₂ O		STD DRY GAS METER V _s ft ³	FIELD DRY GAS METER V _f ft ³	STD METER t _o F	FIELD METER			TIME - MIN	DGM CALIB FACTOR Y NO UNITS	ORIFICE CALIB FACTOR DELTA H @ in H ₂ O
					IN t _i F	OUT t _o F	AVG t _o F			
0.5	* F	331.354	215.613	76	82	82	82	15	1.01	1.45
	I	325.018	209.259							
	D	6.336	6.354							
1.0	F	336.818	221.125	76	85	83	84	8 1/2	1.04	1.54
	I	331.758	216.016							
	D	5.060	5.109							
2.0	F	324.325	208.589	76	82	82	82	6.75	1.00	1.80
	I	319.074	203.290							
	D	5.251	5.279							
3.0	F	343.532	227.928	76	89	84	87	5.75	1.00	1.73
	I	337.930	222.252							
	D	5.602	5.676							
4.0	F	350.365	234.841	76	85	84	85	5.0	1.00	1.68
	I	344.635	229.043							
	D	5.730	5.798							
AVG									1.01	1.64

* FINAL, INITIAL & DIFFERENCE VOLUMES

**INDIVIDUAL VALUES MAY VARY BY ±0.02 FROM AVG.
***INDIVIDUAL VALUES MAY VARY BY ±0.20 FROM AVG.

$$Y = \frac{V_s P_b (t_o + 460)}{V_f \left(P_b + \frac{\text{DELTA H}}{13.6} \right) (t_o + 460)}$$

$$\text{DELTA H @} = \left[\frac{0.0317 \text{ DELTA H}}{P_b (t_o + 460)} \right] \left(\frac{(t_o + 460) \phi}{V_s} \right)^2$$

PITOT TUBE CALIBRATION

Pitot tube calibration number 8 Date 8/16/95
Calibrated by DPF
Effective length 10.8"

Standard value option (yes/no)

Baseline coefficient values of 0.84 assigned. Pitot meets all specifications of 40 CFR, Part 60, App. A, Method 2.

A Side Calibration

Run No.	ΔP_{std} cm H ₂ O (in. H ₂ O)	ΔP_s cm H ₂ O (in. H ₂ O)	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	0.72	0.97	0.85	0.00
2	0.39	0.53	0.85	0.00
3	0.25	0.35	0.84	-0.01
$\bar{C}_p(\text{side A})$			0.85	$\delta = 0.003$ *


B Side Calibration

Run No.	ΔP_{std} cm H ₂ O (in. H ₂ O)	ΔP_s cm H ₂ O (in. H ₂ O)	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	0.72	0.99	0.84	0.00
2	0.39	0.54	0.84	0.00
3	0.25	0.35	0.84	0.00
$\bar{C}_p(\text{side B})$			0.84	$\delta = 0.00$ *

$$C_p(A) - C_p(B) = 0.01 *$$

Figure 4-10. Pitot tube calibration data.

*VALUE MUST BE $\leq \pm 0.01$

**CERTIFICATE OF ANALYSIS****EPA PROTOCOL MIXTURE****PROCEDURE # : G1****SHIPPED FROM:** 80 INDUSTRIAL DRIVE
ALPHA, NJ. 08865**TEL:**(908)454-7455 **FAX:**(908)454-7784**CUSTOMER:** AIR RECON
SGI ORDER # : 117993
ITEM# : 1
P.O.# : 23859**CYLINDER # :** CC63190
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 590**CERTIFICATION DATE:** 5/24/96**EXPIRATION DATE:** 5/24/99**CERTIFICATION HISTORY**

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
OXYGEN	5/24/96	11.0 %	11.0 %	+/- 1%

BALANCE**NITROGEN****REFERENCE STANDARDS**

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
OXYGEN	SRM2659A	CLM006747	20.72%

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE
OXYGEN	HORIBA-MPA510	570694081	PM	5/24/96

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST:Ted Neeme
TED NEEME**DATE:** 5-24-96



215-691-2474
FAX# 215-758-5384

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

120

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER RECON SYSTEMS

P.O NUMBER

REFERENCE STANDARD

COMPONENT

NIST SRM NO.

CYLINDER NO.

CONCENTRATION

OXYGEN 21.09% GMS VS.

2659A

FF-27650

20.71%

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT	OXYGEN	21.09%	GMS VS.	ANALYZER MAKE-MODEL-S/N	SYBRON SERVOMEX 244A	244/701/953
ANALYTICAL PRINCIPLE					LAST CALIBRATION DATE	11/30/93
FIRST ANALYSIS DATE					SECOND ANALYSIS DATE	
Z 0	R 21.09	C 20.93	CONC.	20.93	Z	R C CONC.
R 21.14	Z 0.02	C 20.96	CONC.	20.91	R	Z C CONC.
Z 0.02	C 20.95	R 21.12	CONC.	20.92	Z	C R CONC.
U/M VOLTS		MEAN TEST ASSAY	20.92	U/M VOLTS		MEAN TEST ASSAY

THIS CYLINDER NO. SA10687
HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.4
OF TRACEABILITY PROTOCOL NO. 1

PROCEDURE G1
CERTIFIED ACCURACY ± 1 % NIST TRACEABLE
CYLINDER PRESSURE 2000 PSIG
CERTIFICATION DATE 1/31/94
EXPIRATION DATE 1/31/97

CERTIFIED CONCENTRATION

OXYGEN 20.92%
NITROGEN BALANCE

ANALYZED BY

Robert Hillard
ROBERT HILLARD

CERTIFIED BY

Stephen Pollack
STEPHEN POLLACK

**SPECTRA GASES**

277 Coit St. • Irvington, NJ 07111 USA Tel.: (201) 372-2060 • (800) 932-0624 • Fax: (201) 372-8551

121

**CERTIFICATE OF ANALYSIS****EPA PROTOCOL MIXTURE****PROCEDURE #: G2****SHIPPED FROM:** 80 INDUSTRIAL DRIVE
ALPHA, NJ. 08865**TEL:**(908)454-7455 **FAX:**(908)454-7784**CUSTOMER:** AIR RECON
SGI ORDER #: 115333
ITEM#: 1
P.O.#: 26126**CYLINDER #:** CC53295
CYLINDER PRES: 1900 PSIG
CGA OUTLET: 580**CERTIFICATION DATE:** 12/4/95**EXPIRATION DATE:** 12/4/98**CERTIFICATION HISTORY**

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
CARBON DIOXIDE	12/4/95	10.0%	10.0%	+/- 2%

BALANCE**NITROGEN****REFERENCE STANDARDS**

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
CARBON DIOXIDE	SRM1675B	CLM006352	14.010%

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE
CARBON DIOXIDE	HORIBA-VIA510	571417045	NDIR	11/22/95

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.

DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST:
TED NEEME**DATE:**

12-4-95



610-691-2474
FAX# 610-758-8384

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

122

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER RECON SYSTEMS

P.O. NUMBER 27480

REFERENCE STANDARD

COMPONENT
CARBON DIOXIDE 14.22% GMS VS.

NIST SRM NO.
1675B

CYLINDER NO.
FF28127

CONCENTRATION
14.04%

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

1. COMPONENT CARBON DIOXIDE 14.22% GMS VS. ANALYZER MAKE-MODEL-S/N

ANALYTICAL PRINCIPLE

NDIR

FIRST ANALYSIS DATE

09/26/94

Z 0.00 R 13.58 C 17.38 CONC. 18.20 Z

R 13.58 Z 0.00 C 17.40 CONC. 18.22 R

Z 0.00 C 17.40 R 13.58 CONC. 18.22 Z

U/M % MEAN TEST ASSAY 18.21 U/M %

SIEMENS ULTRAMAT 5E C7-228

LAST CALIBRATION DATE

03/31/94

SECOND ANALYSIS DATE

R C CONC.

Z C CONC.

C R CONC.

MEAN TEST ASSAY

THIS CYLINDER NO. SA13410

HAS BEEN CERTIFIED ACCORDING TO SECTION 3.0.4
OF TRACEABILITY PROTOCOL NO. 1

PROCEDURE G1

CERTIFIED ACCURACY ± 1 % NIST TRACEABLE

CYLINDER PRESSURE 2000PSIG

CERTIFICATION DATE 09/26/94

EXPIRATION DATE 09/26/97

CERTIFIED CONCENTRATION

CARBON DIOXIDE 18.21 %

NITROGEN BALANCE

ANALYZED BY

STAN LECK

CERTIFIED BY

KEVIN BRADY

**SPECTRA GASES**

277 Coit St. • Irvington, NJ 07111 USA Tel.: (201) 372-2060 • (800) 932-0624 • Fax: (201) 372-8551

123

**CERTIFICATE OF ANALYSIS****EPA PROTOCOL MIXTURE****PROCEDURE #: G2****SHIPPED FROM:** 80 INDUSTRIAL DRIVE
ALPHA, NJ. 08865**TEL:**(908)454-7455 **FAX:**(908)454-7784**CUSTOMER:** AIR RECON
SGI ORDER #: 114846
ITEM#: 15
P.O.#: 26398**CYLINDER #:** CC38315
CYLINDER PRES: 1900 PSIG
CGA OUTLET: 660**CERTIFICATION DATE:** 11/13/95
EXPIRATION DATE: 11/13/97**CERTIFICATION HISTORY**

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
NITRIC OXIDE	11/4/95	54.6 PPM	54.6 PPM	+/- 2%
	11/13/95	54.7 PPM		
NOX			54.8 PPM	REFERENCE VALUE ONLY

BALANCE**NITROGEN****REFERENCE STANDARDS**

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
NITRIC OXIDE	NTRM81685	LL2986	245.2PPM.

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE
NITRIC OXIDE	TECO-10	10AR-34979-249	CHEMI	11/2/95

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST:
TED NEEME**DATE:**11-13-95

**SPECTRA GASES**

124



277 Coit St. • Irvington, NJ 07111 USA Tel.: (201) 372-2060 • (800) 932-0624 • Fax: (201) 372-8551

CERTIFICATE OF ANALYSIS**EPA PROTOCOL MIXTURE**

PROCEDURE #: G2

TEL: (908) 454-7455 FAX: (908) 454-7784

SHIPPED FROM: 80 INDUSTRIAL DRIVE
ALPHA, NJ. 08865CUSTOMER: AIR RECON
SGI ORDER #: 115333
ITEM#: 5
P.O.#: 26126CYLINDER #: CC38220
CYLINDER PRES: 1900 PSIG
CGA OUTLET: 660CERTIFICATION DATE: 12/5/95
EXPIRATION DATE: 12/5/97**CERTIFICATION HISTORY**

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
NITRIC OXIDE	11/28/95 12/5/95	110.7 PPM 110.3 PPM	110 PPM	+/- 2%
NOX			111 PPM	REFERENCE VALUE ONLY

BALANCE

NITROGEN

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
NITRIC OXIDE	NTRM81685	LL2986	245.2PPM

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE
NITRIC OXIDE	TECO-10	10AR-34979-249	CHEMI	11/28/95

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST:

TED NEEME

DATE:

12-5-95

BOB HILLARI



610-691-2474
FAX# 610-758-8384

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

126

CERTIFICATE OF ANALYSIS

PRODUCT NUMBER: 4SMECAZ-OAH
PRODUCT DESCRIPTION: 20 ppm METHANE IN ZERO AIR - AH
CYLINDER SERIAL NUMBER: SA7040
DATE OF ANALYSIS: DECEMBER 15, 1994

CUSTOMER: RECON
ORDER: 37915

COMPONENTS =====	REQUESTED CONCENTRATION =====	PREPARATION TOLERANCE =====	CERTIFIED CONCENTRATION =====
Methane	20 ppm	16-24 ppm	21.3 ppm
Zero Air	Balance		Balance

±2% ANALYTICAL ACCURACY

CYLINDER VOLUME/WEIGHT: 140 CU.FT.

CGA VALVE NUMBER: 590

TOTAL CYLINDER PRESSURE: 2000 PSIG

METHODS OF ANALYSIS: Gas Chromatography
Specific Oxygen Analyzer

Certified concentrations were determined by individual analysis.

ANALYZED BY: BILL REIGHTLER, Chemist

It is recommended that cylinders not be depleted
below 50 psig unless otherwise indicated.



610-691-2474
FAX # 610-758-8384

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

127

CERTIFICATE OF ANALYSIS

PRODUCT NUMBER: 4SMECAZ-OAH

CUSTOMER: RECON SYSTEMS
ORDER #: 52824

PRODUCT DESCRIPTION: 46-54 PPM METHANE BALANCE AIR - AH

CYLINDER SERIAL NUMBER: SA9382

DATE OF ANALYSIS: MAY 03, 1995

COMPONENTS =====	REQUESTED CONCENTRATION =====	PREPARATION TOLERANCE =====	CERTIFIED CONCENTRATION =====
METHANE	46-54 PPM		51.3 PPM
AIR	BALANCE		BALANCE

*ANALYTICAL ACCURACY $\pm 2\%$ *

CYLINDER VOLUME/WEIGHT: 135 CU.FT.

CGA VALVE NUMBER: 590

TOTAL CYLINDER PRESSURE: 2000 PSIG

METHODS OF ANALYSIS: Gas Chromatography-FID

Certified concentrations were determined by individual analysis.

ANALYZED BY: STEVE BOGAR SB Chemist

It is recommended that cylinders not be depleted
below 50 psig unless otherwise indicated.



610-691-2474
FAX # 610-758-8384

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

128

CERTIFICATE OF ANALYSIS

PRODUCT NUMBER: 4SMECAZ-OAH

CUSTOMER: RECON SYSTEMS
ORDER #: 52824

PRODUCT DESCRIPTION: 87-92 PPM METHANE BALANCE AIR - AH

CYLINDER SERIAL NUMBER: SA647SG

DATE OF ANALYSIS: MAY 04, 1995

COMPONENTS =====	REQUESTED CONCENTRATION =====	PREPARATION TOLERANCE =====	CERTIFIED CONCENTRATION =====
METHANE	87-92 PPM		88.7 PPM
AIR	BALANCE		BALANCE

ANALYTICAL ACCURACY $\pm 2\%$

CYLINDER VOLUME/WEIGHT: 135 CU.FT.

CGA VALVE NUMBER: 590

TOTAL CYLINDER PRESSURE: 2000 PSIG

METHODS OF ANALYSIS: Gas Chromatography


Certified concentrations were determined by individual analysis.

ANALYZED BY:

STEVE BOGAR

Chemist

It is recommended that cylinders not be depleted
below 50 psig unless otherwise indicated.



CYLINDER GAS PRODUCTS

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

129

CERTIFICATE OF ANALYSIS

PRODUCT NUMBER: 4SMECAZ-OAH

CUSTOMER: Recon Systems

ORDER: 20823

PRODUCT DESCRIPTION: 2500 ppm METHANE IN AIR - AH

CYLINDER SERIAL NUMBER: SA12042

DATE OF ANALYSIS: July 13, 1994

COMPONENTS =====	REQUESTED CONCENTRATION =====	PREPARATION TOLERANCE =====	CERTIFIED CONCENTRATION =====
Methane	2500 ppm	± 5 %	2616.9 ppm
Hydrocarbon Free Air	Balance		Balance
21.04% Oxygen			
Analytical Accuracy	± 2%		

CYLINDER VOLUME/WEIGHT: 136 CU. FT.

CGA VALVE NUMBER: 590

TOTAL CYLINDER PRESSURE: 2000 PSIG

METHODS OF ANALYSIS: Gas Chromatograph
Specific Oxygen Analyzer

Certified concentrations were determined by individual analysis.

ANALYZED BY: W. J. Miller, Chemist

It is recommended that cylinders not be depleted below 50 psig unless otherwise indicated.



610-691-2474
FAX# 610-758-8384

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

130

CERTIFICATE OF ANALYSIS

PRODUCT NUMBER: 4SMECAZ-OAH
PRODUCT DESCRIPTION: 5000 PPM METHANE IN HYDROCARBON-FREE AIR - AH
CYLINDER NUMBER: SA 12389
DATE OF ANALYSIS: OCTOBER 7, 1994
CUSTOMER: RECON SYSTEMS
ORDER NO: 28853
+/- 2% ANALYTICAL ACCURACY

COMPONENTS =====	REQUESTED CONCENTRATION =====	PREPARATION TOLERANCE =====	CERTIFIED CONCENTRATION =====
METHANE	5000 PPM	4800-5300	4916.1 PPM
HYDROCARBON-FREE AIR	BALANCE		BALANCE

CYLINDER VOLUME/WEIGHT: 135 Cu.Ft.

CGA VALVE NUMBER: 590

TOTAL CYLINDER PRESSURE: 2000 PSIG

METHOD OF ANALYSIS: GAS CHROMATOGRAPHY

Certified concentrations were determined by individual analysis.

ANALYZED BY:

R. M. Hall

, Chemist

It is recommended that cylinders not be depleted
below 50 psig unless otherwise indicated.



215-691-2474
FAX# 215-758-8384

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

131

CERTIFICATE OF ANALYSIS

PRODUCT NUMBER: 4SMECAZ-OAH

CUSTOMER: RECON SYSTEMS

ORDER NUMBER: 5576

PRODUCT DESCRIPTION: 9000 ppm METHANE IN HYDROCARBON-FREE AIR - AH

CYLINDER SERIAL NUMBER: SA-8013

DATE OF ANALYSIS: 02-28-94

COMPONENTS =====	REQUESTED CONCENTRATION =====	PREPARATION TOLERANCE =====	CERTIFIED CONCENTRATION =====
METHANE	9000 ppm	±5 %	9175 ppm
AIR (HYDROCARBON-FREE)	BALANCE		BALANCE

21.20% OXYGEN

CYLINDER VOLUME/WEIGHT: 140 CU.FT.

CGA VALVE NUMBER: 590

TOTAL CYLINDER PRESSURE: 2000 PSIG


METHODS OF ANALYSIS: GAS CHROMATOGRAPH
SPECIFIC OXYGEN ANALYZER


Certified concentrations were determined by individual analysis.

ANALYZED BY: Al Marking, Chemist

It is recommended that cylinders not be depleted
below 50 psig unless otherwise indicated.

APPENDIX VI
CEM STRIP CHARTS





ATTACH BAG
 1-1 MIX-BE 171.2 ppm NOX STD. & 20.92% O2 STD.
 NOX MONITOR CONVERTER EFFICIENCY TEST

1 = 20.7 % O2
 9/01/96 7:10:21
 8 = 6.1 ppm NOX

210 20 0:30:00

11-6-74 021 ZERO-002 AND NOX

INITIAL STACK GAS CHECKS

00	90	80	70	60	50	40	30	20	10	0
0	10	20	30	40	50	60	70	80	90	100

END OF NOX MONITOR CONVERTER EFFICIENCY TEST

8 = 116.1 PPM NOX

9/007/96 7:45:21

8 = 116.8 PPM NOX

9/007/96 7:44:21

8 = 116.1 PPM NOX

9/007/96 7:43:21

8 = 116.1 PPM NOX

9/007/96 7:42:21

8 = 116.1 PPM NOX

9/007/96 7:41:21

8 = 116.1 PPM NOX

9/007/96 7:40:21

8 = 116.1 PPM NOX

9/007/96 7:39:21

8 = 116.2 PPM NOX

9/007/96 7:38:21

8 = 116.2 PPM NOX

9/007/96 7:37:21

8 = 116.2 PPM NOX

9/007/96 7:36:21

8 = 116.2 PPM NOX

9/007/96 7:35:21

8 = 116.3 PPM NOX

9/007/96 7:34:21

8 = 116.3 PPM NOX

9/007/96 7:33:21

8 = 116.4 PPM NOX

9/007/96 7:32:21

8 = 116.4 PPM NOX

9/007/96 7:31:21

8 = 116.5 PPM NOX

9/007/96 7:30:21

8 = 116.6 PPM NOX

133

[illegible]

1	1	5	%	Q2	6 = 9.1	%	Q2	8 = 6.7	PPM	NOX
9/00T/95	10	47	38	Q2	6 = 9.1	%	Q02	8 = 7.0	PPM	NOX
1	10.3	%								
9/00T/95	10	47	38	Q2	6 = 9.1	%	Q02	8 = 7.2	PPM	NOX
1	10.3	%								
9/00T/95	10	46	38	Q2	6 = 9.0	%	Q02	8 = 6.8	PPM	NOX
1	11.0	%								
9/00T/95	10	46	38	Q2	6 = 9.0	%	Q02	8 = 6.2	PPM	NOX
1	10.9	%								
9/00T/95	10	46	38	Q2	6 = 9.1	%	Q02	8 = 6.4	PPM	NOX
1	10.7	%								
9/00T/95	10	46	38	Q2	6 = 9.1	%	Q02	8 = 6.7	PPM	NOX
1	10.5	%								
9/00T/95	10	44	38	Q2	6 = 9.2	%	Q02	8 = 6.9	PPM	NOX
1	10.7	%								
9/00T/95	10	44	38	Q2	6 = 9.0	%	Q02	8 = 6.9	PPM	NOX
1	11.0	%								
9/00T/95	10	43	38	Q2	6 = 9.2	%	Q02	8 = 6.5	PPM	NOX
1	10.7	%								
9/00T/95	10	43	38	Q2	6 = 9.2	%	Q02	8 = 6.5	PPM	NOX
1	10.7	%								
9/00T/95	10	42	38	Q2	6 = 9.0	%	Q02	8 = 6.8	PPM	NOX
1	10.3	%								
9/00T/95	10	41	38	Q80	70 6 = 9.0	%	50Q2	8 = 6.7	PPM	NOX
104 = 11.0	90	%								
9/00T/95	10	41	38	Q2	30 6 = 9.1	%	50	8 = 6.9	PPM	NOX
1	10.7	%								
9/00T/95	10	40	38	Q2	6 = 9.1	%	Q02	8 = 7.1	PPM	NOX
1	10.7	%								
9/00T/95	10	40	38	Q2	6 = 9.2	%	Q02	8 = 7.0	PPM	NOX
1	10.3	%								
9/00T/95	10	39	38	Q2	6 = 9.0	%	Q02	8 = 6.5	PPM	NOX
1	10.9	%								
9/00T/95	10	38	38	Q2	6 = 9.1	%	Q02	8 = 6.8	PPM	NOX
1	10.3	%								
9/00T/95	10	38	38	Q2	6 = 9.2	%	Q02	8 = 7.0	PPM	NOX
1	10.7	%								
9/00T/95	10	38	38	Q2	6 = 9.1	%	Q02	8 = 7.2	PPM	NOX
1	10.5	%								

File: [2] ZERO CO2 AND NOX

STACK BIAS CHECKS

THE END OF RACE

129%

[illegible]

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

back home

11

88-11-967170-6

2021

9/00T/96 11: 4: 8

— 8 —

06-11-90 18:33

1000

[illegible]

9707/951138

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

9/00/95 11:23

11

9700796-11-2-8

11

02-11-2007 11:30 AM

03/11/2011

三、

96/10545

 $1 = 10.8\%$

9/OCT/96 11: 0:38

10.6.1

9/00T/96 11:01 88

22

0
9
6
7
1
0
5
9
8

1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100
 101
 102
 103
 104
 105
 106
 107
 108
 109
 110
 111
 112
 113
 114
 115
 116
 117
 118
 119
 120
 121
 122
 123
 124
 125
 126
 127
 128
 129
 130
 131
 132
 133
 134
 135
 136
 137
 138
 139
 140
 141
 142
 143
 144
 145
 146
 147
 148
 149
 150
 151
 152
 153
 154
 155
 156
 157
 158
 159
 160
 161
 162
 163
 164
 165
 166
 167
 168
 169
 170
 171
 172
 173
 174
 175
 176
 177
 178
 179
 180
 181
 182
 183
 184
 185
 186
 187
 188
 189
 190
 191
 192
 193
 194
 195
 196
 197
 198
 199
 200
 201
 202
 203
 204
 205
 206
 207
 208
 209
 210
 211
 212
 213
 214
 215
 216
 217
 218
 219
 220
 221
 222
 223
 224
 225
 226
 227
 228
 229
 230
 231
 232
 233
 234
 235
 236
 237
 238
 239
 240
 241
 242
 243
 244
 245
 246
 247
 248
 249
 250
 251
 252
 253
 254
 255
 256
 257
 258
 259
 260
 261
 262
 263
 264
 265
 266
 267
 268
 269
 270
 271
 272
 273
 274
 275
 276
 277
 278
 279
 280
 281
 282
 283
 284
 285
 286
 287
 288
 289
 290
 291
 292
 293
 294
 295
 296
 297
 298
 299
 300
 301
 302
 303
 304
 305
 306
 307
 308
 309
 310
 311
 312
 313
 314
 315
 316
 317
 318
 319
 320
 321
 322
 323
 324
 325
 326
 327
 328
 329
 330
 331
 332
 333
 334
 335
 336
 337
 338
 339
 340
 341
 342
 343
 344
 345
 346
 347
 348
 349
 350
 351
 352
 353
 354
 355
 356
 357
 358
 359
 360
 361
 362
 363
 364
 365
 366
 367
 368
 369
 370
 371
 372
 373
 374
 375
 376
 377
 378
 379
 380
 381
 382
 383
 384
 385
 386
 387
 388
 389
 390
 391
 392
 393
 394
 395
 396
 397
 398
 399
 400
 401
 402
 403
 404
 405
 406
 407
 408
 409
 410
 411
 412
 413
 414
 415
 416
 417
 418
 419
 420
 421
 422
 423
 424
 425
 426
 427
 428
 429
 430
 431
 432
 433
 434
 435
 436
 437
 438
 439
 440
 441
 442
 443
 444
 445
 446
 447
 448
 449
 450
 451
 452
 453
 454
 455
 456
 457
 458
 459
 460
 461
 462
 463
 464
 465
 466
 467
 468
 469
 470
 471
 472
 473
 474
 475
 476
 477
 478
 479
 480
 481
 482
 483
 484
 485
 486
 487
 488
 489
 490
 491
 492
 493
 494
 495
 496
 497
 498
 499
 500
 501
 502
 503
 504
 505
 506
 507
 508
 509
 510
 511
 512
 513
 514
 515
 516
 517
 518
 519
 520
 521
 522
 523
 524
 525

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

9/00/6 10:01 8

11-10-68

83 80 01 96/100/5

22


9/10/96 10:58

2	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

[illegible]

85 2010 95/1170/5

143



9/00T/96	12:51	%	02	6 = 9.3	%	02	8 = 8.3	ppm	NOX
1 = 10.5	12:50	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:50	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:50	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:49	37	02	6 = 9.3	%	002	8 = 7.7	ppm	NOX
1 = 10.5	12:49	37	02	6 = 9.3	%	002	8 = 7.7	ppm	NOX
9/00T/96	12:48	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:48	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:47	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:47	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:46	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:46	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:45	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:45	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:44	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:44	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:43	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:43	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:42	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:42	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
9/00T/96	12:41	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX
1 = 10.5	12:41	37	02	6 = 9.3	%	002	8 = 8.3	ppm	NOX

1 = 1'	2	3	4	5	6 = 9.5	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
9/OCT/95	5	13	0	37																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				</

1	8	%	02	6 = 9.8	%	002	8 = 7.9	PPM	NOX
9/00T/96	13.1	%	02	6 = 9.1	%	002	8 = 8.1	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.1	%	002	8 = 8.2	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.2	%	002	8 = 7.9	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.3	%	002	8 = 7.8	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.2	%	002	8 = 8.4	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.2	%	002	8 = 8.6	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.8	%	002	8 = 7.9	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.2	%	002	8 = 8.6	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.1	%	002	8 = 7.6	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.1	%	002	8 = 8.6	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.1	%	002	8 = 7.9	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.1	%	002	8 = 7.7	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.3	%	002	8 = 7.6	PPM	NOX
1 = 16.8		%	02						
9/00T/96	13.1	%	02	6 = 9.1	%	002	8 = 7.7	PPM	NOX
1 = 16.8		%	02						

447011196 1131241281

0	021	ZERO	CO2	AND	NOX
---	-----	------	-----	-----	-----

3000

THE LIFE

9-00756-13-20-7

[illegible][illegible]

	I	-10	9	%	02	6 = 9.8
9/007/96	13:	18:	37			

1	= 10.5	%	02	6 = 9.3
9/07/96 13:18: 7				

Time	Temp	Pressure	Flow	Volume	Weight	Concentration	Notes
00:00	10.0	1.0	1.0	1.0	1.0	1.0	
00:05	10.0	1.0	1.0	1.0	1.0	1.0	
00:10	10.0	1.0	1.0	1.0	1.0	1.0	
00:15	10.0	1.0	1.0	1.0	1.0	1.0	
00:20	10.0	1.0	1.0	1.0	1.0	1.0	
00:25	10.0	1.0	1.0	1.0	1.0	1.0	
00:30	10.0	1.0	1.0	1.0	1.0	1.0	
00:35	10.0	1.0	1.0	1.0	1.0	1.0	
00:40	10.0	1.0	1.0	1.0	1.0	1.0	
00:45	10.0	1.0	1.0	1.0	1.0	1.0	
00:50	10.0	1.0	1.0	1.0	1.0	1.0	
00:55	10.0	1.0	1.0	1.0	1.0	1.0	
01:00	10.0	1.0	1.0	1.0	1.0	1.0	
01:05	10.0	1.0	1.0	1.0	1.0	1.0	
01:10	10.0	1.0	1.0	1.0	1.0	1.0	
01:15	10.0	1.0	1.0	1.0	1.0	1.0	
01:20	10.0	1.0	1.0	1.0	1.0	1.0	
01:25	10.0	1.0	1.0	1.0	1.0	1.0	
01:30	10.0	1.0	1.0	1.0	1.0	1.0	
01:35	10.0	1.0	1.0	1.0	1.0	1.0	
01:40	10.0	1.0	1.0	1.0	1.0	1.0	
01:45	10.0	1.0	1.0	1.0	1.0	1.0	
01:50	10.0	1.0	1.0	1.0	1.0	1.0	
01:55	10.0	1.0	1.0	1.0	1.0	1.0	
02:00	10.0	1.0	1.0	1.0	1.0	1.0	
02:05	10.0	1.0	1.0	1.0	1.0	1.0	
02:10	10.0	1.0	1.0	1.0	1.0	1.0	
02:15	10.0	1.0	1.0	1.0	1.0	1.0	
02:20	10.0	1.0	1.0	1.0	1.0	1.0	
02:25	10.0	1.0	1.0	1.0	1.0	1.0	
02:30	10.0	1.0	1.0	1.0	1.0	1.0	
02:35	10.0	1.0	1.0	1.0	1.0	1.0	
02:40	10.0	1.0	1.0	1.0	1.0	1.0	
02:45	10.0	1.0	1.0	1.0	1.0	1.0	
02:50	10.0	1.0	1.0	1.0	1.0	1.0	
02:55	10.0	1.0	1.0	1.0	1.0	1.0	
03:00	10.0	1.0	1.0	1.0	1.0	1.0	
03:05	10.0	1.0	1.0	1.0	1.0	1.0	
03:10	10.0	1.0	1.0	1.0	1.0	1.0	
03:15	10.0	1.0	1.0	1.0	1.0	1.0	
03:20	10.0	1.0	1.0	1.0	1.0	1.0	
03:25	10.0	1.0	1.0	1.0	1.0	1.0	
03:30	10.0	1.0	1.0	1.0	1.0	1.0	
03:35	10.0	1.0	1.0	1.0	1.0	1.0	
03:40	10.0	1.0	1.0	1.0	1.0	1.0	
03:45	10.0	1.0	1.0	1.0	1.0	1.0	
03:50	10.0	1.0	1.0	1.0	1.0	1.0	
03:55	10.0	1.0	1.0	1.0	1.0	1.0	
04:00	10.0	1.0	1.0	1.0	1.0	1.0	
04:05	10.0	1.0	1.0	1.0	1.0	1.0	
04:10	10.0	1.0	1.0	1.0	1.0	1.0	
04:15	10.0	1.0	1.0				

2000-256-13-1-3	5 = 9.3
= 16.4	02

[illegible]

9/00/198	13:16:37	02	6 = 9.2
----------	----------	----	---------

[illegible]

1	= 119.8	%	04
9	007/96	13.15	37

1	= 10	2	%	02	= 5.3
9	00	95	13.10	7	

Year	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093	2094	2095	2096	2097	2098	2099
1990	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093	2094	2095	2096	2097	2098	2099

[illegible]

3200-2500	13.14	02	6	5:1
1	16.0	%		

9/001/96	13.13	%	02	6 = 9.3

9/007/96	13.13	7	02	6	9.1

9/007/96 13-12-37 83

9/007/9613:12:7	112
-----------------	-----

11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140 141 142 143 144 145 146 147 148 149 150 151 152 153 154 155 156 157 158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200 201 202 203 204 205 206 207 208 209 210 211 212 213 214 215 216 217 218 219 220 221 222 223 224 225 226 227 228 229 230 231 232 233 234 235 236 237 238 239 240 241 242 243 244 245 246 247 248 249 250 251 252 253 254 255 256 257 258 259 260 261 262 263 264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297 298 299 300 301 302 303 304 305 306 307 308 309 310 311 312 313 314 315 316 317 318 319 320 321 322 323 324 325 326 327 328 329 330 331 332 333 334 335 336 337 338 339 340 341 342 343 344 345 346 347 348 349 350 351 352 353 354 355 356 357 358 359 360 361 362 363 364 365 366 367 368 369 370 371 372 373 374 375 376 377 378 379 380 381 382 383 384 385 386 387 388 389 390 391 392 393 394 395 396 397 398 399 400 401 402 403 404 405 406 407 408 409 410 411 412 413 414 415 416 417 418 419 420 421 422 423 424 425 426 427 428 429 430 431 432 433 434 435 436 437 438 439 440 441 442 443 444 445 446 447 448 449 450 451 452 453 454 455 456 457 458 459 460 461 462 463 464 465 466 467 468 469 470 471 472 473 474 475 476 477 478 479 480 481 482 483 484 485 486 487 488 489 490 491 492 493 494 495 496 497 498 499 500 501 502 503 504 505 506 507 508 509 510 511 512 513 514 515 516 517 518 519 520 521 522 523 524 525 526 527 528 529 530 531 532 533 534 535 536 537 538 539 540 541 542 543 544 545 546 547 548 549 550 551 552 553 554 555 556 557 558 559 560 561 562 563 564 565 566 567 568 569 570 571 572 573 574 575 576 577 578 579 580 581 582 583 584 585 586 587 588 589 590 591 592 593 594 595 596 597 598 599 600 601 602 603 604 605 606 607 608 609 610 611 612 613 614 615 616 617 618 619 620 621 622 623 624 625 626 627 628 629 630 631 632 633 634 635 636 637 638 639 640 641 642 643 644 645 646 647 648 649 650 651 652 653 654 655 656 657 658 659 660 661 662 663 664 665 666 667 668 669 670 671 672 673 674 675 676 677 678 679 680 681 682 683 684 685 686 687 688 689 690 691 692 693 694 695 696 697 698 699 700 701 702 703 704 705 706 707 708 709 710 711 712 713 714 715 716 717 718 719 720 721 722 723 724 725 726 727 728 729 730 731 732 733 734 735 736 737 738 739 740 741 742 743 744 745 746 747 748 749 750 751 752 753 754 755 756 757 758 759 760 761 762 763 764 765 766 767 768 769 770 771 772 773 774 775 776 777 778 779 780 781 782 783 784 785 786 787 788 789 790 791 792 793 794 795 796 797 798 799 800 801 802 803 804 805 806 807 808 809 810 811 812 813 814 815 816 817 818 819 820 821 822 823 824 825 826 827 828 829 830 831 832 833 834 835 836 837 838 839 840 841 842 843 844 845 846 847 848 849 850 851 852 853 854 855 856 857 858 859 860 861 862 863 864 865 866 867 868 869 870 871 872 873 874 875 876 877 878 879 880 881 882 883 884 885 886 887 888 889 890 891 892 893 894 895 896 897 898 899 900 901 902 903 904 905 906 907 908 909 910 911 912 913 914 915 916 917 918 919 920 921 922 923 924 925 926 927 928 929 930 931 932 933 934 935 936 937 938 939 940 941 942 943 944 945 946 947 948 949 950 951 952 953 954 955 956 957 958 959 960 961 962 963 964 965 966 967 968 969 970 971 972 973 974 975 976 977 978 979 980 981 982 983 984 985 986 987 988 989 990 991 992 993 994 995 996 997 998 999 1000 1001 1002 1003 1004 1005 1006 1007 1008 1009 1010 1011 1012 1013 1014 1015 1016 1017 1018 1019 1020 1021 1022 1023 1024 1025 1026 1027 1028 1029 1030 1031 1032 1033 1034 1035 1036 1037 1038 1039 1040 1041 1042 1043 1044 10

Chemical shift, δ , ppm	Assignment
10.0	CHO
7.7	CHO
7.6	CHO
7.5	CHO
7.4	CHO
7.3	CHO
7.2	CHO
7.1	CHO
7.0	CHO
6.9	CHO
6.8	CHO
6.7	CHO
6.6	CHO
6.5	CHO
6.4	CHO
6.3	CHO
6.2	CHO
6.1	CHO
6.0	CHO
5.9	CHO
5.8	CHO
5.7	CHO
5.6	CHO
5.5	CHO
5.4	CHO
5.3	CHO
5.2	CHO
5.1	CHO
5.0	CHO
4.9	CHO
4.8	CHO
4.7	CHO
4.6	CHO
4.5	CHO
4.4	CHO
4.3	CHO
4.2	CHO
4.1	CHO
4.0	CHO
3.9	CHO
3.8	CHO
3.7	CHO
3.6	CHO
3.5	CHO
3.4	CHO
3.3	CHO
3.2	CHO
3.1	CHO
3.0	CHO
2.9	CHO
2.8	CHO
2.7	CHO
2.6	CHO
2.5	CHO
2.4	CHO
2.3	CHO
2.2	CHO
2.1	CHO
2.0	CHO
1.9	CHO
1.8	CHO
1.7	CHO
1.6	CHO
1.5	CHO
1.4	CHO
1.3	CHO
1.2	CHO
1.1	CHO
1.0	CHO
0.9	CHO
0.8	CHO
0.7	CHO
0.6	CHO
0.5	CHO
0.4	CHO
0.3	CHO
0.2	CHO
0.1	CHO
0.0	CHO

[illegible][illegible]

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	52
--	---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----

002

200	5.7 = 8	1000
1000		

NO.	DATE	TIME	NAME
002	8-8-0	PM	NOX

%	CO ₂	8 = 8.2	ppm	NOX

2.00% 8 = 8.0 PPM 100%

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	5
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	---

0.02	0.05	0.10	0.20	0.30	0.40	0.50	0.60	0.70	0.80	0.90	1.00
0.02	0.05	0.10	0.20	0.30	0.40	0.50	0.60	0.70	0.80	0.90	1.00

Year	1962	1963	1964	1965	1966	1967	1968	1969	1970	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093	2094	2095	2096	2097	2098	2099	2100																																																																																																																																																																	
Population	42	44	46	48	50	52	54	56	58	60	62	64	66	68	70	72	74	76	78	80	82	84	86	88	90	92	94	96	98	100	102	104	106	108	110	112	114	116	118	120	122	124	126	128	130	132	134	136	138	140	142	144	146	148	150	152	154	156	158	160	162	164	166	168	170	172	174	176	178	180	182	184	186	188	190	192	194	196	198	200	202	204	206	208	210	212	214	216	218	220	222	224	226	228	230	232	234	236	238	240	242	244	246	248	250	252	254	256	258	260	262	264	266	268	270	272	274	276	278	280	282	284	286	288	290	292	294	296	298	300	302	304	306	308	310	312	314	316	318	320	322	324	326	328	330	332	334	336	338	340	342	344	346	348	350	352	354	356	358	360	362	364	366	368	370	372	374	376	378	380	382	384	386	388	390	392	394	396	398	400	402	404	406	408	410	412	414	416	418	420	422	424	426	428	430	432	434	436	438	440	442	444	446	448	450	452	454	456	458	460	462	464	466	468	470	472	474	476	478	480	482	484	486	488	490	492	494	496	498	500	502	504	506	508	510	512	514	516	518	520	522	524	526	528	530	532	534	536	538	540	542	544	546	548	550	552	554	556	558	560	562	564	566	568	570	572	574	576	578	580	582	584	586	588	590	592	594	596	598	600	602	604	606	608	610	612	614	616	618	620	622	624	626	628	630	632	634	636	638	64

%	CO ₂	g = 7.4	ppm	NOX%
	0.02			

λ	$\theta = 8.0^\circ$	ρ_{H}	HOKK
062			

%	CO ₂	$\delta = 7.5$	ppm	NOX
100	100	100	100	100
90	90	90	90	90
80	80	80	80	80
70	70	70	70	70
60	60	60	60	60
50	50	50	50	50
40	40	40	40	40
30	30	30	30	30
20	20	20	20	20
10	10	10	10	10
0	0	0	0	0

δ	CO_2	H_2O	ppm	HONH
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				
47				
48				
49				
50				
51				
52				
53				
54				
55				
56				
57				
58				
59				
60				
61				
62				
63				
64				
65				
66				
67				
68				
69				
70				
71				
72				
73				
74				
75				
76				
77				
78				
79				
80				
81				
82				
83				
84				
85				
86				
87				
88				
89				
90				
91				
92				
93				
94				
95				
96				
97				
98				
99				
100				

[illegible][illegible]

100

150

151

DATE	TIME	CONC	UNIT	PPM	NOX	PPM	NOX
9/00T/96	14:21.5	%	02				
1 = 10.3		%	02				
9/00T/96	14:51.35	%	02				
1 = 10.4		%	02				
9/00T/96	14:51.5	%	02				
1 = 10.4		%	02				
9/00T/96	14:51.35	%	02				
1 = 10.3		%	02				
9/00T/96	14:51.5	%	02				
100 FGS	90		80				
0 COMPLIANCE RUN-3	20		20				
1 = 0		%	02				
9/00T/96	13:36.15	%	02				
1 = 0		%	02				
9/00T/96	13:36.4	%	02				
1 = 0		%	02				
9/00T/96	13:36.52	%	02				
54.8 PPM NOX							
1 = 0		%	02				
9/00T/96	13:28.57	%	02				
1 = 0		%	02				
9/00T/96	13:28.45	%	02				
1 = 0		%	02				
9/00T/96	13:28.33	%	02				
10.0% 0021 ZERO	02						
1 = 11.0		%	02				
9/00T/96	13:24.52	%	02				
1 = 11.0		%	02				

9/00T/96	14.17	35	02	6 = 9.1	%	CO2	8 = 8.2	PPM	NOX
1 = 18.7	%								
9/00T/96	14.17	5	02	6 = 9.2	%	CO2	8 = 8.5	PPM	NOX
1 = 18.7	%								
9/00T/96	14.16	35	02	6 = 9.3	%	CO2	8 = 8.6	PPM	NOX
1 = 18.5	%								
9/00T/96	14.16	5	02	6 = 9.2	%	CO2	8 = 8.6	PPM	NOX
1 = 18.5	%								
9/00T/96	14.16	35	02	6 = 9.3	%	CO2	8 = 8.1	PPM	NOX
1 = 18.2	%								
9/00T/96	14.16	5	02	6 = 9.2	%	CO2	8 = 8.5	PPM	NOX
1 = 18.5	%								
9/00T/96	14.14	35	02	6 = 9.3	%	CO2	8 = 8.5	PPM	NOX
1 = 18.5	%								
9/00T/96	14.14	5	02	6 = 9.1	%	CO2	8 = 8.2	PPM	NOX
1 = 18.8	%								
9/00T/96	14.13	35	02	6 = 9.2	%	CO2	8 = 8.3	PPM	NOX
1 = 18.5	%								
9/00T/96	14.13	5	02	6 = 9.2	%	CO2	8 = 8.3	PPM	NOX
1 = 18.7	%								
9/00T/96	14.12	35	02	6 = 9.1	%	CO2	8 = 8.6	PPM	NOX
1 = 18.7	%								
9/00T/96	14.12	5	02	6 = 9.3	%	CO2	8 = 8.8	PPM	NOX
1 = 18.5	%								
9/00T/96	14.11	35	02	6 = 9.4	%	CO2	8 = 8.8	PPM	NOX
1 = 18.3	%								
9/00T/96	14.10	35	02	6 = 9.2	%	CO2	8 = 8.8	PPM	NOX
1 = 18.6	%								
9/00T/96	14.10	5	02	6 = 9.3	%	CO2	8 = 8.8	PPM	NOX
1 = 18.6	%								
9/00T/96	14.9	35	02	6 = 9.1	%	CO2	8 = 8.4	PPM	NOX
1 = 18.8	%								
9/00T/96	14.9	5	02	6 = 9.3	%	CO2	8 = 8.7	PPM	NOX
1 = 18.9	%								
9/00T/96	14.8	35	02	6 = 9.3	%	CO2	8 = 8.7	PPM	NOX
1 = 18.5	%								
9/00T/96	14.8	5	02	6 = 9.4	%	CO2	8 = 8.8	PPM	NOX
1 = 18.6	%								
9/00T/96	14.8	35	02	6 = 9.4	%	CO2	8 = 8.8	PPM	NOX
1 = 18.6	%								
9/00T/96	14.8	5	02	6 = 9.4	%	CO2	8 = 8.8	PPM	NOX
1 = 18.6	%								
9/00T/96	14.8	35	02	6 = 9.4	%	CO2	8 = 8.8	PPM	NOX
1 = 18.6	%								
9/00T/96	14.8	5	02	6 = 9.4	%	CO2	8 = 8.8	PPM	NOX
1 = 18.6	%								

1 = 3	%	02	6 = 9.5	100	90	80	70	60
9/00/95 14:44 10	%	02	6 = 9.4					
1 = 10.5	%	02	6 = 9.4					
9/00T/95 14:43 40	%							
RESUME TEST								
1 = 10.5	%	02	6 = 9.4					
9/00T/95 14:39 43	%							
1 = 11.0	%	02	6 = 9.9					
9/00T/95 14:39 13	%							
1 = 10.5	%	02	6 = 9.3					
9/00T/95 14:38 43	%							
1 = 13.3	%	02	6 = 8.0					
9/00T/95 14:38 13	%							
RECORDER DATA LOGGER VRS 51-1-1								
1 = 10.5	%	02	6 = 9.4					
9/00T/95 14:34 5	%							
1 = 10.4	%	02	6 = 9.4					
9/00T/95 14:33 35	%							
1 = 10.5	%	02	6 = 9.3					
9/00T/95 14:33 5	%							
1 = 10.5	%	02	6 = 9.4					
9/00T/95 14:32 35	%							
1 = 10.5	%	02	6 = 9.2					
9/00T/95 14:32 5	%							
1 = 10.3	%	02	6 = 9.1					
9/00T/95 14:31 35	%							
1 = 10.5	%	02	6 = 9.3					
9/00T/95 14:31 5	%							
1 = 10.5	%	02	6 = 9.3					
9/00T/95 14:30 35	%							
1 = 10.7	%	02	6 = 9.2					
9/00T/95 14:30 5	%							
1 = 10.5	%	02	6 = 9.5					
9/00T/95 14:29 35	%							
1 = 10.7	%	02	6 = 9.2					
9/00T/95 14:29 5	%							
1 = 10.4	%	02	6 = 9.4					

1	6	%	02	6 = 9.2	%	02	8 = 7.8	PPM	NOX
9'00"	156	15.15.40	02	6 = 9.2	%	C02	8 = 7.9	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.15.10	02	6 = 9.2	%	C02	8 = 7.6	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.14.40	02	6 = 9.4	%	C02	8 = 8.4	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.14.10	02	6 = 9.2	%	C02	8 = 7.8	PPM	NOX
1 = 10.7	%		02	6 = 9.2	%				
9'00"	156	15.13.40	02	6 = 9.1	%	C02	8 = 7.8	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.13.10	02	6 = 9.2	%	C02	8 = 7.9	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.12.40	02	6 = 9.2	%	C02	8 = 8.0	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.12.10	02	6 = 9.3	%	C02	8 = 7.7	PPM	NOX
1 = 10.6	%		02	6 = 9.3	%				
9'00"	156	15.11.40	02	6 = 9.3	%	C02	8 = 7.9	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.11.10	02	6 = 9.2	%	C02	8 = 7.8	PPM	NOX
1 = 10.7	%		02	6 = 9.2	%				
9'00"	156	15.10.40	02	6 = 9.60	%	50C02	8 = 8.0	PPM	NOX
1 = 10.790	%		02	6 = 9.40	%	50	70	80	90
0 9'00"	156	15.10.10	20	30	%	C02	8 = 7.6	PPM	NOX
1 = 10.7	%		02	6 = 9.1	%				
9'00"	156	15.9.40	02	6 = 9.8	%	C02	8 = 8.1	PPM	NOX
1 = 10.5	%		02	6 = 8.9	%				
9'00"	156	15.9.10	02	6 = 8.9	%	C02	8 = 7.7	PPM	NOX
1 = 11.0	%		02	6 = 9.1	%				
9'00"	156	15.9.40	02	6 = 9.1	%	C02	8 = 7.3	PPM	NOX
1 = 10.7	%		02	6 = 9.2	%				
9'00"	156	15.8.10	02	6 = 9.2	%	C02	8 = 7.6	PPM	NOX
1 = 10.6	%		02	6 = 9.1	%				
9'00"	156	15.7.40	02	6 = 9.1	%	C02	8 = 7.3	PPM	NOX
1 = 10.6	%		02	6 = 9.4	%				
9'00"	156	15.7.10	02	6 = 9.2	%	C02	8 = 8.5	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.6.40	02	6 = 9.2	%	C02	8 = 7.8	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.6.10	02	6 = 9.2	%	C02	8 = 7.8	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				
9'00"	156	15.5.10	02	6 = 9.2	%	C02	8 = 7.8	PPM	NOX
1 = 10.6	%		02	6 = 9.2	%				

64.8 PPM NOX

1 = 6.1 % 02

9/00T/96 15:25 2

1 = 6.1 % 02

9/00T/96 15:25 60

1 = 6.1 % 02

9/00T/96 15:25 38

6 % CO2: ZERO 02

1 = 11.6 % 02

9/00T/96 15:20 23

1 = 11.1 % 02

9/00T/96 15:20 11

1 = 11.1 % 02

9/00T/96 15:19 59

11.6 % CO2: ZERO CO2 AND NOX

STACK BIAS CHECKS

END OF RUN-3

00 = 10.690 % 020

0 9/00T/96 15:17 40 20

1 = 10.4 % 02

9/00T/96 15:17 10

1 = 10.6 % 02

9/00T/96 15:15 40

1 = 10.7 % 02

9/00T/96 15:15 18

1 = 10.6 % 02

9/00T/96 15:15 40

1 = 10.6 % 02

6 = 9.8 % CO2

8 = 6.1 PPM NOX

6 = 9.9 % CO2

8 = 6.1 PPM NOX

6 = 9.8 % CO2

8 = 6.1 PPM NOX

6 = 9.8 % CO2

8 = 6.1 PPM NOX

6 = 9.8 % CO2

8 = 6.1 PPM NOX

6 = 9.8 % CO2

8 = 6.1 PPM NOX

6 = 9.80 % CO2

8 = 30.8 PPM NOX

6 = 9.2 % CO2

8 = 8.1 PPM NOX

6 = 9.2 % CO2

8 = 8.9 PPM NOX

6 = 9.1 % CO2

8 = 7.5 PPM NOX

6 = 9.2 % CO2

8 = 7.6 PPM NOX

6 = 9.2 % CO2

8 = 7.9 PPM NOX

6 = 9.2 % CO2

8 = 7.9 PPM NOX

6 = 9.2 % CO2

8 = 7.9 PPM NOX

6 = 9.2 % CO2

8 = 7.9 PPM NOX

6 = 9.2 % CO2

8 = 7.9 PPM NOX

6 = 9.2 % CO2

8 = 7.9 PPM NOX


15 68

· APPENDIX VII

LABORATORY DATA

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 07:42:52
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 2617 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG20 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

161




Component	Number	Retention	Height	Area	Area %
Methane	1	1.450	470.645	1488.52	100.00
	1			1488.52	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 07:49:52
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 2617 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG21 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

162




Component	Number	Retention	Height	Area	Area %
Methane (unknown)	1	1.466	472.740	1453.05	99.13
	0	1.816	1.378	12.81	0.87
	2			1465.85	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 07:55:19
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 4916 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG22 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

163




Component	Number	Retention	Height	Area	Area %
Methane	1	1.450	925.546	3282.87	98.77
(unknown)	0	1.833	2.716	40.78	1.23
	2			3323.65	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 08:00:34
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 4916 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG23 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1


164



Component	Number	Retention	Height	Area	Area %
Methane (unknown)	1	1.466	895.902	3178.26	98.96
	0	1.850	2.699	33.48	1.04
	2			3211.74	100.00

Undetected components:


Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 08:07:23
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 9175 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG24 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1



Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	1655.803	5020.23	98.71
(unknown)	0	1.866	3.999	65.55	1.29
	2			5085.78	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 08:13:22
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 9175 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG25 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 lml On-Column Injections, Atten.=1




Component	Number	Retention	Height	Area	Area %
Methane (unknown)	1	1.466	1713.220	5132.38	99.35
	0	1.866	3.376	33.78	0.65
	2			5166.16	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 08:19:58
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG26 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

167




Component	Number	Retention	Height	Area	Area %
(unknown)	0	4.416	0.251	11.79	100.00
	1			11.79	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 08:27:47
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG27 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

168




Component	Number	Retention	Height	Area	Area %
(unknown)	0	5.433	0.342	12.57	100.00
	1			12.57	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 08:58:23
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 9175 ppmv CH4 Bias Cal.
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG30 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

169




Component	Number	Retention	Height	Area	Area %
Methane	1	1.450	1641.940	5037.99	100.00
	1			5037.99	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 09:04:23
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 9175 ppmv CH4 Bias Cal.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG31 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

170




Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	1647.530	5042.94	100.00
	1			5042.94	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 10:08:08
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG35 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 ml On-Column Injections, Atten.=1

171



Component	Number	Retention	Height	Area	Area %
Methane	1	1.500	5008.310	29974.67	98.23
(unknown)	0	4.066	21.459	528.19	1.73
(unknown)	0	5.466	0.502	11.90	0.04


3

30514.76 100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 10:23:11
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-1
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG37 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

172




Component	Number	Retention	Height	Area	Area %
(unknown)	0	0.750	0.515	13.08	0.04
Methane	1	1.450	5007.827	35599.77	98.67
(unknown)	0	4.033	19.649	468.36	1.30
	3			36081.21	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 10:30:45
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG38 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

173




Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	5007.512	35355.45	98.58
(unknown)	0	4.066	20.270	509.80	1.42
	2			35865.25	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 10:45:43
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Control file : DEFAULT.CON
 Data file : MFG40 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

174




Component	Number	Retention	Height	Area	Area %
Methane	1	1.450	5008.265	37437.31	98.67
(unknown)	0	4.050	19.739	504.86	1.33
	2			37942.18	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 10:53:12
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg41 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

175




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.466	5006.681	32540.68	98.52
(unknown)	0	4.033	19.878	487.86	1.48
	2			33028.54	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 11:00:41
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg42 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

176



Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.466	5006.578	31999.44	98.55
(unknown)	0	4.050	19.147	469.37	1.45

2


32468.81 100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 11:51:43
 Method : EPA-18: On-Line GC-FID
 Description : 4916 ppwv Methane Std.
 Column : 60m x 0.53mm RTX-1. 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : mfg53 (c:\peak3\data)
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.-1

177




Component	Number	Retention	Height	Area	Area %
(unknown)	0	0.283	0.000	1.29	0.05
Methane	1	1.483	934.980	2822.62	99.19
(unknown)	0	1.833	2.383	21.63	0.76
				2845.54	100.00

3

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 11:54:59
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 4916 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg54 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

178




Component	Number	Retention	Height	Area	Area %
Methane	1	1.500	832.382	2987.96	100.00
	1			2987.96	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 12:06:40
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg57 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

179




Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

180

Lab name : AirRECON Mobile Lab
Client : LFG Specialties Project
Client ID : AR5-6922
Collected : 10/09/96
Holding time : 48 Hours
Analysis date : 10/09/1996 12:12:24
Method : EPA-18: On-Line GC-FID
Lab ID : Trailer-2
Description : Zero Air Blank
Column : 60m x 0.53mm RTx-1, 5u
Carrier : Helium at 18 psi
Components : CH4_CH2.CPT
Control file : DEFAULT.CON
Data file : mfg58 (c:\peak3\data)
Sample : Channel-2
Operator : John R. Geissler
Comments : 20ml/min Total Hydrogen Flow
: 100ml/min Air
: 105 deg. Isothermal Oven
: Backflush To Detector At 2.5 min.
: Based On 0.25 1ml On-Column Injections, Atten.=1




Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 12:38:10
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg62 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

181




Component	Number	Retention	Height	Area	Area %
Methane	1	1.483	5008.142	34060.81	98.73
(unknown)	0	4.050	19.719	439.78	1.27
				34500.60	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 12:44:10
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg63 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

182




Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	5008.214	34446.60	98.83
(unknown)	0	4.066	19.208	406.32	1.17
	2			34852.93	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 12:50:11
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg64 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

183




Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	5008.069	34432.96	98.79
(unknown)	0	4.066	19.538	423.11	1.21
	2			34856.07	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 12:56:12
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg65 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

184




Component	Number	Retention	Height	Area	Area %
Methane	1	1.450	5007.917	30534.58	98.68
(unknown)	0	4.066	18.571	406.91	1.32
				30941.49	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 13:08:14
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg67 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

185




Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	5008.084	31666.26	98.74
(unknown)	0	4.066	18.337	402.48	1.26
				32068.74	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 13:16:20
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg68 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

186



Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	5008.392	32953.93	98.73
(unknown)	0	4.033	19.062	424.56	1.27


2

33378.49 100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 13:37:59
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 4916 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg71 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

187



Component	Number	Retention	Height	Area	Area %
Methane (unknown)	1	1.450	928.050	3489.04	99.32
	0	1.800	2.479	23.98	0.68


3513.02 100.00

2

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 13:45:52
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 4916 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg72 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

188




Component	Number	Retention	Height	Area	Area %
Methane	1	1.450	1016.637	3474.85	99.33
(unknown)	0	1.800	2.422	23.34	0.67
	2			3498.19	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 13:52:59
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg74 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

189




Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 13:58:34
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg75 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

190




Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 14:47:52
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.COM
 Data file : mfg101 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

191



Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.450	5008.549	32855.26	98.85
(unknown)	0	4.050	18.694	346.25	1.04
(unknown)	0	4.300	4.783	34.62	0.10
				33236.13	100.00


3

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 14:53:53
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg102 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

192



Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.466	5008.626	32948.35	98.81
(unknown)	0	4.033	18.872	368.56	1.11
(unknown)	0	4.333	5.019	29.59	0.09
				33346.50	100.00


3

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 14:59:54
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg103 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

193




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.100	0.517	10.07	0.03
Methane	1	1.450	5008.872	32081.62	98.56
(unknown)	0	4.050	19.263	459.87	1.41

32551.55 100.00

3

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 15:05:55
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg104 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1




Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	5008.184	31882.51	98.60
(unknown)	0	4.050	19.919	452.19	1.40

32334.70 100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 15:12:11
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Inlet, Run-3
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg105 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

195




Component	Number	Retention	Height	Area	Area %
Methane	1	1.466	5008.260	32469.12	98.79
(unknown)	0	4.050	18.622	397.48	1.21

32866.60 100.00

2

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 15:32:22
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 4916 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg108 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1




Component	Number	Retention	Height	Area	Area %
Methane	1	1.450	927.879	3484.89	100.00
	1			3484.89	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 15:37:27
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 4916 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg109 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1


197



Component	Number	Retention	Height	Area	Area %
Methane	1	1.450	1016.301	3468.63	100.00
	1			3468.63	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
Client : LFG Specialties Project
Client ID : AR5-6922
Collected : 10/09/96
Holding time : 48 Hours
Analysis date : 10/09/1996 15:43:01
Method : EPA-18: On-Line GC-FID
Lab ID : Trailer-2
Description : Zero Air Blank
Column : 60m x 0.53mm RTx-1, 5u
Carrier : Helium at 18 psi
Components : CH4_CH2.CPT
Control file : DEFAULT.CON
Data file : mfg110 (c:\peak3\data)
Sample : Channel-2
Operator : John R. Geissler
Comments : 20ml/min Total Hydrogen Flow
: 100ml/min Air
: 105 deg. Isothermal Oven
: Backflush To Detector At 2.5 min.
: Based On 0.25 1ml On-Column Injections, Atten.=1




Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Holding time : 48 Hours
 Analysis date : 10/09/1996 15:48:48
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Control file : DEFAULT.CON
 Data file : mfg111 (c:\peak3\data)
 Sample : Channel-2
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 105 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 0.25 1ml On-Column Injections, Atten.=1

199




Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 06:53:23
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Data file : LFG12 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1


200



Component	Number	Retention	Height	Area	Area %
Methane	1	1.750	23.120	116.31	100.00
				116.31	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 07:02:47
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG13 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1



Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.033	0.336	7.09	5.62
Methane	1	1.750	23.100	119.16	94.38


126.25 100.00

2

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 07:07:40
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 51.3 ppmv Methane Std.
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG14 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

201




Component	Number	Retention	Height	Area	Area %
Methane	1	1.750	54.279	286.40	100.00
	1			286.40	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 07:12:12
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 51.3 ppmv Methane Std.
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG15 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

202




Component	Number	Retention	Height	Area	Area %
Methane	1	1.750	53.611	287.57	100.00
	1			287.57	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 07:19:32
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 88.7 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG16 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

203




Component	Number	Retention	Height	Area	Area %
Methane	1	1.750	99.583	535.98	100.00
	1			535.98	100.00

Undetected components:

AirRECON Mobile Lab
 LFG Specialties Project
 AR5-6922
 10/09/1996 07:19:32
 EPA-18: On-Line GC-FID
 Trailer-2
 88.7 ppmv Methane Std.
 60m x 0.53mm RTx-1, 5u
 Helium at 18 psi
 CH4_CH2.CPT
 LFG16 (c:\peak3\data)
 Channel-1
 John R. Geissler
 20ml/min Total Hydrogen Flow
 100ml/min Air
 120 deg. Isothermal Oven
 Backflush To Detector At 2.5 min.
 Based On 1ml On-Column Injections, Atten.=1

Lab name : AirREGON Mobile Lab
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 07:24:53
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 88.7 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Data file : LFG17 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

204




Component	Number	Retention	Height	Area	Area %
Methane	1	1.766	99.772	500.73	100.00
	1			500.73	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 08:19:58
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG26 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

205




Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 08:27:47
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG27 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

206




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.466	0.322	16.39	100.00
	1			16.39	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 08:46:35
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmv CH4 Bias Cal.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Data file : LFG28 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

207




Component	Number	Retention	Height	Area	Area %
Methane	1	1.766	24.698	125.32	100.00
	1			125.32	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 08:50:56
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmv CH4 Bias Cal.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG29 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections. Atten.=1

208




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.100	0.346	11.63	7.87
Methane	1	1.800	25.540	136.14	92.13
	2			147.77	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 10:15:42
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Data file : LFG36 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

209




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.550	5.391	51.86	91.08
Methane	1	1.816	1.014	5.08	8.92
	2			56.94	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 10:30:45
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG38 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

210




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	5.976	53.86	91.42
Methane	1	1.833	0.864	5.05	8.58
	2			58.91	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 10:38:14
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Data file : LFG39 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

211




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.550	5.911	53.93	81.25
(unknown)	0	5.100	0.244	12.45	18.75
	2			66.38	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 10:45:43
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-1
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG40 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

212




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	5.543	51.89	82.74
(unknown)	0	4.050	0.238	10.83	17.26
	2			62.71	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 10:53:12
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : LFG41 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1


213



Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	5.926	52.27	91.12
Methane	1	1.833	0.991	5.10	8.88
	2			57.37	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 11:00:41
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-1
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg42 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	6.467	58.16	100.00
	1			58.16	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 11:20:14
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg45 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

214




Component	Number	Retention	Height	Area	Area %
Methane	1	1.766	22.446	114.45	100.00
				114.45	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 11:24:46
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg46 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections. Atten.=1

215




Component	Number	Retention	Height	Area	Area %
Methane	1	1.750	22.148	118.06	100.00
				118.06	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 12:06:40
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Data file : lfg57 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

216




Component	Number	Retention	Height	Area	Area %
Methane	1	1.783	3.548	15.24	0.00
(unknown)	0	5.683	1868483.	25387006.72	100.00
				25387021.96	100.00

2

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 12:12:24
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg58 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

217




Component	Number	Area
Methane	1	15.11

Component	Number	Retention	Height	Area	Area %
Methane	1	1.766	2.978	15.11	100.00
				15.11	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 12:26:09
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-2
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg60 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

218




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.050	1.766	81.33	65.78
(unknown)	0	1.566	3.870	37.08	29.99
Methane	1	1.850	0.794	5.23	4.23
				123.63	100.00

3

Undetected components:

218A

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 12:32:09
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg61 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.583	5.154	50.40	87.06
Methane	1	1.900	0.822	7.49	12.94
				57.89	100.00

2

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 12:50:11
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg64 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections. Atten.=1

219




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	6.424	56.44	91.81
Methane	1	1.866	0.883	5.04	8.19
				61.48	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 12:56:12
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-2
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4, CH2, CPT
 Data file : lfg65 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

220




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.550	7.118	66.03	92.47
Methane	1	1.850	0.867	5.38	7.53
				71.41	100.00

2

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 13:02:13
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg66 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

221




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	6.056	57.76	88.36
Methane	1	1.833	1.151	7.61	11.64
	2			65.37	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 13:08:14
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-2
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg67 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

222




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	5.939	46.77	80.83
Methane	1	1.833	0.727	5.13	8.86
(unknown)	0	3.583	0.253	5.96	10.31
				57.86	100.00

3

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 13:26:17
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmc Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg69 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

223




Component	Number	Retention	Height	Area	Area %
Methane	1	1.733	24.616	121.37	100.00
				121.37	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 13:31:21
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmc Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg70 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

224




Component	Number	Retention	Height	Area	Area %
Methane	1	1.733	24.089	125.70	100.00
				125.70	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 13:52:59
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4 CH2.CPT
 Data file : lfg74 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

225




Component	Number	Retention	Height	Area	Area %
Methane	1	1.766	6.594	36.02	100.00
				36.02	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 13:58:34
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTX-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4, CH2, CPT
 Data file : lfg75 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

226




Component	Number	Retention	Height	Area	Area %
Methane	1	1.750	5.681	28.31	100.00
				28.31	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 14:05:16
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4, CH2, CPT
 Data file : lfg76 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

227




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.550	7.393	68.67	100.00
	1			68.67	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 14:11:16
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg77 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1



Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	7.450	66.95	100.00
				66.95	100.00


1

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 14:17:17
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4, CH2, CPT
 Data file : lfg78 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

229




Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.566	6.796	59.61	100.00
	1			59.61	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 14:29:19
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg80 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

230



Component	Number	Retention	Height	Area	Area %
(unknown)	0	1.583	6.171	53.80	100.00
				53.80	100.00


1

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 14:47:52
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg101 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

231




Component	Number	Retention	Height	Area	Area %
Methane	1	1.900	0.916	6.05	100.00
	1			6.05	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 15:05:55
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Outlet, Run-3
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg104 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

232




Component	Number	Retention	Height	Area	Area %
(unknown)	0	4.800	0.256	9.60	100.00
	1			9.60	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 15:22:34
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : 21.3 ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg106 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

233




Component	Number	Retention	Height	Area	Area %
Methane	1	1.750	27.733	120.00	0.00
(unknown)	2	3.600	472173.7	36150000.16	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 15:27:49
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : ~~4918~~ ppmv Methane Std.
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg107 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1


234



Component	Number	Retention	Height	Area	Area %
Methane	1	1.750	27.354	128.22	100.00
	1			128.22	100.00

Undetected components:

Lab name : AirRECON Mobile Lab
Client : LFG Specialties Project
Client ID : AR5-6922
Collected : 10/09/96
Analysis date : 10/09/1996 15:43:01
Method : EPA-18: On-Line GC-FID
Lab ID : Trailer-2
Description : Zero Air Blank
Column : 60m x 0.53mm RTx-1, 5u
Carrier : Helium at 18 psi
Components : CH4_CH2.CPT
Data file : lfg110 (c:\peak3\data)
Sample : Channel-1
Operator : John R. Geissler
Comments : 20ml/min Total Hydrogen Flow
: 100ml/min Air
: 120 deg. Isothermal Oven
: Backflush To Detector At 2.5 min.
: Based On 1ml On-Column Injections, Atten.=1




Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

Lab name : AirRECON Mobile Lab
 Client : LFG Specialties Project
 Client ID : AR5-6922
 Collected : 10/09/96
 Analysis date : 10/09/1996 15:48:48
 Method : EPA-18: On-Line GC-FID
 Lab ID : Trailer-2
 Description : Zero Air Blank
 Column : 60m x 0.53mm RTx-1, 5u
 Carrier : Helium at 18 psi
 Components : CH4_CH2.CPT
 Data file : lfg111 (c:\peak3\data)
 Sample : Channel-1
 Operator : John R. Geissler
 Comments : 20ml/min Total Hydrogen Flow
 : 100ml/min Air
 : 120 deg. Isothermal Oven
 : Backflush To Detector At 2.5 min.
 : Based On 1ml On-Column Injections, Atten.=1

236



Component	Number	Retention	Height	Area	Area %
	0			0.00	100.00

Undetected components:

Methane

INLET		OUTLET	
2617 →	1470.79	213 →	117.74
4916 →	3230.57	51.3 →	286.89
9175 →	5076.31	88.7 →	518.36
9175ppm bias → 5040.47		21.3ppm	
98.6%		30.73 bias → 95.0%	
Post R-1 Cal. Check 4916ppm		Post R-1 Check 21.3ppm	
2881.46 → 94.6%		116.26 → 99.4%	
2905.29		Post R-2 Check 21.3ppm	
Post R-2 Cal. Check 4916ppm		123.54 → 97.7%	
3481.95 → 96.3%		Post R-3 Check 21.3ppm	
Post R-3 Cal. Check 4916ppm		124.11 → 97.4%	

INLET		OUTLET	
2617 →	1470.79	213 →	117.74
4916 →	3230.57	51.3 →	286.89
9175 →	5076.31	88.7 →	518.36
9175ppm bias → 5040.47		21.3ppm	
98.6%		30.73 bias → 95.0%	
Post R-1 Cal. Check 4916ppm		Post R-1 Check 21.3ppm	
2881.46 → 94.6%		116.26 → 99.4%	
2905.29		Post R-2 Check 21.3ppm	
Post R-2 Cal. Check 4916ppm		123.54 → 97.7%	
3481.95 → 96.3%		Post R-3 Check 21.3ppm	
Post R-3 Cal. Check 4916ppm		124.11 → 97.4%	

LFG SPECIALTIES
Project

Attn: John R. Geissler

Sample Town: BETHLEHEM, PA
Sample Matrix: GAS

Sample Date:	10/09/96		
Sample ID:	Inlet Run 1		
	Method No.	MDL	
Aqua Air Sample No.:			AA25196
Parameter (Units)			
Methane (%)	NJATM-3	0.01	24.2

SEE ATTACHED LABORATORY INFORMATION SHEET
FOR DEFINITIONS OF SYMBOLS AND QUALIFIERS

Submitted By:

Robert M. Stelma

Robert M. Stelma
Acting Organic Laboratory Manager

Approved By:

Patrick J. Mulrooney

Patrick J. Mulrooney, CIH
Vice President
Laboratory



Raritan, NJ 08869-0130

239

ANALYSIS REPORT

Project No. AR6922

10/30/96

LFG SPECIALTIES

Project

Attn: John R. Geissler

Sample Town: BETHLEHEM, PA

Sample Matrix: GAS

Sample Date:			10/09/96	10/09/96
Sample ID:			Inlet Run 2	Inlet Run 3
	Method No.	MDL		
Aqua Air Sample No.:			AA25197	AA25198
Parameter (Units)				
Methane (%)	NJATM-3	0.01	24.3	24.7

SEE ATTACHED LABORATORY INFORMATION SHEET
FOR DEFINITIONS OF SYMBOLS AND QUALIFIERS

Submitted By:

Robert M. Stelma
Acting Organic Laboratory Manager

Approved By:

Patrick J. Mulrooney, CIH
Vice President
Laboratory

DUE DATE

Check one for laboratory use only:


***** EXTERNAL STANDARD TABLE *****
***** 10-10-1996 21:13:49 Version 5.1.5 ***** 241
* Sample Name: AA25196-6922 Data File: E:OCT1011
* Date: 10-10-1996 21:09:35 Method: CH40106 10-10-1996 20:57:08 # 457
* Interface: 1 Cycle#: 11 Operator RMS Channel#: 0 Vial#: N.A.
* Starting Peak Width: 10 Threshold: .1 Area Threshold: 100

* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S.
* Solvent Description: 5A Molecular Sieve
* Conditions: 100C ISOTHERMAL
* Detector 0: FID Detector 1: None
* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.

Starting Delay: 0.00 Ending retention time: 5.00
Area reject: 100 One sample per 1.000 sec.
Amount injected: 1.00 Dilution factor: 1.00
Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.383	METHANE	24.2237	100.0000	1592411	100828	15.81	1	0	1.5212E-05
TOTAL AMOUNT =			24.2237							

Areas, times, and heights stored in: E:OCT1011.ATC
Data File = E:OCT1011.PTS Printed on 10-10-1996 at 21:13:54
Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
W Value: 6199 uv High Value: 107003 uv Scale factor: 1.0



***** EXTERNAL STANDARD TABLE *****
***** 10-10-1996 21:24:32 Version 5.1.5 *****
* Sample Name: AA25197-6922 *Raw* Data File: E:OCT1013 *
* Date: 10-10-1996 21:20:14 Method: CH40106 10-10-1996 20:57:08 # 457 *
* Interface: 1 Cycle#: 13 Operator RMS Channel#: 0 Vial#: N.A. *
* Starting Peak Width: 10 Threshold: .1 Area Threshold: 100 *


* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S. *
* Solvent Description: 5A Molecular Sieve *
* Conditions: 100C ISOTHERMAL *
* Detector 0: FID Detector 1: None *
* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ. *

Starting Delay: 0.00 Ending retention time: 5.00
Area reject: 100 One sample per 1.000 sec.
Amount injected: 1.00 Dilution factor: 1.00
Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.383	METHANE	24.3789	100.0000%	1502616	101111	15.9 1	1	0	1.5212E-05

TOTAL AMOUNT = 24.3789

Areas, times, and heights stored in: E:OCT1013.ATB
Data File = E:OCT1013.PTS Printed on 10-10-1996 at 21:24:37
Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
L Value: 6200 uv High Value: 107316 uv Scale factor: 1.0




```

*****
***** EXTERNAL STANDARD TABLE *****
***** 10-10-1996 21:29:51 Version 5.1.5 *****
***** Data File: E:\OCT1014\244 *
* Sample Name: AA25197-6922
* Date: 10-10-1996 21:24:57 Method: CH40106 10-10-1996 20:57:08 # 457
* Interface: 1 Cycle#: 14 Operator RMS Channel#: 0 Vial#: N.A.
* Starting Peak Width: 10 Threshold: .1 Area Threshold: 100
*****
* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S.
* Solvent Description: 5A Molecular Sieve
* Conditions: 100C ISOTHERMAL Detector 1: None
* Detector 0: FID
* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.
*****
***** Retention time: 5.00

```

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT	BL	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.383	METHANE	24.1965	100.0000%	1590625	100600	15.81		1	0	1.9212E-05

Areas, times, and heights stored in: E:\OCT1014.ATB
Data File = E:\OCT1014.PTS Printed on 10-10-1996 at 21:29:56
Start time: 0.00 min. Stop time: 6.00 min. Offset: 0 mv.
Value: 6203 uv High Value: 106809 uv Scale factor: 1.0




***** EXTERNAL STANDARD TABLE *****
***** 10-10-1996 21:36:18 Version 5.1.5 *****
* Sample Name: AA25198-6922 Raw Data File: E:OCT1015 245
* Date: 10-10-1996 21:31:33 Method: CH40106 10-10-1996 20:57:08 # 457 *
* Interface: 1 Cycle#: 15 Operator RMS Channel#: 0 Vial#: N.A. *
* Starting Peak Width: 10 Threshold: .1 Area Threshold: 100 *

* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S. *
* Solvent Description: 5A Molecular Sieve *
* Conditions: 100C ISOTHERMAL *
* Detector 0: FID Detector 1: None *
* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ. *

Starting Delay: 0.00 Ending retention time: 5.00
Area reject: 100 One sample per: 1.000 sec.
Amount injected: 1.00 Dilution factor: 1.00
Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT	BL	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.383	METHANE	24.6744	100.0000%	1622039	102305	15.9	1	1	0	1.5212E-05
TOTAL AMOUNT =			24.6744								

Areas, times, and heights stored in: E:OCT1015.ATS
Data File = E:OCT1015.PTS Printed on 10-10-1996 at 21:36:23
Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
Value: 6199 uv High Value: 103509 uv Scale factor: 1.0




***** EXTERNAL STANDARD TABLE *****
 ***** 10-10-1996 21:41:44 Version 5.1.5 ***** 246
 * Sample Name: AA25198-6922 Raw Data File: E:OCT1016 *
 * Date: 10-10-1996 21:36:42 Method: CH40106 10-10-1996 20:57:08 # 457 *
 * Interface: 1 Cycle#: 16 Operator RMS Channel#: 0 Vial#: N.A. *
 * Starting Peak Width: 10 Threshold: .1 Area Threshold: 100 *

 * Instrument Type: TRACOR S40 GC Column Type: 8'x 1/8" S.S. *
 * Solvent Description: 5A Molecular Sieve *
 * Conditions: 100C ISOTHERMAL *
 * Detector 0: FID Detector 1: None *
 * Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ. *

Starting Delay: 0.00 Ending retention time: 5.00
 Area reject: 100 One sample per 1.000 sec.
 Amount injected: 1.00 Dilution factor: 1.00
 Sample Weight: 1.00000

EAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.383	METHANE	24.5906	100.0000%	1623109	102342	15.91	1	0	1.5212E-05
TOTAL AMOUNT =			24.5906							

Areas, times, and heights stored in: E:OCT1016.AT2
 Data File = E:OCT1016.PTS Printed on 10-10-1996 at 21:41:43
 Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
 Value: 6200 uv High Value: 103547 uv Scale factor: 1.0



EXTERNAL STANDARD TABLE


```

***** 10-10-1996 21:49:08 Version 5.1.5 ***** 247 *****
* Sample Name: 29.5% CH4 CHK STD.
* Date: 10-10-1996 21:44:11 Method: CH40106
* Interface: 1 Cycles: 17 Operator RMS Channel#: 0 Vial#: N.A.
* Starting Peak Width: 10 Threshold: .1 Area Threshold: 100
*****
* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S.
* Solvent Description: 5A Molecular Sieve
* Conditions: 100C ISOTHERMAL
* Detector 0: FID
* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.
* Detector 1: None
*****
Starting Delay: 0.00 Ending retention time: 5.00
Area reject: 100 One sample per 1.000 sec.
Amount injected: 1.00 Dilution factor: 1.00
Sample Weight: 1.00000

```

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT 3L	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.367	METHANE	30.1563	100.0000%	1982442	120484	16.5 1	1	0	1.5213E-05
TOTAL AMOUNT =			30.1563							

Areas, times, and heights stored in: E:\OCT1017.AT3
Data File = E:\OCT1017.PTS Printed on 10-10-1996 at 21:49:12
Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 min.
Low Value: 6197 uv High Value: 126637 uv Scale factor: 1.0



***** EXTERNAL STANDARD TABLE *****
***** 10-10-1996 21:54:36 Version 5.1.5 *****
* Sample Name: 29.5% CH4 CHK STD. *Raw Data File: E:OCT1018*
* Date: 10-10-1996 21:49:34 Method: CH40106 10-10-1996 20:57:08 # **248**
* Interface: 1 Cycle#: 18 Operator RMS Channel#: 0 Vial#: N.A.
* Starting Peak Width: 10 Threshold: .1 Area Threshold: 100


* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S.
* Solvent Description: SA Molecular Sieve
* Conditions: 100C ISOTHERMAL
* Detector 0: FID Detector 1: None
* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.

Starting Delay: 0.00 Ending retention time: 5.00
Area reject: 100 One sample per 1.000 sec.
Amount injected: 1.00 Dilution factor: 1.00
Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION In %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.367	METHANE	30.1332	100.0000	1984173	120379	16.51	1	0	1.5212E-05

TOTAL AMOUNT = 30.1332

Areas, times, and heights stored in: E:OCT1018.ATB
Data File = E:OCT1018.PTS Printed on 10-10-1996 at 21:54:40
Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
Value: 6198 uv High Value: 126583 uv Scale factor: 1.0



OCTOBER 10, 1996

249

ANALYTICAL CONDITIONS

TRACOR 540 GC W/FIS INPUT ATTEN: 100X

8' x 1/8" S.S. COLUMN

5A MOLECULAR SIEVE

100°C ISOTHERMAL

150°C INJECTOR TEMP.

250°C DETECTOR TEMP.

H₂ - 30 CC/MIN. AIR - 400 CC/MIN

He - CARRIER GAS - RATIO = 3.0

1 μl INJECTIONS

STANDARDS PREPARATIONHIGH - 60.4% METHANE BAL. N₂ LIQUID CARBON DIOXIDEMED - 29.59% METHANE BAL. N₂ LIQUID CARBON DIOXIDE

LOW - 2X DILUTION OF MED STANDARD

Continued on Page _____

Read and Understood By _____

R. M. H. H.

Signed

10/10/96

Date

Signed _____

Date _____

Method CH40106

Sample METHANE


RMS Operator RMS

Run date 10-10-1996 20:57:08 version: 457

Printed on 10-10-1996 AT 20:57:32

Straight Line Fit forced through Origin.

250



Component 1 = METHANE
EXTERNAL STANDARD CALIBRATION

LEVEL	AMOUNT	AREA
1	14.7500	959931
2	29.5000	1968037
3	60.4000	3958833

Y = SLOPE * X + INTERCEPT


Area = 6.5738E+04 * Amount + 0.0000E+00
Amount = 1.5212E-05 * Area + 0.0000E+00
R squared = 0.9998

EXTERNAL STANDARD TABLE

***** 10-00-1996 21:01:45 Version 5.1.5 *****
 * Sample Name: 14.75% CH4 STD. Data File: E:OCT103
 * Date: 10-00-1996 20:19:43 Method: E:CH40106 10-00-1996 20:57:08 # 457
 * Interface: 1 Cycle#: 3 Operator RMS Channel#: 0 Vial#: N.A.
 * Starting Peak Width: 10 Threshold: .1 Area Threshold: 100
 * Instrument Type: TRACOR 540 GC Column Type: 3'x 1/8" S.S.
 * Solvent Description: 5A Molecular Sieve
 * Conditions: 100C ISOTHERMAL
 * Detector 0: FID Detector 1: None
 * Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.
 * Starting Delay: 0.00 Ending retention time: 5.00
 * Area reject: 100 One sample per 1.000 sec.
 * Amount injected: 1.00 Dilution factor: 1.00
 * Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT BL	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.417	METHANE	14.5846	100.0000%	958758	64629	14.3 1	1	3	1.5212E-05
TOTAL AMOUNT =			14.5846							

Data File = E:OCT103.PTS Printed on 10-00-1996 at 21:01:49
 Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
 Low Value: 6201 uv High Value: 70316 uv Scale factor: 1.0



***** EXTERNAL STANDARD TABLE *****

***** 10-10-1996 21:01:56 Version 5.1.5 *****

* Sample Name: 14.75% CH4 STD. *gas* Data File: E:OCT104 252

* Date: 10-10-1996 20:26:25 Method: E:CH40106 10-06-1996 20:57:08 # 457

* Interface: 1 Cycle#: 4 Operator RMS Channel#: 0 Vial#: N.A.

* Integrating Peak Width: 10 Threshold: .1 Area Threshold: 100

* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S.

* Solvent Description: 5A Molecular Sieve

* Conditions: 100C ISOTHERMAL

* Detector 0: FID Detector 1: None

* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.

Starting Delay: 0.00 Ending retention time: 5.00

Area reject: 100 One sample per 1.000 sec.

Amount injected: 1.00 Dilution factor: 1.00

Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT BL	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.417	METHANE	14.5203	100.0000%	961104	64390	14.91	1	0	1.5212E-05


TOTAL AMOUNT = 14.5203

gas

Data File = E:OCT104.PTS Printed on 10-10-1996 at 21:01:59

Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.

Low Value: 6198 uv High Value: 70594 uv Scale factor: 1.0



EXTERNAL STANDARD TABLE

***** 10-00-1996 21:02:20 Version 5.1.5 *****

Sample Name: 29.5% CH4 STD. RMS Data File: E:OCT105

Date: 10-00-1996 20:34:12 Method: E:CH40106 10-00-1996 20:57:08 # 457*

Interface: 1 Cycle#: 5 Operator RMS Channel#: 0 Vial#: N.A. *

Starting Peak Width: 10 Threshold: .1 Area Threshold: 100 *

Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S. *

Solvent Description: 5A Molecular Sieve *

Conditions: 100C ISOTHERMAL *

Detector 0: FID Detector 1: None *

Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ. *

Starting Delay: 0.00 Ending retention time: 5.00

Area reject: 100 One sample per 1.000 sec.

Amount injected: 1.00 Dilution factor: 1.00

Sample Weight: 1.00000


PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.367	METHANE	30.0176	100.0000%	1973289	121173	16.31	1	0	1.5212E-05

TOTAL AMOUNT = 30.0176

Data File = E:OCT105.PTS Printed on 10-00-1996 at 21:02:43

Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.

Low Value: 6201 uv High Value: 127379 uv Scale factor: 1.0



***** ^{RMS} EXTERNAL STANDARD TABLE *****

***** 10-00-1996 21:03:14 Version 5.1.5 *****

25

* Sample Name: 29.5% CH4 STD. ^{RMS} Data File: E:OCT106
 * Date: 10-00-1996 20:39:21 Method: E:CH40106 10-00-1996 20:57:08 # 457*
 * Interface: 1 Cycle#: 6 Operator RMS Channel#: 0 Vial#: N.A.
 * Starting Peak Width: 10 Threshold: .1 Area Threshold: 100


 * Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S.
 * Solvent Description: 5A Molecular Sieve
 * Conditions: 100C ISOTHERMAL
 * Detector 0: FID Detector 1: None
 * Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.

Starting Delay: 0.00 Ending retention time: 5.00
 Area reject: 100 One sample per 1.000 sec.
 Amount injected: 1.00 Dilution factor: 1.00
 Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT	BL	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.367	METHANE	29.8578	100.0000%	1962784	120157	16.3	1	1	0	1.5212E-05

TOTAL AMOUNT = 29.8578

Data File = E:OCT106.PTS Printed on 10-00-1996 at 21:03:35
 Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 inv.
 Low Value: 6202 uv High Value: 126365 uv Scale factor: 1.0




275

255

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT BL	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.300	METHANE	50.2611	100.0000%	3951433	214641	18.5 1	1	0	1.5212E-05

Data File = E:\OCT107.PTS Printed on 10-15-1996 at 21:04:29
Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
Low Value: 6201 uv High Value: 220846 uv Scale factor: 1.0



EXTERNAL STANDARD TABLE


256

***** 10-00-1996 21:04:58 Version 5.1.5 *****
 * Sample Name: 60.4% CH4 STD. *RMS* Data File: E:OCT108
 * Date: 10-00-1996 20:50:11 Method: E:CH40106 10-00-1996 20:57:08 # 457*
 * Interface: 1 Cycle#: 8 Operator RMS Channel#: 0 Vial#: N.A.
 * Starting Peak Width: 10 Threshold: .1 Area Threshold: 100
 * Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S.
 * Solvent Description: 5A Molecular Sieve
 * Conditions: 100C ISOTHERMAL
 * Detector 0: FID Detector 1: None
 * Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.
 * Starting Delay: 0.00 Ending retention time: 5.00
 * Area reject: 100 One sample per 1.000 sec.
 * Amount injected: 1.00 Dilution factor: 1.00
 * Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	AREA/ HEIGHT	HEIGHT BL	REF PEAK	% DELTA RET TIME	CONC/AREA
1	1.300	METHANE	60.1835	100.0000%	3956332	214816	18.4	1	0	1.5212E-95

TOTAL AMOUNT = 60.1835

RMS
 Data File = E:OCT108.PTS Printed on 10-00-1996 at 21:05:25
 Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
 Low Value: 6204 uv High Value: 221025 uv Scale factor: 1.0



***** ^{RMS}EXTERNAL STANDARD TABLE ***** 257

***** 10-00-1996 21:00:36 Version 5.1.5 *****

* Sample Name: METHOD BLANK ^{RMS}Data File: E:OCT109 *
* Date: 10-00-1996 20:55:39 Method: CH40106 10-00-1996 20:57:03 # 457 *
* Interface: 1 Cycle#: 9 Operator RMS Channel#: 0 Vial#: N.A. *
* Starting Peak Width: 10 Threshold: .1 Area Threshold: 100 *

* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S. *
* Solvent Description: 5A Molecular Sieve *
* Conditions: 100C ISOTHERMAL *
* Detector 0: FID Detector 1: None *
* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ. *


Starting Delay: 0.00 Ending retention time: 5.00
Area reject: 100 One sample per 1.000 sec.
Amount injected: 1.00 Dilution factor: 1.00
Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT BL	REF PEAK	% DELTA RET TIME	CONC/AREA
-------------	-------------	--------------	-----------------------	--------------------	------	--------	--------------------	-------------	---------------------	-----------

TOTAL AMOUNT = 0.0000

PEAKS NOT FOUND IN THIS RUN
NAME ADJUSTED RET.TIME. REFERENCE PEAK
METHANE 1.35 METHANE

Areas, times, and heights stored in: E:OCT109.ATB
Data File = E:OCT109.PTS Printed on 10-05-1996 at 21:00:41
Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
Low Value: 6200 uv High Value: 6216 uv Scale factor: 1.0



METHOD BLANK

Processed: 10-05-1996 21:06:04, segment 2, cycle 10

RAW DATA SAVED IN FILE E:OCT1010.PTS

EXTERNAL STANDARD TABLE

258

***** 10-00-1996 21:06:06 Version 5.1.5 *****
Sample Name: METHOD BLANK *RMS* Data File: E:OCT1010
Date: 10-00-1996 21:01:03 Method: CH40106 10-00-1996 20:57:08 # 457
* Interface: 1 Cycle#: 10 Operator RMS Channel#: 0 Vial#: N.A.
* Starting Peak Width: 10 Threshold: .1 Area Threshold: 100

* Instrument Type: TRACOR 540 GC Column Type: 8'x 1/8" S.S.
* Solvent Description: 5A Molecular Sieve
* Conditions: 100C ISOTHERMAL
* Detector 0: FID Detector 1: None
* Misc. Information: He-Carrier Gas-ROTO=3.0, 1ml INJ.


Starting Delay: 0.00 Ending retention time: 5.00
Area reject: 100 One sample per 1.000 sec.
Amount injected: 1.00 Dilution factor: 1.00
Sample Weight: 1.00000

PEAK NUM	RET TIME	PEAK NAME	CONCENTRATION in %	NORMALIZED CONC	AREA	HEIGHT	AREA/ HEIGHT BL	-REF PEAK	% DELTA RET TIME	CONC/AREA
-------------	-------------	--------------	-----------------------	--------------------	------	--------	--------------------	--------------	---------------------	-----------

TOTAL AMOUNT = 0.0000

PEAKS NOT FOUND IN THIS RUN
NAME ADJUSTED RET.TIME. REFERENCE PEAK
METHANE 1.35 METHANE

RMS
Data File = E:OCT1010.PTS Printed on 10-00-1996 at 21:06:20
Start time: 0.00 min. Stop time: 5.00 min. Offset: 0 mv.
Low Value: 6197 uv High Value: 6209 uv Scale factor: 1.0



PLANT BETHLEHEM LAND FILLSTACK INLET

SAMPLE NO. _____

OPERATING CONDITIONS _____

JOB NO. AR5-6922DATE 10/11/96

DRY BASIS

LABORATORY ORSAT OF GC GAS ANALYSIS					
SAMPLE ID	DATE	%CO ₂	%O ₂	%CO	%N ₂ (by difference)
INLET RVN 1	10/9/96	25.4	1.8		
		25.4	1.8		
		75.4	1.8		
SAMPLE ID	DATE	%CO ₂	%O ₂	%CO	%N ₂ (by difference)
INLET RVN 2	10/9/96	25.8	1.4		
		25.8	1.4		
		75.8	1.4		
SAMPLE ID	DATE	%CO ₂	%O ₂	%CO	%N ₂ (by difference)
INLET RVN 3	10/9/96	26.2	1.2		
		26.2	1.2		
		76.2	1.2		
SAMPLE ID	DATE	%CO ₂	%O ₂	%CO	%N ₂ (by difference)
SAMPLE ID	DATE	%CO ₂	%O ₂	%CO	%N ₂ (by difference)
SAMPLE ID	DATE	%CO ₂	%O ₂	%CO	%N ₂ (by difference)
SAMPLE ID	DATE	%CO ₂	%O ₂	%CO	%N ₂ (by difference)

CHEMIST: Bay Sava