

Hartford, 11/93

BID
108

AP42
74

NO_x
CO
NMOC - DE
A

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Compliance Test Report
Hartford Landfill Flare
Emissions Test Program
Hartford, Connecticut

ROJAC *Environmental Services, Inc.*

Leigh A. Gammie
Principal Engineer

Richard A. Kopacz
Project Engineer

ROJAC Project F93-09

November 19, 1993

30 Arbor Street • Hartford, Connecticut 06106 • (203) 232-8959

74

TABLE OF CONTENTS

1.0 INTRODUCTION.....	1
1.1 Summary of Test Program.....	1
1.2 Key Personnel.....	2
2.0 SOURCE AND SAMPLING LOCATION DESCRIPTIONS.....	3
2.1 Source Description.....	3
2.2 Control Equipment.....	4
2.3 Description of Outlet Sampling Location.....	5
2.4 Description of Inlet Sampling Location.....	5
3.0 SUMMARY AND DISCUSSION OF RESULTS.....	8
3.1 Objectives and Test Matrix.....	8
3.2 Field Test Changes And Problems.....	10
3.3 Emissions Test Results.....	10
3.3.1 Continuous Emission Monitoring Summary of Results.....	10
3.3.2 Residence Time Summary of Results.....	12
3.3.3 Non-Methane Organic Compound Summary of Results.....	12
3.3.4 Methane Summary of Results.....	12
3.3.5 Opacity Summary of Results.....	13
3.4 Operational Process Parameters.....	13
4.0 SAMPLING AND ANALYTICAL PROCEDURES.....	14
4.1 Emission Test Methods.....	14
4.1.1 Non-Methane Organic Compounds.....	14
4.1.2 Visible Emissions.....	16
4.1.4 Continuous Emission Monitoring.....	17
4.1.4.1 Instrumentation.....	19
4.1.4.2 Analyzer Calibrations.....	21
4.1.4.3 Data Reduction.....	24
4.2 Sample Identification and Custody.....	26
5.0 QA/QC ACTIVITIES.....	27

LIST OF FIGURES

2-3	Landfill Gas Flare Outlet Sampling Location, Hartford Landfill, Hartford, Connecticut.....	6
2-4	Landfill Gas Flare Inlet Sampling Location, Hartford Landfill, Hartford, Connecticut.....	7
4-1	EPA Method 18, Methane and NMOC Collection Train.....	15
4-2	EPA Methods 3A, 6C, 7E, 10, and 25A, Continuous Emission Monitoring System.....	18
4-3	EPA Conditional Test Method 007, Environics 2020 Computerized Multi-Component Gas Mixer.....	22

LIST OF TABLES

3-1	Emission Measurement Test Matrix, Landfill Gas Flare, Hartford Landfill, Hartford, Connecticut.....	9
3-2	Summary Table of Gaseous Emission Data, Hartford Landfill Flare, Hartford, Connecticut.....	11

LIST OF APPENDICES

A	Test Results and Calculations
B	Field Data Sheets
C	CEM Results and Calibration Data Sheets
D	Equipment Calibrations and EPA Protocol 1 Certification Sheets
E	Laboratory Analysis Reports and Analytical Data Sheets
F	Operational/Process Data

1.0 INTRODUCTION

1.1 Summary of Test Program

ROJAC Environmental Services Inc. (ROJAC) was retained by Connecticut Resources Recovery Authority to conduct an emission measurement test program on a landfill flare located in Hartford, Connecticut. The test program was conducted to comply with State of Connecticut Temporary Permit No. 0120, issued by the Department of Environmental Protection.

Gasses measured at the flare outlet sampling location included oxygen (O_2), nitrogen oxides (NO_x), sulfur dioxide (SO_2), carbon monoxide (CO), total hydrocarbons (THC) including methane and non-methane organic compounds (NMOC). In addition, Tedlar bag samples were taken at the inlet sampling location to determine the NMOC concentration and lower heating values of the landfill gas.

The tests were carried out in conformance with the regulations of the Connecticut Department of Environmental Protection (CTDEP). The objectives were to demonstrate compliance with applicable permit conditions or regulations. The following emission limits applied to this source:

TSP	0.90	pounds per hour
SOx, expressed as SO2	0.26	pounds per hour
NOx, expressed as NO2	3.29	pounds per hour
THC	0.50	pounds per hour
CO	11.35	pounds per hour
Methane	6.14	pounds per hour
Destruction Efficiency of NMOC	98%	
Visible Emissions	not to exceed 5 minutes in any two hour observation period.	

1.2 Key Personnel

The following presents the test program organization and names and phone numbers of responsible individuals:

CRRA	David Martin	203-549-1751
<u>ROJAC Envir. Serv., Inc.</u>	Leigh A. Gammie	203-232-8959
<u>Atlantic Analytical Laboratory</u>	Victor Given	908-534-5600

The ROJAC test team consisted of Messrs. John S. Gammie, Richard A. Kopacz, Thomas E. Conroy, and Ms. Eszter Samodai. Mr. David Martin of CRRA provided onsite assistance, and Mr. Carl Ekroth was the CTDEP observer.

2.0 SOURCE AND SAMPLING LOCATION DESCRIPTIONS

2.1 Process Description

Hartford Landfill, located on 180 East Service Road in Hartford, Connecticut, has installed one LFG Specialties enclosed ground flare for destruction of landfill gas produced onsite. The flare is designed to achieve a minimum NMOC destruction efficiency of 98.0%

The flare is fueled by landfill gas, produced onsite, with a lower heating value (LHV) of 550 Btu per standard cubic foot (Btu/scf). The maximum design fuel flow rate is 1500 standard cubic feet per minute (SCFM), and the maximum fuel firing rate is 49.5 million Btu per hour (MMBtu/hr).

To achieve the minimum destruction efficiency a minimum residence time of 0.6 second is required.

Based on the minimum distance of 25 feet from the stack to the nearest property line, the minimum stack height must be 35.25 feet above grade. The unit is designed to operate 24 hours per day for a total of 8760 hours per year.

The gas collection system, which provides Landfill FG gas to the flare, consists of a series of wells installed in the landfill. The wells are connected to the flare site by a subsurface header system. A centrifugal blower located at the flare site draws LFG through a water knockout and particulate filter and delivers it to the flare where it is combusted.

The flare utilizes an electrically ignited pilot, burning propane, to initiate LFG combustion. Pilot gas is turned off after main flame ignition.

The flare is designed to operate at approximately 1650 degrees Fahrenheit.

The system has been provided with several data gathering and recording features:

- A) Continuous combustion temperature chart recorder.
- B) Inlet gas flow meter. A differential pressure type flow meter is available for the determination of instantaneous inlet gas flow.

2.2 Control Equipment


A process description of the flare operation response and a copy of the blue prints of the process can be found in the appendix section.

2.3 Description of Outlet Sampling Location

The landfill gas flare outlet sampling location was located in a circular 84 inch inner diameter (I.D.) section of vertical stack. A schematic of the sampling location is shown in Figure 2-3. Four sampling ports spaced 90° apart on a horizontal plane were located 300 inches (3.6 duct diameters) downstream from the top of the flare tip and 48 inches (.57 duct diameters) upstream from the top of the stack. EPA Method 1 required the use of twenty four (24) sampling points, twelve (12) sampling points per port for isokinetic sampling.

2.4 Description of Inlet Sampling Location


Figure 2-4 shows a schematic diagram of the inlet location. The inlet location was located in a 7.4 inch I.D. section of horizontal PVC duct. Two sampling ports spaced 90° apart on a vertical plane were located at a minimum of two duct diameters upstream from a 90° bend in the duct and eight duct diameters downstream of the flow sensor.



TRAVERSE POINT NUMBER	TRAVERSE POINT LOCATION FROM STACK WALL (IN.)
1	1.8
2	5.6
3	9.9
4	14.9
5	21.0
6	29.9
7	54.1
8	63.0
9	69.1
10	74.1
11	78.4
12	82.2

FIGURE 2-3

Landfill Gas Flare Outlet Sampling Location
Hartford Landfill
Hartford, Connecticut



TRAVERSE POINT NUMBER	TRAVERSE POINT LOCATION FROM STACK WALL (IN.)
1	0.5
2	1.9
3	5.6
4	6.9

FIGURE 2-4
Landfill Gas Flare Inlet Sampling Location
Hartford landfill
Hartford, Connecticut

3.0 SUMMARY AND DISCUSSION OF RESULTS

3.1 Objectives and Test Matrix

The purpose of the test program was to determine source compliance with applicable permit conditions and/or regulations. The specific objectives in order of priority were:

- * Measured continuous outlet stack emissions of O₂, NO_x, CO, SO₂, and THC according to EPA Methods 3A, 7E, 10, 6C, and 25A (40CFR60 Appendix A - Reference Methods).
- * Sampled outlet stack gas to determine Non-Methane Organic Compounds (NMOC) and Methane stack emissions per EPA Method 18. Volumetric flowrates were performed before and after each integrated bag sample per EPA Method 2. Moisture tests, performed by EPA Method 4, were sampled simultaneously with the NMOC tests (40CFR60 Appendix A - Reference Methods).
- * Sampled landfill gas to determine NMOC and lower heating value per EPA Method 18 and ASTM D3588. Volumetric flowrates were performed before and after each integrated bag sample per EPA Method 2. In addition, moisture tests, performed by EPA Method 4, were sampled simultaneously with the NMOC tests (40CFR60 Appendix A - Reference Methods).
- * The flare's residence time was expressed as the ratio of the flare's volume to the flare's exit gas actual flowrate.
- * Determined visible emissions in accordance with EPA Method 22 (40CFR60 Appendix A - Reference Methods).

Table 3-1 presents the sampling and analytical matrix.

Table 3--1
Emission Measurement Test Matrix
Landfill Gas Flare
Hartford, Connecticut

Sampling Location	No. of Runs	Sample/Type Pollutant	Sampling Method	Sampling Organ.	Sample Run Time (min.)	Analytical Method	Analytical Laboratory
Flare Outlet	3	CEM (NOx, SO2, CO, THC)	M7E, M6C M10, M25A	RES	60	M7E, M6C M10, M25A	RES
	3	CO2, O2	M18	RES	60	Orsat, M3	RES
	3	NMOC & Methane	M18	RES	60	M18	Atlantic
	1	Visible Emissions	M9	RES	120	N/A	N/A
Flare Inlet	3	NMOC	M18	RES	60	M18	Atlantic
	3	LHV	M18	RES	60	M18	Atlantic

RES - ROJAC Environmental Services
Atlantic - Atlantic Analytical Laboratory

3.2 Field Test Changes and Problems

ROJAC Environmental Services, Inc. (ROJAC) performed four (60 minute) Non-Methane Organic Compounds (NMOC) tests as compared to the usual three tests as required by the Connecticut Department of Environmental Protection (CTDEP) agency during the compliance test program. A total of eight gaseous samples were withdrawn from both the inlet and outlet flare sample locations in accordance with EPA Method 18 via Tedlar Bag In A Box sampling apparatus. Since the second inlet bag sample was lost during transport, the fourth inlet bag sample was analyzed in its place, therefore, a total of six bag samples were analyzed by Atlantic Analytical Laboratory.

The particulate tests were not performed as scheduled on November 4, 1993 due to ROJAC's equipment failure.

3.3 Emissions Test Results

3.3.1 Continuous Emission Monitoring Summary of Results

Triplicate sixty minute CEM tests were conducted at the Flare outlet location. The following gases were monitored on November 4, 1993: nitrogen oxide, carbon monoxide, total hydrocarbons, sulfur dioxide, and oxygen. The average total hydrocarbons and the average carbon monoxide emissions were the only gases out of compliance with their respective emission limitations.

	<u>Average Emissions</u>	<u>State Limit</u>
Total Hydrocarbons, (lb/hr)	0.56	0.50
Carbon Monoxide, (lb/hr)	12.0	11.35

The results are summarized in Table 3-2.

TABLE 3-2

SUMMARY TABLE OF GASEOUS EMISSION DATA
HARTFORD LANDFILL FLARE
HARTFORD, CONNECTICUT

Method/Component	Units	Flare Outlet Location			
		Run 1	Run 2	Run 3	Avg
	DATE:	11-04-93	11-04-93	11-04-93	
	TIME:	1140-1240	1315-1415	1435-1535	
Method 2 - Flow	dscfm	9870	10993	9817	10227
	acfm	38552	42890	40515	40721
M3 - CO ₂	%	5.7	5.8	6.0	5.8
M3 - Oxygen	%	13.3	13.2	12.8	13.1
Method 4 - Moisture	%	5.3	7.5	8.6	7.1
Method 18 - NMOC	ppm as Carbon	< 18	< 18	< 18	< 18
Methane	lb/hr as Carbon	< 0.42	< 0.69	< 0.58	< 0.56
Residence Time	seconds	1.8	1.6	1.7	1.7
	TIME:	1048-1148	1220-1320	1335-1455	
Method 25A - THC	ppm as Carbon	22.5	33.6	31.8	29.3
	lb/hr as Carbon	0.42	0.69	0.58	0.56
Method 7E - NO _x	ppm	12.3	12.4	12.6	12.4
	lb/hr	0.9	1.0	0.9	0.9
Method 6C - Sulfur Dioxide	ppm	0.6	2.2	2.6	1.8
	lb/hr	0.1	0.2	0.3	0.2
Method 10 - CO	ppm	240	276	287	268
	lb/hr	10.3	13.3	12.3	12.0

Method/Component	Units	Flare Inlet Location			
		Run 1	Run 2	Run 3	Avg
	DATE:	11-04-93	11-04-93	11-04-93	
	TIME:	1140-1240	1315-1415	1435-1535	
Method 2 - Flow	dscfm	687	692	710	696
	acfm	731	742	753	737
M3 - CO ₂	%	34.2	34.4	35.5	34.7
M3 - Oxygen	%	0.6	1.8	0.6	1.0
Method 4 - Moisture	%	2.7	3.6	2.6	3.0
Method 18 - NMOC	ppm as Carbon	1300 *	1100	1100	1167
Methane	ppm as Carbon	51.8 *	33.5	55.0	46.8
ASTM D3588 - LHV	BTU/cf	513 *	332	545	463

Method/Component	Units	Run 1	Run 2	Run 3	Avg
NMOC Destruction Efficiency	ppm	> 98.62%	> 98.36%	> 98.36%	> 98.46%
Method 22 - Visible Emissions	No visible emissions observed from 1200 hours to 1400 hours				

Note: * (M18-4 Tedlar bag sample was analyzed in place of M18-2 sample due to lost bag through shipment)

Please note, an experimental CEM test (Run No. CEM-4B) was performed on November 4, 1993 from 1559 hours to 1620 hours with the flare operating temperature increased from 1650°F to 1700°F. With the increase in flare operating temperature, the average CO and THC emissions were 2.8 lb/hr and 0.06 lb/hr, respectively.

3.3.2 Residence Time Summary of Results

The average gas residence time in the flare was 1.7 seconds. The results from each test are shown in Table 3-2. Residence time was calculated by the following equation:

$$Rt = Vi / Qi$$

where,

Rt = residence time, seconds.
Qi = actual volumetric flow through flare, cubic feet per second.
Vi = volume of flare, from tip of burner to top of flare, 130 cubic feet.

3.3.3 Non-Methane Organic Compound/Lower Heating Value Summary of Results

The average Non-Methane Organic Compounds (NMOC) destruction efficiency was 98.5 percent which was in compliance with the respective regulation (at least 98 percent NMOC destruction efficiency). A summary of NMOC results and lower heating values from each test are shown in Table 3-2. Please note that the sample from Run 2 was replaced by the sample from Run 4 as explained earlier in Section 3-2.

3.3.4 Methane Summary of Results

The average methane emission rate was in compliance with its respective emission limitation. The methane results from the outlet sampling location were to be determined by subtracting the NMOC emissions from the total hydrocarbons emissions. Since the NMOC samples from each

test were not detected, accurate methane emissions could not be calculated. The methane results from Table 3-2 are presented on a worst case scenario and assumed that all the hydrocarbons detected were methane.

3.3.5 Opacity Summary of Results

Visible emissions testing was performed in accordance with EPA Method 22. No visible emissions from the flare were observed during the observation period.

Nomenclature associated with the summary tables is explained as follows.

dscfm	-	dry standard cubic feet per minute.
acfm	-	actual cubic feet per minute.
ppm	-	parts per million.
ppm as carbon	-	parts per million as carbon.
lb/hour	-	pounds per hour.
%	-	percent.
BTU/cf	-	British thermal units per cubic foot.

Standard conditions were 29.92 inches of mercury and 68° F.

3.4 Operational Process Parameters

Flare operating parameters were monitored on a strip chart during the course of the compliance testing. The average flare temperature was 1650°F. ROJAC performed flow measurements at the inlet sampling location and the results are presented in Table 3-2. Copies of all chart recordings and other supplemental data are included in the Appendix section of this report.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 Emissions Test Methods

4.1.1 Non-Methane Organic Compounds

Non-Methane Organic Compound (NMOC) determinations were performed in accordance with EPA Method 18.

Samples from both the inlet and outlet locations were collected for NMOC using the "bag-in-a-box" sampling system, shown in Figure 4-1. The Teflon sample line passed through the wall of the rigid container and was connected to the sample bag, which created a vacuum seal. The bags were filled at a constant rate of 0.5 liters per minute (lpm) over a one (1) hour sampling period by slow evacuation of air within the container. The resulting vacuum inflated the bag with the extracted gas sample. Each sample/line bag pair was filled, purged, and filled again to condition the sampling train and minimize any wall absorption effects. Bag samples were collected in conjunction with each CEM test run.

At the end of the field test program, the bag samples were analyzed first for oxygen and carbon dioxide by an Orsat analyzer per EPA Method 3 and then rushed to the laboratory and analyzed within 24 hours by GC/FID. GC conditions, such as column type, carrier flowrate, temperature, and injected sample volume, were determined before the field sample analyses by means of trial runs on a presurvey sample. Conditions were set to maximize peak resolution and separation. Calibration standards were prepared in advance according to EPA Method 18 protocol. Three (3) standards for high, low, and mid concentration ranges were prepared to encompass the expected stack gas concentrations.




FIGURE 4-1

EPA Method 18
Methane and NMOC Collection Train

The NMOC destruction efficiency was determined through comparison of the inlet and outlet NMOC concentrations using the following equation:

$$\text{Destruction Efficiency} = \frac{\text{NMOC Inlet} - \text{NMOC Outlet}}{\text{NMOC Inlet}} \times 100$$

4.1.2 Visible Emissions

Visible emissions were determined visually in accordance with EPA Method 22. One continuous (two hour) observation period was conducted with three observers alternating between making observations and taking breaks. Observations were recorded on field data sheets which are included in the appendix section of this report.

4.1.3 Continuous Emission Monitoring

ROJAC conducted the outlet flue gas measurements for NO_x , SO_2 , CO, THC, and diluent O_2 using EPA Reference Methods 7E, 6C, 10, 25A, and 3A, respectively. Figure 4-2 shows a schematic diagram of the sampling system.

The CEMS draws flue gas in through a 6 foot glass lined stainless steel heated probe with in-stack and/or heated out-of-stack filtration systems. The gas sample was drawn through the probe and filter(s) by a heated Teflon lined diaphragm vacuum pump. From the pump the sample was sent through a heated Teflon sample line. At the end of the sample line the extracted flue gas was split three ways with one part going through a refrigerator-type condenser, into a manifold, and finally to the NO/NO_x , O_2 , and CO analyzers. Another part of the sample flue gas was sent directly to the THC analyzer in a heated state with no prior moisture removal. The final portion of the sample was sent through a permeation dryer manufactured by Permapure, Inc. before being introduced to the SO_2 analyzer. Analyzer outputs were recorded by a data acquisition system (DAS) at thirty (30) second intervals.

A total of three (3) sixty (60) minute CEM test runs were performed with a zero and mid-range calibration check between each test run. In addition, a full range calibration and linearity check was performed on each reference method analyzer at the beginning of each test day. Emissions was reported in parts per million and pounds per hour (lb/hr).




FIGURE 4-2

EPA Methods 3A, 6C, 7E, 10, 25A, Continuous Emission Monitoring System

The CO instrument was an Horiba Model PIR-2000 analyzer which measured CO concentration by means of non-dispersive infrared radiation (NDIR). The infrared radiation was produced by the analyzer and was, in turn, absorbed by the continuous flow of sample gas through the analyzer. The percentage of infrared radiation thus absorbed was proportional to the concentration of CO in the gas stream.

The heated THC instrument was a Beckman Model 402 analyzer which utilized the flame ionization method of detection of total hydrocarbons. The sensor was a burner in which a regulated flow of sample gas passed through a flame sustained by the regulated flow of air and a mixture of 40% hydrogen and 60% nitrogen fuel. Within the flame, a complex ionization of the hydrocarbons in the sample stream occurred which allows for their detection and measurement. Propane (C_3H_8) was used as the calibration standard. Sample concentrations were reported in parts per million by volume (ppmv) as propane, and were adjusted in terms of ppmv as Carbon using Equation 25A-1:

$$C_C = KC_{meas},$$

where C_C = the THC concentration in ppmv as Carbon,

C_{meas} = the THC concentration as measured in ppmv as propane,

K = the response factor for the calibration gas being used
(propane = 3).

4.1.5 Analyzer Calibrations

Calibrations were performed using an Environics Series 2020 Computerized Multi-Component Gas Mixer. This system (shown in Figure 4-3) accurately blends NIST (National Institute of Standards and Technology) traceable mixtures from EPA Protocol and other certified gases.

The gas mixer contained five (5) mass flow controllers (MFC's) which have been calibrated and certified NIST traceable with the use of a Sierra Cal-Bench. The Sierra Cal-Bench was a NIST recognized and traceable primary flow measurement standard which contained a sonar detection device sensitive to 0.0005 inches. Using this system, the MFC's were calibrated by the manufacturer at eleven (11) points along their respective ranges from zero to the maximum flow. These data points were stored in the gas mixer's computer as a reference table to be used for interpolating all flow commands.

Required flow rates and target mixtures were entered into the instrument's computer along with the undiluted gas concentrations. The MFC's then accurately mixed the calibration gases with the balance gas to produce the requested dilutions. The Environics Series 2020 NIST Traceability Certification is included in the Appendix.

Certified EPA Protocol 1 compressed span gases of SO₂, NO, O₂, CO, and propane (C₃H₈), supplied by Matheson Gas Products, were used as the calibration standards. High purity nitrogen (N₂) was used as the zero and gas mixer balance gas.




FIGURE 4-3

EPA Conditional Test Method 007
Enviro-nics 2020 Computerized Multi-Component Gas Mixer

The gas mixer was used in strict accordance with the EPA's EMTIC (Emission Measurement Technical Information Center) Publication No. CTM-007 Verification of Gas Dilution System For Field Instrument Calibrations (Appendix).

The accuracy of the gas mixer was demonstrated to the onsite observer in accordance with the Performance Specifications Tests outlined in EPA Conditional Test Method 7. Prior to the field testing, a single analyzer was chosen by ROJAC to be calibrated at five (5) points along its measurement range using the gas mixer. These sampling points included the undiluted (100%) calibration gas concentration, as well as 2:1, 5:1, 10:1, and 100:1 dilutions.

The dilutions were introduced to the analyzer one at a time and the responses noted on a field data sheet. The sequence of calibrations were repeated three (3) times and the averages were compared to the predicted responses. These averages did not differ from the predicted concentrations by more than 2% of the predicted value.

Following the dilution sequence tests, a mid-level Protocol 1 gas was introduced directly to the analyzer. The concentration of this mid-level gas did not differ from one of the dilutions by more than 10%. For the gas mixing system to be shown acceptable, the analyzer response to this undiluted gas must be within 2% of the gas concentration.

For the field tests, the analyzers were calibrated and linearized at four (4) points along their measurement ranges at the beginning of each test day. EPA Protocol 1 gases were introduced to each analyzer via the gas mixer to produce calibrations at 90%, 60%, 30%, and 0% of the span values using the N₂ balance/zero gas as the dividing medium.

The system bias and drift tests were conducted with appropriate mid-level dilution gases based on the source emissions. These system calibrations were repeated after each thirty (30) minute test run. The gases passed through all components of the sampling system except the sampling probe. The calibration gas dilutions produced by the gas mixer have the following approximate concentrations:

<u>Constituent</u>	<u>High-level</u>	<u>Mid-level</u>	<u>Low-level</u>	<u>Zero</u>
SO ₂	95.6 ppm	47.8 ppm	00.0 ppm	N ₂
NOx	95.0 ppm	47.5 ppm	00.0 ppm	N ₂
O ₂	20.9 %	16.1 %	00.0 %	N ₂
CO	1200.0 ppm	720.0 ppm	360.0 ppm	N ₂
THC	95.3 ppm	47.7 ppm	28.6 ppm	N ₂

4.1.6 Data Reduction

The system calibrations were performed to document any instrument drift. Using Equation 6C-1 (CFR 40, Part 60, Appendix A), the ppm and percent values were corrected to account for the zero and span values and any instrument drift as follows:

$$C_{\text{gas}} = (\bar{C} - C_0) \times \frac{C_{\text{ma}}}{C_{\text{m}} - C_0},$$

where C_{gas} = emissions concentration (ppm or %)
 $\bar{C}$ = average emissions reading (ppm or %)
 C_0 = average zero reading (ppm or %)
 C_m = average span reading (ppm or %)
 C_{ma} = span gas concentration (ppm or %).

The corrected ppm and % averages were then used to calculate emission rates in the appropriate standard units.

4.2 Sample Identification and Custody

Sample custody procedures for this program were based on EPA recommended procedures. The project manager was responsible for ensuring that proper custody and documentation procedures were followed for the field sampling and field analytical efforts. The project manager was assisted in this effort by key sampling personnel involved in sample recovery. All sampling data, including information regarding sampling times, locations, and any specific considerations associated with sample acquisition were recorded in ink on pre-formatted data sheets.

Following sample collection, all samples were given a unique alphanumeric sample identification code. The sample volumes were measured and recorded, and the liquid levels on each bottle were marked. Sample labels and integrity seals were completed and affixed to the sample container. Samples were stored in a secure area until shipment.

All samples were packed and shipped according to Department of Transportation (DOT) guidelines. As the samples were packed for shipment to the appropriate laboratories chain-of-custody forms were completed for each shipment box and enclosed therein.

5.0 QA/QC ACTIVITIES

ROJAC maintains specific laboratory facilities dedicated to the maintenance and calibration of source sampling equipment used in performing EPA reference method source tests. These facilities include all equipment and standards necessary for equipment calibration using the procedures outlined in the Quality Assurance Handbook for Air Pollution Measurement Systems Volume III, Stationary Source Specific Methods (EPA 600/4-77-027b).

The checkout and calibration of the source sampling equipment is performed prior to and at the completion of each project. Referenced calibration procedures were strictly followed and the results properly documented and retained. The following calibrated equipment was used during the test program.

- * Type-S Pitot Tubes
- * Sampling Nozzles
- * Type-K Thermocouples
- * Dry Gas Meters
- * Gas Mixer Mass Flow Controllers
- * Continuous Emission Monitors

Calculations for determining flow rates, moisture content, isokinetics, and particulate and gaseous concentrations are made using a computer program developed by the QA/QC Manager at ROJAC. This program utilizes the calculation procedures and equations specified in EPA Methods 2, 4, and 5. The program has been successfully used for numerous test efforts and has been validated by independent sources.

Quality control for the various organic and inorganic analytical procedures is established using field blanks, method blanks, trip blanks, surrogate spiking, and internal standards for quantization. Where applicable, percent recoveries are calculated and determined.

APPENDIX A

Test Results and Calculations

HARTFORD LANDFILL
FLARE OUTLET SAMPLING LOCATION
HARTFORD, CONNECTICUT

RUN NO.:	M4-1-Outlet	M4-2-Outlet	M4-3-Outlet	M4-1-Inlet	M4-2-Inlet	M4-3-Inlet
DATE:	11-04-93	11-04-93	11-04-93	11-04-93	11-04-93	11-04-93
TIME:	1140-1240	1315-1415	1435-1535	1140-1240	1315-1415	1435-1535
PBAR, (in. Hg)	30.10	30.10	30.10	30.10	30.10	30.10
STACK AREA, (Sq. Ft.)	38.47	38.47	38.47	0.30	0.30	0.30
NOZZLE DIA., (in.)	60	60	60	60	60	60
TOTAL TIME, (minutes)	0.9992	0.9992	0.9992	1.0043	1.0043	1.0043
CALIBRATION FACTOR	0.84	0.84	0.84	0.99	0.99	0.99
PITOT COEFFICIENT	0.1546	0.1734	0.1599	0.6487	0.6585	0.6712
SQ. RT. DELTA P, (in. H2O)	1.00	1.00	1.00	1.00	1.00	1.00
DELTA H, (in. H2O)	68	72	74	67	72	73
METER TEMP., (Degree F)	-0.06	-0.06	-0.06	2.50	2.50	2.50
STATIC PRESS., (in. H2O)	1505	1457	1544	93	93	93
STACK TEMP., (Degree F)	31.549	31.802	32.115	32.938	33.885	33.049
METER VOLUME, (cu.ft.)	37.60	54.70	63.70	19.60	26.70	18.40
TOTAL H2O VAPOR, (ml)	5.7	5.8	6.0	34.2	34.4	35.5
CO2 IN STACK GAS, (%)	13.3	13.2	12.8	0.6	1.8	0.6
O2 IN STACK GAS, (%)	0.0	0.0	0.0	0.0	0.0	0.0
CO IN STACK GAS, (%)	81.0	81.0	81.2	65.2	63.8	63.9
N2 IN STACK GAS, (%)						

METER VOL. STD, (cu.ft.)	31.79	31.80	32.00	33.42	34.06	33.16
H2O IN STACK GAS, (%)	5.27	7.49	8.57	2.69	3.56	2.55
STACK GAS MOLECULAR WT	28.84	28.60	28.49	33.08	33.02	33.30
EXCESS AIR, (%)	164.5	161.3	148.2	3.6	12.0	3.7
STACK GAS VEL., (FPM)	1002.27	1115.03	1053.30	2447.49	2486.65	2523.84
GAS FLOWRATE, (ACFM)	38552	42890	40515	731	742	753
STP FLOWRATE, (DSCFM)	9870	10993	9817	687	692	710

1. pounds per hour	=	lb/dscf	x	2.205E-3 LB/G	x	1E6
	=	ppm	x	MW	x	22.414 L/G-MOLE x 3.531E-2 CF/L x (528.270R/492.270R)

where

lb/hr = pounds per hour
lb/dscf = pounds per dry standard cubic foot
MW = molecular weight in grams per gram-mole (g/g-mole)
lb/g = pounds per gram
l/g-mole = liters per gram-mole
cf/l = cubic feet per liter
OR = degrees Rankine

[illegible]

2. ppm as Carbon

$$= \frac{\text{ppm HC}}{\text{Carbon equivalent correction factor (propane = 3)}}$$

where

3. pounds per hour as C	=	ppmC	x	MW	x	2.596E-09	x	dscfm	x	60
lbC/hr	=	22.5	x	12.0	x	2.596E-09	x	9870	x	60
lbC/hr	=	0.4 lbC/hr								

EQUATIONS 6C-1 - EMISSIONS CONCENTRATIONS

CLIENT: CRRA
 LOCATION: HARTFORD LANDFILL FLARE
 PROJ. NO: F93-09
 DATE: 11/04/93

TIME	RUN NUMBER	ANALYZER AVERAGE	ZERO RESPONSE		UPSCALE RESPONSE		AVERAGE ZERO	AVERAGE SPAN	SPAN GAS VALUE	EMISSIONS CONCENTRATION
			INITIAL	FINAL	INITIAL	FINAL				
1048-1148	NOx-1	12.7	0.3	0.6	48.4	46.8	0.5	47.6	47.5	12.3 ppm
1220-1320	NOx-2	12.7	0.6	0.6	46.8	47.1	0.6	47.0	47.5	12.4 ppm
1355-1455	NOx-3	13.0	0.6	0.6	47.1	47.3	0.6	47.2	47.5	12.6 ppm
AVERAGE		12.8	0.5	0.6	47.4	47.1	0.6	47.3		12.5 ppm
1048-1148	SO2-1	1.3	0.3	1.1	47.6	48.7	0.7	48.2	47.8	0.6 ppm
1220-1320	SO2-2	3.4	1.1	1.3	48.7	49.1	1.2	48.9	47.8	2.2 ppm
1355-1455	SO2-3	3.9	1.3	1.4	49.1	48.6	1.4	48.9	47.8	2.6 ppm
AVERAGE		2.9	0.9	1.3	48.5	48.8	1.1	48.6		1.8 ppm
1048-1148	O2-1	13.4	0.0	0.1	16.1	16.1	0.1	16.1	16.1	13.4 %
1220-1320	O2-2	13.5	0.1	0.1	16.1	16.1	0.1	16.1	16.1	13.5 %
1355-1455	O2-3	13.5	0.1	0.1	16.1	16.1	0.1	16.1	16.1	13.5 %
AVERAGE		13.5	0.1	0.1	16.1	16.1	0.1	16.1		13.5 %
1048-1148	CO-1	240.0	4.7	2.9	712.6	714.3	3.8	713.5	720.0	239.6 ppm
1220-1320	CO-2	275.2	2.9	2.5	714.3	710.7	2.7	712.5	720.0	276.4 ppm
1355-1455	CO-3	284.8	2.5	3.5	710.7	707.0	3.0	708.9	720.0	287.4 ppm
AVERAGE		266.7	3.4	3.0	712.5	710.7	3.2	711.6		267.8 ppm

123R23\DATA\EQ6C-1

ROJAC Environmental Services, Inc.

EQUATIONS 6C-1 - EMISSIONS CONCENTRATIONS

CLIENT: CRRA
 LOCATION: HARTFORD LANDFILL FLARE
 PROJ. NO: F93-09
 DATE: 11/04/93

TIME	RUN NUMBER	ANALYZER AVERAGE	ZERO RESPONSE		UPSCALE RESPONSE		AVERAGE ZERO	AVERAGE SPAN	SPAN GAS VALUE	EMISSIONS CONCENTRATION
			INITIAL	FINAL	INITIAL	FINAL				
1520-1559 1559-1620	NOx-4A	12.9	0.6	0.3	47.3	47.0	0.5	47.2	47.5	12.7 ppm
	NOx-4B	15.9	0.6	0.3	47.3	47.0	0.5	47.2	47.5	15.7 ppm
	AVERAGE	14.4	0.6	0.3	47.3	47.0	0.5	47.2		14.2 ppm
1520-1559 1559-1620	S02-4A	2.8	1.4	1.1	48.6	48.7	1.3	48.7	47.8	1.6 ppm
	S02-4B	3.0	1.4	1.1	48.6	48.7	1.3	48.7	47.8	1.8 ppm
	AVERAGE	2.9	1.4	1.1	48.6	48.7	1.3	48.7		1.7 ppm
1520-1559 1559-1620	O2-4A	13.4	0.1	0.1	16.1	16.1	0.1	16.1	16.1	13.4 ppm
	O2-4B	12.7	0.1	0.1	16.1	16.1	0.1	16.1	16.1	12.7 ppm
	AVERAGE	13.1	0.1	0.1	16.1	16.1	0.1	16.1		13.0 ppm
1520-1559 1559-1620	CO-4A	298.6	3.5	2.6	707.0	708.9	3.1	708.0	720.0	301.9 ppm
	CO-4B	66.8	3.5	2.6	707.0	708.9	3.1	708.0	720.0	65.1 ppm
	AVERAGE	182.7	3.5	2.6	707.0	708.9	3.1	708.0		183.5 ppm

ROJAC Environmental Services, Inc.

EXAMPLE CALCULATIONS

EQUATION 6C-1 - EMISSION CONCENTRATIONS

CLIENT: CRRRA
 LOCATION: HARTFORD LANDFILL FLARE
 PROJ. NO: F93-09
 DATE: 11/04/93

RUN NUMBER	ANALYZER AVERAGE	ZERO RESPONSE		UPSCALE RESPONSE		AVERAGE ZERO	AVERAGE SPAN	SPAN GAS VALUE	EMISSIONS CONCENTRATION
		INITIAL	FINAL	INITIAL	FINAL				
NOX-1	12.7	0.3	0.6	48.4	46.8	0.5	47.6	47.5	12.3 ppm

EQUATION 6C-1:
$$C_{gas} = \frac{(C - C_o) \times (C_{ma})}{(C_m - C_o)}$$
 WHERE

$$C = \text{ANALYZER RUN AVERAGE}$$

$$C_o = \text{AVERAGE ZERO RESPONSE}$$

$$C_m = \text{AVERAGE SPAN RESPONSE}$$

$$C_{ma} = \text{UPSCALE SPAN GAS CONCENTRATION}$$

$$C_{gas} = \text{POLLUTANT CONCENTRATION}$$

$$C_{gas} = \frac{(12.7 - 0.5) \times (47.5)}{(47.6) - (0.5)} = 12.3 \text{ ppm}$$

APPENDIX B


Field Data Sheets

pg 1 of 3

FUGITIVE OR SMOKE EMISSION INSPECTION
OUTDOOR LOCATION

Company <u>Htfd Landfill</u>	Observer <u>RAK / TC / JSG</u>
Location <u>Hartford, CT</u>	Affiliation <u>ROSA C</u>
Company representative <u>David Martin</u>	Date <u>11/4/93</u>
Sky Conditions <u>Cloudy</u>	Wind direction <u>South</u>
Precipitation <u>NONE</u>	Wind speed <u>5-10 mph</u>
Industry <u>CRRR</u>	Process unit <u>Flare</u>

Sketch process unit; indicate observer position relative to source and sun; indicate potential emission points and/or actual emission points.



OBSERVATIONS


	Clock time	Observation period duration, min:sec	Accumulated emission time, min:sec
Begin Observation	RAK 1200	0	0
	1205	0	0
	1210	0	0
	1215	0	0
	TEC 1220	0	0
	1225	0	0
	1230	0	0
	JSG 35	0	0
	40	0	0
End observation	1245	0	0

Figure 22-1

FUGITIVE OR SMOKE EMISSION INSPECTION
OUTDOOR LOCATION

Company <u>Hartford LANDFILL</u>	Observer <u>RAK/JSG/TC</u>
Location <u>Hartford, CT</u>	Affiliation <u>ROJAC</u>
Company representative <u>David Martin</u>	Date <u>11/4/93</u>
Sky Conditions <u>Cloudy 95%</u>	Wind direction <u>South</u>
Precipitation <u>0</u>	Wind speed <u>5-10 mph</u>
Industry <u>CRRA</u>	Process unit <u>Landfill flare</u>

Sketch process unit; indicate observer position relative to source and sun; indicate potential emission points and/or actual emission points.



OBSERVATIONS


	Clock time	Observation period duration, min:sec	Accumulated emission time, min:sec
Begin Observation	RAK 1245	0	0
	1250	0	0
	1255	0	0
	RAK 1300	0	0
	TEC 1305	0	0
	1310	0	0
	1315	0	0
	TEC 1320	0	0
	JSG 25	0	0
End observation	30	0	0

Figure 22-1

FUGITIVE OR SMOKE EMISSION INSPECTION
OUTDOOR LOCATION

Company <u>Hartford Landfill</u>	Observer <u>RAK/TEC/JSG</u>
Location <u>Hartford, CT</u>	Affiliation <u>ROJAC</u>
Company representative <u>David Martin</u>	Date <u>11/4/93</u>
Key Conditions <u>cloudy</u>	Wind direction <u>South</u>
Precipitation <u>NONE</u>	Wind speed <u>5-10 mph</u>
Industry <u>CERRA</u>	Process unit <u>Landfill Flare</u>

Sketch process unit; indicate observer position relative to source and sun; Indicate potential emission points and/or actual emission points.



OBSERVATIONS

Begin Observation	Clock time	Observation period duration, min:sec	Accumulated emission time, min:sec
End observation	RAK 1330	0	0
	35	0	0
	40	0	0
	RAK 1345	0	0
	50	0	0
	55	0	0
	End 1400		

Figure 22-1

STACK COND.			
STATIC PRES.	-0.065		
DUCT DIM.	8"		
DUCT AREA	38.40		
%H ₂ O	3		
AMBIENT COND.			
AMB. TEMP.	50		°F
BAR. PRES.	30.10		in. Hg.

**Rojac Environmental
Services, Inc.**

37.6

	1	2	3	PAYMENT NO.
C02	5.60	5.6	5.6	5.6
O2	13.3	13.3	13.3	13.3
C0				
N2				

INO. M4-3
NO. F13-07
DATE 11-4-93
NAME CRRA
LOC. Westford
Landfill
STER TEC/TSC-

PITOT LEAK CHECK

INITIAL ✓

FINAL OK

TRAIN LEAK CHECK

INITIAL R² @ In. Hg.

FINAL 0.02 R² @ 5 In. Hg.

SAMPLING TIME 60 min.

INITIAL 1435

FINAL 1535

MODULE NO.	1451
DGM, Y	9792
MOD AH@	1.31
PROBE I.D.	651
PITOT (CP)	87
NOZ. DIA.	-
FILTER I.D.	-
TARE WT.	-

INO. M4-3
NO. F13-07
DATE 11-4-93
NAME CARRA
LOC. Wentford
Landfill
STER TEL/336-

AV. T	SAMPLE TIME (min)	CLOCK TIME (hours)	VEL. ΔP	ORIFICE ΔH	DGM T _m In. °F	DGM T _m Out °F	STACK TEMP. T _s °F	GAS SAMPLE VOLUME Vm ft ³	COND. OUTLET °F	HEATER BOX °F	PROBE TEMP. °F	FILTER OUTLET °F	PUMP VAC. In. Hg.	OTHER
	10 min	1435		1.0	67	67	1541	657.000						
1		45			72	70	1538	664.16						
2		55			79	71	1533	675.0						
3		1505			81	73	1545	680.7						
4		15			81	72	1561	685.1						
5		35			81	71	1543	691.115						
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
AVERAGE			ΔP			74	1544	TOTAL						
			SORT (ΔP)					32.115						

REMARKS

OBESAT BAG ANALYSIS

	1	2	3	AVERAGE
CO2	6.0	6.0	6.0	6.0
O2	12.9	12.9	12.9	12.9
CO				
N2				

POSTIMPS. WEIGHT
BE IMPINGERS TARE

**PRE-IMPINGERS TARE -
A IMP'S CONTENTS**

POST G.G. WEIGHT
SEE PAGE 10

PRE S.Q. TARE.

$$\text{Total} = 63.7 \text{ ml}$$

47

Page 1 of 1

Stack Dimensions	84" ID	Area	ft ²
Barometric Pressure, (Pb)	38.47	in. Hg.	
Static Pressure, (Ps)	-0.06	in. H ₂ O	12.5 in. H ₂ O
Stack Molecular Wt., (Ms)	28.6		
Moisture Content	7	%	

Pitot No. 5
Leak Check OK in. H₂O
Pitot Coefficient 0.84

Tester RAK / LAG

Point	ΔP in. H ₂ O	Ts (°F)	Cyclonic- Flow Angle	Other Ts	Other
A 1	.03	1563		.025	1538
2	.03	1553		.03	1594
3	.03	1550		.025	1535
4	.025	1537		.025	1528
5	.025			.03	1520
6	.025	1466		.025	1470
7	.025			.03	1455
8	.025			.025	1439
9	.03			.03	1429
10	.03	1448		.03	1434
11	.03	1452		.03	1431
12	.03			.025	1430
13	.03			.025	1441
14	.025			.025	1424
Average	0.1667	1516			

$$\text{Gas Velocity, } V_s = (85.49) \times (C_p) \times (\text{SQRT } \Delta P)_{\text{avg}} \times \text{SQRT} \left[\frac{T_s + 460}{P_G \times M_s} \right] \quad \text{ft/sec}$$

41,996 ACFM

$$\text{Standard Gas Flowrate, } Q_{std} = (Q_s) \times \frac{528^\circ R}{T_s} \times \frac{P_D}{20.02} \times \frac{100 - \%H_2O}{100} = \frac{10,917}{1} \text{ DSCFM}$$

0.7" - N_D

EPA METHOD 2 VELOCITY TRAVERSE AND FLOWRATE DETERMINATION

Date 11-4-93
Plant CKRA - Hartford
Location Flue outlet

Page 1 of 4

Pre-Run 1 outlet

Stack Dimensions 94" Area 38.47 ft²
Barometric Pressure, (Pb) 30.10 in. Hg.
Static Pressure, (Ps) -0.065 in. H2O
Stack Molecular Wt., (Ms) 28.84
Moisture Content 3 %

Pitot No. 10' stilers
Leak Check 7.5 in. H2O
Pitot Coefficient .84

Tester TEC/JSC

Point	ΔP in. H2O	Ts (°F)	Cyclonic Flow Angle	Other	Other
1	0.025	1650			
2	0.027				
3	0.03				
4	0.03				
5	0.027				
6	0.025				
7	0.02				
8	0.015				
9	0.015				
10	0.015				
11	0.015				
12	0.01				
1	0.035				
2	0.04				
3	0.045				
4	0.035				
5	0.03				
6	0.03				
7	0.01				
8	0.01				
9	0.0				
10	0.0				
11	0.0				
12	0.0				
Average	0.1273	1650			

Absolute Gas Temperature = $T_s + 460^\circ\text{R}$

Absolute Gas Pressure, $P_g = P_b + P_s/13.6$

Gas Velocity, $V_s = (85.49) \times (C_p) \times (\text{SQRT } \Delta P)_{\text{avg}} \times \text{SQRT} \left[\frac{T_s + 460}{P_g \times M_s} \right]$ ft/sec

Actual Gas Flowrate, $Q_s = (V_s) \times 60 \times \text{Area}$ ACFM

Standard Gas Flowrate, $Q_{std} = (Q_s) \times \frac{528^\circ\text{R}}{T_s} \times \frac{P_g}{29.92} \times \frac{100 - \%H_2O}{100}$ DSCFM

EPA METHOD 2 VELOCITY TRAVERSE AND FLOWRATE DETERMINATION

Date 11-4-93
 Plant Hartford Landfill
 Location Hartford CT Flare Outlet

Page 2 of 4

Post 1
 Pic 2 Flare Outlet

Stack Dimensions 84" Area 3847 ft²
 Barometric Pressure, (Pb) 30.10 in. Hg.
 Static Pressure, (Ps) -0.06 in. H2O
 Stack Molecular Wt., (Ms) 28.7
 Moisture Content 7 %

Pitot No. FA 10-55
 Leak Check OK in. H2O
 Pitot Coefficient .84

Tester TEC/JSK

Point	ΔP in. H2O	Ts (°F)	Cyclonic Flow Angle	Other	Other
1	0.05	1650			
2	0.05				
3	0.05				
4	0.05				
5	0.04				
6	0.04				
7	0.025				
8	0.02				
9	0.02				
10	0.02				
11	0.01				
12	0.01				
1	0.04				
2	0.05				
3	0.05				
4	0.05				
5	0.05				
6	0.04				
7	0.03				
8	0.03				
9	0.03				
10	0.025				
11	0.025				
12	0.025				
Average	0.1819	1650			

Absolute Gas Temperature = $T_s + 460^{\circ}\text{R}$

Absolute Gas Pressure, $P_g = P_b + P_s / 13.6$

Gas Velocity, $V_s = (85.40) \times (C_p) \times (\text{SQRT } \Delta P)_{\text{avg}} \times \text{SQRT} \left[\frac{T_s + 460}{P_g \times M_s} \right]$

Actual Gas Flowrate, $Q_s = (V_s) \times 60 \times \text{Area}$

Standard Gas Flowrate, $Q_{\text{std}} = (Q_s) \times \frac{528^{\circ}\text{R}}{T_s} \times \frac{P_g}{29.92} \times \frac{100 - \% \text{H}_2\text{O}}{100}$

Run 1 FA 10-55 $\sqrt{\Delta P_{\text{avg}}}$

ft/sec

ACFM

DSCFM

EPA METHOD 2 VELOCITY TRAVERSE AND FLOWRATE DETERMINATION

Date 11-4-93
Plant CRRA - Hartford
Location Hartford, CT

Page 3 of 4

Post 2
Pre 3 Outlet Flare

Stack Dimensions 84" Area ft²
Barometric Pressure, (Pb) 30.10 in. Hg.
Static Pressure, (Ps) -0.061 in. H2O
Stack Molecular Wt., (Ms) 28.16
Moisture Content 7.5 %

Pitot No. 10'-55
Leak Check OK in. H2O
Pitot Coefficient .87

Tester TEC/JSG

Point	ΔP in. H2O	Ts (°F)	Cyclonic Flow Angle	Other	Other
1	0.05	1650			
2	0.04				
3	0.05				
4	0.05				
5	0.05				
6	0.035				
7	0.03				
8	0.03				
9	0.03				
10	0.025				
11	0.02				
12	0.025				
1	0.04				
2	0.045				
3	0.05				
4	0.05				
5	0.04				
6	0.03				
7	0.02				
8	0.01				
9	0.015				
10	0.01				
11	0				
12	0				
Average	0.1648	1650			

Absolute Gas Temperature = $T_s + 460^\circ R$

Absolute Gas Pressure, $P_g = P_b + P_s / 13.6$

Gas Velocity, $V_s = (85.49) \times (C_p) \times (\text{SQRT } \Delta P)_{\text{avg}} \times \text{SQRT} \left[\frac{T_s + 460}{P_g \times M_s} \right]$ ft/sec

Actual Gas Flowrate, $Q_s = (V_s) \times 60 \times \text{Area}$ ACFM

Standard Gas Flowrate, $Q_{std} = (Q_s) \times \frac{528^\circ R}{T_s} \times \frac{P_g}{29.92} \times \frac{100 - \%H_2O}{100}$ DSCFM

EPA METHOD 2 VELOCITY TRAVERSE AND FLOWRATE DETERMINATION

Date 11-4-93
Plant Hartford Landfill
Location Hartford, CT

Page 4 of 4

POST Run 3 Flare
Outlet

Stack Dimensions 84" Area 38.47 ft²
Barometric Pressure, (Pb) 30.1 in. Hg.
Static Pressure, (Ps) -0.065 in. H2O
Stack Molecular Wt., (Ms) 28.5
Moisture Content 8.6 %

Pitot No. 10-55
Leak Check OK in. H2O
Pitot Coefficient .87

Tester JSG/TEC

Point	ΔP in. H2O	Ts (°F)	Cyclonic Flow Angle	Other	Other
1	0.03	1650			
2	0.035				
3	0.04				
4	0.03				
5	0.03				
6	0.03				
7	0.01				
8	0.01				
9	0.01				
10	0.0				
11	0.0				
12	0.0				
1	0.055				
2	0.06				
3	0.05				
4	0.04				
5	0.05				
6	0.035				
7	0.03				
8	0.03				
9	0.03				
10	0.03				
11	0.03				
12	0.025				
Average	0.1549	1650			

Absolute Gas Temperature = $T_s + 460^{\circ}R$

Absolute Gas Pressure, $P_g = P_b + P_s / 13.6$

Gas Velocity, $V_s = (85.49) \times (C_p) \times (\text{SQRT } \Delta P)_{\text{avg}} \times \text{SQRT} \left[\frac{T_s + 460}{P_g \times M_s} \right]$

Actual Gas Flowrate, $Q_s = (V_s) \times 60 \times \text{Area}$

Standard Gas Flowrate, $Q_{std} = (Q_s) \times \frac{528^{\circ}R}{T_s} \times \frac{P_g}{29.92} \times \frac{100 - \%H_2O}{100}$

ft/sec

ACFM

DSCFM


EPA METHODS FILE DATA SHEET

RUN NO. m4-1-Inlet
 PROJ. NO. F73-C7
 DATE 11/4/93
 FIRM NAME Hatch Consultants
 PLANT LOC. Hatchford, CT
 TESTER RAL/TS

MODULE NO.	1748
DGM, Y	1.0043
MOD. ΔH @	1.80
PROBE I.D.	Std 16
PITOT (Gp)	99
NOZ DIA.	NA
FILTER I.D.	NA
TARE WT.	NA

PITOT LEAK CHECK	INITIAL	FINAL
TRAIN LEAK CHECK	INITIAL	FINAL
SAMPLING TIME	INITIAL	FINAL

STACK COND.					
STATIC PRES.	+2.5				* F
DUCT DIM.	3.4"				
DUCT AREA	3.50				in. Hg.
%H ₂ O	2.7				
AMBIENT COND.					
AMB. TEMP.	50				
BAR. PRES.	29.10				

TRAV. PT	SAMPLE TIME (min)	CLOCK TIME (hours)	VEL. ΔP	ORIFICE ΔH	DGM Tm in °F	DGM Tm out °F	STACK TEMP. T _b °F	GAS SAMPLE VOLUME Vm ft ³	COND. OUTLET °F	HEATER BOX °F	PROBE TEMP. °F	FILTER OUTLET °F	PUMP VAC. in. Hg.	OTHER	
	0	1140		1.0	58	59	73	803.174							
	5	45			62	59	73	805.8	68				.7"		
	10	50			66	60	73	807							
	15	55			70	61	73	812.1							
	20	1200			71	62	73	816.5							
	25	00			71	62	73	819.7							
	30	10			75	63	73	822.6							
	35	15			75	63	73	823.1							
	40	20			76	65	73	827.1							
	45	25			77	67	73	831.0							
	50	30			78	67	73	833.4							
	55	35		77	69	73	836.112								
	60	1210					73								
AVERAGE		ΔP SORT (ΔP)			67		93	TOTAL 32.935						Pressure 1101 to 1115	

REMARKS

Purge 1101 to 1115
MIE Bay Start 1125

Impingers H₂O Gain

Silica Gel H₂O Gain 11.6

Total Moisture Gain 19.6

	1	2	3	PERCENT
CO2	34.2	34.2	34.2	
O2	0.6	0.6	0.6	
CO				
N2				

DATA SHEET

RUN NO. 144-2-Inlet
PROJ. NO. F93-09
DATE 11/4/93
FIRM NAME H. J. Inland Land Co.
PLANT LOC. West Inland St.

MODULE NO.	1748
DGM, Y	10043
MOD. AH @	1886
PROBE I.D.	1.5 IN
PITOT (Cp)	N/C
NOZ DIA.	N/A
FILTER I.D.	N/A
TARE WT.	N/A

PITOT LEAK CHECK	INITIAL	FINAL
TRAIN LEAK CHECK	INITIAL	FINAL
SAMPLING TIME	INITIAL	FINAL

STACK COND.	STATIC PRES.	+2.5	F
	DUCT DIM.	7.4" ID	
	DUCT AREA	0.3	
	%H ₂ O	3.6%	
AMBIENT COND.	AMB. TEMP.	50	
	BAR. PRES.	30.10	in. Hg.

TRAV. PT	SAMPLE TIME (min)	CLOCK TIME (hours)	VEL. ΔP	ORIFICE ΔH	DGM T_m in °F	DGM T_m out °F	STACK TEMP. T_0 °F	GAS SAMPLE VOLUME Vm ft ³	COND. OUTLET °F	HEATER BOX °F	PROBE TEMP. °F	FILTER OUTLET °F	PUMP VAC. in. Hg.	OTHER
1	0	1315	N/A	1.0	68	67	93	836.462	<68					
	5	20			70	64	93	849.2						
	10	25			74	67	93	846.5						
	15	30			74	67	93	849.4						
	20	35			76	67	93	851.6						
	25	40			77	67	93	852.8						
	30	45			78	67	93	856						
	35	50			78	70	93	857.1					7"	
	40	55			78	70	93	861.7					7"	
	45	1400			79	70	94	866					7"	
	50	05			79	71	94	869					7"	
	55	10			81	72	94	870.397						
	60	1415												
AVERAGE					72		93	TOTAL 33.885						

Page 1217-1220

REMARKS

REMARKS

Page 1217 - 1220
m18 Bay Star + 1007
Stop 1300

	ORSAT BAG ANALYSIS			AVERAGE
	1	2	3	
CO ₂	34.4	34.4	34.4	34.4
O ₂	1.8	1.8	1.8	1.8
CO				
N ₂				

Impingers H₂O Gain 16 ml
Silica Gel H₂O Gain 10.7
Total Moisture Gain 26.7

MODULE NO. 1748
DGM, Y 1,0043
MOD.AH@ 1.86
PROBE I.D. To Flow
PITOT (CPI) NA
NOZ. DIA. NA
FILTER I.D. NA
TARE WT. NA

TESTER CAK

PITOT LEAK CHECK	INITIAL <u>AA</u>	FINAL <u>AA</u>
TRAIN LEAK CHECK	INITIAL <u>0</u>	FINAL <u>0</u>
SAMPLING TIME	INITIAL <u>0</u>	FINAL <u>11</u>

STACK COND.	
STATIC PRES.	+ 2.5
DUCT DIM.	7.4" ID
DUCT AREA	0.342
%H ₂ O	2.6%
AMBIENT COND.	
AMB. TEMP	50 °F
BAR. PRES.	30.0 in. Hg.

TIME	00	min.
INITIAL	1435	
FINAL	1535	

[illegible]

REMARKS

Purge 1400
 MIBAC start
 1405

ORSAT BAG ANALYSIS				
	1	2	3	AVERAGE
CO2	35.5	35.5	35.5	35.5
O2	0.10	0.10	0.10	0.10
CO				
N2				

Impingers H ₂ O Gain	9
Silica Gel H ₂ O Gain	9.4
Total Moisture Gain	18.4

EPA METHOD 2

Date _____

Plant

Location

Page

of 4

Stack Dimensions

Barometric Pressure, (Pb)

Static Pressure, (Ps)

Stack Molecular Wt., (Ms)

Moisture Content

Area 0.30 ft²

in Ho.

in. H₂O

1

Pitot No.

Leak Check

Pitot Coefficient

Tester

Point	ΔP in. H ₂ O	Ts (°F)	Cyclonic Flow Angle	Other	Other
A 1	.40	93			
2	.42	93			
3	.43	92			
4	.44	92			
B 1	.39	93			
2	.43	93			
3	.415	93			
4	.42	93			
Average	0.6465	93			

Absolute Gas Temperature = $T_s + 460^\circ\text{R}$

Absolute Gas Pressure, $P_g = P_b + P_s/13.6$

Gas Velocity, $V_s = (85.49) \times (C_p) \times (\text{SQRT } \Delta P)_{\text{avg}} \times \text{SQRT} \left[\frac{1}{\left(\frac{1}{\text{SG}} \right) - 1} \right]$

TE 460

Pg x Ms

4/500

Actual Gas Flowrate, $Q_s = (V_s) \times 60 \times A_{res}$

ACFM
$$\text{Standard Gas Flowrate, } Q_{std} = (Q_s) \times \frac{528^\circ R}{P_g} \times 100 - \%H_2O$$
Is

28.92

100

DSCFM

DSCFM

Date
Plant
Location

Page 4 of 4

Stack Dimensions	7.4" ID	Area	0.30 ft ²
Barometric Pressure, (Pb)	30.10	in. Hg.	
Static Pressure, (Ps)	+2.5	in. H ₂ O	
Stack Molecular Wt., (Ms)	33.3		
Moisture Content	2.6	%	

Pitot No. Std - 18
Leak Check OK in. H₂O
Pitot Coefficient 0.99

Tester RAK/JS6

3:45 pm

Point	ΔP in. H ₂ O	Ts (°F)	Cyclonic Flow Angle	Other	Other
A 1	.43	93			
2	.47				
3	.46				
4	.45				
B 1	.46				
2	.465				
3	.465				
4	.46				
Average	0.6763	93			

Absolute Gas Temperature = $T_s + 460^\circ\text{R}$

Absolute Gas Pressure, $P_g = P_b + P_s / 13.6$

$$\text{Gas Velocity, } V_s = (85.49) \times (C_p) \times (\text{SQRT } \Delta P)_{\text{avg}} \times \text{SQRT} \left[\frac{T_c + 460}{P_g \times M_s} \right] \quad \text{ft/sec}$$

Actual Gas Flowrate, $Q_s = (V_s) \times 60 \times \text{Area}$ ACFM

$$\text{Standard Gas Flowrate, Qstd} = (Q_g) \times \frac{528^\circ \text{R}}{T_s} \times \frac{P_g}{29.92} \times \frac{100 - \% \text{H}_2\text{O}}{100} \quad \text{DSCFM}$$

APPENDIX C

CEM Results and Calibration Data Sheets

CLIENT: CRRRA
 PROJ. NO.: F93-09
 LOCATION: HARTFORD LANDFILL FLARE

RUN NO.:	CEM-1	CEM-2	CEM-3	AVERAGE
DATE:	11/04/93	11/04/93	11/04/93	
TIME:	1048-1148	1220-1320	1355-1455	
<u>INPUTS</u>				
O2 Concentration (%)	13.4	13.5	13.5	13.5
CO2 Concentration (%)	5.7	5.8	6.0	5.8
NOx Concentration (ppm)	12.3	12.4	12.6	12.4
SO2 Concentration (ppm)	0.6	2.2	2.6	1.8
CO Concentration (ppm)	299.6	276.4	287.4	267.8
THC-Out Concentration (ppm)	7.5	11.2	10.6	9.8
Ambient Temp (DegreeF)	50	56	58	54.7
Ambient Barometric Press (in. Hg)	30.10	30.05	30.01	30.05
Volumetric Flowrate (dscfm)	9870	10993	9817	10227
<u>OUTPUTS</u>				
NOx (lb/hr)	0.9	1.0	0.9	0.9
SO2 (lb/hr)	0.1	0.2	0.3	0.2
CO (lb/hr)	10.3	13.3	12.3	12.0
THC-out (ppm as Carbon)	22.5	33.6	31.8	29.3
THC-out (lb/hr as Carbon)	0.42	0.69	0.58	0.56

CEMAVG

ROJAC Environmental Services, Inc.

CLIENT: CRRA

PROJ. NO.: F93-09

LOCATION: HARTFORD LANDFILL FLARE

RUN NO.:

DATE:

TIME:

CEM-4A
11/04/93
1520-1559

CEM-4B
11/04/93
1559-1620

AVERAGE

INPUTS

O2 Concentration (%)

CO2 Concentration (%)

NOx Concentration (ppm)

SO2 Concentration (ppm)

CO Concentration (ppm)

THC-Out Concentration (ppm)

Ambient Temp (DegreeF)

Ambient Barometric Press (in.Hg)

Volumetric Flowrate (dscfm)

13.4
7.0
12.7
1.6
301.9
11.5
52
30.05
9817

12.7
7.0
15.7
1.8
65.1
1.0
50
30.05
9817

13.1
7.0
14.2
1.7
183.5
6.3
51.0
30.05
9817

OUTPUTS

NOx (lb/hr)

SO2 (lb/hr)

CO (lb/hr)

THC-out (ppm as Carbon)

THC-out (lb/hr as Carbon)

0.9
0.2
12.9
34.5
0.63

1.1
0.2
2.8
3.0
0.06

1.0
0.2
7.9
18.8
0.34

CEMAVG

ROJAC Environmental Services, Inc.

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: Hartford Landfill
Project No:
Location: Flame outlet
Pollutant: NO_x

Date: 11/4/93
Run No: 1
Run Time: 1048-1148
Span Value: 0-100 ppm

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:	0.0	—	47.5	95.0	
Cal Response:	0.3	—	49.4	95.9	
Absolute Difference:	0.3	—	1.9	0.9	
Cal Error (<2%):	0.3%	—	1.9%	0.9%	

System Cal Bias and Drift Check:

Cal Gas: 47.5 (9.31%)		Pre Cal		Post Cal	
Analyzer	System	Syst Bias	System	Syst Bias	Drift
Cal Rspnse	Cal Rspnse	(<5%)	Cal Rspnse	(<5%)	(<3%)
Zero: 0.3	0.3	0.0%	0.6	0.3%	0.3%
Upscale 1: 49.4	48.4	1.0%	46.8	2.6%	1.6%
Upscale 2:					

Calibration Error Calculation, Cerr:

$$Cerr = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$Cd = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

C = 12.7 (Run Average)
 C_o = 0.5 (Average Zero)
 C_m = 47.6 (Average Upscale)
 C_{ma} = 47.5 (Cal Gas Conc)
 C_{gas} = 12.3 ppm (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

%CO₂ =
 C_{co} =
 (%CO₂ from M3/3A)
 (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: *Hartford Landfill*
Project No:
Location: *Flare outlet*
Pollutant: *NOx*

Date: *11/14/93*
Run No: *2*
Run Time: *1220-1320*
Span Value: *0-100 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:					
Cal Response:					
Absolute Difference:					
Cal Error (<2%):					

System Cal Bias and Drift Check:

Cal Gas: <i>47.5 (9.31%)</i>	Pre Cal			Post Cal	
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)
Zero:	<i>0.3</i>	<i>0.6</i>	<i>0.3%</i>	<i>0.6</i>	<i>0.3%</i>
Upscale 1:	<i>49.4</i>	<i>46.8</i>	<i>2.6%</i>	<i>47.1</i>	<i>2.3%</i>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 12.7$ (Run Average)
 $C_o = 0.6$ (Average Zero)
 $C_m = 47.0$ (Average Upscale)
 $C_{ma} = 47.5$ (Cal Gas Conc)
 $C_{gas} = 12.4 \text{ ppm}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: *Hartford Landfill*
Project No:
Location: *Flare outlet*
Pollutant: *NOx*

Date: *11/4/93*
Run No: *3*
Run Time: *1355 - 1455*
Span Value: *0-100 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:					
Cal Response:					
Absolute Difference:					
Cal Error (<2%):					

System Cal Bias and Drift Check:

Cal Gas: <i>47.5 (9.31%)</i>	Pre Cal			Post Cal	
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)
Zero:	<i>0.3</i>	<i>0.6</i>	<i>0.3%</i>	<i>0.6</i>	<i>0.3%</i>
Upscale 1:	<i>49.4</i>	<i>47.1</i>	<i>2.3%</i>	<i>47.3</i>	<i>2.1%</i>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 13.0$ (Run Average)
 $C_o = 0.6$ (Average Zero)
 $C_m = 47.2$ (Average Upscale)
 $C_{ma} = 47.5$ (Cal Gas Conc)
 $C_{gas} = 12.6 \text{ ppm}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: *Hartford Landfill*
Project No:
Location: *Flare outlet*
Pollutant: *SO₂*

Date: *11/4/93*
Run No: *1*
Run Time: *1048-1148*
Span Value: *0-100 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:	<i>0.0</i>	—	<i>47.8</i>	<i>95.6</i>	
Cal Response:	<i>0.5</i>	—	<i>47.2</i>	<i>95.0</i>	
Absolute Difference:	<i>0.5</i>	—	<i>0.6</i>	<i>0.6</i>	
Cal Error (<2%):	<i>0.5%</i>	—	<i>0.6%</i>	<i>0.6%</i>	

System Cal Bias and Drift Check:

Cal Gas: *47.8 ppm (SO₂)*

	Pre Cal			Post Cal	
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)
Zero:	<i>0.5</i>	<i>0.3</i>	<i>0.2%</i>	<i>1.1</i>	<i>0.6%</i>
Upscale 1:	<i>47.2</i>	<i>47.6</i>	<i>0.4%</i>	<i>48.7</i>	<i>1.5%</i>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 1.3$ (Run Average)
 $C_o = 0.7$ (Average Zero)
 $C_m = 48.2$ (Average Upscale)
 $C_{ma} = 47.8$ (Cal Gas Conc)
 $C_{gas} = 0.6 \text{ ppm}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: Hartford Landfill
Project No: _____
Location: Flare outlet
Pollutant: SO₂

Date: 11/11/93
Run No: 2
Run Time: 1220-1320
Span Value: 0-100 ppm

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:				
Cal Response:				
Absolute Difference:				
Cal Error (<2%):				

System Cal Bias and Drift Check:

Cal Gas: <u>47.8 ppm (SDI)</u>	Pre Cal			Post Cal	
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)
Zero:	<u>0.5</u>	<u>1.1</u>	<u>0.6%</u>	<u>1.3</u>	<u>0.8%</u>
Upscale 1:	<u>47.2</u>	<u>48.7</u>	<u>1.5%</u>	<u>49.1</u>	<u>1.9%</u>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 3.4$ (Run Average)
 $C_o = 1.2$ (Average Zero)
 $C_m = 48.9$ (Average Upscale)
 $C_{ma} = 47.8$ (Cal Gas Conc)
 $C_{gas} = 2.2 \text{ ppm}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: *Hart & Lard Level B 11*
Project No:
Location: *Flame incinerator*
Pollutant: *SO₂*

Date: *11/4/93*
Run No: 3
Run Time: *1355-1455*
Span Value: *0-100 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:				
Cal Response:				
Absolute Difference:				
Cal Error (<2%):				

System Cal Bias and Drift Check:

Cal Gas: <i>47.8 ppm (50%)</i>		Pre Cal		Post Cal	
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)
Zero:	<i>0.5</i>	<i>1.3</i>	<i>0.8%</i>	<i>1.4</i>	<i>0.9%</i>
Upscale 1:	<i>47.2</i>	<i>49.1</i>	<i>1.9%</i>	<i>48.6</i>	<i>1.4%</i>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 3.9$ (Run Average)
 $C_o = 1.4$ (Average Zero)
 $C_m = 48.9$ (Average Upscale)
 $C_{ma} = 47.8$ (Cal Gas Conc)
 $C_{gas} = 2.6 \text{ ppm}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: Northford Landfill
Project No:
Location: Flare outlet
Pollutant: O₂

Date: 11/4/93
Run No: 1
Run Time: 1048-1148
Span Value: 0-25%

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:	0.0	—	16.1%	20.9%	
Cal Response:	0.0	—	16.2	20.9	
Absolute Difference:	0.0	—	0.1	0.0	
Cal Error (<2%):	0.0%	—	0.4%	0.0%	

System Cal Bias and Drift Check:

Cal Gas:	Pre Cal			Post Cal		
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)	Drift (<3%)
Zero:	0.0	0.0	0.0%	0.1	0.4%	0.4%
Upscale 1:	16.2	16.1	0.4%	16.1	0.4%	0.0%
Upscale 2:						

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_0) \times \frac{C_{ma}}{C_m - C_0}$$

C = 13.4 (Run Average)
 C₀ = 0.1 (Average Zero)
 C_m = 16.1 (Average Upscale)
 C_{ma} = 16.1 (Cal Gas Conc)
 C_{gas} = 13.4% (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

%CO₂ =
 C_{co} = (%CO₂ from M3/3A)
 (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: Huntford Landfill
Project No:
Location: Flare outlet
Pollutant: O₂

Date: 11/1/93
Run No: 2
Run Time: 1230 - 1330
Span Value: 0.25%.

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:					
Cal Response:					
Absolute Difference:					
Cal Error (<2%):					

System Cal Bias and Drift Check:

Cal Gas: 16.1%

	Pre Cal			Post Cal		
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)	Drift (<3%)
Zero:	0.0	0.1	0.4%	0.1	0.4%	0.0%
Upscale 1:	16.2	16.1	0.4%	16.1	0.4%	0.0%
Upscale 2:						

Calibration Error Calculation, Cerr:

$$Cerr = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$Cd = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

C = 13.5 (Run Average)
 C_o = 0.1 (Average Zero)
 C_m = 16.1 (Average Upscale)
 C_{ma} = 16.1 (Cal Gas Conc)
 C_{gas} = 13.5% (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

%CO₂ =
 C_{co} = (%CO₂ from M3/3A)
 (CO Conc)

CEM CALIBRATION DATA
EPA Method 6C Guidelines

Source ID: 14.14.14 Landfill
Project No: _____
Location: Flame on test
Pollutant: O₂

Date: 11/10/93
Run No: 3
Run Time: 1355 - 1455
Span Value: 0 - 25%

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:					
Cal Response:					
Absolute Difference:					
Cal Error (<2%):					

System Cal Bias and Drift Check:

Cal Gas: <u>16.1%</u>	Pre Cal			Post Cal		
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)	Drift (<3%)
Zero:	<u>0.0</u>	<u>0.1</u>	<u>0.4%</u>	<u>0.1</u>	<u>0.4%</u>	<u>0.0%</u>
Upscale 1:	<u>16.2</u>	<u>16.1</u>	<u>0.4%</u>	<u>16.1</u>	<u>0.4%</u>	<u>0.0%</u>
Upscale 2:						

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 13.5$ (Run Average)
 $C_o = 0.1$ (Average Zero)
 $C_m = 16.1$ (Average Upscale)
 $C_{ma} = 16.1$ (Cal Gas Conc)
 $C_{gas} = 13.5\%$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ ($\%CO_2$ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: *Ham + Ford Landfill*
Project No:
Location: *Flare outlet*
Pollutant: *CO*

Date: *11/4/95*
Run No: *1*
Run Time: *1045 - 1145*
Span Value: *0 - 1300 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:	0.0	360.0	720.0	1200.0	
Cal Response:	1.1	373.3	707.5	1206.0	
Absolute Difference:	1.1	13.3	12.5	6.0	
Cal Error (<2%):	0.1%	1.0%	1.0%	0.5%	

System Cal Bias and Drift Check:

Cal Gas: <i>720.0 (32.74%)</i>	Pre Cal			Post Cal		
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)	Drift (<3%)
Zero:	1.1	4.7	0.3%	2.9	0.1%	0.1%
Upscale 1:	707.5	712.6	0.4%	714.3	0.5%	0.1%
Upscale 2:						

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 240.0$ (Run Average)
 $C_o = 3.8$ (Average Zero)
 $C_m = 713.5$ (Average Upscale)
 $C_{ma} = 720.0$ (Cal Gas Conc)
 $C_{gas} = 239.6 \text{ ppm}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: *Hartford Landfill*
Project No:
Location: *Flare Outlet*
Pollutant: *CO*

Date: *11/4/93*
Run No: *2*
Run Time: *1220-1320*
Span Value: *0-1300 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:					
Cal Response:					
Absolute Difference:					
Cal Error (<2%):					

System Cal Bias and Drift Check:

Cal Gas: <i>720.0 (32.74%)</i>	Pre Cal			Post Cal		
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)	Drift (<3%)
Zero:	<i>1.1</i>	<i>2.9</i>	<i>0.1%</i>	<i>2.5</i>	<i>0.1%</i>	<i>0.0%</i>
Upscale 1:	<i>707.5</i>	<i>714.3</i>	<i>0.5%</i>	<i>710.7</i>	<i>0.2%</i>	<i>0.3%</i>
Upscale 2:						

Calibration Error Calculation, Cerr:

$$Cerr = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$Cd = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 275.2$ (Run Average)
 $C_o = 2.7$ (Average Zero)
 $C_m = 712.5$ (Average Upscale)
 $C_{ma} = 720.0$ (Cal Gas Conc)
 $C_{gas} = 276.4 \text{ ppm}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: *Hwy 4 Road Landfill*
Project No:
Location: *Flame 2041.4*
Pollutant: *CO*

Date: *11/4/13*
Run No: *3*
Run Time: *1355-1455*
Span Value: *0-1300 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:					
Cal Response:					
Absolute Difference:					
Cal Error (<2%):					

System Cal Bias and Drift Check:

Cal Gas: *720.0 (32.74%)*

	Pre Cal			Post Cal	
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)
Zero:	<i>1.1</i>	<i>2.5</i>	<i>0.1%</i>	<i>3.5</i>	<i>0.2%</i>
Upscale 1:	<i>707.5</i>	<i>710.7</i>	<i>0.2%</i>	<i>707.0</i>	<i>0.0%</i>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = 284.8$ (Run Average)
 $C_o = 3.0$ (Average Zero)
 $C_m = 708.9$ (Average Upscale)
 $C_{ma} = 720.0$ (Cal Gas Conc)
 $C_{gas} = 287.4 \text{ ppm}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA
EPA Method 25A - THC

Source ID: Hartford Landfill

Date: 11/4/93

Project No: F93-09

Run No: 1

Location: Flare outlet

Run Time: 1048 - 1148

Span Value: 0-100 ppm

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:	0.0	28.6	47.7	95.3
Cal Response:	0.3	28.4	48.0	95.4
Cal Rspnse - Zero:		28.1	47.7	95.1
Multiplication Factor:		1.0021	1.0021	1.0021
Corrected Conc (ppm):		28.2	47.8	95.3
Cal Error (<5%):		1.4%	0.2%	0.0%

Multiplication Factor Calculation, Mf:

$$Mf = \frac{C_{ma}}{C_m - C_o}$$

$C_{ma} = 95.3$ (Span Gas Conc)
 $C_m = 95.4$ (Cal response)
 $C_o = 0.3$ (Zero response)
 $Mf = 1.0021$

Calibration Error Calculation, Cerr:

$$Cerr = \frac{[\text{Corrected Conc (ppm)} - \text{Cal Gas Conc (ppm)}]}{\text{Cal Gas Conc (ppm)}} \times 100$$

Calibration Drift, Cd:

	Pre Cal	Post Cal	
Gas Conc	Calibration Response	Calibration Response	Drift (<3%)
Zero:	0.0	0.8	2.3%
Upscale 1:	47.7	47.3	0.1%
Upscale 2:		47.4	

$$Cd = \frac{\text{Pre Cal Response} - \text{Post Cal Response}}{\text{Span}} \times 100$$

Emissions Conc = (Avg analyzer reading - Zero) x Mf:

Avg Reading =	9.5
Emissions Conc =	7.5 ppm
Emissions as Carbon =	22.5 ppmC

M18 Bag (1120-1148)
 12.0
 10.0 ppm
 30.1 ppmC

CEM CALIBRATION DATA
EPA Method 25A – THC

Source ID: *Hartford Landfill*
Project No: *F93-09*
Location: *Flare outlet*

Date: *11/4/93*
Run No: *2*
Run Time: *1220-1320*
Span Value: *0-100 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:				
Cal Response:				
Cal Rspnse – Zero:				
Multiplication Factor:				
Corrected Conc (ppm):				
Cal Error (<5%):				

Multiplication Factor Calculation, Mf:

$$Mf = \frac{C_{ma}}{C_m - C_o}$$

$$\begin{aligned} C_{ma} &= \\ C_m &= \\ C_o &= \\ Mf &= \end{aligned}$$

(Span Gas Conc)
(Cal response)
(Zero response)

$$Mf = 1.0021$$

Calibration Error Calculation, Cerr:

$$Cerr = \frac{[\text{Corrected Conc (ppm)} - \text{Cal Gas Conc (ppm)}]}{\text{Cal Gas Conc (ppm)}} \times 100$$

Calibration Drift, Cd:

	Pre Cal	Post Cal	
Gas Conc	Calibration Response	Calibration Response	Drift (<3%)
Zero:	<i>0.0</i>	<i>3.1</i>	<i>1.0%</i>
Upscale 1:	<i>47.7</i>	<i>47.4</i>	<i>0.0%</i>
Upscale 2:			

$$Cd = \frac{\text{Pre Cal Response} - \text{Post Cal Response}}{\text{Span}} \times 100$$

$$\text{Emissions Conc} = (\text{Avg analyzer reading} - \text{Zero}) \times Mf$$

Avg Reading =	<i>13.8</i>
Emissions Conc =	<i>11.2</i> ppm
Emissions as Carbon =	<i>33.7</i> ppmC

M18 Bag (1223-1320)
13.8
11.2 ppm
33.7 ppmC

CEM CALIBRATION DATA EPA Method 25A - THC

Source ID: Hartford Landfill
Project No: F93-09
Location: Flare outlet

Date: 11/4/93
Run No: 3
Run Time: 1355-1455
Span Value: 0-100 ppm

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:				
Cal Response:				
Cal Rspnse - Zero:				
Multiplication Factor:				
Corrected Conc (ppm):				
Cal Error (<5%):				

Multiplication Factor Calculation, Mf:

$$Mf = \frac{C_{ma}}{C_m - C_o}$$

C_{ma} = (Span Gas Conc)
 C_m = (Cal response)
 C_o = (Zero response)
 $Mf = 1.0021$

Calibration Error Calculation, Cerr:

$$Cerr = \frac{[\text{Corrected Conc (ppm)} - \text{Cal Gas Conc (ppm)}]}{\text{Cal Gas Conc (ppm)}} \times 100$$

Calibration Drift, Cd:

	Pre Cal	Post Cal	
Gas Conc	Calibration Response	Calibration Response	Drift (<3%)
Zero:	<u>0.0</u>	<u>2.1</u>	<u>0.1%</u>
Upscale 1:	<u>47.7</u>	<u>49.6</u>	<u>2.2%</u>
Upscale 2:			

$$Cd = \frac{\text{Pre Cal Response} - \text{Post Cal Response}}{\text{Span}} \times 100$$

Emissions Conc = (Avg analyzer reading - Zero) x Mf:

Avg Reading =	<u>12.7</u>
Emissions Conc =	<u>10.6</u> ppm
Emissions as Carbon =	<u>31.9</u> ppmC

M18 Bag (1402-1455)
11.4
9.3 ppm
28.0 ppm C

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: *Hart + Ford Landfill*
Project No:
Location: *Flame on Heat*
Pollutant: *NOx*

Date: *11/12/93*
Run No: *4*
Run Time: *1520-1620*
Span Value: *0-100 ppm*

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range	
Cal Gas Conc:					
Cal Response:					
Absolute Difference:					
Cal Error (<2%):					

System Cal Bias and Drift Check:

Cal Gas: *47.5 (9.31%)*

	Pre Cal			Post Cal	
Analyzer	System	Syst Bias	System	Syst Bias	Drift
Cal Rspnse	Cal Rspnse	(<5%)	Cal Rspnse	(<5%)	(<3%)
Zero:	<i>0.3</i>	<i>0.6</i>	<i>0.3</i>	<i>0.0%</i>	<i>0.3%</i>
Upscale 1:	<i>49.4</i>	<i>47.3</i>	<i>24.1%</i>	<i>47.0</i>	<i>2.4%</i>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$Cerr = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$Cd = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = \frac{4A}{12.9} / \frac{4B}{15.9}$ (Run Average)
 $C_o = 0.5$ (Average Zero)
 $C_m = 47.2$ (Average Upscale)
 $C_{ma} = 47.5$ (Cal Gas Conc)
 $C_{gas} = 12.7 / 15.7$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: Handwritten
Project No: Handwritten
Location: Flame cell
Pollutant: SO₂

Date: 11/11/13
Run No: 4
Run Time: 1520-1620
Span Value: 0-100 ppm

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:				
Cal Response:				
Absolute Difference:				
Cal Error (<2%):				

System Cal Bias and Drift Check:

Cal Gas: 47.8 ppm (SO₂)

	Pre Cal			Post Cal	
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)
Zero:	<u>0.5</u>	<u>1.4</u>	<u>0.9%</u>	<u>1.1</u>	<u>0.6%</u>
Upscale 1:	<u>47.2</u>	<u>48.1</u>	<u>1.4%</u>	<u>48.7</u>	<u>1.5%</u>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$Cerr = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$Cd = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_0) \times \frac{C_{ma}}{C_m - C_0}$$

4A / 4B
C = 2.8 / 3.0 (Run Average)
C₀ = 1.3 (Average Zero)
C_m = 48.7 (Average Upscale)
C_{ma} = 47.8 (Cal Gas Conc)
C_{gas} = 1.6 / 1.8 (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

%CO₂ = (%CO₂ from M3/3A)
C_{co} = (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: Hartford Landfill
Project No: _____
Location: Flame duct
Pollutant: O₂

Date: 11/1/93
Run No: 4
Run Time: 1520-1620
Span Value: 0-25%

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:				
Cal Response:				
Absolute Difference:				
Cal Error (<2%):				

System Cal Bias and Drift Check:

Cal Gas: 16.1%

	Pre Cal			Post Cal		
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)	Drift (<3%)
Zero:	<u>0.0</u>	<u>0.1</u>	<u>0.4%</u>	<u>0.1</u>	<u>0.4%</u>	<u>0.0%</u>
Upscale 1:	<u>16.2</u>	<u>16.1</u>	<u>0.4%</u>	<u>16.1</u>	<u>0.4%</u>	<u>0.0%</u>
Upscale 2:						

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = \frac{4.9}{4.8} \times 12.7 = 13.4$ (Run Average)
 $C_o = 0.1$ (Average Zero)
 $C_m = 16.1$ (Average Upscale)
 $C_{ma} = 16.1$ (Cal Gas Conc)
 $C_{gas} = 13.4$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM CALIBRATION DATA EPA Method 6C Guidelines

Source ID: Hartford Landfill
Project No:
Location: Flare outlet
Pollutant: CO

Date: 11/4/03
Run No: 4
Run Time: 1520-1620
Span Value: 0-1300ppm

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:				
Cal Response:				
Absolute Difference:				
Cal Error (<2%):				

System Cal Bias and Drift Check:

Cal Gas: 720.0 (32.74%)

	Pre Cal			Post Cal	
	Analyzer Cal Rspnse	System Cal Rspnse	Syst Bias (<5%)	System Cal Rspnse	Syst Bias (<5%)
Zero:	<u>1.1</u>	<u>3.5</u>	<u>0.2%</u>	<u>2.6</u>	<u>0.1%</u>
Upscale 1:	<u>707.5</u>	<u>707.0</u>	<u>0.0%</u>	<u>708.9</u>	<u>0.1%</u>
Upscale 2:					

Calibration Error Calculation, Cerr:

$$C_{err} = \frac{\text{Calibration Response} - \text{Cal Gas Concentration}}{\text{Span}} \times 100$$

Calibration Drift Calculation, Cd:

$$C_d = \frac{\text{Pre Cal System Response} - \text{Post Cal System Response}}{\text{Span}} \times 100$$

Emissions Concentration, Cgas:

$$C_{gas} = (C - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$C = \frac{4A}{4B} = \frac{298.6}{66.8}$ (Run Average)
 $C_o = 3.1$ (Average Zero)
 $C_m = 708.0$ (Average Upscale)
 $C_{ma} = 720.0$ (Cal Gas Conc)
 $C_{gas} = \frac{301.9}{65.1}$ (Emissions Conc)

$$C_{co} = C \times (1 - (\%CO_2/100))$$

$\%CO_2 =$ (%CO₂ from M3/3A)
 $C_{co} =$ (CO Conc)

CEM-CALIBRATION DATA EPA Method 25A - THC

Source ID: Hartford Landfill
Project No: F93-09
Location: Plant Outlet

Date: 11/4/93
Run No: 4A + 4B
Run Time: 1520-1620
Span Value: 0-100 ppm

PRE-TEST Calibration Data And Linearity Check:

	Zero	Low Range	Mid Range	High Range
Cal Gas Conc:				
Cal Response:				
Cal Rspnse - Zero:				
Multiplication Factor:				
Corrected Conc (ppm):				
Cal Error (<5%):				

Multiplication Factor Calculation, Mf:

$$Mf = \frac{C_{ma}}{C_m - C_o}$$

C_{ma} = (Span Gas Conc)
 C_m = (Cal response)
 C_o = (Zero response)
 $Mf = 1.0021$

Calibration Error Calculation, Cerr:

$$Cerr = \frac{[\text{Corrected Conc (ppm)} - \text{Cal Gas Conc (ppm)}]}{\text{Cal Gas Conc (ppm)}} \times 100$$

Calibration Drift, Cd:

	Pre Cal		Post Cal		
	Gas Conc	Calibration Response	Calibration Response		Drift (<3%)
Zero:	0.0	2.0	2.0		0.0%
Upscale 1:	47.7	49.6	47.4		2.2%
Upscale 2:					

$$Cd = \frac{\text{Pre Cal Response} - \text{Post Cal Response}}{\text{Span}} \times 100$$

Emissions Conc = (Avg analyzer reading - Zero) x Mf: M18 Bag (1528-1620

Avg Reading = 4A / 4B
13.5 / 3.0

Emissions Conc =	<u>11.5</u>	<u>1.0 ppm</u>
Emissions as Carbon =	<u>34.6</u>	<u>3.0 ppmC</u>

9.8
7.8 ppm
23.4 ppmC

GAS DILUTION PERFORMANCE SPECIFICATIONS TESTS

Isolation Research Model 701-AT2 SC₂ analyzer

MONITOR: EnviroNics Series 2020 Gas Mixer S/N: 1771 DATE OF TEST: 11/4/93

TEST NO.	TIME	100% SUPPLY GAS: 240.0 ppm SC ₂		RESP DEV FROM MEAN (<=2%)	ABSOLUTE DIFFERENCE	RESPONSE ERROR (<=2%)
		PREDICTED VALUE	ANALYZER RESPONSE			
1	0752	240.0	240.8	0.3%	0.8	0.3%
2	0815	240.0	239.7	0.2%	0.3	0.1%
3	0830	240.0	239.8	0.1%	0.2	0.1%
		MEAN VALUES:	240.1	0.2%	0.4	0.2%

TEST NO.	TIME	DILUTION 1: 192.0 ppm (80%)		RESP DEV FROM MEAN (<=2%)	ABSOLUTE DIFFERENCE	RESPONSE ERROR (<=2%)
		PREDICTED VALUE	ANALYZER RESPONSE			
1	0800	192.0	193.4	0.3%	1.4	0.7%
2	0818	192.0	193.9	0.1%	1.9	1.0%
3	0832	192.0	194.8	0.4%	2.8	1.5%
		MEAN VALUES:	194.0	0.3%	2.0	1.1%

TEST NO.	TIME	DILUTION 2: 144.0 ppm (60%)		RESP DEV FROM MEAN (<=2%)	ABSOLUTE DIFFERENCE	RESPONSE ERROR (<=2%)
		PREDICTED VALUE	ANALYZER RESPONSE			
1	0803	144.0	143.4	0.6%	0.6	0.4%
2	0820	144.0	144.6	0.3%	0.6	0.4%
3	0836	144.0	144.6	0.3%	0.6	0.4%
		MEAN VALUES:	144.2	0.4%	0.6	0.4%

TEST NO.	TIME	DILUTION 3: 96.0 ppm (40%)		RESP DEV FROM MEAN (<=2%)	ABSOLUTE DIFFERENCE	RESPONSE ERROR (<=2%)
		PREDICTED VALUE	ANALYZER RESPONSE			
1	0807	96.0	97.5	1.4%	1.5	1.6%
2	0823	96.0	95.6	0.6%	0.4	0.4%
3	0839	96.0	95.3	0.9%	0.7	0.6%
		MEAN VALUES:	96.1	1.0%	0.9	0.9%

TEST NO.	TIME	DILUTION 4: 48.0 ppm (20%)		RESP DEV FROM MEAN (<=2%)	ABSOLUTE DIFFERENCE	RESPONSE ERROR (<=2%)
		PREDICTED VALUE	ANALYZER RESPONSE			
1	0811	48.0	48.6	0.1%	0.6	1.3%
2	0826	48.0	48.7	0.0%	0.7	1.5%
3	0842	48.0	48.7	0.0%	0.7	1.5%
		MEAN VALUES:	48.7	0.0%	0.7	1.4%

INDEPENDENT CHECK:

MID-LEVEL DILUTION	MID-LEVEL CAL GAS	DEV OF CAL GAS VALUE FROM DIL VALUE (<=10%)	ANALYZER RESPONSE	RESP ERROR (<=2%)
96.0 ppm	95.6 ppm	0.4%	94.8	0.8%

APPENDIX D
**Equipment Calibrations
and
EPA Protocol 1 Certification Sheets**


S-TYPE PITOT GEOMETRIC CALIBRATION PART 2 - PITOT ALIGNMENT

Probe Identification 1001
Technical Specialist TFC
Date 10/27/92

Pitot Identification 1001

A.

Transverse
Tube Axis



a 1.120
b .235
c 1.195
d .237
e 1.185
θ 99
θ' 99

$$\frac{a^2 + b^2 - c^2}{2ab} = \cos \theta$$


$$\frac{a^2 + d^2 - e^2}{2ad} = \cos \theta'$$

$$(80^\circ < \theta < 100^\circ)$$

$$(80^\circ < \theta' < 100^\circ)$$

B.

Longitudinal
Tube Axis



a 1.120
b .249
c 1.195
d .350
e 1.185
θ 96
θ' 89


$$\frac{a^2 + b^2 - c^2}{2ab} = \cos \theta$$

$$\frac{a^2 + d^2 - e^2}{2ad} = \cos \theta'$$

$$(35^\circ < \theta < 95^\circ)$$


$$(25^\circ < \theta' < 95^\circ)$$

C.



(f < 1/8")

D.



(g < 1/32")

NOTE: values in parentheses are EPA Method 2 specifications.

PROBE THERMOCOUPLE CALIBRATION

Expected Stack Temperature (T_s) _____ °R

Mercury Thermometer (T_{ref}) _____ °R

Thermocouple Readout _____ °R

Probe Identification _____

Technician _____ Date _____

Tolerances

(T_s ± 10%)

(T_{ref} ± 1.5%)

S-TYPE PITOT GEOMETRIC CALIBRATION


PART 1 - PROBE CONFIGURATION

Probe Identification 1001

Pitot Identification 1001

Technical Specialist TEC

Date 10/21/92



Specifications (EPA Method 2)

$$D_t = 3/16" \text{ to } 3/8"$$

$$D_n = 1/2"$$

$$a \geq 3/4"$$

$$b \geq 0$$

$$c \geq 3"$$

$$d \geq 3"$$

$$e \geq 3/4"$$

$$f \geq 2"$$

$$P_a = P_b$$

$$1.05 D_t \leq P \leq 1.50 D_t$$

If these specifications are met, proceed with Part 2 Pitot alignment

Pre-test / Post-test

Bar. Ps., (Pb): 30/3 in. Hg.

Pre-test / Post-test

Module Orifice Setting (in. H2O)	Standard Meter			Module Meter					Y	ΔHa (in. H2O)	Module Flowrate Q (SCFM)	OF
	Volume Vs (ft³)	Factor Ys	Temp. ts (°F)	Pressure Ps (in. H2O)	Volume Vm (ft³)	Temperatures tmi (°F)		tmo (°F)				
0.5	5.003	1.0001	62	-0.10	5.112	77	75	13.71	99.18	2.00	2.352	
1	5.004	1.0001	62	-0.10	5.166	79	75	9.61	100.51	1.92	2.5442	
1.5	10.003	1.0001	60	-0.15	10.218	82	76	15.31	100.59	1.82	2.6135	
2	10.005	1.0001	60	-0.13	10.506	82	78	13.61	100.62	2.00	2.612	
3	10.003	1.0001	60	-0.13	10.192	87	80	10.87	100.31	1.81	2.632	
								Averages	100.16	1.92		

calc		
avg		

or check, use the average ΔH_a for ΔH

$$Y = \frac{V_s (P_b + \frac{P_s}{13.6})}{V_m (P_b + \frac{\Delta H}{13.6})} \frac{(T_m + 460)}{(T_s + 460)} Y_s$$

$$\Delta H_a = \frac{[0.0317] \quad \Delta H}{Pb \quad (Im + 460)} \frac{[(Is + 460) @]^2}{[Vs \quad Ys]^2}$$

$$Q = Y (17.64) \quad V_m \quad \frac{(P_b + \frac{\Delta H}{13.6})}{(T_m + 450)} @$$

$$\text{force factor} = \frac{[(Ts + 460) \Delta H]^{1/2}}{Pb} \quad \frac{1}{2} \quad \frac{1}{2}$$

Acceptance Criteria:
 Each Y must be 1.00 ± 0.01
 Average Δ Ha must be 1.84 ± 0.25
 Each Δ Ha must be within 0.15 of the average Δ Ha

Correlation Line Equation

$$Q = m(O_F) + b$$

bmi °F	lmo °F	Reference thermometer °F	Module Leak Check	
			ps	in. Hg.
62	62	62	0.00	17

Heater Box Love Control OK:

Probe Heater Love Control OK:

Module Cleaned:

Pitot Tube Manometer Leak Check:

Calibrated and Checked by: TLC

Date: 11/11/13

Reviewed by: TEC

Date: 11/17/15

Method 5 Module Calibration

Pre-test / Post-test

Module #: 570015
Std. Meter: 1748

Date: 9/9/93
Bar, Ps., (Pb): 55.58 in. Hg.

Module Office Setting (in. H2O)	Standard Meter			Module Meter				Y	ΔHa (in. H2O)	Module Flowrate Q (SCFM)	OF
	Volume Vs (ft³)	Factor Ys	Temp. ts (°F)	Pressure Ps (in. H2O)	Volume Vm (ft³)	Temperatures tmi (°F)	tmo (°F)				
0.5	5.001	1.0001	70	-0.10	5.105	85	75	.9962	1.78	.3829	
1	5.003	1.0001	70	-0.10	5.035	86	78	1.0035	1.80	.5085	
1.5	10.001	1.0001	70	-0.15	10.135	87	79	1.0050	1.83	.6818	
2	10.003	1.0001	70	-0.15	10.131	87	80	1.0101	1.86	.7715	
3	10.003	1.0001	73	-0.15	10.125	91	81	1.0044	1.89	.9687	
								Averages	1.0043	1.88	

Check

calc	
avg	

For check, use the average ΔHa for ΔH

$$Y = \frac{Vs (Pb + \frac{Ps}{13.6})}{Vm (Pb + \frac{\Delta H}{13.6})} \frac{(Tm + 460)}{(Ts + 460)} Ys$$

$$\Delta Ha = \frac{(0.0317) \Delta H}{Pb (Tm + 460)} \frac{\Delta H}{Vs Ys} \frac{(Ts + 460)}{13.6} @ \frac{1}{2}$$

$$Q = Y (17.64) Vm \frac{(Pb + \frac{\Delta H}{13.6})}{(Tm + 460)} @ \frac{1}{2}$$

$$\text{Orifice factor} = \frac{[(Ts + 460) \Delta H]^{1/2}}{Pb^{1/2}}$$

Acceptance Criteria:
Each Y must be 1.00 ± 0.01
Average ΔHa must be 1.84 ± 0.25
Each ΔHa must be within 0.15 of the average ΔHa

Correlation Line Equation
 $Q = m (OF) + b$

tmi °F	tmo °F	Reference thermometer °F	Module Leak Check in. Hg.
71	71	71	0.00
			1.3

Heater Box Love Control OK: ☒
Probe Heater Love Control OK: ☒
Module Cleaned: ☒
Pilot Tube Manometer Leak Check: ☒

Date: 9/10/93

Date: 9/10/93

Calibrated and Checked by: TEC

Reviewed by: Hein

Method 5 Module Calibration

Date: 11/12/93
Bar. Ps., (Pb): 30.00 in. Hg

Module #: S-1441
Std. Meter: 507797

Pre-test / Post-test

Module Orifice Setting (in. H2O)	Standard Meter			Module Meter				Y	ΔH_a (in. H2O)	Module Flowrate Q (SCFM)	OF
	Volume Vs (ft ³)	Factor Ys	Temp. ts (°F)	Pressure Ps (in. H2O)	Volume Vm (ft ³)	Temperatures tmi (°F)	tmo (°F)				
0.5	5.001	1.0001	72	-0.10	5.062	85	77	1.0033	2.05	37.87	
1	5.003	1.0001	72	-0.10	5.045	85	79	1.0077	1.99	53.92	
1.5	10.001	1.0001	74	-0.15	10.142	88	80	1.0006	2.00	66.74	
2	10.003	1.0001	74	-0.15	10.120	90	82	1.0035	1.81	80.78	
3	10.002	1.0001	74	-0.15	10.109	94	82	1.0077	1.94	95.46	
								Averages	1.0050	1.96	

Check

calc		
avg		

For check, use the average ΔH_a for ΔH

$$Y = \frac{V_s (P_b + \frac{P_s}{13.6}) (T_m + 460) Y_s}{V_m (P_b + \frac{\Delta H}{13.6}) (T_s + 460)}$$

$$\Delta H_a = \frac{(0.0317) \Delta H}{P_b (T_m + 460)} \left(\frac{[(T_s + 460) @]^{1/2}}{V_s Y_s} \right)^2$$

$$Q = Y (17.64) V_m \left(\frac{P_b + \frac{\Delta H}{13.6}}{(T_m + 460)} \right) @$$

$$\text{orifice factor} = \left[\frac{(T_s + 460) \Delta H}{P_b} \right]^{1/2}$$

Acceptance Criteria:

Each Y must be 1.00 ± 0.01
Average ΔH_a must be 1.04 ± 0.25
Each ΔH_a must be within 0.15 of the average ΔH_a

Correlation Line Equation

$$Q = m (OF) + b$$

tmi °F	tmo °F	Reference thermometer °F	Module Leak Check ft ³	Module Leak Check in. Hg
72	72	72	0.06	1.3

Heater Box Love Control OK: ☒

Probe Heater Love Control OK: ☒

Module Cleaned: ☒

Pitot Tube Manometer Leak Check: ☒

Calibrated and Checked by: T.E.C.

Date: 11/12/93

Reviewed by: T.E.C.

Date: 11/12/93

Method 5 Module Calibration

Module #: 5-1451
 Std. Meter: _____
 Pre-test / Post-test

Date: 10/15/93
 Bar. Ps., (Pb): 30.23 in. Hg

Module Office Setting (in. H2O)	Standard Meter			Module Meter			Y	ΔHa (in. H2O)	Module Flowrate Q (SCFM)	OF
	Volume Vs (ft³)	Factor Ys	Temp. Ts (°F)	Pressure Ps (in. H2O)	Volume Vm (ft³)	Temperatures tmi (°F)	tmo (°F)			
0.5	5.002	1.0001	54	-0.10	5.150	70	60	990.7	1.81	10.43
1	5.003	1.0001	54	-0.10	5.156	72	62	992.3	1.86	5.634
1.5	10.003	1.0001	54	-0.10	10.331	76	64	1004.2	1.89	6.957
2	10.004	1.0001	54	-0.15	10.215	76	66	1006.6	1.75	8.152
3	10.001	1.0001	56	-0.15	10.210	78	68	1002.3	1.81	7.873
								Averages	999.2	1.81

calc	
avg	

check

For check, use the average ΔHa for ΔH

$$Y = \frac{Vs (Pb + \frac{Ps}{13.6}) (Tm + 460) Ys}{Vm (Pb + \frac{\Delta H}{13.6}) (Ts + 460)}$$

$$\Delta Ha = \frac{(0.0317) \frac{\Delta H}{Pb} (Tm + 460)}{[\frac{(Ts + 460)}{Vs} Ys]^2}$$

$$Q = Y (17.64) Vm \left(Pb + \frac{\Delta H}{13.6} \right) @$$

$$\text{ifice factor} = \left[\frac{(Ts + 460) \Delta H}{Pb} \right]^{1/2}$$

Acceptance Criteria:
 Each Y must be 1.00 ± 0.01
 Average ΔHa must be 1.84 ± 0.25
 Each ΔHa must be within 0.15 of the
 average ΔHa

Correlation Line Equation
 $Q = m (OF) + b$

tmi °F	tmo °F	Reference thermometer °F	Module Leak Check ft³	In. Hg.
54	54	54	0.00	12

Heater Box Love Control OK: ☒
 Probe Heater Love Control OK: ☒
 Module Cleaned: ☒
 Pitot Tube Manometer Leak Check: ☒

Calibrated and Checked by: T.E.C. Date: 10/15/93

Reviewed by: T.E.C. Date: 10/15/93

Katheson

P.O. Box 136
6874 South Main Street
Morrow, Georgia 30260
Phone: (404) 961-7891

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

CUSTOMER: ABCO Welding & Ind. Supply

REFERENCE #: 105-94941

CYLINDER #: SX-11721

PROTOCOL: G1

CYLINDER PRESSURE: 2000

LAST ANALYSIS DATE: 09/25/92

EXPIRATION DATE: 03/25/94

REPLICATE CONCENTRATIONS

COMPONENT : Propane

DATE: 09/25/92

DATE: / /

MEAN CONC : 95.3 PPM

95.3 PPM

95.2 PPM

95.4 PPM

COMPONENT :

DATE: / /

DATE: / /

MEAN CONC :

COMPONENT :

DATE: / /

DATE: / /

MEAN CONC :

BALANCE GAS: Nitrogen

REFERENCE STANDARDS

SRM # : 2643

CYLINDER # : CAL5086

CONCENTRATION: 100 PPM

CERTIFICATION INSTRUMENTS

COMPONENT Propane
 MAKE/MODEL Beckman THC
 SERIAL NUMBER 1003052
 MEASUREMENT PRINC. FID
 LAST CALIBRATION 07/01/92

REPLICATE DATA COMPONENT: Propane

DATE 09/25/92

1. Z = 0 R = 413.5 C = 394.1
 2. R = 412.5 Z = 0 C = 392.7
 3. Z = 0 C = 393.8 R = 412.8

DATE / /

Z = R = C =
 R = Z = C =
 Z = C = R =

REPLICATE DATA COMPONENT:

DATE / /

1. Z = R = C =
 2. R = Z = C =
 3. Z = C = R =

DATE / /

Z = R = C =
 R = Z = C =
 Z = C = R =

REPLICATE DATA COMPONENT:

DATE / /

1. Z = R = C =
 2. R = Z = C =
 3. Z = C = R =

DATE / /

Z = R = C =
 R = Z = C =
 Z = C = R =

R = Reference Gas, C = Candidate Gas, Z = Zero Gas

This certification was performed according to EPA Protocol method (s) described in section 2.0.7.G1, and/or section 2.0.7.G2.

ANALYST Pat H. [Signature]

DATE 10/2/92

Matheson

P.O. Box 351
1650 Enterprise Parkway
Twinsburg, Ohio 44067
Phone: (216) 425-4406

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

CUSTOMER: ABCO WELDING & IND SUPPLY

REFERENCE #: 109-21151

CYLINDER #: SX-26562

PROTOCOL: 1

CYLINDER PRESSURE: 2000

LAST ANALYSIS DATE: 05/26/93

EXPIRATION DATE: 05/26/96

REPLICATE CONCENTRATIONS

COMPONENT : CARBON MONOXIDE

DATE: 05/19/93

DATE: 05/26/93

MEAN CONC : 84.9 PPM

85.1 PPM

85.1 PPM

84.7 PPM

84.9 PPM

84.6 PPM

84.9 PPM

COMPONENT :

DATE: / /

DATE: / /

MEAN CONC :

COMPONENT :

DATE: / /

DATE: / /

MEAN CONC :

BALANCE GAS: NITROGEN

REFERENCE STANDARDS

SRM # : GMS 1679C

CYLINDER # : SX-23294

CONCENTRATION: 97.2 PPM

CERTIFICATION TEST RESULTS

COMPONENT CARBON MONOXIDE
 MAKE/MODEL TECO 48H
 SERIAL NUMBER 48H-37040-255
 MEASUREMENT PRINC. INFRARED
 LAST CALIBRATION 03/23/93

REPLICATE DATA COMPONENT: CARBON MONOXIDE

DATE 05/19/93

1. Z = 0 C = 474.5 R = 542
 2. C = 476 R = 546 Z = 0
 3. R = 542 Z = 0 C = 472

DATE 05/26/93

Z = 0 C = 235 F = 268.5
 C = 235 R = 269 Z = 0
 R = 269 Z = 0 C = 235

REPLICATE DATA COMPONENT:

DATE / /

1. Z = C = R =
 2. C = F = Z =
 3. R = Z = C =

DATE / /

Z = C = R =
 C = R = Z =
 R = Z = C =

REPLICATE DATA COMPONENT:

DATE / /

1. Z = C = R =
 2. C = F = Z =
 3. R = Z = C =

DATE / /

Z = C = R =
 C = R = Z =
 R = Z = C =

R = Reference Gas, C = Candidate Gas, Z = Zero Gas

This certification was performed according to EPA Protocol method (s)
 described in section 3.0.4.G1, and/or section 3.0.4.G2.

ANALYST

Tracy Allen

DATE

6.2.93

Katheson

P.O. Box 358
1650 Enterprise Parkway
Twinsburg, Ohio 44087
Phone: (216) 425-4406

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

CUSTOMER: ABCO WELDING & IND SUPPLY

REFERENCE #: 109-21151

CYLINDER #: SX-26160

PROTOCOL: 1

CYLINDER PRESSURE: 1800

LAST ANALYSIS DATE: 05/25/93

EXPIRATION DATE: 05/25/95

REPLICATE CONCENTRATIONS

COMPONENT : NITRIC OXIDE

DATE: 05/10/93

DATE: 05/25/93

MEAN CONC : 93.8 PPM

95.2 PPM

92.6 PPM

94.8 PPM

94.0 PPM

93.5 PPM

91.8 PPM

COMPONENT :

DATE: / /

DATE: / /

MEAN CONC :

COMPONENT :

DATE: / /

DATE: / /

MEAN CONC :

BALANCE GAS: NITROGEN

REFERENCE STANDARDS

SERIAL # : 1684b

CYLINDER # : CLM-2235

CERTIFICATION INSTRUMENTS

COMPONENT NITRIC OXIDE
 MAKE/MODEL TECO 14A
 SERIAL NUMBER 14A-13108-134
 MEASUREMENT PRINC. CHEMILUMINESCENCE
 LAST CALIBRATION 05/17/93

REPLICATE DATA COMPONENT: NITRIC OXIDE

DATE 05/10/93

1. Z = 0 C = 499 R = 499
 2. C = 497 R = 499 Z = 0
 3. R = 496 Z = 0 C = 487

DATE 05/25/93

Z = 0 C = 459 R = 472
 C = 464 R = 470 Z = 0
 R = 475 Z = 0 C = 463

REPLICATE DATA COMPONENT:

DATE / /

1. Z = C = R =
 2. C = R = Z =
 3. R = Z = C =

DATE / /

Z = C = R =
 C = R = Z =
 R = Z = C =

REPLICATE DATA COMPONENT:

DATE / /

1. Z = C = R =
 2. C = R = Z =
 3. R = Z = C =

DATE / /

Z = C = R =
 C = R = Z =
 R = Z = C =

R = Reference Gas, C = Candidate Gas, Z = Zero Gas

This certification was performed according to EPA Protocol method (s) described in section 3.0.9.G1, and/or section 3.0.9.G2.

ANALYST

July 1, 1993

DATE

6.2.93

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

CUSTOMER: ABCO WELDING

REFERENCE #: 109-23706

CYLINDER #: SX-26553

PROTOCOL: 1

CYLINDER PRESSURE: 2000

LAST ANALYSIS DATE: 09/03/93

EXPIRATION DATE: 09/03/95

REPLICATE CONCENTRATIONS

COMPONENT	:	NITRIC OXIDE	DATE:	08/27/93	DATE:	09/03/93
MEAN CONC	:	228 PPM		227 PPM		228 PPM
				228 PPM		228 PPM
				229 PPM		228 PPM

COMPONENT	:	NITROGEN DIOXIDE	DATE:	/ /	DATE:	/ /
MEAN CONC	:	1 PPM				

COMPONENT	:		DATE:	/ /	DATE:	/ /
MEAN CONC	:					

BALANCE GAS: NITROGEN

REFERENCE STANDARDS

SRM # : 1686B

CYLINDER # : CLM-4883

CONCENTRATION: 492 PPM

10/1/93
10/1/93
10/1/93
10/1/93

Katheson

P.O. Box 358
1650 Enterprise Parkway
Twinsburg, Ohio 44087
Phone: (216) 425-4406

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

CUSTOMER: AECO WELDING & IND SUPPLY

REFERENCE #: 109-21151

CYLINDER #: SX-16485

PROTOCOL: 1

CYLINDER PRESSURE: 2000

LAST ANALYSIS DATE: 06/01/93

EXPIRATION DATE: 06/01/95

REPLICATE CONCENTRATIONS

COMPONENT : SULFUR DIOXIDE

DATE: 05/23/93

DATE: 06/01/93

MEAN CONC : 95.6 PPM

95.9 PPM

95.1 PPM

95.5 PPM

95.1 PPM

96.1 PPM

95.8 PPM

COMPONENT :

DATE: / /

DATE: / /

MEAN CONC :

COMPONENT :

DATE: / /

DATE: / /

MEAN CONC :

BALANCE GAS: NITROGEN

REFERENCE STANDARDS

SERIAL #: 1694A

CYLINDER #: CLM-4753

CONCENTRATION: 97.0 PPM

CERTIFICATION STATEMENTS

COMPONENT SULFUR DIOXIDE

MAKE/MODEL TECO 40

SERIAL NUMBER 40-37461-255

MEASUREMENT PRINC. FLUORESCENCE

LAST CALIBRATION 04/20/93

REPLICATE DATA COMPONENT: SULFUR DIOXIDE

DATE 05/23/93

1. Z = 0 C = 256 R = 259
2. C = 257 R = 261 Z = 0
3. R = 259.5 Z = 0 C = 257

DATE 06/01/93

Z = 0 C = 254 R = 259
C = 254 R = 259 Z = 0
R = 259 Z = 0 C = 256

REPLICATE DATA COMPONENT:

DATE / /

1. Z = C = R =
2. C = R = Z =
3. R = Z = C =

DATE / /

Z = C = R =
C = R = Z =
R = Z = C =

REPLICATE DATA COMPONENT:

DATE / /

1. Z = C = R =
2. C = R = Z =
3. R = Z = C =

DATE / /

Z = C = R =
C = R = Z =
R = Z = C =

R = Reference Gas, C = Candidate Gas, Z = Zero Gas

This certification was performed according to EPA Protocol method (s) described in section 3.0.7.G1, and/or section 3.0.7.G2.

ANALYST J. L. Allen

DATE 6.2.93

ABCO WELDING & INDUSTRIAL SUPPLY, INC.

130 CROSS ROAD
P.O. BOX 296
WATERFORD, CT 06385
(203) 442-0363 • 800-962-0285
FAX: (203) 447-3347

OUR 70TH YEAR
1921-1991

BRANCH STORES

ABCO RI
83 GILBANE ST.
WARWICK, RI 02886
(401) 732-2920

CHESHIRE COMPRESSED GAS
140 COMMERCE CT.
CHESHIRE, CT 06410
(203) 272-0369

Technical Data Typical Purity Specifications

Nitrogen	Zero Grade
Chemical Symbol:	N ₂
Minimum Purity:	99.998%
Water:	< 3 ppm
Oxygen	< 5 ppm
THC	< 0.5 ppm
CGA Valve Connection:	CGA580
DOT Shipping Name:	Nitrogen
DOT Hazard Class:	Nonflammable Gas
I.D. Number	UN1066
Specification:	Matheson Zero Grade Specs

Date: ____/____/____

Delivery ticket # _____

Customer Name: _____

Cylinder Serial Number: _____

APPENDIX E

**Laboratory Analysis Reports
and
Analytical Data Sheets**

CHAIN OF CUSTODY FORM
PLEASE COMPLETE AND RETURN

Project No: R93-09 Date Sampled: 11/4/93
 Client: CARRA Location: Landfill Flare
 Project Mgr: Richard Kogacz

SAMPLE RECOVERY

CONTAINER CODE	DESCRIPTION
<u>M18-0-1</u>	
<u>M18-0-2</u>	
<u>M18-0-3</u>	
<u>M18-0-4</u>	
<u>M18-1-Inlet</u>	<u>← Not recovered</u>
<u>M18-2-Inlet</u>	
<u>M18-3-Inlet</u>	
<u>M18-4-Inlet</u>	

PERSON ENGAGED IN SAMPLE RECOVERY

Signature: [Signature]
 Title: Project Manager
 Recovery Location: Hartford Landfill
 Date and time of recovery: 11/4/93 p.m.

SAMPLE(S) RECIPIENT, UPON RECOVERY, IF NOT RECOVERY PERSON

Signature: _____
 Title: _____
 Date and time of receipt: _____
 Sample storage: _____

LABORATORY PERSON RECEIVING SAMPLE(S)

Signature: [Signature]
 Title: Gen. President
 Date and time of receipt: 8:45 AM, NOV. 5, 1993
 Sample storage: Teller

ANALYSIS

CONTAINER CODE	METHOD OF ANALYSIS	DATE AND TIME OF ANALYSIS	SIGNATURE OF ANALYST



Mr. Richard Kopacz
ROJAC Environmental Services, Inc.
30 Arbor Street
Hartford, CT 06106

Report No. AAL-1272
Date Received 11-05-93
Date Reported 11-11-93
P.O. No. 27244

Material Submitted: Seven Gas Samples in Tedlar Bags;
Rojac Project No. F93-09

Information Requested: Gas Chromatographic and
Mass Spectrometric Analysis

Notebook: YP110,p85-88;MS115,p2

Subject samples were analyzed for Total Non-Methane Hydrocarbons
following EPA Method 18 protocol.

Results are attached.

p1111


Don Pachuta, Ph.D.

FAX: 203-232-5378

TELEPHONE: 203-232-8959

Enclosures: Chain of Custody
Chromatograms
Notebook pages

Results of AnalysisGas Samples

Concentration % v/v Dry Basis

Sample Identification	<u>M18-1</u>	<u>M18-3</u>	<u>M18-4</u>
Nitrogen	12.0	8.5	33.6
Oxygen	1.3	0.49	8.0
Argon	0.14	0.11	0.40
Carbon Dioxide	34.7	35.9	24.5
Hydrogen	ND 0.01	ND 0.01	ND 0.01
Helium	ND 0.01	ND 0.01	ND 0.01
Methane	51.8	55.0	33.5
Total Non-Methane			
Hydrocarbons, as hexane	0.021	0.019	0.019
equivalent			
Hydrocarbons, as methane	0.13	0.11	0.11
equivalent			
Lower Heating Value, BTU/CuFt	513	545	332
Higher Heating Value, BTU/CuFt	524	557	339

ND = None detected, followed by the limit of detection.

Page 3 of 3

Results of AnalysisGas Samples

Concentration % v/v Dry Basis

Sample Identification	<u>M18-0-1</u>	<u>M18-0-2</u>	<u>M18-0-3</u>
Nitrogen	-	-	-
Oxygen	-	-	-
Argon	-	-	-
Carbon Dioxide	-	-	-
Hydrogen	-	-	-
Helium	-	-	-
Methane	-	-	-
Total Non-Methane			
Hydrocarbons, as hexane	ND 0.001	ND 0.001	ND 0.001
equivalent			
Hydrocarbons, as methane	ND 0.006	ND 0.006	ND 0.006
equivalent			
Lower Heating Value, BTU/CuFt	-	-	-
Higher Heating Value, BTU/CuFt	-	-	-

ND = None detected, followed by the limit of detection.



APPENDIX F

Operational/Process Data

OPERATION

The LFG Specialties enclosed flare system is designed for fully automatic, unattended operation. To familiarize yourself with the features and flexibility of the complete system, please review this operation and maintenance manual prior to proceeding with the start-up or adjustment of the control system.

To assure both personal and equipment safety, a qualified LFG Specialties factory representative should have completed the initial start-up and commissioning of the enclosed flare station before standard operation is commenced. The qualified representative will also conduct an on-site training session with the customer's operating personnel to assure safe and efficient operation of the enclosed flare station.

Under standard operating conditions, all that is required to start the enclosed flare is to turn the operation mode switch in the Flame-Trol II controller to "Auto". The controller will then automatically start the system proceeding through the following logic sequence:

- 1) Placing the operation mode switch to "Auto", will activate the purge timer and start the purge blower.
Permissive: Main header valve must be in closed position
- 2) When purging is complete the pilot and igniter timers are activated, powering the pilot gas solenoid valve and the ignition system.
Permissive: Flare stack temperature reading must be below the set point in the temperature controller.

Purge pressure switch must sense the purge air flow to confirm that the flare stack is being purged.

Header valve must be in the closed position.
- 3) The pilot will ignite and raise the pilot thermocouple temperature to the blower-on set point.

- 4) At the blower-on set point the controller will start the blower and open the landfill gas main header valve.
Permissive: The pilot must achieve the pilot off temperature within the time set in the pilot timer or the system will shutdown indicating "pilot failure".
- The ultraviolet scanner must confirm the pilot flame.
- 5) The pilot will ignite the landfill gas and raise the thermocouple temperature to the pilot-off setting, which is the High Alarm setting on the pilot temperature controller.
Permissive: Header valve must be in the open position, otherwise the blower would shutdown.
- 6) At the pilot-off temperature (High Alarm setting on the pilot temperature controller), the controller will close the pilot gas solenoid valve
- 7) The flare will continue to operate if and only if all of the following conditions are met:
- A - Header valve is maintained in the open position.
 - B - Flame is confirmed by the ultraviolet scanner.
 - C - Flare chamber temperature is maintained above the low temperature shutdown (HL, High Alarm) on the flare chamber temperature controller.
 - D - Flare chamber temperature is maintained below the high temperature shutdown (SV, Set Value) on the flare chamber temperature controller.
- 8) The flare will shutdown, activate the down timer and go into the automatic restart sequence if:
- A - Flame is not confirmed by the ultraviolet scanner for more than 4 seconds.
 - B - Flare chamber temperature falls below the low temperature shutdown (High Alarm) on the flare chamber temperature controller. The low temperature shutdown is locked out for 15 minutes on start-up.

9) The flare will shutdown and will not go to down time or try to reignite automatically if:

- A - Purge pressure switch does not confirm the purge air flow prior to ignition cycle on start-up.
- B - Pilot does not achieve the pilot off temperature (High Alarm) on the pilot temperature controller within the time set in the pilot timer.
- C - Header valve does not make the open position contact (Delay: 30 seconds on start-up).
- D - Low temperature shutdown is not reached within 15 minutes from start-up.
- E - Flare chamber temperature rises above the high temperature shutdown (Set Value) on the flare chamber temperature controller.

Note: To reinstate the automatic controls, the system must be manually reset by pushing the reset button on the face panel of the Flame-Trol II controller.