

**Horizon Test #:** B06-016-FR  
**Date Tested:** August 28, 2007  
**Report Date:** October 18, 2007  
**Revision Number:** 0

**EMISSION COMPLIANCE TEST  
ON A LANDFILL GAS FLARE**

**Flare #3**

**Sunshine Canyon Landfill**

**Permit to Operate No. F23230  
Facility ID No.: 049111**

***Prepared for:***


BFI of California  
Sunshine Canyon Landfill  
14747 San Fernando Road  
Sylmar, California 91342

***Prepared by:***


Horizon Air Measurement Services, Inc.  
996 Lawrence Drive, Suite 108  
Newbury Park, California 91320

***Regulatory Agency***

South Coast Air Quality Management District  
21865 East Copley Drive  
Diamond Bar, California 91765



**Edward S. Swede  
Project Manager**



**Richard J. Vacherot  
Technical Director**



October 18, 2007

Ms. Susan Jennings  
Sunshine Canyon Landfill  
14747 San Fernando Road  
Sylmar, California 91342

Dear Ms. Jennings:

Please find enclosed three copies of the final report entitled "Emission Compliance Test on a Landfill Gas Flare" for submittal to SCAQMD.

If you have any questions, please call me at (805) 498-8781.

Sincerely,

HORIZON AIR MEASUREMENT SERVICES, INC.

A handwritten signature in purple ink that reads "Edward S. Swede". The signature is written in a cursive, flowing style.

Edward S. Swede  
Project Manager

RV:lmg

## **CERTIFICATE OF NO CONFLICT OF INTEREST**

I certify that I am responsible for the testing operations of Horizon Air Measurement Services, Inc. (Horizon) and am authorized to sign this certificate on Horizon's behalf.

Horizon may conduct tests as an independent contractor of the California Air Resources Board pursuant to Section 91200-91220 of Title 17, of the California Code of Regulations and SCAQMD Rule 304(L). I further certify that Horizon only utilizes personnel to participate in such tests where such testing and participation would not be prohibited by Section 91208, "Conflict of Interest", Title 17, California Code of Regulations.

Signature: \_\_\_\_\_

Name: Richard J. Vacherot

Title: Technical Director

Date: \_\_\_\_\_

10/17/07

## **TABLE OF CONTENTS**

|                                                                                                             |         |
|-------------------------------------------------------------------------------------------------------------|---------|
| 1. INTRODUCTION .....                                                                                       | Page 1  |
| 2. SUMMARY OF RESULTS .....                                                                                 | Page 3  |
| 3. FLARE DESCRIPTION AND OPERATION .....                                                                    | Page 5  |
| 3.1 Flare Description .....                                                                                 | Page 5  |
| 3.2 Flare Operation .....                                                                                   | Page 5  |
| 3.3 Sample Location .....                                                                                   | Page 6  |
| 4. SAMPLING/ANALYSES .....                                                                                  | Page 7  |
| 4.1 Sample Location .....                                                                                   | Page 7  |
| 4.1.1 Flare Exhaust .....                                                                                   | Page 7  |
| 4.1.2 Landfill Gas Supply Line .....                                                                        | Page 7  |
| 4.2 Moisture (Inlet/Outlet) .....                                                                           | Page 8  |
| 4.3 Flow Rate/Temperature (Inlet/Outlet) .....                                                              | Page 8  |
| 4.4 PM10 as Particulate Matter (Outlet) .....                                                               | Page 8  |
| 4.5 Oxides of Nitrogen, Carbon Monoxide, Carbon Dioxide,<br>Oxygen (Outlet) .....                           | Page 8  |
| 4.6 Hydrogen Sulfide (H <sub>2</sub> S), and C <sub>1</sub> - C <sub>3</sub> Sulfur Compounds (Inlet) ..... | Page 9  |
| 4.7 Speciated Organic Compounds (Inlet/Outlet) .....                                                        | Page 9  |
| 4.8 Total Non Methane Hydrocarbons, Methane (Outlet) .....                                                  | Page 9  |
| 4.9 Total Non Methane Hydrocarbons, Methane (Inlet) .....                                                   | Page 9  |
| 4.10 Carbon Monoxide, Carbon Dioxide, Oxygen and Nitrogen (Inlet) .....                                     | Page 9  |
| 5. RESULTS DISCUSSION .....                                                                                 | Page 10 |

APPENDIX A - Methods Description

APPENDIX B - Computer Printout of Results

APPENDIX C - Field Data

APPENDIX D - Laboratory Data

APPENDIX E - Operating Data

APPENDIX F - Strip Chart Records

APPENDIX G - Calibration Data

APPENDIX H - Permit to Operate

## **1. INTRODUCTION**

Under Permit to Operate (PTO) F23230 or per the approved 1150.1 compliance plan which states, "at least one flare every year and then alternate all others such that each is source tested at least once every three years", BFI of California (BFI) is required to conduct an annual source test on the subject landfill gas flare (Flare #3) located at the Sunshine Canyon Landfill in Sylmar, California. Horizon Air Measurement Services, Inc. (Horizon) had been retained for this purpose. The last scheduled test was August 2004 for Flare #3. The next scheduled routine source test will be conducted in August 2010.

The test program was completed on August 28, 2007 by Horizon in accordance with the SCAQMD-approved Test Plan (Horizon # B06-016-TP). The test was not observed by SCAQMD, even though SCAQMD had been notified seven days in advance. The test matrix is shown in Table 1-1.

The results of the testing program, with respect to PTO limits, are summarized in Section 2, Summary of Results. A brief description of the flare and flare operating conditions during testing is provided in Section 3. Section 4 provides a detailed description of the sampling/analytical techniques utilized. Section 5 provides a more detailed results summary/discussion.

**Table 1-1**  
**Compounds of Interest**  
**BFI - Sunshine Canyon Landfill**  
**Flare 3**  
**August 28, 2007**

| <b>Parameter</b>                                                                         | <b>Location</b> | <b>Method</b>                                         | <b>Number of<br/>Samples Per<br/>Flare</b> |
|------------------------------------------------------------------------------------------|-----------------|-------------------------------------------------------|--------------------------------------------|
| Total Non-Methane Hydrocarbons<br>(TNMHC)                                                | Inlet           | ASTM D3588/D1945                                      | 1                                          |
|                                                                                          | Outlet          | SCAQMD Method 25.3                                    | 2                                          |
| Reduced Sulfur Compounds<br>(C <sub>1</sub> -C <sub>3</sub> ) Including H <sub>2</sub> S | Inlet           | SCAQMD Method 307.91 (equivalent)                     | 1                                          |
| Speciated Organic Compounds                                                              | Inlet           | EPA TO-15                                             | 1                                          |
|                                                                                          | Outlet          | EPA TO-15                                             | 3                                          |
| Particulate Matter                                                                       | Outlet          | SCAQMD Method 5.1                                     | 1                                          |
| Oxides of Nitrogen                                                                       | Outlet          | SCAQMD Method 100.1                                   | 1                                          |
| Oxides of Sulfur                                                                         | Outlet          | Calculated based on inlet reduced sulfur<br>compounds | 1                                          |
| Carbon Monoxide                                                                          | Outlet          | SCAQMD Method 100.1                                   | 1                                          |
|                                                                                          | Inlet           | ASTM D 3588                                           | 1                                          |
| Oxygen                                                                                   | Outlet          | SCAQMD Method 100.1                                   | 1                                          |
|                                                                                          | Inlet           | ASTM D 3588                                           | 1                                          |
| Carbon Dioxide                                                                           | Inlet           | ASTM D 3588                                           | 1                                          |
|                                                                                          | Outlet          | SCAQMD Method 100.1                                   | 1                                          |
| Methane                                                                                  | Inlet           | ASTM D 3588                                           | 1                                          |
|                                                                                          | Outlet          | SCAQMD Method 25.3                                    | 1                                          |
| Flow Rate/Temperature                                                                    | Inlet           | SCAQMD Method 2.1                                     | 1                                          |
|                                                                                          | Outlet          | SCAQMD Method 2.1                                     | 1                                          |
| Moisture                                                                                 | Outlet          | SCAQMD Method 5.1                                     | 1                                          |
|                                                                                          | Inlet           | SCAQMD Method 4.1                                     | 1                                          |
| BTU Content                                                                              | Inlet           | ASTM D3588                                            | 1                                          |

## **2. SUMMARY OF RESULTS**

The results of the testing program are provided in Table 2-1. All flare emission rates are based upon the measured exhaust flow rate. Carbon monoxide concentrations were below the quantifiable limit of 20 ppm and is reported as such.

A more detailed summary of results is provided in Section 5.

**Table 2-1**  
**Summary of Results**  
**BFI - Sunshine Canyon Landfill**  
**Flare 3**  
**August 28, 2007**

| <b>Parameter</b>                             | <b>Emission Rate</b>                           | <b>Allowable Emissions</b>                                    |
|----------------------------------------------|------------------------------------------------|---------------------------------------------------------------|
| Inlet Gas Flow Rate                          | 2,900 dscfm                                    | 4,167 dscfm                                                   |
| Oxides of Nitrogen                           | 1.56 lb/hr                                     | 6.3 lb/hr                                                     |
| Total Particulate Matter (PM <sub>10</sub> ) | 0.29 lb/hr                                     | 0.64 lb/hr                                                    |
| Carbon Monoxide                              | <2.07 lb/hr                                    | 3.7 lb/hr                                                     |
| Reactive Organic Gases, as CH <sub>4</sub>   | 0.190 lb/hr                                    | 0.63 lb/hr                                                    |
|                                              | 1.13 ppm (C <sub>6</sub> ) @ 3% O <sub>2</sub> | 20 ppm (C <sub>6</sub> ) @ 3% O <sub>2</sub><br>(Rule 1150.1) |
|                                              | 99.5% DRE                                      | 98% DRE                                                       |
| Oxides of Sulfur, as SO <sub>2</sub>         | 2.41 lb/hr                                     | 3.8 lb/hr                                                     |
| Heat Output                                  | 84.6 MMBtu/hr                                  | 105 MMBtu/hr                                                  |

### **3. FLARE DESCRIPTION AND OPERATION**

#### **3.1 Flare Description**

The landfill gas flare is a Flare Industries equivalent to a McGill model No. EFG-125: consisting of an insulated steel cylinder 50 feet high and approximately 13 feet in diameter. Operating flow rate is limited (by permit conditions) to either 4167 scfm or 105 million BTU/hr, whichever is reached first. The flow rate, continuously monitored during the testing on BFI's permanent strip chart recorder, averaged 2,719 scfm. (Appendix E).

The flare is equipped with a multi-jet burner, propane gas pilot system with electric ignitor system, UV flame sensor (s), automatic shutdown and alarm system, automatic combustion air regulating system (louvers) and temperature controller.

The flare operating temperature range is 1,600°F to 2,000°F. Flare operating temperature during the test was set within this range. Flare temperature was continuously monitored by the facility over the duration of the testing period (Appendix E).

#### **3.2 Flare Operation**

Landfill gas to the flare is supplied by operating one or two blowers: Lampson, Model 362-2D, each 45 H.P., one blower for standby, venting the landfill gas collection system. The blowers supply a vacuum to the landfill gas collection system to extract gas from the landfill. The blower(s) then discharge the gas at a slightly positive pressure towards the flare where additional particulate material is removed in the particulate filter prior to combustion in the flare.

Gas enters the flare through a flame arrestor into the multi-jet burner where it is distributed to one of the six burners. The temperature is regulated by thermocouples (temperature sensors) located through the flare stack at different heights. The temperature then regulates the amount of air allowed in to the combustion chamber through the automated louvers depending upon stack temperature. The higher the temperature the more the louvers will try to open to maintain the preset temperature, and work on the same parameter as the temperature drops the louvers close. This test was conducted at operating temperature above the permitted limit of 1,600°F.

Typical flare operating temperature range is 1,600°F to 2,000°F. Flare operating temperature during this test was set at the 1,650°F. Flare stack and combustion temperature was continuously monitored by the facility over the duration of the testing period.

### 3.3 Sample Location

Flare exhaust samples were obtained from the sample ports, of which there are four, positioned at right angles, six and a half feet from the top of the flare.

The flare inlet landfill gas supply line is 16 inches in diameter (OD) schedule 40 pipe, which is stainless steel. One sample port is located approximately 24 inches upstream of a disturbance and at 84 inches downstream of a bend in the supply piping.

## 4. SAMPLING/ANALYSES

The sampling/analytical program had been designed to quantify the parameters of interest outlined in Table 1-1.

### 4.1 Sample Location

#### 4.1.1 Flare Exhaust

At the flare exhaust 24 sample points (12 per diameter), determined in accordance with Method 1, were utilized for the determination of the following compounds:

- PM<sub>10</sub>, as particulate matter
- NO<sub>x</sub>
- CO
- O<sub>2</sub>/CO<sub>2</sub>
- Flow Rate
- Moisture

A single sample point was used for the collection of the following samples:

- speciated organic compounds
- total non methane hydrocarbons
- methane

#### 4.1.2 Landfill Gas Supply Line

A single sample point was utilized for the collection of the following compounds:

- moisture
- total non methane hydrocarbons
- CO
- CO<sub>2</sub>/O<sub>2</sub>
- reduced sulfur compounds
- speciated organic compounds
- BTU content

#### 4.2 Moisture (Inlet/Outlet)

Moisture content of the landfill gas was determined using SCAQMD Method 4.1. One, sixty-minute SCAQMD Method 4.1 run was conducted at the landfill gas inlet. Moisture content of the exhaust was determined using SCAQMD Method 4.1 in conjunction with SCAQMD Method 5.1 sampling. A description of SCAQMD Method 4.1 is provided in Appendix A.

#### 4.3 Flow Rate/Temperature (Inlet/Outlet)

The landfill gas flow rate was determined using SCAQMD Method 1.1 and 2.1. The flare exhaust flow rate was determined using SCAQMD Methods 1.1 and 2.1 in conjunction with SCAQMD Method 5.1. Descriptions of SCAQMD Methods 1.1 and 2.1 are provided in Appendix A.

#### 4.4 PM10 as Particulate Matter (Outlet)

Horizon conducted one, 60-minute test run on the flare exhaust for particulate matter determination in accordance with SCAQMD Method 5.1 as described in Appendix A. Twenty-four traverse points were utilized. Samples were withdrawn isokinetically from each of the determined traverse points.

#### 4.5 Oxides of Nitrogen, Carbon Monoxide, Carbon Dioxide, Oxygen (Outlet)

One, 60-minute test run was conducted at the flare exhaust. Twenty-four sample points were utilized. All sampling was performed under the guidelines of SCAQMD Method 100.1 as detailed in Appendix A.

#### 4.6 Hydrogen Sulfide (H<sub>2</sub>S), and C<sub>1</sub> - C<sub>3</sub> Sulfur Compounds (Inlet)

Hydrogen sulfide and C<sub>1</sub> - C<sub>3</sub> sulfur compounds samples were collected at the inlet of the flare using the Tedlar bag collection system depicted in Appendix A. All system components coming in contact with the landfill gas were polypropylene or Teflon.

All reduced sulfur samples were analyzed within 24 hours of collection. Hydrogen sulfide and C<sub>1</sub> - C<sub>3</sub> sulfur compounds were analyzed using a Method 307.91 equivalent by AtmAA, Inc. Equivalency has been formally granted by SCAQMD to AtmAA, Inc. for this Method.

#### 4.7 Speciated Organic Compounds (Inlet/Outlet)

One inlet and three outlet samples were gathered in Tedlar bags using the Tedlar bag lung sampling procedure described in Appendix A for analysis using TO-15 (GC/MS) for speciated organic compounds (Rule 1150.1 list).

#### 4.8 Total Non Methane Hydrocarbons, Methane (Outlet)

Duplicate samples for methane and total non methane hydrocarbon (TNMHC) samples were collected at the outlet using SCAQMD Method 25.3 as described in Appendix A.

#### 4.9 Total Non Methane Hydrocarbons, Methane (Inlet)

Total non-methane/non-ethane hydrocarbons and methane concentration of the landfill gas were determined using ASTM D1945. A description of ASTM D1945 is provided in Appendix A.

#### 4.10 Carbon Monoxide, Carbon Dioxide, Oxygen and Nitrogen (Inlet)

Oxygen and carbon dioxide concentrations of the landfill gas were determined using SCAQMD Method 10.1. Nitrogen was determined by difference. A description of SCAQMD Method 10.1 is provided in Appendix A.

## **5. RESULTS DISCUSSION**

The results of the test program are provided in Table 5-1. Trace organic species emission rates and destruction efficiencies are presented in Tables 5-2, 5-3 and 5-4.

### **Test Critique**

No sampling or analytical problems were encountered during any phase of the test program.

**Table 5-1**  
**Summary of Results**  
**BFI - Sunshine Canyon Landfill**  
**Flare 3**  
**August 28, 2007**

|                                                                | LANDFILL GAS | FLARE EXHAUST |
|----------------------------------------------------------------|--------------|---------------|
| Run Number                                                     | 1            | 1             |
| <b>STACK GAS CHARACTERISTICS</b>                               |              |               |
| Temperature, degrees F*                                        | 115          | 1651          |
| Moisture, %                                                    | 6.2          | 9.6           |
| Flow Rate, acfm                                                | 3634         |               |
| Flow Rate, dscfm                                               | 2900         | 23360         |
| Fixed Gases                                                    |              |               |
| Oxygen, %                                                      | 3.02         | 12.44         |
| Carbon Dioxide, %                                              | 35.07        | 7.88          |
| Methane, %                                                     | 45.69        | -             |
| BTU Value, Btu/scf                                             | 471          | -             |
| <b>EMISSIONS</b>                                               |              |               |
| Oxides of Nitrogen                                             |              |               |
| ppm                                                            | -            | 9.2           |
| ppm @ 3% O2                                                    | -            | 19.4          |
| lb/hr                                                          | -            | 1.56          |
| lb/MMBtu                                                       | -            | 0.0265        |
| Carbon Monoxide                                                |              |               |
| ppm                                                            | -            | < 20.0        |
| ppm @ 3% O2                                                    | -            | < 42.3        |
| lb/hr                                                          | -            | < 2.07        |
| lb/MMBtu                                                       | -            | < 0.0351      |
| Total Particulate Matter                                       |              |               |
| gr/dscf                                                        | -            | 0.0014        |
| lb/hr                                                          | -            | 0.29          |
| Total Non-Methane Hydrocarbons<br>(Reactive Organic Compounds) |              |               |
| ppm, as Methane                                                | 5569         | 3.21          |
| lb/hr, as Methane                                              | 40.83        | 0.190         |
| Sulfur Compounds                                               |              |               |
| Hydrogen Sulfide, ppm                                          | 75.3         | 0.500         |
| Total Sulfur, ppm as H2S                                       | 82.2         | -             |
| Oxides of Sulfur**                                             |              |               |
| lb/hr                                                          | -            | 2.41          |

\* As recorded at the Reference Method sample probe, not at the permanent thermocouple.

\*\* Calculated from sulfur balance

**Table 5-2**  
Trace Organic Species  
Destruction Efficiency Results  
BFI - Sunshine Canyon Landfill  
Flare 3  
August 28, 2007  
Run 1

| Species               | Inlet               |                       |   | Outlet              |                       |          | Destruction Efficiency (%) |
|-----------------------|---------------------|-----------------------|---|---------------------|-----------------------|----------|----------------------------|
|                       | Concentration (ppb) | Emission Rate (lb/hr) |   | Concentration (ppb) | Emission Rate (lb/hr) |          |                            |
| Hydrogen Sulfide      | 75300               | 1.18E+00              | < | 500                 | <                     | 6.30E-02 | > 94.65                    |
| Benzene               | 1760                | 6.29E-02              |   | 1.3                 |                       | 3.83E-04 | 99.39                      |
| Benzylchloride        | < 100               | < 5.82E-03            | < | 1.00                | <                     | 4.69E-04 | NA                         |
| Chlorobenzene         | < 60                | < 3.11E-03            | < | 0.6                 | <                     | 2.50E-04 | NA                         |
| Dichlorobenzenes      | 248                 | 1.67E-02              | < | 1.5                 | <                     | 8.14E-04 | > 95.13                    |
| 1,1-dichloroethane    | 81                  | 3.69E-03              | < | 0.6                 | <                     | 2.19E-04 | > 94.06                    |
| 1,2-dichloroethane    | < 60                | < 2.72E-03            | < | 0.6                 | <                     | 2.19E-04 | NA                         |
| 1,1-dichloroethylene  | < 60                | < 2.67E-03            | < | 0.6                 | <                     | 2.15E-04 | NA                         |
| Dichloromethane       | 489                 | 1.91E-02              | < | 0.60                | <                     | 1.88E-04 | > 99.01                    |
| 1,2-dibromoethane     | < 60                | < 5.17E-03            | < | 0.6                 | <                     | 4.16E-04 | NA                         |
| Perchloroethene       | 538                 | 5.85E-02              | < | 0.40                | <                     | 3.50E-04 | > 99.40                    |
| Carbon tetrachloride  | < 50                | < 3.53E-03            | < | 0.4                 | <                     | 2.27E-04 | NA                         |
| Toluene               | 11500               | 4.85E-01              |   | 2.15                |                       | 7.30E-04 | 99.849                     |
| 1,1,1-trichloroethane | < 50                | < 3.05E-03            | < | 0.4                 | <                     | 1.96E-04 | NA                         |
| Trichloroethene       | 273                 | 1.64E-02              | < | 0.4                 | <                     | 1.94E-04 | > 98.82                    |
| Chloroform            | < 50                | < 2.73E-03            | < | 0.4                 | <                     | 1.76E-04 | NA                         |
| Vinyl Chloride        | 320                 | 9.17E-03              | < | 0.6                 | <                     | 1.38E-04 | > 98.49                    |
| m xylenes             | 3970                | 1.93E-01              |   | 1.71                |                       | 6.69E-04 | 99.65                      |
| o+p xylene            | 1290                | 6.27E-02              |   | 0.6                 |                       | 2.43E-04 | 99.61                      |
| TNMHC                 | 5569000             | 4.09E+01              |   | 3210                |                       | 1.90E-01 | 99.54                      |

Note: All values preceded by "<" are below the detection limit - reported values are detection limit values.  
NA--Not applicable: Destruction efficiency cannot be calculated since both inlet and outlet values are below the detection limit.

Table 5-3  
Trace Organic Species  
Destruction Efficiency Results  
BFI - Sunshine Canyon Landfill  
Flare 3  
August 28, 2007  
Run 2

| Species               | INLET          |                         |                     | OUTLET         |                          |                     | Dest. Eff.<br>(%) |
|-----------------------|----------------|-------------------------|---------------------|----------------|--------------------------|---------------------|-------------------|
|                       | Conc.<br>(ppb) | Flow rate<br>2900 dscfm | Em. Rate<br>(lb/hr) | Conc.<br>(ppb) | Flow rate<br>23360 dscfm | Em. Rate<br>(lb/hr) |                   |
| Hydrogen Sulfide      | 75300          | 3.07E+00                | 1.18E+00            | < 500          | < 2.04E-02               | < 6.30E-02          | > 94.65           |
| Benzene               | 1760           | 1.64E-01                | 6.29E-02            | 1.25           | 1.17E-04                 | 3.60E-04            | 99.43             |
| Benzylchloride        | < 100          | < 1.52E-02              | < 5.82E-03          | < 0.60         | < 9.11E-05               | < 2.81E-04          | NA                |
| Chlorobenzene         | < 60           | < 8.10E-03              | < 3.11E-03          | < 1.50         | < 2.03E-04               | < 6.26E-04          | NA                |
| Dichlorobenzenes      | 248            | 4.36E-02                | 1.67E-02            | < 0.60         | < 1.05E-04               | < 3.26E-04          | > 98.05           |
| 1,1-dichloroethane    | 81             | 9.63E-03                | 3.69E-03            | < 0.60         | < 7.10E-05               | < 2.19E-04          | > 94.06           |
| 1,2-dichloroethane    | < 60           | 7.10E-03                | < 2.72E-03          | < 0.60         | < 7.10E-05               | < 2.19E-04          | > 91.95           |
| 1,1-dichloroethylene  | < 60           | < 6.96E-03              | < 2.67E-03          | < 0.60         | < 6.96E-05               | < 2.15E-04          | NA                |
| Dichloromethane       | 489            | 4.97E-02                | < 1.91E-02          | < 0.60         | < 6.10E-05               | < 1.88E-04          | > 99.01           |
| 1,2-Dibromoethane     | < 60           | < 1.35E-02              | < 5.17E-03          | < 0.60         | < 1.35E-04               | < 4.16E-04          | 1 NA              |
| Perchloroethene       | 538            | 1.52E-01                | 5.85E-02            | < 0.40         | < 1.13E-04               | < 3.50E-04          | > 99.40           |
| Carbon tetrachloride  | < 50           | < 9.20E-03              | < 3.53E-03          | < 0.40         | < 7.36E-05               | < 2.27E-04          | NA                |
| Toluene               | 11500          | 1.26E+00                | 4.85E-01            | 2.09           | 2.30E-04                 | 7.10E-04            | 99.85             |
| 1,1,1-trichloroethane | < 50           | < 7.95E-03              | < 3.05E-03          | < 0.40         | < 6.36E-05               | < 1.96E-04          | NA                |
| Trichloroethene       | 273            | 4.27E-02                | 1.64E-02            | < 0.40         | < 6.26E-05               | < 1.94E-04          | > 98.82           |
| Chloroform            | < 50           | < 7.11E-03              | < 2.73E-03          | < 0.40         | < 5.69E-05               | < 1.76E-04          | NA                |
| Vinyl Chloride        | 320            | 2.39E-02                | 9.17E-03            | < 0.60         | < 4.48E-05               | < 1.38E-04          | > 98.49           |
| m+p-xylenes           | 3970           | 5.03E-01                | 1.93E-01            | 0.94           | 1.19E-04                 | 3.68E-04            | 99.81             |
| o-xylene              | 1290           | 1.63E-01                | 6.27E-02            | < 0.40         | < 5.07E-05               | < 1.57E-04          | > 99.75           |
| TNMHC                 | 5569000        | 1.06E+02                | 4.09E+01            | 3210           | 6.14E-02                 | 1.90E-01            | 99.54             |

Note: All values preceded by "<" are below the detection limit. The reported values are the detection limit.

NA--Not Applicable: Destruction efficiency can not be calculated since both inlet and outlet values are below the detection limit.

Table 5-4  
Trace Organic Species  
Destruction Efficiency Results  
BFI - Sunshine Canyon Landfill  
Flare 3  
August 28, 2007  
Run 3

| Species               | Inlet               |                       |   | Outlet              |                       |          | Destruction Efficiency (%) |
|-----------------------|---------------------|-----------------------|---|---------------------|-----------------------|----------|----------------------------|
|                       | Concentration (ppb) | Emission Rate (lb/hr) |   | Concentration (ppb) | Emission Rate (lb/hr) |          |                            |
| Hydrogen Sulfide      | 75300               | 1.18E+00              | < | 500                 | <                     | 6.30E-02 | > 94.65                    |
| Benzene               | 1760                | 6.29E-02              |   | 1.04                |                       | 3.00E-04 | 99.52                      |
| Benzylchloride        | < 100               | < 5.82E-03            | < | 1.00                | <                     | 4.69E-04 | NA                         |
| Chlorobenzene         | < 60                | < 3.11E-03            | < | 0.60                | <                     | 2.50E-04 | NA                         |
| Dichlorobenzenes      | 248                 | 1.67E-02              | < | 1.50                | <                     | 8.14E-04 | > 95.13                    |
| 1,1-dichloroethane    | 81                  | 3.69E-03              | < | 0.60                | <                     | 2.19E-04 | > 94.06                    |
| 1,2-dichloroethane    | < 60                | < 2.72E-03            | < | 0.60                | <                     | 2.19E-04 | NA                         |
| 1,1-dichloroethylene  | < 60                | < 2.67E-03            | < | 0.60                | <                     | 2.15E-04 | NA                         |
| Dichloromethane       | 489                 | 1.91E-02              | < | 0.60                | <                     | 1.88E-04 | > 99.01                    |
| 1,2-dibromoethane     | < 60                | < 5.17E-03            | < | 0.60                | <                     | 4.16E-04 | NA                         |
| Perchloroethene       | 538                 | 5.85E-02              | < | 0.40                | <                     | 3.50E-04 | > 99.40                    |
| Carbon tetrachloride  | < 50                | < 3.53E-03            | < | 0.40                | <                     | 2.27E-04 | NA                         |
| Toluene               | 11500               | 4.85E-01              |   | 1.56                |                       | 5.30E-04 | 99.891                     |
| 1,1,1-trichloroethane | < 50                | < 3.05E-03            | < | 0.40                | <                     | 1.96E-04 | NA                         |
| Trichloroethene       | 273                 | 1.64E-02              | < | 0.40                | <                     | 1.94E-04 | > 98.82                    |
| Chloroform            | < 50                | < 2.73E-03            | < | 0.40                | <                     | 1.76E-04 | NA                         |
| Vinyl Chloride        | 320                 | 9.17E-03              | < | 0.60                | <                     | 1.38E-04 | > 98.49                    |
| m xylenes             | 3970                | 1.93E-01              |   | 0.68                |                       | 2.66E-04 | 99.86                      |
| o+p xylene            | 1290                | 6.27E-02              | < | 0.40                | <                     | 1.57E-04 | > 99.75                    |
| TNMHC                 | 5569000             | 4.09E+01              |   | 3210                |                       | 1.90E-01 | 99.54                      |

Note: All values preceded by "<" are below the detection limit - reported values are detection limit values.  
NA--Not applicable: Destruction efficiency cannot be calculated since both inlet and outlet values are below the detection limit.

## **APPENDIX B - Computer Printout of Results**

# EXPANSION AND F-FACTOR CALC. METHOD

Facility: **BFI SunShine**  
Source: **Flare 3**  
Job No.: **B06-016**  
Date: **08/28/07**

Run No.: **1**

|                     |              |        |            |             |        |
|---------------------|--------------|--------|------------|-------------|--------|
| Fuel temperature    | _____        | deg. F | Std. Temp. | _____       | deg. F |
| Fuel Pressure       | _____        | psi    |            |             |        |
| Fuel Flow Rate      | _____        | cfm    | Fuel Flow  | <b>2900</b> | dscfm  |
| Exhaust Outlet O2   | <b>12.44</b> | %      |            |             |        |
| Barometric Pressure | <b>27.56</b> |        |            |             |        |

| COMPONENTS     |    | MOLE %        | HHV<br>btu/ft3 | LLV<br>btu/ft3 | Exp Factor<br>dscf/scf fuel |
|----------------|----|---------------|----------------|----------------|-----------------------------|
| Oxygen         |    | <b>3.02</b>   |                |                | 0.030                       |
| Nitrogen       |    | <b>15.67</b>  |                |                | 0.157                       |
| Carbon Dioxide |    | <b>35.07</b>  |                |                | 0.351                       |
| Methane        |    | <b>45.69</b>  | 461.47         | 415.50         | 3.916                       |
| Ethane         | C2 | <b>0.55</b>   | 9.73           | 8.90           | 0.084                       |
| Propane        | C3 |               | 0.00           | 0.00           | 0.000                       |
| Iso-Butane     | C4 |               | 0.00           | 0.00           | 0.000                       |
| N-Butane       |    |               | 0.00           | 0.00           | 0.000                       |
| Iso-Pentane    | C5 |               | 0.00           | 0.00           | 0.000                       |
| N-Pentane      |    |               | 0.00           | 0.00           | 0.000                       |
| Hexane         | C6 |               | 0.00           | 0.00           | 0.000                       |
| Heptane        | C7 |               | 0.00           | 0.00           | 0.000                       |
| Octane         | C8 |               | 0.00           | 0.00           | 0.000                       |
| Nonane         | C9 |               | 0.00           | 0.00           | 0.000                       |
| <b>Total</b>   |    | <b>100.00</b> | <b>471.20</b>  | <b>424.41</b>  | <b>4.54</b>                 |

## CALCULATIONS

**EXHAUST FLOW RATE, Q** = (scfm\*Exp Fac)\*(20.92/(20.92-%O2))

**32463 DSCFM**

**EPA F-Factor** = (scf exhaust/scf fuel)/(btu/scf fuel)\*(1000000 btu/MMbtu)

**9629 dscf/MMbtu**

SCAQMD Method 5.1 Particulate Emissions

Facility: BFI SunShine  
 Source: Flare 3  
 Job No.: B06-016  
 Date: 08/28/07

|                               |               |         |
|-------------------------------|---------------|---------|
| STANDARD TEMPERATURE          | Degrees F     | 60      |
| RUN NUMBER                    | *****         | 1       |
| CLOCK TIME: INITIAL           | *****         | 915     |
| CLOCK TIME: FINAL             | *****         | 1024    |
| AVG. STACK TEMPERATURE        | Degrees F     | 1651    |
| AVG. SQUARE DELTA P           | Inches H2O    | 0.1217  |
| NOZZLE DIAMETER               | Inches        | 0.994   |
| BAROMETRIC PRESSURE           | Inches HG     | 27.56   |
| SAMPLING TIME                 | Minutes       | 60      |
| SAMPLE VOLUME                 | Cubic Feet    | 64.384  |
| AVG. METER TEMP.              | Degrees F     | 100     |
| AVG. DELTA H                  | Inches H2O    | 2.92    |
| DGM CALIB. FACTOR [Y]         | *****         | 0.988   |
| WATER COLLECTED               | Milliliters   | 123     |
| CO 2                          | Percent       | 7.88    |
| O 2                           | Percent       | 12.44   |
| CO                            | Percent       |         |
| CH4                           | Percent       |         |
| N 2                           | Percent       | 79.68   |
| STACK AREA                    | Square Inches | 19113.5 |
| STATIC PRESSURE               | Inches WG.    | -0.005  |
| PITOT COEFFICIENT             | *****         | 0.84    |
| SAMPLE VOLUME DRY             | DSCF          | 54.87   |
| WATER AT STD.                 | SCF           | 5.8     |
| MOISTURE                      | Percent       | 9.6     |
| MOLE FRACTION DRY GAS         | *****         | 0.90    |
| MOLECULAR WT.DRY              | lb/lb Mole    | 29.76   |
| EXCESS AIR                    | Percent       | 145     |
| MOLECULAR WT. WET             | lb/lb Mole    | 28.63   |
| STACK GAS PRESSURE            | Inches HG     | 27.56   |
| STACK VELOCITY                | AFPM          | 858     |
| VOLUMETRIC FLOWRATE, DRY STD. | DSCFM         | 23360   |
| VOLUMETRIC FLOWRATE, ACTUAL   | ACFM          | 113859  |
| ISOKINETIC RATIO              | Percent       | 95      |

CALCULATIONS FOR GRAIN LOADING AND EMISSION RATES

|                           |         |        |
|---------------------------|---------|--------|
| TOTAL PARTICULATE         | mg      | 5.1    |
| PARTICULATE CONCENTRATION | gr/dscf | 0.0014 |
| PARTICULATE EMISSION RATE | lb/hr   | 0.29   |

**Facility:** BFI  
**Source:** Flare 3  
**Job No.:** B16-016  
**Date:** 08/28/07

**Run No.:** 1  
**Fuel:** LFG  
**Std. O2:** 3

|        | O2<br>% | CO2<br>% | NOx<br>ppm | CO<br>ppm |
|--------|---------|----------|------------|-----------|
| Range: | 25      | 15       | 25         | 100       |
| Span:  | 12.00   | 7.00     | 13.30      | 49.80     |
| Low:   |         |          |            |           |
| High:  | 19.94   | 11.97    | 23.70      | 79.60     |

**\*\* POST-TEST DRIFT (DIRECT)\*\***

Values

Zero:

Span:

|       |      |       |       |
|-------|------|-------|-------|
| 0.03  | 0.00 | 0.00  | 0.00  |
| 12.00 | 6.95 | 13.30 | 49.70 |

Percent Drift

Zero:

Span:

|      |       |      |       |
|------|-------|------|-------|
| 0.12 | 0.00  | 0.00 | 0.00  |
| 0.00 | -0.33 | 0.00 | -0.10 |

**\*\* PRE-TEST BIAS \*\***

Values

Zero:

Span:

|       |      |       |       |
|-------|------|-------|-------|
| 0.03  | 0.10 | 0.12  | 0.00  |
| 12.00 | 6.95 | 13.32 | 49.70 |

**\*\* POST-TEST BIAS \*\***

Values

Zero:

Span:

|       |      |       |       |
|-------|------|-------|-------|
| 0.03  | 0.00 | 0.19  | 0.00  |
| 11.98 | 6.90 | 13.33 | 49.60 |

**\*\* BIAS CORRECTION \*\***

Zero Average  
 Span Average

|       |      |       |       |
|-------|------|-------|-------|
| 0.03  | 0.05 | 0.16  | 0.00  |
| 11.99 | 6.93 | 13.33 | 49.65 |

**\*\* POST-TEST DRIFT (BIAS)\*\***

Percent Drift

Zero:

Span:

|      |      |       |      |
|------|------|-------|------|
| 0.00 | 0.67 | -0.28 | 0.00 |
| 0.08 | 0.33 | -0.04 | 0.10 |

**Bias-Corrected Concentration**  
**Bias-Corrected Conc.(O2 adjusted)**

|              |             |              |             |
|--------------|-------------|--------------|-------------|
| <b>12.44</b> | <b>7.88</b> | <b>9.18</b>  | <b>3.33</b> |
|              |             | <b>19.44</b> | <b>7.05</b> |

**\*\* RAW AVERAGE CONCENTRATION \*\***

Average:

O2 adjust:

Date

Time

3.0

28-Aug-07

915

12.43

7.79

9.25

3.32

28-Aug-07

916

12.24

7.95

9.23

3.26

28-Aug-07

917

12.33

7.90

9.64

0.06

28-Aug-07

918

12.26

7.91

9.37

0.01

28-Aug-07

919

12.35

7.85

9.31

7.37

28-Aug-07

920

12.23

7.97

9.52

0.06

28-Aug-07

921

12.29

7.90

9.62

0.17

28-Aug-07

922

12.35

7.88

9.49

0.10

28-Aug-07

923

12.22

7.98

10.20

0.01

## Method 100.1 Performance Data

Facility: BFI SunShine  
 Source: Flare 3  
 Job No.: B06-016  
 Date: 08/28/07

| PRETEST        | CALIBRATION ERROR |       |       |       |
|----------------|-------------------|-------|-------|-------|
| LEAK CHECK     | Good              |       |       |       |
|                |                   |       |       |       |
| RANGE :        | 25                | 15    | 25    | 100   |
|                | O2                | CO2   | NOx   | CO    |
| ZERO           |                   |       |       |       |
| Instrument     | 0.00              | 0.00  | 0.00  | 0.00  |
| Cylinder       | 0.00              | 0.00  | 0.00  | 0.00  |
| Difference (%) | 0.00              | 0.00  | 0.00  | 0.00  |
| LOW LEVEL      |                   |       |       |       |
| Instrument     |                   |       |       |       |
| Cylinder       |                   |       |       |       |
| Difference (%) |                   |       |       |       |
| MID LEVEL      |                   |       |       |       |
| Instrument     | 12.00             | 6.99  | 13.25 | 50.00 |
| Cylinder       | 12.00             | 7.00  | 13.30 | 49.80 |
| Difference (%) | 0.00              | -0.07 | -0.20 | 0.20  |
| HIGH LEVEL     |                   |       |       |       |
| Instrument     | 19.83             | 11.99 | 23.75 | 79.80 |
| Cylinder       | 19.94             | 11.96 | 23.70 | 79.60 |
| Difference (%) | -0.44             | 0.20  | 0.20  | 0.20  |

| PRETEST         | LINEARITY |            |
|-----------------|-----------|------------|
|                 | Cylinder  | Instrument |
|                 |           |            |
|                 | O2        |            |
| Zero            | 0.00      | 0.00       |
| High Level      | 19.94     | 19.83      |
| Slope           | 1.01      |            |
| Intercept       | 0.00      | Status     |
| Predicted Value | 11.93     | <1         |
| Linearity (%)   | 0.26      | PASS       |
|                 | CO2       |            |
| Zero            | 0.00      | 0.00       |
| High Level      | 11.96     | 11.99      |
| Slope           | 1.00      |            |
| Intercept       | 0.00      | Status     |
| Predicted Value | 7.02      | <1         |
| Linearity (%)   | -0.18     | PASS       |
|                 | NOx       |            |
| Zero            | 0.00      | 0.00       |
| High Level      | 23.70     | 23.75      |
| Slope           | 1.00      |            |
| Intercept       | 0.00      | Status     |
| Predicted Value | 13.33     | <1         |
| Linearity (%)   | -0.31     | PASS       |
|                 | CO        |            |
| Zero            | 0.00      | 0.00       |
| High Level      | 79.60     | 79.80      |
| Slope           | 1.00      |            |
| Intercept       | 0.00      | Status     |
| Predicted Value | 49.93     | <1         |
| Linearity (%)   | 0.07      | PASS       |

| SYSTEM RESPONSE TIME | #1 | #2 |
|----------------------|----|----|
| Upscale              |    |    |
| CO                   | 49 | 47 |
| NOx                  | 30 | 30 |
| O2                   | 30 | 31 |
| CO2                  | 31 | 30 |
| Downscale            |    |    |
| CO                   | 44 | 45 |
| NOx                  | 28 | 29 |
| O2                   | 32 | 32 |
| CO2                  | 29 | 30 |

| NO2 CONVERTER EFFICIENCY | ppm   | %     | status |
|--------------------------|-------|-------|--------|
| Cylinder(C0)             | 17.90 |       |        |
| NO Mode(C1)              | 0.65  |       |        |
| NOx Mode(C2)             | 17.63 |       |        |
| D1                       | 17.25 |       |        |
| D2                       | 16.98 |       |        |
| D3                       | 0.27  |       |        |
| CE                       |       | 98.41 |        |
| CE > 90 %                |       |       | PASS   |
| D3 <1.0 ppm              | 0.27  |       | PASS   |

| POST TEST      | CALIBRATION ERROR |       |       |       |
|----------------|-------------------|-------|-------|-------|
| LEAK CHECK     | Good              |       |       |       |
|                |                   |       |       |       |
|                | O2                | CO2   | NOx   | CO    |
| ZERO           |                   |       |       |       |
| Instrument     | 0.00              | 0.00  | 0.00  | 0.00  |
| Cylinder       | 0.00              | 0.00  | 0.00  | 0.00  |
| Difference (%) | 0.00              | 0.00  | 0.00  | 0.00  |
| LOW LEVEL      |                   |       |       |       |
| Instrument     |                   |       |       |       |
| Cylinder       |                   |       |       |       |
| Difference (%) |                   |       |       |       |
| MID LEVEL      |                   |       |       |       |
| Instrument     | 12.00             | 6.96  | 13.20 | 49.50 |
| Cylinder       | 12.00             | 7.00  | 13.30 | 49.80 |
| Difference (%) | 0.00              | -0.27 | -0.40 | -0.30 |
| HIGH LEVEL     |                   |       |       |       |
| Instrument     | 19.80             | 11.96 | 23.73 | 79.30 |
| Cylinder       | 19.94             | 11.96 | 23.70 | 79.60 |
| Difference (%) | -0.56             | 0.00  | 0.12  | -0.30 |

| POST TEST       | LINEARITY |            |
|-----------------|-----------|------------|
|                 | Cylinder  | Instrument |
|                 |           |            |
|                 | O2        |            |
| Zero            | 0.00      | 0.00       |
| High Level      | 19.94     | 19.80      |
| Slope           | 1.01      |            |
| Intercept       | 0.00      | Status     |
| Predicted Value | 11.92     | <1         |
| Linearity (%)   | 0.34      | PASS       |
|                 | CO2       |            |
| Zero            | 0.00      | 0.00       |
| High Level      | 11.96     | 11.96      |
| Slope           | 1.00      |            |
| Intercept       | 0.00      | Status     |
| Predicted Value | 7.00      | <1         |
| Linearity (%)   | -0.27     | PASS       |
|                 | NOx       |            |
| Zero            | 0.00      | 0.00       |
| High Level      | 23.70     | 23.73      |
| Slope           | 1.00      |            |
| Intercept       | 0.00      | Status     |
| Predicted Value | 13.32     | <1         |
| Linearity (%)   | -0.47     | PASS       |
|                 | CO        |            |
| Zero            | 0.00      | 0.00       |
| High Level      | 79.60     | 79.30      |
| Slope           | 1.00      |            |
| Intercept       | 0.00      | Status     |
| Predicted Value | 49.61     | <1         |
| Linearity (%)   | -0.11     | PASS       |

Trace Organic Species  
Destruction Efficiency Results  
BFI - Sunshine Canyon Landfill  
Flare 3  
August 28, 2007  
Run 1

| Species               | Inlet               |                       |   | Outlet              |                       |          | Destruction Efficiency (%) |
|-----------------------|---------------------|-----------------------|---|---------------------|-----------------------|----------|----------------------------|
|                       | Concentration (ppb) | Emission Rate (lb/hr) |   | Concentration (ppb) | Emission Rate (lb/hr) |          |                            |
| Hydrogen Sulfide      | 75300               | 1.18E+00              | < | 500                 | <                     | 6.30E-02 | > 94.65                    |
| Benzene               | 1760                | 6.29E-02              |   | 1.3                 |                       | 3.83E-04 | 99.39                      |
| Benzylchloride        | < 100               | < 5.82E-03            | < | 1.00                | <                     | 4.69E-04 | NA                         |
| Chlorobenzene         | < 60                | < 3.11E-03            | < | 0.6                 | <                     | 2.50E-04 | NA                         |
| Dichlorobenzenes      | 248                 | 1.67E-02              | < | 1.5                 | <                     | 8.14E-04 | > 95.13                    |
| 1,1-dichloroethane    | 81                  | 3.69E-03              | < | 0.6                 | <                     | 2.19E-04 | > 94.06                    |
| 1,2-dichloroethane    | < 60                | < 2.72E-03            | < | 0.6                 | <                     | 2.19E-04 | NA                         |
| 1,1-dichloroethylene  | < 60                | < 2.67E-03            | < | 0.6                 | <                     | 2.15E-04 | NA                         |
| Dichloromethane       | 489                 | 1.91E-02              | < | 0.60                | <                     | 1.88E-04 | > 99.01                    |
| 1,2-dibromoethane     | < 60                | < 5.17E-03            | < | 0.6                 | <                     | 4.16E-04 | NA                         |
| Perchloroethene       | 538                 | 5.85E-02              | < | 0.40                | <                     | 3.50E-04 | > 99.40                    |
| Carbon tetrachloride  | < 50                | < 3.53E-03            | < | 0.4                 | <                     | 2.27E-04 | NA                         |
| Toluene               | 11500               | 4.85E-01              |   | 2.15                |                       | 7.30E-04 | 99.849                     |
| 1,1,1-trichloroethane | < 50                | < 3.05E-03            | < | 0.4                 | <                     | 1.96E-04 | NA                         |
| Trichloroethene       | 273                 | 1.64E-02              | < | 0.4                 | <                     | 1.94E-04 | > 98.82                    |
| Chloroform            | < 50                | < 2.73E-03            | < | 0.4                 | <                     | 1.76E-04 | NA                         |
| Vinyl Chloride        | 320                 | 9.17E-03              | < | 0.6                 | <                     | 1.38E-04 | > 98.49                    |
| m xylenes             | 3970                | 1.93E-01              |   | 1.71                |                       | 6.69E-04 | 99.65                      |
| o+p xylene            | 1290                | 6.27E-02              |   | 0.6                 |                       | 2.43E-04 | 99.61                      |
| TNMHC                 | 5569000             | 4.09E+01              |   | 3210                |                       | 1.90E-01 | 99.54                      |

Note: All values preceded by "<" are below the detection limit - reported values are detection limit values.  
NA--Not applicable: Destruction efficiency cannot be calculated since both inlet and outlet values are below the detection limit.

Trace Organic Species  
Destruction Efficiency Results  
BFI - Sunshine Canyon Landfill  
Flare 3  
August 28, 2007  
Run 3

| Species               | INLET          |                        |                             | OUTLET         |                        |                              | Dest. Eff.<br>(%) |
|-----------------------|----------------|------------------------|-----------------------------|----------------|------------------------|------------------------------|-------------------|
|                       | Conc.<br>(ppb) | Flow rate<br>(mg/dscf) | 2900<br>Em. Rate<br>(lb/hr) | Conc.<br>(ppb) | Flow rate<br>(mg/dscf) | 23360<br>Em. Rate<br>(lb/hr) |                   |
| Hydrogen Sulfide      | 75300          | 3.07E+00               | 1.18E+00                    | < 500          | < 2.04E-02             | < 6.30E-02                   | > 94.65           |
| Benzene               | 1760           | 1.64E-01               | 6.29E-02                    | 1.04           | 9.69E-05               | 3.00E-04                     | 99.52             |
| Benzylchloride        | < 100          | < 1.52E-02             | < 5.82E-03                  | < 1.00         | < 1.52E-04             | < 4.69E-04                   | > 91.95           |
| Chlorobenzene         | < 60           | < 8.10E-03             | < 3.11E-03                  | < 0.60         | < 8.10E-05             | < 2.50E-04                   | NA                |
| Dichlorobenzenes      | 248            | 4.36E-02               | 1.67E-02                    | < 1.50         | < 2.64E-04             | < 8.14E-04                   | > 95.13           |
| 1,1-dichloroethane    | 81             | 9.63E-03               | 3.69E-03                    | < 0.60         | < 7.10E-05             | < 2.19E-04                   | > 94.06           |
| 1,2-dichloroethane    | < 60           | < 7.10E-03             | < 2.72E-03                  | < 0.60         | < 7.10E-05             | < 2.19E-04                   | NA                |
| 1,1-dichloroethylene  | < 60           | < 6.96E-03             | < 2.67E-03                  | < 0.60         | < 6.96E-05             | < 2.15E-04                   | NA                |
| Dichloromethane       | 489            | 4.97E-02               | 1.91E-02                    | < 0.60         | < 6.10E-05             | < 1.88E-04                   | > 99.01           |
| 1,2-Dibromoethane     | < 60           | < 1.35E-02             | < 5.17E-03                  | < 0.60         | < 1.35E-04             | < 4.16E-04                   | NA                |
| Perchloroethene       | 538            | 1.52E-01               | 5.85E-02                    | < 0.40         | < 1.13E-04             | < 3.50E-04                   | > 99.40           |
| Carbon tetrachloride  | < 50           | < 9.20E-03             | < 3.53E-03                  | < 0.40         | < 7.36E-05             | < 2.27E-04                   | NA                |
| Toluene               | 11500          | 1.26E+00               | 4.85E-01                    | 1.56           | 1.72E-04               | 5.30E-04                     | 99.89             |
| 1,1,1-trichloroethane | < 50           | < 7.95E-03             | < 3.05E-03                  | < 0.40         | < 6.36E-05             | < 1.96E-04                   | NA                |
| Trichloroethene       | 273            | 4.27E-02               | 1.64E-02                    | < 0.40         | < 6.26E-05             | < 1.94E-04                   | > 98.82           |
| Chloroform            | < 50           | < 7.11E-03             | < 2.73E-03                  | < 0.40         | < 5.69E-05             | < 1.76E-04                   | NA                |
| Vinyl Chloride        | 320            | 2.39E-02               | 9.17E-03                    | < 0.60         | < 4.48E-05             | < 1.38E-04                   | > 98.49           |
| m+p-xylenes           | 3970           | 5.03E-01               | 1.93E-01                    | 0.68           | 8.61E-05               | 2.66E-04                     | 99.86             |
| o-xylene              | 1290           | 1.63E-01               | 6.27E-02                    | < 0.40         | < 5.07E-05             | < 1.57E-04                   | > 99.75           |
| TNMHC                 | 5569000        | 1.06E+02               | 4.09E+01                    | 3210           | 6.14E-02               | 1.90E-01                     | 99.54             |

Note: All values preceded by "<" are below the detection limit. The reported values are the detection limit.

NA--Not Applicable: Destruction efficiency can not be calculated since both inlet and outlet values are below the detection limit.

## VELOCITY DATA SHEET - METHOD 2

Facility: DF1 Sunshine  
Source: Floor 3  
Job #: B06-016  
Date: 8/28/07  
Operator: EL

|                  |         |
|------------------|---------|
| Baro. Press:     | 27.56   |
| Static Press:    | 77.2    |
| Pitot Tube #:    | Std 15" |
| Pitot Tube Type: | std     |
| Magnahelic:      | 2       |

**D<sub>1</sub> upstream:** 2.3

**D<sub>1</sub> downstream:** 11.3

**Stack Diameter:** 1.6 / 16


**Leak Check**

**Initial:**                      **Final:**


Run #: 1

| Point # | Position in. | Velocity Head in. H <sub>2</sub> O | Stack Temp °F | Cyclonic Flow Angle |
|---------|--------------|------------------------------------|---------------|---------------------|
| A-8     | 0.5          | 0.20                               | 115           |                     |
| 7       | 1.7          | 0.28                               | 115           |                     |
| 6       | 3.1          | 0.36                               | 115           |                     |
| 5       | 5.2          | 0.38                               | 115           |                     |
| 4       | 10.8         | 0.42                               | 115           |                     |
| 3       | 12.9         | 0.44                               | 115           |                     |
| 2       | 14.3         | 0.40                               | 115           |                     |
| 1       | 15.8         | 0.38                               | 115           |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
|         |              |                                    |               |                     |
| Average |              | $\sqrt{\Delta P} = 0.5941$         | $T_s = 115$   | $\angle =$          |

### Side View



### Top View



# **PARTICULATE FIELD DATA**

PLANT BFI Sunshine  
 DATE 8/29/07  
 LOCATION Sylvan  
 OPERATOR CP  
 SOURCE Flare 3 out  
 RUN NO. 1  
 SAMPLE BOX NO. C11  
 TIME START 0915

METER BOX NO. 6  
 METER ΔH @ 1.562  
 Y= 0.988  
 PROBE I.D. NO. CQ-4 6. inc  
 NOZZLE DIAMETER, in. 0.008 0.989  
 STACK DIAMETER, in. 156  
 PROBE HEATER SETTING -  
 HEATER BOX SETTING -  
 Δ Cp FACTOR 0.84  
 FILTER NO. 57030

ASSUMED MOISTURE, % 8  
 AMBIENT TEMPERATURE 90  
 BARO. PRESS. 27.56  
 STATIC PRESS. -0.005  
 NOMAGRAPH INDEX 195

PRE TEST LEAK CHECKS  
 METER 2.005 @ 15 in. Hg  
 PITOTS ✓✓ @ 5.0 in. Hg  
 ORSAT -

| P#   | TIME | T <sub>s</sub><br>°F | Δ P<br>in H <sub>2</sub> O | √ Δ P  | Δ H<br>in H <sub>2</sub> O | Vm<br>ft <sup>3</sup> | T <sub>m IN</sub><br>°F | T <sub>m OUT</sub><br>°F | OVEN<br>°F | IMP.<br>OUT °F | VAC.<br>(in Hg) |
|------|------|----------------------|----------------------------|--------|----------------------------|-----------------------|-------------------------|--------------------------|------------|----------------|-----------------|
| A 6  | 0    | 1663                 | 0.015                      |        | 2.9                        | 364.728               | 89                      | 88                       | NA         | 57             | 6               |
| 5    | 2.5  | 1654                 | 0.015                      |        | 2.9                        | 367.4                 | 98                      | 89                       |            | 56             | 6               |
| 7    | 5.0  | 1660                 | 0.015                      |        | 2.9                        | 370.1                 | 103                     | 89                       |            | 56             | 6               |
| 3    | 7.5  | 1661                 | 0.015                      |        | 2.9                        | 372.8                 | 104                     | 90                       |            | 56             | 6               |
| 2    | 10   | 1658                 | 0.01                       |        | 2.0                        | 375.4                 | 104                     | 90                       |            | 54             | 4               |
| 1    | 12.5 | 1673                 | 0.01                       |        | 2.0                        | 377.7                 | 104                     | 91                       |            | 55             | 4               |
| B 6  | 15   | 1645                 | 0.02                       |        | 3.9                        | 375.995               | 100                     | 90                       |            | 56             | 8               |
| 5    | 17.5 | 1655                 | 0.02                       |        | 3.9                        | 382.9                 | 106                     | 92                       |            | 57             | 8               |
| 4    | 20   | 1651                 | 0.015                      |        | 2.9                        | 386.5                 | 105                     | 93                       |            | 56             | 6               |
| 3    | 22.5 | 1672                 | 0.015                      |        | 2.9                        | 389.2                 | 107                     | 93                       |            | 57             | 6               |
| 2    | 25   | 1660                 | 0.015                      |        | 2.9                        | 391.9                 | 108                     | 94                       |            | 58             | 6               |
| 1    | 27.5 | 1653                 | 0.015                      |        | 2.9                        | 394.5                 | 108                     | 94                       |            | 57             | 6               |
| C 6  | 30   | 1657                 | 0.020                      |        | 3.9                        | 397.363               | 100                     | 95                       |            | 56             | 8               |
| 5    | 32.5 | 1641                 | 0.020                      |        | 3.9                        | 400.4                 | 106                     | 95                       |            | 57             | 8               |
| 4    | 35   | 1639                 | 0.020                      |        | 3.9                        | 403.9                 | 109                     | 95                       |            | 56             | 8               |
| 3    | 37.5 | 1634                 | 0.015                      |        | 2.9                        | 407.2                 | 109                     | 95                       |            | 57             | 6               |
| 2    | 40   | 1651                 | 0.015                      |        | 2.9                        | 409.4                 | 110                     | 95                       |            | 56             | 6               |
| 1    | 42.5 | 1653                 | 0.015                      |        | 2.9                        | 411.8                 | 110                     | 95                       |            | 56             | 6               |
| D 6  | 45   | 1649                 | 0.015                      |        | 2.9                        | 414.765               | 103                     | 95                       |            | 57             | 6               |
| 5    | 47.5 | 1647                 | 0.015                      |        | 2.9                        | 417.2                 | 109                     | 95                       |            | 56             | 6               |
| 4    | 50   | 1656                 | 0.015                      |        | 2.9                        | 419.8                 | 110                     | 95                       |            | 56             | 6               |
| 3    | 52.5 | 1643                 | 0.01                       |        | 2.0                        | 422.3                 | 112                     | 97                       |            | 57             | 4               |
| 2    | 55   | 1627                 | 0.01                       |        | 2.0                        | 425.0                 | 112                     | 98                       |            | 56             | 4               |
| 1    | 57.5 | 1632                 | 0.01                       |        | 2.0                        | 427.1                 | 112                     | 98                       |            | 56             | 4               |
|      | 60   |                      |                            |        |                            | 429.12                |                         |                          |            |                |                 |
| Avg. |      | 1651.4               |                            | 0.1217 | 2.92                       | 64.384                |                         | 99.6                     |            |                |                 |

TIME END = 1024 (SM)

(SM)

(SM)

(SM)

2740 SCFM 1650 SP

| Volume of Liquid Water Collected | Impinger Volume |     |    |   | Silica Gel Wght. |
|----------------------------------|-----------------|-----|----|---|------------------|
|                                  | 1               | 2   | 3  | 4 |                  |
| Final                            | 166             | 126 | 12 |   | 269              |
| Initial                          | 100             | 100 | 0  |   | 250              |
| Liquid Collected                 | 66              | 26  | 12 |   | 19               |
| Total Vol. Collected             |                 |     |    |   | 123              |

## **POST TEST LEAK CHECKS**

Meter 2.005 @ 15 in. Hg  
 Pitots ✓✓ @ 6 in. Hg  
 Orsat -

| Orsat Meas. | Time           | CO <sub>2</sub> | O <sub>2</sub> | CO      | N <sub>2</sub> |
|-------------|----------------|-----------------|----------------|---------|----------------|
| 1           |                |                 |                |         |                |
| 2           |                |                 |                |         |                |
| 3           |                |                 |                |         |                |
| Nozzle Cal  | D <sub>1</sub> | D <sub>2</sub>  | D <sub>3</sub> | Average |                |
|             |                |                 |                |         |                |



# CEM TEMPERATURE DATA

Facility: SUNSHINE CYN

Date: 8-28-07

Job No.: B16-016


Run #: 1

Source: FLARE #3

Probe Temp Settings: NA

Heated Line Temp Settings: \_\_\_\_\_

|    |      | TEMPERATURES °F  |       |             |
|----|------|------------------|-------|-------------|
|    | Time | Condenser Outlet | Probe | Teflon Line |
| 1  | 0    | 36               | NA    | 256         |
| 2  | 10   | 34               |       | 252         |
| 3  | 20   | 35               |       | 255         |
| 4  | 30   | 35               |       | 258         |
| 5  | 40   | 37               |       | 260         |
| 6  | 50   | 36               |       | 257         |
| 7  | 60   | 35               |       | 255         |
| 8  |      |                  |       |             |
| 9  |      |                  |       |             |
| 10 |      |                  |       |             |
| 11 |      |                  |       |             |
| 12 |      |                  |       |             |
| 13 |      |                  |       |             |
| 14 |      |                  |       |             |
| 15 |      |                  |       |             |



AtmAA Inc.

23917 Craftsman Rd., Calabasas, CA 91302 • (818) 223-3277 • FAX (818) 223-8250

environmental consultants  
laboratory services

### LABORATORY ANALYSIS REPORT

#### Organic Carbon Analysis in Water Impinger and Methane & TGNMO Analysis in SUMMA Canister Samples from Impinger/Canister Train Sample Collection

Report Date: September 25, 2007

Client: Horizon Air Measurement Services, Inc.

Client Project No.: BO6 - 016

Source Location : BFI Sunshine Canyon Landfill

Source ID: Flare outlet

Date Received: August 28, 2007

Date Analyzed: August 29, - September 11, 2007

*Methane and total gaseous non-methane organics were measured by flame ionization detection/total combustion analysis (FID/TCA). Organic carbon in water vial samples were measured by Dohrman total organic carbon analyzer, water FID/TCA.*


| Lab No.  | ID           | Canister | Canister              | Canister | Impinger | Impinger | P <sub>1</sub> | P <sub>2</sub> |
|----------|--------------|----------|-----------------------|----------|----------|----------|----------------|----------------|
|          |              | Methane  | Ethane                | TGNMO    | Carbon   | Volume   |                |                |
|          |              |          | (concentration, ppmv) |          |          | (ml)     |                |                |
| 02407-18 | S11          | <1       | <1                    | <1       | ---      | ---      | 497            | 820            |
|          | Impinger H98 | ---      | ---                   | ---      | 2.55     | 2.30     | --             | --             |
| 02407-19 | S19          | <1       | <1                    | <1       | ---      | ---      | 469            | 820            |
|          | Impinger H99 | ---      | ---                   | ---      | 1.87     | 2.57     | --             | --             |


*TGNMO is total gaseous non-methane organics (excluding ethane), reported as ppmv carbon.*

*Ethane is reported as ppmv carbon.*

*\* Note - Impinger sample results are not field blank corrected. The field blank (impinger H30) contained 1.21 ug carbon, corresponding to 0.63 ppm carbon for a 3.88 liter sample.*

*P<sub>1</sub> and P<sub>2</sub> are initial and final pressures measured in mm Hg.*

  
Michael L. Porter  
Laboratory Director



AtmAA Inc.

23917 Craftsman Rd., Calabasas, CA 91302 • (818) 223-3277 • FAX (818) 223-8250

LABORATORY ANALYSIS REPORT

environmental consultants  
laboratory services

SCAQMD Rule 1150.1 Components Analysis in Outlet Tedlar Bag Sample

Report Date: September 20, 2007

Client: Horizon Air Measurement Services

Project Location: BFI / Sunshine Cyn LF

Client Project No.: B06-016


Date Received: August 28, 2007

Date Analyzed: August 30-September 1, 2007

| AtmAA Lab No.:        | 02407-20                | 02407-21     | 02407-22     |
|-----------------------|-------------------------|--------------|--------------|
| Sample I.D.:          | Sample                  | Sample       | Sample       |
|                       | B6-16-TB-O-1            | B6-16-TB-O-2 | B6-16-TB-O-3 |
| Components            | (Concentration in ppbv) |              |              |
| Hydrogen sulfide      | <500                    | <500         | <500         |
| Benzene               | 1.33                    | 1.25         | 1.04         |
| Benzylchloride        | <1                      | <1           | <1           |
| Chlorobenzene         | <0.6                    | <0.6         | <0.6         |
| Dichlorobenzenes*     | <1.5                    | <1.5         | <1.5         |
| 1,1-dichloroethane    | <0.6                    | <0.6         | <0.6         |
| 1,2-dichloroethane    | <0.6                    | <0.6         | <0.6         |
| 1,1-dichloroethylene  | <0.6                    | <0.6         | <0.6         |
| Dichloromethane       | <0.6                    | <0.6         | <0.6         |
| 1,2-dibromoethane     | <0.6                    | <0.6         | <0.6         |
| Perchloroethylene     | <0.4                    | <0.4         | <0.4         |
| Carbon tetrachloride  | <0.4                    | <0.4         | <0.4         |
| Toluene               | 2.15                    | 2.09         | 1.56         |
| 1,1,1-trichloroethane | <0.4                    | <0.4         | <0.4         |
| Trichloroethene       | <0.4                    | <0.4         | <0.4         |
| Chloroform            | <0.4                    | <0.4         | <0.4         |
| Vinyl chloride        | <0.6                    | <0.6         | <0.6         |
| m+p-xylenes           | 1.71                    | 0.94         | 0.68         |
| o-xylene              | 0.62                    | <0.4         | <0.4         |

\* total amount containing meta, para, and ortho isomers

  
Michael L. Porter  
Laboratory Director



AtmAA Inc.

23917 Craftsman Rd., Calabasas, CA 91302 • (818) 223-3277 • FAX (818) 223-8250

LABORATORY ANALYSIS REPORT

environmental consultants  
laboratory services

SCAQMD Rule 1150.1 Components Analysis in Inlet Gas Tedlar Bag Sample

Report Date: September 20, 2007

Client: Horizon Air Measurement Services

Project Location: BFI / Sunshine Cyn LF

Client Project No.: B06-016

Date Received: August 28, 2007

Date Analyzed: August 30-September 1, 2007

AtmAA Lab No.: 02407-23

Sample I.D.: Sample

B6-16-TB-I-1

Components

Hydrogen sulfide

(Concentration in ppmv)

75.3

(Concentration in ppbv)

|                       |       |
|-----------------------|-------|
| Benzene               | 1760  |
| Benzylchloride        | <100  |
| Chlorobenzene         | <60   |
| Dichlorobenzenes*     | 248   |
| 1,1-dichloroethane    | 81.4  |
| 1,2-dichloroethane    | <60   |
| 1,1-dichloroethylene  | <60   |
| Dichloromethane       | 489   |
| 1,2-dibromoethane     | <60   |
| Perchloroethylene     | 538   |
| Carbon tetrachloride  | <50   |
| Toluene               | 11500 |
| 1,1,1-trichloroethane | <50   |
| Trichloroethene       | 273   |
| Chloroform            | <50   |
| Vinyl chloride        | 320   |
| m+p-xylenes           | 3970  |
| o-xylene              | 1290  |

\* total amount containing meta, para, and ortho isomers


Michael L. Porter  
Laboratory Director

QUALITY ASSURANCE SUMMARY  
(Repeat Analyses)

Client Project No.: B06-016  
Date Received: August 28, 2007  
Date Analyzed: August 30-September 1, 2007

| Components              | Sample ID    | Repeat Analysis |        | Mean Conc. | % Diff. From Mean |
|-------------------------|--------------|-----------------|--------|------------|-------------------|
|                         |              | Run #1          | Run #2 |            |                   |
| (Concentration in ppbv) |              |                 |        |            |                   |
| Benzene                 | B6-16-TB-I-1 | 1800            | 1720   | 1760       | 2.3               |
| Benzylchloride          | B6-16-TB-I-1 | <100            | <100   | ---        | ---               |
| Chlorobenzene           | B6-16-TB-I-1 | <60             | <60    | ---        | ---               |
| Dichlorobenzenes        | B6-16-TB-I-1 | 223             | 273    | 248        | 10                |
| 1,1-dichloroethane      | B6-16-TB-I-1 | 74.6            | 88.1   | 81.4       | 8.3               |
| 1,2-dichloroethane      | B6-16-TB-I-1 | <60             | <60    | ---        | ---               |
| 1,1-dichloroethylene    | B6-16-TB-I-1 | <60             | <60    | ---        | ---               |
| Dichloromethane         | B6-16-TB-I-1 | 449             | 529    | 489        | 8.2               |
| 1,2-dibromoethane       | B6-16-TB-I-1 | <60             | <60    | ---        | ---               |
| Perchloroethylene       | B6-16-TB-I-1 | 520             | 556    | 538        | 3.3               |
| Carbon tetrachloride    | B6-16-TB-I-1 | <50             | <50    | ---        | ---               |
| Toluene                 | B6-16-TB-I-1 | 11200           | 11800  | 11500      | 2.6               |
| 1,1,1-trichloroethane   | B6-16-TB-I-1 | <50             | <50    | ---        | ---               |
| Trichloroethene         | B6-16-TB-I-1 | 258             | 288    | 273        | 5.5               |
| Chloroform              | B6-16-TB-I-1 | <50             | <50    | ---        | ---               |
| Vinyl chloride          | B6-16-TB-I-1 | 304             | 335    | 320        | 4.8               |
| m+p-xylenes             | B6-16-TB-I-1 | 3580            | 4360   | 3970       | 9.8               |
| o-xylene                | B6-16-TB-I-1 | 1160            | 1420   | 1290       | 10                |





AtmAA Inc.

23917 Craftsman Rd., Calabasas, CA 91302 • (818) 223-3277 • FAX (818) 223-8250

environmental consultants  
laboratory services

## LABORATORY ANALYSIS REPORT

### Speciated Hydrocarbons Analysis in Tedlar Bag Samples

Report Date: September 25, 2007  
Client: Horizon Air Measurement Services  
Site: BFI Sunshine Canyon Landfill  
Project No.: BO6-016

Date Received: August 28, 2007  
Date Analyzed: August 28, & 29, 2007

### ANALYSIS DESCRIPTION

Hydrocarbon Speciation analysis was performed by flame ionization detection/gas chromatography (FID/GC), modified EPA-18.

|                                                                   |                                    |          |  |  |  |
|-------------------------------------------------------------------|------------------------------------|----------|--|--|--|
| AtmAA Lab No.:                                                    | 02407-23                           | (repeat) |  |  |  |
| Sample ID:                                                        | TB-I-1                             | TB-I-1   |  |  |  |
|                                                                   | Inlet                              | Inlet    |  |  |  |
|                                                                   | (Concentration in ppmv, component) |          |  |  |  |
| Methane                                                           | 446000                             | 446000   |  |  |  |
| non-methane hydrocarbons<br>analysis by carbon<br>number grouping |                                    |          |  |  |  |
| C2                                                                | 2.46                               | 2.55     |  |  |  |
| C3                                                                | 35.43                              | 35.44    |  |  |  |
| C4                                                                | 18.98                              | 18.58    |  |  |  |
| C5                                                                | 115.9                              | 97.07    |  |  |  |
| C6                                                                | 120.5                              | 100.9    |  |  |  |
| >C6                                                               | 582.8                              | 568.1    |  |  |  |
| TNMNE                                                             | 5564                               | 5248     |  |  |  |
| TNMHC                                                             | 5569                               | 5253     |  |  |  |

TNMNE - total non-methane, non-ethane, hydrocarbons as ppmv methane.

TNMHC - total non-methane hydrocarbons as ppmv methane.

Michael L. Porter  
Laboratory Director

# CHAIN OF CUSTODY RECORD

|                                            |  |  |                                             |  |  |                                                                                                                                                           |  |  |  |  |  |
|--------------------------------------------|--|--|---------------------------------------------|--|--|-----------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|--|--|--|
| Client/Project Name<br><b>BFI</b>          |  |  | Project Location<br><b>Sunshine Cyn L.F</b> |  |  | ANALYSES<br><i>ACI</i><br><i>Sunshine 25.3</i><br><i>Temp #</i><br><i>ETA</i><br><i>10 15 (USD list)</i><br><i>AQMD 307.91</i><br><i>ASTM D3588/D1945</i> |  |  |  |  |  |
| Project No.<br><b>B06 016</b>              |  |  | Field Logbook No.                           |  |  |                                                                                                                                                           |  |  |  |  |  |
| Sampler: (Signature)<br><i>[Signature]</i> |  |  | Chain of Custody Tape No.                   |  |  |                                                                                                                                                           |  |  |  |  |  |

| Sample No./ Identification | Date           | Time | Lab Sample Number | Type of Sample    | ACI        | Sunshine | Temp #     | ETA      | AQMD     | ASTM     | REMARKS          |
|----------------------------|----------------|------|-------------------|-------------------|------------|----------|------------|----------|----------|----------|------------------|
| <i>Sum 11</i>              | <i>8/28/07</i> |      | <i>02407-18</i>   | <i>Sum</i>        | <i>1.0</i> | <i>X</i> | <i>H98</i> |          |          |          | <i>Sum</i>       |
| <i>Sum 19</i>              | <i>8/28/07</i> |      | <i>-19</i>        | <i>Sum</i>        | <i>1.0</i> | <i>X</i> | <i>H98</i> |          |          |          | <i>Sum</i>       |
| <i>B6-16-TB-0-1</i>        |                |      | <i>-20</i>        | <i>Tedlar bag</i> |            |          |            | <i>X</i> |          |          | <i>Flare Out</i> |
| <i>B6-16-TB-0-2</i>        |                |      | <i>-21</i>        |                   |            |          |            | <i>X</i> |          |          | <i>"</i>         |
| <i>B6-16-TB-0-3</i>        |                |      | <i>-22</i>        |                   |            |          |            | <i>X</i> |          |          | <i>"</i>         |
| <i>B6-16-TB-I-1</i>        |                |      | <i>-23</i>        |                   |            |          |            | <i>X</i> | <i>X</i> | <i>X</i> | <i>Flare In</i>  |
| <i>Blank H30</i>           |                |      | <i>-24</i>        |                   |            | <i>X</i> |            |          |          |          |                  |

|                                                    |                        |                     |                                                            |                        |                      |
|----------------------------------------------------|------------------------|---------------------|------------------------------------------------------------|------------------------|----------------------|
| Relinquished by: (Signature)<br><i>[Signature]</i> | Date<br><i>8/28/07</i> | Time<br><i>1150</i> | Received by: (Signature)<br><i>[Signature]</i>             | Date                   | Time                 |
| Relinquished by: (Signature)                       | Date                   | Time                | Received by: (Signature)                                   | Date                   | Time                 |
| Relinquished by: (Signature)                       | Date                   | Time                | Received for Laboratory: (Signature)<br><i>[Signature]</i> | Date<br><i>8-28-07</i> | Time<br><i>11150</i> |

|                         |                                                   |      |      |
|-------------------------|---------------------------------------------------|------|------|
| Sample Disposal Method: | Disposed of by: (Signature)<br><i>[Signature]</i> | Date | Time |
|-------------------------|---------------------------------------------------|------|------|

|                                                                                                                                                               |                                                                                                  |                 |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|-----------------|
| SAMPLE COLLECTOR<br><br>HORIZON AIR MEASUREMENT SERVICES, INC<br>996 Lawrence Drive, Suite 108<br>Newbury Park, CA 91320<br>(805) 498-8781 Fax (805) 498-3173 | ANALYTICAL LABORATORY<br><br><div style="font-size: 2em; text-align: center;"><i>AtuAA</i></div> | <b>Nº 09598</b> |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|-----------------|

Facility: BFI/SYLMAR  
 Source: FLARE 3  
 Job No.: B06-016  
 Test Date: 08/28/07

SCAQMD Method 5.1

DATA SHEET FOR PARTICULATE MATTER SCAQMD METHOD 5.1

DATE SAMPLED: 08/29/07  
 DATE EXTRACTED: 09/04/07


BLANK

|                      | SAMPLE ID     | BEAKER/<br>FILTER ID | VOLUME | INITIAL | FINAL   | NET WEIGHT(g) |
|----------------------|---------------|----------------------|--------|---------|---------|---------------|
| A - FILTER CATCH     | B6-16-M5-PF-B | Q6017                | NA     | 0.1489  | 0.1486  | 0.0000        |
| FILTER ACID          |               |                      |        |         |         | 0.0000        |
| FILTER SULFATE       |               |                      |        |         |         | 0.0000        |
| B - PROBE CATCH      |               |                      |        |         |         | 0.0000        |
| PROBE ACID           |               |                      |        |         |         | 0.0000        |
| PROBE SULFATE        |               |                      |        |         |         | 0.0000        |
| C - IMP.CATCH(INSOL) | B6-16-M5-EF-B | Q62                  | 250    | 0.1509  | 0.1506  | 0.0000        |
| INSOLUBLE ACID       |               |                      |        |         |         | 0.0000        |
| INSOLUBLE SULFATE    |               |                      |        |         |         | 0.0000        |
| D - IMP. CATCH (SOL) | B6-16-M5-DI-B | B7091                | 250    | 30.0485 | 30.0483 | 0.0000        |
| SOLUBLE ACID         |               |                      |        |         |         | 0.0000        |
| SOLUBLE SULFATE      |               |                      |        |         |         | 0.0000        |
| E - ORGANIC EXTRACT  |               |                      |        |         |         | 0.0000        |
| -----                |               |                      |        |         |         |               |
| TOTAL PARTICULATE    | (A+B+C+D+E)   |                      |        |         |         | 0.0000        |
| SOLID PARTICULATE    | (A+B+C+D)     |                      |        |         |         | 0.0000        |

## **APPENDIX E - Operating Data**

## **APPENDIX F - Strip Chart Records**





# Endrun e



Praxair  
5700 South Alameda Street  
Los Angeles, CA 90058  
Telephone: (323) 585-2154  
Facsimile: (714) 542-6689

## CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS ES

CUSTOMER HORIZON AIR MEASUREMENTS

P.O NUMBER 9048

### REFERENCE STANDARD

| COMPONENT         | NIST SRM NO. | CYLINDER NO. | CONCENTRATION |
|-------------------|--------------|--------------|---------------|
| NITRIC OXIDE GMIS | vs. SRM#2628 | CC 149122    | 10.57 ppm     |

### ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

| 1. COMPONENT         | NITRIC OXIDE | GMIS              | ANALYZER MAKE-MODEL-S/N | THERMO ENV. 42C S/N 0518112467 |         |                 |            |
|----------------------|--------------|-------------------|-------------------------|--------------------------------|---------|-----------------|------------|
| ANALYTICAL PRINCIPLE |              | CHEMILUMINESCENCE |                         | LAST CALIBRATION DATE 03/01/07 |         |                 |            |
| FIRST ANALYSIS DATE  |              | 03/06/07          |                         | SECOND ANALYSIS DATE 03/14/07  |         |                 |            |
| Z 0                  | R 10.66      | C 13.43           | CONC. 13.3              | Z 0                            | R 10.65 | C 13.37         | CONC. 13.3 |
| R 10.66              | Z 0          | C 13.39           | CONC. 13.3              | R 10.66                        | Z 0     | C 13.38         | CONC. 13.3 |
| Z 0                  | C 13.40      | R 10.66           | CONC. 13.3              | Z 0                            | C 13.39 | R 10.66         | CONC. 13.3 |
| U/M ppm              |              | MEAN TEST ASSAY   | 13.3                    | U/M ppm                        |         | MEAN TEST ASSAY | 13.3       |

VALUE NOT VALID BELOW 150 PSIG.  
NOX VALUE FOR REFERENCE USE ONLY.

| THIS CYLINDER NO.                       | CC 145749        | CERTIFIED CONCENTRATION |
|-----------------------------------------|------------------|-------------------------|
| HAS BEEN CERTIFIED ACCORDING TO SECTION | EPA-600/R97/121  | NITRIC OXIDE 13.3 ppm   |
| OF TRACEABILITY PROTOCOL NO.            | Rev. 9/97        | NITROGEN BALANCE        |
| PROCEDURE G1                            |                  | NOx 13.3 ppm            |
| CERTIFIED ACCURACY $\pm 1$              | % NIST TRACEABLE |                         |
| CYLINDER PRESSURE                       | 2000 PSIG        |                         |
| CERTIFICATION DATE                      | 03/14/07         |                         |
| EXPIRATION DATE                         | 03/14/09         | TERM 24 MONTHS          |

ANALYZED BY

HENRY KOUNG

CERTIFIED BY

PHI KIM

#### IMPORTANT

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall liability of Praxair Distribution, Inc. arising out of the use of the information contained herein exceed the fee established for providing such information.



Praxair  
5700 South Alameda Street  
Los Angeles, CA 90058  
Telephone: (323) 585-2154  
Facsimile: (714) 542-6689

## CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER HORIZON AIR MEASUREMENTS

P.O NUMBER 8952

### REFERENCE STANDARD

| COMPONENT            | NIST SRM NO. | CYLINDER NO. | CONCENTRATION |
|----------------------|--------------|--------------|---------------|
| CARBON MONOXIDE GMIS | vs. SRM#1679 | CC 155880    | 99.4 ppm      |
| NITRIC OXIDE GMIS    | vs. SRM#1683 | CC 108042    | 50.6 ppm      |

### ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

| 1. COMPONENT         | CARBON MONOXIDE | GMIS            | ANALYZER MAKE-MODEL-S/N | HORIBA, VIA-510, S/N 576876015 |
|----------------------|-----------------|-----------------|-------------------------|--------------------------------|
| ANALYTICAL PRINCIPLE | NDIR            |                 |                         | LAST CALIBRATION DATE 09/11/06 |
| FIRST ANALYSIS DATE  | 02/22/06        |                 |                         | SECOND ANALYSIS DATE 09/28/06  |
| Z 0.0                | R 99.0          | C 49.9          | CONC. 49.9              | Z 0.0 R 99.4 C 49.6 CONC. 49.6 |
| R 99.0               | Z 0.0           | C 49.9          | CONC. 49.9              | R 99.4 Z 0.0 C 49.6 CONC. 49.6 |
| Z 0.0                | C 50.0          | R 99.0          | CONC. 50.0              | Z 0.0 C 49.6 R 99.4 CONC. 49.6 |
| U/M ppm              |                 | MEAN TEST ASSAY | 49.9                    | U/M ppm MEAN TEST ASSAY 49.6   |

| 2. COMPONENT         | NITRIC OXIDE      | GMIS            | ANALYZER MAKE-MODEL-S/N | BECKMAN 951A S/N#0101354         |
|----------------------|-------------------|-----------------|-------------------------|----------------------------------|
| ANALYTICAL PRINCIPLE | CHEMILUMINESCENCE |                 |                         | LAST CALIBRATION DATE 09/11/06   |
| FIRST ANALYSIS DATE  | 02/22/06          |                 |                         | SECOND ANALYSIS DATE 09/28/06    |
| Z 0.0                | R 540.9           | C 547.9         | CONC. 50.4              | Z 0.0 R 671.0 C 670.0 CONC. 50.5 |
| R 541.2              | Z 0.0             | C 549.0         | CONC. 50.5              | R 673.0 Z 0.0 C 671.0 CONC. 50.4 |
| Z 0.0                | C 549.8           | R 541.6         | CONC. 50.6              | Z 0.0 C 672.0 R 677.0 CONC. 50.2 |
| U/M mV               |                   | MEAN TEST ASSAY | 50.5                    | U/M mV MEAN TEST ASSAY 50.4      |

Values not valid below 150 psig.

NOx value for reference use only.

CO,NO first analysis done vs. 99.0 ppm,49.8 ppm GMIS respectively

| THIS CYLINDER NO.                       | CC 200266               | CERTIFIED CONCENTRATION  |
|-----------------------------------------|-------------------------|--------------------------|
| HAS BEEN CERTIFIED ACCORDING TO SECTION | EPA-600/R97/121         | CARBON MONOXIDE 49.8 ppm |
| OF TRACEABILITY PROTOCOL NO.            | Rev. 9/97               | NITRIC OXIDE 50.5 ppm    |
| PROCEDURE                               | G1                      | NITROGEN BALANCE         |
| CERTIFIED ACCURACY                      | ± 1 % NIST TRACEABLE    | NOx 51.3 ppm             |
| CYLINDER PRESSURE                       | 2000 PSIG               |                          |
| CERTIFICATION DATE                      | 09/28/06                |                          |
| EXPIRATION DATE                         | 09/28/08 TERM 24 MONTHS |                          |

ANALYZED BY

GEORGE WAHBA

CERTIFIED BY

PHU TIEN NGUYEN

#### IMPORTANT

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall liability of Praxair Distribution, Inc. arising out of the use of the information contained herein exceed the fee established for providing such information.



Praxair  
5700 South Alameda Street  
Los Angeles, CA 90058  
Telephone: (323) 585-2154  
Facsimile: (714) 542-6689

6/2/2006

HORIZON AIR  
455 E WOOLEY RD  
OXNARD, CA 93030  
USA

Praxair Order No. **410897-00**  
Customer Reference No.  
Intended End User: **Horizon Air**

Product Lot/Batch No. **109517305**  
Praxair Part No. **EV NINX19MP-AS**

### CERTIFICATE OF ANALYSIS

*Primary Standard*

| <u>Component</u>                      | <u>Requested<br/>Concentration</u> | <u>Certified<br/>Concentration</u> | <u>Analytical<br/>Principle</u> | <u>Analytical<br/>Accuracy</u> |
|---------------------------------------|------------------------------------|------------------------------------|---------------------------------|--------------------------------|
| Nitrogen dioxide (as NOx)<br>Nitrogen | 19 ppm<br>balance                  | 17.9 ppm<br>balance                | U                               | ±1%                            |

Analytical Instruments: **Thermo Environmental-42H-S/N 44979-273 ~Chemiluminescence**  
Cylinder Style: **AS**  
Cylinder Pressure @70°F: **2000 psig**  
Cylinder Volume: **141 ft<sup>3</sup>**  
Valve Outlet Connection: **CGA-660**  
Cylinder No(s): **CC 141408**  
Comments: **All values not valid below 150 psig.  
NO=0.9 ppm value for reference use only.**

Filling Method: **Gravimetric**  
Date of Fill: **6/22/2005**  
Expiration Date: **6/5/2008**

Analyst: **Henry Kounig**

QA Reviewer: **Phu Tien Nguyen**

The gas calibration cylinder standard prepared by Praxair Distribution is considered a certified standard. It is prepared by gravimetric, volumetric, or partial pressure techniques. The calibration standard provided is certified against Praxair Reference Materials which are either prepared by weights traceable to the National Institute of Standards and Technology (NIST) or by using NIST Standard Reference Materials where available.

Note: All expressions for concentration (e.g., % or ppm) are for gas phase, by volume (e.g., ppmv) unless otherwise noted.

|                                                      |                                                         |                                                              |                                                     |
|------------------------------------------------------|---------------------------------------------------------|--------------------------------------------------------------|-----------------------------------------------------|
| Key to Analytical Techniques:                        |                                                         |                                                              |                                                     |
| A Flame Ionization with Methanizer                   | B Gas Chromatography with Discharge Ionization Detector | C Gas Chromatography with Electrolytic Conductivity Detector | D Gas Chromatography with Flame Ionization Detector |
| E Gas Chromatography with Flame Photometric Detector | F Gas Chromatography with Helium Ionization Detector    | G Gas Chromatography with Methanizer Carbonizer              | H Gas Chromatography with Photoionization Detector  |
| I Gas Chromatography with Reduction Gas Analyzer     | J Gas Chromatography with Thermal Conductivity Detector | K Gas Chromatography with Ultrasonic Detector                | L Infrared - FTIR or NDIR                           |
| M Mass Spectrometry - MS or GC/MS                    | N Proprietary                                           | O Paramagnetic                                               | P Specific Water Analyzer                           |
| Q Total Hydrocarbon Analyzer                         | R Wet Chemical                                          | E Detector Tube                                              | T Odor                                              |
| U Chemiluminescence                                  | V Gravimetric                                           | II Electrolytic Cell/Electrochemical                         | X Photoionization                                   |
| Y Pulsed Fluorescence                                | Z UV Spectrometry                                       |                                                              |                                                     |

#### IMPORTANT

The information contained herein has been prepared at your request by personnel within Praxair Distribution. While we believe the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall liability of Praxair Distribution, Inc. arising out of the use of the information contained herein exceed the fee established for providing such information.

*Making Our Planet More Productive*



Praxair  
5700 South Alameda Street  
Los Angeles, CA 90058  
Telephone: (323) 585-2154  
Facsimile: (714) 542-6689

## CERTIFICATE OF ANALYSIS

CUSTOMER HORIZON AIR MEASUREMENTS

DATE 05/12/04

P.O NUMBER

REF. NUMBER 67757400

### REQUESTED COMPOSITION

| GAS                 | CONCENTRATION |
|---------------------|---------------|
| CARBON DIOXIDE      | 12 %          |
| OXYGEN              | 20 %          |
| NITROGEN            | BALANCE       |
| ANALYTICAL ACCURACY | ±0.02%abs     |

### ANALYTICAL METHOD

| INSTRUMENT               | ANALYTICAL PRINCIPLE |
|--------------------------|----------------------|
| Mettler ID5, S/N:1865166 | Gravimetric          |
| Mettler ID5, S/N:1865166 | Gravimetric          |

Values not valid below 150 psig.

| THIS CYLINDER NO. |                    | CERTIFIED CONCENTRATION |           |
|-------------------|--------------------|-------------------------|-----------|
| CYLINDER PRESSURE | SA 4023            | CARBON DIOXIDE          | 11.96 %   |
| EXPIRATION DATE   | 2000 PSIG          | OXYGEN                  | 19.94 %   |
| CLASSIFICATION    | 12/31/07           | NITROGEN                | BALANCE   |
| BATCH NUMBER      | PRIMARY STANDARD   | ANALYTICAL ACCURACY     | ±0.02%abs |
| LOT NUMBER        | N/A                |                         |           |
| PART NUMBER       | 109413304          |                         |           |
| CYLINDER SIZE     | NI CDOXP80-AS      |                         |           |
|                   | AS CGA 590 152 CFT |                         |           |

ANALYZED BY

JACK FU

CERTIFIED BY

TY TRIPLETT

#### IMPORTANT

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

**APEX INSTRUMENTS METHOD 5 PRE-TEST CONSOLE CALIBRATION**  
**USING CALIBRATED CRITICAL ORIFICES**  
**5-POINT ENGLISH UNITS**

| Meter Console Information |          |
|---------------------------|----------|
| Console Model Number      | 522/MB06 |
| Console Serial Number     | 507121   |
| DGM Model Number          | T110     |
| DGM Serial Number         | 1029313  |

| Calibration Conditions                   |      |            |             |
|------------------------------------------|------|------------|-------------|
| Date                                     | Time | 3-Jul-07   | 12:20:00 PM |
| Barometric Pressure                      |      | 29.2       | in Hg       |
| Theoretical Critical Vacuum <sup>1</sup> |      | 13.8       | in Hg       |
| Calibration Technician                   |      | BJ - Run#3 |             |

| Factors/Conversions |        |          |
|---------------------|--------|----------|
| Std Temp            | 528    | °R       |
| Std Press           | 29.92  | in Hg    |
| K <sub>1</sub>      | 17.647 | oR/in Hg |

<sup>1</sup>For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

<sup>2</sup>The Critical Orifice Coefficient, K', must be entered in English units, (ft<sup>3</sup>R<sup>1/2</sup>)/(in.Hg\*min).

| Calibration Data |                     |                   |                   |                        |                      |                  |                        |                     |                     |                  |
|------------------|---------------------|-------------------|-------------------|------------------------|----------------------|------------------|------------------------|---------------------|---------------------|------------------|
| Run Time         | Metering Console    |                   |                   |                        |                      | Critical Orifice |                        |                     |                     |                  |
| Elapsed          | DGM Orifice<br>ΔH   | Volume<br>Initial | Volume<br>Final   | Outlet Temp<br>Initial | Outlet Temp<br>Final | Serial<br>Number | Coefficient            | Amb Temp<br>Initial | Amb Temp<br>Final   | Actual<br>Vacuum |
| (θ)              | (P <sub>m</sub> )   | (V <sub>m</sub> ) | (V <sub>m</sub> ) | (t <sub>m</sub> )      | (t <sub>m</sub> )    |                  | K'                     | (t <sub>amb</sub> ) | (t <sub>amb</sub> ) |                  |
| min              | in H <sub>2</sub> O | cubic feet        | cubic feet        | °F                     | °F                   |                  | see above <sup>2</sup> | °F                  | °F                  | in Hg            |
| 20.0             | 0.2                 | 510.750           | 516.961           | 80                     | 83                   | RN-40            | 0.2333                 | 83                  | 84                  | 24               |
| 16.0             | 0.5                 | 516.961           | 524.331           | 82                     | 83                   | RN-48            | 0.3455                 | 84                  | 84                  | 22               |
| 20.0             | 0.9                 | 524.331           | 536.164           | 83                     | 86                   | RN-55            | 0.4431                 | 84                  | 84                  | 20               |
| 15.0             | 1.7                 | 536.164           | 548.207           | 84                     | 90                   | RN-63            | 0.6003                 | 84                  | 84                  | 18               |
| 28.0             | 2.9                 | 548.207           | 577.670           | 85                     | 96                   | RN-73            | 0.7827                 | 84                  | 85                  | 16               |

| Results                |                        |                         |                         |                    |           |                              |           |             |
|------------------------|------------------------|-------------------------|-------------------------|--------------------|-----------|------------------------------|-----------|-------------|
| Standardized Data      |                        |                         |                         | Dry Gas Meter      |           |                              |           |             |
| Dry Gas Meter          |                        | Critical Orifice        |                         | Calibration Factor |           | Flowrate                     | ΔH @      |             |
| (V <sub>m(Std)</sub> ) | (Q <sub>m(Std)</sub> ) | (V <sub>cr(Std)</sub> ) | (Q <sub>cr(Std)</sub> ) | Value              | Variation | Std & Corr                   | 0.75 SCFM | Variation   |
| cubic feet             | cfm                    | cubic feet              | cfm                     | (Y)                | (ΔY)      | (Q <sub>m(Std)(Corr)</sub> ) | (ΔH@)     | (ΔΔH@)      |
| 5.910                  | 0.296                  | 5.838                   | 0.292                   | 0.988              | 0.000     | 0.292                        | 1.447     | -0.116      |
| 7.006                  | 0.438                  | 6.914                   | 0.432                   | 0.987              | -0.001    | 0.432                        | 1.550     | -0.013      |
| 11.218                 | 0.561                  | 11.083                  | 0.554                   | 0.988              | 0.000     | 0.554                        | 1.585     | 0.023       |
| 11.387                 | 0.759                  | 11.262                  | 0.751                   | 0.989              | 0.001     | 0.751                        | 1.612     | 0.050       |
| 27.752                 | 0.991                  | 27.396                  | 0.978                   | 0.987              | -0.001    | 0.978                        | 1.618     | 0.056       |
|                        |                        |                         |                         | 0.988              | Y Average |                              | 1.562     | ΔH@ Average |

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02.

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR Title 40, Part 60, Appendix A-3, Method 5, 16.2.3

Signature



Date

7-3-07

**Nozzle Calibration Data  
Continuous Quartz**

**Date:** 07/26/07

**Calibrated by:**

**BJ**

**QUARTZ NOZZLES**

| NOZZLE ID  | D1<br>±.001 | D2<br>±.001 | D3<br>±.001 | Delta D<br>(.004 Max) | Avg. D |
|------------|-------------|-------------|-------------|-----------------------|--------|
| CQ-1 (10') | 1.027       | 1.020       | 1.026       |                       | 1.024  |
| CQ-2 (10') | 1.009       | 1.009       | 1.006       |                       | 1.008  |
| CQ-3 (10') | 1.051       | 1.049       | 1.051       |                       | 1.050  |
| CQ-4 (10') | 0.996       | 0.990       | 0.997       |                       | 0.994  |
| CQ-5 (10') | 1.034       | 1.036       | 1.032       |                       | 1.034  |
| CQ-7 (6')  | 1.021       | 1.022       | 1.021       |                       | 1.021  |
| CQ-8 (6')  | 1.054       | 1.054       | 1.056       |                       | 1.055  |
| CQ-9 (6')  | 1.053       | 1.052       | 1.052       |                       | 1.052  |

## **APPENDIX H - Permit to Operate**



**PERMIT TO OPERATE**

**CONTINUATION OF PERMIT TO OPERATE**

- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
- 3) THIS EQUIPMENT SHALL BE OPERATED AND MAINTAINED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
- 4) A SET OF FOUR SAMPLING PORTS SHALL BE INSTALLED IN THE FLARE SHROUD AND LOCATED AT LEAST TWO FEET ABOVE THE FLAME ZONE AND AT LEAST SIX AND ONE HALF FEET BELOW THE TOP OF THE FLARE SHROUD. EACH PORT SHALL CONSIST OF A FOUR-INCH COUPLING WITH PLUG. ADEQUATE AND SAFE ACCESS TO ALL SOURCE TEST PORTS SHALL BE PROVIDED WITHIN 24 HOURS OF A REQUEST BY THE AQMD TO CONDUCT A TEST
- 5) A SAMPLING PORT SHALL BE MAINTAINED AT THE INLET GAS LINE TO THE FLARE TO ALLOW LANDFILL GAS SAMPLING AND FLOW MEASUREMENT.
- 6) THE FLARE SHALL BE EQUIPPED WITH A TEMPERATURE INDICATOR AND RECORDER WHICH MEASURES AND RECORDS THE GAS TEMPERATURE IN THE FLARE STACK. THE TEMPERATURE INDICATOR AND RECORDER SHALL OPERATE WHENEVER THE FLARE IS IN OPERATION. THE THERMOCOUPLE USED TO MEASURE THE TEMPERATURE SHALL BE AT LEAST TWO FEET ABOVE THE FLAME ZONE AND AT LEAST SIX AND ONE HALF FEET BELOW THE TOP OF THE FLARE SHROUD AND AT LEAST 0.6 SECONDS DOWNSTREAM OF THE BURNER.
- 7) WHENEVER THE FLARE IS IN OPERATION, A TEMPERATURE OF NOT LESS THAN 1600 DEGREES F, AS MEASURED BY THE TEMPERATURE INDICATOR AND RECORDER, SHALL BE MAINTAINED IN THE FLARE STACK.
- 8) THE SKIN TEMPERATURE OF THE FLARE SHROUD WITHIN FOUR FEET OF ALL THE SOURCE TEST PORTS SHALL NOT EXCEED 250 DEGREES F. IF A HEAT SHIELD IS REQUIRED TO MEET THIS REQUIREMENT, ITS DESIGN SHALL BE APPROVED BY THE AQMD PRIOR TO CONSTRUCTION. THE HEAT SHIELD, IF REQUIRED TO MEET THE TEMPERATURE REQUIREMENT, SHALL BE IN PLACE WHENEVER A SOURCE TEST IS CONDUCTED BY THE AQMD.
- 9) A SUFFICIENT NUMBER OF SIGHT GLASS WINDOWS SHALL BE MAINTAINED IN THE FLARE TO ALLOW VISUAL INSPECTION OF THE FLAME WITHIN THE FLARE AT ALL TIMES. PERMANENT AND SAFE ACCESS SHALL BE PROVIDED FOR ALL SIGHT GLASS WINDOWS.
- 10) A FLOW INDICATOR AND RECORDER SHALL BE MAINTAINED IN THE LANDFILL GAS SUPPLY LINE TO THE FLARE TO MEASURE AND RECORD THE GAS FLOW RATE (IN SCFM) TO THE FLARE AND SHALL OPERATE WHENEVER THE FLARE IS IN OPERATION.
- 11) THE TOTAL VOLUME OF LANDFILL GAS BURNED IN THE FLARE SHALL NOT EXCEED 4,167 STANDARD CUBIC FEET PER MINUTE.



## PERMIT TO OPERATE

CONTINUATION OF PERMIT TO OPERATE

- 16) A PRESSURE DIFFERENTIAL INDICATOR SHALL BE MAINTAINED ACROSS THE PARTICULATE FILTER.
- 17) A PRESSURE DIFFERENTIAL INDICATOR SHALL BE MAINTAINED ACROSS THE FLAME ARRESTOR.
- 18) THE HEAT RELEASE OF LANDFILL GAS BURNED IN THIS FLARE SHALL NOT EXCEED 105 MILLION BTU/HR.
- 19) LANDFILL GAS ENTERING THE FLARE SHALL BE ANALYZED WEEKLY FOR HEATING VALUE AND METHANE CONCENTRATION. RESULTS SHALL BE RECORDED AND PROVIDED TO THE AQMD UPON REQUEST.
- 20) ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF DAY.
- 21) ALL RECORDS SHALL BE KEPT FOR A PERIOD OF AT LEAST TWO (2) YEARS AND SHALL BE MADE AVAILABLE TO THE AQMD UPON REQUEST. A RECORD OF THE HOURS OF FLARE OPERATION SHALL BE INCLUDED.
- 22) ANY BREAKDOWN OR MALFUNCTION OF THE LANDFILL GAS FLARE SYSTEM RESULTING IN THE EMISSION OF RAW LANDFILL GAS SHALL BE REPORTED TO THE AQMD WITHIN ONE HOUR AFTER OCCURRENCE, AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.

### NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR COPY SHALL BE POSTED ON OR WITHIN 8 METERS OF THE EQUIPMENT.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT CANNOT BE CONSIDERED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF OTHER GOVERNMENT AGENCIES.

EXECUTIVE OFFICER

*Dorris M. Bailey*

By Dorris M. Bailey/tk01  
11/18/1999

ORIGINAL