

Final Report

Compliance Testing of a Landfill Flare at Browning-Ferris Gas Services, Inc.'s Facility in Halifax, Massachusetts

May 1996



RENEE A. VOYT
Permit Coordinator
Gas Services

June 13, 1996

Mr. Christopher Tilden
Regional Engineer
Commonwealth of Massachusetts
Department of Environmental Protection
Southeast Regional Office
20 Riverside Drive
Lakeville, Massachusetts 02347

Re: *Emissions Test Results*
Halifax Landfill Enclosed Flare
Source Number 220

Dear Mr. Tilden:

Enclosed are two copies of the Final Report entitled "Compliance Testing of a Landfill Flare at Browning-Ferris Gas Services, Inc.'s Facility in Halifax, Massachusetts" dated May 1996 for your review. TRC Environmental Corporation performed the tests on April 19 and 22, 1996 in accordance with the original protocol (4S93029) and the revisions to the protocol outlined in my February 21, 1996 letter. Additionally, a sample of landfill gas was analyzed for speciated volatile organic compounds (VOC) as requested by Mr. P.C. Mehta of your staff.

Emissions Summary

The test results demonstrate that emissions of particulate matter, carbon monoxide, hydrogen sulfide, and nitrogen oxides are well below the permitted limits. Additionally, hydrogen chloride (HCl) emissions were measured to be less than one ton per year from the flare. There are no emission limits for HCl, but emissions were measured as requested by the Massachusetts DEP.

VOC emissions during the first 1-hour test run at 1550°F, however, were measured above the permit limit. BFGSI does not believe this run is representative of normal flare operation because the flare had shut down during

Mr. Christopher Tilden
June 13, 1996
Page 2


the previous evening and likely did not reach a steady operating state prior to the first test. Please allow use of only the second two VOC emissions tests to demonstrate compliance with the permit limits.

VOC Destruction Efficiency

The permit currently requires VOC destruction efficiency of 98 percent. The average VOC destruction efficiency during test runs 2 and 3 was calculated to be 93 percent. However, as stated above, emissions were measured below the permit limits and within the requirements of the recently promulgated New Source Performance Standards (NSPS) for municipal solid waste landfills. NSPS requires that enclosed landfill gas flares reduce non methane organic compound (NMOC) emissions by 98 percent reduction efficiency or to 20 ppmv as hexane. The flare at the Halifax Landfill meets the requirement for emissions reductions to 20 ppmv as hexane. BFGSI proposes to modify the permit for the Halifax Landfill to incorporate the 20 ppm NMOC NSPS requirement rather than the 98 percent NMOC reduction requirement for the enclosed landfill gas flare.

As written in the above referenced February 21, 1996 letter, the flare at Halifax will continue to operate within the temperature conditions tested. The emissions were tested at operating temperatures of 1550°F and 1950°F. If you have any questions regarding the enclosed emissions test report, please call me at (713) 870-7446.

Sincerely,



Renee A. Voyt

RAV:sjc
Enclosure

xc: P.C. Mehta, Massachusetts DEP (w/o enclosure)
Dan Barrett, BFGSI Halifax
File: Halifax/B

bxc: Casey Chambers, John Zink

BFI Halifax Outlet Flow - Determined by Carbon Balance Equation per John Zink Company

Run No.	Inlet Flowrate scf/min	Inlet				Outlet				Outlet Flowrate scf/min
		CO ppm	CO2 ppm	CH4 ppm	TGNMO ppm	CO ppm	CO2 ppm	CH4 ppm	TGNMO ppm	
1	1,570	14	409,200	505,000	3,700	10	74,600	8.4	82	19,370
2	1,570	13	407,400	514,000	3,700	21	72,400	0.0	19	20,133
3	1,570	12	405,700	512,000	3,900	13	78,400	0.0	20	18,519

John Zink Company Outlet Flow Carbon Balance Equation:

$$VO = VI \times \frac{(HC + CO + CO2) \text{ Inlet}}{(HC + CO + CO2 - 300) \text{ Outlet}}$$

Where:

- VO = Volume of outlet, standard condition, dry
- VI = Volume of inlet as measured, standard conditions, dry
- HC = Concentration of all hydrocarbons reported AS METHANE equivalent in ppm
- CO = Concentration of CO in ppm
- CO2 = Concentration of CO2 in ppm
- 300 = Approximate background concentration in ppm of CO2 in the inlet air

May 31, 1996

Browning-Ferris Gas Services, Inc.
757 N. Eldridge at Memorial Drive
Houston, TX 77079

Attention: Ms. Renee Voyt
Permit Coordinator

Subject: Final Report for Compliance Testing of BFGSI's Landfill Flare
Located in Halifax, Massachusetts
(TRC Reference No. 20272)

Dear Ms. Voyt:

In accordance with the reporting requirements of the subject program, enclosed herewith are four (4) copies of a Final Report entitled, "**Final Report - Compliance Testing of a Landfill Flare at Browning-Ferris Gas Services, Inc.'s Facility in Halifax, Massachusetts**", dated May 1996.

If you should have any questions regarding this final report, please do not hesitate to call me at (508) 656-3547.

Sincerely,

TRC ENVIRONMENTAL CORPORATION



Michael P. O'Brien
Project Manager
Air Measurements Department

Enclosures

TRC Project No. 20272

May 1996

FINAL REPORT

**Compliance Testing of a Landfill Flare at
Browning-Ferris Gas Services, Inc.'s
Facility in Halifax, Massachusetts**

Prepared for

Browning-Ferris Gas Services, Inc.
757 N. Eldridge at Memorial Drive
Houston, Texas 77079

Prepared by

TRC ENVIRONMENTAL CORPORATION
Boott Mills South
Foot of John Street
Lowell, Massachusetts 01852
(508) 970-5600

DISCLAIMER

This report is intended for use solely by Browning-Ferris Gas Services, Inc. for the specific purposes described in the contractual documents between TRC Environmental Corporation and Browning-Ferris Gas Services, Inc. All professional services performed and reports generated by TRC have been prepared for Browning-Ferris Gas Services, Inc.'s purposes as described in the contract. The information, statements and conclusions contained in the report have been prepared in accordance with the work statement and contract terms and conditions. The report may be subject to differing interpretations and/or may be misinterpreted by third persons or entities who were not involved in the investigative or consultation process. TRC Environmental Corporation therefore expressly disclaims any liability to persons other than Browning-Ferris Gas Services, Inc. who may use or rely upon this report in any way or for any purpose.

TABLE OF CONTENTS

Section	Page
1	INTRODUCTION 1
1.1	Overview 1
1.2	Scope of Work 1
1.3	Report Summary 2
2	SUMMARY AND DISCUSSION OF RESULTS 3
2.1	Operational Parameters 3
2.2	Compliance Test Parameters 3
2.3	Hydrogen Chloride (HCl) 4
2.4	Particulate Matter (PM) 4
2.5	Total Non-Methane Organics as Methane and Hexane 4
2.6	Hydrogen Sulfide Compounds 7
2.7	Continuous Emissions Monitoring for O ₂ , CO ₂ , SO ₂ , NO _x , and CO 7
3	PROCESS DESCRIPTION 13
3.1	Introduction 13
3.2	Operating Conditions 15
3.3	Sampling Locations 15
3.3.1	Inlet Sampling Location 15
3.3.2	Outlet Sampling Location 17
4	SAMPLING PROCEDURES 18
4.1	Overview 18
4.2	Field Program Description 18
4.3	Presampling Activities 20
4.3.1	Equipment Calibration 20
4.3.2	Glassware Preparation 21
4.3.3	Sample Media Preparation 21
4.3.4	Continuous Emissions Monitoring 22
4.3.5	NO ₂ to NO Conversion Efficiency 24
4.4	Onsite Sampling Activities 24
4.4.1	Velocity Measurements/Cyclonic Flow 24
4.4.2	Hydrogen Chloride/Particulate Matter 25
4.4.3	Methane and Non-Methane Organics 27
4.4.4	Oxygen, Carbon Dioxide, Carbon Monoxide 28
4.4.5	Hydrogen Sulfide and Total Reduced Sulfur (TRS) 28
4.4.6	Continuous Emissions Monitoring for O ₂ , CO ₂ , SO ₂ , NO _x , and CO 29

TABLE OF CONTENTS (CONTINUED)

Section	Page
5	ANALYTICAL PROCEDURES 30
5.1	Organic Analysis 30
5.1.1	Methane and Non-Methane Organics 30
5.2	Inorganic Analysis 30
5.2.1	Hydrogen Chloride 30
5.2.2	Particulate Matter 31
5.2.3	Hydrogen Sulfide and Total Reduced Sulfur (TRS) 31
5.3	DRE Calculation 32
5.4	Pounds per Million British Thermal Units Calculation 32
5.5	Pounds per Hour Calculation 33
6	QUALITY ASSURANCE 34
6.1	Overview 34
6.2	Field Quality Control Summary 34
6.2.1	Calibration Gases 34
6.2.2	Instrument Calibrations 35
6.2.3	Calibration Procedures 35
6.2.4	Equipment Leak Checks 35
6.2.5	Cyclonic Flow Check 35
6.2.6	Method Blanks 35
6.3	Sample Chain of Custody 36
6.4	Data Reduction, Validation, and Reporting 36
6.4.1	Field Data Reduction 36
6.4.2	Laboratory Analysis Data Reduction 36
6.4.3	Data Validation 37
6.4.4	Data Reporting 38
6.5	Exceptions 39

Appendices

- A Field Sampling Data Sheets
- B Field Reduced Data
- C Flue Gas Analytical Data
- D CEM Calibration and Data Sheets
- E Calibration Data Sheets
- F Facility Process Data

TABLE OF CONTENTS (CONTINUED)

TABLES

Number		Page
2-1	Hydrogen Chloride Emission Summary @ 1550°F	5
2-2	Particulate Matter Emission Summary @ 1550°F	6
2-3	VOC (as Methane) Emission Summary @ 1550°F	8
2-4	VOC (as Hexane) Emission Summary @ 1550°F	9
2-5	Hydrogen Sulfide Emission Summary @ 1550°F	10
2-6	CEM Emissions Summary @ 1550°F	11
2-7	CEM Emissions Summary @ 1950°F	12

FIGURES

Number		Page
3-1	BFGSI Enclosed Flare System	14
3-2	Stack Sampling Location and Traverse Points	16

SECTION 1

INTRODUCTION

1.1 OVERVIEW

Browning-Ferris Industries, Inc. (BFI) operates a John Zink Company Enclosed Ground Flare at the Halifax Landfill. The waste encapsulated within the landfill decomposes and creates a gas, which primarily consists of methane, carbon dioxide, and trace gases. In an effort to control the air pollution, the landfill gas is directed to and combusted in the enclosed flare system.

Pursuant to the air quality permit issued by the Massachusetts Department of Environmental Protection, an emissions test program was undertaken on the enclosed flare system to demonstrate permit compliance conditions.

TRC Environmental Corporation (TRC) of Lowell, Massachusetts was retained by Browning-Ferris Gas Services, Inc. (BFGSI) to provide sampling and analytical support. The BFGSI Compliance Test Program documents the performance of the enclosed flare system when incinerating the landfill gas. The operation of the system was demonstrated at two operating conditions:

- 1550°F
- 1950°F

Sampling and analysis procedures described in this document were conducted using procedures deemed acceptable by the Massachusetts Department of Environmental Protection (MADEP) and the U.S. EPA. TRC was responsible for the collection and analysis of all flue gas samples.

1.2 SCOPE OF WORK

The test program involved conducting a series of test runs at the inlet and outlet of the enclosed

flare for each condition using EPA Reference Methods. Each inlet test determined the emission rate of oxygen, carbon monoxide, carbon dioxide, methane, non-methane organics, hydrogen sulfide and Btu content. Each outlet test determined the percent Destruction Efficiency for volatile organic carbons (%) and hydrogen sulfide (%), and effluent concentrations for nitrogen oxides, carbon monoxide, sulfur dioxide, methane, total non-methane organics, hydrogen sulfide, HCl, particulate matter, oxygen, and carbon dioxide. Velocity and moisture emissions were also determined during each run.

1.3 REPORT SUMMARY

This report presents a summary of the test procedures and analytical results of the testing conducted on the BFI landfill flare by TRC. Sample analyses were conducted by Chester LabNet of Tigard, Oregon, Performance Analytical Inc. of Canoga Park, California and TRC Environmental Corporation of Lowell, Massachusetts.

Section 2 of this report presents a summary and discussion of the results. Section 3 contains a brief description of the sampling locations. Section 4 contains descriptions of the sampling methodologies that were utilized in the test program and Section 5 presents the analytical methodologies. Section 6 is a presentation of program QA/QC results. Included in the appendices are copies of all sampling and analytical data sheets, CEM and calibration sheets, and facility process data.

SECTION 2 SUMMARY AND DISCUSSION OF RESULTS

This section presents a summary of the emissions testing conducted on BFI's Halifax Landfill Flare System. The flue gas field sampling data sheets are located in Appendix A. Field reduced data sheets can be found in Appendix B. Flue gas analytical data sheets can be found in Appendix C. CEM and calibration data sheets can be found in Appendix D. Equipment calibrations and calibration gas certification sheets can be found in Appendix E. Facility process data can be found in Appendix F.

2.1 OPERATIONAL PARAMETERS

Operational data on the BFI landfill flare system was recorded by a Honeywell Inc. dual channel circular chart recorder. The data generated presented inlet landfill gas flow rate, in standard cubic feet (scfm), and exit flue gas temperature in degree fahrenheit. This can be found in Appendix F.

2.2 COMPLIANCE TEST PARAMETERS

TRC used the following sampling trains to collect flare gas samples from the landfill flare system:

- EPA Method 0050 train to collect HCl and particulate emissions;
- EPA Method 18 to measure hydrogen sulfide and total reduced sulfur content;
- EPA Method 25C to measure methane, total gaseous non-methane organics, oxygen, carbon dioxide, carbon monoxide, Btu content; and
- Transportable Continuous Emissions Monitoring System (TCEMS) to measure CO, NO_x, SO₂, O₂, and CO₂.

The compliance test program consisted of running three test runs at approximately 1550°F and three test runs at approximately 1950°F. TRC conducted emissions testing for HCl/Particulate

Matter at the 1550°F temperature only. The pollutant parameters of NO_x, CO, and SO₂ were measured at the 1950°F temperature only.

On April 22, 1996, TRC waited one hour before starting Run No. 1 at the 1550°F temperature. This was to allow the flare system to stabilize. Based on the results of the testing, it shows that Run No. 1 was not consistent with Run No. 2 and Run No. 3 in regards to the effluent pollutant gas concentrations. This difference may have been the result of additional stabilization time being required on the flare system.

2.3 HYDROGEN CHLORIDE (HCl)

Three 72-minute test runs were conducted isokinetically at the outlet stack of the flare system, using an EPA Method 0050 train for the collection of HCl and particulate emissions. Testing was conducted at the operating temperature of 1550°F. Emission concentrations for HCl are presented in concentration parts per million (ppm), pounds per hour (lbs/hr) and pounds per million Btu (lbs/10⁶Btu). Table 2-1 presents the results of the HCl tests.

2.4 PARTICULATE MATTER (PM)

Particulate matter was determined using an EPA Method 0050 train for the collection of HCl and PM emissions. Three 72-minute test runs were conducted isokinetically at the outlet stack of the flare system. Testing was conducted at the operating temperature of 1550°F. Emission concentrations for PM are presented in grains per dry standard cubic feed (gr/dscf), grains/dscf corrected to 7% oxygen (gr/dscf @ 7% O₂), pounds per hour (lbs/hr), and pounds per million Btu (lbs/10⁶Btu). Table 2-2 presents the results of the PM tests.

2.5 TOTAL NON-METHANE ORGANICS AS METHANE AND HEXANE

The determination of total non-methane organics as methane and as hexane at the inlet and outlet to the flare system followed EPA Method 25C. Three test runs were conducted at the inlet and

**TABLE 2-1. BFGSI - HALIFAX, MA
HYDROGEN CHLORIDE EMISSION SUMMARY @ 1550°F**

<i>Parameter</i>	<i>Units</i>	04/22/96	04/22/96	04/22/96	<i>AVERAGE</i>	<i>AVERAGE</i>
		<i>Run 1</i>	<i>Run 2</i>	<i>Run 3</i>	<i>Runs 1-3</i>	<i>Runs 2-3</i>
Sampling Location		Outlet Stack	Outlet Stack	Outlet Stack		
Start Time		11:50	14:30	17:25		
Stop Time		13:29	16:20	18:49		
Net Sampling Time	minutes	72	72	72	72	
Sample Volume	dscf	54,953	45,137	51,592	50,561	
Stack Gas Flow Rate	dscf/hr	1,401,540	1,185,960	1,286,400	1,291,300	
Stack Gas Temperature	°F	1507	1521	1510	1,513	
Stack Gas Moisture	%	8.6	7.8	8.6	8.3	
O ₂ Concentration at Stack, % dry	%	12.94	13.48	12.68	13.03	
CO ₂ Concentration at Stack, % dry	%	7.46	7.24	7.84	7.51	
HCl Catch	mg	3.37	2.77	2.96	3.03	2.87
HCl Concentration	mg/dscf	0.06	0.06	0.06	0.06	0.06
HCl Concentration	mg/m ³	2.17	2.17	2.03	2.12	2.10
HCl Concentration	ppm	1.43	1.43	1.34	1.40	1.38
HCl Emission Rate	lbs/MMBtu	0.003	0.004	0.003	0.003	0.003
HCl Emission Rate	lbs/hr	0.189	0.160	0.163	0.171	0.162

TAB2-1.WK4

**TABLE 2-2. BFGSI - HALIFAX, MA
PARTICULATE MATTER EMISSION SUMMARY @ 1550°F**

<i>Parameter</i>	<i>Units</i>	04/22/96	04/22/96	04/22/96	<i>AVERAGE</i>	<i>AVERAGE</i>
		<i>Run 1</i>	<i>Run 2</i>	<i>Run 3</i>	<i>Runs 1-3</i>	<i>Runs 2-3</i>
Sampling Location		Outlet Stack	Outlet Stack	Outlet Stack		
Start Time		11:50	14:30	17:25		
Stop Time		13:29	16:20	18:49		
Net Sampling Time	minutes	72	72	72	72	
Sample Volume	dscf	54.953	45.137	51.592	50.561	
Stack Gas Flow Rate	dscf/hr	1,401,540	1,185,960	1,286,400	1,291,300	
Stack Gas Temperature	°F	1507	1521	1510	1513	
Stack Gas Moisture	%	8.6	7.8	8.6	8.3	
<i>O₂ Concentration at Stack, % dry</i>	%	12.94	13.48	12.68	13.03	
<i>CO₂ Concentration at Stack, % dry</i>	%	7.46	7.24	7.84	7.51	
Particulate Catch	mg	5.60	4.80	4.00	4.80	4.40
Grain Loading	gr/dscf	0.0016	0.0016	0.0012	0.0015	0.0014
Grain Loading	gr/acf	0.0004	0.0004	0.0003	0.0004	0.0003
Grain Loading, gr/dscf @ 7% O ₂	gr/dscf	0.0027	0.0031	0.0020	0.0026	0.0025
Particulate Emission Rate	lbs/MMBtu	0.0056	0.0063	0.0041	0.0053	0.0052
Particulate Emission Rate	lbs/hr	0.31	0.55	0.22	0.36	0.38

TAB2-2.WK4

outlet locations for one test condition, 1550°F. These results are presented in Tables 2-3 through 2-4. The destruction and removal efficiency for Total VOCs is also presented in these tables.

2.6 HYDROGEN SULFIDE COMPOUNDS

EPA Method 18 was used to determine emission rates (lbs/hr) for H₂S at the flare inlet and outlet. Three test runs were conducted at the inlet and outlet locations for one test condition, 1550°F. These results are presented in Table 2-5. The destruction and removal efficiency for H₂S is also presented in this table.

2.7 CONTINUOUS EMISSIONS MONITORING FOR O₂, CO₂, SO₂, NO_x, AND CO

The continuous emissions monitoring system (TCEM) measured the effluent concentration from the flare system for the following pollutants; sulfur dioxide (SO₂), oxides of nitrogen (NO_x), carbon monoxide (CO), and the dilutants oxygen O₂ and carbon dioxide (CO₂). Testing was conducted during the two operating conditions of 1550°F and 1950°F. Table 2-6 presents the TCEM data for Runs 1 through 3 at 1550°F and Table 2-7 presents TCEM data for Runs 1 through 3 at 1950°F.

**TABLE 2-3. BFGSI - HALIFAX, MA
VOC (as Methane) EMISSION SUMMARY @ 1550°F**

<i>Parameter</i>	<i>Units</i>	<i>Inlet Run 1</i>	<i>Inlet Run 2</i>	<i>Inlet Run 3</i>	<i>AVERAGE Runs 1-3</i>	<i>AVERAGE Runs 2-3</i>
Sampling Location		Duct	Duct	Duct		
Date		04/22/96	04/22/96	04/22/96		
Stack Gas Flow Rate *	scf/hr	94,200	94,200	94,200		
TGNMO (as methane)	ppm	3700	3700	3900	2825	2533
Total VOC Emission Rate	lbs/hr	14.47	14.47	15.26	14.73	14.86
Total VOC Emission Rate	tons/yr	63.39	63.39	66.82	64.54	65.11

* - data taken from BFI Inlet Velocity Meter

<i>Parameter</i>	<i>Units</i>	<i>Outlet Run 1</i>	<i>Outlet Run 2</i>	<i>Outlet Run 3</i>	<i>AVERAGE Runs 1-3</i>	<i>AVERAGE Runs 2-3</i>
Sampling Location		Stack	Stack	Stack		
Date		04/22/96	04/22/96	04/22/96		
O2 Concentration	% dry	12.94	13.48	12.68		
Stack Gas Flow Rate *	dscf/hr	1,401,540	1,185,960	1,286,400		
TGNMO (as methane)	ppm	82.00	19.00	20.00	40.33	19.50
Total VOC Emission Rate	lbs/hr	4.77	0.94	1.07	2.26	1.00
Total VOC Emission Rate	tons/yr	20.90	4.10	4.68	9.89	4.39
Total VOC Emission Rate	lbs/MMBtu	0.0852	0.0211	0.0200	0.0421	0.0206

* - data taken from HCl/PM train sampling parameters

DESTRUCTION AND REMOVAL EFFICIENCY	67.03%	93.53%	93.00%	84.52%	93.27%
---	---------------	---------------	---------------	---------------	---------------

TAB2-1.WK4

**TABLE 2-4. BFGSI - HALIFAX, MA
VOC (as Hexane) EMISSION SUMMARY @ 1550°F**

<i>Parameter</i>	<i>Units</i>	<i>Inlet Run 1</i>	<i>Inlet Run 2</i>	<i>Inlet Run 3</i>	<i>AVERAGE Runs 1-3</i>	<i>AVERAGE Runs 2-3</i>
Sampling Location		Duct	Duct	Duct		
Date		04/22/96	04/22/96	04/22/96		
Stack Gas Flow Rate *	scf/hr	94,200	94,200	94,200		
TGNMO (as hexane)	ppm	617	617	650	628	633
Total VOC Emission Rate	lbs/hr	12.99	12.99	13.70	13.23	13.34
Total VOC Emission Rate	tons/yr	56.91	56.91	59.99	57.93	58.45

* - data taken from BFI Inlet Velocity Meter

<i>Parameter</i>	<i>Units</i>	<i>Outlet Run 1</i>	<i>Outlet Run 2</i>	<i>Outlet Run 3</i>	<i>AVERAGE Runs 1-3</i>	<i>AVERAGE Runs 2-3</i>
Sampling Location		Stack	Stack	Stack		
Date		04/22/96	04/22/96	04/22/96		
O2 Concentration	% dry	12.94	13.48	12.68		
Stack Gas Flow Rate *	dscf/hr	1,401,540	1,185,960	1,286,400		
TGNMO (as hexane)	ppm	13.67	3.17	3.33	6.72	3.25
TGNMO (as hexane) at 3% O2	ppm	30.73	7.64	7.26	15.21	7.45
Total VOC Emission Rate	lbs/hr	4.28	0.84	0.96	2.03	0.90
Total VOC Emission Rate	tons/yr	18.77	3.68	4.20	8.88	3.94
Total VOC Emission Rate	lbs/MMBtu	0.0764	0.0189	0.0180	0.0378	0.0185

* - data taken from moisture train sampling parameters

DESTRUCTION AND REMOVAL EFFICIENCY	67.03%	93.53%	93.00%	84.52%	93.27%
---	---------------	---------------	---------------	---------------	---------------

Proposed VOC Limits: Outlet concentration of 20 ppmvd at 3% O2 and 98% DRE

TAB2-4WK4

**TABLE 2-5. BFGSI - HALIFAX, MA
HYDROGEN SULFIDE EMISSION SUMMARY @ 1550°F**

<i>Parameter</i>	<i>Units</i>	<i>Inlet Run 1</i>	<i>Inlet Run 2</i>	<i>Inlet Run 3</i>	<i>AVERAGE</i>
Sampling Location		Duct	Duct	Duct	
Date		04/22/96	04/22/96	04/22/96	
Stack Gas Flow Rate *	scf/hr	94,200	94,200	94,200	
Hydrogen Sulfide	ppm	21.10	22.20	21.80	21.70
H2S Emission Rate	lbs/hr	0.1857	0.1954	0.1919	0.1910
H2S Emission Rate	tons/yr	0.8134	0.8558	0.8404	0.8365

* - data taken from BFI Inlet Velocity Meter

<i>Parameter</i>	<i>Units</i>	<i>Outlet Run 1</i>	<i>Outlet Run 2</i>	<i>Outlet Run 3</i>	<i>AVERAGE</i>
Sampling Location		Stack	Stack	Stack	
Date		04/22/96	04/22/96	04/22/96	
O2 Concentration	% dry	12.94	13.48	12.68	
Stack Gas Flow Rate *	dscf/hr	1,401,540	1,185,960	1,286,400	
Hydrogen Sulfide	ppm	0.000	0.000	0.000	0.000
H2S Emission Rate	lbs/hr	0.0000	0.0000	0.0000	0.0000
H2S Emission Rate	tons/yr	0.0000	0.0000	0.0000	0.0000
H2S Emission Rate	lbs/MMBtu	0.000000	0.000000	0.000000	0.000000

* - data taken from HCl/PM train sampling parameters

DESTRUCTION AND REMOVAL EFFICIENCY	100.00%	100.00%	100.00%	100.00%
---	----------------	----------------	----------------	----------------

TAB2-SWK4

**TABLE 2-6. BFGSI - HALIFAX, MA
CEM EMISSIONS SUMMARY @ 1550°F**

DATE	RUN #	TIME	TEST CONDITION (°F)	FLOW RATE (dscfm)	O2 (%)	CO2 (%)	NOx (ppm)	CO (ppm)	SO2 (ppm)
04/22/96	1	12:22 - 13:30	1550	23,359	12.94	7.46	11	10	0.48
04/22/96	2	14:30 - 15:30	1550	19,766	13.48	7.24	11	21	0.41
04/22/96	3	17:25 - 18:25	1550	21,440	12.68	7.84	11	13	0.00
AVERAGE				21,522	13.03	7.51	11	15	0.30

11

RUN #	EMISSION RATE								
	NOx (lbs/hr)	NOx (tons/yr)	NOx (lbs/MMBtu)	CO (lbs/hr)	CO (tons/yr)	CO (lbs/MMBtu)	SO2 (lbs/hr)	SO2 (tons/yr)	SO2 (lbs/MMBtu)
1	1.84	8.06	0.033	1.02	4.46	0.018	0.11	0.49	0.002
2	1.56	6.82	0.035	1.81	7.93	0.041	0.08	0.35	0.002
3	1.69	7.40	0.032	1.22	5.32	0.023	0.00	0.00	0.000
AVERAGE	1.70	7.43	0.033	1.35	5.90	0.027	0.06	0.28	0.001

**TABLE 2-7. BFGSI - HALIFAX, MA
CEM EMISSIONS SUMMARY @ 1950°F**

DATE	RUN #	TIME	TEST CONDITION (°F)	FLOW RATE (dscfm)	O2 (%)	CO2 (%)	NOx (ppm)	CO (ppm)	SO2 (ppm)
04/19/96	1	11:50 - 12:50	1950	12,184	9.78	10.02	25	0	1.29
04/19/96	2	13:25 - 14:25	1950	14,521	10.18	9.64	24	0	0.00
04/19/96	3	15:10 - 16:10	1950	14,753	10.19	9.80	24	0	1.97
AVERAGE				13,819	10.05	9.82	24	0	1.09

12

RUN #	EMISSION RATE								
	NOx (lbs/hr)	NOx (tons/yr)	NOx (lbs/MMBtu) ¹	CO (lbs/hr)	CO (tons/yr)	CO (lbs/MMBtu) ¹	SO2 (lbs/hr)	SO2 (tons/yr)	SO2 (lbs/MMBtu) ¹
1	2.18	9.56	0.053	0.00	0.00	0.000	0.16	0.69	0.004
2	2.50	10.93	0.053	0.00	0.00	0.000	0.00	0.00	0.000
3	2.54	11.11	0.053	0.00	0.00	0.000	0.29	1.27	0.006
AVERAGE	2.40	10.53	0.053	0.00	0.00	0.000	0.15	0.65	0.003

¹ = 9501 dscf/MMBtu - F-Factor Average from 1550° Test condition Used

SECTION 3 PROCESS DESCRIPTION

3.1 INTRODUCTION

The landfill gas collection system consists of gas extraction wells which are spaced across the surface of the landfill. The wells are interconnected by a subsurface manifold system which traverses the landfill. Each landfill gas extraction well is outfitted with a valve allowing the flow of gas to be individually controlled. In addition, each well is equipped with a sampling port enabling the well to be monitored for methane content, temperature, vacuum, and flow rate.

The landfill gas collection system is equipped with two Lamson Corporation, Model No. 854-GB centrifugal blowers, each capable of handling 5120.9 acfm of landfill gas at a static pressure of 18 inches of water. The two blowers were installed in parallel, with one operating as the systems' primary blower, and the other acting as standby. Prior to the blowers, the landfill gas will pass through a condensate knockout vessel. After passing through the blowers, the landfill gas will proceed through a flame arrestor to the enclosed flare system.

The enclosed flare system is a John Zink Company enclosed flare having an energy input rating of 120.08×10^6 Btu per hour when burning landfill gas at a maximum rate of 5120.9 acfm. The flare has an effective chamber length of 31.04 feet from top of the flame assembly to thermocouple resulting in an effective chamber volume of 2258.5 cubic feet. The flare will provide a minimum residence time of 0.50 seconds at the 1600°F, 1750°F, and 1800°F operating temperature ranges, as measured from top of the flame assembly to the thermocouple. The flare is capable of operating in a manual or automatic mode. Propane gas is utilized to fire the flare pilot light during start up.

Emissions from the flare are exhausted through a carbon steel stack which is 40.0 feet above ground level and has an inside exit diameter of 9.6 feet, providing a stack gas exit velocity of 62.44 feet per second at 1400°F. Figure 3-1 presents a schematic of the landfill flare system.




Figure 3-1. BFGSI Enclosed Flare System.

3.2 OPERATING CONDITIONS

The enclosed flare system was tested at two operating temperatures, 1550°F and 1950°F. It was agreed upon, and with the approval of the MADEP, that the emission rates for HCl and particulate be determined at the operating temperature of 1550°F. Only the emission rates for SO₂, NO_x, and CO were determined at the operating temperature of 1950°F.

The inlet flowrate and outlet stack temperature were recorded at the control board using a Honeywell Truline circular strip chart. The strip chart measures inlet flow in scf/min and outlet temperature in degree fahrenheit.

3.3 SAMPLING LOCATIONS


3.3.1 Inlet Sampling Location

The landfill flare has an inlet duct diameter of 12 inches. At this location integrated flue gas samples were collected. Access into the duct work was through a one-inch opening.

Samples were collected for the following:

- Methane and total non methane organics
- Total reduced sulfur and hydrogen sulfide
- O₂, CO₂, CO
- Btu value
- Inlet landfill gas flow rate.

The inlet sampling location is illustrated in Figure 3-2.



Point	Percent of Stack Diameter	Distance from Wall (in.)
1	2.1	2.39
2	6.7	7.64
3	11.8	13.45
4	17.7	20.18
5	25.0	28.50
6	35.6	40.58

Figure 3-2. Stack Sampling Location and Traverse Points.

3.3.2 Outlet Sampling Location

The flare system has an exhaust stack of approximately 40 feet in height. The stack diameter is 9.6 feet. Sampling ports are located approximately 33.69 feet above grade. Four sampling ports accessed for the collection and quantification of the target parameters are located 90° to each other.

Samples were collected for the following:

- HCl and particulate
- Total reduced sulfur and hydrogen sulfide
- Methane and non methane organics
- O₂, CO₂, SO₂, NO_x and CO
- Velocity and % moisture.

The outlet sampling location and traverse points are illustrated in Figure 3-2.

SECTION 4 SAMPLING PROCEDURES

4.1 OVERVIEW

This section describes the procedures TRC followed during the field sampling program on April 19 and 22, 1996. Throughout the program TRC followed EPA Reference Methods 40 CFR Part 60 Appendix A and/or Massachusetts approved sampling protocols. Any deviations from the specified test methods were approved by the MADEP observer and documented in this final report.

The remainder of this section is divided into several subsections: Field Program Description, Presampling Activities and Onsite Sampling Activities.

4.2 FIELD PROGRAM DESCRIPTION

The field sampling was conducted by TRC over the course of four consecutive days. On the first day equipment was set up and preliminary measurements made. On each subsequent test day, flue gas samples were collected for the parameters listed below.

- April 19 - 1950°F sampling condition
 - outlet location
 - CEM testing for O₂, CO₂, SO₂, NO_x and CO
 - Velocity and % percent moisture
 - inlet location
 - Velocity

- April 22 - 1550°F sampling condition

outlet location

CEM testing for O₂, CO₂, SO₂, NO_x, and CO
 Methane and non methane organics
 Hydrogen Chloride
 Particulate Matter
 Hydrogen sulfide and total reduced sulfur
 Velocity and percent moisture

inlet location

Methane and non methane organics
 Hydrogen sulfide and total reduced sulfur
 O₂, CO₂, and CO
 Btu value
 Velocity

The test methods utilized in accordance with 40 CFR Part 60 Appendix A are as follows:

- Method 1 and 2 - Velocity Profile
- Method 3A - O₂ and CO₂ determination
- Method 4 - Percent Moisture
- Method 6C - SO₂ determination
- Method 7E - NO_x determination
- Method 10 - CO determination
- Method 18 - Total Reduced Sulfur and Hydrogen Sulfide determination
- Method 25C - Oxygen, Carbon Dioxide, Carbon Monoxide, Methane, Non-Methane Organics, and Btu content determination
- Method 0050 - HCl/Particulate determination

TRC utilized a four person test team to complete the above test methods.

4.3 PRESAMPLING ACTIVITIES

Presampling activities include equipment calibration, precleaning of the sample train glassware, and other miscellaneous tasks. Each of these activities are described or referenced in the following subsections. Other presampling activities included team meetings, equipment packing, and finalization of all details leading up to the coordinated initiation of the sampling program.

4.3.1 Equipment Calibration

TRC follows an orderly program of positive actions to prevent the failure of equipment or instruments during use. This preventative maintenance and careful calibration helps to ensure accurate measurements from field and laboratory instruments.

Once the equipment has gone through the cleaning and repair process it is then calibrated. All equipment that is scheduled for field use is cleaned and checked prior to calibration. Once the equipment has been calibrated, it is packed and stored to ensure the integrity of the equipment. An adequate supply of spare parts is taken in the field to minimize downtime from equipment failure.

Inspection and calibration of the equipment is a crucial step in ensuring the successful completion of the field effort. All equipment is inspected for proper operation and durability prior to calibration. Calibration of the following equipment was conducted in accordance with the procedures outlined in EPA documents entitled "*Quality Assurance Handbook for Air Pollution Measurement Systems; Volume III - Stationary Source Specific Methods*" (EPA-600/4-77-027b) and 40 CFR Part 60 Appendix A. All calibrations were performed prior to test program.

- Probe Nozzles (QA Handbook, Vol III, Section 3.4.2, pp. 19) - average three ID measurements of nozzle; difference between high and low ≤ 0.1 mm. Recalibrate, reshape and sharpen when nozzle becomes nicked, dented, or corroded.

- Pitot tubes (QA Handbook, Vol III, Section 3.1.2, pp. 1-13) - measured for appropriate spacing and dimensions or calibrated in a wind tunnel. Rejection criteria given on the calibration sheet. Post-test check - inspect for damage.
- Thermocouples (QA Handbook, Vol III, Section 3.4.2, pp. 12-18) - verified against a mercury-in-glass thermometer at three points including the anticipated measurement range. Acceptance limits - impinger $\pm 2^{\circ}\text{F}$; DGM $\pm 5.4^{\circ}\text{F}$; stack ± 1.5 percent of stack temperature.
- Dry gas meters (EPA 40 CFR Part 60, Method 5, Section 5.3) - calibrated against a wet test meter. Acceptance criteria - pretest $Y_i = Y = \pm 0.02$; post test $Y = \pm 0.05 Y_i$.
- Analytical balances (QA Handbook, Vol III, Section 3.4.2, pp. 19) - Acceptance criteria - calibrate with Standard Class-S weights within ± 0.5 g of stated value. Rejection criteria: Have manufacturer recalibrate or adjust.

4.3.2 Glassware Preparation

Sample train glassware and sample containers required specialized precleaning to avoid contamination of the sample from the collection container or devices. The sample train glassware necessary for the Method 0050 hydrogen chloride/particulate sampling was precleaned using analconox soap and water wash. Deionized water was used for rinsing followed by air drying. The glassware was then sealed with parafilm.

Note that all amber sample bottle caps used were fitted with Teflon[®] liners which are cleaned in the same manner as the bottles themselves.

4.3.3 Sample Media Preparation

All reagents were checked in accordance with TRC's existing QC Program to minimize the probability of using contaminated solvents. This includes the use of spectro-grade solvents from the same lot and the collection and analysis of the appropriate blanks.

4.3.4 Continuous Emissions Monitoring

TRC conducted continuous emissions monitoring at the outlet stack for oxygen (EPA Method 3A), carbon dioxide (EPA Method 3A), sulfur dioxide (EPA Method 6C), oxides of nitrogen (EPA Method 7E), and carbon monoxide (EPA Method 10) during all test conditions. TRC followed procedures outlined in the EPA Publication 340/1-83-016 regarding setup and operation of its Transportable Continuous Emissions Monitoring System (TCEMS).

The TCEMS consists of three subsystems: sample acquisition/conditioning, sample analysis, and a data acquisition system. Sample acquisition/conditioning is designed to deliver a representative sample of the stack gas stream to the sample analysis subsystem.

In each case, accurate interpretation of analyzer response required the systematic calibration of the instrument against gases of known concentrations.

The data acquisition subsystem consists of a Yokogawa digital data logger designed to receive and log instrument signals (raw voltages) at user defined intervals. The resulting values are instantaneously accessible (updated every 15 seconds). Once the system was set up, the TCEM was connected to a power source and brought online. Sample line and signal wires are strung between the sampling and TCEM locations, and the probe was placed in the duct at the sampling port.

Prior to insertion of the probe into the stack, the sample/acquisition system was leak checked by the following procedure:

- a. plug probe;
- b. observe that flow in rotameter reaches zero Lpm;
- c. observe vacuum; and
- d. confirm that sample vacuum during sampling does not exceed vacuum attained during leak check.

The initial phase of instrumental analysis methods requires calibration of all involved monitors. At the beginning of each day, direct instrument calibrations for zero and upscale gases were performed prior to initiation of testing by direct calibration gas injection. Following these direct calibrations, system calibrations were performed both prior to and following each run using zero and one upscale gas concentration. This was accomplished by directing calibration gas through the sample line and conditioning system to assess system bias. Following completion of the required runs, final system calibrations were performed. These procedures allow for determination of initial and final system bias, as well as system drift. The calibration gas values and instrument range settings used on the landfill flare system are listed below:

Analyzer	Range	Conc.	High	Mid	Low	Zero
NO _x	0 - 300	ppm	225	180	NA	air
CO	0 - 300	ppm	278	120.0	62.0	air
SO ₂	0 - 150	ppm	123	84.6	NA	air
CO ₂	0 - 20	%	19.8	10.1	5.05	air
O ₂	0 - 25	%	22.3	10.2	5.05	nitrogen

Calibration gases used were EPA Protocol 1, traceable to the National Bureau of Standards Reference Materials. The measurement system performance specifications in 40 CFR 60 Appendix A Methods 3A, 6C, and 7E are listed below and was the performance criteria for this program.

Procedure	Performance Criteria			
	NO _x M7E	SO ₂ M6C	CO M10	O ₂ /CO ₂ M3A
Zero Drift, % of range	< ± 3	< ± 3	< ± 3	< ± 3
Calibration Drift, % of range	< ± 3	< ± 3	< ± 3	< ± 3
Response time, seconds	< 60	< 60	< 90	< 60

Procedure	Performance Criteria			
	NO _x M7E	SO ₂ M6C	CO M10	O ₂ /CO ₂ M3A
Interference Response, % of range	< ± 2	< ± 2	1,000:1 CO ₂	< ± 2
NO ₂ to NO Converter, % efficiency	> 98	NA	NA	NA
Calibration Error, % of cal gas	< ± 2	< ± 2	< ± 2	< ± 2

4.3.5 NO₂ to NO Conversion Efficiency

Before mobilizing for the field portion of this program, the NO₂ to NO converter was checked in the following manner. A mid-level NO gas was introduced into a 30 liter tedlar bag and diluted one-to-one (1:1) with air. The bag was then hooked up to the sampling system and drawn through the system for 30 minutes. The highest peak response remained for the entire thirty minutes. A decrease was less than 2 percent of the highest peak value.

4.4 ONSITE SAMPLING ACTIVITIES

Onsite sampling activities included the emissions testing of the inlet duct and outlet stack, and collection of operational data.

4.4.1 Velocity Measurements/Cyclonic Flow

For the determination of velocity at the inlet to the flare, TRC used BFI's volume meter utilizing EPA Reference Method 2B (40 CFR 60 Appendix A). This methods refers to Method 2A which requires the installation of a volume meter, and the measurement of organic carbon, CO and CO₂ concentrations. For the determination of volumetric measurements BFI has a volume meter installed in the inlet duct. This meter was calibrated prior to the start of the test program.

Velocity traverses were conducted at the outlet sampling location with an S-type pitot assembly in

accordance with EPA Reference Methods 1 and 2. An S-type pitot tube with an attached inclined manometer was used to measure the exhaust velocities. An attached Type-K thermocouple with remote digital display was used to determine the flue gas temperature. During the preliminary and compliance test programs, velocity measurements were conducted during each test run. The required number of velocity measurements points for each sampling location was determined following EPA Method 1.

A cyclonic flow check was conducted at the outlet stack prior to sampling in accordance with Section 2.4 of EPA Method 1. This procedure is referred to as the nulling technique. An S-type pitot tube connected to an inclined manometer was used in this method. The pitot tube was positioned at each traverse point so that the face openings of the pitot tube are perpendicular to the stack cross-sectional plane. This position is called the "0° reference". The velocity pressure (ΔP) measurement was noted. If the ΔP reading is zero, the cyclonic angle was recorded as 0°. If the ΔP reading is not zero, the pitot tube was rotated clockwise or counter clockwise until the ΔP reading became zero. This angle was then measured with a leveled protractor and reported to the nearest degree. After this null technique was applied at each traverse point, the average of the cyclonic angles was calculated. The average was less than 20°.

4.4.2 Hydrogen Chloride/Particulate Matter

The Hydrogen Chloride/Particulate Matter train was operated as described in "*Measurement of HCl and Cl₂ (Method 0050)*" (EPA Methods Manual for Compliance with the BIF Regulations, EPA/530-SW-91-010, December 1990). The Method 0050 train was used to measure and determine the emission rate of Hydrogen Chloride and Particulate Matter from the outlet stack location only.

This sampling train used a air-cooled, quartz-lined probe, with a quartz button-hook nozzle due to the high temperature of the outlet stack. A thermocouple and S-type pitot tube were attached to the probe for the measurement of gas temperature and velocity. The sample gas passes through the probe assembly to a heated quartz fiber filter. The filter holder was maintained at 248°F ±

25°F throughout each test period. Downstream of the heated filter, the gas passed through a series of four ice-cooled impingers kept below 68°F to enable condensation of entrained moisture. The first two impingers each contained 100 mL of 0.1N H₂SO₄. The third and fourth impingers each contained 100 mL of 0.1N NaOH. The fifth impinger contained a preweighed amount of silica gel. The impingers were followed by a Nutech Model 2010 dry gas meter, pump, and calibrated orifice meter.

TRC conducted three Method 0050 runs at the 1550° test condition. Each test run had a sample duration of 72 minutes to ensure the collection of at least 45 cubic feet of sample gas.

Sampling was conducted while traversing the Method 0050 train across two diameters which satisfied the criteria for minimum number of sampling points. At each test point within the stack, all necessary train parameters were measured.

Sampling was isokinetic (± 10 percent) with readings of flue gas parameters recorded at every sampling point during the traverse. In the event where steady operation was not maintained, or there were atypical fluctuations in monitored gas parameters (O₂, CO₂), the testing was stopped until these conditions were stabilized. Steady operation of the unit was the responsibility of BFI personnel. A TRC team member was in contact with BFI and to relay any process related difficulties to the sampling crew.

Leak checks of the entire Method 0050 sampling train were performed before and after each sampling run. All leak checks and leakage rates are documented on the relevant field test data sheet. The acceptance criteria for the Method 0050 train is a leak rate of ≤ 0.02 cfm at the highest vacuum obtained during the run.

Following the completion of each test run, the Method 0050 train was transported to TRC's sample recovery lab. The sample recovery sequence was as follows:

- Removed the sampling train to the recovery area.

- Noted the condition of the train (i.e., filter condition, impinger contents color, silica gel color, etc.).
- Disassembled the filter housing and transferred the filter to its original petri dish. Sealed the container with Teflon[®] tape and labeled it with the appropriate sample information.
- The front half of the train, nozzle, probe, and front-half filter housing, were brush-rinsed with acetone into an amber glass container with a Teflon[®]-lined cap. The rinse procedure was performed three times after which the container was sealed and labeled.
- The contents of the first two impingers were measured for volume and transferred to a glass amber container with a Teflon[®]-lined cap. The impingers, right angle, and U-tubes were rinsed three times with distilled deionized water into the sample container. The container was then sealed and labeled.
- The contents of the third and fourth impingers were measured for volume and transferred to a glass amber container with a Teflon[®]-lined cap. The impingers, right angle, and U-tubes were rinsed three times with distilled deionized water into the sample container. The container was then sealed and labeled.
- The silica gel was returned to its original container and weighed to obtain a final weight.
- All containers were checked to ensure proper sealing, proper labeling, and that all liquid levels were marked. All samples were then logged onto the chain-of-custody record.

The Method 0050 train resulted in the following samples:

- Filter
- Front-Half Acetone Rinse
- 0.1N H₂SO₄ Impinger Catch
- 0.1N NaOH Impinger Catch

The 0.1N H₂SO₄ impinger catches (impingers 1, 2, and 3) were used to determine hydrogen chloride and moisture.

4.4.3 Methane and Non-Methane Organics

Inlet and outlet flue gas samples were collected for methane and non-methane organics utilizing EPA Method 25C, "*Determination of Nonmethane Organic Compounds (NMOC) in MSW*"

Landfill Gases". TRC collected samples from the inlet and outlet by drawing the flue gas through a sampling train comprised of components that regulate the rate and duration of sampling into a pre-evacuated SUMMA passivated canister. Samples were collected over a 1-hour time frame using a pressurized canister. After the flue gas sample was collected, the canister valve was closed.

These SUMMA canisters were shipped via Federal Express overnight delivery to the laboratory and analyzed by gas chromatograph/flame ionization detector (GC/FID) according to EPA Method 25C.

4.4.4 Oxygen, Carbon Dioxide, Carbon Monoxide

Inlet flue gas samples were collected for oxygen, nitrogen, and carbon dioxide utilizing EPA Method 25C, "*Determination of Nonmethane Organic Compounds (NMOC) in MSW Landfill Gases*". TRC collected samples from the inlet by drawing the flue gas through a sampling train comprised of components that regulate the rate and duration of sampling into a pre-evacuated SUMMA passivated canister. Samples were collected over a 1-hour time frame using a pressurized canister. After the flue gas sample was collected, the canister valve was closed.

These SUMMA canisters were shipped via Federal Express overnight delivery to the laboratory and analyzed by gas chromatograph/thermal conductivity detector (GC/TCD) according to EPA Method 25C.

4.4.5 Hydrogen Sulfide and Total Reduced Sulfur (TRS)

Inlet and outlet flue gas samples were collected for Hydrogen Sulfide and Total Reduced Sulfur (TRS) utilizing EPA Method 18, "*Measurement of Gaseous Organic Compound Emissions by Gas Chromatography*". TRC collected an integrated air sample using the bag-in-drum technique. In this procedure, a Tedlar bag was placed inside a rigid container. The bag was then evacuated

and attached to a ¼-inch Teflon[®] sample line which was attached to a stainless steel probe. The sample line was then purged with flue gas and then the rigid container placed under a slight vacuum. To equalize the pressure in the container, flue gas was drawn through the sample line into the Tedlar bag. Sampling was conducted at an approximate rate of 0.35 liters per minute (LPM) for 60 minutes to yield a total sample volume of about 21 liters. These Tedlar bag samples were shipped via Federal Express overnight delivery to the laboratory and analyzed by gas chromatography/flame photometric detection (GC/FPD).

4.4.6 Continuous Emissions Monitoring for O₂, CO₂, SO₂, NO_x, and CO

TRC conducted continuous emissions monitoring at the outlet location for oxygen (EPA Method 3A), carbon dioxide (EPA Method 3A), sulfur dioxide (EPA Method 6C), oxides of nitrogen (EPA Method 7E), and carbon monoxide (EPA Method 10) during all test runs. Measurements were performed continuously for a minimum of four hours of operation concurrently with the Method 0050 tests. Single point sampling was conducted.

The sampling train started with an inconel sampling probe and heated filter box. The sample stream was then drawn through 100 feet of heated (248°F ± 25°F) Teflon[®] sample line and a sample conditioner to remove the moisture from the gas stream. The sample was then drawn through Teflon[®] tubing by a leak-free Teflon[®] double diaphragm pump to a stainless-steel sample manifold with an atmospheric by-pass rotometer. The O₂, CO₂, SO₂, NO_x, and CO analyzers withdrew samples from this manifold.

All CEM data was recorded as averages by a Yokogawa digital data logger designed to receive and log instrument signals. The results were expressed in ppm and lbs/hr for SO₂, NO_x, and CO; and in percent for O₂ and CO₂.

SECTION 5 ANALYTICAL PROCEDURES

This section delineates the analytical procedures used to analyze samples during the BFGSI Halifax Landfill Test Program. The analysis and quality control protocols for each parameter are summarized below in Sections 5.1 through 5.2.

TRC's analytical subcontractors on this program, Performance Analytical, Inc. (PAI) and Chester LabNet (LAB), were responsible for sample analysis and analytical data reporting. Each were responsible for conducting the analyses in accordance with the analytical methods specified in this section.

5.1 ORGANIC ANALYSIS

5.1.1 Methane and Non-Methane Organics

Methane and Non-Methane organic samples were collected using EPA Method 25C. TRC collected an integrated flue gas sample using a SUMMA canister as previously mentioned in Section 4.4.3. These SUMMA canisters were shipped via Federal Express overnight delivery to Performance Analytical, Inc. The SUMMA canisters were analyzed by GC/FID according to EPA Method 25C.

5.2 INORGANIC ANALYSIS

5.2.1 Hydrogen Chloride

The Hydrogen Chloride/Particulate Matter train was operated as described in "*Measurement of HCl and Cl₂*" (EPA Methods Manual for Compliance with the BIF Regulations, EPA/530-SW-91-010, December 1990). The Method 0050 train was used to measure and determine the emission rate of Hydrogen Chloride. Laboratory analyses was conducted by Chester LabNet.

Gaseous and particulate pollutants were withdrawn from an emission source and collected on a filter, and in absorbing solutions. The quartz-fiber filter collected particulate matter. Acidic absorbing solutions collected gaseous HCl. In the acidified water absorbing solution, the HCl gas is solubilized.

Chloride analysis of stack gas impinger samples will be performed for HCl determination via ion chromatography (IC) using Draft Method 9057 (equivalent to EPA Method 300.0).

5.2.2 Particulate Matter

Particulate sampling was accomplished by following the procedures in EPA Method 5. The sampling of particulate was done with the use of the EPA Method 0050 sampling train. Particulate analysis was conducted by TRC Environmental Corporation.

All filters for the test program were quartz fiber filters. The filters were desiccated to a constant weight, then placed in petri dishes and sealed with Teflon[®] tape. An identification label was initially placed on the petri dish. The beakers used for the dry down of the acetone rinse were cleaned and dried. The beakers were desiccated to a constant weight. Weights were obtained using a Mettler AE200 analytical balance. Accuracy for the balances was checked by using Class "S" standard weights.

The front-half acetone rinse was dried down in a tared beaker and then desiccated and weighed to a constant weight. The filter was desiccated and weighed to a constant weight. The sum of the net weights for the probe wash and filter catch were used to calculate the concentration of particulate matter in gr/dscf. The emission rate in lbs/hr is also calculated.

5.2.3 Hydrogen Sulfide and Total Reduced Sulfur (TRS)

Hydrogen sulfide and total reduced sulfur compounds samples were collected using EPA Method 18, "*Measurement of Gaseous Organic Compound Emissions by Gas Chromatography*". TRC

collected an integrated air sample using the bag-in-drum technique as previously mentioned in Section 4.4.5. These Tedlar bag samples were shipped via Federal Express overnight delivery to Performance Analytical, Inc. The Tedlar bag samples were analyzed by gas chromatography/flame photometric detection (GC/FPD) using a direct injection technique.

The analysis was performed on a Hewlett-Packard 5890 gas chromatograph. A subambient GC temperature program was utilized for the analysis.

5.3 DRE CALCULATION

In calculating DREs, the following significant figure rules will apply:

- DREs were calculated using two significant figures for the penetration (i.e., DRE are reported to two places to the right of the decimal (e.g., 99.96 percent) if greater than 99.9 percent DRE is demonstrated).
- DREs were not rounded off to demonstrate a final nine unless that final nine is the second digit to the right of the decimal (e.g., a DRE of 99.987 was not rounded to 99.99).
- The equation used to determine DRE is as follows:

$$\text{DRE} = \frac{(W_{\text{in}} - W_{\text{out}})}{W_{\text{in}}} \times 100\%$$

W_{in} = mass feed rate of one compound in the flue gas stream feeding the enclosed flare.

W_{out} = mass emission rate of the same compound present in exhaust emissions prior to release to the atmosphere.

5.4 POUNDS PER MILLION BRITISH THERMAL UNITS CALCULATION

Emission rates are calculated in units of pollutant mass per quantity of heat input (lbs/10⁶Btu) and in order to compute emission rates in terms of pounds per hour (lbs/hr). Lbs/10⁶Btu was

calculated using the pollutant and diluent concentrations and the fuel-specific F-factor based upon the fuel combustion characteristics. The measured concentrations of NO_x, CO, and SO₂ in units of parts per million (ppm) was first converted to mass per unit volume (lbs/scf) for these calculations. The conversion factors for ppm SO₂, ppm NO_x, and ppm CO to SO₂, NO_x, and CO lbs/scf, as stated in Methods 19 and 20 are:

$$\begin{aligned} \text{SO}_2 \text{ lbs/scf} &= \text{ppm SO}_2 \text{ (meas)} \times 1.660 \times 10^{-7} \\ \text{NO}_x \text{ lbs/scf} &= \text{ppm NO}_x \text{ (meas)} \times 1.194 \times 10^{-7} \\ \text{CO lbs/scf} &= \text{ppm CO (meas)} \times 0.727 \times 10^{-7} \end{aligned}$$

Next, the SO₂, NO_x, and CO lbs/scf were converted to a mass emission rate in terms of pounds per million Btu (lbs/10⁶Btu) as follows:

$$E = \text{lbs/scf} \times F_d \times \frac{20.9}{20.9\% - O_{2 \text{ measured}}}$$

where:

E = Mass emission rate of SO₂, NO_x, and CO in terms of lbs/10⁶Btu

F_d = Ratio of the volume of dry effluent gas to the gross caloric value of the as-fired fuel (from Btu value analysis)

5.5 POUNDS PER HOUR CALCULATION

Emission rates in terms of pounds per hour (lbs/hr) were calculated using the pollutant emission rate in terms of parts per million (ppm), outlet stack flowrate, dscfm (Qs), molecular weight of the pollutant (MW), 60 minutes/hour, divided by 385.3 x 10⁶ dscf/lb-mole @ 68°F (20°C).

$$\text{lbs/hr} = \frac{\text{ppm} \times Q_s \times MW \times 60}{385.3 \times 10^6}$$

SECTION 6 QUALITY ASSURANCE

6.1 OVERVIEW

TRC Environmental Corporation management is fully committed to an effective Quality Assurance/Quality Control Program whose objective is the delivery of a quality product. For much of TRC's work, that product is data resulting from field measurements, sampling and analysis activities, engineering assessments, and the analysis of gathered data for planning purposes. The Quality Assurance Program works to provide complete, precise, accurate, representative data in a timely manner for each project, considering both the project's needs and budget constraints. The Corporate QA Director coordinates and directs the overall quality program with strong management support.

TRC's QA Program conforms with EPA recommendations and is directed by the Corporate QA Director, a full-time professional who reports directly to the Company President. This give the QA Director the necessary authority and independence to find and correct any existing quality problems. Division QC Coordinators are responsible for the QC Program within each technical division; they report both to their Division Manager and the Corporate QA Director.

This section highlights the specific QA/QC procedures to be followed on this Test Program. The QA Director has reviewed and approved this Final Report and will attend project review meetings, as needed, to ensure that appropriate QA/QC procedures will be followed.

6.2 FIELD QUALITY CONTROL SUMMARY

6.2.1 Calibration Gases

All calibration gases used to conduct instrument calibrations were prepared in accordance with EPA Protocol 1, and are traceable to National Bureau of Standards Reference Materials.

6.2.2 Instrument Calibrations

All instrument calibrations met the performance criteria defined in 40 CFR 60 Appendix A, Methods 3A, 6C, 7E, and 10.

6.2.3 Calibration Procedures

Calibration of the field sampling equipment was performed prior to the field sampling effort. Copies of the calibration sheets are submitted in the final report. Calibrations were performed as described in the EPA publications "*Quality Assurance Handbook for Air Pollution Measurement Systems; Volume III - Stationary Source Specific Methods*" (EPA-600/4-77-027b) and EPA 40 CFR Part 60 Appendix A. Equipment to be calibrated included the sample metering system, nozzles, thermocouples, and pitot tubes. Copies of the equipment calibration forms can be found in Appendix E.

6.2.4 Equipment Leak Checks

Prior to sampling, each sampling train was leak checked according to the procedures outlined in EPA Reference Method 5. During the course of a test run, a leak checks were conducted before and after every test.

6.2.5 Cyclonic Flow Check

The presence of cyclonic flow within the outlet stack was checked during preliminary traverses prior to sampling, in accordance with Section 2.4 of EPA Method 1 as described in the July 1, 1988 edition of the Federal Register.

6.2.6 Method Blanks

One Method blank for the Method 0050 for HCl and particulate was taken during the field

sampling program. This was to ensure sample quality and integrity.

6.3 SAMPLE CHAIN OF CUSTODY

The chain-of-custody of the samples was initiated and maintained as follows:

- Each sample collected was labeled, sealed, and the liquid level marked on appropriate samples container.
- The samples were then recorded on the sample chain-of-custody form.
- Custody of the samples were retained by TRC until shipment by Federal Express. Upon receipt of the samples at the analytical laboratory, custody was reestablished by the labs' internal custody procedures.

6.4 DATA REDUCTION, VALIDATION, AND REPORTING

Specific QC measures were used to ensure the generation of reliable data from sampling and analysis activities. Proper collection and organization of accurate information followed by clear and concise reporting of the data is a primary goal on all projects.

6.4.1 Field Data Reduction

Appendix A and B of this Final Report presents the field sampling data. The data collected was reviewed in the field by the Field Team Leader.

6.4.2 Laboratory Analysis Data Reduction

Analytical results were reduced to concentration units specified by the analytical procedures, using the equation provided in the analytical procedures. If units are not specified, data from the analysis of gas samples will be reported as $\mu\text{g}/\text{m}^3$. This latter was calculated by dividing the total weight of the substance detected by the volume of gas sampled.

6.4.3 Data Validation

TRC supervisory and QC personnel used validation methods and criteria appropriate to the type of data and the purpose of the measurement. Records of all data was maintained, including that judged to be an "outlying" or spurious value. The persons validating the data have sufficient knowledge of the technical work to identify questionable values.

Field sampling data was validated by the Field Team Leader and/or the Field QC Coordinator based on their review of the adherence to an approved sampling protocol and written sample collection procedure.

Analytical data was validated by the subcontractor laboratory QC or supervisory personnel using criteria outlined below. TRC utilized results from field and laboratory method blanks, replicate samples and internal QC samples to further validate analytical results. Furthermore, TRC QC personnel has reviewed all subcontractor laboratory raw analytical data to verify calculated results presented.

The following criteria was used to evaluate the field sampling data:

- Use of approved test procedures;
- Proper operation of the process being testing;
- Use of properly operating and calibrated equipment;
- Leak checks conducted before and after tests;
- Use of reagents conforming to QC specified criteria;
- Proper chain-of-custody maintained.

The criteria listed below was used to evaluate the analytical data:

- Use of approved analytical procedures;
- Use of properly operating and calibrated instrumentation;

- Acceptable results from analyses of QC samples (i.e., the reported values should fall within the 95 percent confidence interval for these samples).

6.4.4 Data Reporting

All data was reported in standard units depending on the measurement and the ultimate use of the data. The bulk of the data is computer processed and reported as follows:

- Exhaust Gas Streams
 - Gas Properties:
 - a. Moisture, dscf and percent by volume
 - b. Flow rate, dscfm and acfm
 - c. Pressure, mm of Hg
 - d. Temperature, °F
 - Particulate:
 - a. gr/dscf
 - b. gr/acf
 - c. lbs/10⁶Btu
 - d. lbs/hr
 - Hydrogen Chloride
 - a. mg
 - b. ppm
 - c. lbs/10⁶Btu
 - d. lbs/hr
 - Hydrogen Sulfide
 - a. ppm
 - b. lbs/10⁶Btu
 - c. lbs/hr
 - d. tons/yr
 - Gas Pollutants/Diluents
 - a. O₂, percent
 - b. CO₂, percent
 - c. CO, ppmvd, lbs/10⁶Btu, lbs/hr, and tons/yr
 - d. NO_x, ppmvd, lbs/10⁶Btu, lbs/hr, and tons/yr
 - e. SO₂, ppmvd, lbs/10⁶Btu, lbs/hr, and tons/yr
 - f. VOC, ppm, lbs/10⁶Btu, lbs/hr, and tons/yr


6.5 EXCEPTIONS

Prior to and during Run No. 1 on April 22, 1996, the outlet CO concentration exceeded the carbon monoxide instrument calibration range. The occurrence and time frame the range was exceeded was minimal. TRC notified the MADEP and with their approval, made note of the CO exceedance on the CEM chart recorder and continued testing. As the flare system further stabilized, the CO also stabilized. During Runs No. 2 and 3 there were no exceedances of the calibrated range.

APPENDIX A
FIELD SAMPLING DATA SHEETS

Traverse Point Location for Circular and Rectangular Ducts

Project No.: _____
 Client: BFI Halifax
 Date: _____
 Sampling Location: Outlet Stack
 Internal Stack Diameter: 114"
 Nipple Length: NA
 Total Stack Diameter: 114"
 Nearest Upstream Disturbance (C): _____
 Nearest Downstream Disturbance (D): _____
 Calculator: TRC



Traverse Point Number	Traverse Point Location				
	Fraction of Stack ID ($\frac{1}{100}$)	Stack ID	Traverse Point (1 x 2 = Point)	Nipple Length	Traverse Point inside of Far Wall to Outside of Port Nipple (3 x 4 = Point)
1	0.21	114	7.4		
2	0.67	114	7.6		
3	1.13	114	12.9		
4	1.77	114	20.2		
5	2.50	114	28.5		
6	3.56	114	40.6		
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					

Location of Traverse Points in Circular Stacks

	4	6	8	10	12	14	16	18	20	22	24
1	5.7	4.4	3.2	2.3	2.1	1.3	1.5	1.4	1.0	1.1	1.1
2	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.3	3.5	3.2
3	75.0	29.6	19.4	14.3	11.3	9.9	8.5	7.5	5.7	6.0	5.5
4	93.3	70.4	32.3	22.6	17.7	14.5	12.5	10.9	8.7	9.7	7.9
5		85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.9	10.5
6		95.6	80.6	65.3	35.6	26.9	22.0	18.6	16.3	14.9	13.2
7			83.3	77.4	64.4	36.6	23.3	23.5	20.4	18.0	16.1
8			96.3	85.4	75.0	63.4	37.5	29.5	25.0	21.9	19.4
9				91.3	82.1	73.1	62.5	36.2	30.6	26.0	23.0
10				97.4	88.2	79.9	71.7	61.3	35.3	31.9	27.2
11					93.3	85.4	78.0	70.4	61.2	33.0	32.3
12					97.9	90.1	83.1	76.4	69.4	60.7	39.8
13						94.3	87.5	81.2	75.0	66.5	60.2
14						98.2	91.5	85.4	79.9	73.3	67.7
15							95.1	89.1	83.8	78.2	72.3
16							98.4	92.5	87.1	82.0	77.0
17								95.5	90.3	85.4	80.6
18								98.6	93.0	88.4	83.9
19									96.1	91.0	86.3
20									96.7	94.0	89.5
21										96.5	92.1
22										99.3	94.5
23											96.3
24											98.9

Location of Traverse Points in Rectangular Stacks

	2	3	4	5	6	7	8	9	10	11	12
1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.5	5.0	4.5	4.2
2	75.0	50.0	37.5	30.0	25.0	21.4	18.9	15.7	15.0	13.5	12.5
3		83.3	62.5	50.0	41.7	35.7	31.3	27.3	25.0	22.7	20.9
4			87.5	70.0	58.3	50.0	43.3	38.3	35.0	31.3	29.2
5				90.0	75.0	64.3	56.3	50.0	45.0	40.3	37.5
6					91.7	78.6	68.3	61.1	55.0	50.0	45.8
7						92.9	81.3	72.2	65.0	59.1	54.2
8							93.8	83.3	75.0	68.2	62.5
9								94.4	85.0	77.3	70.8
10									95.0	86.4	79.2
11										95.5	87.5
12											95.3

Stack Geometry & Gas Velocity Data


Project No. _____
 Client BFI
 Plant Halifax, MA
 Operator B Kelly
 Meter Box No. 8138

Source Landfill Flare
 Sample Location Outlet Stack
 Run No. 1 Cond. 1950
 Static, In. H₂O -0.08

Time (24 hr. Clock)	Sample Point	Stack Temp. °F or C°	Manom. Reading In. H ₂ O	Cyclonic Flow Null Angle
11:50	1A	1850	0.01	
	2A	1845	0.00	
	3A	1865	0.00	
	4A	1874	0.01	
	5A	1874	0.015	
	6A	1873	0.015	
	1B	1799	0.01	
	2B	1825	0.01	
	3B	1800	0.01	
	4B	1797	0.015	
	5B	1806	0.02	
	6B	1826	0.02	

Sketch of Sampling Location

Stack Diameter 9'6"
 Diameters Upstream _____
 Diameters Downstream _____



Wet Bulb _____
 Dry Bulb _____
 %M _____

Stack Geometry & Gas Velocity Data


Project No. _____
 Client BFI
 Plant Halifax, MA
 Operator B. Kelly
 Meter Box No. 8138

Source Landfill Flare
 Sample Location Outlet static
 Run No. 1 1950
 Static, In. H₂O _____

Time (24 hr. Clock)	Sample Point	Stack Temp. °F or C°	Manom. Reading In. H ₂ O	Cyclonic Flow Null Angle
	1C	1776	0.00	
	2C	1780	0.00	
	3C	1800	0.01	
	4C	1821	0.01	
	5C	1850	0.01	
	6C	1868	0.02	
	1D	1790	0.005	
	2D	1709	0.01	
	3D	1810	0.02	
	4D	1840	0.02	
	5D	1876	0.02	
	6D	1880	0.025	

Sketch of Sampling Location

Stack Diameter 9'6"
 Diameters Upstream _____
 Diameters Downstream _____



Wet Bulb _____
 Dry Bulb _____
 %M _____

Stack Geometry & Gas Velocity Data


Project No. _____
 Client BFI
 Plant Halifax, MA
 Operator B. Kelly
 Meter Box No. 8138

Source Landfill Flare
 Sample Location Outlet Stack
 Run No. 2 1950
 Static, In. H₂O _____

Time (24 hr. Clock)	Sample Point	Stack Temp. °F or C°	Manom. Reading In. H ₂ O	Cyclonic Flow Null Angle
12:48	1A	1828	0.025	0
	2DA	1810	0.025	5
	3DA	1796	0.020	0
	4DA	1793	0.015	5
	5DA	1789	0.010	0
	6DA	1775	0.010	0
	1B	1789	0.010	
	2B	1840	0.010	
	3B	1871	0.020	
	4B	1865	0.020	
	5B	1855	0.025	
	6B	1835	0.030	

Sketch of Sampling Location

Stack Diameter 9'6"
 Diameters Upstream _____
 Diameters Downstream _____



Wet Bulb _____
 Dry Bulb _____
 %M _____

Stack Geometry & Gas Velocity Data

Project No. _____
 Client BFI
 Plant HerliFAx, MA
 Operator B. Kelly
 Meter Box No. 8138

Source Landfill flare
 Sample Location outlet stack
 Run No. 2 1950
 Static, In. H₂O _____

Time (24 hr. Clock)	Sample Point	Stack Temp. °F or C°	Manom. Reading In. H ₂ O	Cyclonic Flow Null Angle
	1B	1820	0.01	
	2B	1836	0.020	
	3B	1850	0.015	
	4B	1855	0.020	
	5B	1837	0.030	
	6B	1821	0.030	
	1D	1800	0.010	
	2D	1820	0.010	
	3D	1850	0.015	
	4D	1865	0.020	
	5D	1859	0.020	
13:07	QHA	1848	0.030	

Sketch of Sampling Location

Stack Diameter _____
 Diameters Upstream _____
 Diameters Downstream _____

Wet Bulb _____
 Dry Bulb _____
 %M _____

Stack Geometry & Gas Velocity Data

Project No. _____
 Client BFI
 Plant Holifax, MA
 Operator P. Kelly
 Meter Box No. _____

Source Landfill Flare
 Sample Location inlet
 Run No. 2
 Static, In. H₂O _____

4/19/96

Sketch of Sampling Location

Stack Diameter _____
 Diameters Upstream _____
 Diameters Downstream _____

Time (24 hr. Clock)	Sample Point	Stack Temp. °F or C°	Manom. Reading In. H ₂ O	Cyclonic Flow Null Angle
	1	98	0.740	
	2		0.350	
	3		0.380	
	4		0.375	
	5		0.360	
	6		0.350	

Wet Bulb _____
 Dry Bulb _____
 %M _____




Isokinetic Flue Gas Sampling Data Sheet

Page 1 of 2

Project No. 20272
 Client BFI
 Facility Halifax, MA
 Source Landfill Flare
 Sample Location Outlet Stack
 Stack Diameter 114"
 Date 4/19/96
 Run No. Half part 1 of PM Run 1
 Operator B. Kelly
 Meter Box No. 8138
 Meter Δ H@ 1.856
 Y Factor 0.98 to .996

Very Important - Fill in All Blanks

Read and Record at the Start of Each Test Point



Sheet 1 of 2.

Train Prepared By Bill Kissel
 Pilot Number and Side _____
 Pilot Tube CP 0.84
 Filter No. / Thimble No. K-31 N/A
 Ambient Temp. °F 55°
 Bar. Pressure, In. Hg 30.01
 Assumed Moisture, % 6
 Heater Box Setting, °F 250°
 Nozzle # / Dia., In. _____
 Probe Length / Material 7' EFF AIR COOLED
 Probe Heater Setting 250°

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C					
	24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
1A	12:08	0	535.898	—	2.0	2.0	68	67	5	—	—	55	—	—	—
	12:13	5	539.511	—	2.0	2.0	68	67	5	—	—	56	—	—	—
	12:18	10	544.911	—	2.0	2.0	70	67	5	—	—	55	—	—	—
	12:23	15	547.211	—	2.0	2.0	70	67	5	—	—	54	—	—	—
	12:28	20	550.211	—	2.0	2.0	71	67	5	—	—	54	—	—	—
	12:33	25	554.211	—	2.0	2.0	71	67	5	—	—	54	—	—	—
↓	12:38	30	558.305	—	—	—	—	—	—	—	—	—	—	—	—

Train Leak Check:

Before Test: _____ CF _____ SEC _____ In. Hg
 After Test: _____ CF _____ SEC _____ In. Hg

Pilot Tube Leak Check F _____ Static Pressure _____
 ORSAT Train Leak Check _____
 In. H₂O _____
 In. Hg _____

Comments:

Leak Rate
 initial 0.005 012 in
 Final 0.001 05 in

Sampling Train Setup and Recovery Sheet

Project No. _____ Run No. 1
 Client BFI Train Type/# HCl / Part Moisture
 Facility Halifax Date 4/19/94
 Source Flare Recovery Person EMU

Filter No. _____
 Thimble No. (if applicable) _____
 XAD Trap No. (if applicable) _____

VOID

lost contacts

#1 Impinger

Moisture

	1	2	3	4
Impinger #	1	2	3	4
Reagent	<u>H₂SO₄</u>	<u>H₂SO₄</u>	_____	<u>NaOH</u>
Final Volume (mLs)	_____	_____	_____	_____
Initial Volume (mLs)	<u>100</u>	<u>100</u>	<u>0</u>	<u>100</u>
Net Collected (g)	_____	_____	_____	_____

Impinger #	<u>5</u>	_____	_____	_____
Reagent	<u>NaOH</u>	_____	_____	_____
Final Volume (mLs)	_____	_____	_____	_____
Initial Volume (mLs)	<u>100</u>	_____	_____	_____
Net Collected (g)	_____	_____	_____	_____

Silica Gel	<u>6</u>	_____	_____	_____
Final Weight (g)	_____	_____	_____	_____
Initial Weight (g)	<u>302.8</u>	_____	_____	_____
Net Collected (g)	_____	_____	_____	_____

Total Moisture (Impingers and Silica Gel) (g) _____


ISOKINETIC Flue Gas Sampling Data Sheet

Page 1 of 2

Project No. _____
 Client BFI
 Facility Halifax, MA
 Source Landfill Flare
 Sample Location outlet stack
 Stack Diameter 9" 1/2"
 Date 4/19/96
 Run No. moister #2
 Operator B Kelly
 Meter Box No. 8138
 Meter Δ H@ 1.856
 Y Factor 0.996

Very Important - Fill in All Blanks

Read and Record at the Start of Each Test Point



Sheet 1 of 1

Train Prepared By ED MacKinnon
 Pilot Number and Side _____
 Pilot Tube CP 0.84
 Filter No. / Thimble No. N/A
 Ambient Temp. °F 67°
 Bar. Pressure., In. Hg _____
 Assumed Moisture, % _____
 Heater Box Setting, °F 250°
 Nozzle # / Dia., In. N/A
 Probe Length / Material 7' EFF Air Cooled
 Probe Heater Setting 250°

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C					
	24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
↓	13:24	0	558.553	—	2.0	2.0	72	70	3	—	—	58	—	—	—
	13:29	5	562.117	—	2.0	2.0	73	70	3	—	—	55	—	—	—
	13:34	10	566.110	—	2.0	2.0	73	70	3	—	—	55	—	—	—
	13:39	15	569.941	—	2.0	2.0	73	70	3	—	—	54	—	—	—
	13:44	20	574.001	—	2.0	2.0	75	70	3	—	—	54	—	—	—
	13:49	25	577.711	—	2.0	2.0	74	70	3	—	—	53	—	—	—
	13:54	30	581.276	—	2.0	2.0				—	—		—	—	—

Train Leak Check:

Before Test: 0.001 CF 60 SEC 12 In. Hg
 After Test: 0.001 CF 60 SEC 3 In. Hg

	I	F		Static Pressure			
Pilot Tube Leak Check	✓		Port	_____	_____	_____	_____
ORSAT Train Leak Check			In. H ₂ O	_____	_____	_____	_____
			In. Hg	_____	_____	_____	_____

Comments:

Leak rate
 initial 0.001 011 in
 Final

Sampling Train Setup and Recovery Sheet

Project No. _____ Run No. 2
 Client BFI Train Type/# HCl/Past Moisture
 Facility Halifax Date 4/19/96
 Source Flare Recovery Person CU

Filter No. _____
 Thimble No. (if applicable) _____
 XAD Trap No. (if applicable) _____

Moisture

Impinger #	_____	_____	_____	_____
Reagent	_____	_____	_____	_____
Final Volume (mLs)	_____	_____	_____	_____
Initial Volume (mLs)	_____	_____	_____	_____
Net Collected (g)	_____	_____	_____	_____

Impinger #	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
Reagent	<u>H₂SO₄</u>	<u>H₂SO₄</u>	<u>NaOH</u>	<u>NaOH</u>
Final Volume (mLs)	<u>138</u>	<u>100</u>	<u>100</u>	<u>100</u>
Initial Volume (mLs)	<u>100</u>	<u>100</u>	<u>100</u>	<u>100</u>
Net Collected (g)	<u>38</u>	<u>0</u>	<u>0</u>	<u>0</u>

Silica Gel	<u>5</u>	_____	_____	_____
Final Weight (g)	<u>270.8</u>	_____	_____	_____
Initial Weight (g)	<u>264.7</u>	_____	_____	_____
Net Collected (g)	<u>6.1</u>	_____	_____	_____

Total Moisture (Impingers and Silica Gel) (g) 44.1


Isokinetic Flue Gas Sampling Data Sheet

Page 1 of 2

Project No. _____
 Client BFGST
 Facility Halifax Landfill
 Source Landfill Flare
 Sample Location Outlet
 Stack Diameter 9.6"
 Date 4/19/94
 Run No. 3 moisture
 Operator B. Kelly
 Meter Box No. 8132
 Meter Δ H@ 1.856
 Y Factor 0.996

Very Important - Fill in All Blanks

Read and Record at the Start of Each Test Point



Sheet _____ of _____

Train Prepared By Ed Mackinnon
 Pilot Number and Side _____
 Pilot Tube CP 0.84
 Filter No. / Thimble No. N/A
 Ambient Temp. °F 67°
 Bar. Pressure., In. Hg 30.01
 Assumed Moisture, % 9%
 Heater Box Setting, °F 250
 Nozzle # / Dia., In. N/A
 Probe Length / Material 7' Eff Air Cooled
 Probe Heater Setting 250

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C					
	24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
1A	14:10	0	581.405	—	2.0	2.0	70	69	2	—	—	55	—	—	—
	14:15	5	585.115	—	2.0	2.0	71	69	2	—	—	56	—	—	—
	14:20	10	586.988	—	2.0	2.0	72	69	2	—	—	54	—	—	—
	14:25	15	592.511	—	2.0	2.0	72	69	2	—	—	53	—	—	—
	14:30	20	596.668	—	2.0	2.0	72	69	2	—	—	53	—	—	—
	14:35	25	600.211	—	2.0	2.0	72	69	2	—	—	53	—	—	—
	14:40	30	604.064	—	2.0	2.0	72	69	2	—	—	53	—	—	—

Comments:

Train Leak Check:

Before Test: 0.003 CF 60 SEC 10 In. Hg
 After Test: 2.000 CF 60 SEC 5 In. Hg

	I	F		Static Pressure
Pilot Tube Leak Check	<input checked="" type="checkbox"/>		Port	_____
ORSAT Train Leak Check			In. H ₂ O	_____
			In. Hg	_____


ISOKINETIC Flue Gas Sampling Data Sheet

Page 1 of 2

Project No. _____
 Client BFI
 Facility Halifax, MA
 Source Landfill Flame
 Sample Location Outlet Stack
 Stack Diameter 9' 6"
 Date 4/19/96
 Run No. Run #1 Moisture
 Operator B. Kelly
 Meter Box No. 8138
 Meter Δ H@ 1.856
 Y Factor 0.996

Very Important - Fill in All Blanks

Read and Record at the Start of Each Test Point



Sheet 1 of 1

Train Prepared By Ed MacKinnon
 Pilot Number and Side NA
 Pilot Tube CP 0.84
 Filter No. / Thimble No. NA
 Ambient Temp. °F 68°
 Bar. Pressure, In. Hg 30.01
 Assumed Moisture, % 9%
 Heater Box Setting, °F 250
 Nozzle # / Dia., In. NA
 Probe Length / Material 7' ECF
 Probe Heater Setting 250

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C					
	15:37 15:24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
1A	15:37	0	604.225	—	2.0	2.0	69	68	2	—	—	57	—	—	—
	15:42	5	608.211	—	2.0	2.0	69	67	2	—	—	55	—	—	—
	15:47	10	617.577	—	2.0	2.0	65	67	2	—	—	55	—	—	—
	15:52	15	615.887	—	2.0	2.0	69	66	2	—	—	54	—	—	—
	15:57	20	618.411	—	2.0	2.0	69	65	2	—	—	54	—	—	—
	16:02	25	622.311	—	2.0	2.0	65	68	2	—	—	53	—	—	—
	16:07	30	626.783	—						—	—		—	—	—
BK	16:07														

Train Leak Check:

Before Test: 0.003 CF 60 SEC 10 In. Hg
 After Test: 0.000 CF 60 SEC 4 In. Hg

Comments:

Sample train was run for 1-hr

	I	F		Static Pressure
Pilot Tube Leak Check	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Port	_____
ORSAT Train Leak Check	<input type="checkbox"/>	<input type="checkbox"/>	In. H ₂ O	_____
			In. Hg	_____

Field Moisture Determination

Client: BFI - Halifax

Project No.: _____

Location: Flare

Date: ~~4/18/96~~ ^{5m} 4/19/96

Run No.: ~~1~~ ~~2~~ 3

Operator: _____

Data

Min	Clock Time	Gas Meter C.F. VM	TM In	TM Out	PM	
					Orifice In. H ₂ O (+)	Vac. Gage In. Hg (-)
0						
5						
10						
15						
20						
25						
30						
Total/Avg						

Impingers

	1	2	3
Final mL	100 <u>182</u>	<u>105</u>	_____
Initial mL	<u>100 mL</u>	<u>100 mL</u>	<u>0</u>
Net mL	<u>82</u>	<u>5</u>	_____
Total moisture (Net mL + Net gm) =	<u>92.2</u>		

Silica Gel

Container No. A
 Final gm 313.8
 Initial gm ~~308.8~~ 308.6
 Net gm 5.2

Calculations

- (1) PB = _____ Meterbox No. _____
- (2) VM Net = _____ Y = DGM Calibration Factor = _____
- (3) TM Avg = _____ TM + 460 _____
- (4) PM Avg = + _____ Orifice In. H₂O x $\frac{1}{13.6}$ = + _____ orifice In. Hg.
 = - _____ Vacuum gage In. Hg (when meter is before pump)
- (5) VMSTD = $\frac{528 \times VM (PB + PM) (Y)}{29.92 \times (TM + 460)}$ = _____
- (6) VW = mL H₂O + gm Silica gel = _____
- (7) VW Gas = VW x 0.04715 = _____
- (8) %M = $\frac{100 \times VW Gas}{VMSTD + VW Gas} = \frac{100 \times (\quad)}{(\quad) + (\quad)} = \frac{(\quad)}{(\quad)} =$ _____


ISOKINETIC Flue Gas Sampling Data Sheet

Page 1 of 2

Project No. _____
 Client BFI
 Facility Halifax, MA
 Source Landfill Flare
 Sample Location outlet stack
 Stack Diameter 9'6"
 Date 4/22/96
 Run No. Cond 1500-HCl-1
 Operator B. Kelly
 Meter Box No. 8138
 Meter Δ H@ 1.856
 Y Factor 0.996

Very Important - Fill in All Blanks

Read and Record at the Start of Each Test Point



Sheet 1 of 2
 Train Prepared By B Kelly
 Pilot Number and Side N/A
 Pilot Tube CP 0.84
 Filter No. / Thimble No. _____
 Ambient Temp. °F 72.0
 Bar. Pressure., In. Hg 30.15
 Assumed Moisture, % 9%
 Heater Box Setting, °F 2500
 Nozzle # / Dia., In. 0.658
 Probe Length / Material 7' GF Quartz
 Probe Heater Setting 2500

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P 5	Orifice Δ H		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C					
	24 - hr	min			BK In. H ₂ O Desired	Actual	Inlet	Outlet		°F °C					
										Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
1A	11:50	0	649.653	0.030	2.40	2.40	80	76	5	1520	250	58	-	242	-
2A	11:53	3	651.477	0.050	2.40	2.40	82	77	5	1545	251	58	-	247	-
3A	11:56	6	654.511	0.040	1.96	1.96	86	79	5	1495	252	57	-	249	-
4A	11:59	9	657.100	0.035	1.71	1.71	89	81	4	1510	255	57	-	249	-
5A	12:02	12	659.000	0.030	1.55	1.55	90	82	4	1400	249	55	-	248	-
6A	12:05	15	661.000	0.030	1.55	1.55	92	84	4	1405	250	55	-	247	-
Stop	12:08	18	663.043	stop run for port change											
1B	12:22	18	663.043	0.06	2.91	2.91	90	88	5	1523	253	56	-	248	-

Train Leak Check:

Before Test: 0.004 CF 60 SEC 12 In. Hg
 After Test: _____ CF 60 SEC _____ In. Hg

	V	F		Static Pressure			
Pilot Tube Leak Check			Port	_____	_____	_____	_____
ORSAT Train Leak Check			In. H ₂ O	_____	_____	_____	_____
			In. Hg	_____	_____	_____	_____

Comments:

0.659 Nozzle
 0.658 Cal
 0.658
 Stop 12:08
 start 12:22

ISO 1500-100 Gas Sampling Data Sheet

Project No. _____
 Client BFI
 Facility Halifax, MA
 Source Landfill Flare

Date 4/22/ Sheet 2 of 2
 Run No. Cond 1500-HC/part-1
 Sample Location outlet stack Operator B. Kelly

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C					
	24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
2B	12:25	21	666.211	0.06	2.89	2.89	92	89	5	1540	256	55	-	251	-
3B	12:28	24	668.425	0.06	2.89	2.89	97	91	5	1531	254	54	-	257	-
4B	12:31	27	671.511	0.05	2.40	2.40	92	89	5	1550	255	53	-	249	-
5B	12:34	30	673.811	0.04	1.94	1.94	92	89	5	1515	251	54	-	247	-
6B	12:37	33	676.431	0.035	1.79	1.79	92	89	3	1425	250	55	-	254	-
stop	12:40	36	678.615	stop run for part change											
1D	12:43	36	678.615	0.05	2.40	2.40	89	85	4	1545	254	56	-	251	-
2D	12:46	39	681.241	0.045	2.18	2.18	92	88	4	1521	256	57	-	249	-
3D	12:49	42	683.211	0.040	1.92	1.92	94	90	4	1550	255	58	-	248	-
4D	12:52	45	686.211	0.040	2.00	2.00	94	90	4	1465	255	57	-	246	-
5D	12:55	48	688.211	0.025	1.26	1.26	91	87	4	1438	256	56	-	249	-
6D	12:58	51	690.001	0.025	1.25	1.25	90	88	4	1460	257	55	-	253	-
stop	13:01	54	691.939	stop run for part change											
1C	13:11	54	691.939	0.05	2.40	2.40	88	87	5	1540	255	56	-	253	-
2C	13:14	57	694.435	0.05	2.40	2.40	91	88	5	1550	250	55	-	256	-
3C	13:17	60	697.211	0.045	2.16	2.16	93	88	5	1550	257	55	-	257	-
4C	13:20	63	699.318	0.045	2.16	2.16	89	85	5	1547	255	55	-	258	-
5C	13:23	66	702.311	0.035	1.70	1.70	90	87	5	1520	256	55	-	257	-
6C	13:26	69	704.131	0.035	1.71	1.71	91	87	5	1500	254	55	-	258	-
END	13:29	72	706.195												
Total															

Meter Leak Check During Test:
 _____ CF _____ SEC _____ In. Hg _____
 _____ CF _____ SEC _____ In. Hg _____
 Static Pressure Port _____
 In. H₂O _____
 In. Hg _____

Comments: stop: 12:40
 start: 12:43
 stop: 13:01
 start 13:11



Sampling Train Setup and Recovery Sheet

Project No. _____ Run No. 1
 Client BFI Train Type/# HCl / Part.
 Facility Halifax Date 4/22/96
 Source Flare Recovery Person CDM

Filter No. K-31
 Thimble No. (if applicable) _____
 XAD Trap No. (if applicable) _____

Moisture	1	2	3	4
Impinger #	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
Reagent	<u>H₂SO₄</u>	<u>H₂SO₄</u>	<u>NaOH</u>	<u>NaOH</u>
Final Volume (mLs)	<u>163</u>	<u>127</u>	<u>107</u>	<u>100</u>
Initial Volume (mLs)	<u>100</u>	<u>100</u>	<u>100</u>	<u>100</u>
Net Collected (g)	<u>63</u>	<u>27</u>	<u>7</u>	<u>0</u>

Impinger #	_____	_____	_____	_____
Reagent	_____	_____	_____	_____
Final Volume (mLs)	_____	_____	_____	_____
Initial Volume (mLs)	_____	_____	_____	_____
Net Collected (g)	_____	_____	_____	_____

Silica Gel	<u>#1</u>	_____	_____	_____
Final Weight (g)	<u>305.9</u>	_____	_____	_____
Initial Weight (g)	<u>293.5</u>	_____	_____	_____
Net Collected (g)	<u>12.4</u>	_____	_____	_____

Total Moisture (Impingers and Silica Gel) (g) 109.4




Isokinetic Flue Gas Sampling Data Sheet

Page 1 of 2

Project No. _____
 Client BFI
 Facility Halifax, MA
 Source Landfill Flare
 Sample Location outlet stack
 Stack Diameter 9'6"
 Date 4/22/96
 Run No. Cond 1500-Hcl/part-2
 Operator B. Kelly
 Meter Box No. 8188
 Meter Δ H@ 1.856
 Y Factor 0.996

Very Important - Fill in All Blanks

Read and Record at the Start of Each Test Point



Sheet 1 of 2
 Train Prepared By Ed MacKinnon

Pilot Number and Side _____
 Pilot Tube CP 0.84
 Filter No. / Thimble No. _____
 Ambient Temp. °F 72
 Bar. Pressure., In. Hg _____
 Assumed Moisture, % 9%
 Heater Box Setting, °F 250°
 Nozzle # / Dia., In. 658
 Probe Length / Material 7' Eff Quartz
 Probe Heater Setting 250°

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C					
	24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
1C	14:30	0	707.162	0.040	1.92	1.92	80	79	3	1540	258	59	-	241	-
2C	14:33	3	709.377	0.040	1.92	1.92	83	80	3	1545	255	59	-	246	-
3C	14:36	6	711.977	0.035	1.68	1.68	83	80	3	1550	251	58	-	245	-
4C	14:39	9	713.587	0.035	1.68	1.68	85	80	3	1547	250	57	-	245	-
5C	14:42	12	715.511	0.030	1.49	1.49	84	80	3	1470	249	57	-	245	-
6C	14:45	15	717.981	0.025	1.29	1.29	85	80	3	1400	249	57	-	252	-
Stop	14:48	18	719.678	Stop run for port change											
				BK											
1D	15:07	18	719.678	0.40	1.94	1.94	84	80	3	1575	249	59	-	255	-
			719.843	0.040											

Comments: stop 1448
start 1507

Train Leak Check:

Before Test: 0.003 CF 60 SEC 10 In. Hg
 After Test: 2.007 CF 60 SEC 5 In. Hg

	I	F	Static Pressure		
Pilot Tube Leak Check	✓		Port	_____	_____
ORSAT Train Leak Check			In. H ₂ O	_____	_____
			In. Hg	_____	_____

Leak Detection and Gas Sampling Data Sheet

Page 2 of 2

Project No. _____
 Client BFI
 Facility Halifax, MA
 Source Landfill flare

Date 4/22/96
 Run No. Cond 1500 - Heli/part - 2
 Sample Location Outlet stack

Sheet 2 of 2
 Operator B. Kelly

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C						
	24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet	
2D	15:10	21	722.415	0.045	2.20	2.20	83	79	4	1550	255	59	-	248	-	
3D	15:13	24	724.557	0.030	1.46	1.46	82	80	3	1520	254	58	-	249	-	
4D	15:16	27	726.711	0.025	1.21	1.21	82	80	3	1520	255	59	-	247	-	
5D	15:19	30	728.457	0.020	0.99	0.99	81	79	3	1485	253	58	-	252	-	
6D	15:22	33	730.251	0.030	1.49	1.49	82	80	3	1483	250	57	-	249	-	
stop	15:25	36			stop run for part change											
1A	15:33	36	732.005	0.030	1.45	1.45	77	76	3	1580	255	58	-	252	-	
2A	15:36	39	734.005	0.030	1.45	1.45	78	77	3	1581	256	59	-	253	-	
3A	15:39	42	736.127	0.020	0.97	0.97	79	76	3	1526	258	57	-	255	-	
4A	15:42	45	737.788	0.020	0.98	0.98	79	76	3	1500	255	56	-	254	-	
5A	15:45	48	739.377	0.020	1.03	1.03	80	76	3	1400	258	55	-	256	-	
6A	15:48	51	740.841	0.020	1.03	1.03	80	76	3	1410	257	54	-	259	-	
stop	15:51	54	742.523		stop run for Root change											
1B	16:02	54	742.516	0.040	1.96	1.96	75	75	3	1550	255	55	-	258	-	
2B	16:05	57	745.111	0.040	1.94	1.94	78	76	3	1575	250	56	-	253	-	
3B	16:08	60	747.411	0.035	1.69	1.69	78	75	3	1583	252	57	-	255	-	
4B	16:11	63	749.251	0.030	1.45	1.45	78	75	3	1584	251	59	-	248	-	
5B	16:14	66	751.377	0.025	1.21	1.21	79	76	3	1521	255	58	-	249	-	
6B	16:17	69	753.311	0.025	1.21	1.21	79	76	3	1520	256	57	-	246	-	
END	16:20	72	754.884													
Total																

Meter Leak Check During Test:

___ CF ___ SEC ___ In. Hg ___
 ___ CF ___ SEC ___ In. Hg ___

Pressure Port ___
 In. H₂O ___
 In. Hg ___

Meter Reading
 Stop ___ Start ___

Comments:

Stop: 15:25
 Start: 15:33
 Stop: 15:51
 Start: 16:02



Sampling Train Setup and Recovery Sheet

Project No. _____ Run No. 2
 Client BFI Train Type/# Part. / HCl
 Facility Halifax Date 4/22/96
 Source Flare Recovery Person cm

Filter No. ~~K-32~~ K-33 _____
 Thimble No. (if applicable) _____
 XAD Trap No. (if applicable) _____

Moisture Impinger #	1	2	3	4
Reagent	<u>H₂SO₄</u>	<u>H₂SO₄</u>	<u>NaOH</u>	<u>NaOH</u>
Final Volume (mLs)	<u>165</u>	<u>105</u>	<u>100</u>	<u>100</u>
Initial Volume (mLs)	<u>100</u>	<u>100</u>	<u>100</u>	<u>100</u>
Net Collected (g)	<u>65</u>	<u>5</u>	<u>0</u>	<u>0</u>

Impinger # _____
 Reagent _____
 Final Volume (mLs) _____
 Initial Volume (mLs) _____
 Net Collected (g) _____

Silica Gel #2 _____
 Final Weight (g) 325.8 _____
 Initial Weight (g) 314.8 _____
 Net Collected (g) 11.0 _____

Total Moisture (Impingers and Silica Gel) (g) 81.0

ISOKINETIC Flue Gas Sampling Data Sheet


Page 1 of 2

Project No. _____
 Client BFI
 Facility Halifax, MA
 Source Landfill Flare
 Sample Location Outlet Stack
 Stack Diameter 9'6"
 Date 4/22/96
 Run No. Cond 1500 - Hcl/Part - 3
 Operator B. Kelly
 Meter Box No. 8138
 Meter Δ H@ 1.856
 Y Factor 0.996

Very Important - Fill in All Blanks

Read and Record at the Start of Each Test Point

Sketch



Sheet 1 of 2

Train Prepared By ED MacKinnon
 Pilot Number and Side A.R Cooled
 Pilot Tube CP 0.84
 Filter No. / Thimble No. _____
 Ambient Temp. °F 70°
 Bar. Pressure, In. Hg 30.15
 Assumed Moisture, % 9%
 Heater Box Setting, °F 250°
 Nozzle # / Dia., In. .658
 Probe Length / Material 7' Eff Quartz
 Probe Heater Setting 250°

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H. In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures (°F) °C					
	24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
1B	1725	0	755.641	.04	1.90	1.90	72	72	3.0	1660	246	45		228	
2B	1728	3	758.200	.04	1.98	1.90	73	73	3.0	1580	247	46		233	
3B	17:31	6	760.260	0.04	1.88	1.88	75	73	3.0	1585	249	47		239	
4B	17:34	9	762.328	0.04	1.88	1.88	75	73	3.0	1587	251	48		247	
5B	17:37	12	764.535	0.035	1.65	1.65	76	73	3.0	1589	250	49		248	
6B	17:40	15	766.621	0.030	1.41	1.41	77	73	3.0	1575	252	49		245	
Stop	1743	18	768.485	Stop run for part change											
1A	1747	18	768.485	0.040	2.01	2.01	75	72	3.0	1456	251	49		246	

Comments: Stop 1743
Start 1747

Train Leak Check:

Before Test: 0.05 CF 60 SEC 12 In. Hg
 After Test: 0.00 CF 60 SEC 6 In. Hg

	I	F	Static Pressure
Pilot Tube Leak Check	✓	✓	Port _____
ORSAT Train Leak Check			In. H ₂ O _____
			In. Hg _____

ISOTHERMIC FINE GAS SAMPLING DATA SHEET

Page 2 of 2

Project No. _____
 Client BET
 Facility Halifax, MA
 Source Landfill Flare

Date 4/22/96 Sheet 2 of 2
 Run No. Cond1500-Hcl/part-3
 Sample Location Outlet Stack Operator B. Kelly

Point	Clock Time		Dry Gas Meter, (ft ³)	Pilot In. H ₂ O Δ P	Orifice Δ H In. H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Temperatures °F °C					
	24 - hr	min			Desired	Actual	Inlet	Outlet		Stack	Filter Box	Imp Temp	XAD Cond	Probe	Filter Outlet
2A	1750	21	770.488	0.040	2.01	2.01	76	72	3	1460	255	49	-	248	-
3A	1753	24	773.311	0.035	1.76	1.76	76	71	3	1464	251	50	-	250	-
4A	1756	27	775.211	0.030	1.49	1.49	76	71	3	1480	250	50	-	248	-
5A	1759	30	777.188	0.025	1.26	1.26	76	70	3	1452	249	50	-	251	-
6A	1802	33	779.688	0.025	1.26	1.26	75	70	3	1450	248	50	-	248	-
stop	1805	36	780.958	STOP Run For Part Change											
1D	1809	36	780.958	0.040	2.01	2.01	70	69	3	1440	247	50	-	248	-
2D	1812	39	783.780	0.040	2.01	2.01	71	69	3	1448	249	51	-	253	-
3D	1815	42	785.599	0.035	1.71	1.71	71	68	3	1500	245	53	-	248	-
4D	1818	45	787.001	0.035	1.71	1.71	72	68	3	1510	249	53	-	246	-
5D	1821	48	789.311	0.030	1.47	1.47	70	68	3	1505	252	55	-	248	-
6D	1824	51	791.511	0.025	1.23	1.23	70	69	3	1495	248	56	-	259	-
stop	1827	54	793.645												
1C	18:31	54	793.645	0.050	2.42	2.42	68	68	3	1530	247	55	-	250	-
2C	18:34	57	796.001	0.040	1.94	1.94	69	67	3	1515	245	56	-	248	-
3C	18:37	60	798.005	0.040	1.94	1.94	69	66	3	1520	249	57	-	248	-
4C	18:40	63	800.411	0.035	1.72	1.72	68	66	3	1500	249	55	-	246	-
5C	18:43	66	802.881	0.035	1.72	1.72	67	66	3	1495	251	54	-	245	-
6C	18:46	69	804.477	0.035	1.72	1.72	67	66	3	1510	250	53	-	244	-
END	18:49	72	807.115												
Total															

Meter Leak Check During Test:

_____ CF _____ SEC _____ In. Hg
 _____ CF _____ SEC _____ In. Hg

Static Pressure

Port _____
 In. H₂O _____
 In. Hg _____

Meter Reading
 Stop _____
 Start _____

Comments:

stop 1805
 start 1809
 stop 1827
 start

Sampling Train Setup and Recovery Sheet

Project No. _____ Run No. 3
 Client BFI Train Type/# Part 1 HCl
 Facility Halifax Date 4/22/96
 Source Flare Recovery Person GM

Filter No. K-34
 Thimble No. (if applicable) _____
 XAD Trap No. (if applicable) _____

Moisture

Impinger #	1	2	3	4
Reagent	<u>H₂SO₄</u>	<u>H₂SO₄</u>	<u>NaOH</u>	<u>NaOH</u>
Final Volume (mLs)	<u>167</u>	<u>119</u>	<u>103</u>	<u>100</u>
Initial Volume (mLs)	<u>100</u>	<u>100</u>	<u>100</u>	<u>100</u>
Net Collected (g)	<u>67</u>	<u>19</u>	<u>3</u>	<u>0</u>

Impinger #	_____	_____	_____	_____
Reagent	_____	_____	_____	_____
Final Volume (mLs)	_____	_____	_____	_____
Initial Volume (mLs)	_____	_____	_____	_____
Net Collected (g)	_____	_____	_____	_____

Silica Gel	_____	_____	_____	_____
Final Weight (g)	<u>311.4</u>	_____	_____	_____
Initial Weight (g)	<u>297.6</u>	_____	_____	_____
Net Collected (g)	<u>13.8</u>	_____	_____	_____

Total Moisture (Impingers and Silica Gel) (g) _____

APPENDIX B
FIELD REDUCED DATA

**BFI Halifax - Outlet Stack
Sampling @ 1950°F Condition**

Run No.	1	2	3	
Date	19-Apr-96	19-Apr-96	19-Apr-96	AVERAGES
Start Time	11:50	13:25	15:10	
Stop Time	12:50	14:25	16:10	
Barometric Pressure, in. Hg	30.01	30.01	30.01	30.01
Net Sampling Time, minutes	30.0	30.0	60.0	40.0
Volume Metered, cf	22.723	22.723	45.214	30.220
Avg. DGM Temp, F	72	72	70	71
AVG Delta H, in of H2O	2.00	2.00	2.00	2.00
AVG Delta H, in of Hg	0.1471	0.1471	0.1471	0.1471
DGM Calibration Factor	0.996	0.996	0.996	0.996
Volume of Gas Collected, dscf	22.654	22.654	45.194	30.168
Total Water Collected, mL	44.1	44.1	92.2	46.9
Volume of Water Vapor, scf	2.079	2.079	4.347	2.835
Moisture, %	8.4	8.4	8.8	8.5
Dry Mole Fraction, 100-%M	0.9159	0.9159	0.9123	0.9147
CO2 at Stack, % dry	10.02	9.64	9.80	9.82
O2 at Stack, % dry	9.78	10.18	10.19	10.05
CO + N2, % dry	80.20	80.18	80.01	80.13
Dry Molecular Weight, lb/lb mole	29.99	29.95	29.98	29.97
Wet Molecular Weight, lb/lb mole	28.99	28.95	28.92	28.95
Excess Air at Stack, %	85.8	92.7	93.2	90.6
Stack Area, sq. in.	10207.0	10207.0	10207.0	10207.0
Static Pressure, in. of H2O	-0.08	-0.08	-0.08	-0.08
Stack Pressure, in. of Hg	30.00	30.00	30.00	30.00
Avg. Stack Temp., F	1828	1826	1816	1823
Avg. Sqrroot of Delta P	0.1160	0.1381	0.1405	0.1316
SDE Average	5.550	6.604	6.704	6.286
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	811	966	981	919
Stack Flowrate, wet acfm	57,482	68,449	69,504	65,145
Stack Flowrate, dry scfm	12,184	14,521	14,753	13,819
EMISSIONS				
NOx, ppm	25	24	24	24
NOx, lbs/MMBtu	0.05	0.05	0.05	0.05
NOx, lbs/hr	2.18	2.50	2.54	2.40
CO, ppm	0	0	0	0
CO, lbs/MMBtu	0.00	0.00	0.00	0.00
CO, lbs/hr	0.00	0.00	0.00	0.00
SO2, ppm	1.29	0.00	1.97	1.09
SO2, lbs/MMBtu	0.00	0.00	0.01	0.00
SO2, lbs/hr	0.16	0.00	0.29	0.15

**BFI Halifax - Inlet Duct
1950°F Condition**

Run No.	1	2	3	
Date	19-Apr-96	19-Apr-96	19-Apr-96	
Start Time	11:50	13:25	16:10	
Stop Time	12:50	14:25	17:10	AVERAGES
Barometric Pressure, in. Hg	30.01	30.01	30.01	30.01
Net Sampling Time, minutes	0.0	0.0	0.0	0.0
Volume Metered, cf	0.000	0.000	0.000	0.000
Avg. DGM Temp, F				0
AVG Delta H, in of H2O				0.00
AVG Delta H, in of Hg	0.0000	0.0000	0.0000	0.0000
DGM Calibration Factor	1.000	1.000	1.000	1.000
Volume of Gas Collected, dscf	0.000	0.000	0.000	0.000
Total Water Collected, mL	0.0	0.0	0.0	46.9
Volume of Water Vapor, scf	0.000	0.000	0.000	0.000
Moisture, %	5.0	5.0	5.0	5.0
Dry Mole Fraction, 100-%M	0.9500	0.9500	0.9500	0.9500
CO2 at Stack, % dry	40.77	40.77	40.77	40.77
O2 at Stack, % dry	1.11	1.11	1.11	1.11
CO + N2, % dry	58.12	58.12	58.12	58.12
Dry Molecular Weight, lb/lb mole	34.57	34.57	34.57	34.57
Wet Molecular Weight, lb/lb mole	33.74	33.74	33.74	33.74
Excess Air at Stack, %	7.8	7.8	7.8	7.8
Stack Area, sq. in. (12 in. ID)	113.1	113.1	113.1	113.1
Static Pressure, in. of H2O	2.00	2.00	2.00	2.00
Stack Pressure, in. of Hg	30.16	30.16	30.16	30.16
Avg. Stack Temp., F	102	98	98	99
Avg. Sqrroot of Delta P	0.6010	0.5992	0.6000	0.6001
SDE Average	14.247	14.154	14.173	14.191
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	1,925	1,912	1,915	1,917
Stack Flowrate, wet acfm	1,512	1,502	1,504	1,506
Stack Flowrate, wet scfm	1,431	1,432	1,434	1,432
Stack Flowrate, dry scfm	1,360	1,361	1,363	1,361

BFI Halifax - Outlet Stack
HCL/PM Sampling Train @ 1550°F Condition

Run No.	1	2	3	
Date	22-Apr-96	22-Apr-96	22-Apr-96	
Start Time	11:50	14:30	17:25	
Stop Time	13:29	16:20	18:49	AVERAGES
Nozzle Diameter, in.	0.658	0.658	0.658	
Barometric Pressure, in. Hg	30.15	30.15	30.15	30.15
Net Sampling Time, minutes	72.0	72.0	72.0	72.0
Volume Metered, cf	56.542	45.760	51.474	51.259
Avg. DGM Temp, F	88	79	71	79
AVG Delta H, in of H2O	2.08	1.49	1.75	1.77
AVG Delta H, in of Hg	0.1530	0.1092	0.1287	0.1303
DGM Calibration Factor	0.996	0.996	0.996	0.996
Volume of Gas Collected, dscf	54.953	45.137	51.592	50.561
Total Water Collected, mL	109.4	81.0	102.8	46.9
Volume of Water Vapor, scf	5.158	3.819	4.847	4.608
Moisture, %	8.6	7.8	8.6	8.3
Dry Mole Fraction, 100-%M	0.9142	0.9220	0.9141	0.9168
CO2 at Stack, % dry	7.46	7.24	7.84	7.51
O2 at Stack, % dry	12.94	13.48	12.68	13.03
CO + N2, % dry	79.60	79.28	79.48	79.45
Dry Molecular Weight, lb/lb mole	29.71	29.70	29.76	29.72
Wet Molecular Weight, lb/lb mole	28.71	28.79	28.75	28.75
Excess Air at Stack, %	160.3	180.9	152.7	164.6
Stack Area, sq. in.	10207.0	10207.0	10207.0	10207.0
Static Pressure, in. of H2O	-0.08	-0.08	-0.08	-0.08
Stack Pressure, in. of Hg	30.14	30.14	30.14	30.14
Avg. Stack Temp., F	1507	1521	1510	1513
Avg. Sqrroot of Delta P	0.2052	0.1730	0.1886	0.1889
SDE Average	9.099	7.701	8.373	8.391
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	1,333	1,127	1,226	1,228
Stack Flowrate, wet acfm	94,477	79,856	86,873	87,069
Stack Flowrate, dry scfm	23,359	19,766	21,440	21,522
Isokinetics, %	98.1	95.2	100.3	98
EMISSIONS				
NOx, ppm	11	11	11	11
NOx, lbs/MMBtu	0.03	0.03	0.03	0.03
NOx, lbs/hr	1.84	1.56	1.69	1.70
CO, ppm	10	21	13	15
CO, lbs/MMBtu	0.02	0.04	0.02	0.02
CO, lbs/hr	1.02	1.81	1.22	1.35
SO2, ppm	0.48	0.41	0.00	0.30
SO2, lbs/MMBtu	0.00	0.00	0.00	0.00
SO2, lbs/hr	0.11	0.08	0.00	0.06

**BFI Halifax - Inlet Duct
1550°F Condition**

Run No.	1	2	3	
Date	22-Apr-96	22-Apr-96	22-Apr-96	
Start Time	11:50	14:30	17:25	
Stop Time	13:29	16:20	18:49	AVERAGES
Barometric Pressure, in. Hg	30.15	30.15	30.15	30.15
Net Sampling Time, minutes	0.0	0.0	0.0	0.0
Volume Metered, cf	0.000	0.000	0.000	0.000
Avg. DGM Temp, F				0
AVG Delta H, in of H2O				0.00
AVG Delta H, in of Hg	0.0000	0.0000	0.0000	0.0000
DGM Calibration Factor	1.000	1.000	1.000	1.000
Volume of Gas Collected, dscf	0.000	0.000	0.000	0.000
Total Water Collected, mL	0.0	0.0	0.0	46.9
Volume of Water Vapor, scf	0.000	0.000	0.000	0.000
Moisture, %	5.0	5.0	5.0	5.0
Dry Mole Fraction, 100-%M	0.9500	0.9500	0.9500	0.9500
CO2 at Stack, % dry	40.90	40.80	40.60	40.77
O2 at Stack, % dry	1.13	1.03	1.18	1.11
CO + N2, % dry	57.97	58.17	58.22	58.12
Dry Molecular Weight, lb/lb mole	34.59	34.57	34.54	34.57
Wet Molecular Weight, lb/lb mole	33.76	33.74	33.72	33.74
Excess Air at Stack, %	8.0	7.2	8.3	7.8
Stack Area, sq. in. (12 in. ID)	113.1	113.1	113.1	113.1
Static Pressure, in. of H2O	2.00	2.00	2.00	2.00
Stack Pressure, in. of Hg	30.30	30.30	30.30	30.30
Avg. Stack Temp., F	102	96	98	99
Avg. Sqrroot of Delta P	0.5767	0.5731	0.6000	0.5833
SDE Average	13.672	13.512	14.173	13.786
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	1,842	1,821	1,911	1,858
Stack Flowrate, wet acfm	1,447	1,430	1,501	1,459
Stack Flowrate, wet scfm	1,376	1,376	1,438	1,397
Stack Flowrate, dry scfm	1,308	1,307	1,366	1,327

APPENDIX C

FLUE GAS ANALYTICAL DATA

BTU F-FACTOR CONVERSION

Run No.	Specific Gravity @ 60°F	Density to 68°F	Density lb/cf	Btu/cf @ 60°F	Btu/cf to 68°F	Btu/lb	F-Factor dscf/MMBtu
Run 1	0.9877	0.0752	0.0743	511.6	503.8	6782	9524
Run 2	0.9821	0.0752	0.0739	522.8	514.9	6970	9493
Run 3	0.9822	0.0752	0.0739	520.3	512.4	6936	9485

Mole % H2	H2 lbs	H2 lbs %	Mole % C	C lbs	C lbs %	Mole % S2	S2 lbs	S2 lbs %	Mole % N2	N2 lbs	N2 lbs %	Mole % O2	O2 lbs	O2 lbs %	Total lbs	Total lbs %
51.40	0.52	7.11	23.30	2.80	38.39	0.00	0.00	0.00	3.87	0.54	7.44	21.42	3.43	47.06	7.2831	100.00
52.11	0.53	7.31	23.35	2.80	39.01	0.00	0.00	0.00	3.42	0.48	6.67	21.11	3.38	47.02	7.1837	100.00
51.99	0.52	7.28	23.29	2.79	38.81	0.00	0.00	0.00	3.56	0.50	6.92	21.15	3.38	46.99	7.2013	100.00

DATA INPUT

Particulate Analysis

Project No. 20272
 Client BFI
 Plant Halifax Landfill Flare

Date 4/22/96
 Source Landfill Flare
 Analyst S. J.

A. SAMPLE VOLUME

93 mL

B. WASH VOLUME

25 mL
 _____ mL
 _____ mL
 _____ mL
 Total: 25 mL

C. BLANK CORRECTION

Sample: _____ mL x _____ g/mL = _____ g

Wash: _____ mL x _____ g/mL = _____ g

D. TARE WEIGHTS

	No.	Wt.	
Container	B-1	105.9116	g
Filter			g
Thimble			g
Total		105.9116	g

E. GROSS WEIGHTS

RH/°F	Date/Time	(1)	RH/°F	Date/Time	(4)
48%, 63°	5/9, Am	105.9160g	/	/	g
43%, 65°	5/9, Pm	105.9162g	/	/	g
/	/	(3) _____ g	/	/	(6) _____ g

Final Gross Weight 105.9162 g
 Total Tare Weight 105.9116 g
 Residue Weight 0.0046 g
 Blank Weight 0.0000 g

F. NET WEIGHT

Net Weight 0.0046 g = 4.6 mg

REMARKS: 1550° F HCL/PM BFIH-FH4LE-1
Run #1 Acetone Rinse

Particulate Analysis

Project No. 20272
 Client BFI
 Plant Halifax Landfill Flare

Date 4/22/96
 Source Landfill Flare
 Analyst [Signature]

A. SAMPLE VOLUME

_____ mL

B. WASH VOLUME

_____ mL
 _____ mL
 _____ mL
 _____ mL
 Total: _____ mL

C. BLANK CORRECTION

Sample: _____ mL x _____ g/mL = _____ g

Wash: _____ mL x _____ g/mL = _____ g

D. TARE WEIGHTS

	No.	Wt.	
Container			_____ g
Filter	K-31	0.3390	_____ g
Thimble			_____ g
Total		0.3390	_____ g

E. GROSS WEIGHTS

RH/°F	Date/Time	(1)	(2)	(3)	RH/°F	Date/Time	(4)	(5)	(6)
40%, 65°	5/8, 1 Am	0.3401 g	0.3400 g	_____ g	_____	_____	_____ g	_____ g	_____ g
44%, 66°	5/8, 1 Pm				_____	_____			
_____	_____				_____	_____			

Final Gross Weight 0.3400 g
 Total Tare Weight 0.3390 g
 Residue Weight 0.0010 g
 Blank Weight 0.0000 g

F. NET WEIGHT

Net Weight 0.0010 g = 1.0 mg

REMARKS: 1550° F HCL/PM BFIH - PF - 1
Run #1 Filter

Particulate Analysis

Project No. 20272

Date 4/22/96

Client BFI

Source Landfill Flare

Plant Halifax Landfill Flare

Analyst S. J.

A. SAMPLE VOLUME

91 mL

B. WASH VOLUME

25 mL
 _____ mL
 _____ mL
 _____ mL
 Total: 25 mL

C. BLANK CORRECTION

Sample: _____ mL x _____ g/mL = _____ g

Wash: _____ mL x _____ g/mL = _____ g

D. TARE WEIGHTS

	No.	Wt.	
Container	B-2	118.3257	g
Filter			g
Thimble			g
Total		118.3257	g

E. GROSS WEIGHTS

RH/°F	Date/Time	(1)	RH/°F	Date/Time	(4)
48%/63°	5/9, Am	118.3297g	_____	_____	_____g
43%/65°	5/9, Pm	118.3299g	_____	_____	_____g
_____	_____	(3) _____g	_____	_____	(6) _____g

Final Gross Weight 118.3299 g

Total Tare Weight 118.3257 g

Residue Weight 0.0042 g

Blank Weight 0.0000 g

F. NET WEIGHT

Net Weight 0.0042 g = 4.2 mg

REMARKS: 1550° F HCL/PM BFIH-FHACE-2
Rv #2 Acetone Rinse

Particulate Analysis

Project No. 20272
 Client BEI
 Plant Halifax Landfill Flare

Date 4/22/96
 Source Landfill Flare
 Analyst [Signature]

A. SAMPLE VOLUME

_____ mL

B. WASH VOLUME

_____ mL
 _____ mL
 _____ mL
 _____ mL
 Total: _____ mL

C. BLANK CORRECTION

Sample: _____ mL x _____ g/mL = _____ g

Wash: _____ mL x _____ g/mL = _____ g

D. TARE WEIGHTS

	No.	Wt.	
Container			_____ g
Filter	K-33	0.3371	_____ g
Thimble			_____ g
Total		0.3371	_____ g

E. GROSS WEIGHTS

RH/°F	Date/Time		RH/°F	Date/Time	
40% / 65°	5/8 1 Am	(1) 0.3376 g	_____	_____	(4) _____ g
44% / 66°	5/8 1 Pm	(2) 0.3377 g	_____	_____	(5) _____ g
_____	_____	(3) _____ g	_____	_____	(6) _____ g

Final Gross Weight 0.3377 g
 Total Tare Weight 0.3371 g
 Residue Weight 0.0006 g
 Blank Weight 0.0000 g

F. NET WEIGHT Net Weight 0.0006 g = 0.6 mg

REMARKS: 1550°F HCL/PM BEIH-PF-2
Rv #2 Filter

Particulate Analysis

Project No. 20272
 Client BFI
 Plant Healthcare Landfill Flare

Date 4/22/96
 Source Landfill Flare
 Analyst S. J.

A. SAMPLE VOLUME

75 mL

B. WASH VOLUME

25 mL
 _____ mL
 _____ mL
 _____ mL
 Total: 25 mL

C. BLANK CORRECTION

Sample: _____ mL x _____ g/mL = _____ g

Wash: _____ mL x _____ g/mL = _____ g

D. TARE WEIGHTS

	No.	Wt.	
Container	B-3	104.9275	g
Filter			g
Thimble			g
Total		104.9275	g

E. GROSS WEIGHTS

RH/°F	Date/Time		RH/°F	Date/Time	
<u>43% / 65°</u>	<u>5/9, 1 Pm</u>	(1) <u>104.9303</u> g	<u>1</u>	<u>1</u>	(4) _____ g
<u>46% / 61°</u>	<u>5/13, 1 Am</u>	(2) <u>104.9306</u> g	<u>1</u>	<u>1</u>	(5) _____ g
<u>1</u>	<u>1</u>	(3) _____ g	<u>1</u>	<u>1</u>	(6) _____ g

Final Gross Weight 104.9303 g
 Total Tare Weight 104.9275 g
 Residue Weight 0.0028 g
 Blank Weight 0.0000 g

F. NET WEIGHT Net Weight 0.0028 g = 2.8 mg

REMARKS: 1550° F HCL/PM BFIH-FHAGE-3
Run #3 Acetone Rinse

Particulate Analysis

Project No. 20272
 Client BEI
 Plant Halifax Landfill Flare

Date 4/22/96
 Source Landfill Flare
 Analyst S. J.

A. SAMPLE VOLUME

_____ mL

B. WASH VOLUME

_____ mL
 _____ mL
 _____ mL
 _____ mL
 Total: _____ mL

C. BLANK CORRECTION

Sample: _____ mL x _____ g/mL = _____ g

Wash: _____ mL x _____ g/mL = _____ g

D. TARE WEIGHTS

	No.	Wt.	
Container			_____ g
Filter	K-34	0.3380	_____ g
Thimble			_____ g
Total		0.3380	_____ g

E. GROSS WEIGHTS

RH/°F	Date/Time	(1)	Weight	RH/°F	Date/Time	(4)	Weight
40% / 65°	5/8, Am	(1)	0.3394 g	/	/	(4)	_____ g
44% / 66°	5/8, Pm	(2)	0.3392 g	/	/	(5)	_____ g
/	/	(3)	_____ g	/	/	(6)	_____ g

Final Gross Weight 0.3392 g

Total Tare Weight 0.3380 g

Residue Weight 0.0012 g

Blank Weight 0.0000 g

F. NET WEIGHT

Net Weight 0.0012 g = 1.2 mg

REMARKS: 1550°F HCL/PM BEIH-PF-2
Run #3 Filter

Particulate Analysis

Project No. 20272
 Client BFI
 Plant Halifax Landfill Flare

Date 4/22/96
 Source Landfill Flare
 Analyst B. J.

A. SAMPLE VOLUME

117 mL

B. WASH VOLUME

25 mL
 _____ mL
 _____ mL
 _____ mL
 Total: 25 mL

C. BLANK CORRECTION

Sample: _____ mL x _____ g/mL = _____ g

Wash: _____ mL x _____ g/mL = _____ g

D. TARE WEIGHTS

	No.	Wt.
Container	B-4	113.2827 g
Filter		_____ g
Thimble		_____ g
Total		113.2827 g

E. GROSS WEIGHTS

RH/°F	Date/Time	(1)	RH/°F	Date/Time	(4)
_____	_____	<u>113.2830</u> g	_____	_____	_____ g
_____	_____	<u>113.2826</u> g	_____	_____	<u>(5)</u> _____ g
_____	_____	<u>(3)</u> _____ g	_____	_____	<u>(6)</u> _____ g

Final Gross Weight 113.2826 g
 Total Tare Weight 113.2827 g
 Residue Weight _____ g
 Blank Weight -0.0001 g

F. NET WEIGHT

Net Weight -0.0001 g = -0.1 mg

REMARKS: 1550°F HCL/PM BFIH-Blank-ACE
Blank Acetone Rinse

Particulate Analysis

Project No. 20272

Date 4/22/96

Client BFI

Source Landfill Flare

Plant Halifax Landfill Flare

Analyst [Signature]

A. SAMPLE VOLUME

_____ mL

B. WASH VOLUME

_____ mL
 _____ mL
 _____ mL
 _____ mL
 Total: _____ mL

C. BLANK CORRECTION

Sample: _____ mL x _____ g/mL = _____ g

Wash: _____ mL x _____ g/mL = _____ g

D. TARE WEIGHTS

	No.	Wt.	
Container			g
Filter	K-35	0.3389	g
Thimble			g
Total		0.3389	g

E. GROSS WEIGHTS

RH/°F	Date/Time	(1)	(2)	(3)	RH/°F	Date/Time	(4)	(5)	(6)
44% / 66°	5/8 1 Pm	0.3391 g	0.3388 g						
48% / 63°	5/9 1 Pm								

Final Gross Weight 0.3388 g
 Total Tare Weight 0.3389 g
 Residue Weight _____ g
 Blank Weight -0.0001 g

F. NET WEIGHT

Net Weight -0.0001 g = -0.1 mg

REMARKS: 1550° F HCL/PM BFIH - Blank - Filter
Filter Blank

CHAIN OF CUSTODY RECORD

Project Name BFI Halifax
 Project No.: 20272
 Sampling Date(s): 4/22/96
 Laboratory: TRC Lowell
 Laboratory P.O. #: _____
 Shipping Airbill No.: _____
 Shipping Date(s): N/A
 Shipper's Name: N/A

MATRIX

Aqueous
 Organic Solvent
 Ash/Soil/Sediment
 Acidic
 Basic
 Other

ANALYSIS

Trace Metals*
 Mercury
 Hexavalent Chromium
 HCl
 Cl2
 Particulate Matter
 PCDD/PCDF
 Semi-Volatile Organics
 Volatile Organics
 Physical Parameters*

Sample Code	Sampled Date	Container		MATRIX						Source Description	ANALYSIS										Comments				
		Size	G/P	Aqueous	Organic Solvent	Ash/Soil/Sediment	Acidic	Basic	Other		Trace Metals*	Mercury	Hexavalent Chromium	HCl	Cl2	Particulate Matter	PCDD/PCDF	Semi-Volatile Organics	Volatile Organics	Physical Parameters*					
BFIH-FHACE-1	4/22	G		X										X											
BFIH-FHACE-2	4/22	G		X										X											
BFIH-FHACE-3	4/22	G		X										X											
PM Filters in desiccator																									
Run 1			P											X											
Run 2			P											X											
Run 3			P											X											

Relinquished by: [Signature]

Date/Time: 4/23/96

Relinquished by: _____

Date/Time: _____

Received by: [Signature]

Date/Time: 5/8/96

Received by: _____

Date/Time: _____

REMARKS (*):

N^o 00584

TRC - LOWELL
BFI HALIFAX
JOB # T004
REPORT # 96-064

SUBMITTED BY:
CHESTER LABNET - PORTLAND
12242 S.W. GARDEN PLACE
TIGARD, OR 97223
☎(503)624-2183/FAX (503)624-2653

CHESTER LabNet

Portland
12242 S.W. Garden Place
Tigard, OR 97223
☎ (503)624-2183
Fax (503)624-2653

Case Narrative

Date: May 2, 1996

General Information

Client: TRC - Lowell
Sample Description: EPA Method 26 Impinger Solutions
Sample Numbers: 96M288 - 96M290
Job Number: T004
Report Number: 96-064

Analysis

Analytes: HCl
Analytical Protocols: EPA Method 26
Analytical Notes: Analysis was performed with no problems encountered.
QA/QC Review: All of the data have been reviewed by the analysts performing the analyses and the quality assurance officer. All of the quality control and sample-specific information in this package is complete and meets or exceeds the minimum requirements for acceptability.
Comments: If you have any questions or concerns regarding this analysis, please feel free to contact the project manager.

 5/2/96

QA Officer Date
Charles Lytle

 5/2/96

Project Manager Date
Paul Duda

Client Name: TRC - Lowell
Project Number: T004

=====
Lab ID: 96-M288
Client ID: BF1H-HCl-1
Site: BFI Halifax
Sample Date: 4/22/96
Sample Volume: 435.0 ml

Analyte	Results		
HCl	7.74	µg/ml	3370 µg

Lab ID: 96-M289
Client ID: BF1H-HCl-2
Site: BFI Halifax
Sample Date: 4/22/96
Sample Volume: 395.0 ml

Analyte	Results		
HCl	7.02	µg/ml	2770 µg

Lab ID: 96-M290
Client ID: BF1H-HCl-3
Site: BFI Halifax
Sample Date: 4/22/96
Sample Volume: 420.0 ml

Analyte	Results		
HCl	7.05	µg/ml	2960 µg

QA/QC REPORT: BLANK ANALYSIS

Client: TRC-LOWELL
 Analytical Technique: METHOD 26
 Sample Description: IMPINGER SOLUTIONS
 Chester Analysis Range: 96M 288 - 290
 Date: 5/1/96

Sample ID	ANALYTES							
	Cl mg/L							
PREP BLANK	<MDL							
Average Blank	<MDL							
MDL	0.1							

Note:
 MDL = Method Detection Limit
 OC = Organic Carbon; EC = Elemental Carbon; TC = Total Carbon

All samples will be blank subtracted based on the average blank values listed above

5/2/96 Sat

VOLUMES - TRC LOWELL

SAMPLE

96M 288
289
290

VOLUME

435
395
420

```

Sample Name: CCV MID                               Date: Wed May 01 16:05:55 1996
Data File : C:\DX\DATA\0501AN01.D24
Method : C:\DX\METHOD\AN_AUTO.mat
ACQ Address: 1      System : 1      Inject#: 24      Detector: DM-1

```


***** EXTERNAL STANDARD REPORT *****

```

Start Time = 0.00 minutes      Stop time = 9.50 minutes
Number of Data Points = 2850   One Data Point per 0.2 seconds
Acq. Reject = 100
Amount Injected = 1           Dilution factor = 1

```

PEAK NUM	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	BL	REF PEAK	% DELTA RET TIME
1	0.90		7.826e+002	7.826e+002	183	1		
2	1.07	F	9.931e+000	2.350e+005	55952	1	1	0.00%
3	1.67	CL	9.527e+000	1.591e+005	36927	1	2	0.00%
4	3.53	M03	9.390e+000	7.270e+004	8514	1	5	0.00%
5	5.40	P04	1.009e+001	3.746e+004	2728	1	1	-6.76%
6	7.18	S04	1.837e+000	1.612e+004	947	1	1	-1.41%




DATA NAME: 008
Date File: C:\DATA\DATA\008\008.D
Method: INJECT\INJECT.METHOD
Injection Volume: 25
Detector: GPC-1
Injection Number: 1
Injection Volume: 25
Injection Concentration: 1.00 mg/ml
Injection Date: 11/11/88
Injection Time: 11:11:11
Injection Operator: J. J. J.

EXPERIMENTAL STANDARD REPORT *****

Run Time: 1.00 minutes
Number of Data Points = 2850
Area Under Curve = 2850
Area Reject = 100
Stop Time = 9.50 minutes
One Data Point per 0.2 seconds
Amount Injected = 1
Dilution Factor = 1

PEAK RET TIME	PEAK NAME	COND. In ppm	AREA	HEIGHT	RL	PEAK RET TIME	REF	% DELTA
1.05 F		4.7390e+002	4.861e+002	71	1	1		0.00%

22




39

Sample Name: CDV K10 Date: Wed May 01 19:45:48 1996
 Data File : C:\DX\DATA\05019801.D00
 Method : C:\DX\MET-00\44 AUTO.M00
 PDI Address: System : 1 InjectWt: 33 Detector: DM-1

***** EXTERNAL STANDARD REPORT *****

Start Time = 0.00 minutes Stop time = 9.50 minutes
 Number of Data Points = 2880 One Data Point per 0.2 seconds
 Area Reject = 100
 Amount Injected = 1 Dilution factor = 1

PEAK ROW	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	BL	REF PEAK	% DELTA RET TIME
1	0.90		8.009e+002	8.009e+002	190	1		
2	1.07	F	7.877e+000	2.342e+005	56988	1	1	0.00%
3	1.67	CL	7.484e+000	1.583e+005	36547	1	2	0.00%
4	3.58	H03	7.429e+000	7.301e+004	8308	1	3	0.00%
5	5.40	P04	1.002e+001	3.721e+004	2781	1	1	-6.78%
6	7.18	S04	1.844e+000	1.539e+004	931	1	1	-1.41%



```

=====
Sample Name: 002                               Date Recd: May 01 19:57:53 1996
Data File : C:\DX\DATA\05019401.D04
Method : C:\XP\MSY\00\CN\AUT0.met
Lab Address : System : J Injec# : 34 Detector: CN-1
=====

```


***** EXTERNAL STANDARD REPORT *****

```

Start Time = 0.00 minutes           Stop time = 9.50 minutes
Number of Data Points = 2850        One Data Point per 0.2 seconds
Area Reject = 100
Amount Injected = 1                 Dilution factor = 1

```

PEAK NUM	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	BL	REF PEAK	% DELTA RET TIME
1	1.07	F	-6.407e-003	3.160e+002	68	1	1	0.00%




Sample Name: 94M 207 Date: Wed May 01 10:28:30 1996
 Data File : C:\DX\DATA\0501AN01.D26
 Method : C:\DX\METHODS\ANALTO.met
 PCI Address: 1 System : 1 Inject#: 26 Detectors: CDM-1

*****EXTERNAL STANDARD REPORT*****

Start Time = 0.00 minutes Stop time = 9.50 minutes
 Number of Data Points = 2850 One Data Point per 0.2 seconds
 Area Reject = 100
 Amount Injected = 1 Dilution factor = 1

PEAK NUM	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	BL	REF PEAK	% DELTA RET TIME
1	0.90		3.409e+004	3.409e+004	4205	1		
2	1.23		1.197e+004	1.197e+004	981	1		
3	1.65	CL	<u>7.478e+000</u>	1.239e+005	18405	1	2	0.00%
4	2.23		3.388e+004	3.388e+004	1564	1		
5	3.82	N03	2.885e+000	2.046e+004	2567	1	5	0.00%
6	5.55	P04	7.944e+003	3.009e+007	528657	1	1	-5.67%




Sample Name: 96E 23B DUP Date: Wed May 01 18:39:40 1996
 Data File : C:\DX\DATA\CS91AN01.D27
 Method : C:\DX\METHODS\GEN_AU10.met
 Cell Address: 1 System : 1 Inject#s : 27 Detector : CDF-1

***** EXTERNAL STANDARD REPORT *****

Start Time = 0.00 minutes Stop time = 9.50 minutes
 Number of Data Points = 2650 One Data Point per 0.2 seconds
 Area Reject = 100
 Amount Injected = 1 Dilution factor = 1

PEAK NO.	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	BL	REF PEAK	% DELTA RET TIME
1	0.90		3.453e+004	3.453e+004	4236	1		
2	1.23		1.171e+004	1.171e+004	954	1		
3	1.63	CL	7.556e+000	1.249e+005	17657	1	2	0.00%
4	2.23		3.318e+004	3.318e+004	1593	1		
5	3.80	NO3	2.857e+000	2.024e+004	2452	1	5	0.00%
6	5.55	PO4	7.959e+003	3.014e+007	529357	1	1	-5.67%




Sample Name: 96M 208 SPIKE Date: Wed Nov 01 18:50:50 1996
 Data File: C:\DX\DATA\0501\N01.DD
 Method: C:\DX\METHOD\A4 AUTO.LIB
 ADC Address: 1 System: 1 Injector: 20 Detector: CDM-1

***** EXTERNAL STANDARD REPORT *****

Start Time = 0.00 minutes Stop time = 9.50 minutes
 Number of Data Points = 2850 One Data Point per 0.2 seconds
 Gain Offset = 100
 Amount Injected = 1 Dilution factor = 1

PEAK NUM	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	REF BL	PEAK	% DELTA RET TIME
1	0.92		1.029e+004	1.029e+004	2674	1		
2	1.10	F	9.243e+000	2.188e+005	27116	1	1	0.00%
3	1.67	CL	1.479e+001	2.851e+005	36720	1	2	0.00%
4	2.20	NO2	1.708e+000	1.490e+004	1252	1	6	-5.17%
5	3.72	NO3	1.247e+001	9.742e+004	11626	1	5	0.00%
6	5.30		2.547e+004	2.547e+004	3277	1		
7	5.62	PO4	7.189e+003	2.723e+007	490457	1	1	-5.96%




Sample Name: 96K 289 Date: Wed May 01 19:02:08 1996
 Data File : C:\DX\DATA\0501AND1.D29
 Method : C:\DX\METHODS\AUTO.MET
 ADI Address: 1 System: 1 Injector: 29 Detector: CDM-1

***** EXTERNAL STANDARD REPORT *****

Start Time = 0.00 minutes Stop time = 9.50 minutes
 Number of Data Points = 2850 One Data Point per 0.2 seconds
 Area Reject = 100
 Amount Injected = 1 Dilution factor = 1

PEAK NUM	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	REF BL	% DELTA PEAK RET TIME
1	0.92		4.820e+004	4.820e+004	5556	1	
2	1.33		1.061e+004	1.061e+004	898	1	
3	1.63	CL	3.814e+000	3.121e+005	18663	1	2 0.00%
4	2.18		5.508e+004	5.503e+004	1493	1	
5	3.83		1.901e+004	1.901e+004	2395	1	
6	5.47		3.353e+007	3.353e+007	573834	1	




Sample Name: 94M 289 DUP Date: Wed May 01 19:13:18 1996
 Data File : C:\EXPERIMENT\94M\94M01.D30
 Method : C:\EX\METHOD\AN_AUTO.MET
 AIT Address: 1 System : 1 InjectW: 30 Detectors: CDM-1

***** EXTERNAL STANDARD REPORT *****

Start Time = 0.00 minutes Stop time = 9.50 minutes
 Number of Data Points = 2850 One Data Point per 0.2 seconds
 Area Reject = 100
 Amount Injected = 1 Dilution factor = 1

PEAK NUM	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	BL	REF PEAK	% DELTA RET TIME
1	0.92		4.833e+004	4.833e+004	5573	1		
2	1.33		1.074e+004	1.074e+004	923	1		
3	1.63	CL	6.837e+000	1.125e+005	19015	1	2	0.00%
4	2.18		5.419e+004	5.419e+004	1512	1		
5	3.83		1.890e+004	1.890e+004	2406	1		
6	5.47		3.346e+007	3.346e+007	573746	1		




Sample Name: 2ah, 220 Date: Wed May 03 19:24:28 1996
 Data File: C:\NWX\DATA\N05016\N01.DSI
 Method: C:\NWX\METHODS\AM_AUTO.MET
 VOT Address: 1 System: 1 Inject#: 31 Detector: UD4-1

***** EXTERNAL STANDARD REPORT *****

Start Time = 0.00 minutes Stop time = 9.50 minutes
 Number of Data Points = 2850 One Data Point per 0.2 seconds
 Area Reject = 100
 Amount Injected = 1 Dilution factor = 1

PEAK NUM	RET TIME	PEAK NAME	CONC. in ppb	AREA	HEIGHT	REF BL	PEAK	% DELTA RET TIME
1	0.92		4.106e+004	4.186e+004	4979	1		
2	1.23		1.135e+006	1.135e+004	848	1		
3	1.63	CL	6.885e+000	1.133e+005	17250	1	2	0.00%
4	2.21		4.004e+004	4.004e+004	1390	1		
5	3.82	H03	2.229e+000	1.520e+004	1849	1	5	0.00%
6	5.52	P04	8.334e+003	3.156e+007	548956	1	1	-6.27%



```

Sample Name: 96M 290 DUP                               Date: Wed May 01 17:35:38 1996
Data File : C:\DX\DATA\0501AH01.L32
Method : C:\DX\METHOD\AN_AUTO.met
ADI Address: 1      System : 1      Inject#: 32      Detector: UDM-1

```


***** EXTERNAL STANDARD REPORT *****

```

Start Time = 0.00 minutes      Stop time = 9.50 minutes
Number of Data Points = 2850   One Data Point per 0.2 seconds
Area Reject = 100
Amount Injected = 1           Dilution factor = 1

```

PEAK NUM	RET TIME	PEAK NAME	CONC. in ppm	AREA	HEIGHT	BL	REF PEAK	% DELTA RET TIME
1	0.92		4.183e+004	4.163e+004	5020	1		
2	1.23		1.155e+004	1.155e+004	836	1		
3	1.63	CL	6.843e+000	1.126e+005	17334	1	2	0.00%
4	2.23		4.130e+004	4.130e+004	1414	1		
5	3.87	ND3	2.206e+000	1.301e+004	1844	1	5	0.00%
6	5.52	PD4	6.331e+003	3.155e+007	548356	1	1	-6.23%





LABORATORY REPORT

Client: TRC ENVIRONMENTAL CORPORATION Date of Report: 05/06/96
Address: Boott Mills South, Foot of John Street Date Received: 04/23/96
Lowell, MA 01852 PAI Project No: P9600706
Contact: Mr. Mike O'Brien Purchase Order: 028667
Client Project ID: BFI Halifax #20272

Six (6) Tedlar Bag Samples labeled:

"BFIH-IN-1" "BFIH-OUT-1" "BFIH-IN-2"
"BFIH-OUT-2" "BFIH-IN-3" "BFIH-OUT-3"

The samples were received at the laboratory under chain of custody on April 23, 1996. The samples were received intact. The dates of analyses are indicated on the attached data sheets.

Sulfur Analysis

The samples were analyzed for twenty Sulfur compounds and total reduced Sulfur by gas chromatography/flame photometric detection (FPD). The analytical system used was comprised of a Hewlett Packard Model 5890 equipped with a flame photometric detector (FPD). A thick film (5 micron) crossbonded 100% Dimethyl polysiloxane megabore column (60 meter x 0.53mm RT_x-1, Restek Corporation, Bellefonte, PA) was used to achieve chromatographic separation.

The results of analyses are given on the attached data sheets.

Data Release Authorization:

Ku-Jih Chen
Principal Chemist

Reviewed and Approved:

Michael Taday
Laboratory Director

Project Name BFI - Halifax
 Project No.: 20272
 Sampling Date(s): 4/22/96
 Laboratory: PAI
 Laboratory P.O. #: _____
 Shipping Airbill No.: _____
 Shipping Date(s): 4/22/96
 Shipper's Name: Mike O'Brien

MATRIX

ANALYSIS

P9600706

Aqueous
 Organic Solvent
 Ash/Soil/Sediment
 Acidic
 Basic
 Other ATR

Trace Metals*
 Mercury
 Hexavalent Chromium
 HCl
 Cl2
 Particulate Matter
 PCDD/PCDF
 Semi-Volatile Organics
 Volatile Organics
 Physical Parameters*
TSS + H2S

Sample Code	Sampled Date	Container		MATRIX						Source Description	ANALYSIS										Comments						
		Size	G/P	Aqueous	Organic Solvent	Ash/Soil/Sediment	Acidic	Basic	Other		Trace Metals*	Mercury	Hexavalent Chromium	HCl	Cl2	Particulate Matter	PCDD/PCDF	Semi-Volatile Organics	Volatile Organics	Physical Parameters*							
✓ BFIH-IN-1	4/22/96		Tedhi							✓	Landfill Flare Inlet															✓	P9600706-001
✓ BFI-OUT-1	↓		↓							✓	" " outlet															✓	-002
✓ BFI-IN-2	↓		↓							✓	" " Inlet															✓	-003
✓ BFI-OUT-2	↓		↓							✓	" " Outlet															✓	-004
✓ BFI-IN-3	↓		↓							✓	" " Inlet															✓	-005
✓ BFI-OUT-3	4/22/96		✓							✓	" " outlet															✓	-006

Relinquished by: E. Mpc Kinnon Date/Time: 4/22/96 Relinquished by: _____ Date/Time: _____
 Received by: Roder D & V Date/Time: 4/23/96 9:00 AM Received by: _____ Date/Time: _____

REMARKS (*): _____

Nº 09156



Performance Analytical Inc.
Air Quality Laboratory

LABORATORY REPORT

Client:	TRC ENVIRONMENTAL CORPORATION	Date of Report:	05/06/96
Address:	Boott Mills South, Foot of John Street	Date Received:	04/24/96
	Lowell, MA 01852	PAI Project No:	P9600715
Contact:	Mr. Mike O'Brien	Purchase Order:	028667

Client Project ID: BFI Halifax #20272

Six (6) Stainless Steel Summa Canisters labeled:

"BFIH-IN-SUMMA-1"	"BFIH-OUT-SUMMA-1"	"BFIH-IN-SUMMA-2"
"BFIH-OUT-SUMMA-2"	"BFIH-IN-SUMMA-3"	"BFIH-OUT-SUMMA-3"

The samples were received at the laboratory under chain of custody on April 24, 1996. The samples were received intact. The dates of analyses are indicated on the attached data sheets.

Methane and Total Gaseous Non-Methane Organics Analysis

The samples were analyzed for Methane and total gaseous non-Methane organics according to EPA Method 25C. The analyses were performed by gas chromatography using flame ionization detection/total combustion analysis.

Methane, Oxygen and Carbon Dioxide Analysis

The samples were also analyzed for Methane, Oxygen and Carbon dioxide using a Hewlett Packard Model 5890 gas chromatograph equipped with a thermal conductivity detector (TCD).

Data Release Authorization:

Christopher Casteel
Manager of Technical Operations

Reviewed and Approved:

Michael Tuday
Laboratory Director



Performance Analytical Inc.

Air Quality Laboratory

Volatile Organic Compound Analysis

The sample labeled "BFIH-IN-SUMMA-1" was also analyzed by combined gas chromatography/mass spectrometry (GC/MS) for volatile organic compounds. The analyses were performed according to the methodology outlined in EPA Method TO-14 from the Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air, EPA 600/4-84-041, U.S. Environmental Protection Agency, Research Triangle Park, NC, April, 1984 and May, 1988. The analyses were performed by gas chromatography/mass spectrometry, utilizing a direct cryogenic trapping technique. The analytical system used was comprised of a Hewlett Packard Model 5989 GC/MS/DS interfaced to an Entech 7000 whole air inlet system/cryogenic concentrator. A 100% Dimethylpolysiloxane capillary column (RT_x-1, Restek Corporation, Bellefonte, PA) was used to achieve chromatographic separation.

The results of analyses are given on the attached data sheets.



RESULTS OF METHANE &

TOTAL GASEOUS NON-METHANE ORGANICS (TGNMO) ANALYSIS
PAGE 1 OF 1

Client: TRC Environmental Corporation

Client Project ID: #20272
PAI Project ID: P9600715

Test Code: EPA Method 25C
Instrument ID: HP 5890A/FID/TCA
Analyst: J. Dan Taliaferro
Matrix: Summa Canisters

Date Sampled: 4/22/96
Date Received: 4/24/96
Date Analyzed: 4/24/96
Volume(s) Analyzed: 0.50 (ml)

Client Sample ID	PAI Sample ID	D.F.	Concentration in ppm, v/v	
			Methane	Total Non-Methane Organics (as Methane)
BFIH-IN-SUMMA-1	P9600715-001	1.31	N/A	3,700
BFIH-OUT-SUMMA-1	P9600715-002	1.59	8.4	82
BFIH-IN-SUMMA-2	P9600715-003	1.40	N/A	3,700
BFIH-OUT-SUMMA-2	P9600715-004	1.23	ND < 0.50	19
BFIH-IN-SUMMA-3	P9600715-005	1.29	N/A	3,900
BFIH-OUT-SUMMA-3	P9600715-006	1.72	ND < 0.50	20
BFIH-OUT-SUMMA-3	Lab Duplicate	1.72	ND < 0.50	17
N/A (4/24/96)	Method Blank	1.00	ND < 0.50	ND < 1.0

TR = Detected Below Indicated Reporting Limit
ND = Not Detected

Verified by: RG

Date: 5/3/96



RESULTS OF METHANE ANALYSIS

PAGE 1 OF 1

Client: TRC Environmental Corporation

Client Project ID: #20272
PAI Project ID: P9600715

Test Code: GC/TCD
Instrument ID: HP 5890A/TCD #1
Analyst: J. Dan Taliaferro
Matrix: Summa Canisters

Date Sampled: 4/22/96
Date Received: 4/24/96
Date Analyzed: 4/24/96
Volume(s) Analyzed: 1.00 (ml)
0.10 (ml)

Client Sample ID	PAI Sample ID	D.F.	Methane (%, v/v)	
			Result	Reporting Limit
BFIH-IN-SUMMA-1	P9600715-001	1.31	50.3	0.200
BFIH-IN-SUMMA-2	P9600715-003	1.40	51.4	0.200
BFIH-IN-SUMMA-3	P9600715-005	1.29	51.2	0.200
N/A (4/24/96)	Method Blank	1.00	ND	0.0200

TR = Detected Below Indicated Reporting Limit
ND = Not Detected

Verified by: RG

Date: 5/3/96



RESULTS OF FIXED GASES ANALYSIS

PAGE 1 OF 1

Client: TRC Environmental Corporation

Client Project ID: #20272
PAI Project ID: #P9600715

Test Code: GC/TCD
Instrument ID: HP 5890A/TCD #1
Analyst: J. Dan Taliaferro
Matrix: Summa Canisters

Date Sampled: 4/22/96
Date Received: 4/24/96
Date Analyzed: 4/24/96
Volume(s) Analyzed: 1.00 (ml)
0.10 (ml)

Client Sample ID	PAI Sample ID	D.F.	Oxygen (%, v/v)	Carbon Dioxide (%, v/v)
BFIH-IN-SUMMA-1	P9600715-001	1.31	1.13	40.9
BFIH-IN-SUMMA-2	P9600715-003	1.40	1.03	40.8
BFIH-IN-SUMMA-3	P9600715-005	1.29	1.18	40.6
N/A (4/24/95)	Method Blank	1.00	ND < 0.0300	ND < 0.0200

TR = Detected Below Indicated Reporting Limit
ND = Not Detected

Verified by : RG

Date : 5/6/96



RESULTS OF ANALYSIS
PAGE 2 OF 2

Client : TRC Environmental Corporation

Client Sample ID : N/A
PAI Sample ID : Method Blank

Test Code : GC/MS EPA TO-14
Analyst : Chris Casteel
Instrument : HP 5989A/Entech 7000
Matrix : Summa Canister
Date Sampled : N/A
Date Received : N/A
Date Analyzed : 4/30/96
Volume(s) Analyzed : 1.000 Liter(s)

Pi 1 = 0.0
Pf 1 = 0.0

D.F. = 1.00

CAS #	COMPOUND	RESULT (UG/M3)	REPORTING LIMIT (UG/M3)	RESULT (PPB)	REPORTING LIMIT (PPB)
75-27-4	Bromodichloromethane	ND	1.0	ND	0.15
79-01-6	Trichloroethene	ND	1.0	ND	0.19
10061-01-5	cis-1,3-Dichloropropene	ND	1.0	ND	0.22
108-10-1	4-Methyl-2-pentanone	ND	1.0	ND	0.24
10061-02-6	trans-1,3-Dichloropropene	ND	1.0	ND	0.22
79-00-5	1,1,2-Trichloroethane	ND	1.0	ND	0.19
108-88-3	Toluene	ND	1.0	ND	0.27
124-48-1	Dibromochloromethane	ND	1.0	ND	0.12
591-78-6	2-Hexanone	ND	1.0	ND	0.24
106-93-4	1,2-Dibromoethane	ND	1.0	ND	0.13
127-18-4	Tetrachloroethene	ND	1.0	ND	0.15
108-90-7	Chlorobenzene	ND	1.0	ND	0.22
100-41-4	Ethylbenzene	ND	1.0	ND	0.23
75-25-2	Bromoform	ND	1.0	ND	0.10
100-42-5	Styrene	ND	1.0	ND	0.24
1330-20-7	m,p-Xylenes	ND	1.0	ND	0.23
95-47-6	o-Xylene	ND	1.0	ND	0.23
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.0	ND	0.15
541-73-1	1,3-Dichlorobenzene	ND	1.0	ND	0.17
106-46-7	1,4-Dichlorobenzene	ND	1.0	ND	0.17
95-50-1	1,2-Dichlorobenzene	ND	1.0	ND	0.17

TR = Detected Below Indicated Reporting Limit
ND = Not Detected

Verified by : RG

Date : 5/3/96



RESULTS OF ANALYSIS
PAGE 1 OF 2

Client : TRC Environmental Corporation

Client Sample ID : BFIH-IN-SUMMA-1
PAI Sample ID : P9600715-001

Test Code : GC/MS EPA TO-14
Analyst : Chris Casteel
Instrument : HP 5989A/Entech 7000
Matrix : Summa Canister
Date Sampled : 4/22/96
Date Received : 4/24/96
Date Analyzed : 4/30/96
Volume(s) Analyzed : 0.001 Liter(s)

Pi 1 = -1.2
Pf 1 = 3.0

D.F. = 1.31

CAS #	COMPOUND	RESULT (UG/M3)	REPORTING LIMIT (UG/M3)	RESULT (PPB)	REPORTING LIMIT (PPB)
74-87-3	Chloromethane	ND	1,000	ND	490
75-01-4	Vinyl Chloride	4,600	1,000	1,800	390
75-00-3	Chloroethane	1,500	1,000	560	380
74-83-9	Bromomethane	ND	1,000	ND	260
67-64-1	Acetone	15,000	1,000	6,400	420
75-69-4	Trichlorofluoromethane	2,300	1,000	410	180
75-35-4	1,1-Dichloroethene	ND	1,000	ND	250
75-09-2	Methylene chloride	4,400	1,000	1,300	290
75-15-0	Carbon Disulfide	ND	1,000	ND	320
76-13-1	Trichlorotrifluoroethane	ND	1,000	ND	130
156-60-5	trans-1,2-Dichloroethene	ND	1,000	ND	250
156-59-2	cis-1,2-Dichloroethene	3,400	1,000	850	250
75-34-3	1,1-Dichloroethane	2,800	1,000	700	250
1634-04-4	Methyl tert-Butyl Ether	ND	1,000	ND	280
108-05-4	Vinyl Acetate	ND	1,000	ND	280
78-93-3	2-Butanone	14,000	1,000	4,800	340
67-66-3	Chloroform	ND	1,000	ND	210
107-06-2	1,2-Dichloroethane	ND	1,000	ND	250
71-55-6	1,1,1-Trichloroethane	1,100	1,000	200	190
71-43-2	Benzene	6,800	1,000	2,100	310
56-23-5	Carbon Tetrachloride	ND	1,000	ND	160
78-87-5	1,2-Dichloropropane	ND	1,000	ND	220

TR = Detected Below Indicated Reporting Limit
ND = Not Detected

Verified by : RG

Date : 5/3/96



RESULTS OF ANALYSIS

PAGE 2 OF 2

Client : TRC Environmental Corporation

Client Sample ID : BFIH-IN-SUMMA-1

PAI Sample ID : P9600715-001

Test Code : GC/MS EPA TO-14
Analyst : Chris Casteel
Instrument : HP 5989A/Entech 7000
Matrix : Summa Canister

Date Sampled : 4/22/96
Date Received : 4/24/96
Date Analyzed : 4/30/96
Volume(s) Analyzed : 0.001 Liter(s)

Pi 1 = -1.2

Pf 1 = 3.0

D.F. = 1.31

CAS #	COMPOUND	RESULT (UG/M3)	REPORTING LIMIT (UG/M3)	RESULT (PPB)	REPORTING LIMIT (PPB)
75-27-4	Bromodichloromethane	ND	1,000	ND	150
79-01-6	Trichloroethene	3,000	1,000	560	190
10061-01-5	cis-1,3-Dichloropropene	ND	1,000	ND	220
108-10-1	4-Methyl-2-pentanone	3,100	1,000	750	240
10061-02-6	trans-1,3-Dichloropropene	ND	1,000	ND	220
79-00-5	1,1,2-Trichloroethane	ND	1,000	ND	190
108-88-3	Toluene	95,000	1,000	25,000	270
124-48-1	Dibromochloromethane	ND	1,000	ND	120
591-78-6	2-Hexanone	ND	1,000	ND	240
106-93-4	1,2-Dibromoethane	ND	1,000	ND	130
127-18-4	Tetrachloroethene	4,300	1,000	640	150
108-90-7	Chlorobenzene	ND	1,000	ND	220
100-41-4	Ethylbenzene	38,000	1,000	8,700	230
75-25-2	Bromoform	ND	1,000	ND	98
100-42-5	Styrene	5,100	1,000	1,200	240
1330-20-7	m,p-Xylenes	50,000	1,000	11,000	230
95-47-6	o-Xylene	15,000	1,000	3,500	230
79-34-5	1,1,2,2-Tetrachloroethane	ND	1,000	ND	150
541-73-1	1,3-Dichlorobenzene	ND	1,000	ND	170
106-46-7	1,4-Dichlorobenzene	2,500	1,000	410	170
95-50-1	1,2-Dichlorobenzene	ND	1,000	ND	170

TR = Detected Below Indicated Reporting Limit

ND = Not Detected

Verified by : RG

Date : 5/3/96



RESULTS OF ANALYSIS

PAGE 1 OF 2

Client : TRC Environmental Corporation

Client Sample ID : BFIH-IN-SUMMA-1

PAI Sample ID : P9600715-001 Dup

Test Code : GC/MS EPA TO-14
Analyst : Chris Casteel
Instrument : HP 5989A/Entech 7000
Matrix : Summa Canister

Date Sampled : 4/22/96
Date Received : 4/24/96
Date Analyzed : 4/30/96
Volume(s) Analyzed : 0.001 Liter(s)

Pi 1 = -1.2

Pf 1 = 3.0

D.F. = 1.31

CAS #	COMPOUND	RESULT (UG/M3)	REPORTING LIMIT (UG/M3)	RESULT (PPB)	REPORTING LIMIT (PPB)
74-87-3	Chloromethane	ND	1,000	ND	490
75-01-4	Vinyl Chloride	4,500	1,000	1,800	390
75-00-3	Chloroethane	1,400	1,000	530	380
74-83-9	Bromomethane	ND	1,000	ND	260
67-64-1	Acetone	15,000	1,000	6,200	420
75-69-4	Trichlorofluoromethane	2,000	1,000	360	180
75-35-4	1,1-Dichloroethene	ND	1,000	ND	250
75-09-2	Methylene chloride	4,200	1,000	1,200	290
75-15-0	Carbon Disulfide	ND	1,000	ND	320
76-13-1	Trichlorotrifluoroethane	ND	1,000	ND	130
156-60-5	trans-1,2-Dichloroethene	ND	1,000	ND	250
156-59-2	cis-1,2-Dichloroethene	3,300	1,000	840	250
75-34-3	1,1-Dichloroethane	2,600	1,000	650	250
1634-04-4	Methyl tert-Butyl Ether	ND	1,000	ND	280
108-05-4	Vinyl Acetate	ND	1,000	ND	280
78-93-3	2-Butanone	13,000	1,000	4,400	340
67-66-3	Chloroform	ND	1,000	ND	210
107-06-2	1,2-Dichloroethane	ND	1,000	ND	250
71-55-6	1,1,1-Trichloroethane	1,100	1,000	200	190
71-43-2	Benzene	6,600	1,000	2,100	310
56-23-5	Carbon Tetrachloride	ND	1,000	ND	160
78-87-5	1,2-Dichloropropane	ND	1,000	ND	220

TR = Detected Below Indicated Reporting Limit

ND = Not Detected

Verified by : RG

Date : 5/3/96



RESULTS OF ANALYSIS
PAGE 2 OF 2

Client : TRC Environmental Corporation

Client Sample ID : BFIH-IN-SUMMA-1

PAI Sample ID : P9600715-001 Dup

Test Code : GC/MS EPA TO-14
Analyst : Chris Casteel
Instrument : HP 5989A/Entech 7000
Matrix : Summa Canister

Date Sampled : 4/22/96
Date Received : 4/24/96
Date Analyzed : 4/30/96
Volume(s) Analyzed : 0.001 Liter(s)

Pi 1 = -1.2
Pf 1 = 3.0

D.F. = 1.31

CAS #	COMPOUND	RESULT (UG/M3)	REPORTING LIMIT (UG/M3)	RESULT (PPB)	REPORTING LIMIT (PPB)
75-27-4	Bromodichloromethane	ND	1,000	ND	150
79-01-6	Trichloroethene	2,700	1,000	510	190
10061-01-5	cis-1,3-Dichloropropene	ND	1,000	ND	220
108-10-1	4-Methyl-2-pentanone	2,900	1,000	700	240
10061-02-6	trans-1,3-Dichloropropene	ND	1,000	ND	220
79-00-5	1,1,2-Trichloroethane	ND	1,000	ND	190
108-88-3	Toluene	92,000	1,000	24,000	270
124-48-1	Dibromochloromethane	ND	1,000	ND	120
591-78-6	2-Hexanone	ND	1,000	ND	240
106-93-4	1,2-Dibromoethane	ND	1,000	ND	130
127-18-4	Tetrachloroethene	4,100	1,000	620	150
108-90-7	Chlorobenzene	ND	1,000	ND	220
100-41-4	Ethylbenzene	35,000	1,000	8,100	230
75-25-2	Bromoform	ND	1,000	ND	98
100-42-5	Styrene	4,600	1,000	1,100	240
1330-20-7	m,p-Xylenes	46,000	1,000	11,000	230
95-47-6	o-Xylene	14,000	1,000	3,300	230
79-34-5	1,1,2,2-Tetrachloroethane	ND	1,000	ND	150
541-73-1	1,3-Dichlorobenzene	ND	1,000	ND	170
106-46-7	1,4-Dichlorobenzene	2,400	1,000	400	170
95-50-1	1,2-Dichlorobenzene	ND	1,000	ND	170

TR = Detected Below Indicated Reporting Limit
ND = Not Detected

Verified by : RG

Date : 5/3/96


Performance Analytical Inc.

Air Quality Laboratory

RESULTS OF CARBON MONOXIDE ANALYSIS
PAGE 1 OF 1
Client: TRC Environmental Corporation
Client Project ID: #20272
PAI Project ID: #P9600715C
Test Code: EPA Method 25C
Instrument ID: HP 5890A/FID/TCA
Analyst: J. Dan Taliaferro
Matrix: Summa Canisters
Date Sampled: 4/22/96
Date Received: 4/24/96
Date Analyzed: 4/24/96
Volume(s) Analyzed: 0.50 (ml)

Client Sample ID	PAI Sample ID	D.F.	Carbon Monoxide	
			Concentration in ppm, v/v	Reporting Limit
			Result	
BFIH-IN-SUMMA-1	P9600715C-001	1.31	14	1.0
BFIH-IN-SUMMA-2	P9600715C-003	1.40	13	1.0
BFIH-IN-SUMMA-3	P9600715C-005	1.29	12	1.0
N/A (4/24/96)	Method Blank	1.00	ND	1.0

 TR = Detected Below Indicated Reporting Limit
 ND = Not Detected

 Verified by: RG

 Date: 5/21/96

Project Name BFT Halifax
 Project No.: 20272
 Sampling Date(s): 4/22/96
 Laboratory: PAT
 Laboratory P.O. #: _____
 Shipping Airbill No.: _____
 Shipping Date(s): 2/23/96
 Shipper's Name: M. O'Brien

MATRIX

ANALYSIS

Aqueous
 Organic Solvent
 Ash/Soil/Sediment
 Acidic
 Basic
 Other

Trace Metals*
 Mercury
 Hexavalent Chromium
 HCl
 Cl₂
 Particulate Matter
 PCDD/PCDF
 Semi-Volatile Organics
 Volatile Organics
 Physical Parameters*
 TO14
 M. O'Brien
 Lisa M. O'Brien

P9600715

Sample Code	Sampled Date	Container Size	Matrix	Source Description	Trace Metals*	Mercury	Hexavalent Chromium	HCl	Cl ₂	Particulate Matter	PCDD/PCDF	Semi-Volatile Organics	Volatile Organics	Physical Parameters*	TO14	Comments
BFLH-IN-SUMMA-1	4/22	SS		P9600715 - 001									X	X		7
BFLH-OUT-SUMMA-1	4/22	SS		- 002										X		191
BFLH-IN-SUMMA-2	4/22	SS		- 003									X			133
BFLH-OUT-SUMMA-2	4/22	SS		- 004									X			116
BFLH-IN-SUMMA-3	4/22	SS		- 005									X			62
BFLH-OUT-SUMMA-3	4/22	SS		- 006									X			183 822/881

Relinquished by: [Signature] Date/Time: 4/22/96 10:30 Relinquished by: _____ Date/Time: _____
 Received by: Kelvin D. Pitt Date/Time: 4/24/96 9:00 A.M. Received by: _____ Date/Time: _____

REMARKS (*): Please analyze BFLH-IN-SUMMA-1 for TO14/Methane-Non Methane. All odors, Methane-Non Methane only.

Nº 09149




Performance Analytical Inc.

Air Quality Laboratory

RESULTS OF BTU ANALYSIS

PAGE 1 OF 1

Client: TRC Environmental Corporation
Client Sample ID: BFIH-IN-SUMMA-1
PAI Sample ID: P9600715B-001
Test Code: ASTM D3588-91
Analyst: J. Dan Taliaferro
Matrix: Tedlar Bag & Summa Canister
Date Sampled: 4/22/96
Date Received: 4/24/96

Components	Volume %	Weight %
Hydrogen	< 0.01	< 0.01
Oxygen	1.13	1.27
Nitrogen	7.60	7.45
Carbon Monoxide	< 0.01	< 0.01
Methane	50.30	28.23
Carbon Dioxide	40.92	63.02
Hydrogen Sulfide	< 0.01	< 0.01
Ethane	< 0.01	< 0.01
Propane	< 0.01	< 0.01
Butanes	< 0.01	< 0.01
Pentanes	< 0.01	0.01
Hexanes	< 0.01	< 0.01
> Hexanes	0.03	< 0.01
TOTALS	99.98	99.98

Components	Mole %	Weight %
C	23.30	38.40
H	51.40	7.11
O	21.42	47.04
N	3.87	7.45
S	< 0.10	< 0.10

Specific Gravity (Air = 1)	0.9877
* Specific Volume, cu. ft./lb	13.27
* Gross Heating Value, BTU/cu. ft.	501.2
** Gross Heating Value, BTU/cu. ft.	511.6
** Gross Heating Value, BTU/lb.	6786.4
** Net Heating Value, BTU/cu. ft.	460.7
** Net Heating Value, BTU/lb	6111.2
* Net Heating Value, BTU/cu. ft.	451.3
Compressibility Factor "Z" (60 F, 14.696 psig)	0.9970

* - Water Saturated at 0.25636 psig

** - Dry Gas @ 60 F, 14.696 psig

 Verified By: RG

 Date: 5/21/96


Performance Analytical Inc.

Air Quality Laboratory

RESULTS OF BTU ANALYSIS

PAGE 1 OF 1

Client: TRC Environmental Corporation
Client Sample ID: BFIH-IN-SUMMA-2
PAI Sample ID: P9600715B-003
Test Code: ASTM D3588-91
Analyst: J. Dan Taliaferro
Matrix: Tedlar Bag & Summa Canister
Date Sampled: 4/22/96
Date Received: 4/24/96

Components	Volume %	Weight %
Hydrogen	< 0.01	< 0.01
Oxygen	1.03	1.16
Nitrogen	6.77	6.68
Carbon Monoxide	< 0.01	< 0.01
Methane	51.41	29.02
Carbon Dioxide	40.74	63.11
Hydrogen Sulfide	< 0.01	< 0.01
Ethane	< 0.01	< 0.01
Propane	< 0.01	< 0.01
Butanes	< 0.01	< 0.01
Pentanes	< 0.01	0.01
Hexanes	< 0.01	0.01
> Hexanes	0.03	< 0.01
TOTALS	99.98	99.99

Components	Mole %	Weight %
C	23.35	39.02
H	52.11	7.31
O	21.11	47.00
N	3.42	6.67
S	< 0.10	< 0.10

Specific Gravity (Air = 1)	0.9821
* Specific Volume, cu. ft./lb	13.34
* Gross Heating Value, BTU/cu. ft.	512.1
** Gross Heating Value, BTU/cu. ft.	522.8
** Gross Heating Value, BTU/lb.	6975.0
** Net Heating Value, BTU/cu. ft.	470.8
** Net Heating Value, BTU/lb	6281.0
* Net Heating Value, BTU/cu. ft.	461.2
Compressibility Factor "Z" (60 F, 14.696 psig)	0.9970

* = Water Saturated at 0.25636 psig

** = Dry Gas @ 60 F, 14.696 psig

 Verified By: RG

 Date: 5/21/96


Performance Analytical Inc.

Air Quality Laboratory

RESULTS OF BTU ANALYSIS

PAGE 1 OF 1

Client: TRC Environmental Corporation
Client Sample ID: BFIH-IN-SUMMA-3
PAI Sample ID: P9600715B-005
Test Code: ASTM D3588-91
Analyst: J. Dan Taliaferro
Matrix: Tedlar Bag & Summa Canister
Date Sampled: 4/22/96
Date Received: 4/24/96

Components	Volume %	Weight %
Hydrogen	< 0.01	< 0.01
Oxygen	1.18	1.33
Nitrogen	7.04	6.93
Carbon Monoxide	< 0.01	< 0.01
Methane	51.17	28.88
Carbon Dioxide	40.57	62.82
Hydrogen Sulfide	< 0.01	< 0.01
Ethane	< 0.01	< 0.01
Propane	< 0.01	< 0.01
Butanes	< 0.01	< 0.01
Pentanes	< 0.01	0.01
Hexanes	< 0.01	0.01
> Hexanes	0.03	< 0.01
TOTALS	99.99	99.98

Components	Mole %	Weight %
C	23.29	38.83
H	51.99	7.27
O	21.15	46.97
N	3.56	6.93
S	< 0.10	< 0.10

Specific Gravity (Air = 1)	0.9822
* Specific Volume, cu. ft./lb	13.34
* Gross Heating Value, BTU/cu. ft.	509.7
** Gross Heating Value, BTU/cu. ft.	520.3
** Gross Heating Value, BTU/lb.	6941.0
** Net Heating Value, BTU/cu. ft.	468.5
** Net Heating Value, BTU/lb	6250.3
* Net Heating Value, BTU/cu. ft.	459.0
Compressibility Factor "Z" (60 F, 14.696 psig)	0.9970

* = Water Saturated at 0.25636 psig

** = Dry Gas @ 60 F, 14.696 psig

 Verified By: RG

 Date: 5/21/96

CHAIN OF CUSTODY RECORD

Project Name: <u>BFI Halifax</u>			<table border="1"> <tr><th colspan="6">MATRIX</th></tr> <tr><td>Aqueous</td><td>Organic Solvent</td><td>Ash/Soil/Sediment</td><td>Acidic</td><td>Basic</td><td>Other</td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>						MATRIX						Aqueous	Organic Solvent	Ash/Soil/Sediment	Acidic	Basic	Other																															<table border="1"> <tr><th colspan="6">ANALYSIS</th></tr> <tr><td>Trace Metals*</td><td>Mercury</td><td>Hexavalent Chromium</td><td>HCl</td><td>Cl2</td><td>Particulate Matter</td></tr> <tr><td>PCDD/PCDF</td><td>Semi-Volatile Organics</td><td>Volatile Organics</td><td>Physical Parameters*</td><td>TOT</td><td>TOC</td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>						ANALYSIS						Trace Metals*	Mercury	Hexavalent Chromium	HCl	Cl2	Particulate Matter	PCDD/PCDF	Semi-Volatile Organics	Volatile Organics	Physical Parameters*	TOT	TOC																								
MATRIX																																																																																																		
Aqueous	Organic Solvent	Ash/Soil/Sediment							Acidic	Basic	Other																																																																																							
ANALYSIS																																																																																																		
Trace Metals*	Mercury	Hexavalent Chromium	HCl	Cl2	Particulate Matter																																																																																													
PCDD/PCDF	Semi-Volatile Organics	Volatile Organics	Physical Parameters*	TOT	TOC																																																																																													
Project No.: <u>20272</u>																																																																																																		
Sampling Date(s): <u>4/22/96</u>																																																																																																		
Laboratory: <u>PAT</u>																																																																																																		
Laboratory P.O. #:																																																																																																		
Shipping Airbill No.:																																																																																																		
Shipping Date(s): <u>2/23/96</u>																																																																																																		
Shipper's Name: <u>M. O'Brien</u>																																																																																																		
Sample Code	Sampled Date	Container Size	Source Description						Comments																																																																																									
<u>BFIH-IN-SUMMA-1</u>	<u>4/22</u>	<u>SS</u>	<u>P9600715 - 001</u>						<u>7</u>																																																																																									
<u>BFIH-OUT-SUMMA-1</u>	<u>4/22</u>	<u>SS</u>	<u>- 002</u>						<u>191</u>																																																																																									
<u>BFIH-IN-SUMMA-2</u>	<u>4/22</u>	<u>SS</u>	<u>- 003</u>						<u>133</u>																																																																																									
<u>BFIH-OUT-SUMMA-2</u>	<u>4/22</u>	<u>SS</u>	<u>- 004</u>						<u>116</u>																																																																																									
<u>BFIH-IN-SUMMA-3</u>	<u>4/22</u>	<u>SS</u>	<u>- 005</u>						<u>62</u>																																																																																									
<u>BFIH-OUT-SUMMA-3</u>	<u>4/22</u>	<u>SS</u>	<u>- 006</u>						<u>183 822/881</u>																																																																																									
Relinquished by: <u>[Signature]</u>			Date/Time: <u>4/22/96 11:32</u>			Relinquished by:			Date/Time:																																																																																									
Received by: <u>[Signature]</u>			Date/Time: <u>4/24/96 9:00 A.M.</u>			Received by:			Date/Time:																																																																																									
REMARKS (*): <u>Please analyze BFIH-IN-SUMMA-1 for Tot14/Methane-Non Methane. All others, Methane-Non Methane on</u>																																																																																																		

Nº 09149

WHITE - LABORATORY YELLOW - OFFICE COPY PINK - FIELD COPY



PERFORMANCE ID: 818-709-1139 MAY 24 '96 13:27 NO. 012 P. 06

P9600715

[Handwritten marks]

APPENDIX D

CEM CALIBRATION AND DATA SHEETS

**TRC Environmental Corporation
CEM Data Sheet**

Firm BFI Ambient Temp, deg. F = 55
 Location Halifax, Ma MEL Temp, deg. F = 66.4
 Tester William Kissel Bar. Pressure, in Hg = 29.5
 Test No. 1900°F - Run 1 Vacuum Gauge = 5
 Location Flare Outlet Pressure Gauge = 2
 Date April 19, 1996
 TIME 1150-1250

Calibration Gases			
Mid Cal	High Cal	TankID	
		Mid	High
CO	120.0	278.0	ALM038611 ALM063760
O2	10.2	22.3	ALM026170 ALM027466
CO2	10.1	19.8	ALM026170 ALM027466
NOx	180.0	255.0	ALM043688 ALM009773
SO2	84.6	123.0	ALM021721 ALM063760

	(Rack) Analyzer Cal. Response	Initial Values		Final Values		Drift % of Span	Analyzer Range & Units	Avg. Gas Conc.	Effluent Gas Conc.
		System Cal. Response	System Cal. Bias % of Span	System Cal. Response	System Cal. Bias % of Span				
CO	Zero	0	0.0	0	0.0	0.0	ppm	-	-
	Upscale	118	117 -0.3	119	0.3	0.7	300	0	0
O2	Zero	0.04	0.36 1.3	0.43	1.6	0.3	PERCENT	-	-
	Upscale	10.26	10.35 0.4	10.32	0.2	-0.1	25.0	9.93	9.78
CO2	Zero	0.07	0.07 0.0	0.04	-0.2	-0.2	PERCENT	-	-
	Upscale	10.02	9.86 -0.8	9.93	-0.5	0.4	20.0	9.82	10.02
NOx	Zero	0	0.0	0	0.0	0.0	ppm	-	-
	Upscale	181	172 -3.0	170	-3.7	-0.7	300	24	25
SO2	Zero	0.90	0.00 -0.6	1.80	0.6	1.2	ppm	-	-
	Upscale	84.90	79.40 -3.7	79.70	-3.5	0.2	150.0	2.10	1.29
		LIMITS	+/- 5%	+/- 5%	+/- 3%				

	Cal. Back Analyzer Response	Cal. Upstream Analyzer Response	Bias Check % of Span	
				CO
	Upscale	118.0	117.0	-0.3
NOx	Zero	0.0	0.0	0.0
	Upscale	181.0	172.0	-3.0
		LIMIT	+/- 5%	

	ZERO Cal. Gas Analyzer Response	Analyzer Calib. Error	MID Cal. Gas Analyzer Response	Analyzer Calib. Error	HIGH Cal. Gas Analyzer Response	Analyzer Calib. Error
CO	0.0	0.00	118.0	-0.67	279.0	0.33
O2	0.04	0.16	10.26	0.24	22.44	0.56
CO2	0.07	0.35	10.02	-0.40	19.75	-0.25
NOx	0.00	0.00	181.00	0.33	255.00	0.00
SO2	0.9	0.60	84.90	0.20	124.6	1.07
		LIMIT	+/- 2%	+/- 2%	+/- 2%	

40 CFR 60, Appendix A, Method 6C, subpart 4.1

**TRC Environmental Corporation
CEM Data Sheet**

Firm BFI Ambient Temp, deg. F = 55
 Location Halifax, Ma MEL Temp, deg. F = 66.4
 Tester William Kissel Bar. Pressure, in Hg = 29.5
 Test No. 1900°F - Run 2 Vacuum Gauge = 5
 Location Flare Outlet Pressure Gauge = 2
 Date April 19, 1996
 TIME 1325-1425

Calibration Gases			
Mid Cal	High Cal	Tank ID	
		Mid	High
CO 120.0	278.0	ALM038611	ALM063760
O2 10.2	22.3	ALM026170	ALM027466
CO2 10.1	19.8	ALM026170	ALM027466
NOx 180.0	255.0	ALM043688	ALM009773
SO2 84.6	123.0	ALM021721	ALM063760

	(Rack) Analyzer Cal. Response	Initial Values		Final Values		Drift % of Span	Analyzer Range & Units	Avg. Gas Conc.	Effluent Gas Conc.
		System Cal. Response	System Cal. Bias % of Span	System Cal. Response	System Cal. Bias % of Span				
CO	Zero	0	0.0	2	0.7	0.7	ppm	-	-
	Upscale	118	119	118	0.0	-0.3	300	0	-1
O2	Zero	0.04	1.6	0.46	1.7	0.1	PERCENT	-	-
	Upscale	10.26	10.32	10.17	-0.4	-0.6	25.0	9.71	9.64
CO2	Zero	0.07	-0.2	0.07	0.0	0.2	PERCENT	-	-
	Upscale	10.02	9.93	9.88	-0.7	-0.3	20.0	9.98	10.18
NOx	Zero	0	0.0	0	0.0	0.0	ppm	-	-
	Upscale	181	-3.7	177	-1.3	2.3	300	23	24
SO2	Zero	0.90	0.6	0.90	0.0	-0.6	ppm	-	-
	Upscale	84.9	-3.5	78.90	-4.0	-0.5	150.0	1.13	-0.24
		LIMITS	+/- 5%	+/- 5%	+/- 3%				

	Cal. Back Analyzer Response	Cal. Upstream Analyzer Response	Bias Check % of Span	
				Zero
CO	Upscale	118.0	117.0	-0.3
NOx	Zero	0.0	0.0	0.0
	Upscale	181.0	170.0	-3.7
LIMIT			+/- 5%	

	ZERO Cal. Gas Analyzer Response	Analyzer Calib. Error	MID Cal. Gas Analyzer Response	Analyzer Calib. Error	HIGH Cal. Gas Analyzer Response	Analyzer Calib. Error
CO	0.0	0.00	118.0	-0.67	279.0	0.33
O2	0.04	0.16	10.26	0.24	22.44	0.56
CO2	0.07	0.35	10.02	-0.40	19.75	-0.25
NOx	0.00	0.00	181.00	0.33	255.00	0.00
SO2	0.9	0.60	84.90	0.20	124.6	1.07
LIMIT		+/- 2%	+/- 2%		+/- 2%	

40 CFR 60, Appendix A, Method 6C, subpart 4.1

TRC Environmental Corporation
CEM Data Sheet

Firm BFI Ambient Temp, deg. F = 70
 Location Halifax, Ma MEL Temp, deg. F = 72
 Tester William Kissel Bar. Pressure, in Hg = 30.15
 Test No. 1500°F - Run 3 Vacuum Gauge = 5
 Location Flare Outlet Pressure Gauge = 2
 Date April 22, 1996
 TIME 1725-1825

Calibration Gases			
Mid Cal	High Cal	Tank ID	
		Mid	High
CO 120.0	278.0	ALM038611	ALM063760
O2 10.2	22.3	ALM026170	ALM027466
CO2 10.1	19.8	ALM026170	ALM027466
NOx 180.0	255.0	ALM043688	ALM009773
SO2 84.6	123.0	ALM021721	ALM063760

	(Rack) Analyzer Cal. Response	Initial Values		Final Values		Drift % of Span	Analyzer Range & Units	Avg. Gas Conc.	Effluent Gas Conc.
		System Cal. Response	System Cal. Bias % of Span	System Cal. Response	System Cal. Bias % of Span				
CO	Zero	0	5	4	1.3	-0.3	ppm	-	-
	Upscale	120	121	121	0.3	0.0	300	17	13
O2	Zero	0.04	0.29	0.34	1.2	0.2	PERCENT	-	-
	Upscale	10.30	10.14	10.13	-0.7	-0.0	25.0	12.52	12.68
CO2	Zero	0.09	0.23	0.29	1.0	0.3	PERCENT	-	-
	Upscale	10.05	9.81	9.84	-1.1	0.1	20.0	7.68	7.84
NOx	Zero	0	0	0	0.0	0.0	ppm	-	-
	Upscale	182	175	177	-1.7	0.7	300	11	11
SO2	Zero	-0.20	1.50	0.50	0.5	-0.7	ppm	-	-
	Upscale	85.20	84.70	84.10	-0.7	-0.4	150.0	0.83	-0.17
LIMITS		+/- 5%		+/- 5%	+/- 3%				

	Cal. Back Analyzer Response	Cal. Upstream Analyzer Response	Bias Check % of Span
CO	Zero	4.0	1.3
	Upscale	120.0	0.3
NOx	Zero	0.0	0.0
	Upscale	182.0	-3.0
LIMIT		+/- 5%	

	ZERO Cal. Gas Analyzer Response	Analyzer Calib. Error	MID Cal. Gas Analyzer Response	Analyzer Calib. Error	HIGH Cal. Gas Analyzer Response	Analyzer Calib. Error
CO	0.0	0.00	120.0	0.00	281.0	1.00
O2	0.04	0.16	10.30	0.40	22.55	1.00
CO2	0.09	0.45	10.05	-0.25	19.76	-0.20
NOx	0.00	0.00	182.00	0.67	255.00	0.00
SO2	-0.2	-0.13	85.20	0.40	125.2	1.47
LIMIT		+/- 2%	+/- 2%		+/- 2%	

40 CFR 60, Appendix A, Method 6C, subpart 4.1

LINE	UNIT	NO.	EXPRESSION	LEFT END	RIGHT END
01	001	001	TLOS AVE 00	0.00	25.00
02	001	002	TLOS AVE 00	0.00	20.00
03	001	003	TLOS AVE 00	0.00	300.00
04	001	004	TLOS AVE 00	0.00	300.00
05	001	005	TLOS AVE 00	0.00	150.00
06	001	006	TLOS AVE 00	0.00	25.00
07	001	007	TLOS AVE 00	0.00	20.00
08	001	008	TLOS AVE 00	0.00	250.00
09	001	009	TLOS AVE 00	0.00	250.00
10	001	010	TLOS AVE 00	0.00	150.00

K01=1.0000	K02=1.0000	K03=1.0000	K04=1.0000	K05=1.0000
K06=1.0000	K07=1.0000	K08=1.0000	K09=1.0000	K10=1.0000
K11=1.0000	K12=1.0000	K13=1.0000	K14=1.0000	K15=1.0000
K16=1.0000	K17=1.0000	K18=1.0000	K19=1.0000	K20=1.0000
K21=1.0000	K22=1.0000	K23=1.0000	K24=1.0000	K25=1.0000
K26=1.0000	K27=1.0000	K28=1.0000	K29=1.0000	K30=1.0000

LINE	ANALOG	INTERPOLATION	ZONE	DIGITAL	MOVE	AVE	MEMORY	WRITE	INTVL	NO.	PARTIAL
01	ON	OFF	175-250	OFF	ON			ON			
02	ON	OFF	175-250	OFF	ON			ON			
03	ON	OFF	175-250	OFF	ON			ON			
04	OFF	OFF	175-250	OFF	ON			ON			
05	OFF	OFF	175-250	OFF	ON			ON			
06	OFF	OFF	175-250	OFF	ON			ON			
07	OFF	OFF	175-250	OFF	ON			ON			
08	OFF	OFF	175-250	OFF	ON			ON			
09	OFF	OFF	175-250	OFF	ON			ON			
10	OFF	OFF	175-250	OFF	ON			ON			
11	OFF	OFF	175-250	OFF	ON			ON			
12	OFF	OFF	175-250	OFF	ON			ON			
13	OFF	OFF	175-250	OFF	ON			ON			
14	OFF	OFF	175-250	OFF	ON			ON			
15	OFF	OFF	175-250	OFF	ON			ON			
16	OFF	OFF	175-250	OFF	ON			ON			
17	OFF	OFF	175-250	OFF	ON			ON			
18	OFF	OFF	175-250	OFF	ON			ON			
19	OFF	OFF	175-250	OFF	ON			ON			
20	OFF	OFF	175-250	OFF	ON			ON			
21	OFF	OFF	175-250	OFF	ON			ON			
22	OFF	OFF	175-250	OFF	ON			ON			
23	OFF	OFF	175-250	OFF	ON			ON			
24	OFF	OFF	175-250	OFF	ON			ON			
25	OFF	OFF	175-250	OFF	ON			ON			
26	OFF	OFF	175-250	OFF	ON			ON			
27	OFF	OFF	175-250	OFF	ON			ON			
28	OFF	OFF	175-250	OFF	ON			ON			
29	OFF	OFF	175-250	OFF	ON			ON			
30	OFF	OFF	175-250	OFF	ON			ON			

MESSAGE	TYPE	TRC	ENV.	MESSAGE	PROG
	CONT 1				
	CONT 2				
	CONT 3				
	CONT 4				
	CONT 5				
	CONT 6				
	CONT 7				
	CONT 8				
	CONT 9				
	CONT 10				

Handwritten notes: "STL" and "Klitax" with arrows pointing to the message table.

RESPONSE
Time Check
4/18/96

04% CO2 1hr -0.03% CO 1hr -7ppmv NOx 1hr
 Apr. 18 09:36
 TRC ENVIRONMENTAL CORPORATION
 25.00
 409:35 500mm/02
 MANUAL Apr. 18, 96 09:33
 CO2 21.03% CO2 -0.03% CO -6ppmv NOx 0ppmv
 SO2 -1.1PPM CO2 1hr 21.03% CO2 1hr -0.03% CO 1hr 0ppmv
 NOx 1hr 0ppmv SO2 1hr -4.2ppmv CO2 1hr 10.30% CO2 1hr -0.07%
 CO 1hr 22ppmv NOx 1hr 0ppmv SO2 1hr 34.5EPPM

TRC Env. Merrimac Paper
 Apr. 18, 96 09:33

0 10 20 30 40 50 60 70 80 90 100
 SCRN INTVL TREND INTVL CHART SPEED LOGGING INTVL
 1SEC AUTO 2SEC (1) (2) (1-1) (1-2) (2) (3)
 500 100mm/h 00:01 01:00 01:00 00:00

CH	TAG NO.	RANGE	LEFT END	RIGHT END	SCALE LEFT	RIGHT
01	02	2V	0.0000	1.0000 V	0.00	25.00 %
02	CO2	2V	0.0000	1.0000 V	0.00	20.00 %
03	CO	2V	0.0000	0.6000 V	0	300 ppmv
04	NOx	20V	0.000	6.0000 V	0	300 ppmv
05	NOx	SKIP				
06	THC3	SKIP				
07	THC4	SKIP				
08	SO2	2V	0.0000	0.2975 V	0.0	150.0 PPM
09		SKIP				
10		SKIP				
11	02 2	SKIP				
12	THC2	SKIP				
13	CH4 2	SKIP				
14	NCH42	SKIP				
15	THC1	SKIP				
16	CH41	SKIP				
17	NCH41	SKIP				
18		SKIP				
19		SKIP				
20		SKIP				
CH	TAG NO.	EXPRESSION	LEFT END	RIGHT END		
31	02 1hr	T105 AVE(01)	0.00	25.00 %		
32	CO2 1hr	T105 AVE(02)	0.00	20.00 %		
33	CO 1hr	T105 AVE(03)	0	300 ppmv		
34	NOx 1hr	T105 AVE(04)	0	300 ppmv		
35	CO2 1hr	T105 AVE(05)	0.0	150.0 ppm		
41	02 1hr	T105 AVE(01)	0.00	25.00 %		
42	CO2 1hr	T105 AVE(02)	0.00	20.00 %		
43	CO 1hr	T105 AVE(03)	0	300 ppmv		
44	NOx 1hr	T105 AVE(04)	0	300 ppmv		

MP	24.74%	CO2	-0.02%	CO	-0.05%	NOx	-0.02%
NOx 1hr	14.8ppm	S02 1hr	5.8ppm	O2 1hr	18.26%	CO 1hr	-0.03%
CO 1hr	2ppm	NOx 1hr	11ppm	S02 1hr	-4.57ppm	CO 1hr	-0.03%
MANUAL	Apr. 18.96	10:00					
O2	21.01%	CO2	-0.07%	CO	-0.05%	NOx	175ppm
S02	-4.57ppm	CO 1hr	20.64%	CO2 1hr	-0.02%	CO 1hr	-2ppm
NOx 1hr	10ppm	S02 1hr	-0.18ppm	O2 1hr	18.45%	CO 1hr	-0.03%
CO 1hr	3ppm	NOx 1hr	11ppm	S02 1hr	-4.57ppm	CO 1hr	-0.03%
MANUAL	Apr. 18.96	10:59					
O2	21.01%	CO2	-0.02%	CO	-0.05%	NOx	1ppm
S02	-4.57ppm	CO 1hr	20.64%	CO2 1hr	-0.02%	CO 1hr	-2ppm
NOx 1hr	2ppm	S02 1hr	-0.18ppm	O2 1hr	18.71%	CO 1hr	-0.02%
CO 1hr	3ppm	NOx 1hr	10ppm	S02 1hr	-4.55ppm	CO 1hr	-0.02%
MANUAL	Apr. 18.96	10:58					
O2	21.01%	CO2	-0.07%	CO	-0.05%	NOx	175ppm
S02	-4.57ppm	CO 1hr	20.64%	CO2 1hr	-0.07%	CO 1hr	-2ppm
NOx 1hr	10ppm	S02 1hr	-0.18ppm	O2 1hr	18.34%	CO 1hr	-0.02%
CO 1hr	3ppm	NOx 1hr	10ppm	S02 1hr	-4.55ppm	CO 1hr	-0.02%
MANUAL	Apr. 18.96	10:57					
O2	21.02%	CO2	-0.03%	CO	-0.05%	NOx	80
S02	-4.57ppm	CO 1hr	20.64%	CO2 1hr	-0.03%	CO 1hr	90
NOx 1hr	2ppm	S02 1hr	-0.18ppm	O2 1hr	19.19%	CO 1hr	-0.02%
CO 1hr	3ppm	NOx 1hr	5ppm	S02 1hr	-4.55ppm	CO 1hr	-0.02%
MANUAL	Apr. 18.96	10:55					
O2	21.08%	CO2	-0.08%	CO	-0.05%	NOx	131ppm
S02	-4.77ppm	CO 1hr	0.50%	CO2 1hr	-0.07%	CO 1hr	-2ppm
NOx 1hr	10ppm	S02 1hr	-0.15ppm	O2 1hr	19.45%	CO 1hr	-0.02%
CO 1hr	3ppm	NOx 1hr	0ppm	S02 1hr	-4.55ppm	CO 1hr	-0.02%
MANUAL	Apr. 18.96	10:53					
O2	21.02%	CO2	-0.07%	CO	-0.05%	NOx	0ppm
S02	-4.77ppm	CO 1hr	5.07%	CO2 1hr	-0.05%	CO 1hr	-2ppm
NOx 1hr	0ppm	S02 1hr	-0.15ppm	O2 1hr	20.13%	CO 1hr	-0.02%
CO 1hr	3ppm	NOx 1hr	0ppm	S02 1hr	-4.55ppm	CO 1hr	-0.02%

1100:02
 1100:02
 1059:16
 1059:02
 1058:14
 1058:00
 1057:20
 1057:10
 1056:10
 1055:03
 START 1054
 1053:41 50
 START @ 1053
 TURNED OFF

0 10 20 30 40 50 60 70 80 90 100

20	94%	CO2 1hr Apr. 18 15:23	0.14%	CO 1hr	6ppmv	NOx 1hr	0ppmv	02
18	61%	CO2 1hr Apr. 18 15:22	0.14%	CO 1hr	3ppmv	NOx 1hr	0ppmv	
1	19%	CO2 1hr Apr. 18 15:21	0.09%	CO 1hr	8ppmv	NOx 1hr	0ppmv	20.00
20	92%	CO2 1hr Apr. 18 15:19	0.15%	CO 1hr	5ppmv	NOx 1hr	0ppmv	
18	26%	CO2 1hr Apr. 18 15:18	0.51%	CO 1hr	6ppmv	NOx 1hr	0ppmv	
20	87%	CO2 1hr Apr. 18 15:18	0.15%	CO 1hr	6ppmv	NOx 1hr	0ppmv	
20	90%	CO2 1hr Apr. 18 15:17	0.14%	CO 1hr	4ppmv	NOx 1hr	0ppmv	
10	95%	CO2 1hr Apr. 18 15:16	0.12%	CO 1hr	5ppmv	NOx 1hr	0ppmv	
7	89%	CO2 1hr Apr. 18 15:15	0.11%	CO 1hr	5ppmv	NOx 1hr	0ppmv	TRC ENVIRONMENTAL CORPORATION 25.00
18	00%	CO2 1hr Apr. 18 15:14	0.14%	CO 1hr	4ppmv	NOx 1hr	0ppmv	
1	06%	CO2 1hr Apr. 18 15:13	0.11%	CO 1hr	4ppmv	NOx 1hr	0ppmv	
3	64%	CO2 1hr Apr. 18 15:12	0.52%	CO 1hr	6ppmv	NOx 1hr	17ppmv	
20	92%	CO2 1hr Apr. 18 15:11	0.14%	CO 1hr	4ppmv	NOx 1hr	0ppmv	
20	93%	CO2 1hr Apr. 18 15:10	0.15%	CO 1hr	4ppmv	NOx 1hr	1ppmv	
9	09%	CO2 1hr Apr. 18 15:09	0.15%	CO 1hr	5ppmv	NOx 1hr	48ppmv	12.0 30.0 PPM
4	51%	CO2 1hr Apr. 18 15:08	1.54%	CO 1hr	8ppmv	NOx 1hr	75ppmv	
12	75%	CO2 1hr Apr. 18 15:07	7.58%	CO 1hr	4ppmv	NOx 1hr	0ppmv	
10	34%	CO2 1hr Apr. 18 15:06	9.79%	CO 1hr	7ppmv	NOx 1hr	0ppmv	
3	45%	CO2 1hr Apr. 18 15:05	2.50%	CO 1hr	7ppmv	NOx 1hr	0ppmv	
1	14%	CO2 1hr Apr. 18 15:04	0.09%	CO 1hr	8ppmv	NOx 1hr	0ppmv	
8	62%	CO2 1hr Apr. 18 15:03	1.44%	CO 1hr	10ppmv	NOx 1hr	3ppmv	30 ppmv

MANUAL		Apr. 18, 98	11:39	CO2	125.80PPM	CO	0.11%	CO 1hr	270ppmv	NOx	0ppmv	SO2	80.31%	90	100
0	SO2	125.80PPM	CO2 1hr	0.11%	CO 1hr	270ppmv	NOx	0ppmv	372ppmv	CO 1hr	80.31%	90	100	SO2 SPAN 123	
0	CO 1hr	270ppmv	NOx 1hr	0.11%	CO 1hr	460%	CO2 1hr	40.72PPM	CO 1hr	80.31%	90	100			

0	04%	CO2 1hr Apr. 18 11:38	0.15%	CO 1hr	101ppmv	NOx 1hr	3ppmv	30 ppmv
---	-----	--------------------------	-------	--------	---------	---------	-------	------------

MANUAL		Apr. 18, 98	11:37	CO2	85.2PPM	CO	0.11%	CO 1hr	50ppmv	NOx	1ppmv	SO2	84.6 MID
SO2	85.2PPM	CO2 1hr	0.11%	CO 1hr	0.11%	CO 1hr	60ppmv	NOx 1hr	4.55%	CO2 1hr	0.33%	84.6 MID	
NOx 1hr	1ppmv	CO2 1hr	0.11%	CO 1hr	60ppmv	NOx 1hr	33.49PPM	CO2 1hr	0.33%	84.6 MID			

4	05%	CO2 1hr Apr. 18 11:37	0.15%	CO 1hr	30ppmv	NOx 1hr	0ppmv	
---	-----	--------------------------	-------	--------	--------	---------	-------	--

19	74%	CO2 1hr Apr. 18 11:36	0.18%	CO 1hr	34ppmv	NOx 1hr	0ppmv	20.00
----	-----	--------------------------	-------	--------	--------	---------	-------	-------

MANUAL		Apr. 18, 98	11:34	CO2	94.4PPM	CO	0.12%	CO 1hr	51ppmv	NOx	1ppmv	CO	10.12
CO2	94.4PPM	CO 1hr	0.12%	CO 1hr	0.12%	CO 1hr	0.12%	0.12%	51ppmv	NOx	1ppmv	CO	10.12


9	80%	CO2 1hr	Apr. 18 17:44	9.81%	CO 1hr	-1ppmv	NOx 1hr	23ppmv		
9	92%	CO2 1hr	Apr. 18 17:47	9.81%	CO 1hr	-1ppmv	NOx 1hr	23ppmv		
9	76%	CO2 1hr	Apr. 18 17:46	9.95%	CO 1hr	-1ppmv	NOx 1hr	23ppmv		
10	27%	CO2 1hr	Apr. 18 17:46	9.55%	CO 1hr	-1ppmv	NOx 1hr	23ppmv		
9	36%	CO2 1hr	Apr. 18 17:44	10.50%	CO 1hr	-1ppmv	NOx 1hr	24ppmv		
10	32%	CO2 1hr	Apr. 18 17:43	9.52%	CO 1hr	-1ppmv	NOx 1hr	22ppmv		
10	00%	CO2 1hr	Apr. 18 17:42	9.71%	CO 1hr	-1ppmv	NOx 1hr	23ppmv		76.90
9	43%	CO2 1hr	Apr. 18 17:41	9.89%	CO 1hr	-2ppmv	NOx 1hr	24ppmv		
9	15%	CO2 1hr	Apr. 18 17:40	10.48%	CO 1hr	-2ppmv	NOx 1hr	25ppmv		
9	63%	CO2 1hr	Apr. 18 17:39	10.01%	CO 1hr	-2ppmv	NOx 1hr	24ppmv		
9	77%	CO2 1hr	Apr. 18 17:38	10.47%	CO 1hr	-2ppmv	NOx 1hr	24ppmv		
10	27%	CO2 1hr	Apr. 18 17:37	9.55%	CO 1hr	-2ppmv	NOx 1hr	22ppmv		
9	97%	CO2 1hr	Apr. 18 17:36	10.09%	CO 1hr	-2ppmv	NOx 1hr	24ppmv		25.00
9	50%	CO2 1hr	Apr. 18 17:35	10.05%	CO 1hr	-2ppmv	NOx 1hr	24ppmv		
9	09%	CO2 1hr	Apr. 18 17:34	10.54%	CO 1hr	-1ppmv	NOx 1hr	26ppmv		
8	72%	CO2 1hr	Apr. 18 17:32	10.30%	CO 1hr	-1ppmv	NOx 1hr	26ppmv		
8	90%	CO2 1hr	Apr. 18 17:32	10.73%	CO 1hr	-1ppmv	NOx 1hr	25ppmv		
9	50%	CO2 1hr	Apr. 18 17:31	10.13%	CO 1hr	-1ppmv	NOx 1hr	24ppmv		
9	34%	CO2 1hr	Apr. 18 17:30	10.30%	CO 1hr	-1ppmv	NOx 1hr	24ppmv		
9	58%	CO2 1hr	Apr. 18 17:29	10.05%	CO 1hr	-1ppmv	NOx 1hr	24ppmv		
9	06%	CO2 1hr	Apr. 18 17:28	10.55%	CO 1hr	-1ppmv	NOx 1hr	26ppmv		
8	94%	CO2 1hr	Apr. 18 17:27	10.55%	CO 1hr	0ppmv	NOx 1hr	25ppmv		
9	62%	CO2 1hr	Apr. 18 17:26	9.90%	CO 1hr	-1ppmv	NOx 1hr	23ppmv		
10	55%	CO2 1hr	Apr. 18 17:25	9.55%	CO 1hr	0ppmv	NOx 1hr	22ppmv		
9	71%	CO2 1hr	Apr. 18 17:24	9.93%	CO 1hr	2ppmv	NOx 1hr	24ppmv		
9	78%	CO2 1hr	Apr. 18 17:23	10.09%	CO 1hr	20ppmv	NOx 1hr	19ppmv		
20	53%	CO2 1hr	Apr. 18 17:22	0.55%	CO 1hr	1ppmv	NOx 1hr	0ppmv		
20	94%	CO2 1hr	Apr. 18 17:21	0.17%	CO 1hr	1ppmv	NOx 1hr	0ppmv		
20	37%	CO2 1hr	Apr. 18 17:19	0.15%	CO 1hr	22ppmv	NOx 1hr	0ppmv		
12	31%	CO2 1hr	Apr. 18 17:18	1.24%	CO 1hr	11ppmv	NOx 1hr	20ppmv		
0	97%	CO2 1hr	Apr. 18 17:18	0.11%	CO 1hr	63ppmv	NOx 1hr	1ppmv		

STOP
1950°F
GOING TO
1400°F

IN
STACK
DIAGNOSTIC
1700
1950°F

AVERAGE		Apr. 18 1996		17:18							
CO2	0.37%	CO2	0.11%	CO	0.70%	NOx	1.25%	SO2	5.00 PPM		
CO	24.52 PPM	SO2	85.4 PPM	CO2	12.22%	CO	1.25%				
NOx	11 PPM	NOx	2.40 PPM	NOx	5.03 PPM	CO2	70	80	90	100	

13	52%	CO2	1mm	9mm	18	18:00	6.94%	CO	1mm	30ppm	NOx	1mm	9ppm		
13	53%	CO2	1mm	9mm	18	18:05	6.85%	CO	1mm	34ppm	NOx	1mm	11ppm		
12	68%	CO2	1mm	9mm	18	18:10	7.55%	CO	1mm	97ppm	NOx	1mm	12ppm		
13	57%	CO2	1mm	9mm	18	18:15	6.45%	CO	1mm	45ppm	NOx	1mm	10ppm		
12	53%	CO2	1mm	9mm	18	18:20	7.95%	CO	1mm	11ppm	NOx	1mm	15ppm		
13	27%	CO2	1mm	9mm	18	18:25	7.12%	CO	1mm	205ppm	NOx	1mm	10ppm		
15	64%	CO2	1mm	9mm	18	18:30	7.75%	CO	1mm	93ppm	NOx	1mm	14ppm		300
12	63%	CO2	1mm	9mm	18	18:35	7.58%	CO	1mm	68ppm	NOx	1mm	13ppm		
13	46%	CO2	1mm	9mm	18	18:40	6.96%	CO	1mm	252ppm	NOx	1mm	10ppm		
13	43%	CO2	1mm	9mm	18	18:45	6.94%	CO	1mm	225ppm	NOx	1mm	11ppm		
13	44%	CO2	1mm	9mm	18	18:50	6.97%	CO	1mm	167ppm	NOx	1mm	11ppm		
13	39%	CO2	1mm	9mm	18	18:55	7.06%	CO	1mm	138ppm	NOx	1mm	11ppm		
13	35%	CO2	1mm	9mm	18	18:58	7.05%	CO	1mm	161ppm	NOx	1mm	11ppm		300
13	40%	CO2	1mm	9mm	18	18:47	7.02%	CO	1mm	230ppm	NOx	1mm	10ppm		
13	25%	CO2	1mm	9mm	18	18:46	7.14%	CO	1mm	52ppm	NOx	1mm	12ppm		
12	27%	CO2	1mm	10mm	18	18:48	7.10%	CO	1mm	96ppm	NOx	1mm	13ppm		
13	32%	CO2	1mm	9mm	18	18:44	7.07%	CO	1mm	218ppm	NOx	1mm	11ppm		
14	67%	CO2	1mm	9mm	18	18:43	6.47%	CO	1mm	58ppm	NOx	1mm	11ppm		
13	69%	CO2	1mm	9mm	18	18:42	6.74%	CO	1mm	257ppm	NOx	1mm	10ppm		20.00
14	65%	CO2	1mm	9mm	18	18:41	6.47%	CO	1mm	207ppm	NOx	1mm	9ppm		
13	36%	CO2	1mm	9mm	18	18:40	7.10%	CO	1mm	70ppm	NOx	1mm	12ppm		
13	58%	CO2	1mm	9mm	18	18:39	7.02%	CO	1mm	177ppm	NOx	1mm	11ppm		
13	4%	CO2	1mm	9mm	18	18:38	7.24%	CO	1mm	41ppm	NOx	1mm	13ppm		
12	74%	CO2	1mm	9mm	18	18:37	7.51%	CO	1mm	100ppm	NOx	1mm	12ppm		
13	75%	CO2	1mm	9mm	18	18:36	6.55%	CO	1mm	57ppm	NOx	1mm	12ppm		25.00
12	10%	CO2	1mm	9mm	18	18:35	8.12%	CO	1mm	131ppm	NOx	1mm	3ppm		
13	27%	CO2	1mm	9mm	18	18:34	7.11%	CO	1mm	51ppm	NOx	1mm	13ppm		
12	73%	CO2	1mm	9mm	18	18:33	7.51%	CO	1mm	60ppm	NOx	1mm	2ppm		
14	52%	CO2	1mm	9mm	18	18:32	6.81%	CO	1mm	323ppm	NOx	1mm	4ppm		
13	63%	CO2	1mm	9mm	18	18:31	6.72%	CO	1mm	62ppm	NOx	1mm	11ppm		
13	63%	CO2	1mm	9mm	18	18:30	7.33%	CO	1mm	43ppm	NOx	1mm	13ppm		15.00
13	29%	CO2	1mm	9mm	18	18:29	7.10%	CO	1mm	251ppm	NOx	1mm	11ppm		
13	40%	CO2	1mm	9mm	18	18:28	6.96%	CO	1mm	223ppm	NOx	1mm	11ppm		
13	28%	CO2	1mm	10mm	18	18:20	7.14%	CO	1mm	55ppm	NOx	1mm	12ppm		



1450°F

Time	CO2 (ppm)	CO (ppm)	NOx (ppm)	SO2 (ppm)	PM10 (µg/m³)	PM2.5 (µg/m³)	Temperature (°C)	Humidity (%)	Wind Speed (m/s)	Wind Direction	Pressure (hPa)	Other
14:11	434.7	0.18	0.00	0.00	0.00	0.00	18.24	61.8	0.0	0.0	1013.0	
14:12	434.7	0.18	0.00	0.00	0.00	0.00	18:24	61.8	0.0	0.0	1013.0	
14:13	434.7	0.18	0.00	0.00	0.00	0.00	18:24	61.8	0.0	0.0	1013.0	
12:38	434.7	0.18	0.00	0.00	0.00	0.00	18:24	61.8	0.0	0.0	1013.0	
10:05	434.7	0.18	0.00	0.00	0.00	0.00	18:21	61.7	0.0	0.0	1013.0	
10:04	434.7	0.18	0.00	0.00	0.00	0.00	18:19	61.7	0.0	0.0	1013.0	
10:02	434.7	0.18	0.00	0.00	0.00	0.00	18:19	61.7	0.0	0.0	1013.0	
10:01	434.7	0.18	0.00	0.00	0.00	0.00	18:18	61.7	0.0	0.0	1013.0	
9:58	434.7	0.18	0.00	0.00	0.00	0.00	18:17	61.7	0.0	0.0	1013.0	
10:18	434.7	0.18	0.00	0.00	0.00	0.00	18:16	61.7	0.0	0.0	1013.0	
9:52	434.7	0.18	0.00	0.00	0.00	0.00	18:15	61.7	0.0	0.0	1013.0	
10:01	434.7	0.18	0.00	0.00	0.00	0.00	18:14	61.7	0.0	0.0	1013.0	
10:20	434.7	0.18	0.00	0.00	0.00	0.00	18:13	61.7	0.0	0.0	1013.0	
10:05	434.7	0.18	0.00	0.00	0.00	0.00	18:12	61.7	0.0	0.0	1013.0	
10:10	434.7	0.18	0.00	0.00	0.00	0.00	18:11	61.7	0.0	0.0	1013.0	
10:13	434.7	0.18	0.00	0.00	0.00	0.00	18:10	61.7	0.0	0.0	1013.0	
10:02	434.7	0.18	0.00	0.00	0.00	0.00	18:09	61.7	0.0	0.0	1013.0	
10:25	434.7	0.18	0.00	0.00	0.00	0.00	18:08	61.7	0.0	0.0	1013.0	
9:54	434.7	0.18	0.00	0.00	0.00	0.00	18:07	61.7	0.0	0.0	1013.0	
10:01	434.7	0.18	0.00	0.00	0.00	0.00	18:06	61.7	0.0	0.0	1013.0	
10:43	434.7	0.18	0.00	0.00	0.00	0.00	18:05	61.7	0.0	0.0	1013.0	
9:55	434.7	0.18	0.00	0.00	0.00	0.00	18:04	61.7	0.0	0.0	1013.0	
10:11	434.7	0.18	0.00	0.00	0.00	0.00	18:03	61.7	0.0	0.0	1013.0	
9:59	434.7	0.18	0.00	0.00	0.00	0.00	18:02	61.7	0.0	0.0	1013.0	
9:50	434.7	0.18	0.00	0.00	0.00	0.00	18:01	61.7	0.0	0.0	1013.0	
9:18	434.7	0.18	0.00	0.00	0.00	0.00	18:00	61.7	0.0	0.0	1013.0	
9:17	434.7	0.18	0.00	0.00	0.00	0.00	17:59	61.7	0.0	0.0	1013.0	
10:20	434.7	0.18	0.00	0.00	0.00	0.00	17:58	61.7	0.0	0.0	1013.0	
9:45	434.7	0.18	0.00	0.00	0.00	0.00	17:57	61.7	0.0	0.0	1013.0	
9:51	434.7	0.18	0.00	0.00	0.00	0.00	17:56	61.7	0.0	0.0	1013.0	
10:34	434.7	0.18	0.00	0.00	0.00	0.00	17:55	61.7	0.0	0.0	1013.0	
9:40	434.7	0.18	0.00	0.00	0.00	0.00	17:54	61.7	0.0	0.0	1013.0	
10:02	434.7	0.18	0.00	0.00	0.00	0.00	17:53	61.7	0.0	0.0	1013.0	
9:59	434.7	0.18	0.00	0.00	0.00	0.00	17:52	61.7	0.0	0.0	1013.0	
9:57	434.7	0.18	0.00	0.00	0.00	0.00	17:52	61.7	0.0	0.0	1013.0	

TRC ENVIRONMENTAL CORPORATION

303

23

22

22

23

23

22

23

23

22

24

22

23

22

23

23

24

24

24

22

25

23

22

23

21

25

23

RRRPPH	Apr. 9, 96	08:34	19.78	CO	0.0000	NOx	0.0000	
SO2	0.0000	CO2	12.58%	CO	1hr	19.72%	CO	1hr
NOx	0.0000	SO2	1.0000	CO	1hr	17.46%	CO	1hr
NOx	0.0000	NOx	0.0000	SO2	1hr	1.0000	NOx	1hr
RRRPPH	Apr. 9, 96	08:37	19.02%	CO	0.0000	NOx	0.0000	
SO2	0.0000	CO2	12.58%	CO	1hr	17.46%	CO	1hr
NOx	0.0000	SO2	1.0000	CO	1hr	17.46%	CO	1hr
NOx	0.0000	NOx	0.0000	SO2	1hr	1.0000	NOx	1hr
RRRPPH	Apr. 9, 96	08:31	18.07%	CO	0.0000	NOx	0.0000	
SO2	0.0000	CO2	12.58%	CO	1hr	18.13%	CO	1hr
NOx	0.0000	SO2	1.0000	CO	1hr	18.20%	CO	1hr
NOx	0.0000	NOx	0.0000	SO2	1hr	0.9400	NOx	1hr

O₂/CO₂ span
2-3/98

O₂/CO₂ 14.2/10.1
CO zero


O₂/CO₂/SO₂/NO_x
Direct zero

NOx 019:20 003:50 500ppm/h

CAL'S FOR 4/9/96

0 10 20 30 40 50 60 70 80 90 100

13	26%	CO2 1hr	7.11%	CO 1hr	1.2000	NOx 1hr	12.0000	
13	70%	CO2 1hr	6.74%	CO 1hr	2.6600	NOx 1hr	9.0000	300 ppm SO ₂
13	65%	CO2 1hr	6.78%	CO 1hr	2.1000	NOx 1hr	10.0000	
13	53%	CO2 1hr	6.89%	CO 1hr	1.4400	NOx 1hr	11.0000	CO ₂
13	37%	CO2 1hr	6.86%	CO 1hr	1.3900	NOx 1hr	10.0000	
13	52%	CO2 1hr	6.91%	CO 1hr	820.00	NOx 1hr	11.0000	CO ₂
13	52%	CO2 1hr	6.89%	CO 1hr	1.0000	NOx 1hr	11.0000	
13	52%	CO2 1hr	6.81%	CO 1hr	2.3600	NOx 1hr	10.0000	20.00
13	52%	CO2 1hr	6.75%	CO 1hr	2.2300	NOx 1hr	10.0000	
13	47%	CO2 1hr	6.76%	CO 1hr	2.2600	NOx 1hr	10.0000	
13	50%	CO2 1hr	6.91%	CO 1hr	6.4000	NOx 1hr	11.0000	
13	57%	CO2 1hr	7.01%	CO 1hr	5.9000	NOx 1hr	12.0000	
13	51%	CO2 1hr	7.10%	CO 1hr	7.0000	NOx 1hr	12.0000	CO ₂
13	52%	CO2 1hr	6.81%	CO 1hr	2.2400	NOx 1hr	10.0000	25.00
13	50%	CO2 1hr	6.85%	CO 1hr	7.5000	NOx 1hr	11.0000	
13	30%	CO2 1hr	7.10%	CO 1hr	7.5000	NOx 1hr	12.0000	
13	41%	CO2 1hr	6.70%	CO 1hr	2.2000	NOx 1hr	10.0000	



0.5 ppm	002 1hr Apr. 19 11:41	0.22%	CO 1hr	0ppmv	NOx 1hr	57ppmv				
21.0 ppm	002 1hr Apr. 19 11:39	0.09%	CO 1hr	1ppmv	NOx 1hr	0ppmv		02		
20.7 ppm	002 1hr Apr. 19 11:37	0.05%	CO 1hr	1ppmv	NOx 1hr	0ppmv		130.0 0ppmv		
20.3 ppm	002 1hr Apr. 19 11:35	0.09%	CO 1hr	1ppmv	NOx 1hr	0ppmv				
20.9 ppm	002 1hr Apr. 19 11:33	0.12%	CO 1hr	1ppmv	NOx 1hr	0ppmv				
20.0 ppm	002 1hr Apr. 19 11:31	0.10%	CO 1hr	2ppmv	NOx 1hr	0ppmv		300 0ppmv		
77.7 ppm	002 1hr Apr. 19 11:29	0.03%	CO 1hr	0ppmv	NOx 1hr	1ppmv				
4.4 ppm	002 1hr Apr. 19 11:27	0.05%	CO 1hr	17ppmv	NOx 1hr	133ppmv				
0.2 ppm	002 1hr Apr. 19 11:25	0.04%	CO 1hr	2ppmv	NOx 1hr	172ppmv	80	90		
MANUAL 02	Apr. 19 98 11:24	0.04%	CO	2ppmv	NOx	172ppmv				
SO2	0.2PPM	02 1hr	0.33%	002 1hr	0.04%	CO 1hr	2ppmv			
NOx 1hr	172ppmv	302 1hr	0.3ppm	02 1hr	2.88%	CO2 1hr	0.37%			
CO 1hr	2ppmv	NOx 1hr	96ppmv	302 1hr	0.24PPM					
0.3 ppm	002 1hr Apr. 19 11:23	0.04%	CO 1hr	2ppmv	NOx 1hr	0ppmv		20.00 %		
MANUAL 02	Apr. 19 98 11:22	0.04%	CO	1ppmv	NOx	0ppmv				
SO2	0.2PPM	02 1hr	0.33%	002 1hr	0.04%	CO 1hr	2ppmv			
NOx 1hr	0ppmv	302 1hr	0.3ppm	02 1hr	3.25%	CO2 1hr	0.42%			
CO 1hr	2ppmv	NOx 1hr	95ppmv	302 1hr	0.24PPM					
3.1 ppm	002 1hr Apr. 19 11:21	0.08%	CO 1hr	0ppmv	NOx 1hr	182ppmv		25.00 %		
MANUAL 02	Apr. 19 98 11:20	0.02%	CO	1ppmv	NOx	181ppmv				
SO2	-0.2PPM	02 1hr	0.01%	002 1hr	0.02%	CO 1hr	0ppmv			
NOx 1hr	180ppmv	302 1hr	-0.2ppm	02 1hr	3.55%	CO2 1hr	0.49%			
CO 1hr	1ppmv	NOx 1hr	118ppmv	302 1hr	0.21PPM					
0.01%	002 1hr Apr. 19 11:20	0.02%	CO 1hr	0ppmv	NOx 1hr	251ppmv				
MANUAL 02	Apr. 19 98 11:19	0.02%	CO	0ppmv	NOx	255ppmv				
SO2	-0.1PPM	02 1hr	0.01%	002 1hr	0.02%	CO 1hr	1ppmv			
NOx 1hr	252ppmv	302 1hr	-0.2ppm	02 1hr	3.54%	CO2 1hr	0.54%			
CO 1hr	2ppmv	NOx 1hr	97ppmv	302 1hr	0.25PPM					
0.01%	002 1hr Apr. 19 11:19	0.03%	CO 1hr	0ppmv	NOx 1hr	132ppmv				
0.2 ppm	10	20	30	40	50	60	70	80	90	100

NOx 180

NOx 545 zero

NOx 180 DIRECT

NOx 255 DIRECT

10.55%	002 1m	9.43%	CO 1m	0ppmv	NOx 1m	23ppmv			
9.62%	002 1m	9.84%	CO 1m	0ppmv	NOx 1m	25ppmv			
9.57%	002 1m	10.70%	CO 1m	0ppmv	NOx 1m	27ppmv			
9.57%	002 1m	9.78%	CO 1m	0ppmv	NOx 1m	24ppmv			
9.90%	002 1m	9.84%	CO 1m	0ppmv	NOx 1m	24ppmv			300 ppmv
9.62%	002 1m	10.05%	CO 1m	0ppmv	NOx 1m	26ppmv			
9.55%	002 1m	10.52%	CO 1m	0ppmv	NOx 1m	26ppmv			
100.21%	10.2 1m	20.56%	30 CO 1m 40	0ppmv	NOx 1m	247ppmv	80	90	300 ppmv
10.24%	002 1m	9.59%	CO 1m	0ppmv	NOx 1m	23ppmv			
9.65%	002 1m	10.10%	CO 1m	0ppmv	NOx 1m	24ppmv			
8.92%	002 1m	10.71%	CO 1m	0ppmv	NOx 1m	27ppmv			20.00%
10.02%	002 1m	9.75%	CO 1m	0ppmv	NOx 1m	26ppmv			
10.11%	002 1m	9.58%	CO 1m	0ppmv	NOx 1m	24ppmv			
10.44%	002 1m	9.58%	CO 1m	5ppmv	NOx 1m	23ppmv			
9.98%	002 1m	9.78%	CO 1m	0ppmv	NOx 1m	24ppmv			25.00%
9.40%	002 1m	10.48%	CO 1m	0ppmv	NOx 1m	26ppmv			
9.88%	002 1m	9.86%	CO 1m	0ppmv	NOx 1m	25ppmv			
90.72%	10.2 1m	20.98%	30 CO 1m 40	2ppmv	NOx 1m	257ppmv	80	90	400 ppmv

530mm/h
 Arr. 19 12:00
 CO2

TRC ENVIRONMENTAL CORPORATION
 25104

START
 RUN 1
 1950°F

02	0.38%	CO2	0.00%	CO	118PPM	NOx	0PPM		
SO2	0.70PPM	CO2	0.00%	CO	118PPM	NOx	0PPM		
NOx 1hr	0PPM	SO2 1hr	0.00%	CO 1hr	4.43%	CO2 1hr	118PPM		
CO 1hr	13PPM	NOx 1hr	0.00%	CO 1hr	26.48PPM	CO2 1hr	2.98%		CO 120
MANUAL Apr. 19. 96 13:12									
02	0.38%	CO2	0.00%	CO	118PPM	NOx	0PPM		
SO2	70.78PPM	CO2 1hr	0.00%	CO 1hr	0.00%	CO 1hr	118PPM		
NOx 1hr	0PPM	SO2 1hr	78.58PPM	CO 1hr	4.62%	CO2 1hr	118PPM		SO2 84.6
CO 1hr	28PPM	NOx 1hr	24PPM	SO2 1hr	23.80PPM	CO2 1hr	3.12%		
MANUAL Apr. 19. 96 13:10									
02	0.38%	CO2	0.00%	CO	118PPM	NOx	0PPM		
SO2	78.09PPM	CO2 1hr	0.00%	CO 1hr	0.00%	CO 1hr	118PPM		
NOx 1hr	0PPM	SO2 1hr	77.78PPM	CO 1hr	4.51%	CO2 1hr	118PPM		SO2 84.6
CO 1hr	24PPM	NOx 1hr	25PPM	SO2 1hr	20.14PPM	CO2 1hr	3.33%		
MANUAL Apr. 19. 96 13:03									
02	0.38%	CO2	0.00%	CO	118PPM	NOx	0PPM		
SO2	0.59PPM	CO2 1hr	0.00%	CO 1hr	65PPM	NOx 1hr	1PPM		
NOx 1hr	0.39%	SO2 1hr	0.00%	CO 1hr	65PPM	NOx 1hr	1PPM		
CO 1hr	17.68PPM	NOx 1hr	0.00%	CO 1hr	65PPM	NOx 1hr	1PPM		
MANUAL Apr. 19. 96 13:02									
02	0.38%	CO2	0.00%	CO	118PPM	NOx	0PPM		
SO2	0.59PPM	CO2 1hr	0.00%	CO 1hr	9.79%	CO 1hr	118PPM		
NOx 1hr	2PPM	SO2 1hr	0.59PPM	CO 1hr	7.29%	CO2 1hr	4.95%		O/CO 10.2/10.1
CO 1hr	15.68PPM	NOx 1hr	4.17%	SO2 1hr	4.17PPM	CO2 1hr	5.25%		CO 0
MANUAL Apr. 19. 96 12:59									
02	0.42%	CO2	0.03%	CO	3PPM	NOx	170PPM		
SO2	1.22PPM	CO2 1hr	0.03%	CO 1hr	0.00%	CO 1hr	2PPM		
NOx 1hr	170PPM	SO2 1hr	1.22PPM	CO 1hr	5.48%	CO2 1hr	5.25%		NOx 180
CO 1hr	0.42%	NOx 1hr	4.88PPM	SO2 1hr	1.91PPM	CO2 1hr	5.25%		
MANUAL Apr. 19. 96 12:57									
02	0.43%	CO2	0.04%	CO	2PPM	NOx	0PPM		
SO2	1.89PPM	CO2 1hr	0.04%	CO 1hr	0.05%	CO 1hr	2PPM		
NOx 1hr	0.43%	SO2 1hr	1.89PPM	CO 1hr	7.10%	CO2 1hr	6.91%		SYS ZERO
CO 1hr	0.43%	NOx 1hr	1.89PPM	SO2 1hr	2.06PPM	CO2 1hr	6.91%		
MANUAL Apr. 19. 96 12:55									
02	0.43%	CO2	0.04%	CO	2PPM	NOx	0PPM		
SO2	1.89PPM	CO2 1hr	0.04%	CO 1hr	0.05%	CO 1hr	2PPM		
NOx 1hr	0.43%	SO2 1hr	1.89PPM	CO 1hr	7.10%	CO2 1hr	6.91%		
CO 1hr	0.43%	NOx 1hr	1.89PPM	SO2 1hr	2.06PPM	CO2 1hr	6.91%		

TAF ENVIRONMENTAL CORPORATION 25.00

END OF R4N1

Time	CO (%)	NOx (ppm)	SO2 (ppm)	PM10 (µg/m³)	PM2.5 (µg/m³)	Temperature (°C)	Humidity (%)	Wind Speed (m/s)	Wind Direction	Pressure (hPa)	Other
07:00	9.58%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
07:30	9.52%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
08:00	9.59%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
08:30	9.74%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
09:00	9.78%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
09:30	9.80%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
10:00	9.77%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
10:30	9.92%	0.00	0.00	25.00	0.00	10.0	70	0.0	0.0	1013.0	
11:00	9.73%	0.00	0.00	25.00	0.00	10.0	70	0.0	0.0	1013.0	
11:30	9.56%	0.00	0.00	23.00	0.00	10.0	70	0.0	0.0	1013.0	
12:00	9.55%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
12:30	9.55%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
13:00	9.55%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
13:30	9.52%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
14:00	9.45%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
14:30	9.55%	0.00	0.00	23.00	0.00	10.0	70	0.0	0.0	1013.0	
15:00	10.08%	0.00	0.00	25.00	0.00	10.0	70	0.0	0.0	1013.0	
15:30	9.98%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
16:00	9.55%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	
16:30	9.51%	0.00	0.00	24.00	0.00	10.0	70	0.0	0.0	1013.0	

10.00mm	CO2 1hr	Apr. 1996 13:20	9.76%	CO 1hr	0ppmv	NOx 1hr	23ppmv	
10.00mm	CO2 1hr	Apr. 1996 13:22	9.79%	CO 1hr	0ppmv	NOx 1hr	23ppmv	
10.00mm	CO2 1hr	Apr. 1996 13:24	10.31%	CO 1hr	0ppmv	NOx 1hr	25ppmv	20.00
10.00mm	CO2 1hr	Apr. 1996 13:26	10.52%	CO 1hr	0ppmv	NOx 1hr	23ppmv	
10.00mm	CO2 1hr	Apr. 1996 13:28	10.50%	CO 1hr	0ppmv	NOx 1hr	25ppmv	
10.00mm	CO2 1hr	Apr. 1996 13:30	9.96%	CO 1hr	0ppmv	NOx 1hr	23ppmv	
10.00mm	CO2 1hr	Apr. 1996 13:32	10.18%	CO 1hr	0ppmv	NOx 1hr	23ppmv	25.00
10.00mm	CO2 1hr	Apr. 1996 13:34	10.57%	CO 1hr	0ppmv	NOx 1hr	25ppmv	
10.00mm	CO2 1hr	Apr. 1996 13:36	10.11%	CO 1hr	0ppmv	NOx 1hr	24ppmv	

0 10 20 30 40 50 60 70 80 90 100

10.00mm	CO2 1hr	Apr. 1996 13:14	11.51%	CO 1hr	0.00%	NOx 1hr	118ppmv	150.0 PPM
MANUAL	Apr. 19.96	13:13						
CO2	0.38%	CO2	0.00%	CO	118ppmv	NOx	0ppmv	
SO2	33.4ppm	CO2 1hr	0.38%	CO2 1hr	0.00%	CO 1hr	118ppmv	
NOx 1hr	0ppmv	SO2 1hr	33.4ppm	CO2 1hr	0.00%	CO 1hr	118ppmv	
CO 1hr	32ppmv	NOx 1hr	23ppmv	SO2 1hr	4.43%	CO2 1hr	2.92%	CO 120

MANUAL	Apr. 19.96	13:12						
CO2	0.38%	CO2	0.00%	CO	119ppmv	NOx	0ppmv	
SO2	79.7ppm	CO2 1hr	0.37%	CO2 1hr	0.00%	CO 1hr	116ppmv	
NOx 1hr	0ppmv	SO2 1hr	78.5ppm	CO2 1hr	4.62%	CO 1hr	116ppmv	
CO 1hr	28ppmv	NOx 1hr	24ppmv	SO2 1hr	20.14ppm	CO2 1hr	3.12%	SO2 84.6

MANUAL	Apr. 19.96	13:10						
CO2	0.38%	CO2	0.00%	CO	62ppmv	NOx	1ppmv	
SO2	78.0ppm	CO2 1hr	0.38%	CO2 1hr	0.00%	CO 1hr	63ppmv	
NOx 1hr	1ppmv	SO2 1hr	77.7ppm	CO2 1hr	4.91%	CO2 1hr	3.33%	SO2 84.6
CO 1hr	24ppmv	NOx 1hr	25ppmv	SO2 1hr	20.14ppm			

70.00mm

Apr. 1996 13:09

10.00mm	CO2 1hr	Apr. 1996 13:07	0.01%	CO 1hr	65ppmv	NOx 1hr	1ppmv	
---------	---------	-----------------	-------	--------	--------	---------	-------	--

Altitude (m)	CO2 (ppm)	CO2 (%)	CO (ppm)	NOx (ppm)	SO2 (ppm)	PM10 (ppm)	PM2.5 (ppm)	Temperature (°C)	Humidity (%)	Wind Speed (m/s)	Wind Direction	Other
0.1	402	10.12%	0	0	0	24	12	24	70	1.5	120	
0.3	402	9.94%	0	0	0	24	12	24	70	1.5	120	
0.5	402	10.53%	0	0	0	25	13	25	70	1.5	120	20.00
0.7	402	9.92%	0	0	0	24	12	24	70	1.5	120	
0.9	402	9.64%	0	0	0	23	11	23	70	1.5	120	
1.1	402	9.75%	0	0	0	23	11	23	70	1.5	120	25.00
1.3	402	9.87%	0	0	0	23	11	23	70	1.5	120	
1.5	402	9.72%	0	0	0	22	10	22	70	1.5	120	
1.7	402	9.96%	0	0	0	23	11	23	70	1.5	120	
1.9	402	9.97%	0	0	0	23	11	23	70	1.5	120	
2.1	402	9.90%	0	0	0	23	11	23	70	1.5	120	
2.3	402	9.98%	0	0	0	23	11	23	70	1.5	120	15.00
2.5	402	9.79%	0	0	0	23	11	23	70	1.5	120	
2.7	402	10.11%	0	0	0	24	12	24	70	1.5	120	
2.9	402	9.79%	0	0	0	22	10	22	70	1.5	120	30.00
3.1	402	10.21%	0	0	0	24	12	24	70	1.5	120	
3.3	402	9.90%	0	0	0	23	11	23	70	1.5	120	

TOTAL ENVIRONMENTAL MONITORING

12-1-15

15.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00

10.00


10.00

10.00

10.00

10.00

10.00



70	100%	CO2 1hr	0.01%	CO 1hr	62ppmv	NOx 1hr	1ppmv		
0	2%	Apr. 19 14:44							
		MANUAL	Apr. 19. 96	14:43					
		O2	21.03%	CO2	0.00%	CO	53ppmv	NOx	1ppmv
		SO2	78.3PPM	O2 1hr	21.30%	CO2 1hr	0.02%	CO 1hr	162ppmv
		NOx 1hr	1ppmv	SO2 1hr	78.2ppm	O2 1hr	21.05%	CO2 1hr	2.00%
		CO 1hr	34ppmv	NOx 1hr	144ppmv	SO2 1hr	24.47PPM		
									SO2 84.6
50	100%	CO2 1hr	0.00%	CO 1hr	63ppmv	NOx 1hr	1ppmv		
0	10%	Apr. 19 14:44							
60	100%	CO2 1hr	0.01%	CO 1hr	63ppmv	NOx 1hr	1ppmv		
0	30%	Apr. 19 14:44							
40	100%	CO2 1hr	0.25%	CO 1hr	109ppmv	NOx 1hr	0ppmv		
0	54%	Apr. 19 14:58							50%
		MANUAL	Apr. 19. 96	14:37					
		O2	21.30%	CO2	0.04%	CO	110ppmv	NOx	0ppmv
		SO2	30.3PPM	O2 1hr	21.43%	CO2 1hr	0.12%	CO 1hr	87ppmv
		NOx 1hr	1ppmv	SO2 1hr	38.2ppm	O2 1hr	21.30%	CO2 1hr	3.14%
		CO 1hr	13ppmv	NOx 1hr	88ppmv	SO2 1hr	2.85PPM		
									CO 120
80	100%	CO2 1hr	0.00%	CO 1hr	2ppmv	NOx 1hr	6ppmv		20.00
0	10	Apr. 19 14:36							
		MANUAL	Apr. 20. 96	30:4:35	40	50	60	70	80
		O2	21.1%	CO2	0.00%	CO	2ppmv	NOx	1ppmv
		SO2	23.3PPM	O2 1hr	21.17%	CO2 1hr	0.07%	CO 1hr	2ppmv
		NOx 1hr	7ppmv	SO2 1hr	0.9ppm	O2 1hr	21.22%	CO2 1hr	3.03%
		CO 1hr	7ppmv	NOx 1hr	73ppmv	SO2 1hr	1.26PPM		
									O2/CO2 10.2/10.1
									CO 750
		MANUAL	Apr. 19. 96	14:34					
		O2	21.02%	CO2	0.01%	CO	2ppmv	NOx	177ppmv
		SO2	0.5PPM	O2 1hr	21.02%	CO2 1hr	0.01%	CO 1hr	1ppmv
		NOx 1hr	177ppmv	SO2 1hr	0.5ppm	O2 1hr	21.00%	CO2 1hr	2.74%
		CO 1hr	7ppmv	NOx 1hr	74ppmv	SO2 1hr	1.26PPM		
									NOx 180
100	100%	CO2 1hr	0.01%	CO 1hr	3ppmv	NOx 1hr	32ppmv		
0	2%	Apr. 19 14:32							
0	50%	CO2 1hr	0.01%	CO 1hr	3ppmv	NOx 1hr	04ppmv		25.00
		MANUAL	Apr. 19. 96	14:28					
		O2	21.44%	CO2	0.05%	CO	3ppmv	NOx	0ppmv
		SO2	1.7PPM	O2 1hr	21.40%	CO2 1hr	0.07%	CO 1hr	9ppmv
		NOx 1hr	0ppmv	SO2 1hr	1.6ppm	O2 1hr	21.18%	CO2 1hr	6.20%
		CO 1hr	13ppmv	NOx 1hr	16ppmv	SO2 1hr	1.32PPM		
		MANUAL	Apr. 19. 96	14:28					
		O2	21.46%	CO2	0.07%	CO	5ppmv	NOx	0ppmv
		SO2	1.6PPM	O2 1hr	21.40%	CO2 1hr	0.09%	CO 1hr	20ppmv
		NOx 1hr	0ppmv	SO2 1hr	1.5ppm	O2 1hr	21.24%	CO2 1hr	7.33%
		CO 1hr	14ppmv	NOx 1hr	12ppmv	SO2 1hr	1.25PPM		
									SO2 200
0	10	20	30	40	50	60	70	80	90
0	10	20	30	40	50	60	70	80	90


Time	CO2 1hr	CO 1hr	NOx 1hr	SO2 1hr	PM10 1hr	PM2.5 1hr	Temp	Humidity	Wind	Dir	Pressure	Other
5:45 AM	0.02%	10.00%	0.00%	0.00%	0.00%	0.00%	25.00	25%	0.00	0.00	1013	CO2
6:00 AM	0.02%	10.00%	0.00%	0.00%	0.00%	0.00%	25.00	25%	0.00	0.00	1013	CO2
6:15 AM	0.02%	9.78%	0.00%	0.00%	0.00%	0.00%	24.00	24%	0.00	0.00	1013	CO2
6:30 AM	0.02%	10.18%	0.00%	0.00%	0.00%	0.00%	23.00	23%	0.00	0.00	1013	CO2
6:45 AM	0.02%	9.85%	0.00%	0.00%	0.00%	0.00%	24.00	24%	0.00	0.00	1013	CO2
7:00 AM	0.02%	2.64%	0.00%	0.00%	0.00%	0.00%	23.00	23%	0.00	0.00	1013	CO2
7:15 AM	0.02%	10.18%	0.00%	0.00%	0.00%	0.00%	23.00	23%	0.00	0.00	1013	CO2
7:30 AM	0.02%	9.84%	0.00%	0.00%	0.00%	0.00%	21.00	21%	0.00	0.00	1013	CO2
7:45 AM	0.02%	0.01%	0.00%	0.00%	0.00%	0.00%	20.00	20%	0.00	0.00	1013	CO2
8:00 AM	0.02%	0.12%	0.00%	0.00%	0.00%	0.00%	20.00	20%	0.00	0.00	1013	CO2
8:15 AM	0.02%	0.15%	0.00%	0.00%	0.00%	0.00%	20.00	20%	0.00	0.00	1013	CO2
7:00 AM	0.02%	0.01%	0.00%	0.00%	0.00%	0.00%	62.00	62%	0.00	0.00	1013	CO2
<p>TRC ENVIRONMENTAL CORPORATION</p> <p>MANUAL Apr. 19 96 14:43</p> <p>CO2 0.03% CO 0.00% NOx 1.00ppm</p> <p>SO2 78.9PPM SO2 1hr 0.30% CO2 1hr 0.02% CO 63ppm</p> <p>NOx 1hr 1.00ppm SO2 1hr 78.2ppm CO2 1hr 2.25% CO 1hr 62ppm</p> <p>CO 1hr 34ppm NOx 1hr 44ppm SO2 1hr 24.47PPM CO2 1hr 2.00%</p>												
6:15 AM	0.02%	0.00%	0.00%	0.00%	0.00%	0.00%	63.00	63%	0.00	0.00	1013	CO2
6:30 AM	0.02%	0.01%	0.00%	0.00%	0.00%	0.00%	63.00	63%	0.00	0.00	1013	CO2
6:45 AM	0.02%	0.23%	0.00%	0.00%	0.00%	0.00%	10.00	10%	0.00	0.00	1013	CO2
<p>MANUAL Apr. 19 96 14:37</p> <p>CO2 0.38% CO 0.04% NOx 1.00ppm</p> <p>SO2 36.3PPM SO2 1hr 0.43% CO2 1hr 0.12% CO 113ppm</p> <p>NOx 1hr 1.00ppm SO2 1hr 18.2ppm CO2 1hr 3.30% CO 1hr 87ppm</p> <p>CO 1hr 1.00ppm NOx 1hr 66ppm SO2 1hr 2.85PPM CO2 1hr 3.11%</p>												
6:45 AM	0.02%	0.03%	0.00%	0.00%	0.00%	0.00%	20.00	20%	0.00	0.00	1013	CO2

SO2 84.6

CO 120

Time	Temp	Humidity	Wind	Pressure	CO2	CO	NOx	PM10	PM2.5	SO2	NO2
10:00	9.62K	9.62K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:05	9.63K	9.63K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:10	9.64K	9.64K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:15	9.65K	9.65K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:20	9.66K	9.66K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:25	9.67K	9.67K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:30	9.68K	9.68K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:35	9.69K	9.69K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:40	9.70K	9.70K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:45	9.71K	9.71K	0.00m/s	1000.0hPa	25.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:50	9.72K	9.72K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
10:55	9.73K	9.73K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:00	9.74K	9.74K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:05	9.75K	9.75K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:10	9.76K	9.76K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:15	9.77K	9.77K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:20	9.78K	9.78K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:25	9.79K	9.79K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:30	9.80K	9.80K	0.00m/s	1000.0hPa	24.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:35	9.81K	9.81K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:40	9.82K	9.82K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:45	9.83K	9.83K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:50	9.84K	9.84K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm
11:55	9.85K	9.85K	0.00m/s	1000.0hPa	23.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm	0.0ppm

1510
START RUN



TRC ENVIRONMENTAL CORPORATION

O₂/CO₂/NO_x/SO₂
Direct zero

CALC 4/22/96

SYS. CAL CHECK

21	0.11 ppm	0.021%	0.22%	CO 1hr	3ppmv	NOx 1hr	0ppmv		
21	0.14 ppm	0.021%	0.22%	CO 1hr	3ppmv	NOx 1hr	0ppmv	20.00%	
21	0.13 ppm	0.021%	0.22%	CO 1hr	3ppmv	NOx 1hr	0ppmv		
21	0.11 ppm	0.021%	0.22%	CO 1hr	3ppmv	NOx 1hr	0ppmv		
21	0.13 ppm	0.021%	0.22%	CO 1hr	3ppmv	NOx 1hr	0ppmv	25.00%	
21	0.14 ppm	0.021%	0.22%	CO 1hr	3ppmv	NOx 1hr	0ppmv		
21	0.12 ppm	0.021%	0.22%	CO 1hr	29ppmv	NOx 1hr	13ppmv		
20	0.11 ppm	0.021%	0.22%	CO 1hr	3ppmv	NOx 1hr	0ppmv		
7	0.11 ppm	0.021%	0.21%	CO 1hr	53ppmv	NOx 1hr	1ppmv		

TRC ENVIRONMENTAL CORPORATION

0	10	20	30	40	50	60	70	80	90	100
---	----	----	----	----	----	----	----	----	----	-----

MANUAL	Apr. 22.96	08:07	0.18%	CO	54ppmv	NOx	1ppmv		
SO2	0.11ppm	CO2 1hr	0.21%	CO2 1hr	0.18%	CO 1hr	54ppmv		
NOx 1hr	1ppmv	SO2 1hr	0.11ppm	CO 1hr	12.33%	CO2 1hr	1.67%		
CO 1hr	29ppmv	NOx 1hr	14ppmv	SO2 1hr	13.52ppm	CO2 1hr	1.67%		

SO2 54.6

76	0.22 ppm	0.21%	0.21%	CO 1hr	64ppmv	NOx 1hr	1ppmv		
11	0.28 ppm	0.32%	0.32%	CO 1hr	86ppmv	NOx 1hr	1ppmv		

MANUAL	Apr. 22.96	08:02	0.26%	CO	6ppmv	NOx	0ppmv		
SO2	14.7ppm	CO2 1hr	0.13%	CO2 1hr	9.88%	CO 1hr	41ppmv		
NOx 1hr	0ppmv	SO2 1hr	37.7ppm	CO 1hr	13.12%	CO2 1hr	1.65%		
CO 1hr	28ppmv	NOx 1hr	15ppmv	SO2 1hr	10.31ppm	CO2 1hr	1.65%		

SO2/CO2 10.2/10.0

66	0.89 ppm	0.99%	0.99%	CO 1hr	120ppmv	NOx 1hr	1ppmv		
----	----------	-------	-------	--------	---------	---------	-------	--	--

MANUAL	Apr. 22.96	08:01	0.16%	CO	121ppmv	NOx	1ppmv		
SO2	0.31ppm	CO2 1hr	0.22%	CO2 1hr	0.16%	CO 1hr	119ppmv		
NOx 1hr	1ppmv	SO2 1hr	56.4ppm	CO 1hr	13.34%	CO2 1hr	1.90%		
CO 1hr	26ppmv	NOx 1hr	16ppmv	SO2 1hr	8.92ppm	CO2 1hr	1.90%		

CO 120

0	10	20	30	40	50	60	70	80	90	100
---	----	----	----	----	----	----	----	----	----	-----

DATE	TIME	CO2	CO	SO2	NOx	PM10	PM2.5	PM10-2.5	PM2.5-10	PM10-2.5-10
02	07:22	0.12%	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
SD2		0.11PPM	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
NOx 1hr		17.2ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
CO 1hr		26ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
0 22	07:22	0.24%	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
MANUAL	Apr. 22.96	07:50	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
SD2		0.11PPM	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
NOx 1hr		17.2ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
CO 1hr		26ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
0 27	07:27	0.23%	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
MANUAL	Apr. 22.96	07:55	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
SD2		0.11PPM	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
NOx 1hr		17.2ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
CO 1hr		26ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
0 28	07:28	0.24%	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
MANUAL	Apr. 22.96	07:54	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
SD2		0.11PPM	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
NOx 1hr		17.2ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
CO 1hr		26ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
5 30	07:30	0.50%	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
MANUAL	Apr. 22.96	07:52	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
SD2		0.11PPM	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
NOx 1hr		17.2ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
CO 1hr		26ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
12 31	07:31	0.18%	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
MANUAL	Apr. 22.96	07:50	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
SD2		0.11PPM	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
NOx 1hr		17.2ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
CO 1hr		26ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
MANUAL	Apr. 22.96	07:48	0.17%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
SD2		0.11PPM	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
NOx 1hr		17.2ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%
CO 1hr		26ppm	0.16%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%	0.15%

NOx 180

CO/CO2/SO2/NOx
5/5.750

NOx 180

NOx 100 255

CO 120

CO 278
SO2 123

CO 62.0
SO2 84.6

1.45%	CO2 1hr	7.7%	CO 1hr	42ppm	NOx 1hr	1ppm		
1.45%	CO2 1hr	7.0%	CO 1hr	44ppm	NOx 1hr	7ppm		25.00
1.45%	CO2 1hr	7.2%	CO 1hr	42ppm	NOx 1hr	9ppm		
1.45%	CO2 1hr	7.1%	CO 1hr	40ppm	NOx 1hr	9ppm		
1.45%	CO2 1hr	7.7%	CO 1hr	38ppm	NOx 1hr	1ppm		

END OF
SYS. CHECK
CO 62.0
SO2 84.6

MANUAL	Apr. 22 1996	10:27						
O2	21.1%	CO2	0.17%	CO	55ppm	NOx	3ppm	
SO2	84ppm	O2 1hr	21.1%	CO2 1hr	0.17%	CO 1hr	54ppm	
NOx 1hr	1ppm	SO2 1hr	84ppm	O2 1hr	21.15%	CO2 1hr	1.94%	
CO 1hr	37ppm	NOx 1hr	17ppm	SO2 1hr	11.10ppm			

0.22%	CO2 1hr	0.2%	CO 1hr	40	NOx 1hr	60	CO2	1ppm
0.22%	CO2 1hr	0.2%	CO 1hr	40	NOx 1hr	60	CO2	1ppm
0.22%	CO2 1hr	0.2%	CO 1hr	40	NOx 1hr	60	CO2	1ppm

O2/CO2 10.2/10.1
CO zero

MANUAL	Apr. 22 1996	10:23						
O2	21.25%	CO2	0.83%	CO	5ppm	NOx	10ppm	
SO2	133ppm	O2 1hr	21.25%	CO2 1hr	0.83%	CO 1hr	4ppm	
NOx 1hr	133ppm	SO2 1hr	133ppm	O2 1hr	21.25%	CO2 1hr	2.00%	
CO 1hr	21ppm	NOx 1hr	21ppm	SO2 1hr	0.51ppm			

NOx 1hr
SO2 zero

MANUAL	Apr. 22 1996	10:22						
O2	21.24%	CO2	0.17%	CO	5ppm	NOx	174ppm	
SO2	0.5ppm	O2 1hr	21.24%	CO2 1hr	0.17%	CO 1hr	4ppm	
NOx 1hr	18ppm	SO2 1hr	1.0ppm	O2 1hr	21.24%	CO2 1hr	1.86%	
CO 1hr	22ppm	NOx 1hr	18ppm	SO2 1hr	0.5ppm			

O2/CO2/NOx
zero

0.22%	CO2 1hr	0.3%	CO 1hr	5ppm	NOx 1hr	12ppm		
-------	---------	------	--------	------	---------	-------	--	--

Time	CO2 (ppm)	CO2 (%)	CO (ppm)	NOx (ppm)	SOx (ppm)
11:00	002	0.25%	00	0000	0000
11:05	002	4.60%	00	002000	0000
11:10	002	7.02%	00	320000	100000
11:15	002	7.90%	00	720000	300000
11:20	002	7.55%	00	1570000	1000000
11:25	002	6.85%	00	2330000	500000
11:30	002	7.40%	00	810000	300000
11:35	002	7.81%	00	1400000	1100000
11:40	002	7.56%	00	1480000	900000
11:45	002	7.00%	00	2850000	800000
11:50	002	7.04%	00	1700000	800000
11:55	002	7.17%	00	1430000	900000
12:00	002	4.55%	00	670000	1300000
12:05	002	7.05%	00	2370000	800000
12:10	002	7.70%	00	1600000	1100000
12:15	002	7.10%	00	3000000	800000

OUT OF STACK NOX AND AIR CHECK

Ramped Flare up to 1560

THE ENVIRONMENTAL CORPORATION

STOP TEST FOR CO TO SETTLE? - ON SCALE 10/8

OFF SCALE CO @ 10/6

0 10 20 30 40 50 60 70 80 90 100

Time	CO2 (ppm)	CO (ppm)	NOx (ppm)	SO2 (ppm)	PM10 (ppm)	PM2.5 (ppm)
12:07	7.52%	1800	110			
12:09	7.56%	6000	700			
12:11	7.55%	6500	1100			
12:12	7.21%	8000	1000			
12:14	6.86%	4000	900			
12:16	7.55%	1000	100			
12:18	7.31%	1000	1100			
12:20	7.45%	3000	1000			
12:22	7.50%	0	1000			
12:24	7.25%	2000	800			
12:26	8.00%	1000	1100			
12:28	7.46%	8000	1000			
12:30	7.36%	9000	1000			
12:32	7.55%	30	40	50	60	70
12:34	7.41%	1000	1000			
12:36	7.55%	0	1000			
12:38	7.31%	1000	1100			
12:40	7.45%	0	1000			
12:42	7.50%	0	1000			
12:44	7.25%	2000	800			
12:46	8.00%	1000	1100			
12:48	7.46%	8000	1000			
12:50	7.36%	9000	1000			
12:52	7.55%	30	40	50	60	70

Run 1
VOID

OFF SCALE
AGAIN

Ballbans

Run STOP
~~Run 1~~
Port Change
+ Off Scale

11:50
START RUN 1
150°F

ISO ENVIRONMENTAL CORPORATION


5000ppm
Apr. 22 12:00

12	85%	002 1hr Arr. 22:12:54	7.59%	C0 1hr	14000V	NOx 1hr	10000V		
12	82%	002 1hr Arr. 22:12:57	7.27%	C0 1hr	10000V	NOx 1hr	10000V	NOx	2500
12	87%	002 1hr Arr. 22:12:50	8.01%	C0 1hr	00000V	NOx 1hr	11000V	CO2	
12	82%	002 1hr Arr. 22:12:46	7.65%	C0 1hr	00000V	NOx 1hr	10000V	CO2	
12	82%	002 1hr Arr. 22:12:46	7.56%	C0 1hr	00000V	NOx 1hr	10000V	CO2	1700
12	73%	002 1hr Arr. 22:12:44	7.46%	C0 1hr	00000V	NOx 1hr	10000V		
12	85%	002 1hr Arr. 22:12:42	7.70%	C0 1hr	00000V	NOx 1hr	10000V	CO2	
12	72%	002 1hr Arr. 22:12:40	7.46%	C0 1hr	12000V	NOx 1hr	10000V	CO2	300
0								02	
12	80%	002 1hr Arr. 22:12:38	7.91%	C0 1hr	-10000V	NOx 1hr	11000V		
12	85%	002 1hr Arr. 22:12:36	7.53%	C0 1hr	10000V	NOx 1hr	10000V		
12	81%	002 1hr Arr. 22:12:34	7.56%	C0 1hr	00000V	NOx 1hr	10000V	NOx	300
12	85%	002 1hr Arr. 22:12:32	7.79%	C0 1hr	00000V	NOx 1hr	11000V	CO2	
12	71%	002 1hr Arr. 22:12:30	7.51%	C0 1hr	17000V	NOx 1hr	10000V	CO2	
13	80%	002 1hr Arr. 22:12:28	6.87%	C0 1hr	50000V	NOx 1hr	00000V		2000
12	89%	002 1hr Arr. 22:12:26	7.73%	C0 1hr	20000V	NOx 1hr	10000V		
12	84%	002 1hr Arr. 22:12:24	7.75%	C0 1hr	25000V	NOx 1hr	11000V		
12	80%	002 1hr Arr. 22:12:22	7.40%	C0 1hr	29000V	NOx 1hr	10000V	CO2	
12	89%	002 1hr Arr. 22:12:22	7.26%	C0 1hr	31000V	NOx 1hr	00000V		2500
0								02	

Handwritten notes:
 100% V
 100% NOx
 100% CO2

Handwritten note:
 START Run Again.

1330



OFF SCALE
~ 400ppm

BACK ON
LINE 1310

Port
Change
CO2 Probe
Moved to
D Port
1304

500ppm/h
Apr. 22 13:00

MANUAL	Apr. 22.96	13:47								
CO2	0.00%	CO2	0.15%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.00ppm	SO2 1hr	0.00%	CO2 1hr	0.15%	CO 1hr	0.00%	NOx 1hr	0.00%	
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	SO2 84.6
MANUAL	Apr. 22.96	13:46								
CO2	0.10%	CO2	0.10%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.00ppm	SO2 1hr	0.00%	CO2 1hr	0.10%	CO 1hr	0.00%	NOx 1hr	0.00%	
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	
MANUAL	Apr. 22.96	13:41								
CO2	0.10%	CO2	0.10%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.00ppm	SO2 1hr	0.00%	CO2 1hr	0.10%	CO 1hr	0.00%	NOx 1hr	0.00%	
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	
MANUAL	Apr. 22.96	13:40								
CO2	0.20%	CO2	0.20%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.00ppm	SO2 1hr	0.00%	CO2 1hr	0.20%	CO 1hr	0.00%	NOx 1hr	0.00%	
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	300 ppm
MANUAL	Apr. 22.96	13:38								
CO2	0.20%	CO2	0.23%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.00ppm	SO2 1hr	0.00%	CO2 1hr	0.23%	CO 1hr	0.00%	NOx 1hr	0.00%	CO 120
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	
MANUAL	Apr. 22.96	13:37								
CO2	0.00%	CO2	0.00%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.00ppm	SO2 1hr	0.00%	CO2 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	20.00
MANUAL	Apr. 22.96	13:35								
CO2	0.24%	CO2	0.20%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.40ppm	SO2 1hr	0.00%	CO2 1hr	0.20%	CO 1hr	0.00%	NOx 1hr	0.00%	CO 200
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	NOx 80
MANUAL	Apr. 22.96	13:33								
CO2	0.30%	CO2	0.30%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.00ppm	SO2 1hr	0.00%	CO2 1hr	0.30%	CO 1hr	0.00%	NOx 1hr	0.00%	
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	25.00
MANUAL	Apr. 22.96	13:32								
CO2	0.20%	CO2	0.22%	CO	0.00%	NOx	0.00%	SO2	0.00%	
NOx 1hr	1.70ppm	SO2 1hr	0.00%	CO2 1hr	0.22%	CO 1hr	0.00%	NOx 1hr	0.00%	CO2/NOx/SO2 zero
CO 1hr	0.00ppm	NOx 1hr	0.00%	CO 1hr	0.00%	NOx 1hr	0.00%	SO2 1hr	0.00ppm	

AVG 12 12.8% CO2 7.3% CO 12.2 NOx 10.33 SO2 1.82
 0 10 20 30 40 50 60 70 80 90 100


MANUAL	Apr. 22, 96	13:47								
O2	4.00%	CO2	0.15%	CO	55ppmv	NOx	1ppmv			
SO2	35.7ppm	CO2 1hr	0.10%	CO2 1hr	0.15%	CO 1hr	83ppmv			SO2 84.6
NOx 1hr	1ppmv	SO2 1hr	35.3ppm	CO2 1hr	5.31%	CO2 1hr	3.09%			
CO 1hr	55ppmv	NOx 1hr	29ppmv	SO2 1hr	18.4ppm					
0.15%	CO2 1hr	0.10%	CO 1hr	54ppmv	NOx 1hr					
0.22%	CO2 1hr	0.10%	CO 1hr	63ppmv	NOx 1hr					
0.22%	CO2 1hr	0.10%	CO 1hr	63ppmv	NOx 1hr					
0.22%	CO2 1hr	0.10%	CO 1hr	63ppmv	NOx 1hr					
0.22%	CO2 1hr	0.10%	CO 1hr	63ppmv	NOx 1hr					
MANUAL	Apr. 22, 96	13:38								
O2	4.20%	CO2	0.21%	CO	118ppmv	NOx	1ppmv			
SO2	4.0ppm	CO2 1hr	0.16%	CO2 1hr	0.26%	CO 1hr	80ppmv			CO 120
NOx 1hr	1ppmv	SO2 1hr	2.1ppm	CO2 1hr	8.02%	CO2 1hr	4.63%			
CO 1hr	45ppmv	NOx 1hr	44ppmv	SO2 1hr	11.5ppm					
0.15%	CO2 1hr	0.16%	CO 1hr	40	NOx 1hr	60	CO 1hr	80	90	300ppmv
MANUAL	Apr. 22, 96	13:37								
O2	10.09%	CO2	0.84%	CO	0ppmv	NOx	1ppmv			
SO2	1.3ppm	CO2 1hr	10.08%	CO2 1hr	9.80%	CO 1hr	0ppmv			
NOx 1hr	1ppmv	SO2 1hr	1.3ppm	CO2 1hr	8.47%	CO2 1hr	4.72%			
CO 1hr	40ppmv	NOx 1hr	48ppmv	SO2 1hr	11.5ppm					20.00
MANUAL	Apr. 22, 96	13:35								
O2	0.24%	CO2	0.20%	CO	2ppmv	NOx	174ppmv			
SO2	1.4ppm	CO2 1hr	0.25%	CO2 1hr	0.20%	CO 1hr	2ppmv			CO zero
NOx 1hr	174ppmv	SO2 1hr	1.4ppm	CO2 1hr	6.76%	CO2 1hr	4.63%			NOx 180
CO 1hr	49ppmv	NOx 1hr	41ppmv	SO2 1hr	1.5ppm					
0.15%	CO2 1hr	0.20%	CO 1hr	2ppmv	NOx 1hr	165ppmv				
0.15%	CO2 1hr	0.22%	CO 1hr	3ppmv	NOx 1hr	9ppmv				25.00
MANUAL	Apr. 22, 96	13:32								
O2	0.23%	CO2	0.22%	CO	3ppmv	NOx	9ppmv			
SO2	1.7ppm	CO2 1hr	0.23%	CO2 1hr	0.22%	CO 1hr	3ppmv			02/CO2/NOx/SO2 zero
NOx 1hr	9ppmv	SO2 1hr	1.7ppm	CO2 1hr	11.79%	CO2 1hr	6.19%			
CO 1hr	9ppmv	NOx 1hr	10ppmv	SO2 1hr	1.5ppm					

AVG 1/2 12.84 CO2 7.34 CO 122 NOx 10.33 SO2 1.32

Time	CO2 (ppm)	CO (ppm)	NOx (ppm)	SO2 (ppm)	PM10 (ppm)	PM2.5 (ppm)	Temperature (°C)	Humidity (%)	Wind Speed (m/s)	Wind Direction
13:42:00	100	10	10	10	10	10	25.00	50	10	10
13:42:30	100	10	10	10	10	10	25.00	50	10	10
13:43:00	100	10	10	10	10	10	25.00	50	10	10
13:43:30	100	10	10	10	10	10	25.00	50	10	10
13:44:00	100	10	10	10	10	10	25.00	50	10	10
13:44:30	100	10	10	10	10	10	25.00	50	10	10
13:45:00	100	10	10	10	10	10	25.00	50	10	10
13:45:30	100	10	10	10	10	10	25.00	50	10	10
13:46:00	100	10	10	10	10	10	25.00	50	10	10
13:46:30	100	10	10	10	10	10	25.00	50	10	10
13:47:00	100	10	10	10	10	10	25.00	50	10	10
13:47:30	100	10	10	10	10	10	25.00	50	10	10
13:48:00	100	10	10	10	10	10	25.00	50	10	10
13:48:30	100	10	10	10	10	10	25.00	50	10	10
13:49:00	100	10	10	10	10	10	25.00	50	10	10
13:49:30	100	10	10	10	10	10	25.00	50	10	10
13:50:00	100	10	10	10	10	10	25.00	50	10	10
13:50:30	100	10	10	10	10	10	25.00	50	10	10
13:51:00	100	10	10	10	10	10	25.00	50	10	10
13:51:30	100	10	10	10	10	10	25.00	50	10	10
13:52:00	100	10	10	10	10	10	25.00	50	10	10
13:52:30	100	10	10	10	10	10	25.00	50	10	10
13:53:00	100	10	10	10	10	10	25.00	50	10	10
13:53:30	100	10	10	10	10	10	25.00	50	10	10
13:54:00	100	10	10	10	10	10	25.00	50	10	10
13:54:30	100	10	10	10	10	10	25.00	50	10	10
13:55:00	100	10	10	10	10	10	25.00	50	10	10
13:55:30	100	10	10	10	10	10	25.00	50	10	10
13:56:00	100	10	10	10	10	10	25.00	50	10	10
13:56:30	100	10	10	10	10	10	25.00	50	10	10
13:57:00	100	10	10	10	10	10	25.00	50	10	10
13:57:30	100	10	10	10	10	10	25.00	50	10	10
13:58:00	100	10	10	10	10	10	25.00	50	10	10
13:58:30	100	10	10	10	10	10	25.00	50	10	10
13:59:00	100	10	10	10	10	10	25.00	50	10	10
13:59:30	100	10	10	10	10	10	25.00	50	10	10
14:00:00	100	10	10	10	10	10	25.00	50	10	10

TPC ENVIRONMENTAL CORPORATION

START
RUN 2
1480



OFF SCALE
CO
145-14

12.74%	CO2 Inlet Arr. 22 Feb 15:55	7.55%	CO Inlet	29ppmv	NOx Inlet	11ppmv	
12.75%	CO2 Inlet Arr. 22 Feb 15:57	7.70%	CO Inlet	40ppmv	NOx Inlet	12ppmv	
12.74%	CO2 Inlet Arr. 22 Feb 15:59	7.71%	CO Inlet	49ppmv	NOx Inlet	9ppmv	
12.74%	CO2 Inlet Arr. 22 Feb 15:53	7.80%	CO Inlet	10ppmv	NOx Inlet	11ppmv	CO2
12.76%	CO2 Inlet Arr. 22 Feb 15:51	7.29%	CO Inlet	35ppmv	NOx Inlet	10ppmv	CO2
12.73%	CO2 Inlet Arr. 22 Feb 15:30	7.71%	CO Inlet	24ppmv	NOx Inlet	11ppmv	
12.72%	CO2 Inlet Arr. 22 Feb 15:29	7.55%	CO Inlet	5ppmv	NOx Inlet	11ppmv	
12.73%	CO2 Inlet Arr. 22 Feb 15:27	7.81%	CO Inlet	24ppmv	NOx Inlet	11ppmv	
12.74%	CO2 Inlet Arr. 22 Feb 15:25	7.53%	CO Inlet	26ppmv	NOx Inlet	10ppmv	
12.71%	CO2 Inlet Arr. 22 Feb 15:23	7.71%	CO Inlet	53ppmv	NOx Inlet	10ppmv	CO2
0							
10							
20							
30							
40							
50							
60							
70							
80							
90							
100							
12.67%	CO2 Inlet Arr. 22 Feb 15:21	7.24%	CO Inlet	4ppmv	NOx Inlet	12ppmv	
12.81%	CO2 Inlet Arr. 22 Feb 15:15	7.84%	CO Inlet	23ppmv	NOx Inlet	11ppmv	
12.65%	CO2 Inlet Arr. 22 Feb 15:17	7.57%	CO Inlet	4ppmv	NOx Inlet	12ppmv	NOx CO
12.70%	CO2 Inlet Arr. 22 Feb 15:15	8.32%	CO Inlet	4ppmv	NOx Inlet	13ppmv	CO
12.65%	CO2 Inlet Arr. 22 Feb 15:13	7.56%	CO Inlet	5ppmv	NOx Inlet	12ppmv	CO2
12.74%	CO2 Inlet Arr. 22 Feb 15:11	7.61%	CO Inlet	11ppmv	NOx Inlet	11ppmv	

STOP RUN 2
1532

12	43%	002 1hr Apr. 22 14:03	7.55%	CO 1hr	5ppmv	NOx 1hr	12ppmv		
12	75%	002 1hr Apr. 22 14:03	7.54%	CO 1hr	6ppmv	NOx 1hr	11ppmv	CO2	20.00
12	90%	002 1hr Apr. 22 14:03	7.70%	CO 1hr	6ppmv	NOx 1hr	11ppmv	CO2	
12	77%	002 1hr Apr. 22 14:03	7.51%	CO 1hr	7ppmv	NOx 1hr	11ppmv		
12	25%	002 1hr Apr. 22 14:01	7.95%	CO 1hr	5ppmv	NOx 1hr	12ppmv	CO2	25.00
12	93%	002 1hr Apr. 22 14:50	7.33%	CO 1hr	20ppmv	NOx 1hr	11ppmv	CO2	5.00 Apr. 22 14:00
12	59%	002 1hr Apr. 22 15:45	7.52%	CO 1hr	60ppmv	NOx 1hr	10ppmv	CO2	
4	9	002 1hr Apr. 22 15:45	5.96%	CO 1hr	49ppmv	NOx 1hr	6ppmv		15.00

0 MANUAL 10 | Apr 22 96 30:54 40 50 60 70 80 90 100

SO2	0.22%	CO	0.21%	NOx	70ppmv	CO2	1ppmv
SO2	0.77PPM	CO 1hr	0.02%	CO2 1hr	0.20%	CO 1hr	70ppmv
NOx 1hr	11ppmv	SO2 1hr	0.77PPM	CO 1hr	0.12%	CO2 1hr	5.63%
CO 1hr	40ppmv	NOx 1hr	17ppmv	SO2 1hr	0.43PPM		

12	43%	002 1hr Apr. 22 15:45	7.70%	CO 1hr	6ppmv	NOx 1hr	11ppmv	NOx	
5	4	002 1hr Apr. 22 15:50	3.26%	CO 1hr	73ppmv	NOx 1hr	2ppmv	CO	25.00

MANUAL	Apr. 22 96	15:49					
SO2	0.28%	CO2	0.21%	CO	69ppmv	NOx	1ppmv
NOx 1hr	11ppmv	CO 1hr	0.02%	CO2 1hr	0.21%	CO 1hr	72ppmv
CO 1hr	40ppmv	SO2 1hr	0.77PPM	CO 1hr	0.12%	CO2 1hr	5.71%
		NOx 1hr	17ppmv	SO2 1hr	0.43PPM		

MANUAL	Apr. 22 96	15:48					
SO2	0.28%	CO2	0.27%	CO	121ppmv	NOx	1ppmv
NOx 1hr	11ppmv	CO 1hr	0.26%	CO2 1hr	0.50%	CO 1hr	120ppmv
CO 1hr	36ppmv	SO2 1hr	3.3ppmv	CO 1hr	9.50%	CO2 1hr	6.01%
		NOx 1hr	20ppmv	SO2 1hr	1.55PPM		

13 100%

Handwritten scribble


CO 120

SO2 81.6

Sample No.	Depth (ft)	Parameter	Value	Unit	Method	Notes
12	50	CO2	7.81%	CO	100% 1hr	12ppmv 002
12	50	CO2	7.78%	CO	100% 1hr	12ppmv 02
12	50	CO2	7.86%	CO	100% 1hr	12ppmv
12	50	CO2	7.57%	CO	100% 1hr	12ppmv 02
12	50	CO2	8.02%	CO	100% 1hr	13ppmv
12	50	CO2	7.54%	CO	100% 1hr	11ppmv 02
12	50	CO2	7.59%	CO	100% 1hr	12ppmv
12	50	CO2	8.82%	CO	100% 1hr	13ppmv
12	50	CO2	7.07%	CO	100% 1hr	9ppmv 02
12	50	CO2	8.09%	CO	100% 1hr	12ppmv
12	50	CO2	7.52%	CO	100% 1hr	17ppmv 02
12	50	CO2	7.50%	CO	100% 1hr	11ppmv 02
12	50	CO2	7.37%	CO	100% 1hr	12ppmv
12	50	CO2	7.24%	CO	100% 1hr	11ppmv 02
12	50	CO2	7.40%	CO	100% 1hr	10ppmv 02
12	50	CO2	8.04%	CO	100% 1hr	12ppmv 02
12	50	CO2	7.37%	CO	100% 1hr	11ppmv 02

TRC ENVIRONMENTAL CORPORATION
25.00

10 20 30 40 50 60 70 80 90 100



12	0.44	002 1hr Apr. 22 17:55	7.74%	CO 1hr	4ppmv	NOx 1hr	11ppmv	CO2	20.00
12	0.57	002 1hr Apr. 22 17:53	7.58%	CO 1hr	5ppmv	NOx 1hr	11ppmv	CO2	
12	0.62	002 1hr Apr. 22 17:51	7.86%	CO 1hr	6ppmv	NOx 1hr	12ppmv	CO2	
12	0.64	002 1hr Apr. 22 17:49	7.58%	CO 1hr	5ppmv	NOx 1hr	11ppmv	CO2	25.00
12	0.71	002 1hr Apr. 22 17:47	7.45%	CO 1hr	6ppmv	NOx 1hr	11ppmv	CO2	
12	0.81	002 1hr Apr. 22 17:45	7.84%	CO 1hr	8ppmv	NOx 1hr	12ppmv	CO2	
11	0.97	002 1hr Apr. 22 17:43	8.11%	CO 1hr	9ppmv	NOx 1hr	13ppmv	CO2	
12	0.97	002 1hr Apr. 22 17:42	7.52%	CO 1hr	30	NOx 1hr	70	CO2	
12	1.01	002 1hr Apr. 22 17:39	7.77%	CO 1hr	18ppmv	NOx 1hr	12ppmv	CO2	
12	1.07	002 1hr Apr. 22 17:37	8.03%	CO 1hr	5ppmv	NOx 1hr	12ppmv	CO2	
12	1.11	002 1hr Apr. 22 17:36	7.51%	CO 1hr	5ppmv	NOx 1hr	11ppmv	CO2	
12	1.08	002 1hr Apr. 22 17:33	7.75%	CO 1hr	9ppmv	NOx 1hr	11ppmv	CO2	
12	1.09	002 1hr Apr. 22 17:31	7.92%	CO 1hr	5ppmv	NOx 1hr	12ppmv	CO2	
12	1.30	002 1hr Apr. 22 17:29	7.57%	CO 1hr	5ppmv	NOx 1hr	11ppmv	CO2	
12	1.30	002 1hr Apr. 22 17:27	8.03%	CO 1hr	23ppmv	NOx 1hr	12ppmv	CO2	
12	1.32	002 1hr Apr. 22 17:26	7.76%	CO 1hr	11ppmv	NOx 1hr	12ppmv	CO2	
12	1.33	002 1hr Apr. 22 17:25	7.72%	CO 1hr	4ppmv	NOx 1hr	12ppmv	CO2	
12	1.39	002 1hr Apr. 22 17:20	7.92%	CO 1hr	4ppmv	NOx 1hr	12ppmv	CO2	

1725
START
RAIN 3
1550

0.113	CO2 1hr	Apr. 22 18:37	0.25%	CO 1hr	57ppmv	NOx 1hr	1ppmv			
0.133	CO2 1hr	Apr. 22 18:38	0.25%	CO 1hr	5ppmv	NOx 1hr	156ppmv			
0.153	CO2 1hr	Apr. 22 18:39	0.29%	CO 1hr	7ppmv	NOx 1hr	177ppmv			
0.173	CO2 1hr	Apr. 22 18:40	0.32%	CO 1hr	9.30%	NOx 1hr	177ppmv			NOx 180
0.193	CO2 1hr	Apr. 22 18:41	0.33%	CO 1hr	5.7ppmv	NOx 1hr	3.71%			
0.213	CO2 1hr	Apr. 22 18:42	0.26%	CO 1hr	26ppmv	NOx 1hr	0.01ppm			
0.233	CO2 1hr	Apr. 22 18:43	0.26%	CO 1hr	5ppmv	NOx 1hr	0ppmv			
0.253	CO2 1hr	Apr. 22 18:44	0.26%	CO 1hr	121ppmv	NOx 1hr	0ppmv			
0.273	CO2 1hr	Apr. 22 18:45	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.293	CO2 1hr	Apr. 22 18:46	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.313	CO2 1hr	Apr. 22 18:47	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.333	CO2 1hr	Apr. 22 18:48	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.353	CO2 1hr	Apr. 22 18:49	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.373	CO2 1hr	Apr. 22 18:50	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.393	CO2 1hr	Apr. 22 18:51	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.413	CO2 1hr	Apr. 22 18:52	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.433	CO2 1hr	Apr. 22 18:53	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.453	CO2 1hr	Apr. 22 18:54	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.473	CO2 1hr	Apr. 22 18:55	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.493	CO2 1hr	Apr. 22 18:56	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.513	CO2 1hr	Apr. 22 18:57	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.533	CO2 1hr	Apr. 22 18:58	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.553	CO2 1hr	Apr. 22 18:59	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			
0.573	CO2 1hr	Apr. 22 19:00	0.27%	CO 1hr	10ppmv	NOx 1hr	0ppmv			

O₂/CO₂ mtd
CO zero

CO 120

O₂/CO₂/SO₂/NO_x
zero

END
Run 3
1825

APPENDIX E
CALIBRATION DATA SHEETS



Scott Specialty Gases

2330 HAMILTON BOULEVARD SOUTH PLAINFIELD NJ 07080 (908)754-7700 FAX:(908)754-7303

CERTIFICATE OF ANALYSIS: Interference-Free Multi-Component EPA Protocol GAS

Customer
TRC ENVIRONMENTAL
ATTN: ED SANTOS
5 WATERSIDE CROSSING
WINDSOR CT 06095

Assay Laboratory
Scott Specialty Gases
2330 Hamilton Blvd
South Plainfield NJ 07080

Purchase order 90PSO2/120PCO/N2E
Scott Project #0741302

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards - Procedure G1 September 1993

Cylinder Number ALM038611
Cylinder Pressure 2000psig

Certification Date 01-19-1996

Expiration Date 1-19-1998

ANALYZED CYLINDER

Components
(CARBON MONOXIDE)
(SULFUR DIOXIDE)

Certified Concentration
120ppm
90.8ppm

Analytical Uncertainty*
+/-1%NIST Directly Traceable
+/-1%NIST Directly Traceable

(Nitrogen gas 7727379)

Balance

4

*Do not use when cylinder Pressure is below 150 psig

*Analytical accuracy is inclusive of usual known error sources which at least includes precision of the measurement process

REFERENCE STANDARD

Type Expiration Date
NTRM1679 08/11/95
NTRM1694 05/11/97

Cylinder Number
ALM041538
ALM040185

Concentration
97.1 ppmCO in N2
94.4 ppmSO2 in N2

INSTRUMENTATION

Instrument/Model/Serial#
CO:NICOLET/8220AAB9400258
SO2:NICOLET/8220AAB9400258

Date Last Calibrated
12/26/1995
01-19-1996

Analytical Principle
FTIR
FTIR

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
CARBON MONOXIDE	Date: 01-10-1996 Response units: ppm Z1=0 R1=97.1 T1=120 R2=97.1 Z2=0 T2=120 Z3=0 T3=120 R3=97.1 Ave. Conc. of Cust. Cyl. = 120	Date: 01-19-1996 Response units: ppm Z1=0 R1=97.1 T1=120 R2=97.1 Z2=0 T2=120 Z3=0 T3=120 R3=97.1 Ave. Conc. of Cust. Cyl. = 120	Concentration = A + Bx + Cx ² + Dx + Ex r = 0.999999 Constants: A = -7.8316E-03 B = 1.0781E-04 C = D = E =
SULFUR DIOXIDE	Date: 01-10-1996 Response units: ppm Z1=0 R1=94.4 T1=90.4 R2=94.4 Z2=0 T2=90.4 Z3=0 T3=90.4 R3=94.4 Ave. Conc. of Cust. Cyl. = 90.4	Date: 01-19-1996 Response units: ppm Z1=0 R1=94.4 T1=91.1 R2=94.4 Z2=0 T2=91.1 Z3=0 T3=91.1 R3=94.4 Ave. Conc. of Cust. Cyl. = 91.1	Concentration = A + Bx + Cx ² + Dx + Ex r = 1 Constants: A = 1.46931E-1 B = 9.36614E-1 C = 4.07252E-5 D = E =

Special Notes

Analyst: Tom DeKing



Scott Specialty Gases

2330 HAMILTON BOULEVARD SOUTH PLAINFIELD NJ 07080 (908)754-7700 FAX:(908)754-7303

CERTIFICATE OF ANALYSIS: Interference-Free Multi-Component EPA Protocol GAS

Customer
TRC ENVIRONMENTAL
ATTN: RAY POTTER
5 WATERSIDE CROSSING
RECEIVING DEPARTMENT
WINDSOR CT 06095

Assay Laboratory
Scott Specialty Gases
2330 Hamilton Blvd
South Plainfield NJ 07080

Purchase order 120pSO2/280CO/N2E
Scott Project #0741303

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards - Procedure G1 September 1993

Cylinder Number ALM063760
Cylinder Pressure 2000psig
ANALYZED CYLINDER
Components
(CARBON MONOXIDE)
(SULFUR DIOXIDE)

(Nitrogen cas 7727379)

Certification Date 01-18-1996

Certified Concentration
278ppm
123ppm

Balance

Expiration Date 1-18-1998

Analytical Uncertainty*
+/-1%NIST Directly Traceable
+/-1%NIST Directly Traceable

*Do not use when cylinder Pressure is below 150 psig

*Analytical accuracy is inclusive of usual known error sources which at least includes precision of the measurement processes

REFERENCE STANDARD

Type **Expiration Date**
CRM2636 08/12/96
NTRM1694 05/11/97

Cylinder Number
ALM034179
ALM040185

Concentration
244.2 ppmCO in N2
94.4 ppmSO2 in N2

INSTRUMENTATION

Instrument/Model/Serial#
CO: NICOLET/8220AAB9400258
SO2: NICOLET/8220AAB9400258

Date Last Calibrated
12/26/1995
01-18-1996

Analytical Principle
FTIR
FTIR

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
CARBON MONOXIDE	Date: 01-10-1996 Response units: ppm Z1=0 R1= 244.2 T1=278 R2= 244.2 Z2=0 T2=278 Z3=0 T3=278 R3= 244.2 Ave. Conc. of Cust. Cyl. = 278	Date: 01-18-1996 Response units: ppm Z1=0 R1= 244.2 T1=278 R2= 244.2 Z2=0 T2=278 Z3=0 T3=278 R3= 244.2 Ave. Conc. of Cust. Cyl. = 278	Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴ r = 0.9999999 Constants: A = -7.8316E-03 B = 1.0783E-04 C = D = E =
SULFUR DIOXIDE	Date: 01-10-1996 Response units: ppm Z1=0 R1= 94.4 T1=122 R2= 94.4 Z2=0 T2=122 Z3=0 T3=122 R3= 94.4 Ave. Conc. of Cust. Cyl. = 122	Date: 01-18-1996 Response units: ppm Z1=0 R1= 94.4 T1=123 R2= 94.4 Z2=0 T2=123 Z3=0 T3=123 R3= 94.4 Ave. Conc. of Cust. Cyl. = 123	Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴ r = 1 Constants: A = 1.46931E-1 B = 9.36614E-1 C = 4.07252E-5 D = E =

Special Notes

Analyst  Tom Delong



Scott Specialty Gases

2330 HAMILTON BOULEVARD SOUTH PLAINFIELD NJ 07080 (908)754-7700 FAX:(908)754-7303

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS CERTIFICATION

Customer
TRC ENVIRONMENTAL
5 Waterside Crossing
Receiving Department
Windsor CT 06095
Attn: RAY POTTER

Assay Laboratory
Scott Specialty Gases
2330 Hamilton Blvd
South Plainfield NJ 07080

Purchase order 28500
Scott Project #0743885

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards -Procedure G1 September 1993

Cylinder Number ALM026170
Cylinder Pressure 2000psig

Certification Date 03-22-1996

Expiration Date 3-22-1999

ANALYZED CYLINDER

Components
(CARBON DIOXIDE)
(OXYGEN)

Certified Concentration
10.2%
10.2%

Analytical Uncertainty*
+/-1%NIST Directly Traceable
+/-NIST Directly Traceable

(Nitrogen cas7727379)

Balance

*Do not use when cylinder Pressure is below 150 psig

*Analytical accuracy is inclusive of usual known error sources which at least includes precision of the measurement processes

REFERENCE STANDARD

Type **Expiration Date**
NTRM18C00 12/21/96
CRM2658 11/23/96

Cylinder Number
ALM047422
ALM032048

Concentration
17.95 %CO2 in N2
9.68 %O2 in N2

INSTRUMENTATION

Instrument/Model/Serial#
CO2: HORIBA/AIA-23/5657161705
O2: HORIBA/MPA-21A/8506581308

Date Last Calibrated
03/11/1996
03/11/1996

Analytical Principle
NDIR
Paramagnetic

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis:	Calibration Curve
CARBON DIOXIDE	Date: 03-22-1996 Response units: % Z1=0 R1= 17.95 T1=10.2 R2= 17.95 Z2=0 T2=10.2 Z3=0 T3=10.1 R3= 17.95 Ave. Conc. of Cust. Cyl. = 10.2		Concentration = A+Bx+Cx ² +Dx ³ +Ex ⁴ r=0.9999919 Constants: A= -3.7268E-02 B=5.7325E-05 C= D= E=
OXYGEN	Date: 03-22-1996 Response units: % Z1=0 R1= 9.68 T1=10.2 R2= 9.68 Z2=0 T2=10.2 Z3=0 T3=10.2 R3= 9.68 Ave. Conc. of Cust. Cyl. = 10.2		Concentration = A+Bx+Cx ² +Dx ³ +Ex ⁴ r=0.9999944 Constants: A= -2.8496E-02 B=1.7674E-05 C= D= E=

Special Notes

Analyst John O'Shea



Scott Specialty Gases, Inc.

2330 HAMILTON BOULEVARD SOUTH PLAINFIELD NJ 07080 (908)754-7700 FAX:(908)754-7303

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

TRC ENVIRONMENTAL
Boott Mills South
Foot of John Street
Lowell MA 01852
Attn.: CAREN O'BRIEN

Assay Laboratory

Scott Specialty Gases
2330 Hamilton Blvd
South Plainfield NJ 07080

Purchase order to 3527
Scott Project #0730155

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards
-Procedure 1 September 1993

Cylinder Number ALM027466

Certification Date 10-03-1994

Expiration Date 10-03-1997

Cylinder Pressure 2000psig

ANALYZED CYLINDER

Components

(CARBON DIOXIDE)
(OXYGEN)

Certified Concentration

19.8%
22.3%

Analytical Uncertainty*

+/-1%NIST Directly Traceable
+/-NIST Directly Traceable

(Nitrogen cas 7727379)

Balance

*Do not use when cylinder Pressure is below 150 psig

*Analytical accuracy is inclusive of usual known error sources which at least includes precision of the measurement processes

REFERENCE STANDARD

Type

SRM2745
CRM2659

Expiration Date

10/30/97
10/31/94

Cylinder Number

SX20316
ALM017576

Concentration

15.8 % CO2 in N2
20.6 % O2 in N2

INSTRUMENTATION

Instrument/Model/Serial#

CO2: Varian-3700-31608928
O2: Varian-3700-31608928

Date Last Calibrated

09/06/1994
09/06/1994

Analytical Principle

GC TCD
GC TCD

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE

Date: 10-03-1994 Response units: %
Z1=0 R1= 15.8 T1=19.9
R2= 15.8 Z2=0 T2=19.8
Z3=0 T3=19.8 R3= 15.8
Ave. Conc. of Cust. Cyl. = 19.8

Concentration = $A + Bx + Cx^2 + Dx^3 + Ex^4$
 $r = 0.9999919$
Constants: A = -3.7268E-02
B = 5.7325E-05 C =
D = E =

OXYGEN

Date: 10-03-1994 Response units: %
Z1=0 R1= 20.6 T1=22.3
R2= 20.6 Z2=0 T2=22.2
Z3=0 T3=22.3 R3= 20.6
Ave. Conc. of Cust. Cyl. = 22.3

Concentration = $A + Bx + Cx^2 + Dx^3 + Ex^4$
 $r = 0.9999944$
Constants: A = -2.8496E-02
B = 1.7674E-05 C =
D = E =

Special Notes


Analyst Adela Sy



Scott Specialty Gases

2330 HAMILTON BOULEVARD SOUTH PLAINFIELD NJ 07080 (908)754-7700 FAX:(908)754-7303

CERTIFICATE OF ANALYSIS: Interference-Free Multi-Component EPA Protocol GAS

Customer
TRC ENVIRONMENTAL
Boot Mills South
Foot of John Street
Lowell MA 01852
Attn.: CAREN O'BRIEN

Assay Laboratory
Scott Specialty Gases
2330 Hamilton Blvd
South Plainfield NJ 07080

Purchase order L27131
Scott Project #0736708

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards
-Procedure G1 September 1993

Cylinder Number ALM043688
Cylinder Pressure 2000psig

Certification Date 07-31-1995

Expiration Date 7-31-1997

ANALYZED CYLINDER

Components
(NITRIC OXIDE)

Certified Concentration
180ppm

Analytical Uncertainty*
+/-1%NIST Directly Traceable

(Nitrogen cas7727379)
Total Oxides of Nitrogen

Balance
180ppm

Reference Value Only

*Do not use when cylinder Pressure is below 150 psig

*Analytical accuracy is inclusive of usual known error sources which at least includes precision of the measurement processes

REFERENCE STANDARD

Type **Expiration Date**
NTRM1685 **08/04/96**

Cylinder Number
ALM036278

Concentration
245 ppmNO in N2

INSTRUMENTATION

Instrument/Model/Serial#
NO:TECO/10S/C5404 225

Date Last Calibrated.
07/10/1995

Analytical Principle
CHEMILUMINESCENCE

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

NITRIC OXIDE

First Triad Analysis

Date: 07-20-1995 Response units: ppm
Z1=0 R1= 245 T1=180
R2= 245 Z2=0 T2=180
Z3=0 T3=180 R3= 245
Ave. Conc. of Cust. Cyl. = 180

Second Triad Analysis

Date: 07-31-1995 Response units: ppm
Z1=0 R1= 245 T1=181
R2= 245 Z2=0 T2=180
Z3=0 T3=180 R3= 245
Ave. Conc. of Cust. Cyl. = 180

Calibration Curve

Concentration = $A+Bx+Cx^2+Dx^3+Ex^4$
 $r=0.99999$
Constants: A= 4.315567E-02
 B=0.4599E+00 C=
 D= E=

Special Notes

Analyst Steven Yu



Scott Specialty Gases

2330 HAMILTON BOULEVARD SOUTH PLAINFIELD NJ 07080 (908)754-7700 FAX:(908)754-7303

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer TRC ENVIRONMENTAL Boott Mills South Foot of John Street Lowell MA 01852 Attn.: CAREN O'BRIEN	Assay Laboratory Scott Specialty Gases 2330 Hamilton Blvd South Plainfield NJ 07080	Purchase order T03890 Scott Project #0734034
---	---	---

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards -Procedure G1 September 1993

Cylinder Number ALM 009773	Certification Date 04-24-1995	Expiration Date 4-24-1997
Cylinder Pressure 2000psig		
ANALYZED CYLINDER	Certified Concentration	Analytical Uncertainty*
Components (NITRIC OXIDE)	255ppm	+/-1%NIST Directly Traceable

(Nitrogen gas 7727379)	Balance	
Total Oxides of Nitrogen	255ppm	Reference Value Only

*Do not use when cylinder Pressure is below 150 psig

*Analytical accuracy is inclusive of usual known error sources which at least includes precision of the measurement processes

REFERENCE STANDARD

Type	Expiration Date	Cylinder Number	Concentration
NTRM1685	08/04/96	ALM036278	245 ppmNO in N2

INSTRUMENTATION

Instrument/Model/Serial# NO:TECO/10S/26404 225	Date Last Calibrated 04/01/1995	Analytical Principle CHEMILUMINESCENCE
--	---	--

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
NITRIC OXIDE	Date: 04-14-1995 Response units: ppm Z1=0 R1= 245 T1=255 R2= 245 Z2=0 T2=255 Z3=0 T3=255 R3= 245 Ave. Conc. of Cust. Cyl. = 255	Date: 04-24-1995 Response units: ppm Z1=0 R1= 245 T1=254 R2= 245 Z2=0 T2=254 Z3=0 T3=254 R3= 245 Ave. Conc. of Cust. Cyl. = 254	Concentration = A+Bx+Cx ² +Dx ³ +Ex ⁴ r=0.99999 Constants: A= 4.315567E-02 B=0.4599E+00 C= D= E=

Special Notes

Analyst Adela Sy



Scott Specialty Gases

2330 HAMILTON BOULEVARD SOUTH PLAINFIELD NJ 07080 (908)754-7700 FAX:(908)754-7303

CERTIFICATE OF ANALYSIS: Interference-Free Multi-Component EPA Protocol GAS

Customer
TRC ENVIRONMENTAL
Boot Mills South
Foot of John Street
Lowell MA 01852
Attn.: CAREN O'BRIEN

Assay Laboratory
Scott Specialty Gases
2330 Hamilton Blvd
South Plainfield NJ 07080

Purchase order 28097
Scott Project #0740266

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards - Procedure G1 September 1993

Cylinder Number ALM021721
Cylinder Pressure 2000psig

Certification Date 11-27-1995

Expiration Date 11-27-1997

ANALYZED CYLINDER

Components
(CARBON MONOXIDE)
(SULFUR DIOXIDE)

Certified Concentration

62.0ppm
84.6ppm

Analytical Uncertainty*

+/-1%NIST Directly Traceable
+/-1%NIST Directly Traceable

(Nitrogen cas7727379)

Balance

*Do not use when cylinder Pressure is below 150 psig

*Analytical accuracy is inclusive of usual known error sources which at least includes precision of the measurement processes

REFERENCE STANDARD

Type **Expiration Date**
NTRM1679 08/11/96
NTRM1694 05/11/97

Cylinder Number
ALM041538
ALM040185

Concentration
97.1 ppmCO in N2
94.4 ppmSO2 in N2

INSTRUMENTATION

Instrument/Model/Serial#
CO: NICOLET /8220AAB9400258
SO2: NICOLET/8220AAB940058

Date Last Calibrated
10/27/1995
12-01-1995

Analytical Principle
FTIR
FTIR

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON MONOXIDE Date: 11-20-1995 Response units: ppm
Z1=0 R1= 97.1 T1=62.0
R2= 97.1 Z2=0 T2=62.0
Z3=0 T3=62.0 R3= 97.1
Ave. Conc. of Cust. Cyl. = 62

Date: 11-27-1995 Response units: ppm
Z1=0 R1= 97.1 T1=62.0
R2= 97.1 Z2=0 T2=62.0
Z3=0 T3=62.0 R3= 97.1
Ave. Conc. of Cust. Cyl. = 62

Concentration = $A + Bx + Cx^2 + Dx^3 + Ex^4$
 $r = 0.9999999$
Constants: A = -7.8316E-03
B = 1.0783E-04 C =
D = E =

SULFUR DIOXIDE Date: 11-20-1995 Response units: ppm
Z1=0 R1= 94.4 T1=84.4
R2= 94.4 Z2=0 T2=84.5
Z3=0 T3=84.5 R3= 94.4
Ave. Conc. of Cust. Cyl. = 84.5

Date: 11-27-1995 Response units: ppm
Z1=0 R1= 94.4 T1=84.7
R2= 94.4 Z2=0 T2=84.8
Z3=0 T3=84.6 R3= 94.4
Ave. Conc. of Cust. Cyl. = 84.7

Concentration = $A + Bx + Cx^2 + Dx^3 + Ex^4$
 $r = 1$
Constants: A = 1.46931E-1
B = 9.36614E-1 C = 4.07252E-5
D = E =

Special Notes

Analyst Tom Delong

METHOD 5 DRY GAS METER CALIBRATION

Calibrated By: Brian Kelly

Barometric Pressure, Pb = 29.81 in. Hg

Date: 4/3/96

Meter Box No.: 8138

Orifice Manometer Setting delta H in. H ₂ O	Gas Volume wet test meter V _w , ft ³	Gas Volume dry test meter V _d , ft ³	Temperature				Time T min.	Y	delta H @	Deviation	
			Wet Test Meter t _w , °F	Dry gas meter						Y	delta H @
				Inlet t _{d1} , °F	Outlet t _{d2} , °F	Average t _{da} , °F					
0.5	5.810	5.990	65.0	74	79	76	15.0	0.990	1.812	0.006	0.044
1.0	8.130	8.410	65.0	86	81	83	15.0	0.998	1.845	0.002	0.011
2.0	11.280	11.680	65.0	90	83	87	15.0	1.000	1.910	0.004	0.054
Average								0.996	1.856		

CALCULATIONS

Y	delta H @
$\frac{V_w * P_b * (t_{da} + 460)}{V_d * (P_b + dH/13.6) * (t_w + 460)}$	$\frac{0.0317 * dH}{P_b * (t_{do} + 460)} * \left[\frac{(t_w + 460) * T}{V_w} \right]^2$

Y = Ratio of reading of wet test meter to dry gas meter;
Tolerance for individual value ± 0.02 from average

delta H @ = Orifice pressure differential that equates to 0.75 cfm of air
at 68°F and 29.92 inches of mercury, in. H₂O;
Tolerance for individual values ± 0.20 from average

METER BOX CALIBRATION WORKSHEET

Time Minutes	Inlet Temp.	Outlet Temp.	Meter Box Ser. #	Date
			8138	4/3/96
0	81	78	DGM Serial #	BAR Press (PB) 29.81
2	81	78	Δ H ⑤ 1.0 2.0	Calibrated by B. Kelly
4	83	79		
6	83	79	Final DGM 410.239	Final WTM 6402.13
8	83	79	Initial DGM 404.250	Initial WTM 6396.32
10	83	79	Net DGM 5.99	Net WTM 5.81
12	84	80		
14	84	80	Vac. in. HG. 3in	Average DGM Temperature 76.33
15	84	80		
AVG	73.55	79.11	y = _____ =	
			Δ H = _____ [_____] ² =	
			Wet Test Meter Temperature	65
			Total Time, minutes; seconds	15.0

METER BOX CALIBRATION WORKSHEET

Time Minutes	Inlet Temp.	Outlet Temp.	Meter Box Ser. # 8138	Date 4/3/96
0	85	80	DGM Serial #	BAR Press (PB) 29.81
2	85	80	ΔH .5 <u>1.0</u> 2.0	Calibrated by B. Kelly
4	86	81		
6	85	81	Final DGM 421.141	Final WTM 6412.68
8	86	81	Initial DGM 412.735	Initial WTM 6404.55
10	86	81	Net DGM	Net WTM
12	87	81	8.41	8.13
14	87	81	Vac. in. HG.	Average DGM Temperature
15	87	81	3.2	83.44
Avg	86.11	80.77	y = _____ =	
			$\Delta H = \text{_____} \left[\text{_____} \right]^2 =$	
			Wet Test Meter Temperature 65°	
			Total Time, minutes; seconds <u>15.0</u>	


METER BOX CALIBRATION WORKSHEET

Time Minutes	Inlet Temp.	Outlet Temp.	Meter Box Ser. #	Date
			8138	4/3/96
0	88	82	DGM Serial #	BAR Press (PB) 29.81
2	90	82	Δ H .5 1.0 2.0	Calibrated by B. Kelly
4	90	82		
6	91	83	Final DGM 434.063	Final WTM 6425.17
8	91	83	Initial DGM 422.384	Initial WTM 6413.89
10	91	83	Net DGM 11.68	Net WTM 11.28
12	91	83		
14	91	83	Vac. in. HG. 3 in	Average DGM Temperature 86.55
15	91	83		
Avg	90.44	82.66	y = _____ =	
			Δ H = _____ [_____] ² =	
			Wet Test Meter Temperature 65	
			Total Time, minutes; seconds (15.0)	

Thermocouple Calibration Form

Box # 8138

Thermocouple Number	Temperature Reading 1	Reference Temperature 1	Temperature Reading 2	Reference Temperature 2	Temperature Reading 3	Reference Temperature 3
1	202	200	500	500	701	700
2	201	200	500	500	701	700
3	201	200	500	500	701	700
4	201	200	500	500	701	700
5	201	200	500	500	701	700
1	51	50	75	75	100	100
2	50	50	75	75	99	100
3	50	50	75	75	99	100
4	50	50	74	75	100	100
5	50	50	74	75	99	100



Signature of Person Performing Calibration

10/16/95

Calibration Date

METHOD 5 DRY GAS METER CALIBRATION

Calibrated By: Scott James

Barometric Pressure, Pb = 30.42 in. Hg

Date: 5/9/96

Meter Box No.: 8138

Orifice Manometer Setting delta H in. H ₂ O	Gas Volume wet test meter V _w , ft ³	Gas Volume dry test meter V _d , ft ³	Temperature				Time T min.	Y	delta H @	Deviation	
			Wet Test Meter t _w , °F	Dry gas meter		Y				delta H @	
				Inlet tdi, °F	Outlet tdo, °F						Average tda, °F
0.5	5.840	5.974	71.0	86	80	83	15.0	0.999	1.793	0.001	0.063
1.0	8.120	8.333	72.0	88	84	86	15.0	0.997	1.851	0.001	0.005
2.0	11.250	11.567	72.0	92	85	89	15.0	0.998	1.923	0.000	0.067
Average								0.998	1.856		


CALCULATIONS

Y	delta H @
$\frac{V_w * P_b * (t_{da} + 460)}{V_d * (P_b + dH/13.6) * (t_w + 460)}$	$\frac{0.0317 * dH * (t_w + 460) * T}{P_b * (t_{do} + 460) * V_w}$

Y = Ratio of reading of wet test meter to dry gas meter;
Tolerance for individual value ± 0.02 from average

delta H @ = Orifice pressure differential that equates to 0.75 cfm of air
at 68°F and 29.92 inches of mercury, in. H₂O;
Tolerance for individual values ± 0.20 from average

METER BOX CALIBRATION WORKSHEET

Time Minutes	Inlet Temp.	Outlet Temp.	Meter Box Ser # 8138	Date 5/9/96
0	84	78	DGM Serial # 8138	BAR Press (PB) 30.42
2	85	79	Δ H ⑤ 1.0 2.0	Calibrated by 
4	85	79		
6	86	80	Final DGM 238.876	Final WTM 6596.36
8	87	81	Initial DGM 232.902	Initial WTM 6590.52
10	87	81	Net DGM	Net WTM
12	86	82	5.974	5.84
14	86	82	Vac. in. HG.	Average DGM Temperature
15	86	82	2.0	83.1
Ave =	85.8	80.4	y = _____ =	
			Δ H = _____ $\left[\frac{\quad}{\quad} \right]^2 =$	
			Wet Test Meter Temperature 71°	
			Total Time, minutes; seconds 15.0	

Calculations

Y	ΔHθ
$\frac{V_w P_b (t_d + 460)}{V_d \left(P_b + \frac{\Delta H}{13.6} \right) (t_w + 460)}$	$\frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$

METER BOX CALIBRATION WORKSHEET

Time Minutes	Inlet Temp.	Outlet Temp.	Meter Box Ser # 8138	Date 5/9/96
0	87	83	DGM Serial # 8138	BAR Press (PB) 30.42
2	87	83	Δ H .5 <u>1.0</u> 2.0	Calibrated by 
4	87	83		
6	88	83	Final DGM 250.303	Final WTM 6617.51
8	88	84	Initial DGM 241.970	Initial WTM 6609.39
10	88	84	Net DGM	Net WTM
12	89	84	8.333	8.12
14	89	84	Vac. in. HG. 2.0	Average DGM Temperature 85.8
15	89	84		
Ave =	88	83.6	y = _____ =	
			Δ H = _____ $\left[\frac{\quad}{\quad} \right]^2 =$	
			Wet Test Meter Temperature 72°	
			Total Time, minutes; seconds 15.0	

Calculations

Y	ΔHθ
$\frac{V_w P_b (t_d + 460)}{V_d \left(P_b + \frac{\Delta H}{13.6} \right) (t_w + 460)}$	$\frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$

METER BOX CALIBRATION WORKSHEET

Time Minutes	Inlet Temp.	Outlet Temp.	Meter Box Ser # 8138	Date 5/9/96
0	89	84	DGM Serial # 8138	BAR Press (PB) 30.42
2	92	86	Δ H .5 1.0 <u>2.0</u>	Calibrated by 
4	92	85		
6	92	85	Final DGM 263.710	Final WTM 6620.55
8	92	85	Initial DGM 252.143	Initial WTM 6609.30
10	93	85	Net DGM	Net WTM
12	83	85	11.567	11.25
14	93	86	Vac. in. HG.	Average DGM Temperature
15	93	86	2.0	88.65
Ave =	92.1	85.2	y = _____ =	
			Δ H = _____ $\left[\frac{\quad}{\quad} \right]^2 =$	
			Wet Test Meter Temperature 72°	
			Total Time, minutes; seconds 15.0	

Calculations

Y	ΔHθ
$\frac{V_w P_b (t_d + 460)}{V_d \left(P_b + \frac{\Delta H}{13.6} \right) (t_w + 460)}$	$\frac{0.0317 \Delta H}{P_b(t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$

Thermocouple Number	Temperature Reading 1	Reference Temperature 1	Temperature Reading 2	Reference Temperature 2	Temperature Reading 3	Reference Temperature 3		
# 1	33°	32.0°F	253°	250°F	551°F	550°F	1502°F	1500
	33°		253°		551°		1501°F	
	32°		252°		551°		1501°	
Ave =	33°F		253°F		551°F		1501°F	
# 2	33°	32.0°F	253°	250.0°F	551°	550°F	1501°	1500
	33°		253°		551°		1501°	
	33°		252°		551°		1501°	
Ave =	33°F		253°F		551°F		1501°F	
# 3	34°	32.0°F	253°	250°F	551°	550°F	1501°	1500°
	33°		253°		551°		1501°	
	34°		252°		551°		1501°	
Ave =	34°		253°		551°		1501°	
# 4	34°	32.0°F	253°	250°F	551°	550°F	1501°	1500°
	33°		252°		551°		1501°	
	33°		253°		551°		1501°	
Ave =	33°		253°		551°		1501°	

Scott J...
 Signature of Person Performing Calibration

5/9/96
 Calibration Date




APPENDIX F

FACILITY PROCESS DATA


Low Temp

1 - 11:50 - 13:29
2ND - 14:30 - 16:20

3RD - 17:25 - 18:49
4-22-96



© HONEYWELL INC. 30755317
Truline
 FT. WASHINGTON, PA. U.S.A.



14:54
 0 TO 4400 SCFH
 0 TO 2400 DEG F
 04/19/96

**TRC Environmental
Corporation**

Offices located in
major industrial centers
throughout the U.S.

1-800-TRC-5601