

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

**EMISSION TESTING AT
BFI's ARBOR HILLS LANDFILL
NORTHVILLE, MICHIGAN**

September 22 through 25, 1992

Prepared for

**AtmAA, Inc.
21354 Nordhoff Street, Suite 113
Chatsworth, California 91311**

December 1992

Prepared by

**Steiner Environmental, Inc.
4930 Boylan Street
Bakersfield, California 93308**

Report PS-92-2926/Project 7244-92

TABLE OF CONTENTS

Section		Page
1	INTRODUCTION	1-1
2	TEST MATRIX	2-1
3	TEST RESULTS	3-1
4	SAMPLING EQUIPMENT AND PROCEDURES	4-1
5	ANALYSIS PROCEDURES	5-1
6	QUALITY ASSURANCE	6-1
	APPENDIX A - STEINER ENVIRONMENTAL INLET DATA .	A-1
	APPENDIX B - STEINER ENVIRONMENTAL OUTLET DATA .	B-1
	APPENDIX C - FLARE OPERATING DATA	C-1
	APPENDIX D - AtmAA INC. ANALYTICAL DATA	D-1

SECTION 1

INTRODUCTION

At the request of AtmAA, Inc., on behalf of Browning-Ferris Industries (BFI), Steiner Environmental, Inc. conducted a series of emission tests on the enclosed flare system combusting the landfill gas generated at the Arbor Hills sanitary landfill located near Northville, Michigan. The primary purpose of these tests was to determine compliance with the emission limits contained in the permit to construct. A secondary purpose was to evaluate the accuracy of the landfill gas flowmeter which measures and records the volume of gas burned in the flare. The destruction efficiency of several organic compounds in the flare was also determined.

Figure 1 depicts the process of the landfill gas extraction and enclosed flare system. Basically, landfill gas from 78 wells is drawn through the collection system and transported to the flare. The volumetric flowrate of these gases is measured and recorded by a mass flowmeter. At the flare, the landfill gas goes through a water knockout and into two blowers. These blowers deliver the gas to the eight burners in the bottom of the flare. Air for combustion is admitted into the bottom of the flare through manually and automatically controlled dampers. The flare is refractory lined (1-inch AP Green Inswool-HTZ rated at 2700°F backed with 1-inch AP Green Inswool-AP rated at 2400°F)




FIGURE 1. Process of the Landfill Gas Extraction and Enclosed Flare System

carbon steel shell which is 50 feet tall. Sample ports have been installed at the 44 foot level on the flare.

Testing at the inlet of the flare was conducted to determine the volumetric flowrate, moisture and fixed gas composition of the landfill gas. The moisture content of the landfill gas was determined using EPA Method 2. The flowrate was determined using EPA Method 4. The fixed gas composition and methane and non-methane hydrocarbon were determined using summa canisters and FID/TCA analysis. Samples of the landfill gases were also collected in Tedlar bags for trace organic analysis. Finally, landfill gas samples were collected in stainless steel bombs for CHNOS, specific gravity, moisture and Btu analysis using ASTM Methods.

Testing at the outlet of the flare was conducted to continuously measure the emissions of NO_x , CO, CO_2 and O_2 using EPA Methods 7E and 3A under two different flare operating temperatures - 1600°F and 2000°F. Testing was also conducted to determine emissions of SO_2 and SO_3 using EPA Method 8 and emissions of HCl and Cl_2 using EPA Method 26A. Tedlar bag samples of the exhaust gases were also collected to determine specific trace organic species.

Section 2 of this report describes the test matrix for this program.

SECTION 2

TEST MATRIX

Table 2-1 summarizes the tests performed on this program. It was originally planned to conduct tests at 1600° and 2000°F which represent the minimum and maximum limits specified in the permit to construct. Due to ambient conditions (wind blowing into the louvers at the base of the flare) it was difficult to sustain a specific operating temperature. A malfunction in the flare temperature setpoint controller (diagnosed on the last day of testing) also made it difficult to set a precise operating condition. The faulty thermocouple for the setpoint controller was replaced toward the end of the test program (Test #6) and the flare operation was steady from that point.

Section 3 presents the results of these tests.

TABLE 2-1. ARBOR HILLS TEST MATRIX

Date	Test Location	Test Number	Test Condition	Test Parameter	Test Time
9/23/92	Outlet	1 ^a	1904°F	NO _x /CO/CO ₂ /O ₂ /Flowrate/H ₂ O	11:14 am - 1:04 pm
		2 ^a	1861°F	NO _x /CO/CO ₂ /O ₂ /Flowrate/H ₂ O	2:35 pm - 4:26 pm
9/24/92	Outlet	3 ^a	1848°F	NO _x /CO/CO ₂ /O ₂ /HCl/Cl ₂	10:27 am - 12:09 pm
				Fixed Gases/CH ₄	2:12 pm - 2:13 pm
				Trace Organics	2:18 pm - 2:25 pm
		4 ^b	1891°F	NO _x /CO/CO ₂ /O ₂ /HCl/Cl ₂	2:48 pm - 4:45 pm
				Fixed Gases/CH ₄	5:00 pm - 5:01 pm
				Trace Organics	5:05 pm - 5:11 pm
	Inlet	3		Flowrate	12:29 pm - 12:34 pm
				H ₂ O	1:20 pm - 1:55 pm
				Fixed Gases/CH ₄	2:12 pm - 2:13 pm
				Trace Organics	2:18 pm - 2:20 pm
		4		Flowrate	5:29 pm - 5:34 pm
				H ₂ O	5:46 pm - 6:21 pm
				Fixed Gases/CH ₄	5:00 pm - 5:01 pm
				Trace Organics	5:05 pm - 5:07 pm
9/25/92	Outlet	5 ^b	1799°F	NO _x /CO/CO ₂ /O ₂ /SO ₂ /SO ₃	12:29 pm - 2:05 pm
				Fixed Gases/CH ₄	11:23 am - 11:24 am
				Trace Organics	11:27 am - 11:32 am
		6 ^{a,c}	1700°F	NO _x /CO/CO ₂ /O ₂ /SO ₂ /SO ₃	3:44 pm - 5:16 pm

^a = Deadband on setpoint controller set at 20° and changed to 30°

^b = Deadband on setpoint controller set at 50°

^c = Changed out thermocouple for setpoint controller

SECTION 3

TEST RESULTS

All emission data is referenced to 68°F and 29.92 inches Hg. Table 3-1 summarizes the measurements made at the inlet of the flare. Tables 3-2 to 3-4 present the results of the tests conducted at the flare outlet. Table 3-5 compares the measured emissions at the flare outlet to those allowed by the permit. Finally, Table 3-6 presents the VOC reduction efficiencies achieved by the flare on this test program.

3.1 INLET

The volumetric flowrate of the landfill gas entering the flare was measured by EPA Methods 2 and 4 and was compared to the mass flowmeter installed in the gas line leading to the flare. The volumetric flowrates measured by the pitot tube for Tests #3, #4 and #5 were 4970 dscfm, 4893 dscfm, and 4982 dscfm versus the mass flowmeter reading of approximately 7700 scfm (see pages C-2 through C-4). However, it is not known what the "standard temperature or pressure" is for the mass flowmeter or what moisture factor was used to convert acfm to scfm. A different standard temperature or pressure or moisture factor could account for the observed differences.

Using the volumetric flowrates measured by pitot tube at the flare inlet, the excess O₂ in the flare exhaust, and the F-Factor (dscf/MMBtu) for the landfill gas, it was possible to calculate volumetric flowrates

for the flare exhaust and to compare these values with the flowrates measured by the pitot tube during the emission tests. Calculated flare exhaust flowrates for Tests #3, #4 and #5 were 46,635 dscfm, 45,685 dscfm, and 52,733 dscfm versus measured values of 49,403 dscfm, 47,420 dscfm and 53,219 dscfm. The average variation between calculated and measured flare exhaust flowrate was 3.4%.

3.2 OUTLET

Table 3-5 on page 3-9 summarizes the results of the source test and individual comments for each run. An examination of the strip charts for the continuous NO_x, CO, CO₂ and O₂ monitors presents a realistic view of the flare's operation throughout the test program. At the beginning of the test program, it became clear that ambient wind conditions determined, to a large extent, the operational status of the flare. Any attempts to set a particular flare operating temperature using the setpoint controller were defeated by wind blowing into the manual and automatic louvers installed at the base of the flare.

The strip charts for Tests #5 and #6 reveal that the swings present in the earlier tests were now minimized and the flare operated in a more consistent and steady manner. The stack gas temperatures were reduced to 1800°F and 1700°F for Tests #5 and #6 and fluctuations in stack gas temperature were also reduced. NO_x and CO were in compliance for Test #5 but CO emissions were over the limit during the 1700°F test.

Emissions for HCl, Cl₂, SO₂ and SO₃ are not dramatically affected by the flare operating temperature. These species are directly related to the composition of the gas being extracted from the landfill. The SO₂ emissions from the flare were in compliance with the permit limits.

There are no limits for SO_2 emissions and these emissions were very low. No Cl_2 was found in the flare exhaust at the detection level of the method. HCl emissions were higher than the permitted values.

Greater than methane hydrocarbon emissions ($>\text{C}_1$) are influenced by the flare operation. $>\text{C}_1$ hydrocarbon emissions were greater than the permitted values for all three tests (#3, #4 and #5). Using the inlet and outlet $>\text{C}_1$ hydrocarbon emission rates, VOC destruction efficiencies for the flare averaged 97.38%.

The results of the trace organics analysis conducted by AtmAA, Inc. at the inlet and outlet of the flare are contained in Appendix D.

TABLE 3-1. SUMMARY OF SOURCE EMISSION TEST DATA (68 dF)

Unit Tested : BFI ARBOR HILLS
FLARE INLET

Date : SEPT 24, 25, 1992

Test Number	3	4	5	Average
Test Condition				
Barometric Pressure (in. Hg)	29.31	29.3	29.21	29.27
Stack Pressure (in. Hg)	19.91	20.10	19.81	19.94
Stack Area (ft ²)	1.40	1.40	1.40	1.40
Elapsed Sampling Time (min.)	35.0	35.0	35.0	35.00
Volume Gas Sampled (dscf)	19.739	20.068	19.785	19.864

$$1.40 \text{ ft}^2 \cdot \frac{93.86 \text{ ft}}{\text{s}} \times \frac{60 \text{ s}}{\text{min}} = 7884 \text{ CFM}$$

GAS DATA

Average Gas Velocity (fps)	94.52	92.12	94.94	93.86
Average Gas Temperature (dF)	75.17	75.08	74.33	74.86
Gas Flowrate (dscfm)	4,970	4,893	4,982	4,948
Gas Analysis (Volume %)				
Carbon Dioxide, dry	40.80	41.00	40.40	40.73
Oxygen, dry	0.49	0.46	0.44	0.46
Water	4.40	4.35	4.27	4.34

EMISSION CONCENTRATION

analysis 1 Methane %
analysis 2 " "

54.31%	54.19%	54.89%	54.46%
			57.73%

>C1 HC (ppm) as CH₄
as Hexane =
EMISSION RATE - lb/hr

8610.00	11000.00	8090.00	9233.33
			1539

>C1 HC

106.92	134.48	100.69	114.03
--------	--------	--------	--------

TABLE 3-2. SUMMARY OF SOURCE EMISSION TEST DATA (68 dF)

Unit Tested : BFI ARBOR HILLS
FLARE OUTLET

Date : SEPT 23, 1992

Test Number	1	2	Average
Test Condition	1904 dF	1861 dF	
Barometric Pressure (in. Hg)	29.23	29.32	29.28
Stack Pressure (in. Hg)	29.23	29.32	29.27
Stack Area (ft ²)	106.14	106.14	106.14
Elapsed Sampling Time (min.)	72.0	72.0	72.00
Volume Gas Sampled (dscf)	55.945	53.506	54.726
F-Factor	8388.01	8388.01	8388.01

GAS DATA

Average Gas Velocity (fps)	38.49	37.49	37.99
Average Gas Temperature (dF)	1904.04	1860.79	1882.42
Gas Flowrate (dscfm)	49,935 ✓	47,706 ✓	48,821
Gas Analysis (Volume %)			
Carbon Dioxide, dry	9.67	9.63	9.65
Oxygen, dry	11.03	11.15	11.09
Water	6.62	10.37	8.50

EMISSION CONCENTRATION

CO (ppm)	73.06	95.37	84.22
NOx (ppm)	19.04	18.20	18.62

EMISSION RATE - lb/hr

CO	15.91	19.84	17.87
NOx	6.81	6.22	6.52

EMISSION FACTOR - lb/MMBtu

CO	0.0944	0.1247	0.1096
NOx	0.0404	0.0391	0.0397

EMISSION FACTOR - tons/yr

CO	69.69	86.90	78.29
NOx	29.83	27.24	28.54

TABLE 3-3. SUMMARY OF SOURCE EMISSION TEST DATA (68 dF)

Unit Tested : BFI ARBOR HILLS
FLARE OUTLET

Date : SEPT 24, 1992

Test Number	3	4	Average
Test Condition	1848 dF	1891 dF	
Barometric Pressure (in. Hg)	29.33	29.31	29.32
Stack Pressure (in. Hg)	29.33	29.31	29.32
Stack Area (ft ²)	106.14	106.14	106.14
Elapsed Sampling Time (min.)	72.0	72.0	72.00
Volume Gas Sampled (dscf)	60.250	59.553	59.901
F-Factor	8386.65	8386.65	8386.65

GAS DATA

Average Gas Velocity (fps)	38.95	37.88	38.41
Average Gas Temperature (dF)	1848.08	1891.29	1869.69
Gas Flowrate (dscfm)	49,403	47,420	48,411
Gas Analysis (Volume %)			
Carbon Dioxide, dry	9.67	9.64	9.66
Oxygen, dry	10.85	10.80	10.83
Water	11.17	10.63	10.90

EMISSION CONCENTRATION

HCl (ppm)	6.58	6.24	6.41
CO (ppm)	69.36	14.31	41.84
Cl ₂ (ppm)	<0.01	<0.01	<0.01
NO _x (ppm)	17.42	18.44	17.93
> C1 HC (ppm)	28.80	16.40	22.60

EMISSION RATE - lb/hr

HCl	1.85	1.68	1.77
CO	14.94	2.96	8.95
Cl ₂	<0.01	<0.01	<0.01
NO _x	6.17	6.26	6.21
> C1 HC	3.55	1.94	2.75

EMISSION FACTOR - lb/MMBtu

HCl	0.0109	0.0102	0.0106
CO	0.0880	0.0181	0.0530
Cl ₂	<0.00003	<0.00003	<0.00003
NO _x	0.0363	0.0382	0.0373
> C1 HC	0.0209	0.0119	0.0164

EMISSION FACTOR - tons/yr

HCl	8.10	7.36	7.73
CO	65.44	12.96	39.20
Cl ₂	<0.04	<0.04	<0.04
NO _x	27.02	27.42	27.22
> C1 HC	15.55	8.50	12.02

TABLE 3-4. SUMMARY OF SOURCE EMISSION TEST DATA (68 dF)

Unit Tested : BFI ARBOR HILLS
FLARE OUTLET

Date : SEPT 25, 1992

*only test #6 data were used
Problems & Sampling during other tests*

	5	6	Average
1799 dF	1799 dF	1700 dF	
in. Hg)	29.21	29.14	29.18
g)	29.20	29.13	29.17
106.14	106.14	106.14	106.14
(min.)	72.0	72.0	72.00
scf)	59.368	58.484	58.926
	8323.36	8323.36	8323.36

GAS DATA

Average Gas Velocity (fps)	40.82	40.21	40.51
Average Gas Temperature (dF)	1798.79	1700.00	1749.40
Gas Flowrate (dscfm)	53,219	54,669	53,944
Gas Analysis (Volume %)			
Carbon Dioxide, dry	9.02	8.41	8.72
Oxygen, dry	11.45	12.09	11.77
Water	10.26	10.30	10.28
Methane content (From pg. 5-7)		56.93%	

EMISSION CONCENTRATION

LFG FR. = 4982 (From pg. 3-1)

SO3 (ppm)	0.46	0.69	0.38
CO (ppm)	91.07	394.29	242.68
SO2 (ppm)	3.17	3.10	3.14
NOx (ppm)	14.92	11.69	13.31
> C1 HC (ppm)	23.50		23.50

EMISSION RATE - lb/hr

SO3	0.31	0.47	0.39
CO	21.13	94.00 lb/hr	57.57
SO2	1.68	1.69	1.69
NOx	5.69	4.58	5.13
> C1 HC	3.12		3.12

EMISSION FACTOR - lb/MMBtu

SO3	0.0018	0.0028	0.0023
CO	0.1219	0.5663	0.3441
SO2	0.0097	0.0102	0.0100
NOx	0.0328	0.0276	0.0302
> C1 HC	0.0180		0.0180

Avg CO =
0.3441 +
0.0530/2

EMISSION FACTOR - tons/yr

SO3	1.36	2.06	1.71
CO	92.55	411.72	252.14
SO2	7.36	7.40	7.38
NOx	24.92	20.06	22.49

TABLE 3-5. ARBOR HILLS LANDFILL EMISSION CALCULATIONS

	CARBON MONOXIDE (CO)			NITROGEN OXIDES (NO _x)			VOC		SO ₂		HCl		Cl ₂		SO _x	
	lbs/hr	tons/yr	lbs/M8tu	lbs/hr	tons/yr	lbs/M8tu	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr
Run #1 • 1904 F	15.91	69.69	0.0944	6.81	29.83	0.0404	---	---	---	---	---	---	---	---	---	---
Tests #1 and #2: Attempts to set a particular flare operating temperature were defeated by wind blowing into manual/automatic louvers at base of flare; it was not known that the thermocouple for flare temperature setpoint controller was faulty or that setpoint controller deadband was too low (20 F); louvers continually "hunted" for setpoint creating swings in emissions (O ₂ ~7%, NO _x ~25 ppm, CO ~400 ppm). Attempts to block wind with tarp were unsuccessful.																
Run #2 • 1861 F	19.84	86.90	0.1247	6.22	27.24	0.0391	---	---	---	---	---	---	---	---	---	---
See comments under Run #1																
Run #3 • 1848 F • 7,918 acfm • 4,970 dscfm • 5,199 scfm (Inlet Flowrates)	14.94	65.44	0.0860	6.17	27.02	0.0363	3.55	15.55	---	---	1.65	8.10	<0.01	<0.04	---	---
Test #3: Deadband on temperature setpoint controller changed from 20 F to 30 F. Swings in emissions greatly reduced (O ₂ ~2.5%, NO _x ~10 ppm).																
Run #4 • 1891 F • 7,717 acfm • 4,893 dscfm • 5,118 scfm (Inlet Flowrates)	2.96	12.96	0.0181	6.26	27.42	0.0382	1.94	8.50	---	---	1.68	7.86	<0.01	<0.04	---	---
Tests #4 and #5: Deadband on temperature setpoint controller changed from 30 F to 50 F. Swings in emissions reduced even more.																

TABLE 3-5. ARBOR HILLS LANDFILL EMISSION CALCULATIONS (Concluded)

	CARBON MONOXIDE (CO)			NITROGEN OXIDES (NO _x)			VOC		SO ₂		HCl		Cl ₂		SO ₃	
	lbs/hr	tons/yr	lbs/HrBtu	lbs/hr	tons/yr	lbs/HrBtu	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr	lbs/hr	tons/yr
Run #5 • 1799° F • 7,954 acfm • 4,982 dscfm • 5,206 scfm (Inlet Flowrates)	21.13	92.55	0.1219	5.69	24.92	0.0328	3.12	13.67	1.60	7.36	---	---	---	---	0.31	1.36
See comments for Run #4.																
Run #6 • 1700° F	94.00	411.72	0.5663	4.58	20.06	0.0276	---	---	1.69	7.40	---	---	---	---	0.47	2.06
Run #6: Replaced faulty thermocouple for temperature setpoint controller; emission swings completely minimized.																
Permit Conditions • ≥1600° F	54.94	240.46	0.33	20.0	87.6	0.12	0.1	0.438	1.8	7.88	1.0	4.38	not regulated	not regulated	not regulated	not regulated
No comments.																

TABLE 3-6. FLARE ^{NMOC} VOC REDUCTION EFFICIENCY

Date	Test No.	Inlet VOC (lb/hr)	Outlet VOC (lb/hr)	Reduction ^A (%)
9/24/92	3	106.92	3.55	96.68
	4	134.48	1.94	98.56
9/25/92	5	100.69	3.12	96.90

$$A = \frac{\text{Inlet} - \text{Outlet}}{\text{Inlet}} \times 100$$

SECTION 4

SAMPLING EQUIPMENT AND PROCEDURES

This section of the report describes the equipment and procedures used to conduct the particulate and gaseous tests on this program.

4.1 PRELIMINARY MEASUREMENTS

Before conducting the stack tests a series of preliminary measurements were made to determine:

- The location of the sampling site and the number and location of the sampling points to be used (EPA Method 1)
- The velocity, temperature and pressure of the gases in the stack (EPA Method 2)
- The composition of the stack gases (EPA Method 3A)
- The moisture content of the stack gases (EPA Method 4)

4.2 PREPARATION OF THE SO₂/SO₃ SAMPLING TRAIN

All sampling train components were cleaned in the laboratory (soap and water, tap water rinse, distilled water rinse, and IPA rinse) to eliminate previous contamination. The sampling train components were sealed and transported to the sampling site in a mobile lab. The EPA Method 8 equipment used to measure SO₂ and SO₃ consisted of:

- A Quartz nozzle for constant rate sampling

- A water cooled Quartz sampling probe (6 feet long) equipped with an S-type pitot tube and a thermocouple to measure stack velocity, pressure and temperature
- A heated Pyrex glass filter holder containing an untared 100-mm Whatman 934 AH glass fiber filter
- A Pyrex glass impinger train in an icebath (impinger 1 contained 100-ml 80% IPA; a Pyrex glass filter holder containing a 47-mm Whatman 934 AH filter; bubbler 2 and impinger 3 each contained 100-ml of 3% H_2O_2 ; bubbler 4 contained a weighed amount of silica gel)
- An umbilical to connect the probe and sample box to the control module
- A control module containing a vacuum pump, a calibrated dry gas meter and a calibrated orifice meter to measure the pressure, temperature and flowrate throughout the train.

The sampling train was charged in the mobile lab using freshly prepared reagents. Each impinger and its contents was weighed to the nearest 0.1 gm on a calibrated electronic balance. Blanks of all filters and reagents were retained for subsequent analysis. The sampling point locations were marked on the probe using a high-temperature marker. The sampling train was completely assembled and lifted to the sampling site.

4.3 SAMPLING PROCEDURES FOR SO_2/SO_3 SAMPLING TRAIN

Prior to a test, the sampling train was heated and leak-checked at 15-inches Mercury to insure leakage was less than 0.02 or 4% of the average sampling rate. The S-type pitot tube was also leak-checked. The

sampling train was installed on the unirail and the probe was inserted into the stack at the farthest point. A constant sampling rate was calculated using an HP-41CV calculator for each sampling point on the traverse (6 points per traverse; 4 traverses at 90°). Each point was sampled for an equal period of time (3 minutes) and all pertinent data were recorded on the data sheet every 3 minutes for each point. The probe and sample box were maintained at 250°F throughout the traverse. The gases leaving the impinger train were maintained at <68°F. At the end of a traverse, the probe was withdrawn from the stack and the entire sampling train was transferred intact to the next sampling port. The remaining traverses of the stack were completed and the sampling train was withdrawn for the final leak-check. This leak-check was performed at 15-inches Mercury or at the highest vacuum achieved during the test. The S-type pitot tube was also checked at this time. The sampling train was then purged with ambient air for 15-minutes using the highest ΔH measured during the test. After the train was purged, the sample box and impinger train were sealed with aluminum foil and lowered to the mobile lab for sample recovery.

4.4 SAMPLE RECOVERY PROCEDURES FOR SO₂/SO₃ SAMPLING TRAIN

Sample recovery for the nozzle and probe occurred on the stack. The nozzle and probe were brushed and rinsed three times using 80% IPA into a polyethylene sample bottle. Sample recovery for the filter holder and impinger train occurred in the mobile lab. The 100-mm filter was removed from the 4-inch filter holder and sealed in its petri dish. The glass fibers stuck to the gasket were scraped off and put into the petri dish. The front half of the 4-inch glass filter holder was brushed and

rinsed with 80% IPA. Each impinger was removed from the icebath, wiped dry and weighed to the nearest 0.1 gm. The contents of impinger 1 were transferred to a polyethylene sample bottle. The back half of the 4-inch glass filter holder, the glass connectors, impinger 1 and the front half of the 2-inch filter holder were rinsed with 80% IPA and the rinsings were transferred to this same bottle. The 47-mm filter from the 2-inch filter holder was sealed in its petri dish. The contents of bubbler 2 and impinger 3 were transferred to a polyethylene sample bottle. Distilled water rinsings of the back half of the 2-inch filter holder, bubbler 2, the connector and impinger 3 were transferred to this same bottle. All sample bottles and petri dishes were marked and labeled. A chain-of-custody log was completed and the field data sheet was also labeled with the sample ID numbers. The sampling train was then recharged in preparation for the next test.

4.5 PREPARATION OF THE HCl/Cl₂ SAMPLING TRAIN

All sampling train components were cleaned in the laboratory (soap and water, tap water rinse, distilled water rinse, and IPA rinse) to eliminate previous contamination. The sampling train components were sealed and transported to the sampling site in a mobile lab. The EPA Method 26A equipment used to measure HCl and Cl₂ consisted of:

- A Quartz glass nozzle for constant rate sampling
- A water cooled Quartz sampling probe (6 feet long) equipped with an S-type pitot tube and a thermocouple to measure stack velocity, pressure and temperature
- A heated Pyrex glass filter holder containing an untared, Teflon coated, 100-mm Whatman 934 AH glass fiber filter

- A Pyrex glass impinger train in an icebath (impingers 1 and 2 contained 100-ml of 0.1N H_2SO_4 ; impingers 3 and 4 contained 100-ml of 0.1N NaOH; bubbler 5 contained a weighed amount of silica gel)
- An umbilical to connect the probe and sample box to the control module
- A control module containing a vacuum pump, a calibrated dry gas meter and a calibrated orifice meter to measure the pressure, temperature and flowrate throughout the train.

The sampling train was charged in the mobile lab using freshly prepared reagents. Each impinger and its contents was weighed to the nearest 0.1 gm on a calibrated electronic balance. Blanks of all filters and reagents were retained for subsequent analysis. The sampling point locations were marked on the probe using a high-temperature marker. The sampling train was completely assembled and lifted to the sampling site.

4.6 SAMPLING PROCEDURES FOR HCl/Cl_2 SAMPLING TRAIN

Prior to a test, the sampling train was heated and leak-checked at 15-inches Mercury to insure leakage was less than 0.02 cfm or 4% of the average sampling rate. The S-type pitot tube was also leak-checked. The sampling train was installed on the unirail and the probe was inserted into the stack at the farthest point. A constant sampling rate was calculated using an HP-41CV calculator for each sampling point on the traverse (6 points per traverse; 4 traverses at 90°). Each point was sampled for an equal period of time (3 minutes) and all pertinent data were recorded on the data sheet for each point. The probe and sample box were maintained at $250^\circ F$ throughout the traverse. The gases leaving the

impinger train were maintained at $<68^{\circ}\text{F}$. At the end of a traverse, the probe was withdrawn from the stack and the entire sampling train was transferred intact to the next sampling port. The remaining traverses of the stack were completed and the sampling train was withdrawn for the final leak-check. This leak-check was performed at 15-inches Mercury or at the highest vacuum achieved during the test. The S-type pitot tube was also checked at this time. If liquid droplets were present in the filter holder, the train was purged for 15 minutes with clean ambient air to evaporate the droplets. The filter holder and impinger train were sealed with aluminum foil and lowered to the mobile lab for sample recovery.

4.7 SAMPLE RECOVERY PROCEDURES FOR HCl/Cl_2 SAMPLING TRAIN

Sample recovery for the nozzle and probe occurred on the stack. The nozzle and probe were brushed and rinsed three times using distilled water into a polyethylene sample bottle. Sample recovery for the filter holder and impinger train occurred in the mobile lab. The 100-mm filter was removed from the 4-inch filter holder and sealed in its petri dish. The front half of the 4-inch glass filter holder was brushed and rinsed with distilled water. Each impinger was removed from the icebath, wiped dry and weighed to the nearest 0.1 gm. The contents of impingers 1 and 2, and 3 and 4 were transferred to separate glass sample bottles. The back half of the 4-inch glass filter holder, the glass connectors, impingers 1 and 2 were rinsed with distilled water and the rinsings were transferred to the glass sample bottle. The glass connectors and impingers 3 and 4 were rinsed with distilled water and the rinsings were transferred to the other glass sample bottle. All sample bottles and

petri dishes were marked, labeled and sealed. A chain-of-custody log was completed and the field data sheet was also labeled with the sample ID numbers. The sampling train was then recharged in preparation for the next test.

4.8 SAMPLING PROCEDURES FOR CONTINUOUS MONITORING

The continuous monitors used in the Steiner Environmental Mobile Monitoring Lab are shown in Table 4-1. Figure 4-1 is a schematic of the continuous emission monitoring system (CEMS). The procedures used to continuously monitor the stack gases for NO_x , CO, CO_2 and O_2 strictly follow EPA Methods 7E and 3A.

Sample was taken from the stack (24 points) using a water cooled 316 stainless steel probe. Sample gas was transported through a heated Teflon sample line (maintained at $>250^\circ\text{F}$) by a Teflon-lined diaphragm pump to a 316 stainless steel refrigeration type conditioner (Hankison Model E-4G-SS0). The sample gas was passed through the conditioner two separate times under vacuum before entering the pump, then two additional times under pressure. The clean, dry sample gas (approximately 35°F) was then transported to the continuous analyzer system through an unheated Teflon line. A series of flowmeters, valves, and regulators maintained constant flow through the system at a constant pressure.

Prior to the test program, the CEMS was assembled and leak-checked. The water cooled sample probe was sealed with a cap and the flow through the individual rotameters was observed. The leak-check was successful if the pressure at the analyzer system and the flow through the rotameters all dropped to zero. A leak-check of the entire CEMS was performed before and after each test to insure no leaks occurred during movement of the sample probe from port to port.

TABLE 4-1. CONTINUOUS MONITORING LAB - TRAILERS 1, 2 AND 4

NO_x CHEMILUMINESCENT ANALYZER - THERMO ELECTRON MODEL 10

Response Time (0-90%)	1.5 sec - NO mode; 1.7 sec - NO _x mode
Zero Drift	Negligible after 1/2 hour warmup
Linearity	±1% of full scale
Accuracy	Derived from the NO or NO ₂ calibration gas, ±1% of full scale
Output	0-10 V
Operating Ranges	0-2, 10, 25, 100, 250, 1000, 2500 and 10,000 ppm
Flowrate = 2 scfh	0-2.5

O₂ ANALYZER, FUEL TYPE - TELEDYNE MODEL 326

Response Time (0-90%)	60 seconds
Accuracy	±1% of scale at constant temperatures; ±1% of scale of ±5% of reading, whichever is greater, over the operating temperature range
Output	0-1 V
Operating Ranges	0-5%, 10%, 25% O ₂
Flowrate	2 scfh

CO₂/CO INFRARED ANALYZER - ANARAD MODEL AR-600

Response Time (0-90%)	5 seconds
Zero Drift	±1%
Span Drift	±1%
Linearity	1%
Resolution	Less than 1% of full scale
Output	0-1 V
Operating Ranges	0-20% CO ₂ /0-10,000 ppm CO
Flowrate	1000 cc/min

CO GAS FILTER CORRELATION - THERMO ELECTRON MODEL 48

Response Time (0-95%)	1 minute
Zero Drift	±0.2 ppm CO
Span Drift	Less than 1% full scale in 24 hours
Linearity	±1% full scale, all ranges
Accuracy	±0.1 ppm CO
Output	0-10 V
Operating Ranges	1, 2, 5, 10, 20, 50, 100, 200, 500, 1000 ppm
Flowrate	.5 - 2 lpm

SO₂ UV ANALYZER - DUPONT MODEL 400

Response Time (0-90%)	Less than 60 seconds
Zero Drift	Less than 2% full scale in 24 hours
Linearity	±1% full scale
Accuracy	±2% full scale
Output	0-5 V
Operating Ranges	0-100 ppm, 1-1000 ppm
Flowrate	500 - 1500 cc/min

STRIP CHART RECORDERS (3) - LINSEIS 7025

Pen Response	0.35 seconds Full Scale
Input Spans	1, 2, 5, 10, 20, 50, 100 MV
Zero Set	Stable across entire chart-width ±100%
Accuracy	.35% of Span
Dead Band	.15% of Span
Linearity	.25% of Span
Chart Speed	1, 2, 5, 10, 20, 50, 100 cm/min; 1, 2, 5, 10, 20, 50 cm/hr; fast advance 100 cm/min; LED indicator; forward and reverse selector
Recording Pen	Fiber tip pen
Chart Width	250 mm

SCOTSMAN TRAILER

Fully Insulated	Air Conditioned - 8 feet x 14 feet x 11 feet
-----------------	--

1. Filter 0.6 μ , 99.9999 percent efficient
2. Duct
3. 316 stainless steel probe
4. 3/8-inch, heated (250°F) Teflon
5. Four-pass conditioner-dryer, 316 stainless steel internals
6. 3/8-inch, unheated Teflon
7. Teflon-lined sample pump
8. 3/8-inch unheated Teflon
9. Rotameter
10. 1/4-inch Teflon tubing
11. Calibration gas manifold
12. Calibration gas selector valve
13. Calibration gas cylinders
14. Backpressure regulator
15. Auxiliary analysis port




FIGURE 4-1. SCHEMATIC OF CONTINUOUS MONITORING SYSTEM

High range calibration gases (EPA Protocol 1) for NO_x , CO , CO_2 and O_2 were then introduced into each analyzer to calibrate the analyzer and recorder via a Environics gas diluter. Once these adjustments were completed, the analyzer calibration error checks were performed. Zero, mid-range and high-range calibration gases were introduced to the gas analyzers. No adjustments were made to the system except those necessary to achieve the proper calibration gas flowrate. The analyzer responses to each calibration gas were recorded on the CEMS field data sheet. If the difference between the gas concentration exhibited by each gas analyzer and the known concentration of each calibration gas, when each calibration gas was introduced directly to each analyzer, was less than $\pm 2\%$ of span for any calibration gas, the check was considered successful. Next, a sampling system bias check was performed by introducing calibration gases at the sample probe. A zero gas and either the mid-range or high-range calibration gas, whichever most closely approximated the stack gas concentrations, was used for this check. No adjustments were made to the system except those necessary to achieve the proper calibration gas flowrate. At the same time, the measurement system response time (95% of gas value) was determined for both the zero and upscale gases. The sampling system bias check was considered valid if the difference between the gas concentrations displayed by the measurement system for the analyzer calibration error check and the sampling system bias check were less than $\pm 5\%$ of span.

The CEMS was now ready for the interference response test for NO_x , CO , CO_2 and O_2 which was performed in accordance with Section 5.4 of EPA Method 20. Each high-range calibration gas was introduced into the

measurement system and the responses for the individual analyzers was recorded. If the response of each analyzer to the other interfering gases was less than $\pm 2\%$ of span, the system was considered to be interference free.

An EPA Protocol 1 gas was introduced directly into the NO_x analyzer (by passing the Environics dilution device) to audit the calibration of the NO_x analyzer.

Each reference method run was 72 minutes in duration.

At the end of each run, the zero and upscale sampling system bias check was repeated. Zero drift and calibration drift determinations were made by calculating the difference in the measurement system output reading from the initial and final calibration response for both the zero and upscale gases. If the drift in either case was less than $\pm 3\%$ of span, then the drift was considered acceptable. If the sampling system bias check was less than $\pm 5\%$ of span, the run was considered valid.

The measured gas concentrations were corrected for sampling system bias in accordance with Section 8 equation 6C-1 of EPA Method 6C.

4.9 SAMPLING PROCEDURES FOR FIXED GASES AND HYDROCARBONS

The sampling train for the fixed gases and hydrocarbons consisted of a probe (4 feet of stainless steel) and a Summa canister. A single point grab sample of the stack gases was collected over a one minute period. After sample collection, the canister was lowered to the mobile lab for subsequent analysis. Triplicate grab samples were collected during the test series:

4.10 SAMPLING PROCEDURES FOR TRACE HYDROCARBONS

The sampling train for hydrocarbons consisted of a probe (4 feet of stainless steel), a Teflon sample line, a Xitech bag sampler and a

Tedlar bag. The entire train was purged with stack gas three times before collecting a sample. An integrated grab sample of the stack gases was collected over a two minute test period. After sample collection, the Tedlar bag was lowered to the mobile lab for subsequent analysis. Triplicate grab samples were collected during the test series.

SECTION 5

ANALYSIS PROCEDURES

This section of the report describes the procedures used to analyze the samples collected during the test program. All SO_2 , SO_3 , HCl and Cl_2 analyses were performed in the Steiner Environmental climate-controlled laboratory in Bakersfield. All fixed gas and hydrocarbon analyses were performed by AtmAA, Inc. in Chatsworth, California. Analysis of the landfill gas was done by Pacific Gas Technology (PGT) in Bakersfield, California.

5.1 ANALYSIS OF SO_2/SO_3 SAMPLES

5.1.1 Filterable Particulate Sulfate

The 80% IPA washings residue and the 100-mm filter were combined and then leached with distilled water to remove sulfate and the leachate was diluted to 100-ml. An aliquot was passed through ion exchange resin and titrated against 0.01N BaCl_2 (which was previously standardized against 0.0100N H_2SO_4) using the barium-thorin titration procedure specified in EPA Method 8. The acetone blank and 100-mm filter blank were treated in an identical manner.

5.1.2 SO_3

The 47-mm glass fiber filter was leached with distilled water and the leachate was added to the contents and washings from impinger 1. The

volume was measured and a 10-ml aliquot was removed for sulfate analysis using the barium-thorin titration procedure. A blank 47-mm filter and 80% IPA solution were treated in the same manner.

5.1.3 SO₂

The volume of contents and washings from bubbler 2 and impinger 3 was measured and an aliquot was analyzed for sulfate using the barium-thorin procedure. A 3% H₂O₂ blank was treated in the same manner.

5.2 ANALYSIS OF HCl SAMPLES

The total volume of sample was measured. A 25-ml aliquot of the liquid was taken from the sample bottle. The Cl⁻ content was determined directly using a calibrated (two points) specific ion electrode. The 25-ml aliquot was placed in a 100-ml beaker with a Teflon stir bar. Chloride ionic strength adjuster (CISA) solution was added to the sample solution (1:1). The electrode was rinsed with distilled water, immersed in the liquid and allowed to reach a stable reading. A blank of the 0.1N H₂SO₄ impinger solution was treated in an identical manner. Some samples were analyzed in duplicate while others were spiked. A known standard was analyzed with the samples.

5.3 ANALYSIS OF Cl₂ SAMPLES

The total volume of sample was measured. A 25-ml aliquot of the liquid was taken from the sample bottle. The Cl⁻ content was determined directly using a calibrated (two points) specific ion electrode. The 25-ml aliquot was placed in a 100-ml beaker with a Teflon stir bar. Chloride ionic strength adjuster (CISA) solution was added to the sample solution (1:1). The electrode was rinsed with distilled water, immersed in the liquid and allowed to reach a stable reading. A blank of the 0.1N NaOH impinger solution was treated in an identical manner. Some samples

were analyzed in duplicate while others were spiked. A known standard was analyzed with the samples.

5.4 ANALYSIS OF THE FIXED GASES AND THE HYDROCARBON SAMPLES

The organic content of the sample fraction collected in each canister was measured by injecting a portion into the FID/TCA analysis system which used two-phase gas chromatography (GC) column to separate carbon monoxide (CO), methane (CH₄) and carbon dioxide (CO₂) from each other and from the total gaseous non-methane organics (TGNMO) which were eluted as a backflush peak. All eluted components were first oxidized to CO₂ by a hopcalite catalyst and then reduced to methane by a nickel catalyst. The resulting methane was detected using the flame ionization detector.

A gas standard containing CO, CH₄, CO₂ and propane, prepared by Scott Specialty Gases, traceable to NBS, was used to calibrate the FID/TCA analysis system.

5.5 FUEL

A sample of the fuel fired during this test program was collected and sent to Pacific Gas Technology for analysis. Analysis was performed by PGT in accordance with EPA Title 40 Section 60.45. The specific procedures are itemized in Table 5-1. The results appear at the end of this section.

TABLE 5-1. FUEL ANALYSIS METHODS
LABORATORY TEST PROCEDURES FOR FUEL OILS AND FUEL GASES

Reference: EPA Title 40, Section 60.45

FUEL OIL TESTS:

Sediment and Water, Vol. %	ASTM D4007-81
Gravity by Hydrometer (API)	ASTM D1298-80
API Gravity Corrected to 60°F	ASTM Table 5A
Gross Calorific Value (Btu/lb)	ASTM D2015-77
Ultimate Analysis (C, H, O, N, S, wt. %)	
Carbon, Hydrogen	ASTM D3178-73
Nitrogen (chemiluminescence detector)	ASTM D3431-80
Sulfur	ASTM D2622-82
Ash	ASTM D482
Oxygen	ASTM D3176-74

GASEOUS FUELS BY GAS-LIQUID CHROMATOGRAPHY:

Gas Analysis	ASTM D1945-81
Sulfur Analysis	CPA B16
Calculation of Gross Calorific Value	ASTM D3588-81
Component Weight %, F-factor calculations	EPA 40:60.45

PROCEDURES FOR SCRUBBER LIQUOR ANALYSIS:

Specific Gravity	ASTM D1429
Chlorides	ASTM D512-67

PACIFIC GAS TECHNOLOGICAL




2122 G Street
Bakersfield, California 93301
805/324-1317
Fax: 805/324-2746

GAS ANALYSIS BY CHROMATOGRAPH

STEINER ENVIRONMENTAL, INC
4930 Boylan Street
Bakersfield, CA 93308

Attention: Jim Steiner

Sample ID : BFI\ARBOR HILLS, MI
FLARE INLET
TEST #1 & #2
METHANE GAS



SAMPLED: SEPTEMBER 23, 1992

SUBMITTED: SEPTEMBER 30, 1992

REPORTED: OCTOBER 6, 1992

LAB # 4706-1

STEINER ID # 33753

ANALYZED GAS

	MOLE %	WT %	CHONS WT %
OXYGEN	1.60	1.84	CARBON 39.53
NITROGEN	6.68	6.71	HYDROGEN 7.69
CARBON DIOXIDE	38.52	60.83	OXYGEN 46.07
HYDROGEN	ND	0.00	NITROGEN 6.71
CARBON MONOXIDE	ND	0.00	SULFUR 0.00
HYDROGEN SULFIDE	ND	0.00	
METHANE	53.20	30.62	
ETHANE	ND	0.00	
PROPANE	ND	0.00	
iso-BUTANE	ND	0.00	
n-BUTANE	ND	0.00	
iso-PENTANE	ND	0.00	
n-PENTANE	ND	0.00	
HEXANE +	ND	0.00	
TOTAL:	100.00		

SPECIFIC GRAVITY * : 0.962

SPECIFIC VOLUME : 15.15 cu ft/lb

HYDROGEN SULFIDE : ppm (GC/FPD)
STEINER ID# :

TOTAL * DRY : 537
BTU/cu ft

NET * DRY : 484
BTU/cu ft WET : 475

WET : 528

BTU/lb : 8133

BTU/lb : 7324

* CALCULATED ACCORDING TO : ASTM D-3588

PACIFIC GAS TECHNOLOGY




2122 G Street
Bakersfield, California 93301
805/324-1317
Fax: 805/324-2746

GAS ANALYSIS BY CHROMATOGRAPH

STEINER ENVIRONMENTAL, INC
4930 Boylan Street
Bakersfield, CA 93308

Attention: Jim Steiner



SAMPLED: SEPTEMBER 24, 1992

SUBMITTED: SEPTEMBER 30, 1992

REPORTED: OCTOBER 6, 1992

LAB # 4706-2

Sample ID : BFI\ARBOR HILLS, MI
FLARE INLET
TEST #3 & #4
METHANE GAS

STEINER ID # 33771

ANALYZED GAS

	MOLE %	WT %	CHONS WT %
OXYGEN	1.57	1.80	CARBON 39.62
NITROGEN	6.45	6.48	HYDROGEN 7.71
CARBON DIOXIDE	38.67	61.04	OXYGEN 46.19
HYDROGEN	ND	0.00	NITROGEN 6.48
CARBON MONOXIDE	ND	0.00	SULFUR 0.00
HYDROGEN SULFIDE	ND	0.00	
METHANE	53.31	30.67	
ETHANE	ND	0.00	
PROPANE	ND	0.00	
iso-BUTANE	ND	0.00	
n-BUTANE	ND	0.00	
iso-PENTANE	ND	0.00	
n-PENTANE	ND	0.00	
HEXANE +	ND	0.00	
TOTAL:	100.00		

SPECIFIC GRAVITY * : 0.962

HYDROGEN SULFIDE :
STEINER ID# : ppm (GC/FPD)

TOTAL * DRY : 538
BTU/cu ft

WET : 529

BTU/lb : 8149

SPECIFIC
VOLUME : 15.15 cu ft/lb

NET * DRY : 485
BTU/cu ft

WET : 476

BTU/lb : 7340

* CALCULATED ACCORDING TO : ASTM D-3588


TECHNOLOGY

2122 G Street
Bakersfield, California 93301
805/324-1317
Fax: 805/324-2746

GAS ANALYSIS BY CHROMATOGRAPH

ER ENVIRONMENTAL, INC
Boylan Street
Bakersfield, CA 93308

Attention: Jim Steiner



SAMPLED: SEPTEMBER 25, 1992

SUBMITTED: SEPTEMBER 30, 1992

REPORTED: OCTOBER 6, 1992

LAB # 4706-3

Sample ID : BFI\ARBOR HILLS, MI
FLARE INLET
TEST #5 & #6
METHANE GAS

STEINER ID # 33794

ANALYZED GAS

	MOLE %	WT %	CHONS WT %
OXYGEN	0.37	0.43	CARBON 42.35
NITROGEN	1.73	1.75	HYDROGEN 8.27
CARBON DIOXIDE	40.97	64.93	OXYGEN 47.64
HYDROGEN	ND	0.00	NITROGEN 1.75
CARBON MONOXIDE	ND	0.00	SULFUR 0.00
HYDROGEN SULFIDE	ND	0.00	
METHANE	56.93	32.89	
ETHANE	ND	0.00	
PROPANE	ND	0.00	
iso-BUTANE	ND	0.00	
n-BUTANE	ND	0.00	
iso-PENTANE	ND	0.00	
n-PENTANE	ND	0.00	
HEXANE +	ND	0.00	
TOTAL:	100.00		

SPECIFIC GRAVITY * : 0.958

SPECIFIC VOLUME : 15.30 cu ft/lb

HYDROGEN SULFIDE : ppm (GC/FPD)
STEINER ID# :

TOTAL * DRY : 575

NET * DRY : 518

BTU/cu ft WET : 565

BTU/cu ft WET : 509

BTU/lb : 8798

BTU/lb : 7919

* CALCULATED ACCORDING TO : ASTM D-3588

SECTION 6

QUALITY ASSURANCE

6.1 MANUAL SAMPLING EQUIPMENT

A detailed record of repair and maintenance to each sampling train is kept. Preventative maintenance to each system is performed periodically to avoid complete component breakdown during a field test.

A detailed record of sampling system calibrations is also kept. Calibration data for the sampling nozzles, pitot tubes, dry gas meters and orifice meters are available for review. Results of the EPA Quality Assurance Branch biannual audits of the dry gas meter and orifice meter combinations are also logged and verify our in-house calibration data. The calibration data for the equipment used on this program can be found in Appendices A and B.

6.2 LAB ANALYSIS

All field samples are assigned a label and an ID number. This ID is also affixed to a chain-of-custody log and to the field data sheet to eliminate any chance of sample mixup.

Prior to analysis, all glassware is thoroughly cleaned (soap and water, tap water rinse, distilled water rinse, IPA rinse) to eliminate any contamination. The evaporating dishes used to evaporate the washings are treated the same as a sample (dried in an oven, desiccated and

weighed repeatedly at 6-hour intervals until a constant weight is achieved). The glassware used to measure volumes and make transfers and dilutions are all NBS Class A to insure accurate measurements.

All weighings are carried out on a Sartorius Research Model R160P electronic semi-micro balance supported by a marble table in a separate room from the main analytical laboratory. The balance is calibrated regularly against an NBS Class S-1 weight.

All reagents used in the field and in the laboratory are ACS reagent grade and blanks of these reagents are evaluated for every set of tests. Blanks are taken in the field from the squeeze bottles and not the original container. Records are kept on these blanks to insure consistent quality of the reagents. Prior to use, the IPA is also analyzed to insure no peroxides are present which could lead to high SO_3 and low SO_2 values.

A quality control program consisting of duplicate analyses (to measure precision), spikes (to measure recovery efficiency) or analysis of blind standards supplied by EPA's Quality Assurance Branch (to measure accuracy) is implemented for each test program. Table 6-1 summarizes the results of the QC checks on this program. Records of our lab's participation in the EPA biannual audits for SO_2 are kept on file and verify our in-house QA/QC effort.

6.3 QUALITY ASSURANCE/QUALITY CONTROL FOR CONTINUOUS MONITORS

The results of the checks performed on the Steiner Environmental CEMS during the test program appear in the Appendix B. All checks were within the limits specified by the test methods.

The interference tests performed on the NO_x and O_2 analyzers using EPA Method 20 were all negative (no interference).

The results of the NO_x audits performed directly at the NO_x analyzer using a separate EPA Protocol 1 gas (39.6 ppm NO_x) were as follows: Tests #1 and #2 - 40.0 ppm; Tests #3 and #4 - 38.5 ppm; Tests #5 and #6 - 39.6 ppm. The multipoint calibration of the analyzers performed with EPA Protocol 1 gases and the Environics gas diluter were in excellent agreement with the audits.


TABLE 6-1. QA/QC RESULTS

Test No.	Test Parameter	Duplicate (%)	Recovery (%)
3	HCl	102.5	
4	HCl		95.5
3	Cl ₂	100.0	
4	Cl ₂		95.2
5	Filterable Sulfate	96.9	
6	Filterable Sulfate		98.4
	EPA SO ₂ Lot 0584 5XXX		99.6
5	SO ₃		100.4
6	SO ₃	98.8	
5	SO ₂	103.0	
6	SO ₂		100.0
	EPA SO ₂ Lot 0584 5XXX		99.9

APPENDIX A
STEINER ENVIRONMENTAL INLET DATA

SAMPLING POINT LOCATION DATA SHEET

Plant B.F.I. Arbor Hills
 Date 9-22-92
 Test Location FLARE INLET
 Upstream Dist./Dia. 31" / 1.94 Ø
 Downstream Dist./Dia. 32" / 2.0 Ø
 No. of Sampling Points 12
 Stack Dimension 16"
 Coupling Length 1"
1-.5 -inch MPT/FPT/Flange



XEQ PNT

Sample Point	Dist	Sample Point	Dist	Sample Point	Dist	Sample Point	Dist
1	1.3						
2	2.1						
3	2.9						
4	3.8						
5	5.0						
6	6.7						
7	11.3						
8	13.0						
9	14.2						
10	15.1						
12	15.9						
12	16.7						

SAMPLING POINT RELOCATION: #1 to 1.5
 #12 to 16.5

VELOCITY TRAVERSE DATA SHEET

Plant BFI Arbor Hills
 Date 9-24-92
 Test Location FLARE Inlet
 Static Pressure (in. wg) 0 - 9.4" Hg
 Barometric Pressure 29.33
 Probe Type/Length N/A
 Pitot Coefficient 0.99
 Stack Dimension 16.0"

Time: 12:29 Time: _____ Time: _____ Time: _____

Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s	Smp1 Pt.	ΔP	T_s
1	0.73	75									
2	1.30	76									
3	1.55	76									
4	1.65	76									
5	1.70	76									
6	1.55	76									
7	1.45	76									
8	1.30	75									
9	1.15	75									
10	1.15	75									
11	1.03	75									
12	0.90	71									

SAMPLING POINT RELOCATION #1 to 1.5"

7487 acfm

4871 dscfm

#12 to 16.5"

Avg. $\sqrt{\Delta P}$ = 1.1271

Avg. ΔP = _____

Avg. T_s = 75.17

VelTrav.Frm (1/91)

VELOCITY TRAVERSE DATA SHEET

Plant BFI Arbor Hills
 Date 9/24/92
 Test Location inlet
 Static Pressure (in. wg) -9.2" Hg

Barometric Pressure 29.31
 Probe Type/Length 55/3'
 Pitot Coefficient 0.99
 Stack Dimension 16

Time: 5:29

Time:

Time:

Time:

Sample Point	ΔP	T_s	Angle	Sample Point	ΔP	T_s	Angle	Sample Point	ΔP	T_s	Angle	Sample Point	ΔP	T_s	Angle
A 1	0.85	75													
2	1.35	75													
3	1.40	75													
4	1.70	75													
5	1.65	75													
6	1.50	75													
7	1.55	75													
8	1.35	75													
9	1.20	75													
10	1.00	75													
11	0.90	75													
12	0.80	76													

SAMPLING POINT RELOCATION

VELTRAV.FRM(9/92)

Avg. $\sqrt{\Delta P}$ = 1.1054

Avg. ΔP = _____

Avg. T_s = 75.08

Angle ° = _____

VELOCITY TRAVERSE DATA SHEET

Plant BFI Arbor Hills Barometric Pressure 29.21
 Date 9/25/92 Probe Type/Length SS/3'
 Test Location Inlet Pitot Coefficient 0.99
 Static Pressure (in. wg) - 9.4 "Hg
 Stack Dimension 16

Time: 11:08				Time:				Time:			
Sample Point	ΔP	T_s	Angle	Sample Point	ΔP	T_s	Angle	Sample Point	ΔP	T_s	Angle
A 1	0.98	75									
2	1.45	75									
3	1.45	75									
4	1.60	75									
5	1.65	74									
6	1.55	74									
7	1.50	74									
8	1.55	74									
9	1.20	74									
10	1.05	74									
11	0.93	74									
12	0.75	74									

SAMPLING POINT RELOCATION

VEL TRAV .FRM(9/92)

Avg. $\sqrt{\Delta P}$ = 1.1275 Avg. ΔP = _____ Avg. T_s = 74.33 Angle ° = _____

Date 9-24-92 Barometric Pressure 29.31
 Test Location FLARE INLET Static in.wg. N/A
 Run Number #1 Probe Type/Length N/A
 Stack Diameter 16.0" Pitot Coefficient N/A
 Operator SW Meter Box No./Y 6825355/0.9832
 Filter No. N/A Nozzle No./Size STRAIGHT

IMPIGGER				VOLUMES/WEIGHTS				GAS COMPOSITION			
Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO	Leakrate	cfm	"Hg	
DI	561.4	547.1	14.3								
DI	520.4	519.7	0.7								
DRY	435.3	435.3	0.0								
S.G.	648.5	641.9	6.6					Initial	0.007	MAX	
		TOTAL	21.6					Final	0.007	MAX	

Sample Point	Time	AP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F						Pump Vacuum in.Hg	√ΔP	Comments
					Stack	Probe	Oven	Imp.	Gas Meter				
									In	Out			
1	13:20	N/A	N/A	012.937	N/A	N/A	N/A	62	N/A	71	MAX	N/A	
	5			015.855				62		72			
	10			018.711				64		72			
	15			022.140				63		73			
	20			025.000				64		73			
	25			027.453				64		73			
	30			030.657				65		74			
END TEST	13:55			033.557									

PLANT BFI Arbor Hills

BFI Aeboe Hills

TEST TYPE

14-2-4

SHEET (Page

1 of

2.

Date 9-24-92 Barometric Pressure 29.30
Test Location F1485 SWIFT Static in.wg. N/A
Run Number #2 Probe Type/Length N/A
Stack Diameter 16.0" Pitot Coefficient N/A
Operator SW Meter Box No./Y 6825355/0.9832
Filter No. N/A Nozzle No./Size STRAIGHT

Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
DI	577.8	561.4	16.4				
DI	521.4	520.4	1.0				
DRY	435.5	435.3	0.2				
				Leakrate			111g
S.G.	654.8	648.5	6.3	Initial	0.003	0.003	MAX
		TOTAL	23.9	Final	0.003	0.003	MAX

[TEMPERATURE • F]

Sample Point	Time	ΔP in wg	AH in wg	Gas Meter Volume Ft ³	Stack	Probe	Oven	Imp.	Gas Meter IN OUT	Pump Vacuum in.Hg	$\sqrt{\Delta P}$	Comments
1	17:46	N/A	N/A	034.385	N/A	N/A	N/P	65	N/A 71	MAX	N/A	
	5			037.375				62	71			
	10			040.380				61	72			
	15			043.372				60	71			
	20			046.360				59	71			
	25			049.338				59	71			
	30			052.320				59	71			
END TEST	18:21			055.299								
T/A	35 min			20,914								

PLANT B.E.I. Arbor Hills

TEST TYPE

M/2/4

FIELD TEST DATA SHEET (Page

1 of 1)

[IMPINGER VOLUMES/WEIGHTS] [GAS COMPOSITION]

Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
DI	573.9	559.4	14.5				
DI	529.8	528.3	1.5				
dry	435.7	435.5	.2				
				Leakrate			Wtg
s.g.	659.9	652.4	7.5	Initial	0.002		MAX
		TOTAL	23.7	Final	0.003		MAX

Date 9-25-92 Barometric Pressure 29.
 Test Location FLARE INLET Static in.wg. N/A
 Run Number #3 Probe Type/Length N/A
 Stack Diameter 6.0" Pitot Coefficient N/A
 Operator SW Meter Box No. 17 6825355/0.9832
 Filter No. N/A Nozzle No./Size STRAIGHT

[TEMPERATURE ° F]

Sample Point	Time	AP in wg	ΔH in wg	Gas Meter Volume Ft ³	Stack	Probe	Oven	Imp.	Gas Meter IN OUT	Pump Vacuum in.Hg	ΔP	Comments
1	11:40	N/A	N/A	055.952	N/A	N/A	N/A	70	N/A 88	MAX	N/A	
	5			059.023				68	89			
	10			062.097				66	89			
	15			065.121				62	91			
	20			068.258				63	91			
	25			071.317				61	92			
	30			074.398				64	92			
END TEST	12:15			077.380								
T/A	35 min			21.428					90.28			

SOURCE TEST CALCULATIONS - SYMBOLS

PLANT :

RUN NO.:

DATE :

T(std) = 68 DEG. F

METER TEMP.	= Tm	DEG. F	STATIC PRESS.	= Pstatic	in. H2O
STACK TEMP.	= Ts	DEG. F	Cp	= 0.840	
SQ.RT. dP	=	in. H2O	STACK I.D.	=	inch
METER ORIFICE	= dH	in. H2O	DUCT LENGTH	=	inch
METER VOLUME	= Vm	Cu.Ft.	DUCT WIDTH	=	inch
METER Y	= Y		STACK AREA	= As	Sq.Ft.
BAR. PRESSURE	= Pb	in.Hg	TEST TIME	= Time	min.
COND. (Vlc)	= Vlc	ml	NOZZLE DIA.	=	inch

GAS ANALYSIS	:	0.00 % O2	0.00 % CO
		0.00 % CO2	100.00 % N2

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots\dots =$ dscf

$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic =$ scf

$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots =$ Lower

Bws @ Saturated Conditions = Vapor Press. of H2O
@ Dew Point Temp. / (Ps, in.Hg.) $\dots\dots\dots =$ Bws value used.

$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 =$

$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] =$

$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots =$

$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots =$ in. Hg

$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots\dots\dots =$ ft/sec

$Qs = vs \times As \times 60 \dots\dots\dots =$ acf/min

$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots\dots\dots =$ dscf/min

$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92)] \times 100 / (Time \times Ps \times An \times vs \times 60) =$ %

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE INLET

RUN NO.: 3
DATE : SEPT 24,25,1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	72.57 DEG. F	:	STATIC PRESS.	=	-127.84 in. H2O
STACK TEMP.	=	75.17 DEG. F	:	Cp	=	0.990
SQ.RT. dP	=	1.1271 in. H2O	:	STACK I.D.	=	16.00 inch
METER ORIFICE	=	1.00 in. H2O	:	DUCT LENGTH	=	inch
METER VOLUME	=	20.620 Cu.Ft.	:	DUCT WIDTH	=	inch
METER Y	=	0.9832	:	STACK AREA	=	1.396 Sq.Ft.
BAR. PRESSURE	=	29.31 in.Hg	:	TEST TIME	=	35.00 min.
COND.(Vlc)	=	21.6 ml	:	NOZZLE DIA.	=	inch
GAS ANALYSIS	=	0.49 % O2		0.00 % CO		
		40.80 % CO2		58.71 % N2		

$$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots\dots = 19.739 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 1.017 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots = 0.049 \text{ : Lower Bws value used.}$$

Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 3.26$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 27.81$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots = 27.38$$

$$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots = 19.91 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots\dots\dots = 94.52 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots\dots\dots = 7,918 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots\dots\dots = 4,970 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) = \%$$

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE INLET

RUN NO.: 4
DATE : SEPT 24, 25, 1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	71.14 DEG. F	:	STATIC PRESS.	=	-125.12 in. H2O
STACK TEMP.	=	75.08 DEG. F	:	Cp	=	0.990
SQ.RT. dP	=	1.1054 in. H2O	:	STACK I.D.	=	16.00 inch
METER ORIFICE	=	1.00 in. H2O	:	DUCT LENGTH	=	inch
METER VOLUME	=	20.914 Cu.Ft.	:	DUCT WIDTH	=	inch
METER Y	=	0.9832	:	STACK AREA	=	1.396 Sq.Ft.
BAR. PRESSURE	=	29.30 in.Hg	:	TEST TIME	=	35.00 min.
COND. (Vlc)	=	23.9 ml	:	NOZZLE DIA.	=	inch

GAS ANALYSIS	:	0.46 % O2		0.00 % CO
		41.00 % CO2		58.54 % N2

$V_m(\text{std}) = [T(\text{std}) + 460 / 29.92] \times V_m \times Y \times$
 $(P_b + (dH / 13.6)) / (T_m + 460) \dots\dots = 20.068 \text{ dscf}$

$V_w(\text{std}) = (8.9148 \times 10e-5) \times (T_{\text{std}} + 460) \times V_{lc} = 1.125 \text{ scf}$

$B_{ws} = V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std})) \dots\dots\dots = 0.053$: Lower
 : Bws

Bws @ Saturated Conditions = Vapor Press. of H2O
 @ Dew Point Temp. / (Ps, in.Hg.) = 0.044 : value
 : used.

$\%EA = (\%O_2 - 0.5\%CO) / (0.264\%N_2 - (\%O_2 - 0.5\%CO)) \times 100 = 3.07$

$M_d = (.44 \times \%CO_2) + (.32 \times \%O_2) + [.28 \times (\%N_2 + \%CO)] = 27.89$

$M_s = (M_d \times (1 - B_{ws})) + (18.0 \times B_{ws}) \dots\dots\dots = 27.46$

$P(\text{stack}) = P_{\text{bar}} + [P_{\text{static}} / 13.6] \dots\dots\dots = 20.10 \text{ in. Hg}$

$v_s = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(T_s + 460) / (M_s \times P_s)] \dots\dots\dots = 92.12 \text{ ft/sec}$

$Q_s = v_s \times A_s \times 60 \dots\dots\dots = 7,717 \text{ acf/min}$

$Q_s(\text{std}) = Q_s \times (1 - B_{ws}) \times ((T_{\text{std}} + 460) / (T_s + 460)) \times (P_s / 29.92) \dots\dots\dots = 4,893 \text{ dscf/min}$

$I = (T_s + 460) \times [(0.002669 \times V_{lc}) + (V_m(\text{std}) / (T_{\text{std}} + 460) / 29.92)] \times 100 / (Time \times P_s \times A_n \times v_s \times 60) = \%$

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE INLET

RUN NO.: 5
DATE : SEPT 24,25,1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	90.28 DEG. F	:	STATIC PRESS.	=	-127.84 in. H2O
STACK TEMP.	=	74.33 DEG. F	:	Cp	=	0.990
SQ.RT. dP	=	1.1275 in. H2O	:	STACK I.D.	=	16.00 inch
METER ORIFICE	=	1.00 in. H2O	:	DUCT LENGTH	=	inch
METER VOLUME	=	21.428 Cu.Ft.	:	DUCT WIDTH	=	inch
METER Y	=	0.9832	:	STACK AREA	=	1.396 Sq.Ft.
BAR. PRESSURE	=	29.21 in.Hg	:	TEST TIME	=	35.00 min.
COND.(Vlc)	=	23.7 ml	:	NOZZLE DIA.	=	inch

GAS ANALYSIS	:	0.44 % O2		0.00 % CO
		40.40 % CO2		59.16 % N2


$V_m(std) = [T(std) + 460 / 29.92] \times V_m \times Y \times$ $(P_b + (dH / 13.6)) / (T_m + 460) \dots\dots$	=	19.785	dscf
$V_w(std) = (8.9148 \times 10e-5) \times (T_{std} + 460) \times V_{ic}$	=	1.116	scf
$B_{ws} = V_w(std) / (V_m(std) + V_w(std)) \dots\dots\dots$	=	0.053	: Lower : Bws
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	0.043	: value : used.
$\%EA = (\%O_2 - 0.5\%CO) / (0.264\%N_2 - (\%O_2 - 0.5\%CO)) \times 100 =$		2.90	
$M_d = (.44 \times \%CO_2) + (.32 \times \%O_2) + [.28 \times (\%N_2 + \%CO)]$	=	27.66	
$M_s = (M_d \times (1 - B_{ws})) + (18.0 \times B_{ws}) \dots\dots\dots$	=	27.25	
$P(stack) = P_{bar} + [P_{static} / 13.6] \dots\dots\dots$	=	19.81	in. Hg
$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(T_s + 460)$ $/ (M_s \times P_s)] \dots\dots\dots$	=	94.94	ft/sec
$Q_s = vs \times A_s \times 60 \dots\dots\dots$	=	7,954	acf/min
$Q_s(std) = Q_s \times (1 - B_{ws}) \times ((T_{std} + 460) / (T_s + 460))$ $\times (P_s / 29.92) \dots\dots\dots$	=	4,982	dscf/min
$I = (T_s + 460) \times [(0.002669 \times V_{lc}) + (V_m(std) / (T_{std} +$ $460) / 29.92] \times 100 / (Time \times P_s \times A_n \times vs \times 60) =$			%

APPENDIX B
STEINER ENVIRONMENTAL OUTLET DATA

SAMPLING POINT LOCATION DATA SHEET

Plant BFI Arbor Hills
 Date 9/22/92
 Test Location Flare Outlet
 Upstream Dist./Dia. 72.75" / 0.5 ϕ
 Downstream Dist./Dia. 408.375" / 2.9 ϕ
 No. of Sampling Points 24
 Stack Dimension 139.5
 Coupling Length 8
4, 3-inch MPT/FPT/Flange

*has hooks
 needs scaffold
 water cooled probe
 heat blankets*



XEQ PNT

Sample Point	Dist	Sample Point	Dist	Sample Point	Dist	Sample Point	Dist
1	11.0						
2	17.3						
3	24.5						
4	32.7						
5	42.9						
6	57.6						

SAMPLING POINT RELOCATION: none

PLANT BFI Arbor Hills TEST TYPE 112/4 FIELD TEST DATA SHEET (Page 1 of 2)

[IMPINGER VOLUMES/WEIGHTS] [GAS COMPOSITION]

Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
DI	611.0	552.9	58.3				
DI	542.3	530.6	11.7				
dry	435.8	432.8	3.0				
S.G.	672.7	656.4	16.3	Leakrate	Initial	0.018	15
		TOTAL	84.3	Final	0.010	5.	

Date 9/23/92 Barometric Pressure 29.23
 Test Location Flare Out Static in.wg. -0.045
 Run Number 1 - 2000° Probe Type/Length Q/7'
 Stack Diameter 189.6 Pitot Coefficient 0.84
 Operator JG Meter Box No./Y 21313 / 1.0098
 Filter No. blank Nozzle No./Size straight

[TEMPERATURE ° F]

Sample Point	1114 Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	Stack	Probe	Oven	Imp.	Gas Meter IN OUT	Pump Vacuum in.Hg	ΔAP	Comments
C 1	0	0.11	2.00	418.480	1890	253	251	70	71 69	5.0	0.322	pilot ok
2		0.15	2.00	415.750	1854	208	230	68	71 69	5.0	0.307	
3	6	0.13	2.00	418.240	1760	265	243	67	70 68	5.0	0.361	Read = 0.0668
4		0.16	2.00	420.700	1967	285	245	67	70 66	5.0	0.400	ALFM = 245.025.63
5	12	0.12	2.00	422.870	1958	271	235	65	70 67	5.0	0.346	QS = 49.985.90
6		0.10	2.00	425.268	1966	267	257	65	70 66	5.0	0.316	
	18			427.581								
B 1	18	0.11	2.00	427.581	1876	228	229	69	76 72	5.0	0.332	
2		0.15	2.00	429.930	1997	252	243	65	76 72	5.0	0.387	
3	6	0.16	2.00	432.280	1914	252	227	58	75 71	5.0	0.400	
4		0.12	2.00	434.646	1973	254	225	59	75 71	5.0	0.346	
5	12	0.10	2.00	436.980	1909	253	223	60	74 69	5.0	0.316	
6		0.06	2.00	439.345	1964	251	226	60	74 69	5.0	0.245	
	18			441.900								

PLANT BFI Arbor Hills TEST TYPE _____ FIELD TEST DATA SHEET (Page 2 of 2)
DATE 9/23/92 RUN NO. 1
TEST LOCATION Flare out OPERATOR 8

[illegible]

PLANT B.F.T. Aebbe Hill

TEST TYPE

12/4

FIELD TEST DATA SHEET (Page

1 of 2

GAS COMPOSITION

I

IMPINGER VOLUMES/WEIGHTS

Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
DI	706.7	611.6	95.1				
DI	605.7	584.5	21.2				
DRY	444.4	441.4	3.0				
				Leakrate			%Hg
S.G.	731.3	719.1	12.2	Initial	0.012		15
		TOTAL	131.5	Final	0.005		5

Date 9-23-92 Barometric Pressure 29.92
 Test Location Flare Out Static in.wg. -0.05
 Run Number #2 Probe Type/Length Q17'
 Stack Diameter 187.5 Pitot Coefficient 0.84
 Operator JB Meter Box No./Y 21313/1.0098
 Filter No. UNTRAPED Nozzle No./Size Straight

[TEMPERATURE ° F]

Sample Point	Time	AP in wg	AH in wg	Gas Meter Volume Ft ³	Stack	Probe	Oven	Imp.	Gas Meter IN OUT	Pump Vacuum in.Hg	ΔP	Comments
D 1	0	0.12	2.00	473.096	1915	235	263	66	104 104	3.0	0.346	pilot ok
2		0.12	2.00	475.600	1936	254	252	62	109 105	3.0	0.346	
3	6	0.10	2.00	477.810	1950	253	246	62	109 105	3.0	0.316	
4		0.09	2.00	480.175	1787	256	253	62	108 104	3.0	0.300	
5	12	0.10	2.00	482.530	1858	255	260	62	107 103	3.0	0.316	
6		0.04	2.00	484.985	1799	254	261	63	105 103	3.0	0.200	
	18			487.399								
A 1	0	0.13	2.00	487.399	1926	241	242	66	107 106	3.0	0.361	
2		0.12	2.00	489.775	1985	250	254	59	108 106	3.0	0.346	
3	6	0.07	2.00	492.145	1732	257	247	57	108 105	3.0	0.265	
4		0.11	2.00	494.322	1790	256	251	57	106 104	3.0	0.332	
5	12	0.10	2.00	496.935	1908	258	251	57	105 102	3.0	0.316	
		0.04	2.00	499.360	1837	256	259	58	102 101	3.0	0.200	
	18			501.775								

TEST LOCATION	Flare Out
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
96	
97	
98	
99	
100	

Form 15: Fieldset Form

PLANT BFI Arbor Hills

TEST TYPE

M26A

FIELD TEST DATA SHEET (Page

1 of 2)

[IMPINGER VOLUMES/WEIGHTS]

[GAS COMPOSITION]

Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
H ₂ SO ₄	702.7	685.1	17.6				
H ₂ SO ₄	571.1	546.8	24.3				
NaOH	530.3	527.4	2.9				
NaOH	529.2	528.5	0.7				
				Leakrate			µHg
S.G.	730.2	714.7	15.5	Initial		0.012	15
		TOTAL	161.0	Final		0.002	5.5

Date 9/24/92 Barometric Pressure 29.33Test Location Flare Out Static in.wg. -0.05Run Number 3 Probe Type/Length Q/12'Stack Diameter 139.5 Pitot Coefficient 0.84Operator JR Meter Box No./Y 21313 LL0098Filter No. 77-TFE Nozzle No./Size Straight

[TEMPERATURE ° F]

Sample Point	10:29 Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	Stack	Probe	Oven	Imp.	Gas Meter IN OUT	Pump Vacuum in.Hg	ΔAP	Comments
C 1	0	0.11	2.5	531.889	1785	325	249	62	102 101	5.0	0.832	pitotok
2		0.11	2.5	534.525	1846	292	292	47	95 95	5.0	0.832	
3	6	0.16	2.5	537.149	1794	260	332	48	95 94	5.0	0.800	new 33754
4		0.12	2.5	539.805	1855	338	352	49	93 93	5.0	0.346	
5	12	0.12	2.5	542.480	1926	366	332	49	91 92	5.0	0.346	new 33755
6		0.06	2.5	545.085	1735	371	329	49	91 91	5.0	0.245	
	18			547.268								
B 1	10:32 0	0.16	2.5	547.768	1775	195	191	61	91 91	5.0	0.400	new 33756
2		0.12	2.5	550.500	1872	326	264	51	91 91	5.0	0.346	new 33757
3	6	0.14	2.5	553.014	1828	346	283	51	92 91	5.0	0.374	
4		0.14	2.5	555.665	1860	338	287	53	92 91	5.0	0.374	can 3 33758
5	12	0.13	2.5	558.250	1715	216	285	55	92 91	5.0	0.361	
6		0.08	2.5	560.880	1808	298	286	55	91 90	5.0	0.283	new 33759
	18			563.524								

45

Forms 1B: Fielddata from 1/01

[IMPINGER VOLUMES/WEIGHTS] [GAS COMPOSITION]

Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
H ₂ SO ₄	645.4	545.7	99.7				
H ₂ SO ₄	575.7	548.8	26.9				
NaOH	539.1	536.1	3.0				
NaOH	546.3	545.3	1.0				
				Leakrate			"Hg
S.G.	681.0	661.1	19.9	Initial	0.011		15
		TOTAL	150.5	Final	0.007		11

Date 9/24/93 Barometric Pressure 29.31
 Test Location Flare Out Static in.wg. - 0.04
 Run Number 4 Probe Type/Length Q/7'
 Stack Diameter 139.5 Pitot Coefficient 0.84
 Operator J Meter Box No./Y 21313/1.0098
 Filter No. 82 TFE Nozzle No./Size straight

[TEMPERATURE ° F]

Sample Point	2-4% Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	Stack	Probe	Oven	Imp.	Gas Meter IN OUT	Pump Vacuum in. Hg	ΔP	Comments
1	0	0.13	2.5	595.518	1894	259	265	71	97 95	10.0	0.361	pilot ok
2		0.11	2.5	598.140	1907	261	237	69	97 95	10.0	0.332	
3	6	0.09	2.5	600.762	1854	301	226	67	97 95	10.0	0.300	can adjust
4		0.07	2.5	603.385	1876	334	256	67	97 95	10.0	0.265	2:15:00 0.50
5	12	0.06	2.5	606.024	1829	346	278	67	97 94	10.0	0.245	bag 2:18:00
6		0.04	2.5	608.646	1756	357	250	67	97 94	10.0	0.200	2:25:00
	18			611.281								
A 1	3:17	0.06	2.5	611.281	1937	235	253	71	98 97	10.0	0.245	2:26 A 33762 33753
2		0.13	2.5	612.915	1880	227	243	65	99 97	10.0	0.261	2:26 P 33763 33771
3	6	0.11	2.5	616.525	1890	241	230	65	100 97	10.0	0.332	2:26 P 33763 33771
4		0.10	2.5	619.149	1868	303	271	65	100 98	10.0	0.316	2:26 P 33763 33771
5	12	0.08	2.5	621.810	1839	341	243	66	100 98	10.0	0.283	2:26 P 33764
6		0.06	2.5	624.388	1786	303	251	66	100 98	10.0	0.245	2:26 P 33764
	18			626.995								2:26 P 33765

PLANT BFI Arbor Hills TEST TYPE M26A FIELD TEST DATA SHEET (Page 2 of 2)
 DATE 9/24/92 RUN NO. 4
 TEST LOCATION Flare Out OPERATOR JS

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F							Pump Vacuum in. Hg	ΔP	Comments
					Stack	Probe	Oven	Imp.	Gas Meter					
									In	Out				
B 1	0	0.14	2.5	626.695	1983	230	250	68	100	98	9.0	0.374		
2		0.13	2.5	629.620	1960	318	253	53	100	98	9.0	0.361		
3	6	0.14	2.5	632.270	1940	325	247	55	100	97	9.5	0.374	bag 5:05:45	
4		0.14	2.5	634.705	1927	387	249	56	100	96	9.5	0.374	'A'	
5	12	0.13	2.5	637.650	1813	373	240	54	100	96	9.5	0.361	5:11:45	
6		0.10	2.5	640.190	1859	367	257	55	99	97	9.5	0.316		
	18			642.879									can. Steiner	
C 1	4:37	0.13	2.5	642.879	1984	225	234	64	97	95	9.5	0.361	Steiner	
2	0	0.13	2.5	645.465	1950	363	253	54	97	94	9.5	0.361	'A'	
3	6	0.13	2.5	648.035	1953	394	245	54	97	95	9.5	0.361		
4		0.11	2.5	650.650	1947	374	261	56	97	95	9.5	0.332		
5	12	0.10	2.5	652.321	1915	420	251	56	97	94	9.5	0.316	33769 bag	
6		0.04	2.5	655.963	1904	415	253	56	98	95	9.5	0.200	pibtok	
	18			658.650										
													33766 can	
					33772 FAN 0.2	33773 HP 0.2	33774 H ₂ SO ₄ 0.2	33775 NAOH 0.2					33767 bag 4	
	72		2.5	63.132	1891.29					97.17		0.3155	33768 can	

PLANT BEL Arbor HillsTEST TYPE MBFIELD TEST DATA SHEET (Page 1 of 2)

[IMPINGER VOLUMES/WEIGHTS] [GAS COMPOSITION]

Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
80% IPA	570.5	533.3	37.2				
3% H ₂ O	595.1	549.1	46.0				
3% H ₂ O	558.1	535.1	23.0				
				Leakrate			"Hg
S.G.	758.4	720.4	38.0	Initial	0.016		15
		TOTAL	144.2	Final	0.007		7.5

Date 9/25/92 Barometric Pressure 29.21
 Test Location Flare Out Static in.wg. -0.10
 Run Number 5 Probe Type/Length Q/1'
 Stack Diameter 139.5 Pitot Coefficient 0.84
 Operator JB Meter Box No./Y 21313/1.0090
 Filter No. 962 Nozzle No./Size Straight

[TEMPERATURE • F]

Sample Point	12:29 Time	AP in wg	ΔH in wg	Gas Meter Volume Ft ³	Stack	Probe	Oven	Imp.	Gas Meter IN OUT	Pump Vacuum in. Hg	ΔP	Comments
A 1	0	0.17	2.5	659.639	1873	194	262	75	102 101	7.0	0.412	pilot ok
2		0.13	2.5	662.217	1899	354	267	64	102 99	7.5	0.361	
3	6	0.15	2.5	664.865	1856	385	270	65	100 98	7.5	0.387	can do asl 10:28:30
4		0.13	2.5	668.500	1822	372	265	65	99 96	7.5	0.361	11:24:00
5	12	0.14	2.5	670.150	1805	356	258	65	98 95	7.5	0.374	bag 11:27:15
6		0.07	2.5	672.785	1831	366	270	65	97 94	7.5	0.265	11:32:15
	18:30			675.525								
B 1	0	0.16	2.5	675.525	1850	246	263	75	99 96	7.5	0.400	33789 33790 Can 5 H ₂ O BL
2		0.15	2.5	678.145	1846	369	275	67	98 97	7.5	0.387	33788 33791 Bag 5 AHF BL
3	6	0.16	2.5	680.790	1774	393	271	67	98 96	7.5	0.400	
4	12	0.15	2.5	683.480	1823	390	269	67	98 96	7.5	0.387	33787 33792 Can 5 HF BL
5	12	0.15	2.5	686.130	1776	414	260	67	97 94	7.5	0.387	
6		0.09	2.5	688.793	1827	390	269	67	96 94	7.5	0.360	33786 33793 Bag 5 IPA BL
	18			691.485								

TEST LOCATION Flare Outlet

B-12

PLANT BEE Arber Hills TEST TYPE H8 FIELD TEST DATA SHEET (Page 1 of 2)

(IMPINGER VOLUMES/WEIGHTS) (GAS COMPOSITION)

Date 9/25/92 Barometric Pressure 29.14

Test Location Elev Out Static in.wg. -0.09

Run Number 6 Probe Type/Length Q/7'

Stack Diameter 139.6 Pitot Coefficient 0.84

Operator JR Meter Box No./Y 21313/1.0098

Filter No. 966 Nozzle No./Size straight

Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
80% IPA	568.5	520.3	48.2				
2% H ₂ O ₂	573.1	532.3	40.8				
3% H ₂ O ₂	581.2	538.5	42.7				
S.G.	646.9	616.0	30.9	Leakrate			WtHg
		TOTAL	142.6	Initial	0.009		15
				Final	0.009		13

[TEMPERATURE ° F]

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	Stack	Probe	Oven	Imp.	Gas Meter IN OUT	Pump Vacuum in. Hg	ΔP	Comments
D 1	0	0.13	2.5	723.406	1702	252	237	78	93 93	9.0	0.361	pilot ok
2		0.12	2.5	725.990	1787	265	242	66	95 93	9.0	0.346	
3	6	0.14	2.5	728.575	1713	269	257	66	96 94	9.0	0.374	changed out
4		0.13	2.5	731.150	1723	274	254	66	97 94	11.0	0.361	setpoint TC
5	12	0.13	2.5	733.765	1652	294	261	67	99 95	12.5	0.361	
6		0.05	2.5	736.373	1642	283	256	67	100 96	13.0	0.224	
	18			739.005								33781 FHW
C 1	4:09	0.15	2.5	739.005	1650	289	274	71	104 101	10.0	0.387	33782 HF
2		0.16	2.5	741.630	1725	298	255	65	103 100	11.0	0.400	
3	6	0.14	2.5	744.238	1628	295	263	66	104 100	12.0	0.374	33783 IPA
4		0.15	2.5	746.864	1662	297	259	66	104 101	12.5	0.382	
5	12	0.14	2.5	749.480	1692	298	262	66	105 102	13.0	0.374	33784 AMF
6		0.11	2.5	752.116	1623	297	262	67	106 102	13.0	0.332	
	18			754.768								33785 H ₂ O ₂

3

B-14

~ 2000

CONTINUOUS MONITOR DATA SHEET

Plant BFI Run No. 9/23/92 CALIBRATION/CHECKS
 Date 9/23/92
 Test Location ARROW HILL FLARE
 Operator PCS
 Fuel Type METHANE SAIL Trailer No. 2 EQUIP

APCD Witness/Number _____
 Client Rep CHUCK CASSIE
 Generator Type _____
 Burner Type _____
 O₂ Controller Type _____

ENVIRONICS MODEL # 201-1520-00-00 5/11/23

Time	Sample Point	Dry Uncorrected					NO _x ppm	Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm			
0810		19.50	15.9	402.5	—	—	80.4	SPAN GAS VALUES	CALIBRATION GASES NO _x <u>CC 389</u> <u>CC 72048</u> SO ₂ <u>CC 86353</u> CO <u>CC 81181</u> CO/NO ₂ <u>CC 81154</u> AIR
		φ	φ	φ	—	φ	—	ZERO	
		—	—	—	—	—	—	"HID-LEVEL" CHECKS	
0823		—	—	—	—	—	42.0	NO _x GAS = 41.2 ppm	
0840		15.10	—	—	—	—	—	O ₂ GAS = 14.75%	
0855		—	—	260.0	—	—	—	CO GAS = 255.0 ppm	
0920		—	11.96	—	—	—	—	CO ₂ GAS = 11.80%	
0940		0.0	—	—	—	—	—	EXTERNAL LEAK CHECKS	
		—	—	—	—	—	—	EXTERNAL CHECKS 2/5	
0945		0.0	—	—	—	—	—	O ₂ ZERO (N ₂)	
0950		15.25	—	—	—	—	—	O ₂ SPAN (14.94)	
		—	—	—	—	—	1.40	NO _x ZERO (N ₂)	
		—	—	—	—	—	41.2	NO _x SPAN (40.3)	
1010		—	—	250	—	—	—	CO ZERO (N ₂)	
		—	—	256.5	—	—	—	CO SPAN (255.5)	
1020		—	0.0	—	—	—	—	CO ₂ ZERO (N ₂)	
		—	11.86	—	—	—	—	CO ₂ SPAN (12.0%)	
								NO _x Test Audit	
							40.0	Protocol 1 39.60 ppm	
								CYL # CC 387	

Wet Bulb: _____ Dry Bulb: _____
 Barometric Press: _____

RESPONSE TIME
 Upscale: 23 Downscale: 22
 Upscale: 29 Downscale: 22
 Upscale: 33 Downscale: 22

PROCESS DATA
 Fuel Flow: _____
 Steam Flow: _____
 Rating: C ~ 2000°F

CONVERTER GAS
 Cal Gas Values | Actual Values
 NO _____ | _____
 NO₂ _____ | _____
 Conv. Efficiency: _____

CONTINUOUS MONITOR DATA SHEET

Plant BFI APCD Witness/Number _____
 Date 9/23/93 Client Rep _____
 Test Location ARBOR HILL FLARE Generator Type _____
 Operator PCS Burner Type _____
 Fuel Type METHANE SOUR O₂ Controller Type _____
 Trailer No. 2 EQUIP _____

Dry Uncorrected										Comments	Miscellaneous Information
Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm				
1111	B1	9.80	11.0	65.0	—	—	25.3	START RUN #1 C 1111HRS PORT "B"		CALIBRATION GASES NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____	
1119	B2	9.75	10.9	70.5	—	—	24.6				
1122	B3	10.33	10.3	62.5	—	—	22.4				
1125	B4	10.80	10.0	56.5	—	—	21.2				
1128	B5	11.40	9.4	40.0	—	—	19.3				
1131	B6	11.93	8.8	45.5	—	—	18.0				
1143	A1	10.88	9.5	89.0	—	—	21.5	PORT "A" C 1143		Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____	
1146	A2	11.13	9.8	75.0	—	—	21.0				
1149	A3	10.65	10.0	126.0	—	—	23.1				
1152	A4	11.10	9.6	101.0	—	—	20.0				
1155	A5	12.30	8.7	105.5	—	—	17.5				
1158	A6	12.90	7.9	103.0	—	—	15.1				
1213	D1	11.50	9.5	91.0	—	—	19.5	PORT "D" C 1213		RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____	
1216	D2	11.20	9.7	80.0	—	—	20.3				
1219	D3	11.40	9.1	91.0	—	—	19.9				
1222	D4	12.15	9.1	95.0	—	—	18.5				
1225	D5	12.58	8.6	117.0	—	—	17.0				
1228	D6	12.85	8.5	72.0	—	—	16.3				
					—	—				PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: _____	
					—	—					
					—	—					
					—	—					
					—	—					
					—	—					
					—	—		CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____			
					—	—					
					—	—					
					—	—					
					—	—					
					—	—					

CONTINUOUS MONITOR DATA SHEET

Plant BFI APCD Witness/Number _____
 Date 9/23/92 Client Rep _____
 Test Location ARBOR HILL FLARE Generator Type _____
 Operator PLS Burner Type _____
 Fuel Type METHANE SEVER Trailer No. 2 O₂ Controller Type _____
 Equip _____

Dry Uncorrected

Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	Comments	Miscellaneous Information
1243	C1	11.00	9.78	83.5	—	—	20.3	PORT "C" C 1243	CALIBRATION GASES NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____
1246	C2	11.00	10.00	87.0	—	—	20.8		
1249	C3	10.45	10.34	68.0	—	—	23.0		
1252	C4	11.18	10.00	61.5	—	—	20.0		
1255	C5	11.38	9.64	26.0	—	—	18.8		
1258	C6	11.75	9.20	21.5	—	—	17.5		
1305		0.0	0.0	6.0	—	—	1.25	EXTERNAL CAL CHECKS	Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
		—	—	—	—	—	40.4	ZERO - NO ADJUST	
		15.40	—	—	—	—	—	NO _x SPAN (57.8)	
		—	—	256.5	—	—	—	O ₂ SPAN (14.97)	RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____
		—	11.86	—	—	—	—	CO SPAN (250.1)	
		—	—	—	—	—	—	CO ₂ SPAN (12.0)	
	Avg	11.31	9.56	76.38	—	—	20.00		PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: <u>2000°F</u>
									CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____

CONTINUOUS MONITOR DATA SHEET

Plant BFI
 Date 9/23/92 Run No. #2
 Test Location ARBOR HILL FLARE
 Operator PPS
 Fuel Type NATURAL GAS Trailer No. 2 EQUIP

APCD Witness/Number _____
 Client Rep _____
 Generator Type _____
 Burner Type _____
 O₂ Controller Type _____

Time	Sample Point	Dry Uncorrected					Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm		
1305		0.0	0.0	6.0	—	—	1.25	EXTERNAL ZERO CHECK EXTERNAL SPAN CHECK CERAM RUN #1 (FINAL) START RUN #2 @ 1432 PART "C"
		15.40	11.86	265.6	—	—	40.4	
1432	C1	10.73	9.84	55.0			21.0	
1435	C2	10.25	10.20	56.0			21.5	
1438	C3	10.79	7.92	55.0			20.6	
1441	C4	11.18	9.50	37.0			19.6	
1444	C5	12.03	8.90	65.0			17.3	Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____ RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: <u>2000 °F</u> CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____
1447	C6	11.88	8.98	43.0			16.2	
1513	D1	11.83	9.32	117.0			17.3	
1516	D2	11.18	9.92	115*			19.2	
1519	D3	11.75	9.70	153*			17.8	
1522	D4	12.13	8.80	158*			16.4	
1525	D5	13.05	8.20	186*			14.4	PART "D" @ 1513 * CO SPIKE TO 355 PPM * CO SPIKE TO 318 PPM * CO SPIKE TO 329 PPM * CO SPIKE TO 380 PPM PART "A" @ 1539 * SPIKE TO 319 PPM * CO SPIKE TO 309 PPM
1528	D6	13.13	8.00	128.0			13.7	
1539	A1	11.50	9.84	91.0			18.5	
1542	A2	11.43	9.76	59.5			18.2	
1545	A3	11.55	9.68	101.5*			19.8	
1548	A4	11.58	9.16	153			16.0	
1551	A5	12.52	9.50	149			17.5	
1554	A6	12.62	8.30	92.5*			15.3	

~ 2000 °F

N 2000 F

CONTINUOUS MONITOR DATA SHEET

Plant BFI APCD Witness/Number _____
 Date 9/23/92 Client Rep _____
 Test Location ARBOR HILL FLARE Generator Type _____
 Operator RES Burner Type _____
 Fuel Type NATURAL GAS Trailer No. 2 O₂ Controller Type _____

Dry Uncorrected

Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	Comments	Miscellaneous Information
1305		0.0	0.0	6.0	—	—	1.25	EXT. ZERO CHECK	CALIBRATION GASES
		15.40	11.86	265.6	—	—	40.4	EXT. SPAN CHECK	NO _x _____
					—	—		(FROM RUN #1 - FINE)	SO ₂ _____
					—	—		PORT "B" @ 1605	CO _____
1605	B1	10.63	10.30	92.5	—	—	22.0		CO/CO ₂ /O ₂ _____
1608	B2	10.18	10.80	96.5	—	—	23.5		Wet Bulb: _____ Dry Bulb: _____
	B3	9.95	10.64	74.0	—	—	23.1		Barometric Press: _____
	B4	10.00	10.10	103.0	—	—	21.6		
	B5	10.55	9.92	86.5	—	—	20.2		
	B6	11.48	9.20	58.0	—	—	17.2		
				0.0	—	—		EXTERNAL CAL CHECKS	RESPONSE TIME
		0.0	-0.04	0.0	—	—	+1.00	ZERO - NO ADJUST	Upscale: _____ Downscale: _____
		—	—	—	—	—	39.5	MIX SPAN V (39.8)	Upscale: _____ Downscale: _____
		15.18	—	—	—	—	—	O ₂ SPAN V (14.89)	Upscale: _____ Downscale: _____
		—	—	252.5	—	—	—	CO SPAN V (250.2)	
		—	11.88	—	—	—	—	CO ₂ SPAN V (12.0)	PROCESS DATA
									Fuel Flow: _____
									Steam Flow: _____
									Rating: <u>0 ~ 2000 °F</u>
	Avg	11.41	9.52	96.88			18.66		
									CONVERTER GAS
									Cal Gas Values Actual Values
									NO _____
									NO ₂ _____
									Conv. Efficiency: _____



CONTINUOUS MONITOR DATA SHEET

~ 16000

Plant BFI
Date 9/24/92 Run No. 3
Test Location ARBOR HILLS FLARE
Operator PPS
Fuel Type METHANE SOURCE Trailer No. 2 EQUIP

APCD Witness/Number _____
Client Rep _____
Generator Type _____
Burner Type _____
O₂ Controller Type _____

Time	Sample Point	Dry Uncorrected					Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm		
0625		19.50	14.75	403	—	80.2	SPAN GAS VALUES ZERO MID-LEVEL CHECKS NOX GAS = 41.0 PPM O ₂ GAS = 11.82 % CO GAS = 206 PPM CO ₂ GAS = 9.4 % RESET NOX ZERO & SPAN DUE TO TEMP DRIFT NOX MID GAS = 41.0 PPM INTERFERENCE CHECKS EXTERNAL CHECKS EXT. Z/S CHECKS O ₂ ZERO (N ₂) O ₂ SPAN (11.95%) NOX ZERO (N ₂) NOX SPAN (39.8 PPM) CO ZERO (N ₂) CO SPAN (202 PPM) O ₂ ZERO (N ₂) CO ₂ SPAN (10.0%)	CALIBRATION GASES NO _x CC389 CC72048 SO ₂ CO ₂ CC86353 CO CC81181 CO/CO ₂ CC81154 AIR
		0	0	—	—			
0710		—	—	—	—	—		
0735		12.3	—	—	—	40.0		
0755		—	—	207	—	—		
0825		—	10.0	—	—	—		
0830		—	—	—	—	80.2		
		—	—	—	—	0		
		—	—	—	—	41.0		
		0	0	0	—	0		
0840		0.0	—	—	—	—		
0850		—	—	—	—	—		
		0.0	—	—	—	—		
		12.5	—	—	—	—		
		—	—	—	—	0.0		
		—	—	—	—	39.6		
		—	—	0.0	—	—		
		—	—	205	—	—		
		—	0.0	—	—	—		
		—	9.88	—	—	—		
		—	—	—	—	—		
		—	—	—	—	—		
1000		—	—	—	—	38.5		
		—	—	—	—	—		
		—	—	—	—	—		

Wet Bulb: _____ Dry Bulb: _____
Barometric Press: _____

RESPONSE TIME
Upscale: 32 Downscale: 28
Upscale: 33 Downscale: 33
Upscale: 34 Downscale: 32

PROCESS DATA
Fuel Flow: _____
Steam Flow: _____
Rating: C ~ 1600°F

CONVERTER GAS
Cal Gas Values | Actual Values
NO _____ | _____
NO₂ _____ | _____
Conv. Efficiency: _____

~ 16000

CONTINUOUS MONITOR DATA SHEET

Plant BFI APCD Witness/Number _____
 Date 9/24/92 Run No. #3 Client Rep _____
 Test Location ARBOR HILLS FLARE Generator Type _____
 Operator ROS Burner Type _____
 Fuel Type MACHINE SOVE Trailer No. 2 EQUIP O₂ Controller Type _____

Dry Uncorrected										Comments	Miscellaneous Information
Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm				
		—	—	—	—	—	—	INITIAL EXT. VALUES		CALIBRATION GASES NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____	Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
		12.5	9.88	205	—	—	39.6	SPAN VALUES			
		0.0	0.0	0.0	—	—	0.0	ZERO VALUES			
								START RUN # 3 @ 1013			
1013	B1		SCRUB @	1015 HRS				RESTART RUN #3 @ 1024		RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____	PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: <u>Q ~ 1600°F</u>
1024	B1	9.88	10.34	120			22.2	PART "B"			
	B2	10.58	9.74	213			18.8	* CO SPIKE TO 490 PPM			
	B3	10.88	9.52	235*			17.4	* CO ₂ PEN. STUCK ON CHART RECORDER			
	B4	11.28	* 9.81	148			17.0			CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____	
	B5	11.50	9.50	127			16.0				
	B6	11.75	9.52	96			16.4				
								PART "A" @ 1048			
1048	A1	11.20	9.52	103			17.3				
1051	A2	11.35	9.44	87			16.5				
1054	A3	10.88	9.66	38			18.1				
	A4	12.03	9.20	100			14.3				
	A5	12.53	8.26	98			12.4				
	A6	12.80	8.18	123			12.8				
								PART "D" @ 1121			
1121	D1	10.73	10.00	21.0			18.6				
1124	D2	11.15	9.60	13.5			18.0				
1127	D3	11.45	9.60	23.0			16.2				
1130	D4	11.93	8.46	23.0			15.3				
1133	D5	12.50	8.86	70.0			14.0				
1136	D6	13.25	7.68	36.0			12.0				

CONTINUOUS MONITOR DATA SHEET

Plant BFI
 Date 9/24/92 Run No. #3
 Test Location ARBOR HILLS FLARE
 Operator PS
 Fuel Type METHANE SOUR Trailer No. 2 EQUIP

APCD Witness/Number _____
 Client Rep _____
 Generator Type _____
 Burner Type _____
 O₂ Controller Type _____

Dry Uncorrected

Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	Comments	Miscellaneous Information
		12.5	9.88	205	—	—	39.6	INITIAL EXT ✓ VALUES	CALIBRATION GASES NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____
		Ø	Ø	Ø	—	—	Ø	EXT SPAN (VALUE)	
					—	—		EXT ZERO VALUE } FRICTION	
					—	—		PORT "C" @ 1148	
1148	C1	10.05	10.52	5.0	—	—	20.5		Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
1151	C2	9.38	11.40	6.5	—	—	22.9		
1154	C3	10.15	10.68	6.0	—	—	20.6		
1157	C4	9.85	10.56	3.0	—	—	20.3		
1200	C5	10.30	10.40	1.5	—	—	19.0		RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____
1203	C6	10.85	9.68	1.0	—	—	17.6		
					—	—			
					—	—			
1215		Ø	Ø	Ø	—	—	-0.4	EXTERNAL CHECK - NO ADJ	PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: <u>@ ~ 1600 °F</u>
		—	—	—	—	—	39.8	ZERO VALUE	
		—	—	207	—	—	—	ADJ. SPAN = 39.9 PPM	
		—	9.94	—	—	—	—	CO SPAN = 202 PPM	
		12.13	—	—	—	—	—	CO ₂ SPAN = 10.00 %	CONVERTER GAS Cal Gas Values Actual Values NO _____ NO ₂ _____ Conv. Efficiency: _____
		11.18	9.58	70.73	—	—	17.26	CO ₂ SPAN = 11.86 %	
					—	—			
					—	—			
		* NOTE: TEMPERATURE CONVERTER FOR FLARE "DETERMINED" CHANGED FROM 22 °F TO 30 °F TIME: APPROX 1034 HRS.							

CONTINUOUS MONITOR DATA SHEET

Plant BFI APCD Witness/Number _____
 Date 9/24/92 Run No. #4 Client Rep _____
 Test Location ARBOR HILLS FLARE Generator Type _____
 Operator PS Burner Type _____
 Fuel Type METHANE SOLID Trailer No. 2 EQUIP O₂ Controller Type _____

Time	Sample Point	Dry Uncorrected						Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm		
		Ø	Ø	Ø	—	—	Ø	EXTERNAL ZERO CHECK	CALIBRATION GASES NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____
		12.5	9.88	205	—	—	39.6	EXTERNAL SPAN CHECK	
					—	—		(FROM RUN #3 INITIAL V)	
					—	—		START RUN #4 @ 1445	
1445	C1	9.25	11.00	8.00	—	—	23.1	PART "C"	Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
1448	C2	9.00	11.28	6.00	—	—	24.0		
1451	C3	9.55	10.72	6.00	—	—	21.8		
1454	C4	9.38	10.70	6.00	—	—	22.2		
1459	C5	10.00	10.40	1.50	—	—	20.9		RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____
1500	C6	10.90	9.56	1.00	—	—	17.5		
					—	—		PART "D" @ 1514	
1514	D1	10.95	9.70	8.00	—	—	18.8		
1517	D2	11.38	9.48	27.50	—	—	17.3		PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: <u>@ ~ 1600°F</u>
1520	D3	11.85	8.90	25.0	—	—	16.0		
1523	D4	12.20	8.50	28.0	—	—	14.6		
1526	D5	12.45	8.28	15.0	—	—	14.2		
1529	D6	13.05	7.78	31.5	—	—	13.4		CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____
					—	—			
					—	—			
					—	—			
★ NOTE: At 1400 HRS, FLARE TEMPERATURE CONTROLLER SET FOR A "DEAD BAND" OF 50°F.					—	—			

[illegible]Plant BFI

Date 9/24/92

Test Location *200*

Operator RES
Fuel Type RES

type / ɪˈteɪp /

O₂ Controller Type

B-24

CONTINUOUS MONITOR DATA SHEET

Plant BFI APCD Witness/Number _____
 Date 9/25/92 Run No. 15 Client Rep _____
 Test Location ARBOR HILLS FLARE Generator Type _____
 Operator RS Burner Type _____
 Fuel Type METANE SOLID Trailer No. 22 EQUIP O₂ Controller Type _____

Dry Uncorrected

Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	Comments	Miscellaneous Information
0700		19.50	16.0	402	—	—	80.2	SPAN GAS VALUES	CALIBRATION GASES NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____
		φ	φ	φ	—	—	φ	ZERO VALUES	
		—	—	—	—	—	—	MID-LEVEL CHECKS	
		—	—	—	—	—	40.9	NO _x (41.0 ppm)	
		12.35	—	—	—	—	—	O ₂ (11.8%)	
		—	—	207.5	—	—	—	CO (206 ppm)	Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
		—	—	44.5	—	—	—	CO (44.5 ppm)	
		—	—	24.0	—	—	—	CO (23.9 ppm)	
		—	10.04	—	—	—	—	CO ₂ (9.90%)	
		—	—	—	—	—	—	REAL NO _x DUE TO DELAY	
		—	—	—	—	—	φ	NO _x ZERO VALUE	RESPONSE TIME Upscale: <u>23</u> Downscale: <u>18</u> Upscale: <u>22</u> Downscale: <u>17</u> Upscale: <u>22</u> Downscale: <u>19</u>
		—	—	—	—	—	80.6	NO _x SPAN VALUE	
		—	—	—	—	—	41.0	NO _x -MID V (41.1 ppm)	
		—	—	—	—	—	—	EXT LEAK CHECK	
		40.05	—	—	—	—	—	O ₂ EXT V (11.96%)	
1055		12.55	—	—	—	—	—	NO _x EXT V (39.8 ppm)	PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: _____
		—	—	—	—	—	41.0	NO _x EXT V (41.1 ppm)	
		—	—	—	—	—	φ	O ₂ EXT ZERO V (N ₂)	
		0.0	—	—	—	—	—	CO EXT ZERO V (N ₂)	
		—	—	0.0	—	—	—	CO EXT SPAN V (202 ppm)	
		—	—	192.5	—	—	—	CO LOW EXT V (45.5 ppm)	CONVERTER GAS Cal Gas Values Actual Values NO _____ NO ₂ _____ Conv. Efficiency: _____
		—	—	45.0	—	—	—	CO ₂ ZERO EXT V (N ₂)	
		—	0.0	—	—	—	—	CO ₂ EXT SPAN V (10.02%)	
		—	10.04	—	—	—	—	INTERFERENCE CHECKS	
		φ	φ	φ	—	—	φ	TEST AUDIT (Nov 3.6)	
		—	—	—	—	—	—	PROMOVAL 00389	
		—	—	—	—	—	39.6		

* NOTE: FURTHER TIGHTENING OF ROBE PRODUCED A LEAK CHECK OF DO₂ AT 11:55 HRS. LEAK CHECK AT 10:55 HRS. INVAULT.

CONTINUOUS MONITOR DATA SHEET

Plant BFI - ARBOR HILLS FLARE APCD Witness/Number _____
 Date 9/25/92 Run No. 5 Client Rep _____
 Test Location ARBOR HILLS FLARE Generator Type _____
 Operator PCS Burner Type _____
 Fuel Type METHANE Trailer No. 2 EQUIP O₂ Controller Type _____

		Dry Uncorrected						Comments	Miscellaneous Information
Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm		
		0.0	0.0	0.0	—	—	0.0	INITIAL EXITS - ZERO	CALIBRATION GASES NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____
		12.55	10.04	192.5	—	—	41.0	INITIAL EXITS - SPAN	
								START RUN SEC 1226	
								PART "B"	
1226	B1	11.15	9.64	15.00			17.4		Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
1229	B2	10.90	9.82	2.50			17.8		
1232	B3	11.40	9.44	10.00			16.2		
1235	B4	10.88	9.80	7.00			17.3		
1238	B5	11.28	9.60	15.00			16.3		
1241	B6	11.80	9.10	4.00			14.5		RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____
								PART "A" @ 1250	
1250	A1	12.18	9.30	90.0			15.6		
1253	A2	11.60	9.16	25.0			16.3		
1256	A3	12.25	8.60	77.0			13.8		
1259	A4	12.65	8.22	81.0			13.4		PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: _____
1302	A5	13.15	7.74	146.0			12.2		
1305	A6	13.88	7.36	154.0			11.3		
								PART "D" @ 1320	
1320	D1	11.45	9.52	37.0			17.4		
1323	D2	12.38	8.70	140.0			15.0		CONVERTER GAS Cal Gas Values Actual Values NO _____ NO ₂ _____ Conv. Efficiency: _____
1326	D3	13.08	8.06	199.0			18.2		
1329	D4	13.33	7.46	495*			12.0	*CO SPIKES TO 838 PPM	
1332	D5	14.03	7.80	243			13.3		
1335	D6	13.25	7.60	320*			12.2	*CO SPIKES TO 667 PPM	

CONTINUOUS MONITOR DATA SHEET

Plant BFI

Date 9/25/92 Run No. #5

Test Location ARBOR HILLS FLARE

Operator PCS

Fuel Type METHANE Trailer No. 2 EDU/P :

Dry Uncorrected								Miscellaneous Information	
Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	Comments	
		ϕ	ϕ	ϕ	-	-	ϕ	TUNING EXT ✓ - ZERO	CALIBRATION GASES
		12.55	10.04	192.5	-	-	41.0	TUNING EXT ✓ - SPAN	NO _x _____
1344	C1	10.95	9.92	27.0			17.2	PORT "C" @ 1344	SO ₂ _____
1347	C2	10.70	10.14	33.0			18.5		CO _____
1350	C3	10.70	10.04	7.5			19.2		CO/CO ₂ /O ₂ _____
1353	C4	11.18	9.60	7.5			14.5		Wet Bulb: _____ Dry Bulb: _____
1356	C5	11.55	9.00	11.0			15.1		Barometric Press: _____
1359	C6	11.65	9.14	9.5			16.1		
		ϕ	ϕ	ϕ	-	-	+0.8	EXT ZERO CHECKS - NO ADJ	RESPONSE TIME
		-	-	-	-	-	40.5	NO _x EXT ✓ (39.8 ppm)	Upscale: _____ Downscale: _____
		-	-	206	-	-	-	CO EXT ✓ (203 ppm)	Upscale: _____ Downscale: _____
		-	-	45.5	-	-	-	CO ₂ EXT ✓ (44.5 ppm)	Upscale: _____ Downscale: _____
		-	9.84	-	-	-	-	O ₂ EXT ✓ (10.01 %)	
		12.45	-	-	-	-	-	O ₂ EXT ✓ (11.89 %)	PROCESS DATA
									Fuel Flow: _____
									Steam Flow: _____
									Rating: _____
									CONVERTER GAS
									Cal Gas Values Actual Values
									NO _____ _____
									NO ₂ _____ _____
									Conv. Efficiency: _____

CONTINUOUS MONITOR DATA SHEET

APCD Witness/Number _____
 Client Rep _____
 Generator Type _____
 Burner Type _____
 O₂ Controller Type _____

Plant BFI
 Date 9/25/92 Run No. #6
 Test Location ARBOR HILLS FERR
 Operator PCS
 Fuel Type METHANE Trailer No. 2 EQUIP

Dry Uncorrected


Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	Comments	Miscellaneous Information
		Ø	Ø	Ø	—	—	Ø	INITIAL EXTV - ZERO	CALIBRATION GASES
		12.55	10.04	182.5		41.0		INITIAL EXTV - SPAN	NO _x _____
								START RUN #6 @ 1542	SO ₂ _____
								PORT "C"	CO _____
1542	C1	11.10	9.70	231			17.0		CO/CO ₂ /O ₂ _____
1545	C2	11.00	9.76	178			16.8		Wet Bulb: _____ Dry Bulb: _____
1548	C3	11.58	9.06	263			15.1		Barometric Press: _____
1551	C4	12.45	8.32	355			12.9		
1554	C5	12.90	8.12	311			12.3		
1557	C6	13.63	7.52	375			10.8		
									RESPONSE TIME
1606	D1	12.70	8.20	625*			12.10	PORT "D" @ 1606	Upscale: _____ Downscale: _____
1609	D2	12.38	8.56	470			13.2	* CO OFFSCALE FOR MOST	Upscale: _____ Downscale: _____
1612	D3	12.58	8.22	530			12.3	OF THIS POINT. CHANGE	Upscale: _____ Downscale: _____
1615	D4	12.58	8.28	508			12.1	RANGE TO 1000PPMC 1609	
1618	D5	12.95	8.10	575			11.2		PROCESS DATA
1621	D6	13.15	7.80	458			11.0		Fuel Flow: _____
									Steam Flow: _____
									Rating: _____
1632	A1	12.80	8.14	628			10.8	PORT "A" @ 1632	CONVERTER GAS
1635	A2	12.95	7.96	590			11.7		Cal Gas Values Actual Values
1638	A3	12.73	8.24	398			12.9		NO _____
1641	A4	13.40	7.70	540			11.3		NO ₂ _____
1644	A5	13.40	7.70	516			11.4		Conv. Efficiency: _____
1647	A6	14.15	7.00	426			10.0		

CONTINUOUS MONITOR DATA SHEET

Plant BFI APCD Witness/Number _____
 Date 9/25/92 Client Rep _____
 Test Location ARBOR HILLS FLARE Generator Type _____
 Operator RES Burner Type _____
 Fuel Type METHANE O₂ Controller Type _____
 Trailer No. 2 EQUIP

Dry Uncorrected

Time	Sample Point	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	Comments	Miscellaneous Information
									CALIBRATION GASES
1654	B1	12.55	8.40	215			12.7		NO _x _____
1657	B2	12.58	8.34	250			12.2		SO ₂ _____
1700	B3	12.65	8.42	260			12.1		CO _____
1703	B4	12.83	8.24	290			11.2		CO/CO ₂ /O ₂ _____
1706	B5	12.88	7.80	298			10.5		
1709	B6	13.30	7.86	290			9.8		Wet Bulb: _____ Dry Bulb: _____
									Barometric Press: _____
		0.10	0.0	0.0			0.20		
		12.7	9.98	—	—	—	—		RESPONSE TIME
		—	9.78	—	—	—	—		Upscale: _____ Downscale: _____
		—	—	792	—	—	—		Upscale: _____ Downscale: _____
		—	—	599	—	—	—		Upscale: _____ Downscale: _____
		—	—	400	—	—	—		
		—	—	203	—	—	—		PROCESS DATA
		—	—	164	—	—	—		Fuel Flow: _____
		—	—	54.0	—	—	—		Steam Flow: _____
		—	—	—	—	—	40.4		Rating: _____
									CONVERTER GAS
									Cal Gas Values Actual Values
									NO _____
									NO ₂ _____
									Conv. Efficiency: _____



0. MID-LEVEL CHECK - NO RES
 Response =
 Actual = 15.00%

(971)



CHART NO. CL-2172-8

Chart No.



0. MID-LEVEL CHECK - NO RES
 Response = 15.10%
 Actual = 15.75%

0. SPARE - NO RES
 19.50%



No Zero - NO

0. SPARE RES = 19.50%

(971)



- No Zero
 - 0. REORDER ZONE 400

0. MID-LEVEL CHECK - NO RES = 19.00%
 Actual = 19.00%

NO. CL-2172-8


CHART NO. CL2172-8

Chart No.

(971)

CHART NO. CL2172-8

Chart No.



姓名

619-1B2

-10	0	10	20	30	40	50	60	70	80	90	100
-----	---	----	----	----	----	----	----	----	----	----	-----

五、

20 cm / 1 m

ANALYZER TEST DATA
Protocol 1 Gas = 59.9 ppm NOx
ANALYZER RE 510058 = 49.0 ppm

(4971)

CHART NO. CI-2172-B

己亥

$$n = 2^2$$

U-29

0-22


4-23


Q. 22

۵۵

五

11





10 20 30 40 50 60 70 80 90 100

O_2 EXT. V - NO ADD = 15.10%

10 20 30 40 50 60 70 80 90 100

NO_2 EXT. V - NO ADD = 32.5 ppm

0 10 20 30 40 50 60 70 80 90 100

O_2 INTERNAL ZERO V - NO ADD = 0.0%
 NO_2 EXT. ZERO V - NO ADD = +1.00 ppm

76.1625 - 1620 84

85.1611 - 1617 85

84.1611 - 1614 84

83.1611 - 1611 83

82.1611 - 1608 82


81.1611 - 1605 81





80.1611 - 1602 80


79.1611 - 1599 79

78.1611 - 1596 78

77.1611 - 1593 77







(071)

CHART NO. CL2172-R

Chart No.




(071)

CHART NO. CL2172-R

Chart No.


(071)


CO₂ EFF. SPAN - NO. 100 = 254.5 ppm








CO₂ EFF. SPAN - NO. 100 = 254.5 ppm

CO₂ EFF. ZERO CHECK - 610 ppm - NO. 100












CHART 1

Output

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60

70

80

90

100

0

10

20

30

40

50

60





CHART NO. CL21724


Chart No.




(271)

CHART NO. CL21724


Chart No.













START RUN #4 @ 1445 HRS
N 1600'







9/24/92 ARBOR HILLS FLARE YES
 CO = 0 - 500 ppm
 CO₂ = 0 - 20 %



CO₂ EXT CHECK = 9.88%
NO ADS
ACTUAL = 10.0%

CO₂ EXT CHECK = 205 ppm
NO ADS
ACTUAL = 202 ppm

CO₂ EXT ZERO = 0 ppm
CO₂ EXT ZERO = 0%
NO ADS

BEGIN EXTERNAL CHECKS

INTERFERENCE CHECK (NO CO₂)
CO₂ = 10
CC = 10

CO₂ MID-LEVEL / NO ADS = 10.0%
ACTUAL = 9.9%

CO₂ SPAN = 15.9%
NO ADS

N₂ ZERO - NO ADS

CHART NO. C

CHART NO. C


CHART NO. C

CHART NO. C





CHART NO. C


CHART NO. C

CHART NO. C



CO2 EXT CHECK = 9.881.
NO ADS
ACTUAL = 10.04





F. S. L.

CO₂ EXT ✓ = 9.80%
ACTUAL = 10.0%

CO EXT ✓ = 209 ppm
ACTUAL = 206 ppm

CO₂ ZERO ✓ - 0 EXT
CO ZERO ✓ - 0 EXT

CHART NO. CL2172-8

Charting

CHART NO. CL2172-8




CHART NO. C-1

DATE

(1977)

CHART NO. C-1222

DATE

0

10

20

30

40

50

60

70

80

90

100

O₂ Span = 25.0 %
NO_x Span = 100 ppm

O₂ Zero Check = No Adj

O₂ Span Adj = 19.50 %

- O₂ (U₂) Zero

- O₂ Rec Zero Adj

NO_x Mid Level Check = 40.9 ppm
No Adj

NO_x Span = 80.2 ppm
No Adj

N₂ Zero Adj

NO_x Span Adj = 80.2 ppm

- NO_x Zero Adj

- Rec Zero

9/25/92 BFI- ARBOR HILLS FLARE

NO_x = 0-100 ppm

DES

O₂ = 0-25 %

(4971)


CHART NO. CL-2172.8

CHART NO.

(4971)

CHART NO. CL-2172.8

CHART NO.



NO₂ MID CHECK - 41.0
ACTUAL = 41.1 ppm

NO₂ SPAN = 89.0 ppm
NO 2.05

- NO₂ ZERO ADJ

REAL NO₂ DUE TO TEMP DRIFT

O₂ MID LEVEL CHECK = 12.35%
ACTUAL = 11.8%

O₂ SPAN = 2.50%
NO 2.05

O₂ ZERO CHECK - NO 2.05

CHART NO. CL-1172.8

Pressure

0

10

20

30

40

50

60

70

80

90

100

CHART NO. CL-1172.8

Pressure

0

10

20

30

40

50


60

70

80

90

100



O₂ EXT V = 12.5%
ACTUAL = 111.9.0


EXT ZERO CHECK = +0.05% O₂

RT Probe





Pneumo


CHART NO. CL2172.8




CL NO. CL2172.8




START RUN #5 @ 12.26












CHART NO. CL-21728

CHART NO. CL-21728

CHART NO. CL-21728

CHART NO. CL-21728

CHART NO. CL-21728

CHART NO. CL-21728

A1 1305 - 1305 AG
A5 1302 - 1302 AS
A1 1259 - 1259 AU
A3 1254 - 1254 A3
A2 1253 - 1253 A2
A1 1250 - 1250 A1

B1 1241 - 1241 BU
B5 1238 - 1238 B5
B4 1235 - 1235 BU
B3 1232 - 1232 B3
B2 1229 - 1229 B2
B1 1226 - 1226 B1

START RUN # 5 @ 1226 20m/HR

INTERFERENCE CHECKS (NO. @ 120 ppm) CO = 0
CO2 = 0

CO2 EXT V = 10.04%
ACTUAL = 10.02%

CO2 EXT ZERO V = 0.04%

CO LOW EXT V = 45.0 ppm
ACTUAL = 45.5 ppm

CO EXT V = 142.5 ppm
CO ACTUAL = 202 ppm

CO EXT ZERO CHECK = 0








CHART NO. CL-21728

CHART NO. CL-21728

CHART NO. CL-21728

CHART NO. CL-21728

CHART NO. CL-21728



CHAM


0.0000

(071)

CHART NO. CL21728

0.0000

(071)



CO2 ZERO CHECK = 0 EXT
CO EXT ZERO CHECK = 0

CHART NO. CL-2172








CHART NO. CL-2172A



9/25/92 BFI ARBOR HILLS FLARE
CO = 0 - 200 PPM







C5 1554

C4 1551

C3 1548

C2 1545

C1 1542

C2 1542

(497)



CHART NO. CL2172.8

(497)



CO LOW EXT V = 45.2 ppm
ACTUAL = 44.5 ppm

(497)



CO EXT ZV = 0

1357 C6




1352 C5

1353 C4

1350 C3

1347 C2

1344 C1



**TABLE A-1. CEMS ANALYZER CALIBRATION ERROR
TEST RESULTS (TESTS #1 + #2)**

	High Range Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	19.50	19.50	0.00	0.0	+2
NOx (ppm)	80.40	80.40	0.00	0.0	+2
CO (ppm)	402.50	402.50	0.00	0.0	+2
CO2 (%)	15.90	15.90	0.00	0.0	+2

	Mid Range Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	14.75	15.10	0.35	1.4	+2
NOx (ppm)	41.20	42.00	0.80	0.8	+2
CO (ppm)	255.00	260.00	5.00	1.0	+2
CO2 (%)	11.80	11.96	0.16	0.8	+2

	Zero Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	0.00	0.00	0.00	0.0	+2
NOx (ppm)	0.00	0.00	0.00	0.0	+2
CO (ppm)	0.00	0.00	0.00	0.0	+2
CO2 (%)	0.00	0.00	0.00	0.0	+2

**Instrument Span
Range 0 to :**

O2 (%)	25
NOx (ppm)	100
CO (ppm)	500
CO2 (%)	20

TABLE A-1. CEMS ANALYZER CALIBRATION ERROR
TEST RESULTS (TESTS #3+#4)

	High Range Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	19.50	19.50	0.00	0.0	+2
NOx (ppm)	80.20	80.20	0.00	0.0	+2
CO (ppm)	403.00	403.00	0.00	0.0	+2
CO2 (%)	14.75	14.75	0.00	0.0	+2

	Mid Range Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	11.82	12.30	0.48	1.9	+2
NOx (ppm)	41.00	40.00	1.00	1.0	+2
CO (ppm)	206.00	207.00	1.00	0.2	+2
CO2 (%)	9.90	10.00	0.10	0.5	+2

	Zero Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	0.00	0.00	0.00	0.0	+2
NOx (ppm)	0.00	0.00	0.00	0.0	+2
CO (ppm)	0.00	0.00	0.00	0.0	+2
CO2 (%)	0.00	0.00	0.00	0.0	+2

Instrument Span
Range 0 to :

O2 (%)	25
NOx (ppm)	100
CO (ppm)	500
CO2 (%)	20

TABLE A-1. CEMS ANALYZER CALIBRATION ERROR
TEST RESULTS (TESTS #5 + #6)

	High Range Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	19.50	19.50	0.00	0.0	+2
NOx (ppm)	80.20	80.60	0.40	0.4	+2
CO (ppm)	402.00	402.00	0.00	0.0	+2
CO2 (%)	16.00	16.00	0.00	0.0	+2

	Mid Range Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	11.80	12.35	0.55	2.2	+2
NOx (ppm)	41.10	41.00	0.10	0.1	+2
CO (ppm)	206.00	207.50	1.50	0.3	+2
CO2 (%)	9.90	10.04	0.14	0.7	+2

	Zero Span Gas Value	Analyzer Calibration Response	Absolute Difference	Absolute Difference (% of span)	Allowable (% of span)
O2 (%)	0.00	0.00	0.00	0.0	+2
NOx (ppm)	0.00	0.00	0.00	0.0	+2
CO (ppm)	0.00	0.00	0.00	0.0	+2
CO2 (%)	0.00	0.00	0.00	0.0	+2

Instrument Span
Range 0 to :

O2 (%)	25
NOx (ppm)	100
CO (ppm)	500
CO2 (%)	20

TABLE A-2. CEMS ZERO DRIFT TEST RESULTS

	Test No.	Initial Zero	Final Zero	Absolute Difference	Difference (% of span)	Zero Drift Allowable (% of span)
O ₂ (%)	1	0.00	0.00	0.00	0.0	+-3
	2	0.00	0.00	0.00	0.0	+-3
NO _x (ppm)	1	1.40	1.25	0.15	0.1	+-3
	2	1.25	1.00	0.25	0.3	+-3
CO (ppm)	1	2.50	6.00	3.50	0.7	+-3
	2	6.00	0.00	6.00	1.2	+-3
CO ₂ (%)	1	0.00	0.00	0.00	0.0	+-3
	2	0.00	-0.04	0.04	0.2	+-3

TABLE A-2. CEMS ZERO DRIFT TEST RESULTS

	Test No.	Initial Zero	Final Zero	Absolute Difference	Difference (% of span)	Zero Drift Allowable (% of span)
O ₂ (%)	3	0.00	0.00	0.00	0.0	+-3
	4	0.00	0.00	0.00	0.0	+-3
NO _x (ppm)	3	0.00	-0.40	0.40	0.4	+-3
	4	-0.40	-0.70	0.30	0.3	+-3
CO (ppm)	3	0.00	0.00	0.00	0.0	+-3
	4	0.00	0.00	0.00	0.0	+-3
CO ₂ (%)	3	0.00	0.00	0.00	0.0	+-3
	4	0.00	0.00	0.00	0.0	+-3

TABLE A-2. CEMS ZERO DRIFT TEST RESULTS

	Test No.	Initial Zero	Final Zero	Absolute Difference	Difference (% of span)	Zero Drift Allowable (% of span)
O ₂ (%)	5	0.00	0.00	0.00	0.0	+3
	6	0.00	0.10	0.10	0.4	+3
NO _x (ppm)	5	0.00	0.80	0.80	0.8	+3
	6	0.80	0.20	0.60	0.6	+3
CO (ppm)	5	0.00	0.00	0.00	0.0	+3
	6	0.00	0.00	0.00	0.0	+3
CO ₂ (%)	5	0.00	0.00	0.00	0.0	+3
	6	0.00	0.00	0.00	0.0	+3

TABLE A-3. CEMS CALIBRATION DRIFT TEST RESULTS

	Test	Initial Calibration Response	Final Calibration Response	Absolute Difference	Absolute Difference (% of span)	Calibration Drift Allowable (% of span)
O2 (%)	1	15.25	15.40	0.15	0.6	+3
	2	15.40	15.18	0.22	0.9	+3
NOx (ppm)	1	41.30	40.40	0.90	0.9	+3
	2	40.40	39.50	0.90	0.9	+3
CO (ppm)	1	256.50	256.50	0.00	0.0	+3
	2	256.50	252.50	4.00	0.8	+3
CO2 (%)	1	11.86	11.86	0.00	0.0	+3
	2	11.86	11.88	0.02	0.1	+3

TABLE A-3. CEMS CALIBRATION DRIFT TEST RESULTS

	Test	Initial Calibration Response	Final Calibration Response	Absolute Difference	Absolute Difference (% of span)	Calibration Drift Allowable (% of span)
O ₂ (%)	3	12.50	12.13	0.37	1.5	+ -3
	4	12.13	12.35	0.22	0.9	+ -3
NO _x (ppm)	3	39.60	39.80	0.20	0.2	+ -3
	4	39.80	39.10	0.70	0.7	+ -3
CO (ppm)	3	205.00	207.00	2.00	0.4	+ -3
	4	207.00	209.00	2.00	0.4	+ -3
CO ₂ (%)	3	9.88	9.94	0.06	0.3	+ -3
	4	9.94	9.80	0.14	0.7	+ -3

TABLE A-3. CEMS CALIBRATION DRIFT TEST RESULTS

	Test	Initial Calibration Response	Final Calibration Response	Absolute Difference	Absolute Difference (% of span)	Calibration Drift Allowable (% of span)
O ₂ (%)	5	12.55	12.45	0.10	0.4	+ -3
	6	12.45	12.70	0.25	1.0	+ -3
NO _x (ppm)	5	41.00	40.50	0.50	0.5	+ -3
	6	40.50	40.40	0.10	0.1	+ -3
CO (ppm)	5	192.50	206.00	13.50	2.7	+ -3
	6	206.00	203.00	3.00	0.6	+ -3
CO ₂ (%)	5	10.04	9.84	0.20	1.0	+ -3
	6	9.84	9.78	0.06	0.3	+ -3

TABLE A-4. CEMS UPSCALE GAS SAMPLING SYSTEM BIAS TEST RESULTS

	Test No.	Initial System Calibration		Analyzer Calibration		Absolute Difference		Sampling System Bias (% of span)		Final System Calibration		Analyzer Calibration Response		Absolute Difference		Sampling System Bias (% of span)		Allowable Sampling System Bias (% of span)	
		Response		Response						Response		Response							
O ₂ (%)	1	15.25		15.10		0.15		0.6		15.40		15.10		0.30		1.2		+5	
	2	15.40		15.10		0.30		1.2		15.18		15.10		0.08		0.3		+5	
NO _x (ppm)	1	41.30		42.00		0.70		0.7		40.40		42.00		1.60		1.6		+5	
	2	40.40		42.00		1.60		1.6		39.50		42.00		2.50		2.5		+5	
CO (ppm)	1	256.50		260.00		3.50		0.7		256.50		260.00		3.50		0.7		+5	
	2	256.50		260.00		3.50		0.7		252.50		260.00		7.50		1.5		+5	
CO ₂ (%)	1	11.86		11.96		0.10		0.5		11.86		11.96		0.10		0.5		+5	
	2	11.86		11.96		0.10		0.5		11.88		11.96		0.08		0.4		+5	

TABLE A-4. CEMS UPSCALE GAS SAMPLING SYSTEM BIAS TEST RESULTS

	Test No.	Initial System Calibration Response	Analyzer Calibration Response	Absolute Difference	Sampling System Bias (% of span)	Final System Calibration Response	Analyzer Calibration Response	Absolute Difference	Sampling System Bias (% of span)	Allowable Sampling System Bias (% of span)
O ₂ (%)	3	12.50	12.30	0.20	0.8	12.13	12.30	0.17	0.7	+5
	4	12.13	12.30	0.17	0.7	12.35	12.30	0.05	0.2	+5
NO _x (ppm)	3	39.60	40.00	0.40	0.4	39.80	40.00	0.20	0.2	+5
	4	39.80	40.00	0.20	0.2	39.10	40.00	0.90	0.9	+5
CO (ppm)	3	205.00	207.00	2.00	0.4	207.00	207.00	0.00	0.0	+5
	4	207.00	207.00	0.00	0.0	209.00	207.00	2.00	0.4	+5
CO ₂ (%)	3	9.88	10.00	0.12	0.6	9.94	10.00	0.06	0.3	+5
	4	9.94	10.00	0.06	0.3	9.80	10.00	0.20	1.0	+5

TABLE A-4. CEMS UPSCALE GAS SAMPLING SYSTEM BIAS TEST RESULTS

Test No.		Initial System Calibration		Analyzer Calibration		Absolute Difference		Sampling System Bias (% of span)		Final System Calibration Response		Analyzer Calibration Response		Absolute Difference		Sampling System Bias (% of span)		Allowable Sampling System Bias (% of span)	
		Response		Response						Response		Response							
5	O ₂ (%)	12.55		12.35		0.20		0.8		12.45		12.35		0.10		0.4		+5	
		12.45		12.35		0.10		0.4		12.70		12.35		0.35		1.4		+5	
5	NO _x (ppm)	41.00		41.00		0.00		0.0		40.50		41.00		0.50		0.5		+5	
		40.50		41.00		0.50		0.5		40.40		41.00		0.60		0.6		+5	
5	CO (ppm)	192.50		207.50		15.00		3.0		206.00		207.50		1.50		0.3		+5	
		206.00		207.50		1.50		0.3		203.00		207.50		4.50		0.9		+5	
5	CO ₂ (%)	10.04		10.04		0.00		0.0		9.84		10.04		0.20		1.0		+5	
		9.84		10.04		0.20		1.0		9.78		10.04		0.26		1.3		+5	

TABLE A-5. CEMS ZERO GAS SAMPLING SYSTEM BIAS TEST RESULTS

Test No.	Initial System Calibration Response	Analyzer Calibration Response		Absolute Difference	Sampling System Bias (% of span)	Final System Calibration Response		Absolute Difference	Sampling System Bias (% of span)	Allowable Sampling System Bias (% of span)
		Response				Response				
O2 (%)	1	0.00	0.00	0.00	0.0	0.00	0.00	0.00	0.0	+5
	2	0.00	0.00	0.00	0.0	0.00	0.00	0.00	0.0	+5
NOx (ppm)	1	1.40	0.00	1.40	1.4	1.25	0.00	1.25	1.3	+5
	2	1.25	0.00	1.25	1.3	1.00	0.00	1.00	1.0	+5
CO (ppm)	1	2.50	0.00	2.50	0.5	6.00	0.00	6.00	1.2	+5
	2	6.00	0.00	6.00	1.2	0.00	0.00	0.00	0.0	+5
CO2 (%)	1	0.00	0.00	0.00	0.0	0.00	0.00	0.00	0.0	+5
	2	0.00	0.00	0.00	0.0	-0.04	0.00	0.04	0.2	+5

TABLE A-5. CEMS ZERO GAS SAMPLING SYSTEM BIAS TEST RESULTS

	Test No.	Initial System Calibration		Analyzer Calibration Response	Absolute Difference	Sampling System Bias (% of span)	Final System Calibration		Analyzer Calibration Response	Absolute Difference	Sampling System Bias (% of span)	Allowable Sampling System Bias (% of span)
		Response	Response				Response	Response				
O ₂ (%)	3 4	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.0 0.0	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.0 0.0	+5 +5
NO _x (ppm)	3 4	0.00 -0.40	0.00 0.00	0.00 0.00	0.00 0.40	0.0 0.4	-0.40 -0.70	0.00 0.00	0.00 0.00	0.40 0.70	0.4 0.7	+5 +5
CO (ppm)	3 4	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.0 0.0	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.0 0.0	+5 +5
CO ₂ (%)	3 4	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.0 0.0	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.0 0.0	+5 +5

TABLE A-5. CEMS ZERO GAS SAMPLING SYSTEM BIAS TEST RESULTS

Test No.	Initial System Calibration Response	Analyzer Calibration Response		Absolute Difference		Sampling System Bias (% of span)		Final System Calibration Response		Analyzer Calibration Response		Absolute Difference		Sampling System Bias (% of span)		Allowable Sampling System Bias (% of span)
		Response		Difference		(% of span)		Response		Response		Difference		(% of span)		
O2 (%)	5	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.0	+5
	6	0.00	0.00	0.00	0.10	0.0	0.0	0.10	0.00	0.00	0.00	0.10	0.10	0.4	0.4	+5
NOx (ppm)	5	0.00	0.00	0.00	0.80	0.0	0.0	0.80	0.00	0.00	0.00	0.80	0.80	0.8	0.8	+5
	6	0.80	0.00	0.80	0.20	0.8	0.0	0.20	0.00	0.00	0.00	0.20	0.20	0.2	0.2	+5
CO (ppm)	5	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.0	+5
	6	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.0	+5
CO2 (%)	5	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.0	+5
	6	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.0	+5

TABLE A-6. CORRECTED GAS CONCENTRATIONS

	Test No.	$\bar{C}$	C_o	C_m	C_{ma}	C_{gas}
O ₂ (%)	1	11.31	0.00	15.33	14.94	11.03
	2	11.41	0.00	15.29	14.94	11.15
NO _x (ppm)	1	20.00	1.33	40.85	40.30	19.04
	2	18.66	1.13	39.95	40.30	18.20
CO (ppm)	1	76.38	4.25	256.50	255.50	73.06
	2	96.88	3.00	254.50	255.50	95.37
CO ₂ (%)	1	9.56	0.00	11.86	12.00	9.67
	2	9.52	-0.02	11.87	12.00	9.63

$$C_{gas} = (\bar{C} - C_o) \times [C_{ma} / (C_m - C_o)] \text{ : Equation 6C-1, EPA Method 6C.}$$

Where : C_{gas} = Effluent gas concentration, dry basis.

$\bar{C}$ = Average gas concentration indicated by gas analyzer dry basis.

C_o = Average of initial and final system calibration bias check responses for the zero gas.

C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas.

C_{ma} = Actual concentration of the upscale calibration gas.

TABLE A-6. CORRECTED GAS CONCENTRATIONS

	Test No.	$\bar{C}$	C_o	C_m	C_{ma}	C_{gas}
O ₂ (%)	3	11.18	0.00	12.32	11.95	10.85
	4	11.06	0.00	12.24	11.95	10.80
NO _x (ppm)	3	17.26	-0.20	39.70	39.80	17.42
	4	17.98	-0.55	39.45	39.80	18.44
CO (ppm)	3	70.73	0.00	206.00	202.00	69.36
	4	14.73	0.00	208.00	202.00	14.31
CO ₂ (%)	3	9.58	0.00	9.91	10.00	9.67
	4	9.51	0.00	9.87	10.00	9.64

$$C_{gas} = (\bar{C} - C_o) \times [C_{ma} / (C_m - C_o)] \text{ : Equation 6C-1, EPA Method 6C.}$$

Where : C_{gas} = Effluent gas concentration, dry basis.

$\bar{C}$ = Average gas concentration indicated by gas analyzer dry basis.

C_o = Average of initial and final system calibration bias check responses for the zero gas.

C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas.

C_{ma} = Actual concentration of the upscale calibration gas.

TABLE A-6. CORRECTED GAS CONCENTRATIONS

	Test No.	$\bar{C}$	Co	Cm	Cma	Cgas
O2 (%)	5	11.97	0.00	12.50	11.96	11.45
	6	12.71	0.05	12.58	11.96	12.09
NOx (ppm)	5	15.53	0.40	40.75	39.80	14.92
	6	12.23	0.50	40.45	39.80	11.69
CO (ppm)	5	89.83	0.00	199.25	202.00	91.07
	6	399.17	0.00	204.50	202.00	394.29
CO2 (%)	5	8.95	0.00	9.94	10.02	9.02
	6	8.23	0.00	9.81	10.02	8.41

$$C_{gas} = (\bar{C} - C_o) \times [C_{ma} / (C_m - C_o)] : \text{Equation 6C-1, EPA Method 6C.}$$

Where : C_{gas} = Effluent gas concentration, dry basis.

$\bar{C}$ = Average gas concentration indicated by gas analyzer dry basis.

C_o = Average of initial and final system calibration bias check responses for the zero gas.

C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas.

C_{ma} = Actual concentration of the upscale calibration gas.

Date: 9/25/92Test Location: Flare Out/in

SAMPLE HANDLING/LOG-IN

NO	SAMPLE TYPE	VOLUME	COMMENTS
1	33758 <u>Can</u> <u>3</u> Meth Sample Test		Outlet
2	33759 <u>Bag</u> <u>3</u> Meth Sample Test		Outlet
3	33760 <u>Can</u> <u>3</u> Meth Sample Test		Inlet
4	33761 <u>Bag</u> <u>3</u> Meth Sample Test		Inlet
5	33766 <u>Can</u> <u>4</u> Meth Sample Test		Outlet
6	33767 <u>Bag</u> <u>4</u> Meth Sample Test		Outlet
7	33768 <u>Can</u> <u>4</u> Meth Sample Test		Inlet
8	33769 <u>Bag</u> <u>4</u> Meth Sample Test		Inlet
9	33789 <u>Can</u> <u>5</u> Meth Sample Test		Inlet
10	33788 <u>Bag</u> <u>5</u> Meth Sample Test		Inlet
11	33787 <u>Can</u> <u>5</u> Meth Sample Test		Outlet
12	33786 <u>Bag</u> <u>5</u> Meth Sample Test		Inlet

CHAIN-OF-CUSTODY

Signature

Date/Time

Signature

Date/Time

Jim Steiner9/26/92 11:00am

Date: 9/25/92Test Location: Flare Outlet / In

SAMPLE HANDLING/LOG-IN

NO	SAMPLE TYPE	VOLUME	COMMENTS
1	33754 $\frac{26A}{Meth}$ $\frac{FHW}{Sample}$ $\frac{3}{Test}$		
2	33755 $\frac{26A}{Meth}$ $\frac{HF}{Sample}$ $\frac{3}{Test}$		
3	33756 $\frac{26A}{Meth}$ $\frac{H_2SO_4}{Sample}$ $\frac{3}{Test}$		
4	33757 $\frac{26A}{Meth}$ $\frac{NaOH}{Sample}$ $\frac{3}{Test}$		
5	33762 $\frac{26A}{Meth}$ $\frac{FHW}{Sample}$ $\frac{4}{Test}$		
6	33763 $\frac{26A}{Meth}$ $\frac{HF}{Sample}$ $\frac{4}{Test}$		
7	33764 $\frac{26A}{Meth}$ $\frac{H_2SO_4}{Sample}$ $\frac{4}{Test}$		
8	33765 $\frac{26A}{Meth}$ $\frac{NaOH}{Sample}$ $\frac{4}{Test}$		
9	33753 $\frac{ASTM}{Meth}$ $\frac{N/A}{Sample}$ $\frac{1.2}{Test}$		
10	33771 $\frac{ASTM}{Meth}$ $\frac{N/A}{Sample}$ $\frac{3.4}{Test}$		
11	33772 $\frac{26A}{Meth}$ $\frac{FHW}{Sample}$ $\frac{BL}{Test}$		
12	33773 $\frac{26A}{Meth}$ $\frac{HF}{Sample}$ $\frac{BL}{Test}$		

CHAIN-OF-CUSTODY

Signature

Jim Steiner

Date/Time

9/27/92 11:00 am

Signature

Walter A. Brown

Date/Time

9-28-92 / 11:10

Date: 9/25/92Test Location: Flare Out/In

SAMPLE HANDLING/LOG-IN

NO	SAMPLE TYPE	VOLUME	COMMENTS
1	33774 <u>2LA</u> <u>H₂SO₄</u> <u>BL</u> Meth Sample Test		
2	33775 <u>2LA</u> <u>NaOH</u> <u>BL</u> Meth Sample Test		
3	33776 <u>B</u> <u>FHW</u> <u>5</u> Meth Sample Test		
4	33777 <u>B</u> <u>MF</u> <u>5</u> Meth Sample Test		
5	33778 <u>B</u> <u>IPA</u> <u>5</u> Meth Sample Test		
6	33779 <u>B</u> <u>AMF</u> <u>5</u> Meth Sample Test		
7	33780 <u>B</u> <u>H₂O₂</u> <u>5</u> Meth Sample Test		
8	33781 <u>B</u> <u>FAW</u> <u>6</u> Meth Sample Test		
9	33782 <u>B</u> <u>MF</u> <u>6</u> Meth Sample Test		
10	33783 <u>B</u> <u>IPA</u> <u>6</u> Meth Sample Test		
11	33784 <u>B</u> <u>AMF</u> <u>6</u> Meth Sample Test		
12	33785 <u>B</u> <u>H₂O₂</u> <u>6</u> Meth Sample Test		

CHAIN-OF-CUSTODY

Signature

Jim Steiner

Date/Time

9/27/92 11:00am

Signature

Wayne H. Burson

Date/Time

9-28-92 11:10

Date: 9/25/92

Test Location: Flare Out/In

SAMPLE HANDLING/LOG-IN

NO	SAMPLE TYPE	VOLUME	COMMENTS
1	33790 <u>B</u> <u>H₂O₂</u> <u>BL</u> Meth Sample Test		
2	33791 <u>B</u> <u>AME</u> <u>BL</u> Meth Sample Test		
3	33792 <u>B</u> <u>MF</u> <u>BL</u> Meth Sample Test		
4	33793 <u>B</u> <u>IPA</u> <u>BL</u> Meth Sample Test		
5	33794 <u>ASTM</u> <u>S.G.</u> Meth Sample Test		
6			
7			
8			
9			
10			
11			
12			

CHAIN-OF-CUSTODY

Signature

Date/Time

Signature

Date/Time

Jim Steiner

9/27/92 11:00 AM

Weyne A. Brumley

9-28-92 11:10

ANALYTICAL REPORT

SAMPLE TYPE	: .1 N H ₂ SO ₄	TEST DATE	: 09/23,24,25/9
SAMPLE COMPONENT	: HCl	ANALYSIS DATE	: 09/29/92
REQUESTED BY	: BFI - ARBOR HILLS	ANALYST	: WB
ANALYTICAL METHOD	: ISE METER		

Sample ID #	Test No.	Sample Volume mL	Cl ppm	HCl mg	QC %
-----	-----	-----	-----	-----	-----
33756	3	415	41	17.01	102.5 DUP
33764	4	420	38	15.93	95.5 REC
33774	BLANK	100	1	0.10	

ANALYTICAL REPORT

SAMPLE TYPE : .1 N NaOH
 SAMPLE COMPONENT : Cl2
 REQUESTED BY : BFI - ARBOR HILLS
 ANALYTICAL METHOD : ISE METER

TEST DATE : 09/23,24,25/92
 ANALYSIS DATE: 09/29/92
 ANALYST : WB

Sample ID #	Test No.	Sample Volume mL	Cl ppm	Cl2 mg	QC %
33757	3	270	.96	ND	100.0 DUP
33765	4	265	1.1	ND	95.2 REC
33775	BLANK	100	.92	.05	

ND = LESS THAN .05 mg

ANALYTICAL REPORT

SAMPLE TYPE	: FILTERABLE SO4	TEST DATE	: 09/23, 24, 25/92
SAMPLING METHOD	: M8	ANALYSIS DATE	: 09/29/92
SAMPLE COMPONENT	: FHW + MF	ANALYST	: WB
REQUESTED BY	: BFI - ARBOR HILLS		
ANALYTICAL METHOD	: BaCl2 Titration		

Test No.	Sample Volume mL	Sample Aliquot mL	Titer mL	Analyt. Result (total sample) mg H2SO4
-----	-----	-----	-----	-----
5	100	10	0.32	1.04
6	100	10	0.29	0.89
BLANK	100	10	0.11	0.54

% Duplicate =

TEST 5 = 96.88

% Recovery =

TEST 6 = 98.38

% CONFIDENCE =

99.55

EPA SO2 LOT

0584 5XXX

NORMALITY =

0.010101

ANALYTICAL REPORT

SAMPLE TYPE : CONDENSIBLE SULFATE
 SAMPLING METHOD : M8
 SAMPLE COMPONENT : BHW + AMF
 REQUESTED BY : BFI - ARBOR HILLS
 ANALYTICAL METHOD : BaCL2 Titration

TEST DATE : 09/23,24,25/92
 ANALYSIS DATE: 09/29/92
 ANALYST : WB

Test No.	Sample Volume mL	Sample Aliquot ml	Titer mL	Analyt. Result (total sample) mg H2SO4
5	100	10	0.51	2.13
6	100	10	0.84	3.76
AMF BK	100	10	0.08	0.39
IPA BK	100	10	0.07	0.34
Di BK	100	10	0.07	0.34

% Duplicate =

TEST 6 = 98.81

% Recovery =

TEST 5 = 100.40

% CONFIDENCE =

99.55

EPA SO2 LOT 0584 5XXX

NORMALITY =

0.010101

ANALYTICAL REPORT

SAMPLE TYPE : SO2	TEST DATE : 09/23, 24, 25/
SAMPLING METHOD : M8	ANALYSIS DATE : 09/29/92
SAMPLE COMPONENT : 3% H2O2	ANALYST : WB
REQUESTED BY : BFI - ARBOR HILLS	

ANALYTICAL METHOD : BaCL2 Titration

Sample ID #	Test No.	Sample Volume mL	Sample Aliquot mL	Titer mL	Analyt. Result (total sample mg H2SO4)
-----	-----	-----	-----	-----	-----
33780	5	460	10	1.02	21.7
33785	6	430	10	1.05	20.9
33790	BLANK	100	10	0.06	0.3

% Duplicate =

TEST 5 = 103.00

% Recovery =

TEST 6 = 100.00

% CONFIDENCE =
NORMALITY =

99.87
0.0100401

EPA SO2 LOT 0584 5XXX

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE OUTLET

RUN NO.: 1
DATE : SEPT 23, 1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	72.88 DEG. F	:	STATIC PRESS.	=	-0.05 in. H2O
STACK TEMP.	=	1904.04 DEG. F	:	Cp	=	0.840
SQ.RT. dP	=	0.3220 in. H2O	:	STACK I.D.	=	139.50 inch
METER ORIFICE	=	2.00 in. H2O	:	DUCT LENGTH	=	inch
METER VOLUME	=	56.948 Cu.Ft.	:	DUCT WIDTH	=	inch
METER Y	=	1.0098	:	STACK AREA	=	106.139 Sq.Ft.
BAR. PRESSURE	=	29.23 in.Hg	:	TEST TIME	=	72.00 min.
COND.(Vlc)	=	84.3 ml	:	NOZZLE DIA.	=	inch

GAS ANALYSIS	=	11.03 % O2		0.00 % CO
		9.67 % CO2		79.30 % N2

$V_m(std) = [T(std) + 460 / 29.92] \times V_m \times Y \times$ $(P_b + (dH / 13.6)) / (T_m + 460) \dots\dots$	=	55.945	dscf
$V_w(std) = (8.9148 \times 10e-5) \times (T_{std} + 460) \times V_{lc}$	=	3.968	scf
$Bws = V_w(std) / (V_m(std) + V_w(std)) \dots\dots\dots$	=	0.066	: Lower
Bws @ Saturated Conditions = Vapor Press. of H2O			: Bws
@ Dew Point Temp. / (Ps, in.Hg.)	=	1.000	: value
			: used.
$\%EA = (\%O_2 - 0.5\%CO) / (0.264\%N_2 - (\%O_2 - 0.5\%CO)) \times 100 =$		111.36	
$M_d = (.44 \times \%CO_2) + (.32 \times \%O_2) + [.28 \times (\%N_2 + \%CO)]$	=	29.99	
$M_s = (M_d \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots$	=	29.19	
$P(stack) = P_{bar} + [P_{static} / 13.6] \dots\dots\dots$	=	29.23 in. Hg	
$v_s = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460)$ $/ (M_s \times P_s)] \dots\dots\dots$	=	38.49	ft/sec
$Q_s = v_s \times A_s \times 60 \dots\dots\dots$	=	245,112	acf/min
$Q_s(std) = Q_s \times (1 - Bws) \times ((T_{std} + 460) / (T_s + 460))$ $\times (P_s / 29.92) \dots\dots\dots$	=	49,935	dscf/min
$I = (Ts + 460) \times [(0.002669 \times V_{lc}) + (V_m(std) / (T_{std} +$ $460) / 29.92] \times 100 / (Time \times P_s \times A_n \times v_s \times 60) =$			%

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE OUTLET

RUN NO.: 2
DATE : SEPT 23, 1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	= 101.88 DEG. F	STATIC PRESS.	= -0.05 in. H2O
STACK TEMP.	= 1860.79 DEG. F	Cp	= 0.840
SQ. RT. dP	= 0.3146 in. H2O	STACK I.D.	= 139.50 inch
METER ORIFICE	= 2.00 in. H2O	DUCT LENGTH	= inch
METER VOLUME	= 57.253 Cu.Ft.	DUCT WIDTH	= inch
METER Y	= 1.0098	STACK AREA	= 106.139 Sq.Ft.
BAR. PRESSURE	= 29.32 in. Hg	TEST TIME	= 72.00 min.
COND. (Vlc)	= 131.5 ml	NOZZLE DIA.	= inch

GAS ANALYSIS : 11.15 % O2 0.00 % CO
9.63 % CO2 79.22 % N2

$$V_m(\text{std}) = [T(\text{std}) + 460 / 29.92] \times V_m \times Y \times (P_b + (dH / 13.6)) / (T_m + 460) \dots = 53.506 \text{ dscf}$$

$$V_w(\text{std}) = (8.9148 \times 10^{-5}) \times (T_{\text{std}} + 460) \times V_{ic} = 6.190 \text{ scf}$$

$$B_{ws} = V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std})) \dots = 0.104 \text{ ; Lower}$$

$$B_{ws} \text{ @ Saturated Conditions} = \text{Vapor Press. of H}_2\text{O} \text{ ; } B_{ws} \\ \text{@ Dew Point Temp. / (Ps, in. Hg.)} \dots = 1.000 \text{ ; value used.}$$

$$\%EA = (\%O_2 - 0.5\%CO) / (0.264\%N_2 - (\%O_2 - 0.5\%CO)) \times 100 = 114.19$$

$$M_d = (.44 \times \%CO_2) + (.32 \times \%O_2) + [.28 \times (\%N_2 + \%CO)] = 29.99$$

$$M_s = (M_d \times (1 - B_{ws})) + (18.0 \times B_{ws}) \dots = 28.74$$

$$P(\text{stack}) = P_{bar} + [P_{static} / 13.6] \dots = 29.32 \text{ in. Hg}$$

$$v_s = 85.49 \times C_P \times (Sq. Rt. dP) \times [Sq. Rt. (T_s + 460) / (M_s \times P_s)] \dots = 37.49 \text{ ft/sec}$$

$$Q_s = v_s \times A_s \times 60 \dots = 238,765 \text{ acf/min}$$

$$Q_s(\text{std}) = Q_s \times (1 - B_{ws}) \times ((T_{\text{std}} + 460) / (T_s + 460)) \times (P_s / 29.92) \dots = 47,706 \text{ dscf/min}$$

$$I = (T_s + 460) \times [(0.002669 \times V_{lc}) + (V_m(\text{std}) / (T_{\text{std}} + 460) / 29.92)] \times 100 / (Time \times P_s \times A_n \times v_s \times 60) = \%$$

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE OUTLET

RUN NO.: 3
DATE : SEPT 24, 1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	90.94 DEG. F	:	STATIC PRESS.	=	-0.05 in. H2O
STACK TEMP.	=	1848.08 DEG. F	:	Cp	=	0.840
SQ. RT. dP	=	0.3272 in. H2O	:	STACK I.D.	=	139.50 inch
METER ORIFICE	=	2.50 in. H2O	:	DUCT LENGTH	=	inch
METER VOLUME	=	63.114 Cu.Ft.	:	DUCT WIDTH	=	inch
METER Y	=	1.0098	:	STACK AREA	=	106.139 Sq.Ft.
BAR. PRESSURE	=	29.33 in.Hg	:	TEST TIME	=	72.00 min.
COND. (Vlc)	=	161.0 ml	:	NOZZLE DIA.	=	inch

GAS ANALYSIS	=	10.85 % O2		0.00 % CO
		9.67 % CO2		79.48 % N2

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times$
 $(Pb + (dH / 13.6)) / (Tm + 460) \dots\dots = 60.250 \text{ dscf}$

$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 7.578 \text{ scf}$

$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots = 0.112$: Lower
: Bws

Bws @ Saturated Conditions = Vapor Press. of H2O : value
@ Dew Point Temp. / (Ps, in.Hg.) : used.

$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 107.08$

$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.98$

$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots = 28.64$

$P(stack) = Pbar + [Pstatic / 13.6] \dots\dots\dots = 29.33 \text{ in. Hg}$

$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots\dots\dots = 38.95 \text{ ft/sec}$

$Qs = vs \times As \times 60 \dots\dots\dots = 248,042 \text{ acf/min}$

$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots\dots\dots = 49,403 \text{ dscf/min}$

$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) = \%$

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE OUTLET

RUN NO.: 4
DATE : SEPT 24, 1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	97.17 DEG. F	:	STATIC PRESS.	=	-0.04 in. H2O
STACK TEMP.	=	1891.29 DEG. F	:	Cp	=	0.840
SQ. RT. dP	=	0.3155 in. H2O	:	STACK I.D.	=	139.50 inch
METER ORIFICE	=	2.50 in. H2O	:	DUCT LENGTH	=	inch
METER VOLUME	=	63.132 Cu.Ft.	:	DUCT WIDTH	=	inch
METER Y	=	1.0098	:	STACK AREA	=	106.139 Sq.Ft.
BAR. PRESSURE	=	29.31 in.Hg	:	TEST TIME	=	72.00 min.
COND. (Vlc)	=	150.5 ml	:	NOZZLE DIA.	=	inch

GAS ANALYSIS	:	10.80 % O2		0.00 % CO
		9.64 % CO2		79.56 % N2

$$V_m(\text{std}) = [T(\text{std}) + 460 / 29.92] \times V_m \times Y \times (P_b + (dH / 13.6)) / (T_m + 460) \dots = 59.553 \text{ dscf}$$

$$V_w(\text{std}) = (8.9148 \times 10^{-5}) \times (T_{\text{std}} + 460) \times V_{lc} = 7.084 \text{ scf}$$

$$B_{ws} = V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std})) \dots = 0.106 \text{ : Lower Bws value}$$

$$B_{ws} \text{ @ Saturated Conditions} = \text{Vapor Press. of H}_2\text{O @ Dew Point Temp.} / (P_s, \text{ in.Hg.}) \dots = 1.000 \text{ : used.}$$

$$\%EA = (\%O_2 - 0.5\%CO) / (0.264\%N_2 - (\%O_2 - 0.5\%CO)) \times 100 = 105.84$$

$$M_d = (.44 \times \%CO_2) + (.32 \times \%O_2) + [.28 \times (\%N_2 + \%CO)] = 29.97$$

$$M_s = (M_d \times (1 - B_{ws})) + (18.0 \times B_{ws}) \dots = 28.70$$

$$P(\text{stack}) = P_{bar} + [P_{static} / 13.6] \dots = 29.31 \text{ in. Hg}$$

$$v_s = 85.49 \times C_P \times (Sq. Rt. dP) \times [Sq. Rt. (T_s + 460) / (M_s \times P_s)] \dots = 37.88 \text{ ft/sec}$$

$$Q_s = v_s \times A_s \times 60 \dots = 241,233 \text{ acf/min}$$

$$Q_s(\text{std}) = Q_s \times (1 - B_{ws}) \times ((T_{\text{std}} + 460) / (T_s + 460)) \times (P_s / 29.92) \dots = 47,420 \text{ dscf/min}$$

$$I = (T_s + 460) \times [(0.002669 \times V_{lc}) + (V_m(\text{std}) / (T_{\text{std}} + 460) / 29.92)] \times 100 / (Time \times P_s \times A_n \times v_s \times 60) = \%$$

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE OUTLET

RUN NO.: 5
DATE : SEPT 25,1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	=	98.6 DEG. F	:	STATIC PRESS.	=	-0.10 in. H2O
STACK TEMP.	=	1798.79 DEG. F	:	Cp	=	0.840
SQ.RT. dP	=	0.3461 in. H2O	:	STACK I.D.	=	139.50 inch
METER ORIFICE	=	2.50 in. H2O	:	DUCT LENGTH	=	inch
METER VOLUME	=	63.313 Cu.Ft.	:	DUCT WIDTH	=	inch
METER Y	=	1.0098	:	STACK AREA	=	106.139 Sq.Ft.
BAR. PRESSURE	=	29.21 in.Hg	:	TEST TIME	=	72.00 min.
COND.(Vlc)	=	144.2 ml	:	NOZZLE DIA.	=	inch

GAS ANALYSIS	=	11.45 % O2		0.00 % CO
		9.02 % CO2		79.53 % N2

$V_m(std) = [T(std) + 460 / 29.92] \times V_m \times Y \times$
 $(P_b + (dH / 13.6)) / (T_m + 460) \dots\dots = 59.368 \text{ dscf}$

$V_w(std) = (8.9148 \times 10e-5) \times (T_{std} + 460) \times V_{lc} = 6.788 \text{ scf}$

$Bws = V_w(std) / (V_m(std) + V_w(std)) \dots\dots\dots = 0.103$: Lower
: Bws

Bws @ Saturated Conditions = Vapor Press. of H2O
@ Dew Point Temp. / (Ps, in.Hg.) $\dots\dots\dots = 1.000$: value
: used.

$\%EA = (\%O_2 - 0.5\%CO) / (0.264\%N_2 - (\%O_2 - 0.5\%CO)) \times 100 = 119.95$

$M_d = (.44 \times \%CO_2) + (.32 \times \%O_2) + [.28 \times (\%N_2 + \%CO)] = 29.90$

$M_s = (M_d \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots = 28.68$

$P(stack) = P_{bar} + [P_{static} / 13.6] \dots\dots\dots = 29.20 \text{ in. Hg}$

$v_s = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(T_s + 460)$
 $/ (M_s \times P_s)] \dots\dots\dots = 40.82 \text{ ft/sec}$

$Q_s = v_s \times A_s \times 60 \dots\dots\dots = 259,932 \text{ acf/min}$

$Q_s(std) = Q_s \times (1 - Bws) \times ((T_{std} + 460) / (T_s + 460))$
 $\times (P_s / 29.92) \dots\dots\dots = 53,219 \text{ dscf/min}$

$I = (T_s + 460) \times [(0.002669 \times V_{lc}) + (V_m(std) / (T_{std} + 460) / 29.92] \times 100 / (Time \times P_s \times A_n \times v_s \times 60) =$ %

SOURCE TEST CALCULATIONS

PLANT : BFI ARBOR HILLS
FLARE OUTLET

RUN NO.: 6
DATE : SEPT 25, 1992

STANDARD TEMP.: 68 DEG. F

METER TEMP.	= 101.75 DEG. F	STATIC PRESS.	= -0.09 in. H2O
STACK TEMP.	= 1700.00 DEG. F	Cp	= 0.840
SQ.RT. dP	= 0.3478 in. H2O	STACK I.D.	= 139.50 inch
METER ORIFICE	= 2.50 in. H2O	DUCT LENGTH	= inch
METER VOLUME	= 62.871 Cu.Ft.	DUCT WIDTH	= inch
METER Y	= 1.0098	STACK AREA	= 106.139 Sq.Ft.
BAR. PRESSURE	= 29.14 in.Hg	TEST TIME	= 72.00 min.
COND.(Vlc)	= 142.6 ml	NOZZLE DIA.	= inch

GAS ANALYSIS	:	12.09 % O2	0.00 % CO
		8.41 % CO2	79.50 % N2

$$V_m(\text{std}) = [T(\text{std}) + 460 / 29.92] \times V_m \times Y \times (P_b + (dH / 13.6)) / (T_m + 460) \dots = 58.484 \text{ dscf}$$

$$V_w(\text{std}) = (8.9148 \times 10e-5) \times (T_{\text{std}} + 460) \times V_{ic} = 6.712 \text{ scf}$$

$$B_{ws} = V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std})) \dots = 0.103 \text{ : Lower : } B_{ws}$$

$$B_{ws} \text{ @ Saturated Conditions} = \text{Vapor Press. of H2O @ Dew Point Temp.} / (P_s, \text{ in.Hg.}) \dots = 1.000 \text{ : value : used.}$$

$$\%EA = (\%O_2 - 0.5\%CO) / (0.264\%N_2 - (\%O_2 - 0.5\%CO)) \times 100 = 135.87$$

$$M_d = (.44 \times \%CO_2) + (.32 \times \%O_2) + [.28 \times (\%N_2 + \%CO)] = 29.83$$

$$M_s = (M_d \times (1 - B_{ws})) + (18.0 \times B_{ws}) \dots = 28.61$$

$$P(\text{stack}) = P_{bar} + [P_{static} / 13.6] \dots = 29.13 \text{ in. Hg}$$

$$v_s = 85.49 \times C_P \times (Sq.Rt.dP) \times [Sq.Rt.(T_s + 460) / (M_s \times P_s)] \dots = 40.21 \text{ ft/sec}$$

$$Q_s = v_s \times A_s \times 60 \dots = 256,043 \text{ acf/min}$$

$$Q_s(\text{std}) = Q_s \times (1 - B_{ws}) \times ((T_{\text{std}} + 460) / (T_s + 460)) \times (P_s / 29.92) \dots = 54,669 \text{ dscf/mi}$$

$$I = (T_s + 460) \times [(0.002669 \times V_{lc}) + (V_m(\text{std}) / (T_{\text{std}} + 460) / 29.92)] \times 100 / (\text{Time} \times P_s \times A_n \times v_s \times 60) = \%$$

EMISSION RATE CALCULATIONS

PLANT : BFI ARBOR HILLS
SOURCE : FLARE OUTLET

Temp. Std. : 68 dF
Press. Std.: 29.92 in. Hg. 3 % O2 Correction

Run No.	1	2	AVERAGE
Date	9/23/92	9/23/92	
Oxygen (%)	11.03	11.15	11.09
Qs(std), dscfm	49,935	47,706	48,821
NOx, ppm	19.04	18.20	18.62
SO2, ppm			84.22
CO, ppm	73.06	95.37	
HC, ppm			8388.01
F-Factor	8388.01	8388.01	

NOx, MW = 46.005			
NOx, lb/hr	6.81	6.22	6.52
NOx, ppm @ O2	34.53	33.41	33.97
NOx, lb/MMBtu	0.0404	0.0391	0.0397

SO2, MW = 64.058
SO2, lb/hr
SO2, ppm @ O2
SO2, lb/MMBtu

CO, MW = 28.010			
CO, lb/hr	15.91	19.84	17.87
CO, ppm @ O2	132.50	175.09	153.79
CO, lb/MMBtu	0.0944	0.1247	0.1096

HC, MW = 16.043
HC, lb/hr
HC, ppm @ O2
HC, lb/MMBtu

$$* \text{ lb/hr} = 8.223\text{E-}5 \times \text{Qs(std)} \times \text{MW} \times \text{ppm} / (\text{Tstd} + 460)$$

$$* \text{ ppm @ O2} = \text{ppm measured} \times [(20.9 - 02\% \text{ correction}) / (20.9 - \% \text{O2 measured})]$$

$$* \text{ lb/MMBtu} = \text{F-Factor} \times \text{MW} \times [1.3711\text{E-}6 / (\text{Tstd} + 460)] \times [20.9 / (20.9 - 02\%)] \times \text{ppm}$$

$$* \text{ lb/Bbl} = (\text{lb/MMBtu}) \times (\text{MMBtu/Bbl})$$

EMISSION RATE CALCULATIONS

PLANT : BFI ARBOR HILLS
SOURCE : FLARE OUTLET

Temp. Std. : 68 dF
Press. Std.: 29.92 in. Hg. 3 % O2 Correction

Run No.	3	4	AVERAGE
Date	9/24/92	9/24/92	
Oxygen (%)	10.85	10.80	10.83
Qs(std), dscfm	49,403	47,420	48,412
NOx, ppm	17.42	18.44	17.93
SO2, ppm			
CO, ppm	69.36	14.31	41.84
HC, ppm	28.80	16.40	22.60
F-Factor	8386.65	8386.65	8386.65

NOx, MW = 46.005			
NOx, lb/hr	6.17	6.26	6.21
NOx, ppm @ O2	31.03	32.68	31.85
NOx, lb/MMBtu	0.0363	0.0382	0.0373

SO2, MW = 64.058
SO2, lb/hr
SO2, ppm @ O2
SO2, lb/MMBtu

CO, MW = 28.010			
CO, lb/hr	14.94	2.96	8.95
CO, ppm @ O2	123.54	25.36	74.45
CO, lb/MMBtu	0.0880	0.0181	0.0530

HC, MW = 16.043			
HC, lb/hr	3.55	1.94	2.75
HC, ppm @ O2	51.30	29.07	40.18
HC, lb/MMBtu	0.0209	0.0119	0.0164

* $\text{lb/hr} = 8.223\text{E-}5 \times Qs(\text{std}) \times MW \times \text{ppm} / (T_{\text{std}} + 460)$

* $\text{ppm @ O2} = \text{ppm measured} \times [(20.9 - \text{O2\% correction}) / (20.9 - \text{O2\% measured})]$

* $\text{lb/MMBtu} = F\text{-Factor} \times MW \times [1.3711\text{E-}6 / (T_{\text{std}} + 460)] \times [20.9 / (20.9 - \text{O2\%})] \times \text{ppm}$

* $\text{lb/Bbl} = (\text{lb/MMBtu}) \times (\text{MMBtu/Bbl})$

EMISSION RATE CALCULATIONS

PLANT : BFI ARBOR HILLS
SOURCE : FLARE OUTLET

Temp. Std. : 68 dF
Press. Std.: 29.92 in. Hg. 3 % O2 Correction

Run No.	5	6	AVERAGE
Date	9/24/92	9/24/92	
Oxygen (%)	11.45	12.09	11.77
Qs(std), dscfm	53,219	54,669	53,944
NOx, ppm	14.92	11.69	13.31
SO2, ppm			
CO, ppm	91.07	394.29	242.68
HC, ppm	23.50		23.50
F-Factor	8323.36	8323.36	8323.36

NOx, MW = 46.005			
NOx, lb/hr	5.69	4.58	5.13
NOx, ppm @ O2	28.26	23.75	26.01
NOx, lb/MMBtu	0.0328	0.0276	0.0302

SO2, MW = 64.058
SO2, lb/hr
SO2, ppm @ O2
SO2, lb/MMBtu

CO, MW = 28.010			
CO, lb/hr	21.13	94.00	57.57
CO, ppm @ O2	172.50	801.11	486.81
CO, lb/MMBtu	0.1219	0.5663	0.3441

HC, MW = 16.043			
HC, lb/hr	3.12		3.12
HC, ppm @ O2	44.51		44.51
HC, lb/MMBtu	0.0180		0.0180

* $\text{lb/hr} = 8.223\text{E-}5 \times \text{Qs(std)} \times \text{MW} \times \text{ppm} / (\text{Tstd} + 460)$

* $\text{ppm @ O2} = \text{ppm measured} \times [(\text{20.9} - \text{O2\% correction}) / (\text{20.9} - \text{\%O2 measured})]$

* $\text{lb/MMBtu} = \text{F-Factor} \times \text{MW} \times [1.3711\text{E-}6 / (\text{Tstd} + 460)] \times [20.9 / (\text{20.9} - \text{O2\%})] \times \text{ppm}$

* $\text{lb/Bbl} = (\text{lb/MMBtu}) \times (\text{MMBtu/Bbl})$

HCl CALCULATIONS

COMPANY NAME : BFI ARBOR HILLS
 SOURCE : FLARE OUTLET
 DATE : SEPT 24, 1992
 O2 CORRECTION: 3 %

TEMP. STD. :

68 dF

	Run 3	Run 4	Blank
Tm, dF	90.94	97.17	94.06
Y, meter fac.	1.0098	1.0098	1.0098
Vm, cu.ft. ..	63.114	63.132	63.123
Pb, in.Hg. ..	29.33	29.31	29.32
dH, in.H2O ..	2.50	2.50	2.50
O2, percent .	10.85	10.80	10.83
Qs(std), dscfm	49,403	47,420	48,412
F-Factor	8,386.65	8,386.65	8,386.65

$$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) :$$

	Run 3	Run 4	Blank
Vm(std)	60.2497	59.5526	59.8986

dscf

LABORATORY ANALYSIS :

	Run 3	Run 4	Blank
mg HCl	17.01	15.93	0.10
* MW of HCl	36.46		

EMISSION CALCULATIONS :

$$ppm \text{ HCl} = 1.60982 \times (\text{Temp.Std.} + 460) \times (\text{mg HCl}) / (\text{MW} \times Vm, \text{std})$$

$$ppm \text{ HCl @ corrected O2\%} = ppm \text{ HCl} \times [20.9 - \text{O2 correction} / (20.9 - \%O2 \text{ measured})]$$

$$lb/hr = 8.223e-5 \times Qs(std) \times MW \times ppm / (Tstd + 460)$$

$$lb/MMBTU = F\text{-Factor} \times MW \times 0.00000137 / [Tstd + 460] \times [20.9 / (20.9 - \%O2)] \times ppm \text{ HCl}$$

	Run 3	Run 4	Blank
ppm HCl	6.58	6.24	0.04
ppm HCl @ 3.0 %O2	11.72	11.05	0.07
lb/hr HCl	1.85	1.68	0.01
lb/MMBTU HCl	0.0109	0.0102	0.0001

Cl2 CALCULATIONS

COMPANY NAME : BFI ARBOR HILLS
 SOURCE : FLARE OUTLET
 DATE : SEPT 24, 1992
 O2 CORRECTION: 3 %

TEMP. STD. : 68 dF

	Run 3	Run 4	Blank
Tm, dF	90.94	97.17	94.06
Y, meter fac.	1.0098	1.0098	1.0098
Vm, cu.ft. ..	63.114	63.132	63.123
Pb, in.Hg. ..	29.33	29.31	29.32
dH, in.H2O ..	2.50	2.50	2.50
O2, percent .	10.85	10.80	10.83
Qs(std), dscfm	49,403	47,420	48,412
F-Factor	8,386.65	8,386.65	8,386.65

$$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) :$$

	Run 3	Run 4	Blank	
Vm(std)	60.2497	59.5526	59.8986	dscf

LABORATORY ANALYSIS :

	Run 3	Run 4	Blank
mg Cl2	0.05	0.05	0.05
* MW of HCl	70.91		

EMISSION CALCULATIONS :

$$ppm \text{ Cl2} = 1.60982 \times (Temp.Std. + 460) \times (mg \text{ Cl2}) / (MW \times Vm, std)$$

$$ppm \text{ Cl2 @ corrected O2\%} = ppm \text{ Cl2} \times [20.9 - O2 \text{ correction} / (20.9 - \%O2 \text{ measured})]$$

$$lb/hr = 8.223e-5 \times Qs(std) \times MW \times ppm / (Tstd + 460)$$

$$lb/MMBTU = F-Factor \times MW \times 0.00000137 / [Tstd + 460] \times [20.9 / (20.9 - \%O2)] \times ppm \text{ Cl2}$$

	Run 3	Run 4	Blank
ppm Cl2	0.01	0.01	0.01
ppm Cl2 @ 3.0 %O2	0.02	0.02	0.02
lb/hr Cl2	0.01	0.01	0.01
lb/MMBTU Cl2	0.00003	0.00003	0.00003

SO2 CALCULATIONS

COMPANY NAME : BFI ARBOR HILLS
SOURCE : FLARE OUTLET
DATE : SEPT 25, 1992
O2 CORRECTION: 3 %

TEMP.STD. :

68 dF

	Run 5	Run 6	Blank
Tm, dF	98.60	101.75	100.18
Y, meter fac.	1.0098	1.0098	1.0098
Vm, cu.ft. ..	63.313	62.871	63.092
Pb, in.Hg. ..	29.21	29.14	29.18
dH, in.H2O ..	2.50	2.50	2.50
O2, percent .	11.45	12.09	11.77
Qs(std), dscfm	53,219	54,669	53,944
F-Factor	8,323.36	8,323.36	8,323.36

$$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) :$$

	Run 5	Run 6	Blank	
Vm(std)	59.3685	58.4838	58.9341	dscf

LABORATORY ANALYSIS :

	Run 5	Run 6	Blank
mg SO2	14.19	13.69	0.20
* MW of SO2	64.06		

EMISSION CALCULATIONS :

$$ppm SO2 = 1.60982 \times (Temp.Std. + 460) \times (mg SO2) / (MW \times Vm, std)$$

$$ppm SO2 @ corrected O2\% = ppm SO2 \times [20.9 - O2 correction / (20.9 - \%O2 measured)]$$

$$lb/hr = 8.223e-5 \times Qs(std) \times MW \times ppm / (Tstd + 460)$$

$$lb/MMBTU = F-Factor \times MW \times 0.00000137 / [Tstd + 460] \times [20.9 / (20.9 - \%O2)] \times ppm SO2$$

	Run 5	Run 6	Blank
ppm SO2	3.17	3.11	0.05
ppm SO2 @ 3.0 %O2	6.01	6.31	0.09
lb/hr SO2	1.68	1.69	0.02
lb/MMBTU SO2	0.0097	0.0102	0.0001

S03 CALCULATIONS

COMPANY NAME : BFI ARBOR HILLS
 SOURCE : FLARE OUTLET
 DATE : SEPT 25,1992
 O2 CORRECTION: 3 %

TEMP.STD. :

68 dF

	Run 5	Run 6	Blank
Tm, dF	98.60	101.75	100.18
Y, meter fac.	1.0098	1.0098	1.0098
Vm, cu.ft. ..	63.313	62.871	63.092
Pb, in.Hg. ..	29.21	29.14	29.18
dH, in.H2O ..	2.50	2.50	2.50
O2, percent .	11.45	12.09	11.77
Qs(std), dscfm	53,219	54,669	53,944
F-Factor	8,323.36	8,323.36	8,323.36

$$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) :$$

	Run 5	Run 6	Blank	
Vm(std)	59.3685	58.4838	58.9341	dscf

LABORATORY ANALYSIS :

	Run 5	Run 6	Blank
mg SO3	2.59	3.80	0.72
* MW of SO3	80.06		

EMISSION CALCULATIONS :

$$ppm SO3 = 1.60982 \times (Temp.Std. + 460) \times (mg SO3) / (MW \times Vm,std)$$

$$ppm SO3 @ corrected O2\% = ppm SO3 \times [20.9 - O2 correction / (20.9 - \%O2 measured)]$$

$$lb/hr = 8.223e-5 \times Qs(std) \times MW \times ppm / (Tstd + 460)$$

$$lb/MMBTU = F-Factor \times MW \times 0.00000137 / [Tstd + 460] \times [20.9 / (20.9 - \%O2)] \times ppm SO3$$

	Run 5	Run 6	Blank
ppm SO3	0.46	0.69	0.13
ppm SO3 @ 3.0 %O2	0.88	1.40	0.25
lb/hr SO3	0.31	0.47	0.09
lb/MMBTU SO3	0.0018	0.0028	0.0005

FUEL/FLOWRATE CALCULATIONS

PLANT BFI ARBOR HILLS
 SOURCE FLARE OUTLET Temp. Std.: 68
 DATE SEPT 24,25,1992 Press. Std: 29.92

FUEL FLOWRATE DATA :

	RUN3	RUN 4	RUN 5
Barometric Press., in.Hg..			
Brake Horsepower			
Fuel Flow, scfh	298200.00	293580.00	298920.00
Oxygen, %	10.85	10.80	11.45
Fuel Flow, acfh			
Fuel Press, psig			
" " psia			
Fuel Temp, dF			

FUEL ANALYSIS DATA :

	RUN 3	RUN 4	RUN 5
Btu/scf, Gross Cal. Value:	538.00	538.00	575.00
Btu/lb, Gross Cal. Value :	8149.00	8149.00	8798.00
Hydrogen, Wt.% :	7.71	7.71	8.27
Carbon, Wt.% :	39.62	39.62	42.35
Sulfur, Wt.% :	0.00	0.00	0.00
Nitrogen, Wt.% :	6.48	6.48	1.75
Oxygen, Wt.% :	46.19	46.19	47.64

CALCULATIONS :

	RUN 3	RUN 4	RUN 5	AVERAGE
F-Factor, dscf/MMBtu :	8,386.65	8,386.65	8,323.36	8,365.55
Fuel Rate, scfh :	298200.00	293580.00	298920.00	296900.00
Heat Rate, MMBtu/hr :	160.432	157.946	171.879	163.419
Flue gas flowrate, dscfm :	46634.51	45684.72	52733.27	48350.83

$$* \text{ F-Factor} = 10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(T_{std} + 460) / 528]$$

$$* \text{ scfh} = \text{fuel acfh} \times [P_b + (P, \text{psig} \times 2.036 \text{ in.Hg/psi}) / (T \text{ fuel} + 460)] \times [(T_{std} + 460) / P_{std}]$$

where: psig = psia - 14.7

$$* \text{ MMBtu/hr} = \text{scfh} \times (\text{Btu/scf}) / 10E6$$

$$* \text{ dscfm} = \text{MMBtu/hr} \times \text{dscf/MMBtu} \times (1\text{hr}/60\text{min}) \times [20.9 / (20.9 - \%O_2)]$$

DRY GAS METER / ORIFICE METER CALIBRATION DATA

DateAUGUST 25 1992
 Bar. Press. in.Hg 29.89
 Meter Box No. ...CRATE LOW

Dry Gas Meter No. ... 6825355
 Standard Test Meter # 69279
 Operator AB

STANDARD TEST METER			DRY TEST METER				Time t (min)
Press. dHs (in. H2O)	Temp. Ts (dF)	Volume Vs (ft3)	Sample Rate (cfm)	Temp. Tdi (dF)	Temp. Tdo (dF)	Volume Vd (ft3)	
	0.0	0.000		0	0	0.000	
0.0	0.0	0.000	0.010	0	0	0.000	0.0
Avg/Net :	0.0	0.000			0	0.000	
	82.0	485.012		88	87	10.017	
0.0	81.0	480.143	0.035	85	85	5.016	217.0
Avg/Net :	81.5	4.869			86	5.001	
	79.0	476.262		92	86	1001.015	
-0.2	78.0	471.191	0.100	87	85	995.781	53.0
Avg/Net :	78.5	5.071			88	5.234	
	0.0	0.000		0	0	0.000	
0.0	0.0	0.000		0	0	0.000	0.0
Avg/Net :	0.0	0.000			0	0.000	
	0.0	0.000		0	0	0.000	
0.0	0.0	0.000		0	0	0.000	0.0
Avg/Net :	0.0	0.000			0	0.000	

$$y = V_s \times (P_{bar} + (dHs / 13.6)) \times (Avg. Td + 460) / [V_d \times (P_{bar} + (dH / 13.6)) \times (Ts + 460)]$$

$$K_o = [(V_s/t) \times [(Tdo + 460) / (Ts + 460)] \times [(P_{bar} + (dHs/13.6)) / (P_{bar} + (dH/13.6))] / [((Tdo + 460) \times dH) / (P_{bar} + (dH/13.6))] \times (Mm)]^{0.5}$$

cfm :	0.010	0.035	0.100		Avg.	Std.Dev.
y :		0.9821	0.9843		0.9832	

Ko :

y : % Relative Std. Dev.

Ko : % Relative Std. Dev.

DRY GAS METER / ORIFICE METER CALIBRATION DATA

DateJULY 20 1992
 Bar. Press. in.Hg 29.88
 Meter Box No. ... 21313

Dry Gas Meter No. ... 103707
 Standard Test Meter # 69279
 Operator AB

STANDARD TEST METER			DRY TEST METER				Time t (min)
Press. dHs (in. H2O)	Temp. Ts (dF)	Volume Vs (ft3)	Press. dH (in. H2O)	Temp. Tdi (dF)	Temp. Tdo (dF)	Volume Vd (ft3)	
-1.4	68.0	391.523	0.5	83	82	1020.297	54.0
	67.0	368.346		82	81	996.854	
Avg/Net :	67.5	23.177			82	23.443	
-2.3	68.0	367.739	1.0	81	80	996.234	40.0
	67.0	344.170		80	79	972.482	
Avg/Net :	67.5	23.569			80	23.752	
-2.5	67.0	265.627	1.5	80	79	894.385	38.0
	67.0	237.624		78	79	866.307	
Avg/Net :	67.0	28.003			79	28.078	
-3.8	67.0	299.374	2.0	79	80	928.127	42.0
	68.0	266.025		78	79	894.793	
Avg/Net :	67.5	33.349			79	33.334	
-5.4	67.0	343.531	3.0	80	79	971.849	42.0
	66.0	301.895		78	78	930.627	
Avg/Net :	66.5	41.636			79	41.222	

$$y = V_s \times (P_{bar} + (dH_s / 13.6)) \times (Avg. T_d + 460) / [V_d \times (P_{bar} + (dH / 13.6)) \times (T_s + 460)]$$

$$K_o = [(V_s/t) \times [(T_{do} + 460) / (T_s + 460)] \times [(P_{bar} + (dH_s/13.6)) / (P_{bar} + (dH/13.6))] / [((T_{do} + 460) \times dH) / (P_{bar} + (dH/13.6))] \times (Mm)]^{0.5}$$

dH :	0.5	1.0	1.5	2.0	3.0	Avg.	Std.Dev.
y :	1.0111	1.0076	1.0100	1.0077	1.0123	1.0098	0.0019
Ko :	0.7845	0.7580	0.7735	0.7187	0.7295	0.7528	0.0252
y :	0.18 % Relative Std. Dev.						
Ko :	3.34 % Relative Std. Dev.						



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (714) 653-6780 • FAX (714) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

STEI01

TO:

SUE POWERS
STEINER ENVIRONMENTAL
4930 BOYLAN ST
BAKERSFIELD, CA 93308-

RECEIVED AUG 28 1992

DATE : 08/20/92

CUSTOMER ORDER NUMBER: SP-2750-90 R.69

PAGE 1

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA	
CYLINDER NO.:	CC28672					
Nitric Oxide	786 + 8 ppm	GMIS	Monitor Labs Model 8448 S/N 136	82/28/94	88/11/92 785 ppm	88/28/92 787 ppm
NOx	786 ppm	Cylinder #	Continuous		784 ppm	786 ppm
Nitrogen, O2-Free Balance		CC78162	Chemiluminescence		784 ppm	785 ppm
Cylinder Pressure: 2000 psig		@ 1824 ppm	Last Cal Date: 06/02/92	Mean: 785 ppm	786 ppm	
CYLINDER NO.:	CC389					
Nitric Oxide	39.6 + 0.4 ppm	GMIS	Monitor Labs Model 8448 S/N 136	82/18/94	88/11/92 39.5 ppm	88/18/92 39.7 ppm
NOx	39.6 ppm	Cylinder #	Continuous		39.7 ppm	39.6 ppm
Nitrogen, O2-Free Balance		CC65317	Chemiluminescence		39.4 ppm	39.5 ppm
Cylinder Pressure: 2000 psig		@ 48.2 ppm	Last Cal Date: 06/02/92	Mean: 39.5 ppm	39.6 ppm	

ppm = umole/mole

% = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.

Analyst:

B.E. Gross

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
TELEPHONE (714) 784-1240

REPORT OF ANALYSIS

EPA PROTOCOL GAS MIXTURES

STEI01

TO:

SUE POWERS
STEINER ENVIRONMENTAL, INC.
4930 BOYLAN ST.
BAKERSFIELD, CA 93308

DATE : 04/18/91

CUSTOMER ORDER NUMBER: SP2750-90REL.17

PAGE 1

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.: CC51313					
Sulfur Dioxide	965 ± 10 ppm	GMIS	Interscan Model RM2450P S/N 72138	10/16/92	84/08/91 84/16/91 976 ppm 963 ppm
Nitrogen	Balance	Cylinder #	Electrochemical		961 ppm 968 ppm
Cylinder Pressure: 2000 psig		CC12074	Gas Chromatography		971 ppm 949 ppm
		@ 1889 ppm	Last Cal Date: 05/18/91	Mean: 969 ppm	968 ppm
CYLINDER NO.: CC28837					
Sulfur Dioxide	3030 ± 30 ppm	SM 1664	Interscan Model RM2450P S/N 72138	10/17/92	84/08/91 84/17/91 3060 ppm 2986 ppm
Nitrogen	Balance	Cylinder #	Electrochemical		3010 ppm 3030 ppm
Cylinder Pressure: 2000 psig		FF1483	Gas Chromatography		3050 ppm 3010 ppm
		@ 2515 ppm	Last Cal Date: 05/18/91	Mean: 3040 ppm	3010 ppm
CYLINDER NO.: CC72048					
Nitric Oxide	1039 ± 10 ppm	GMIS	Monitor Labs Model 8448 S/N 136	10/17/92	84/09/91 84/17/91 1038 ppm 1039 ppm
NOx	1039 ppm	Cylinder #	Continuous		1040 ppm 1036 ppm
Nitrogen, O2-Free Balance		CC78162	Chemiluminescence		1049 ppm 1029 ppm
Cylinder Pressure: 2000 psig		@ 1020 ppm	Last Cal Date: 03/11/91	Mean: 1039 ppm	1038 ppm

$$\text{ppm} = \text{umole/mole}$$

t = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.

Analyst:

Steve Kozl

S.B. Kozy

Approved:

J.T. Marri

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
TELEPHONE (714) 784-1240

REPORT OF ANALYSIS
NIST TRACEABLE GAS MIXTURES

PAPE01

TO:

SUE POWERS
PAPE & STEINER
5801 NORRIS ROAD
BAKERSFIELD, CA 93308

DATE: 10/09/90

CUSTOMER ORDER NUMBER: BL-SP275090REL7

PAGE 1

XX

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC86353	Carbon Dioxide Nitrogen	41.2 ± 0.4 % Balance	VOLUMETRIC
CC56538	Carbon Monoxide Carbon Dioxide Oxygen Nitrogen	381 ± 4 ppm 15.63 ± 0.16 % 3.81 ± 0.04 % Balance	SRM 1680b SRM 1675b SRM 2658a
CC83071	Carbon Monoxide Carbon Dioxide Oxygen Nitrogen	384 ± 4 ppm 15.77 ± 0.16 % 3.81 ± 0.04 % Balance	SRM 1680b SRM 1675b SRM 2658a

ppm = umole/mole

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above.

Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

Analyst:

Mark Monson

M.J. Monson

Approved:

J.T. Marrin

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

REPORT OF ANALYSIS
EPA PROTOCOL GAS MIXTURES

STEI01

TO:

SUE POWERS
STEINER ENVIRONMENTAL INC
4930 BOYLAN STREET
BAKERSFIELD, CA 93308

DATE : 03/26/91

CUSTOMER ORDER NUMBER: SP-2750-90REL17

PAGE 1

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.:	CC81181				
Carbon Monoxide	10430 ± 104 ppm	GMIS	Carle Insts Model 8800 S/N 8249	09/21/92	03/05/91 03/21/91 10410 ppm 10420 ppm
Nitrogen	Balance	Cylinder # FF17326	Methanation/FID Gas Chromatography		10360 ppm 10540 ppm 10340 ppm 10490 ppm
Cylinder Pressure:	2000 psig	@ 9860 ppm	Last Cal Date: 01/02/91	Mean:	10370 ppm 10490 ppm

ppm $\hat{=}$ umole/mole % = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.


Analyst: Mark Monson
M.J. Monson


Approved: J.T. Marrin
J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

APPENDIX C
FLARE OPERATING DATA





APPENDIX D


AtmAA, INC. ANALYTICAL DATA



AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services



December 3, 1992

LTR/489/92

Jim Steiner
Steiner Environmental
4930 Boylan Street
Bakersfield, CA 93308

re: Arbor Hills

Dear Jim:

Please find enclosed the laboratory analysis report, quality assurance summary, and the original chain of custody form for six Summa canister samples and six Tedlar bag samples received on September 28, 1992.

The samples were analyzed for selected components, permanent gases, total gaseous non-methane organics, hydrogen sulfide, and reduced sulfur compounds.


One of the Tedlar bags ID (#33761, Lab #92722-4) was received flat, without sufficient sample for testing.

Sincerely,

AtmAA, Inc.


Michael L. Porter
Laboratory Director

Encl.
MLP/krp

**AtMAA**

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services**LABORATORY ANALYSIS REPORT****Selected Volatile Organic Components Analysis
in Summa Canister Samples**

Report Date: October 7, 1992
Client: BFI/Steiner
Site: Arbor Hills
Date Received: September 28, 1992
Date Analyzed: September 28, & 29, 1992

AtmAA Lab No.:	92722-1	92722-3	92722-5	92722-7
Sample I.D.:	33758	33760	33766	33768
	Can 3	Can 3	Can 4	Can 4

Arg including cans

OUTLET INLET**Components:**

	(Concentration in %, v/v)		
Nitrogen	78.8	2.52	78.0
Oxygen	12.1	0.49	11.8
Methane		57.4	58.1
Carbon Dioxide	8.52	40.3	8.32

	(Concentration in ppm, v/v)		
Methane	17.1	3.86	
TGNMO	28.8	8610	16.4

	(Concentration in ppb, v/v)		
Benzene	5.46	954	1.94
Chlorobenzene	<0.3	706	<0.3
Ethylbenzene	0.43	18700	0.46
Toluene	0.81	69500	1.44
m + p xylenes	1.09	40800	0.86
o-xylene	0.76	15000	0.44
Vinyl Chloride	<0.1	6580	<0.1
1,1-dichloroethylene (vinylidene chloride)	<0.11	239	<0.11
Chloroform	<0.4	<5	<0.4
1,1,1-trichloroethane	<0.8	152	<0.8
1,2-dichloroethane	<0.2	271	<0.2
Carbon Tetrachloride	<0.3	<5	<0.3
Trichloroethylene	<0.8	4370	<0.8
Perchloroethylene	0.88	7740	0.62
Methylene chloride	<0.2	3550	<0.2
1,1-dichloroethane	<0.47	1590	<0.47

	ppm	ppm
	22.9	9230
	ppb	ppb
	3.41	930
	<0.15	715
	0.35	19100
	1.56	68933
	1.35	57000
	0.10	6590
	<0.11	240
	nd	nd
	<0.4	147
	<0.1	383
	nd	nd
	<0.4	4170
	0.87	7500
	<0.10	3103
	<0.16	1343

TGNMO is total gaseous non-methane organics measured and reported as ppm methane.

The reported oxygen concentration includes any argon present in the sample, calibration is based on a standard atmosphere containing 20.95% oxygen and 0.93% argon.

LABORATORY ANALYSIS REPORT

Selected Volatile Organic Components Analysis in Summa Canister Samples

Report Date: October 7, 1992
 Client: BFI/Steiner
 Site: Arbor Hills
 Date Received: September 28, 1992
 Date Analyzed: September 28, & 29, 1992
 AtmAA Lab No.: INLET 92722-9 OUTLET 92722-11
 Sample I.D.: 33789 33786

Can 5	Can 5
-------	-------

Components:

(Concentration in %, v/v)

Nitrogen	2.32	78.3
Oxygen	0.44	12.7
Methane	57.7	
Carbon Dioxide	40.4	8.01

(Concentration in ppm, v/v)


Methane		71.6
TGNMO	8090	23.5

(Concentration in ppb, v/v)

Benzene	841	2.82
Chlorobenzene	702	<0.3
Ethylbenzene	19000	<0.3
Toluene	67600	2.42
m + p xylenes	37800	0.74
o-xylene	13600	<0.3
Vinyl Chloride	6610	0.19
1,1-dichloroethylene	241	0.23
Chloroform	<5	<0.4
1,1,1-trichloroethane	148	<0.8
1,2-dichloroethane	538	<0.2
Carbon Tetrachloride	<5	<0.3
Trichloroethylene	4000	<0.8
Perchloroethylene	6980	1.11
Methylene chloride	2920	<0.2
1,1-dichloroethane	1180	<0.47

TGNMO is total gaseous non-methane organics measured and reported as ppm methane.

The reported oxygen concentration includes any argon present in the sample, calibration is based on a standard atmosphere containing 20.95% oxygen and 0.93% argon.


 Michael L. Porter
 Laboratory Director



QUALITY ASSURANCE SUMMARY
(Repeat Analysis)

Site: Arbor Hills

Component:	Sample ID	Repeat Analysis		Mean	% Diff.
		Run #1	Run #2	Conc.	From Mean
(Concentration in %, v/v)					
Nitrogen	33758	79.0	78.7	78.8	0.19
	33789	2.53	2.11	2.32	9.0
Oxygen	33758	12.1	12.1	12.1	0.0
	33789	0.47	0.42	0.44	5.6
Methane	33760	57.4	57.4	57.4	0.0
Carbon Dioxide	33758	8.60	8.44	8.52	0.94
	33760	40.4	40.2	40.3	0.25
(Concentration in ppm, v/v)					
TGNMO	33768	11100	11000	11000	0.45
(Concentration in ppb, v/v)					
Benzene	33760	952	955	954	0.16
	33786	3.18	2.45	2.82	13
Chlorobenzene	33760	628	784	706	11
	33786	<0.3	<0.3	—	—
Ethylbenzene	33760	17900	19500	18700	4.3
	33786	<0.3	<0.3	—	—
Toluene	33760	67700	71300	69500	2.6
	33786	2.47	2.36	2.42	2.3
m + p-xylenes	33760	40800	40800	40800	0.0
	33786	0.81	0.67	0.74	9.4
o-xylene	33760	13800	16300	15000	8.3
	33786	<0.3	<0.3	—	—
Vinyl chloride	33758	<0.1	<0.1	—	—
	33760	6570	6600	6580	0.23
	33786	0.21	0.17	0.19	10



QUALITY ASSURANCE SUMMARY

(Repeat Analysis)

(continued)

Component:	Sample ID	Repeat Analysis		Mean	% Diff.
		Run #1	Run #2	Conc.	From Mean
		(Concentration in ppb, v/v)			
1,1-dichloroethylene	33758	<0.11	<0.11	---	---
	33760	239	239	239	0.0
	33786	0.23	0.23	0.23	0.0
Chloroform	33789	<5	<5	---	---
1,1,1-trichloroethane	33789	146	150	148	1.4
1,2-dichloroethane	33758	<0.2	<0.2	---	---
	33789	568	509	538	5.5
Carbon Tetrachloride	33789	<5	<5	---	---
Trichloroethylene	33789	3990	4020	4000	0.37
Perchloroethylene	33758	0.82	0.93	0.88	6.3
	33768	7260	8290	7780	6.6
Methylene chloride	33789	2930	2920	2920	0.17
	33786	<0.2	<0.2	---	---
1,1-dichloroethane	33766	<0.47	<0.47	---	---
	33789	1190	1180	1180	0.42

A set of 6 Summa canister samples laboratory numbers, 92722-(1,3,5,7,9,11,) was analyzed for selected volatile organic components, permanent gases, and total gaseous non-methane organics (TGNMO). Agreement between repeat analyses is a measure of precision and is shown above in the column "% Difference from Mean." Repeat analyses are an important part of AtmAA's quality assurance program. The average % Difference from Mean for 28 repeat measurements from the sample set of 6 Summa canister samples is 3.5%.





AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services

LABORATORY ANALYSIS REPORT

Selected Volatile Sulfur Containing Components Analysis in Tedlar Bag Samples

Report Date: October 7, 1992
Client: BFI/Steiner
Site: Arbor Hills
Date Received: September 28, 1992
Date Analyzed: September 28, 1992

ANALYSIS DESCRIPTION

Hydrogen sulfide was analyzed by gas chromatography with a Hall electrolytic conductivity detector operated in the oxidative sulfur mode. Methyl mercaptan, ethyl mercaptan, dimethyl sulfide, carbon disulfide, dimethyl disulfide, and carbonyl sulfide were analyzed by GC/Mass Spec.

AtmAA Lab No.:	92722-2	92722-6	INLET 92772-8	92722-8
Sample I.D.:	33759	33767	33769	
	Bag 3	Bag 4	Bag 4	
Components:	(Concentration in ppm, v/v)			
				(repeat)
Hydrogen sulfide	< 0.5	< 0.5	20.7	20.4
Carbonyl sulfide	< 0.02	< 0.02	0.054	0.047
Methyl mercaptan	< 0.04	< 0.04	0.29	0.62
Ethyl mercaptan	< 0.03	< 0.03	0.051	0.11
Dimethyl sulfide	< 0.02	< 0.02	3.07	3.20
Carbon disulfide	< 0.006	< 0.006	0.092	0.093
Dimethyl disulfide	< 0.005	< 0.005	0.11	0.14

LABORATORY ANALYSIS REPORT

Selected Volatile Sulfur Containing Components Analysis in Tedlar Bag Samples

Report Date: October 7, 1992
Client: BFI/Steiner
Site: Arbor Hills
Date Received: September 28, 1992
Date Analyzed: September 28, 1992

ANALYSIS DESCRIPTION

Hydrogen sulfide was analyzed by gas chromatography with a Hall electrolytic conductivity detector operated in the oxidative sulfur mode. Methyl mercaptan, ethyl mercaptan, dimethyl sulfide, carbon disulfide, dimethyl disulfide, and carbonyl sulfide were analyzed by GC/Mass Spec.

AtmAA Lab No.:	92722-10	92722-12	92722-12
Sample I.D.:	33788	33786	
	INLET Bag 5	Bag 5	
Components:	(Concentration in ppm, v/v)		
			(repeat)
Hydrogen sulfide	20.4	<0.5	<0.5
Carbonyl sulfide	0.058	<0.02	<0.02
Methyl mercaptan	0.73	<0.04	<0.04
Ethyl mercaptan	0.13	<0.03	<0.03
Dimethyl sulfide	3.23	<0.02	<0.02
Carbon disulfide	0.093	0.014	0.0077
Dimethyl disulfide	0.11	<0.005	<0.005

Avg for bag 5 & 4
INLET OUTLET

20.6	10.2
0.056	<0.01
0.51	<0.02
0.09	<0.03
3.15	<0.02
0.093	0.0085
0.11	<0.0025

$$\text{Avg outlet} = \frac{2(0.006/2) + 0.014 + 0.0077}{4} = 0.0069$$

Michael L. Porter
Michael L. Porter
Laboratory Director



Date: 9/25/92Test Location: Flare Out/In

SAMPLE HANDLING/LOG-IN

NO	SAMPLE TYPE	VOLUME	COMMENTS
722-1 1	33758 <u>Can</u> <u>3</u> Meth Sample Test		Outlet
-2 2	33759 <u>Bag</u> <u>3</u> Meth Sample Test		Outlet
-3 3	33760 <u>Can</u> <u>3</u> Meth Sample Test		Inlet
-4 4	33761 <u>Bag</u> <u>3</u> Meth Sample Test		Inlet
-5 5	33766 <u>Can</u> <u>4</u> Meth Sample Test		Outlet
-6 6	33767 <u>Bag</u> <u>4</u> Meth Sample Test		Outlet
-7 7	33768 <u>Can</u> <u>4</u> Meth Sample Test		Inlet
-8 8	33769 <u>Bag</u> <u>4</u> Meth Sample Test		Inlet
9 9	33780 <u>Can</u> <u>5</u> Meth Sample Test		Inlet
0 10	33788 <u>Bag</u> <u>5</u> Meth Sample Test		Inlet
1 11	33787 <u>Can</u> <u>5</u> Meth Sample Test		Outlet
12 12	33786 <u>Bag</u> <u>5</u> Meth Sample Test		Inlet

Signature

Jim Steiner

CHAIN-OF-CUSTODY

Date/Time

9/26/92 11:00am

Signature

Karen J. Porter

Date/Time


9/28/92



AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services



October 28, 1992

LTR/428/92

John Steiner
Steiner Environmental
4950 Boylan Street
Bakersfield, CA 93308

re: Arbor Hills

Dear John:

Please find enclosed the reported values for permanent gases, methane, and total gaseous non-methane organics in Summa canister samples received from Arbor Hills Landfill on September 28, 1992.

Sincerely,

AtmAA, Inc.

Michael L. Porter
Laboratory Director

Encl.
MLP/krp



AtmAA Inc.

21354 Nordhoff St., Suite 113, Chatsworth, CA 91311 (818) 718-6070 • FAX (818) 718-9779

environmental consultants
laboratory services

LABORATORY ANALYSIS REPORT

Permanent Gases Analysis in Summa Canister Samples

Report Date: October 7, 1992
Client: BFI/Steiner
Site: Arbor Hills
Date Received: September 28, 1992
Date Analyzed: September 28, & 29, 1992

ANALYSIS DESCRIPTION

Nitrogen, oxygen, methane, and carbon dioxide were analyzed by thermal conductivity detection/gas chromatography (TCD/GC). Methane and TGNMO reported in ppm was analyzed by flame ionization detection\total combustion analysis portion (FID/TCA).

AtmAA Lab No.:	92722-1	92722-3	92722-5	92722-7
Sample I.D.:	33758	33760	33766	33768
	Can 3	Can 3	Can 4	Can 4
<u>Components:</u>	(Concentration in %, v/v)			
Nitrogen	78.8	2.52	78.0	2.30
Oxygen	12.1	0.49	11.8	0.46
Methane		57.4		58.1
Carbon Dioxide	8.52	40.3	8.32	41.0
	(Concentration in ppm, v/v)			
Methane	17.1		3.86	
TGNMO	28.8	8610	16.4	11000

TGNMO is total gaseous non-methane organics measured and reported as ppm methane.

The reported oxygen concentration includes any argon present in the sample, calibration is based on a standard atmosphere containing 20.95% oxygen and 0.93% argon.

LABORATORY ANALYSIS REPORT

Permanent Gases Analysis in Summa Canister Samples

Report Date: October 7, 1992
Client: BFI/Steiner
Site: Arbor Hills
Date Received: September 28, 1992
Date Analyzed: September 28, & 29, 1992


ANALYSIS DESCRIPTION

Nitrogen, oxygen, methane, and carbon dioxide were analyzed by thermal conductivity detection/gas chromatography (TCD/GC). Methane and TGNMO reported in ppm was analyzed by flame ionization detection\total combustion analysis portion (FID/TCA).

AtmAA Lab No.:	92722-9	92722-11
Sample I.D.:	33789	33786
	Can 5	Can 5
Components:	(Concentration in %, v/v)	
Nitrogen	2.32	78.3
Oxygen	0.44	12.7
Methane	57.7	
Carbon Dioxide	40.4	8.01
	(Concentration in ppm, v/v)	
Methane		71.6
TGNMO	8090	23.5

TGNMO is total gaseous non-methane organics measured and reported as ppm methane.

The reported oxygen concentration includes any argon present in the sample, calibration is based on a standard atmosphere containing 20.95% oxygen and 0.93% argon.


Michael L. Porter
Laboratory Director

