



**MOSTARDI-PLATT
ASSOCIATES, INC.**

Environmental Contract
Engineering Services

1077 Entry Drive
Bensenville, IL 60106
(312) 860-5900

CID, 8/89

LFG EFD AP42


Rating = BC
Lack of process data
emission calc.

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

GASEOUS EMISSION STUDY
PERFORMED FOR
WASTE MANAGEMENT OF NORTH AMERICA, INC.
CID ENVIRONMENTAL COMPLEX GAS
RECOVERY FACILITY
CHICAGO, ILLINOIS
CENTAUR UNITS 1, 2, 3
AUGUST 8, 1989

PROJECT NO. 92008
DATE SUBMITTED: AUGUST 25, 1989



EXECUTIVE SUMMARY

INTRODUCTION

MOSTARDI-PLATT ASSOCIATES, INC. (MPA) was retained by Waste Management of North America to perform carbon monoxide (CO) study at the CID Environmental Complex in Chicago, Illinois. This test program was authorized by and performed for Waste Management, Inc.

The purpose of this test program was to determine carbon monoxide emissions on each of three Solar Turbines during normal operations with test performance at the stack locations.

These tests were conducted by Messrs. G.M. Gozzi, K. Dyra and P. Schwalbach of MPA. Messrs. Gary Stuenkel and Joseph Gentile of Waste Management CID provided assistance and coordinated plant operating conditions during this test program.

SUMMARY OF RESULTS

On August 8, 1989, three one-hour carbon monoxide emission tests were performed on each of three stacks. The following readings were measured:

<u>Unit No.</u>	1	2	3	<u>Avg</u>
CO ppm	33.13	33.83	29.83	32.26 ppm
CO lbs/hr	3.897	3.937	3.437	3.757 lbs/hr

A complete summary is tabulated and can be found on page 3.



**MOSTARDI-PLATT
ASSOCIATES, INC.**

TEST PROCEDURES

All testing, sampling, analytical and calibration procedures used for this test program were performed as described in the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 10 and the latest revisions thereof.

Appendices

Test Location Diagram
Field Test Data
CO Analysis
Calibration Data
Operational Data
Horiba Monitor Description

Respectfully submitted,
MOSTARDI-PLATT ASSOCIATES, INC.


Graziano Gozzi
Graziano Gozzi - Project Supervisor



**MOSTARDI-PLATT
ASSOCIATES, INC.**

WASTE MANAGEMENT
CID Landfill Facility
August 8, 1989

	<u>Test No.</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
Unit 1	CO emissions				
	ppm	32.9	31.8	34.7	33.13
	ppm @ 15% O ₂	43.14	41.69	41.78	42.20
	lbs/dscf x 10 ⁻⁶	2.39	2.31	2.52	2.407
	lbs/hr	3.87	3.74	4.08	3.897
	tons/yr				17.07
	(365 days)				
	O ₂ %	16.4	16.4	16.0	16.27
	DSCFM	26974			26974
Unit 2	CO emissions				
	ppm	34.8	34.9	31.8	33.83
	ppm @ 15% O ₂	42.8	43.8	44.7	43.77
	lbs/dscf x 10 ⁻⁶	2.53	2.54	2.31	2.46
	lbs/hr	4.05	4.06	3.70	3.937
	tons/yr				17.24
	(365 days)				
	O ₂ %	16.1	16.2	16.2	16.33
	DSCFM	26662			26662
Unit 3	CO emissions				
	ppm	28.9	30.4	30.2	29.83
	ppm @ 15% O ₂	33.43	34.49	36.36	34.76
	lbs/dscf x 10 ⁻⁶	2.10	2.21	2.19	2.167
	lbs/hr	3.33	3.50	3.48	3.437
	tons/yr				15.05
	(365 days)				
	O ₂ %	15.8	15.7	16.0	15.83
	DSCFM	26429			26429



EAST
↑
Compass
Direction

(Percent of stack diameter from inside wall to traverse point)													Traverse point number on a diameter												
													1.1	24											
													3.2	23											
													1.1	5.5	22										
													3.5	7.9	21										
													1.3	6.0	10.5	20									
													3.9	8.7	13.2	19									
													1.4	6.7	11.6	16.1	18								
													4.4	9.7	14.6	19.4	17								
													1.6	7.5	12.9	18.0	23.0	16							
													4.9	10.9	16.5	21.8	27.2	15							
													1.8	8.5	14.6	20.4	26.1	32.3	14						
													5.7	12.5	18.8	25.0	31.5	39.8	13						
													2.1	9.9	16.9	23.6	30.6	39.3	60.2	12					
													6.7	14.6	22.0	29.6	38.8	60.7	67.7	11					
													2.5	11.8	20.1	28.3	38.2	61.2	68.5	72.8	10				
													8.2	17.7	26.9	37.5	61.8	69.4	73.9	77.0	9				
													3.3	14.6	25.0	36.6	62.5	70.4	75.0	78.2	80.6	8			
													10.5	22.6	35.5	63.4	71.7	76.4	79.6	82.0	83.9	7			
													4.4	19.4	34.2	64.5	73.1	78.0	81.2	83.5	85.4	86.8	6		
													14.7	32.3	65.8	75.0	79.9	83.1	85.4	87.1	88.4	89.5	5		
													6.7	29.5	67.7	77.4	82.3	85.4	87.5	89.1	90.3	91.3	92.1	4	
													25.0	70.5	80.6	85.4	88.2	90.1	91.5	92.5	93.3	94.0	94.5	3	
													14.6	75.0	85.3	89.5	91.8	93.3	94.3	95.1	95.6	96.1	96.5	96.8	2
													85.4	93.3	95.6	96.7	97.5	97.9	98.2	98.4	98.6	98.7	98.9	98.9	1
													2	4	6	8	10	12	14	16	18	20	22	24	
Number of traverse points on a diameter																									

JOB: Waste Management CID LANDFILL
 DATE: 8-8-89
 TEST NO. A11
 DUCT NO. TYPICAL of STACKS 1, 2, 3
 DUCT DIA. _____ ft. _____ ins.
 DUCT AREA _____ ft²
 NO. POINTS ACROSS DIA. _____

mostardi-platt associates, inc.



EQUAL AREA TRAVERSE

FOR ROUND DUCTS

SCALE:

DRAWN

APPROVED

mostardi-platt associates, i.



Date: 3-8-89

Monitor: Model

Serial No.

Orsat No.

Bag Type: TELDAR

Module No.

Rate Meter Units: L/MIN

Test (Run) No. 1/112771

Test(Run) No. 211447 /

[illegible]

ANALYSIS			
% By Volume (dry-basis)			
Total	CO ₂	O ₂	CO
Avg			

Train:

Bag:

Pipettes:

Burette:

Train:

Bag:

Pipettes:

Burette:

VALIDATION		
Fuel Factor (F_o)		Percent Difference
Orsat	Fuel	

[illegible]

ANALYSIS			
% By Volume (dry-basis)			
Total	CO ₂	O ₂	CO
Avg			

Train:

Bag:

Pipettes:

Burette:

Train:

Bag:

Pipettes:

Burette:

VALIDATION		
Fuel Factor (F_o)		Percent Difference
Orsat	Fuel	

Comments:

Operator:

$$F_o(\text{Orsat}) = \frac{20.9 - (x_{O_2} - 0.5 x_{CO})}{x_{CO_2} + x_{CO}}$$

$$F_o(\text{Fuel}) = \frac{0.209 F_d}{F_c} = \frac{0.651 (1.53 \text{ XC} + 3.64 \text{ XI}) + 0.57 \text{ XS} + 0.14 \text{ XM} - 0.46}{\text{XC}}$$

$$\% \text{ Difference} = \frac{F_o(\text{Orsat}) - F_o(\text{Fuel})}{F_o(\text{Fuel})} \times 100$$

mostardi-platt associates, inc.



Date: 8-8-84

Monitor: Model

Source Condition:

Fuel Type:

Serial No.

Module No. /

Rate Meter Units:

Orsat No.

Bag Type: TELDAR

Test (Run) No. 3/1017/

Test (Run) No.

[illegible][illegible]

VALIDATION		
Fuel Factor (F_o)		Percent Difference
Orsat	Fuel	

VALIDATION		
Fuel Factor (F_o)		Percent Difference
Orsat	Fuel	

Comments:

Operator:

$$F_o(\text{Orsat}) = \frac{20.9 - (x_{O_2} - 0.5 x_{CO})}{x_{CO_2} + x_{CO}}$$

$$F_o(Fuel) = \frac{0.209 F_d}{F_c} \cdot \frac{0.651 (1.53 \%C + 3.64 \%H + 0.57 \%S + 0.14 \%N - 0.46$$

$$\% \text{ Difference} = \frac{F_o(\text{Orsat}) - F_o(\text{Fuel})}{F_o(\text{Fuel})} \times 100$$

mostardi-platt associates, inc



Date: 8-8-89

Sampling Location: UNIT 2 STACK

Source Condition:

Monitor: Model

Fuel Type:

Serial No.

Module No.

Rate Meter Units: L/MUN

Qrsat No.

Bag Type: *TELDAIR*

Test(Run) No. 1/LIMIT 2

Test(Run) No. 2 UNIT 2

Burette:

Burette:

VALIDATION		
Fuel Factor (F_o)		Percent Difference
Orsat	Fuel	

Comments:

Operator:

$$F_o(\text{Orsat}) = \frac{20.9 - (x_{O_2} - 0.5 x_{CO})}{x_{CO_2} + x_{CO}}$$

$$F_o(\text{Fuel}) = \frac{0.209 F_d}{F_c} = \frac{0.651 (1.53 \text{ XC} + 3.64 \text{ XH} + 0.57 \text{ XS} + 0.14 \text{ XM} - 0.46 \text{ XO})}{\text{XC}}$$

$$\% \text{ Difference} = \frac{F_o(\text{Orsat}) - F_o(\text{Fuel})}{F_o(\text{Fuel})} \times 100$$

Date: 8-8-89

Source Condition:

Monitor: Model

Fuel Type:

Serial No.

Module No.

Rate Meter Units: L/MIN

Orsat No.

Bag Type: FE20AR

Test (Run) No. _____

Burette:Burette:

VALIDATION		
Fuel Factor (F_O)		Percent Difference
Orsat	Fuel	

Operator:

$$\% \text{ Difference} = \frac{F_o(\text{Orsat}) - F_o(\text{Fuel})}{F_o(\text{Fuel})} \times 100$$

mostardi-platt associates, inc.

39

Test(Run) No. | UNIT 3

Test (Run) No. 2 LIMIT 3

[illegible]

ANALYSIS			
% By Volume (dry-basis)			
Total	CO ₂	O ₂	CO
Avg			

Train:

Pipettes:

Burette:

Train:

Bag:

Pipettes:

Burette:

VALIDATION		
Fuel Factor (F_o)		Percent Difference
Orsat	Fuel	

[illegible]

ANALYSIS			
% By Volume (dry-basis)			
Total	CO ₂	O ₂	CO
Avg			

Train:

Bag:

Pipettes:

Burette:

Train:

Bảng:

Pipettes:

Burette:


VALIDATION		
Fuel Factor (F_o)		Percent Difference
Orsat	Fuel	

Operator:

$$F_o(\text{Orsat}) = \frac{20.9 \cdot (\%O_2 - 0.5 \%CO)}{\%CO_2 + \%CO}$$

$$F_o(\text{Fuel}) = \frac{0.209 F_d}{F_c} = \frac{0.651 (1.53 \text{ XC} + 3.64 \text{ XH} + 0.57 \text{ XS} + 0.14 \text{ XN} - 0.46 \text{ XO})}{\text{XC}}$$

$$\% \text{ Difference} = \frac{F_0(\text{Orsat}) - F_0(\text{Fuel})}{F_0(\text{Fuel})} \times 100$$



Bag Type: TELDAR

Fuel

Operator:.

$$\% \text{ Difference} = \frac{F_o(\text{Orsat}) - F_o(\text{Fuel})}{F_o(\text{Fuel})} \times 100$$



METHOD 10-CARBON MONOXIDE MONITOR

COMPANY Waste Management
 TEST LOCATION Units 1; 2, 3
STACK

PLANT CID
 DATE 8-8-89

TIME

CO MONITOR READING

STRIP CHART READING

CO₂/O₂

collected

Unit 3 Test no. 1				19.6	
	30	28.9	29	3.8	15.8
Test 2	30 (31.5)	30.4	31.5	3.6	15.7
Test 3	31.5	30.2	31.5	4.2	16.0
Unit 2					
Test 1	36	34.8	36	3.3	16.1
2	36	34.9		3.0	16.2
3	33	31.78		3.7	16.7
Unit 1	33.9	32.88		3.0	16.4
1	33.9	32.88		3.0	16.4
2	33.0	31.81		3.6	16.4
3	36	34.7		3.6	16.0

CALIBRATION-

Strip Chart Settings; Rate= _____ Input= 10 mv

Pre-Test


Reference Gas P.P.M.	Monitor Reading P.P.M.	Strip Chart Reading
279	271	93%
148	152	50%
90.4		
0	0	0

Post-Test

Reference Gas P.P.M.	Monitor Reading P.P.M.	Strip Chart Reading


REORDER 8377-01

PAI PARALLEL INSTRUMENT COMPANY INC. 1111 N. 1st St. St. Paul, MN 55101



REORDER 8377-01

PAI PARALLEL INSTRUMENT COMPANY INC. 1111 N. 1st St. St. Paul, MN 55101









FIGURE 217-01



RECORDS 8372.01



RECEIVED JUL 17 1989



Air Products and Chemicals, Inc.

INDUSTRIAL GAS DIVISION

Specialty Gas Department
12722 South Wentworth Avenue
Chicago, IL 60628
(312) 785-3000

ANALYTICAL REPORT

SAMPLE OF: 100 PPM CARBON MONOXIDE/ NITROGEN

DATE: 11/16/1987

PAGE: 1 of 1

SHIPPER NO.:

CUSTOMER ORDER NO.:

SAMPLE DATE:

REQUESTED BY:

REMARKS:

ANALYTICAL METHOD	ANALYST
Electrolytic Cell (O ₂ Trace)	
Infrared Horiba	
Ion Mobility for N ₂ in Ar	
Dew Point	
Hydrogen Flame Analyzer (THC)	
Wet Analysis	
Flame Photometer	

ANALYTICAL METHOD	ANALYST
Gas Chromatography	
Infrared Spectroscopy	
C.G. Flame Ionization Unit	X RM
Chemiluminescence	
Paramagnetic	
Gravimetric	

ANALYSIS

LAB NO.	CYL. NO.	COMPONENT REQUESTED	CONCENTRATION REQUESTED	ANALYTICAL RESULT	UNIT OF MEASURE
C7369	SG1085NB	CARBON MONOXIDE	100	90.4	MOLAR PPM

CERTIFICATION

This analysis has been performed utilizing the analytical method(s) stated and is correct to within the analytical accuracies of this (these) method(s).

Authorized Signature

CC: Cylinder
File



INDUSTRIAL GAS DIVISION

Air Products and Chemicals, Inc.

Specialty Gas Department
Box 351, RD 1
Tamaqua, PA 18252
(717) 467-2981

ANALYTICAL REPORT

SAMPLE OF: 150 PPM CARBON MONOXIDE/BAL. NITROGEN
'BAL'

DATE: JULY 25, 1988 PAGE: 1 of 1

SHIPPER NO.

CUSTOMER ORDER NO.:

SAMPLE DATE:

REQUESTED BY: MOSTARDI PLATT ASSOC.

REMARKS:

ANALYTICAL METHOD	ANALYST
Electrolytic Cell (O ₂ Trace)	
Infrared Horiba	
Ion Mobility for N ₂ in Ar	
Dew Point	
Hydrogen Flame Analyzer (THC)	
Wet Analysis	
Flame Photometer	

ANALYTICAL METHOD	ANALYST
Gas Chromatography	
Infrared Spectroscopy	
C.G. Flame Ionization Unit	X RM
Chemiluminescence	
Paramagnetic	
Gravimetric	

ANALYSIS

LAB NO.	CYL. NO.	COMPONENT REQUESTED	CONCENTRATION REQUESTED	ANALYTICAL RESULT	UNIT OF MEASURE
C9179	SG0734	CARBON MONOXIDE	150	148	MOLAR PPM

CERTIFICATION

This analysis has been performed utilizing the analytical method(s) stated and is correct to within the analytical accuracies of this (these) method(s).

Authorized SignatureCC: Cylinder
File



INDUSTRIAL GAS DIVISION

Air Products and Chemicals, Inc.

Specialty Gas Department
Box 351, RD 1
Tamaqua, PA 18252
(717) 467-2981

ANALYTICAL REPORT

SAMPLE OF: 300 PPM CARBON MONOXIDE/BAL NITROGEN

DATE: 7/25/88

PAGE: 1 of 1

SHIPPER NO.

CUSTOMER ORDER NO.:

SAMPLE DATE:

REQUESTED BY: MOSTARDI PLATT

REMARKS:

ANALYTICAL METHOD	ANALYST
Electrolytic Cell (O ₂ Trace)	
Infrared Horiba	
Ion Mobility for N ₂ in Ar	
Dew Point	
Hydrogen Flame Analyzer (THC)	
Wet Analysis	
Flame Photometer	

ANALYTICAL METHOD	ANALYST
Gas Chromatography	
Infrared Spectroscopy	
C.G. Flame Ionization Unit	X RM
Chemiluminescence	
Paramagnetic	
Gravimetric	

ANALYSIS

LAB NO.	CYL. NO.	COMPONENT REQUESTED	CONCENTRATION REQUESTED	ANALYTICAL RESULT	UNIT OF MEASURE
C9178	SG861390	CARBON MONOXIDE	300	279	MOLAR PPM

CERTIFICATION

This analysis has been performed utilizing the analytical method(s) stated and is correct to within the analytical accuracies of this (these) method(s).

Authorized Signature

CC: Cylinder
File



Turbine Performance Record

Plant: CID

Engine Model: Centaur T4500

Equipment #: 1

Location: Columet City, IL

Serial #: 4283C

Date: 8-8-89

Oil Used - Brand: Mobil

Type: SHC 824

READING	REQUIRED VALUE	ACTUAL VALUE TIME: 4:34 PM	ACTUAL VALUE TIME:	ACTUAL VALUE TIME:
Turbine Starts		74		
Turbine Hours		321.1		
Turbine Vibrations (IPS)	< 0.4	0.07		
Gearbox Vibrations (Gs)	< 20	6		
Generator Winding Temperature A (°C)	< 150	91		
Generator Winding Temperature B (°C)	< 150	91		
Generator Winding Temperature C (°C)	< 150	94		
Generator Vibrations Forward (IPS)	< 0.4	0.04		
Generator Vibrations Aft (IPS)	< 0.4	0.04		
Forward Generator Bearing Temp (°C)	< 82	72		
Aft Generator Bearing Temp (°C)	< 82	72		
Turbine Speed (%)	100%	100		
Turbine Temperature (°F)	1170 Max	1160		
Megawatts	2.8-3.3	2.85		
Power Factor	0.98	0.96		
KVAR		550		
Frequency (HZ)	60	60		
Volts A-B	4160	4300		
Volts B-C	4160	4325		
Volts A-C	4160	4300		
Ampere A	< 480	380		
Ampere B	< 480	395		
Ampere C	< 480	385		
Generator Oil Pressure (PSI)	15-22	15.5		
Fuel Pressure (PSI)	150-185	172		
PCD	113-125	115		
Turbine Filter Inlet Oil (PSI)	55-65	67		
Turbine Filter Outlet Oil (PSI)	35-65	57		
Oil Filter ΔP (PSI)	< 20	10		
Oil Level	1/2 - Full	Full		
Oil Temperature (°F)	135-155	151		
Fuel Gas Flow (SCFM)	1200-1750	1222		
Gas Temperature (°F)	120-140	108		
Turbine Room Temperature (°F)		78		
Battery Charger (Volts)	24-28	31		
Battery Charger (AMPS)	5-10	16		
Ambient Temperature (°F)		70		
Inlet Filter ΔP (H ₂ O)	< 3.0	1.4		
Operator's Initials				

Avg = 1136.6 CFM
#5 sets

(Make all comments on back)



Turbine Performance Record

Plant: CID

Engine Model: Centaur T4500

Equipment #: 2

Location: Calumet City, IL

Serial #: 4239C

Date: 8-8-89

Oil Used - Brand: Mobil

Type: SHC 824

READING	REQUIRED VALUE	ACTUAL VALUE	ACTUAL VALUE	ACTUAL VALUE
		TIME: 7:12 AM	TIME: 4:38 PM	TIME:
Turbine Starts		77	77	
Turbine Hours		823.9	823.6	
Turbine Vibrations (IPS)	< 0.4	0.09	0.09	
Gearbox Vibrations (G's)	< 20	7.5	7.2	
Generator Winding Temperature A (°C)	< 150	75	90	
Generator Winding Temperature B (°C)	< 150	78	93	
Generator Winding Temperature C (°C)	< 150	78	94	
Generator Vibrations Forward (IPS)	< 0.4	0.04	0.04	
Generator Vibrations Aft (IPS)	< 0.4	0.02	0.03	
Forward Generator Bearing Temp (°C)	< 82	77	80	
Aft Generator Bearing Temp (°C)	< 82	77	80	
Turbine Speed (%)	100%	100	100	
Turbine Temperature (°F)	1170 Max	960	940	
Megawatts	2.8-3.3	2.0	2.2	
Power Factor	0.98	0.95	0.94	
KVAR		450	600	
Frequency (HZ)	60	60	60	
Volts A-B	4160	4300	4350	
Volts B-C	4160	4300	4350	
Volts A-C	4160	4300	4300	
Ampere A	< 480	285	300	
Ampere B	< 480	280	300	
Ampere C	< 480	280	300	
Generator Oil Pressure (PSI)	15-22	18	17.5	
Fuel Pressure (PSI)	150-185	161	158	
PCD	113-125	110	110	
Turbine Filter Inlet Oil (PSI)	55-65	64	64	
Turbine Filter Outlet Oil (PSI)	35-65	58	58	
Oil Filter ΔP (PSI)	< 20	6	6	
Oil Level	1/2 - Full	3/4	3/4	
Oil Temperature (°F)	135-155	149	150	
Fuel Gas Flow (SCFM)	1200-1750	964	1009	
Gas Temperature (°F)	120-140	106	121	
Turbine Room Temperature (°F)		84	76	
Battery Charger (Volts)	24-28	28	28	
Battery Charger (AMPS)	5-10	14	15	
Ambient Temperature (°F)		52	70	
Inlet Filter ΔP (H ₂ O)	< 3.0	1.4	1.5	
Operator's Initials		X.B	8-D	

(Make all comments on back)



Turbine Performance Record

Plant: CID

Engine Model: Centaur T4500

Equipment #: 2³

Location: Columet City, IL

Serial #: 4239C

Date: 8-8-89

Oil Used - Brand: Mobil

Type: SHC 824

READING	REQUIRED VALUE	ACTUAL VALUE TIME: 7:16 AM	ACTUAL VALUE TIME: 3:16 PM	ACTUAL VALUE TIME:
Turbine Starts		77	77	
Turbine Hours		848.0	856.0	
Turbine Vibrations (IPS)	< 0.4	0.1	0.09	
Gearbox Vibrations (G's)	< 20	7.5	7	
Generator Winding Temperature A (°C)	< 150	103	104	
Generator Winding Temperature B (°C)	< 150	108	106	
Generator Winding Temperature C (°C)	< 150	108	107	
Generator Vibrations Forward (IPS)	< 0.4	0.02	0.02	
Generator Vibrations Aft (IPS)	< 0.4	0.02	0.02	
Forward Generator Bearing Temp (°C)	< 82	79	80	
Aft Generator Bearing Temp (°C)	< 82	79	80	
Turbine Speed (%)	100%	100	100	
Turbine Temperature (°F)	1170 Max	1160	1170	
Megawatts	2.8-3.3	2.9	2.8	
Power Factor	0.98	0.95	0.95	
KVAR		625	550	
Frequency (HZ)	60	60	60	
Volts A-B	4160	4300	4350	
Volts B-C	4160	4300	4325	
Volts A-C	4160	4300	4350	
Amperes A	< 480	385	380	
Amperes B	< 480	390	385	
Amperes C	< 480	390	390	
Generator Oil Pressure (PSI)	15-22	18	18	
Fuel Pressure (PSI)	150-185	154	154	
PCD	113-125	118	116	
Turbine Filter Inlet Oil (PSI)	55-65	64	64	
Turbine Filter Outlet Oil (PSI)	35-65	57	57	
Oil Filter ΔP (PSI)	< 20	7	7	
Oil Level	1/2 - Full	3/4	3/4	
Oil Temperature (°F)	135-155	150	150	
Fuel Gas Flow (SCFM)	1200-1750	1238	1250	
Gas Temperature (°F)	120-140	111	118	
Turbine Room Temperature (°F)		84	88	
Battery Charger (Volts)	24-28	28	28	
Battery Charger (AMPS)	5-10	15	15	
Ambient Temperature (°F)		61	60	
Inlet Filter ΔP (°H ₂ O)	< 3.0	1.5		
Operator's Initials		X.B	X.B	

(Make all comments on back)

HORIBA

SPECIFICATIONS

Type	MEXA-201E	MEXA-221E	MEXA-321E
Measuring Method	Non-dispersive Infrared Ray Absorption Method (NDIR)		
Object of Measurement	Carbon Monoxide (CO)	Hydrocarbons (HC)	Carbon Monoxide (CO) and Hydrocarbons (HC)
Range of Measurement	0-2vol% CO)Dual Range 0-8vol% CO	0-500ppm HC)Dual Range 0-2000ppm HC	0-2vol% CO)Dual Range 0-8vol% CO 0-500ppm HC)Dual Range 0-2000ppm HC
Accuracy	CO: Within $\pm 0.5\text{vol}\%$ CO	HC: Within 5% of full scale of each range.	CO: Within $\pm 0.5\text{vol}\%$ CO HC: Within 5% of full scale of each range.
Indicator	Scale Length: Approx. 96mm concentration scale.		
Minimum Graduation	0.05vol% CO (0-2vol% CO Range) (0.2vol% CO (0-8vol% CO Range)	10ppm HC (0-500ppm HC Range) (50ppm HC (0-2000ppm HC Range)	0.05vol% CO (0-2vol% CO Range) (0.2vol% CO (0-8vol% CO Range) 10ppm HC (0-500ppm HC Range) (50ppm HC (0-2000ppm HC Range)
Warm Up Time	Approx. 30 min.		
Speed of Response	Within 10 sec. for 90% response (including sample handling system)		
Output for Recorder	DC100mV full scale (output impedance: 100 Ω)		
Ambient Condition	Ambient Temperature: 0-40°C		
	Ambient Humidity: Less than relative humidity of 90%		
Sampling	Directly sampled		
Power Source	AC100V/110V/115V $\pm 10\%$ 60Hz AC220V/230V/240V $\pm 10\%$ 50Hz		
Power Consumption	Approx. 50W		
External Dimensions	220(W) X 225(H) X 520(D) mm		
Weight	Approx. 9.5kg		

SPECIFICATIONS

Type	MEXA-201E	MEXA-221E	MEXA-321E
Measuring Method	Non-dispersive Infrared Ray Absorption Method (NDIR)		
Object of Measurement	Carbon Monoxide (CO)	Hydrocarbons (HC)	Carbon Monoxide (CO) and Hydrocarbons (HC)
Range of Measurement	0-2vol% CO 0-8vol% CO Dual Range	0-500ppm HC 0-2000ppm HC Dual Range	0-2vol% CO 0-8vol% CO 0-500ppm HC 0-2000ppm HC Dual Range
Accuracy	CO: Within ± 0.5 vol% CO	HC: Within 5% of full scale of each range.	CO: Within ± 0.5 vol% CO HC: Within 5% of full scale of each range.
Indicator	Scale Length: Approx. 98mm concentration scale.		
Minimum Graduation	0.05vol% CO (0-2vol% CO Range) 0.2vol% CO (0-8vol% CO Range)	10ppm HC (0-500ppm HC Range) 50ppm HC (0-2000ppm HC Range)	0.05vol% CO (0-2vol% CO Range) 0.2vol% CO (0-8vol% CO Range) 10ppm HC (0-500ppm HC Range) 50ppm HC (0-2000ppm HC Range)
Warm Up Time	Approx. 30 min.		
Speed of Response	Within 10 sec. for 90% response (including sample handling system)		
Output for Recorder	DC100mV full scale (output impedance: 100 Ω)		
Ambient Condition	Ambient Temperature: 0-40°C Ambient Humidity: Less than relative humidity of 90%		
Sampling	Directly sampled from tail pipe of vehicle.		
Power Source	AC100V/110V/115V $\pm 10\%$ 60Hz AC220V/230V/240V $\pm 10\%$ 50Hz		
Power Consumption	Approx. 50W		
External Dimensions	220(W) X 225(H) X 520(D) mm		
Weight	Approx. 9.5kg		
	Approx. 80W		
	330(W) X 225(H) X 520(D) mm		
	Approx. 13kg		

RUST**ENVIRONMENT &
INFRASTRUCTURE***Fax Transmittal*1240 East Diehl Road ■ Naperville, IL 60563
Tel: (708) 955-6600 ■ Fax: (708) 955-6601Date: JULY 11, 1994Time: 10:10To: MR STEPHEN M. ROIZCompany: E. H. PECCHAN & ASSOCCity/State: RANCHO CORDOVA, CAFax Number: 916 852-9451From: CHUCK ANDERSON

Project No: _____

Total Pages including This Page: 3Comments: ATTACHED PLEASE FIND A RESPONSE TO
YOUR REQUEST FOR INFORMATION DATED JUNE 16, 1994IF WE CAN BE OF FURTHER ASSISTANCE, PLEASE CALL ME
AT (708) 955-6665-THANKS !CHUCK

For Originator:


Return Original

☐ Yes☐ No☐ Pickup

For Operator:

Date Sent 7/11/94 Time _____ By _____

In case of transmission problems, please call: (708) 955-6600



RUST ENVIRONMENT &
INFRASTRUCTURERUST Environment & Infrastructure Inc.
1240 East Diehl Road
Naperville, IL 60563
Tel. (708) 955-6600 • FAX (708) 955-6601

Ref. # 2

July 8, 1994

Mr. Steven M. Roe
E.H. Pechan & Associates, Inc.
2880 Sunrise Boulevard, Suite 220
Rancho Cordova, CA 95742

Dear Mr. Roe:

In response to your request for information dated June 16, 1994 the following information is provided:

- Altamont Landfill has no history of co-disposal. Hazardous wastes were never accepted at the site. The fuel flow rate during the June 1988 test was approximately 1500 scfm of landfill gas. To the best of our knowledge NMOC sampling of the fuel gas has never been performed at Altamont.

- The methane content of the LFG fuel at Monroe-Livingston during the July 1989 test was approximately 54.2%. *Need fuel FR.*

- The following information was available for CID. To the best of our knowledge NMOC sampling of the fuel gas has never been performed at CID.

8/25/89 The average methane content was 58.4%.

$$\frac{58.4 + 58.2}{2} = 58.3\%$$

2/16/90 The average landfill gas flow rate at the gas recovery plant was 3282 scfm.

$$\rightarrow \text{AVG} = 3320$$


2/22/90 The average methane content was 58.2% and the average landfill gas flow rate at the gas recovery plant was 3359 scfm.

NMOC sampling of the fuel gas has not been performed for the Altamont or CID facilities. If you feel it may be beneficial to have the landfill gas tested at both facilities at this time, please contact me to discuss this option.

If we can be of any further assistance, please call me at (708) 955-6665.

Sincerely,

RUST Environment & Infrastructure, Inc.

A handwritten signature in cursive script, appearing to read "Charles E. Anderson".

Charles E. Anderson
Manager of Gas Recovery

cc: Mike Niemann

