

June 6, 1991

Mr. Andrew Washington  
Pacific Energy  
6055 East Washington Blvd.  
Commerce, CA 90040


SUBJECT: Otay Landfill Annual Compliance  
Source Test Results  
SCEC Job No. T1259

Dear Mr. Washington:

Enclosed are two (2) copies of the second addendum to the report presenting the results of the annual compliance test conducted on April 2-5, 1991. This addendum reflects emissions of NO<sub>2</sub> in lbs/hr rather than ppm, and is based on combustion analysis and fuel flow rates rather than CARB Method 1-4 for exhaust gas flow measurements.

If you have any questions, comments, or require any further information please contact me or Keith B. Shannon at 714-596-6540.

Sincerely,  
SOUTH COAST ENVIRONMENTAL COMPANY



Leslie A. Johnson  
Source Test Manager

LAJ/KBS:smw

T1259m

May 29, 1991

Mr. Andrew Washington  
Pacific Energy  
6055 East Washington Blvd.  
Commerce, CA 90040

SUBJECT: Otay Landfill Annual Compliance  
Source Test Results  
SCEC No. T1259

Dear Mr. Washington:

Enclosed are two (2) copies of the addendum to the report presenting the results of the annual compliance test conducted on April 2-5, 1991. This addendum reflects emissions based on combustion analysis and fuel flow rates rather than CARB Method 1-4.

If you have any questions, comments, or require any further information please contact me or Keith B. Shannon at 714-596-6540.

Sincerely,  
SOUTH COAST ENVIRONMENTAL COMPANY



Leslie A. Johnson  
Source Test Manager

LAJ/KBS:smw

Encl.

T12591

ADDENDUM TO  
SOURCE TEST REPORT

PACIFIC ENERGY  
6055 EAST WASHINGTON BOULEVARD  
COMMERCE, CA 90040

UNIT TESTED:  
OTAY LANDFILL  
SUPERIOR ENGINE #1

TEST DATE:  
APRIL 2, 1991

ISSUE DATE:  
MAY 29, 1991

PARAMETERS MEASURED:  
NO<sub>x</sub>, NO<sub>2</sub>, CO, O<sub>2</sub>, REACTIVE ORGANIC GASES,  
AND PARTICULATE EMISSIONS

TESTED BY:  
SOUTH COAST ENVIRONMENTAL COMPANY  
1915 MCKINLEY AVE., SUITE E  
LA VERNE, CA 91750

REPORT NO: T1259

TESTED BY: Keith Hammer

REVIEWED BY: OK

RECEIVED  
JUN 12 1 08 PM '91  
AIR POLLUTION  
CONTROL DISTRICT

TABLE OF CONTENTS

|                                            | <u>PAGE NO.</u> |
|--------------------------------------------|-----------------|
| I. SUMMARY OF RESULTS                      | 3               |
| II. EXHAUST VOLUMETRIC FLOW DATA           | 5               |
| III. NO <sub>x</sub> , CO, AND ROG RESULTS | 10              |

T1259k

I. SUMMARY OF RESULTS



**PACIFIC ENERGY**

A SUBSIDIARY OF  
PACIFIC  
ENTERPRISES

6055  
East  
Washington  
Boulevard,  
Commerce,  
California  
90040

Facsimile  
(213) 725-8772

Telephone  
(213) 725-1139

June 11, 1991

Mr. John Jackson  
San Diego County APCD  
9150 Chesapeake Drive  
San Diego, CA 92123-1095

Dear Mr. Jackson:

RE: Otay Landfill Source Test Results  
AB2588 Report - SCEC #T1265  
Annual Compliance Report - SCEC #1259

Enclosed please find copies of the above referenced reports for Pacific Energy's Otay facility.

As I explained to you during our telephone conversation, the Annual Compliance report has two addenda. The first represents emissions based on carbon balance rather than CARB Method 1-4. The second represents emissions based on combustion analysis rather than CARB Method 1-4. The AB2588 report has an addendum representing emissions based on carbon balance.

We look forward to discussing these results with you during our meeting tentatively scheduled for June 20, 1991 at 11:00 a.m. in your offices.

In the meantime, if you have any questions, please call me at (213) 725-1139 x448.

Sincerely,

Andrew F. Washington  
Environmental Compliance Mgr.

cc: P. Nakamoto  
R. Rolfe

June 6, 1991

Mr. Andrew Washington  
Pacific Energy  
6055 East Washington Blvd.  
Commerce, CA 90040


SUBJECT: Otay Landfill Annual Compliance  
Source Test Results  
SCEC Job No. T1259

Dear Mr. Washington:

Enclosed are two (2) copies of the second addendum to the report presenting the results of the annual compliance test conducted on April 2-5, 1991. This addendum reflects emissions of NO<sub>2</sub> in lbs/hr rather than ppm, and is based on carbon analysis rather than CARB Method 1-4 for exhaust gas flow measurements.

If you have any questions, comments, or require any further information please contact me or Keith B. Shannon at 714-596-6540.

Sincerely,  
SOUTH COAST ENVIRONMENTAL COMPANY



Leslie A. Johnson  
Source Test Manager

LAJ/KBS:smw

T1259n

May 14, 1991

Mr. Terence Hee  
Pacific Energy  
6055 East Washington Blvd.  
Commerce, CA 90040

SUBJECT: Otay Landfill Annual Compliance  
Source Test Results  
SCEC No. T1259

Dear Mr. Hee:

Enclosed are two (2) copies of the addendum to the report presenting the results of the annual compliance test conducted on April 2-5, 1991. This addendum reflects emissions based on total carbon analysis rather than CARB Method 1-4.

Upon your review please forward one copy to Mr. John Jackson at San Diego Air Pollution Control District. We hope everything is in order and to your satisfaction.

If you have any questions, comments, or require any further information please contact me or Keith B. Shannon at 714-596-6540.

Sincerely,  
SOUTH COAST ENVIRONMENTAL COMPANY



Leslie A. Johnson  
Source Test Manager

LAJ/KBS:smw

Encl.

T1259j



ADDENDUM TO  
SOURCE TEST REPORT

PACIFIC ENERGY  
6055 EAST WASHINGTON BOULEVARD  
COMMERCE, CA 90040

UNIT TESTED:  
  
OTAY LANDFILL  
SUPERIOR ENGINE #1

TEST DATE:  
  
APRIL 2, 1991

ISSUE DATE:  
  
MAY 14, 1991

PARAMETERS MEASURED:  
  
NO<sub>x</sub>, NO<sub>2</sub>, CO, O<sub>2</sub>, REACTIVE ORGANIC GASES,  
AND PARTICULATE EMISSIONS

TESTED BY:  
  
SOUTH COAST ENVIRONMENTAL COMPANY  
1915 MCKINLEY AVE., SUITE E  
LA VERNE, CA 91750

REPORT NO: T1259  
TESTED BY: *Kurt Hanna*  
REVIEWED BY: *R. John*

TABLE OF CONTENTS

|                                            | <u>PAGE NO.</u> |
|--------------------------------------------|-----------------|
| I. SUMMARY OF RESULTS                      | 3               |
| II. EXHAUST VOLUMETRIC FLOW DATA           | 5               |
| III. NO <sub>x</sub> , CO, AND ROG RESULTS | 10              |

T1259i

I. SUMMARY OF RESULTS

# LANDFILL GAS ENGINE EXHAUST EMISSION TEST REPORT

PLANT: OTAY

| TEST DATE: April 2 & 3, 1991       |                                           | TESTING LAB: South Coast Environmental |        | TECHNICIAN: K. B. Shannon |        |
|------------------------------------|-------------------------------------------|----------------------------------------|--------|---------------------------|--------|
| KW LOAD: 1959                      |                                           | RATED HP: 2650                         |        | TOTAL TEST KWRS: 5877     |        |
| STACK TEMP: 815°F                  |                                           | STACK MOISTURE % VOLUME: 12.2%         |        | FLOW SDCFM: 4712*         |        |
| TEST PARAMETER                     | PERMIT LIMITS                             | TEST AVERAGE                           | RUN #1 | run #2                    | run #3 |
| FUEL FLOW (DSCFM)                  | NONE                                      | 588                                    | N/A    | N/A                       | N/A    |
| O2 %                               | NONE                                      | 7.86                                   | 7.95   | 7.79                      | 7.83   |
| NO2 (NOX-NO)<br>LBS-HR             | 10.9                                      | 1.53                                   | 1.39   | 1.55                      | 1.65   |
| NOx (Corrected)<br>PPM             | 400 (Dry)                                 | 159.95                                 | 157.79 | 162.52                    | 159.53 |
| LBS-HR                             | --                                        | 5.49                                   | 5.42   | 5.58                      | 5.48   |
| g/Bhp-Hr                           | --                                        | 0.95                                   | 0.94   | 0.96                      | 0.95   |
| NON-METHANE<br>HYDROCARBONS<br>PPM | -                                         | 5.00                                   | 5.90   | 5.20                      | 3.90   |
| LBS-HR @                           | -                                         | 0.16                                   | 0.23   | 0.16                      | 0.09   |
| g/Bhp-Hr                           | 0.3 g/Bhp-Hr                              | 0.03                                   | 0.04   | 0.03                      | 0.02   |
| CARBON MONOXIDE<br>PPM @ 3 % O2    | 750 (Dry)                                 | 354.95                                 | 355.01 | 355.60                    | 354.23 |
| LBS-HR                             | -                                         | 5.40                                   | 5.36   | 5.44                      | 5.40   |
| g/Bhp-Hr                           | -                                         | 0.93                                   | 0.93   | 0.94                      | 0.93   |
| PARTICULATES<br>Gr/DSCF            | 0.1 Gr/DSCF                               | 0.003                                  | 0.005  | 0.002                     | 0.001  |
| TEST COORDINATOR                   | TERENCE HEE 213-725-1139 (SEND REPORT TO) |                                        |        |                           |        |
| SITE CONTACT                       | MAURICE KING 619-421-5945                 |                                        |        |                           |        |

\* Flow DSCFM calculated from carbon balance equation.

ENGINEERING SOURCE TEST REPORT FORMAT:

INTRODUCTION

SUMMARY

FORAMLIZED COPY OF THIS FORM

INSTRUMENT DATA

EXHAUST VOLUMETRIC FLOW DATA

COPY OF ALL CALCULATIONS

FUEL GAS ANALYSIS REPORT

INCLUDE VOLUME AND WEIGHT OF SAMPLE

LAB REPORT TO IDENTIFY PLANT AND GAS SAMPLE SOURCE

FIELD DATA

COPY OF PLANT GAS CHROMATOGRAPH PRINTOUT

ALL ENGINE OPERATING PARAMETERS DOCUMENTED

## II. EXHAUST VOLUMETRIC FLOW DATA

COMPANY: PACIFIC ENERGY  
DATE: MAY 6, 1991  
UNIT: ICE #1  
REPORT #:T1259

# EXHUAUST FLOW RATE CALCULATIONS -----

CALCULATIONS BASED ON INLET GAS FLOW RATE AND CARBON BALANCE FROM  
TOTAL CARBON ANALYSIS.

EXHAUST O2 % = 7.86

INLET FLOW RATE (SCFM) = 588

INLET CARBON CONC. (CONC. OF CO2, CO, CH4, NMHC IN PPM) = 920690


EXHAUST CARBON CONC. (CONC. OF CO2, CO, CH4, NMHC IN PPM) = 114880

EXHAUST FLOW CALCULATION = 
$$\frac{(\text{INLET FLOW RATE})(\text{INLET CARBON CONC.})}{(\text{EXHAUST CARBON CONC.})}$$

EXHAUST FLOW RATE (DSCFM)= 4712

EXHAUST FLOW RATE @ 0% O2 (DSCFM)= 2940

EXHAUST FLOW RATE @ 15% O2 (DSCFM)= 10415



# ZALCO LABORATORIES, INC.

## Analytical & Consulting Services

SOUTH COAST ENVIRONMENTAL  
1915 McKinley, Suite E  
Livermore, CA 91750

Lab. No.: 027378\_001  
Received: May 3, 1991  
Reported: May 3, 1991

Attention: Russ Logan

Sample Description: PEN-OTAY LF Ice #1 Inlet


### \* CHROMATOGRAPHIC ANALYSIS (Z 1610) \*


| Components      | Mole %  | ppm     | Wt %    | G.P.M. |
|-----------------|---------|---------|---------|--------|
| Carbon Dioxide  | 38.428  | 384280  | 60.666  |        |
| Oxygen          | 2.198   |         | 2.522   |        |
| Nitrogen        | 5.733   |         | 5.761   |        |
| Carbon Monoxide | 0.000   |         | 0.000   |        |
| Methane         | 53.567  | 535,670 | 30.827  |        |
| Ethane          | 0.000   |         | 0.000   |        |
| Propane         | 0.000   |         | 0.000   | 0.000  |
| IsoButane       | .004    | 40      | .008    | .001   |
| N-Butane        | 0.000   |         | 0.000   | 0.000  |
| IsoPentane      | 0.000   |         | 0.000   | 0.000  |
| N-Pentane       | 0.000   |         | 0.000   | 0.000  |
| Hexanes+        | .070    | 700     | .215    | .030   |
| Totals =        | 100.000 | 920,690 | 100.000 | .031   |

|                                          |         |
|------------------------------------------|---------|
| SPECIFIC GRAVITY (Air = 1)               | .9664   |
| * SPECIFIC VOLUME, cu.ft./lb             | 13.56   |
| * GROSS CALORIFIC VALUE, BTU/cu.ft.      | 537.60  |
| ** GROSS CALORIFIC VALUE, BTU/cu.ft.     | 546.89  |
| ** GROSS CALORIFIC VALUE, BTU/lb         | 7414.66 |
| * NET CALORIFIC VALUE, BTU/cu.ft.        | 484.14  |
| ** NET CALORIFIC VALUE, BTU/cu.ft.       | 492.51  |
| COMPRESSIBILITY FACTOR 'Z' (60 F, 1 ATM) | .9975   |

\* Water Saturated

\*\* Dry Gas @ 60 F, 14.73 psia

  
Maryann W. Benoit  
Organics Supervisor


  
Richard L. Penner  
Laboratory Director

4309 Armour Avenue Bakersfield, California 93308

(805) 395-0539

7

FAX (805) 395-3069



# ZALCO LABORATORIES, INC.

## Analytical & Consulting Services

SOUTH COAST ENVIRONMENTAL  
1915 McKinley, Suite E  
Laverne, CA 91750

Lab. No.: 027378\_002  
Received: May 3, 1991  
Reported: May 3, 1991

Attention: Russ Logan

Sample Description: PEN-OTAY LF Ice #1 Outlet

### \* CHROMATOGRAPHIC ANALYSIS (Z 1610) \*

| Components      | Mole %  | PPM     | WL %    | G.P.M. |
|-----------------|---------|---------|---------|--------|
| Carbon Dioxide  | 11.340  | 113,400 | 16.531  |        |
| Oxygen          | 9.470   |         | 10.037  |        |
| Nitrogen        | 79.040  |         | 73.337  |        |
| Carbon Monoxide | .032    | 320     | .030    |        |
| Methane         | .1150   | 1150    | .061    |        |
| Ethane          | 0.000   |         | 0.000   | 0.000  |
| Propane         | 0.000   |         | 0.000   | 0.000  |
| IsoButane       | 0.000   |         | 0.000   | 0.000  |
| N-Butane        | 0.000   |         | 0.000   | 0.000  |
| IsoPentane      | 0.000   |         | 0.000   | 0.000  |
| N-Pentane       | 0.000   |         | 0.000   | 0.000  |
| Hexanes+        | .001    | 10      | .004    | .001   |
| Totals =        | 100.000 | 114,880 | 100.000 | .001   |

|    |                                          |        |
|----|------------------------------------------|--------|
|    | SPECIFIC GRAVITY (Air = 1)               | 1.0510 |
| *  | SPECIFIC VOLUME, cu.ft./lb               | 12.47  |
| *  | GROSS CALORIFIC VALUE, BTU/cu.ft.        | 1.31   |
| ** | GROSS CALORIFIC VALUE, BTU/cu.ft.        | 1.34   |
| ** | GROSS CALORIFIC VALUE, BTU/lb            | 16.65  |
| *  | NET CALORIFIC VALUE, BTU/cu.ft.          | 1.19   |
| ** | NET CALORIFIC VALUE, BTU/cu.ft.          | 1.21   |
|    | COMPRESSIBILITY FACTOR 'Z' (60 F, 1 ATM) | .9995  |

\* Water Saturated

\*\* Dry Gas @ 60 F, 14.73 psia

Note: See attached ppm Hydrocarbon Analysis for a more accurate measurement of hydrocarbons.

*Maryann W. Benoit*  
Maryann W. Benoit  
Organics Supervisor

*Richard L. Penner*  
Richard L. Penner  
Laboratory Director

4309 Armour Avenue Bakersfield, California 93308

(805) 395-0539

8

FAX (805) 395-3069



Zalco C1-C6 PPM Report

Sample Name : PEN-OTAY LF Ice #1 Outlet

0199, 027378\_002, May 3, 1991

Peak Processor : Genie

Multilevel : False

Instrument : ADC\_2

Application : Loop


Calculation : ExternalSTD

Quantitation: AreaUnits

Result File : /DATA/LOOP/RESULT/ADC\_2/SCE27378\_002.RES

Run Time : 25.00 Minutes, injected on Fri May 3, 1991 11:38:21

Run Status : RunStatusOK



Report Time: Fri May 3, 1991 1:03:32 pm

Method: /DATA/LOOP/METHOD/LOWPPMA.MTH

Format File: /DATA/LOOP/FORMAT/SIDE\_BY\_SIDE.FMT

### III. NO<sub>x</sub>, CO, AND ROG RESULTS

COMPANY: PACIFIC ENERGY  
 DATE: APRIL 2, 1991  
 UNIT: OTAY FACILITY ICE #1  
 REPORT #:T-1259

NO2 - NOx CORRECTIONS  
 -----

| RUN #   | UNCORRECTED |         |         | NOx CORRECTED VALUES |             |        |      |
|---------|-------------|---------|---------|----------------------|-------------|--------|------|
|         | NO ppm      | NO2 ppm | % LOSS* | NO2 ppm              | ppm @ 3% O2 | LB/HR  |      |
| #1      | 117.24      | 37.55   | 7.98%   | 40.55                | 157.79      | 218.10 | 5.42 |
| #2      | 117.24      | 40.50   | 11.79%  | 45.28                | 162.52      | 221.90 | 5.58 |
| #3      | 111.58      | 41.48   | 15.60%  | 47.95                | 159.53      | 218.48 | 5.48 |
| AVERAGE |             |         |         | 44.59                | 159.95      | 219.50 | 5.49 |

| RUN #     | %O2  | DSCFM | GR/BHP-HR | NO2 LB/HR |
|-----------|------|-------|-----------|-----------|
| #1        | 7.95 | 4712  | 0.94      | 1.39      |
| #2        | 7.79 | 4712  | 0.96      | 1.55      |
| #3        | 7.83 | 4712  | 0.95      | 1.65      |
| AVERAGE = |      |       | 0.95      | 1.53      |

\* Initial NO2 system loss was 6.08%, final NO2 system loss was 17.50%

COMPANY: PACIFIC ENERGY  
 DATE: APRIL 2, 1991  
 UNIT: ICE #1  
 REPORT #: T1259  
 RUN #: #1-NOx MODE

NOx/CO/O2 DATA

| TIME INTERVAL |          | CONCENTRATIONS |         |        | % Full Scale |        |       |
|---------------|----------|----------------|---------|--------|--------------|--------|-------|
| BEGIN         | END      | O2;%           | NOx;ppm | CO;ppm | O2%fs        | NOx%fs | CO%fs |
| 10:30 AM      | 10:35 AM | 7.88           | 153.79  | 259.14 | 42           | 20.4   | 30.8  |
| 10:35 AM      | 10:40 AM | 7.88           | 159.78  | 259.14 | 42           | 21     | 30.8  |
| 10:40 AM      | 10:45 AM | 8.03           | 155.79  | 257.17 | 42.6         | 20.6   | 30.6  |
| 10:45 AM      | 10:50 AM | 8.03           | 152.79  | 257.17 | 42.6         | 20.3   | 30.6  |
| 10:50 AM      | 10:55 AM | 7.88           | 159.78  | 251.23 | 42           | 21     | 30    |
| 10:55 AM      | 11:00 AM | 7.98           | 146.80  | 257.17 | 42.4         | 19.7   | 30.6  |
| Averages;     |          | 7.95           | 154.79  | 256.84 | 42.3         | 20.5   | 30.6  |

|                     | O2   | NOx  | CO   |
|---------------------|------|------|------|
| INITAL zero; %fs    | 10   | 5    | 4.6  |
| INITAL span; %fs    | 42.5 | 56.2 | 53.2 |
| FINAL zero; %fs     | 10   | 5    | 4.8  |
| FINAL span; %fs     | 44   | 56   | 52.4 |
| ZERO DRIFT %/ppm:   | 0    | 0    | 2    |
| CALIB. DRIFT %/ppm: | 0.4  | -2   | -8   |
| ZERO DRIFT %fs:     | 0    | 0    | -0.2 |
| CALIB.DRIFT %fs:    | -1.5 | 0.2  | 0.8  |
| CAL GAS value       | 8.05 | 511  | 483  |
| FULL SCALE RANGE    | 25   | 1000 | 1000 |

SDCFM = 4712.0 CARBON BALANCE  
 B-Hp = 2627 %O2 = 7.95

|             | ppm    | @ 3%O2 | @15%O2 | lbs/hr   | lb/day |
|-------------|--------|--------|--------|----------|--------|
| NOx values; | 154.79 | 213.96 | 70.52  | 5.31     | 127.44 |
|             |        |        |        | grms/BHp | 0.92   |
| CO values;  | 256.84 | 355.01 | 117.02 | 5.36     | 128.64 |
|             |        |        |        | grms/BHp | 0.93   |

COMPANY: PACIFIC ENERGY  
 DATE: APRIL 2, 1991  
 UNIT: ICE #1  
 REPORT #: T1259  
 RUN #: #2-NOx MODE

NOx/CO/O2 DATA

| TIME INTERVAL |   |          | CONCENTRATIONS |         |        | % Full Scale |        |       |
|---------------|---|----------|----------------|---------|--------|--------------|--------|-------|
| BEGIN         | - | END      | O2;%           | NOx;ppm | CO;ppm | O2%fs        | NOx%fs | CO%fs |
| 11:57 AM      | - | 12:02 PM | 7.81           | 154.40  | 261.96 | 42.8         | 20.4   | 30.6  |
| 12:02 PM      | - | 12:07 PM | 7.76           | 160.42  | 260.95 | 42.6         | 21     | 30.5  |
| 12:07 PM      | - | 12:12 PM | 7.76           | 164.43  | 260.95 | 42.6         | 21.4   | 30.5  |
| 12:12 PM      | - | 12:17 PM | 7.73           | 160.42  | 260.95 | 42.5         | 21     | 30.5  |
| 12:17 PM      | - | 12:22 PM | 7.85           | 154.40  | 259.93 | 43           | 20.4   | 30.4  |
| 12:22 PM      | - | 12:27 PM | 7.85           | 152.40  | 257.90 | 43           | 20.2   | 30.2  |
| Averages;     |   |          | 7.79           | 157.74  | 260.44 | 42.8         | 20.7   | 30.5  |

|                     | O2   | NOx  | CO   |
|---------------------|------|------|------|
| INITAL zero; %fs    | 10   | 5    | 4.8  |
| INITAL span; %fs    | 44   | 56   | 52.4 |
| FINAL zero; %fs     | 9.9  | 4.9  | 4.8  |
| FINAL span; %fs     | 43.1 | 56.9 | 52.2 |
| ZERO DRIFT %/ppm:   | 0    | -1   | 0    |
| CALIB. DRIFT %/ppm: | -0.2 | 9    | -2   |
| ZERO DRIFT %fs:     | 0.1  | 0.1  | 0    |
| CALIB.DRIFT %fs:    | 0.9  | -0.9 | 0.2  |
| CAL GAS value       | 8.05 | 511  | 483  |
| FULL SCALE RANGE    | 25   | 1000 | 1000 |

SDCFM = 4712.0  
 B-Hp = 2627      %O2 = 7.79

|             |        |        |        |          |        |
|-------------|--------|--------|--------|----------|--------|
| NOx values; | ppm    | @ 3%O2 | @15%O2 | 1bs/hr   | 1b/day |
|             | 157.74 | 215.37 | 70.99  | 5.41     | 129.84 |
|             |        |        |        | grms/BHp |        |
|             |        |        |        | 0.93     |        |
| CO values;  | ppm    | @ 3%O2 | @15%O2 | 1bs/hr   | 1b/day |
|             | 260.44 | 355.6  | 117.21 | 5.44     | 130.56 |
|             |        |        |        | grms/BHp |        |
|             |        |        |        | 0.94     |        |

COMPANY: PACIFIC ENERGY  
 DATE: APRIL 2, 1991  
 UNIT: ICE #1  
 REPORT #: T1259  
 RUN #: #3-NOx MODE

NOx/CO/O2 DATA  
 -----

| TIME INTERVAL |          | CONCENTRATIONS |         |        | % Full Scale |        |       |
|---------------|----------|----------------|---------|--------|--------------|--------|-------|
| BEGIN         | END      | O2;%           | NOx;ppm | CO;ppm | O2%fs        | NOx%fs | CO%fs |
| 01:05 PM      | 01:10 PM | 7.81           | 151.75  | 258.99 | 42.1         | 20.4   | 30.2  |
| 01:10 PM      | 01:15 PM | 7.84           | 151.75  | 258.99 | 42.2         | 20.4   | 30.2  |
| 01:15 PM      | 01:20 PM | 7.84           | 157.63  | 258.99 | 42.2         | 21     | 30.2  |
| 01:20 PM      | 01:25 PM | 7.84           | 155.67  | 258.99 | 42.2         | 20.8   | 30.2  |
| 01:25 PM      | 01:30 PM | 7.86           | 150.78  | 257.97 | 42.3         | 20.3   | 30.1  |
| 01:30 PM      | 01:35 PM | 7.79           | 150.78  | 257.97 | 42           | 20.3   | 30.1  |
| Averages;     |          | 7.83           | 153.06  | 258.65 | 42.2         | 20.5   | 30.2  |

|                     | O2   | NOx  | CO   |
|---------------------|------|------|------|
| INITAL zero; %fs    | 9.9  | 4.9  | 4.8  |
| INITAL span; %fs    | 43.1 | 56.9 | 52.2 |
| FINAL zero; %fs     | 9.8  | 5    | 4.8  |
| FINAL span; %fs     | 43.4 | 57   | 52   |
| ZERO DRIFT %/ppm:   | 0    | 1    | 0    |
| CALIB. DRIFT %/ppm: | 0.1  | 1    | -2   |
| ZERO DRIFT %fs:     | 0.1  | -0.1 | 0    |
| CALIB.DRIFT %fs:    | -0.3 | -0.1 | 0.2  |
| CAL GAS value       | 8.05 | 511  | 483  |
| FULL SCALE RANGE    | 25   | 1000 | 1000 |

SDCFM = 4712.0  
 B-Hp = 2627      %O2 = 7.83

|             |        |        |        |          |        |
|-------------|--------|--------|--------|----------|--------|
| NOx values; | ppm    | @ 3%O2 | @15%O2 | lbs/hr   | lb/day |
|             | 153.06 | 209.62 | 69.09  | 5.25     | 126    |
|             |        |        |        | grms/BHp |        |
|             |        |        |        | 0.91     |        |
| CO values;  | ppm    | @ 3%O2 | @15%O2 | lbs/hr   | lb/day |
|             | 258.65 | 354.23 | 116.76 | 5.4      | 129.6  |
|             |        |        |        | grms/BHp |        |
|             |        |        |        | 0.93     |        |