

**EMISSION TESTING AT
COALINGA COGENERATION PLANT**

January 29 and 30, 1991

Prepared for

Shell Western Exploration & Production, Inc.
P. O. Box 11164
Bakersfield, California 93389-1164

February 1991

Prepared by

Steiner Environmental, Inc.
4930 Boylan Street
Bakersfield, California 93308

Report PS-91-2367/Project 6938-91

TABLE OF CONTENTS

Section		Page
1	INTRODUCTION	1-1
2	TEST MATRIX	2-1
3	TEST RESULTS	3-1
4	SAMPLING EQUIPMENT AND PROCEDURES	4-1
5	ANALYTICAL PROCEDURES	5-1
6	QUALITY ASSURANCE	6-1
	APPENDIX A - STEINER ENVIRONMENTAL RAW DATA . .	A-1
	APPENDIX B - SWEPI COALINGA COGEN OPERATING DATA	B-1

SECTION 1
INTRODUCTION

At the request of Shell Western Exploration & Production, Inc., Steiner Environmental, Inc. conducted a series of emission tests on the effluent of two gas turbines at the cogeneration plant located north of Coalinga, California. The tests were conducted on January 29 and 30, 1991 to determine compliance with Fresno County Air Pollution Control District rules and regulations when burning the maximum amount of natural gas fuel.

Duplicate particulate, sulfate and SO₂ tests were conducted on the effluent of each HRSG serving each gas turbine (101A and 101B) using EPA Method 5/8. Duplicate NO_x, CO, CO₂ and O₂ tests were conducted using EPA Method 20. Duplicate hydrocarbon tests were conducted using EPA Method 18. A sample of the PUC natural gas fired in each turbine was collected and analyzed for CHNOS, specific gravity, moisture and Btu using ASTM Methods. Finally, a single test for H₂S in the fuel gas was conducted using EPA Method 11.

Section 2 of the report summarizes the test matrix for this program.

SECTION 2
TEST PROGRAM

Table 2-1 summarizes the tests performed on each unit. Extended sampling times were used to maximize the amount of particulate and SO₂ for subsequent analysis.

An upset occurred during the test program (HRSG 101-B, Test 2) and the data may not be representative of emissions from this plant.

Section 3 summarizes the results of these tests.

TABLE 2-1. COALINGA COGENERATION PLANT TEST MATRIX

<u>Date</u>	<u>Unit #</u>	<u>Test #</u>	<u>Test Parameter</u>	<u>Test Time</u>
01/29/91	101A	1	Particulates/Sulfates/SO ₂ /HC NO _x /CO/CO ₂ /O ₂	4:40 am - 7:41 am 4:40 am - 7:16 am
	"	2	Particulates/Sulfates/SO ₂ /HC NO _x /CO/CO ₂ /O ₂	8:40 am - 11:23 am 8:30 am - 11:00 am
01/30/91	101B	1	Particulates/Sulfates/SO ₂ /HC NO _x /CO/CO ₂ /O ₂	4:46 am - 6:59 am 4:40 am - 7:00 am
	"	2	Particulates/Sulfates/SO ₂ /HC NO _x /CO/CO ₂ /O ₂	7:52 am - 10:03 am 7:35 am - 9:43 am
01/29/91	101A	1	H ₂ S	5:57 am - 9:01 am
01/30/91	101B	1	H ₂ S	8:10 am - 11:40 am

SECTION 3 TEST RESULTS

Tables 3-1 and 3-2 summarize the results of the tests performed on Units 101A and 101B. All data are reported at 60°F and 29.92 inches Hg.

Both tests on HRSG 101-A were conducted at stable turbine operating conditions. Test 1 on HRSG 101-B was conducted at stable turbine operating conditions. At 8:10 am, during Test 2 on HRSG 101-B, the CO increased sharply and went off scale (>20 ppm) twice during the remainder of this test. Internal and external calibrations of the Steiner Environmental monitoring system were performed to determine if the system was still in calibration. All checks were positive and the system was in calibration. The CO remained high and erratic during the remainder of Test 2. The cause of this problem was not found prior to the end of this test, so this result is not indicative of emissions under normal operating conditions.

The moisture content of the stack gas increased from 7.87% to 8.30% from Test 1 to Test 2, suggesting that more water was injected into the turbine for NO_x control. NO_x at 15% O₂ did decrease slightly from Test 1 to Test 2 (38.09 to 37.45) and CO at 15% O₂ increased from Test 1 to Test 2 (4.08 to 11.52) which is consistent with the suggestion of a change in water injection rate.

The plant operating data does not show an increase in water injection rate (see Appendix B). As per SWEPI'S representative, Mr. K. D. Kirkpatrick, the cause of the problem was determined to be, that when the evaporative cooler came on and the inlet filters being saturated with moisture gave the same results as an increase in water injection. After the evaporative cooler was shut off, CO decreased and NO_x increased, but, due to low ambient air temperature, it would take a long time to dry the filters and stabilize to normal operating conditions.

Although H₂S was present in the PUC gas fired in the turbine, the H₂S was less than the detection limit (<0.10 ppm) on both test days.

TABLE 3-1. SUMMARY OF SOURCE EMISSION TEST DATA (60°F)

Unit Tested: SWEPI Coalinga
Cogen Plant HRSG Unit 101A

Date: January 29, 1991

Test Number	1	2	Average
Test Condition	Gas 100%	Gas 100%	
Barometric Pressure (in. Hg)	28.81	28.91	28.86
Stack Pressure (in. Hg)	28.80	28.90	28.85
Stack Area (ft ²)	15.67	15.67	15.67
Elapsed Sampling Time (min.)	140.00	140.00	140.00
Volume Gas Sampled (dscf)	114.716	114.885	114.801
F-Factor	8474.21	8474.21	8474.21
GAS DATA			
Average Gas Velocity (fps)	42.20	41.42	41.81
Average Gas Temperature (°F)	242.71	240.18	241.45
Gas Flowrate	25,984	25,744	25,864
Gas Analysis (Volume %)			
Carbon Dioxide, dry	3.49	3.48	3.49
Oxygen, dry	14.90	15.04	14.97
Water	8.05	7.83	7.94
EMISSION CONCENTRATION			
Filterable Particulate (gr/dscf)	0.0014	0.0009	0.0012
Total Particulate (gr/dscf)	0.0022	0.0016	0.0019
Total Sulfate	0.0001	0.0001	0.0001
CO (ppm)	4.15	4.38	4.27
SO ₂ (ppm)	0.08	0.09	0.08
NO _x (ppm)	38.44	38.61	38.53
>C ₁ HC (ppm)	<1.00	2.00	<1.50
EMISSION RATE - 1b/hr			
Filterable Particulate	0.32	0.20	0.26
Total Particulate	0.48	0.36	0.42
Total Sulfate	0.01	0.03	0.02
CO	0.48	0.50	0.49
SO ₂	0.02	0.02	0.02
NO _x	7.27	7.23	7.25
>C ₁ HC	<0.07	0.13	<0.10
EMISSION FACTOR - 1b/MMBtu			
Filterable Particulate	0.0060	0.0039	0.0050
Total Particulate	0.0091	0.0070	0.0080
Total Sulfate	0.0002	0.0005	0.0004
CO	0.0090	0.0098	0.0094
SO ₂	0.0004	0.0005	0.0004
NO _x	0.1376	0.1416	0.1396
>C ₁ HC	<0.0013	0.0025	<0.0019

TABLE 3-2. SUMMARY OF SOURCE EMISSION TEST DATA (60°F)

Unit Tested: SWEPI Coalinga
Cogen Plant HRSG Unit 101B

Date: January 30, 1991

Test Number	1	2	Average
Test Condition	Gas 100%	Gas 100%	
Barometric Pressure (in. Hg)	28.92	29.00	28.96
Stack Pressure (in. Hg)	28.91	28.98	28.94
Stack Area (ft ²)	15.67	15.67	15.67
Elapsed Sampling Time (min.)	120.00	120.00	120.00
Volume Gas Sampled (dscf)	97.748	99.623	98.685
F-Factor	8473.94	8473.94	8473.94
GAS DATA			
Average Gas Velocity (fps)	41.53	41.76	41.65
Average Gas Temperature (°F)	238.33	237.04	237.69
Gas Flowrate	25,879	26,015	25,947
Gas Analysis (Volume %)			
Carbon Dioxide, dry	4.02	3.42	3.72
Oxygen, dry	15.20	14.95	15.08
Water	7.87	8.30	8.08
EMISSION CONCENTRATION			
Filterable Particulate (gr/dscf)	0.0008	0.0010	0.0009
Total Particulate (gr/dscf)	0.0016	0.0024	0.0020
Total Sulfate	0.0001	0.0001	0.0001
CO (ppm)	3.94	11.62	7.78
SO ₂ (ppm)	0.10	0.09	0.10
NO _x (ppm)	36.80	38.27	37.54
>C ₁ HC (ppm)	1.00	1.00	1.00
EMISSION RATE - 1b/hr			
Filterable Particulate	0.17	0.23	0.20
Total Particulate	0.36	0.54	0.45
Total Sulfate	0.02	0.03	0.03
CO	0.45	1.34	0.89
SO ₂	0.03	0.02	0.03
NO _x	6.93	7.24	7.08
>C ₁ HC	0.07	0.07	0.07
EMISSION FACTOR - 1b/MMBtu			
Filterable Particulate	0.0034	0.0044	0.0039
Total Particulate	0.0071	0.0103	0.0087
Total Sulfate	0.0005	0.0005	0.0005
CO	0.0090	0.0255	0.0173
SO ₂	0.0005	0.0005	0.0005
NO _x	0.1387	0.1382	0.1384
>C ₁ HC	0.0013	0.0013	0.0013

SECTION 4
SAMPLING EQUIPMENT AND PROCEDURES

This section of the report describes the equipment and procedures used to conduct the particulate and gaseous tests on this program.

4.1 PRELIMINARY MEASUREMENTS

Before conducting the stack tests a series of preliminary measurements were made to determine:

- The location of the sampling site and the number and location of the sampling points to be used (EPA Method 1)
- The velocity, temperature and pressure of the gases in the stack (EPA Method 2)
- The composition of the stack gases (EPA Method 3)
- The moisture content of the stack gases (EPA Method 4)

Using the results of these preliminary measurements and the calibration constants for the sampling train, a series of calculations were made to determine the value of K, a constant, and N_d , ideal nozzle diameter, required to run an isokinetic test according to the equation:

$$\Delta H = \left\{ \frac{60^2 \pi^2 K_p^2 C_p^2 (1 - B_{wo})^2 P_s MW_d}{576^2 K_o^2 MW_s P_m} \right\} (N_d^4) \left(\frac{T_m}{T_s} \right) (\Delta P)$$

where

$$K = \left\{ \frac{60^2 \pi^2 K_p^2 C_p^2 (1 - B_{wo})^2 P_s M W_d}{576^2 K_o^2 M W_s P_m} \right\}$$

An actual nozzle, whose diameter was as close as possible to the ideal nozzle diameter, was selected for the test. Isokinetic sampling rates for each sampling point in the stack were computed using the equation:

$$\Delta H = (K)(N_d^4) \left(\frac{T_m}{T_s} \right) (\Delta P)$$

Since K and N_d are known, and remain constant during a test, the only variables are the meter temperatures, the stack gas temperature and the velocity pressure for each sampling point.

4.2 PREPARATION OF THE PARTICULATE-SO_x SAMPLING TRAIN

All sampling train components were cleaned in the laboratory (soap and water, tap water rinse, distilled water rinse, and IPA rinse) to eliminate previous contamination. The sampling train components were sealed and transported to the sampling site in a mobile lab. The EPA Method 5/8 equipment used to measure particulates (filterable and total) and SO_x consisted of:

- A calibrated 316 stainless steel nozzle for isokinetic sampling
- A heated Pyrex glass sampling probe (6 feet long) equipped with an S-type pitot tube and a thermocouple to measure stack velocity pressure and temperature

- A heated Pyrex glass filter holder containing a weighed 100-mm Whatman 934 AH glass fiber filter
- A Pyrex glass impinger train in an icebath (impinger 1 contained 100 ml 80-percent IPA; a Pyrex glass filter holder containing a 47-mm Whatman 934 AH filter; bubbler 2 and impinger 3 each contained 100 ml of 3-percent H₂O₂; bubbler 4 contained a weighed amount of silica gel)
- An umbilical to connect the probe and sample box to the control module
- A control module containing a vacuum pump, a calibrated dry gas meter and a calibrated orifice meter to measure the pressure, temperature and flowrate throughout the train.

The sampling train was charged in the mobile lab using freshly prepared reagents. Each impinger and its contents was weighed to the nearest 0.1 gm on a calibrated electronic balance. Blanks of all filters and reagents were retained for subsequent analysis. The sampling point locations were marked on the probe using a high-temperature marker. The sampling train was completely assembled and lifted to the sampling site.

4.3 SAMPLING PROCEDURES FOR PARTICULATE-SO_x SAMPLING TRAIN

Prior to a test, the sampling train was heated and leak-checked at 15-inches Mercury to insure leakage was less than 0.02 or 4% of the average sampling rate. The S-type pitot tube was also leak-checked. The sampling train was installed on the uniraill and the probe was inserted into the stack at the farthest point. An isokinetic sampling rate was calculated using an HP-41CV calculator for each sampling point on the traverse (4 points per traverse; 7 traverses for 101A and 6 points per

traverse; 4 traverses for 101B). Each point was sampled for an equal period of time (5.0 minutes) and all pertinent data was recorded on the data sheet for each point. The probe and sample box were maintained at 250°F throughout the traverse. The gases leaving the impinger train were maintained at <68°F. At the end of a traverse, the probe was withdrawn from the stack and the entire sampling train was transferred intact to the next sampling port. Another traverse of the stack was completed and the sampling train was withdrawn for the final leak check. This leak check was performed at 15-inches Mercury or at the highest vacuum achieved during the test. The S-type pitot tube was also checked at this time. The sampling train was then purged with ambient air for 15-minutes using the highest ΔH measured during the test. After the train was purged, the filter holder and impinger train were sealed with aluminum foil and lowered to the mobile lab for sample recovery.

4.4 SAMPLE RECOVERY PROCEDURES FOR PARTICULATE-SO_x SAMPLING TRAIN

Sample recovery for the nozzle and probe occurred on the stack. The nozzle and probe were brushed and rinsed three times using ACS reagent grade acetone into a polyethylene sample bottle. Sample recovery for the filter holder and impinger train occurred in the mobile lab. The 100-mm filter was removed from the 4-inch filter holder and sealed in its petri dish. The glass fibers stuck to the gasket were scraped off and put into the petri dish. The front half of the 4-inch glass filter holder was brushed and rinsed with acetone. Each impinger was removed from the icebath, wiped dry and weighed to the nearest 0.1 gm. The contents of impinger 1 were transferred to a polyethylene sample bottle. The back half of the 4-inch glass filter holder, the glass connectors,

impinger 1, and the front half of the 2-inch filter holder were rinsed with 80-percent IPA and the rinsings were transferred to this same bottle. The 47-mm filter from the 2-inch filter holder was sealed in its petri dish. The contents of bubbler 2 and impinger 3 were transferred to a polyethylene sample bottle. Distilled water rinsings of the back half of the 2-inch filter holder, bubbler 2, the connector, and impinger 3 were transferred to this same bottle. All sample bottles and petri dishes were marked and labeled. A chain-of-custody log was completed and the field data sheet was also labeled with the sample ID numbers. The sampling train was then recharged in preparation for the next test.

4.5 SAMPLING PROCEDURES FOR CONTINUOUS MONITORING

The continuous monitors used in the Steiner Environmental Mobile Monitoring Lab are shown in Table 4-1. Figure 4-1 is a schematic of the continuous monitoring system. The procedures used to continuously monitor stack gases for NO_x , CO, CO_2 , and O_2 strictly follow EPA Method 20.

Sample was taken from the stack (at 2 points) using a 316 stainless steel probe. A heated Balston filter holder and fiberglass filter (99.9999 percent efficiency retention of 0.6 micron particles) was connected to the outlet of the probe. Sample gas was transported through heated Teflon sample line (maintained at $>250^\circ\text{F}$) by a Teflon-lined diaphragm pump to a 316 stainless steel refrigeration type conditioner (Hankison Model E-4G-SS). The sample gas was passed through the conditioner two separate times under vacuum before entering the pump, then two additional times under pressure. The clean, dry sample gas ($\sim 35^\circ\text{F}$) was then transported to the continuous analyzer system through an unheated Teflon line. A series of flowmeters, valves and regulators maintain constant flow through the system at a constant pressure.

TABLE 4-1 CONTINUOUS MONITORING LAB - TRAILERS 1, 2 AND 4

NO_x CHEMILUMINESCENT ANALYZER -- THERMO ELECTRON MODEL 10

Response Time (0-90%)	1.5 sec -- NO mode; 1.7 sec -- NO _x mode
Zero Drift	Negligible after 1/2 hour warmup
Linearity	±1% of full scale
Accuracy	Derived from the NO or NO ₂ calibration gas, ±1% of full scale
Output	0-10 V
Operating Ranges	0-2, 5, 10, 25, 100, 250, 1000, 2500 and 10,000 ppm

O₂ ANALYZER, FUEL TYPE -- TELEDYNE MODEL 326

Response Time (0-90%)	60 seconds
Accuracy	±1% of scale at constant temperatures; ±1% of scale of ±5% of reading, whichever is greater, over the operating temperature range
Output	0-1 V
Operating Ranges	0-5%, 10%, 25% O ₂

CO₂/CO INFRARED ANALYZER -- ANARAD MODEL AR-600

Response Time (0-90%)	5 seconds
Zero Drift	±1%
Span Drift	±1%
Linearity	1%
Resolution	Less than 1% of full scale
Output	0-1 V
Operating Ranges	0-20% CO ₂ /0-10,000 ppm CO

CO GAS FILTER CORRELATION -- THERMO ELECTRON MODEL 48

Response Time (0-95%)	1 minute
Zero Drift	±0.2 ppm CO
Span Drift	Less than 1% full scale in 24 hours
Linearity	±1% full scale, all ranges
Accuracy	±0.1 ppm CO
Output	0-10 V
Operating Ranges	1, 2, 5, 10, 20, 50, 100, 200, 500, 1000 ppm

SO₂ UV ANALYZER -- DUPONT MODEL 400

Response Time (0-90%)	Less than 1 second
Zero Drift	Less than 1% full scale in 24 hours
Linearity	±1% full scale
Accuracy	±2% full scale
Output	0-5 V
Operating Ranges	0-100 ppm, 1-1000 ppm

STRIP CHART RECORDERS (3) -- MOLYTEK MODEL 2800

Pen Response	0.75 seconds Full Scale
Input Spans	10, 20, 50, 100 MV; 1, 5, 10 VDC
Zero Set	LH standard, adjustable to 100% of Full Scale
Accuracy	±0.25% of Span
Dead Band	±0.15% of Span
Linearity	±0.25% of Span
Chart Speed	0.5, 1, 2, 3, 6, 12 inches/hour; 0.5, 1, 2, 4, 10, inches/minute
Recording Pen	Fiber tip cartridge
Chart Width	10 inches

SCOTSMAN TRAILER

Fully Insulated	Air Conditioned -- 8 feet x 14 feet x 11 feet
-----------------	---

1. Filter 0.6 μ , 99.9999 percent efficient
2. Duct
3. 316 stainless steel probe
4. 3/8-inch, heated (250°F) Teflon
5. Four-pass conditioner-dryer, 316 stainless steel internals
6. 3/8-inch, unheated Teflon
7. Teflon-lined sample pump
8. 3/8-inch unheated Teflon
9. Rotameter
10. 1/4-inch Teflon tubing
11. Calibration gas manifold
12. Calibration gas selector valve
13. Calibration gas cylinders
14. Backpressure regulator
15. Auxiliary analysis port




FIGURE 4-1. SCHEMATIC OF CONTINUOUS MONITORING SYSTEM

Calibrations of the continuous analyzers were performed using EPA Protocol 1 calibration gases ($\pm 1\%$) for NO_x and NBS certified calibration gases ($\pm 1\%$) for CO , CO_2 and O_2 . Copies of the gas certifications are included in the Appendix of this report. All pertinent data (date, time, test locations, analyzer range, cal gas value) were recorded on both the field data sheets and continuous analyzer strip charts in the field.

At the start of a test day, a leak-check was performed. The sample probe was removed from the stack and the end was sealed. A leak-check was successful only if pressure at the analyzer system and flow through the rotameters to the individual analyzers all dropped to zero. A mandatory leak-check was performed at the completion of each test day.

An initial calibration was performed at the start of a test period by introducing zero and span gases for each analyzer and making the necessary adjustments. A multipoint linearity check was performed on each analyzer to insure all points were within $\pm 2\%$ of full scale. An NO_2 to NO converter check was performed to insure converter efficiency was greater than 90%. And, finally, the upscale and downscale response time of the sampling system was measured to insure the sampling time per point could be set at 1-minute plus the system response time. Calibration gas values were recorded on the continuous monitor strip charts and field data sheets. A calibration check was completed at the end of a test and adjustments (if necessary) to the analyzers were made in preparation for another test.

An external calibration of the sampling system was performed at the start of a test day. EPA Protocol 1 gas was flowed through the entire sampling system from the probe tip. The response of the analyzers

had to be within $\pm 5\%$ of the certified tank value before testing could proceed. An external calibration was also performed at the end of each test day.

Test data was collected by recording 10-minute averages from the strip chart recordings onto the field data sheets. Data collected over the test period was averaged and reported. A fuel analysis was used to calculate the F-factor, dscf/MMBtu corrected to zero percent O_2 (standard conditions $60^\circ F$, 29.92 inches Mercury), as described in 40 CFR 60.45. The pollutant concentration and the F-factor were used to calculate an emission factor in lb/MMBtu.

4.6 SAMPLING PROCEDURES FOR HYDROCARBONS

The sampling train for hydrocarbons consisted of a probe (short piece of stainless steel), a Tygon sample line, a Tedlar bag and a hand pump. The entire train was purged with stack gas three times before collecting a sample. An integrated grab sample of the stack gases was collected over the test period. After sample collection, the Tedlar bag was lowered to the mobile lab for subsequent analysis. Duplicate grab samples were collected during the test series.

4.7 PREPARATION OF H_2S SAMPLING TRAIN

All sampling train components were cleaned in the laboratory (soap and water, tap water rinse, distilled water rinse, and IPA rinse) to eliminate previous contamination.

EPA Method 11, with cadmium sulfate as the absorbing solution, was used to collect H_2S . Samples were collected from the gas stream using the following sampling train:

- A Teflon sample line (3 feet long) to connect the impinger train to the duct
- An impinger train consisting of five midget impingers with glass connections (impinger 1 contained 15 mls of 3-percent H_2O_2 ; impingers 2, 3, and 4 each contained 15 mls of the 3 M cadmium sulfate absorbing solution; and, impinger 5 contained approximately 20 grams of silica gel)
- A control module containing a pump, control valves, gas meter, orifice meter, dual inclined manometer and temperature indicator with selector switch
- An umbilical cord to connect the control module and the sample train

4.8 SAMPLING PROCEDURES FOR H_2S

Tests were conducted in strict accordance with EPA Method 11. The entire sample train was assembled at the test site. An initial leak-check was performed at 5-inches Mercury vacuum to insure leakage was less than 0.002 cfm. After completing the leak-check, sample was drawn through the midget impinger train at approximately 0.13 cfm for 4 hours. A final leak-check was performed after completing each test. The impinger train was transported to the mobile lab for sample recovery.

4.9 SAMPLE RECOVERY PROCEDURES FOR H_2S

Recovery of the EPA Method 11 sample train was performed in the mobile lab. The contents of the hydrogen peroxide impinger were discarded. The contents of impingers 2, 3, and 4 were quantitatively transferred to a labelled polyethylene sample bottle.

SECTION 5

ANALYSIS PROCEDURES

This section of the report describes the procedures used to analyze the samples collected during the test program. The fuel gas and hydrocarbon samples were sent to Pacific Gas Technology for analysis. All other analyses were performed in the Steiner Environmental laboratory in Bakersfield.

5.1 ANALYSIS OF PARTICULATE-SO_x SAMPLES

5.1.1 Nozzle, Probe, Filter Holder Wash

The volume of the acetone washings was measured and the washings were transferred to clean, tared, aluminum weighing dishes. The dishes were placed on temperature-controlled water bath under a fume hood and gently heated to dryness (100°F). The dishes with the dry residue were desiccated and weighed repeatedly at 6-hour intervals until a constant weight was achieved (to the nearest 0.01 mg with a tolerance of <0.1 mg between weighings). The ACS reagent grade acetone blank was treated in the same manner.

5.1.2 Filter

The 100-mm filter was removed from its petri dish and transferred to an oven where it was heated for 2 hours at 105°C. The filter was then desiccated and weighed repeatedly at 6-hour intervals until a constant weight was achieved (to nearest 0.01 mg with a tolerance of <0.1 mg

between weighings). An unused, tared blank filter was treated in the same manner.

5.1.3 Filterable Particulate Sulfate

The acetone washings residue and the 100-mm filter were combined and then leached with distilled water to remove sulfate and the leachate was diluted to 100 ml. An aliquot was passed through ion exchange resin and titrated against 0.01N BaCl₂ (which was previously standardized against 0.0100N H₂SO₄) using the barium-thorin titration procedure specified in EPA Method 8. The acetone blank and 100-mm filter blank were treated in an identical manner.

5.1.4 Condensable Particulate, Sulfate, and SO₂

The 47-mm glass fiber filter was leached with distilled water and the leachate was added to the contents and washings from impinger 1. The volume was measured and the entire volume was transferred to a clean, tared glass evaporating dish. The dish was placed on a temperature-controlled hot plate under a fume hood and gently heated to dryness (150°F). The dish with the dry residue was desiccated and weighed repeatedly at 6-hour intervals until a constant weight was achieved (to nearest 0.01 mg with a tolerance of <0.1 mg between weighings). The dry residue was dissolved in distilled water and diluted to 100 ml using distilled water and analyzed for sulfate using the barium-thorin titration procedure. A blank 47-mm filter and 80-percent IPA solution were treated in the same manner.

5.1.5 SO₂

The volume of contents and washings from bubbler 2 and impinger 3 was measured and an aliquot was analyzed for sulfate using the barium-thorin procedure. A 3-percent H₂O₂ blank was treated in the same manner.

5.2 ANALYSIS OF HYDROCARBON SAMPLES

The grab sample of hydrocarbons was analyzed using a Carle Model 211 AGC-FID. After purging the sample loop three times, a 1-ml sample was extracted from the Tedlar sample bag and injected onto a 6-foot long, 1/8-inch stainless steel column containing 80/100 mesh Porapak Q, maintained at 150°C. The C₁ hydrocarbon was separated and the greater than C₁ hydrocarbons were backflushed to the detector for quantitation as a single peak. An HP Model 3390A reporting integrator was used to record and integrate the signal from the GC. A ±1 percent certified calibration gas (C₁-C₆ HC in N₂) was used to calibrate the GC before and after sample analysis to quantitate the C₁ and greater than C₁ hydrocarbons. The beginning and end calibrations must agree within ±5% for the data to be acceptable.

5.3 ANALYSIS PROCEDURES FOR H₂S

In the laboratory, the contents of the sample bottle were transferred to an iodine flask along with the water rinsings. A known amount of iodine was added to the sample and acidified with 3 M HCl. The iodine flask was immediately stoppered and shaken. The flask was placed in the dark for 30-minutes. Standard 0.01 N sodium thiosulfate was used to standardize the iodine solution used each day of testing. Samples were titrated with the same sodium thiosulfate solution to an iodine/starch blue endpoint. The blank and standard solutions were handled in exactly the same manner.

5.4 FUEL ANALYSIS

A sample of the fuel gas fired during this test program was collected and sent to Pacific Gas Technology (PGT) for analysis. Analysis was performed by PGT in accordance with EPA Title 40 Section 60.45. The specific procedures are itemized in Table 5-1. The results appear at the end of this section.

TABLE 5-1. FUEL ANALYSIS METHODS
LABORATORY TEST PROCEDURES FOR FUEL OILS AND FUEL GASES

Reference: EPA Title 40, Section 60.45

FUEL OIL TESTS:

Sediment and Water, Vol. %	ASTM D4007-81
Gravity by Hydrometer (API)	ASTM D1298-80
API Gravity Corrected to 60°F	ASTM Table 5A
Gross Calorific Value (Btu/lb)	ASTM D2015-77
Ultimate Analysis (C, H, O, N, S, wt. %)	
Carbon, Hydrogen	ASTM D3178-73
Nitrogen (chemiluminescence detector)	ASTM D3431-80
Sulfur	ASTM D2622-82
Ash	ASTM D482
Oxygen	ASTM D3176-74

GASEOUS FUELS BY GAS-LIQUID CHROMATOGRAPHY:

Gas Analysis	ASTM D1945-81
Sulfur Analysis	CPA B16
Calculation of Gross Calorific Value	ASTM D3588-81
Component Weight %, F-factor calculations	EPA 40:60.45

PROCEDURES FOR SCRUBBER LIQUOR ANALYSIS:

Specific Gravity	ASTM D1429
Chlorides	ASTM D512-67

PACIFIC GAS TECHNOLOGY

RECEIVED



FEB 01 1991

Ans'd.....

4200 Easton Drive - Suite 5
 Bakersfield, California 93309
 805/324-1317
 Fax: 805/324-2746

GAS ANALYSIS BY CHROMATOGRAPH

PAPE & STEINER ENVIRONMENTAL SERVICES
 5801 Norris Road
 Bakersfield, CA 93308

Attention: Jim Steiner

Sample ID : SWEPI/COALINGA
 NATURAL GAS
 TEST #1

SAMPLED: JANUARY 29, 1991

SUBMITTED: JANUARY 31, 1991

REPORTED: JANUARY 31, 1991

LAB # 3315-1

P&S ID # : 22263

=====

ANALYZED GAS

	MOLE %	WT %	CHONS	WT %
OXYGEN	0.03	0.06	CARBON	71.90
NITROGEN	1.09	1.77	HYDROGEN	23.22
CARBON DIOXIDE	1.65	4.20	OXYGEN	3.11
HYDROGEN	ND	0.00	NITROGEN	1.77
CARBON MONOXIDE	ND	0.00	SULFUR	0.00
HYDROGEN SULFIDE	ND	0.00		
METHANE	93.78	87.10		
ETHANE	2.77	4.82		
PROPANE	0.50	1.28		
iso-BUTANE	0.04	0.13		
n-BUTANE	0.06	0.20		
iso-PENTANE	0.02	0.08		
n-PENTANE	0.01	0.04		
HEXANE +	0.05	0.31		

=====

SPECIFIC GRAVITY * :	0.596	SPECIFIC VOLUME :	22.07	cu ft/lb
HYDROGEN SULFIDE (Draeger) :	ppm			
TOTAL * DRY :	1018	NET * DRY :	918	
BTU/cu ft WET :	1000	BTU/cu ft WET :	902	
BTU/lb :	22470	BTU/lb :	20258	


=====

5-6
 * CALCULATED ACCORDING TO : ASTM D-3588

FEB 01 1991

Ans'd.....

4200 Easton Drive - Suite 5
 Bakersfield, California 93309
 805/324-1317
 Fax: 805/324-2746



GAS ANALYSIS BY CHROMATOGRAPH

PAPE & STEINER ENVIRONMENTAL SERVICES
 5801 Norris Road
 Bakersfield, CA 93308

SAMPLED: JANUARY 30, 1991

SUBMITTED: JANUARY 31, 1991

Attention: Jim Steiner

REPORTED: JANUARY 31, 1991

Sample ID : SWEPI/COALINGA
 NATURAL GAS
 TEST #1

LAB # 3315-2

P&S ID # : 25861

ANALYZED GAS

	MOLE %	WT %	CHONS	WT %
OXYGEN	0.02	0.04	CARBON	72.00
NITROGEN	1.03	1.67	HYDROGEN	23.28
CARBON DIOXIDE	1.62	4.14	OXYGEN	3.04
HYDROGEN	ND	0.00	NITROGEN	1.67
CARBON MONOXIDE	ND	0.00	SULFUR	0.00
HYDROGEN SULFIDE	ND	0.00		
METHANE	93.79	87.30		
ETHANE	2.94	5.13		
PROPANE	0.45	1.15		
iso-BUTANE	0.04	0.13		
n-BUTANE	0.06	0.20		
iso-PENTANE	0.02	0.08		
n-PENTANE	0.01	0.04		
HEXANE +	0.02	0.11		

SPECIFIC GRAVITY * : 0.595

SPECIFIC VOLUME : 22.12 cu ft/lb

HYDROGEN SULFIDE : ppm
 (Draeger)

TOTAL * DRY : 1018
 BTU/cu ft

NET * DRY : 917
 BTU/cu ft

WET : 1000

WET : 901

BTU/lb : 22516

BTU/lb : 20292

SECTION 6

QUALITY ASSURANCE

This section of the report describes the QA/QC procedures employed on the test program.

6.1 PARTICULATE/SO_x SAMPLING EQUIPMENT

A detailed record of repair and maintenance to each sampling train is kept. Preventative maintenance to each system is performed periodically to avoid complete component breakdown during a field test.

A detailed record of sampling system calibrations is also kept. Calibration data for the sampling nozzles, pitot tubes, dry gas meters and orifice meters are available for review. Results of the EPA Quality Assurance Branch biannual audits of the dry gas meter and orifice meter combinations are also logged and verify our in-house calibration data. The calibration data for the equipment used on this program can be found in the Appendix of this report.

6.2 LAB ANALYSIS

All field samples are assigned a label and an ID number. This ID is also affixed to a chain-of-custody log and to the field data sheet to eliminate any chance of sample mixup.

Prior to analysis, all glassware is thoroughly cleaned (soap and water, tap water rinse, distilled water rinse, IPA rinse) to eliminate any contamination. The evaporating dishes used to evaporate the washings

are treated the same as a sample (dried in an oven, desiccated and weighed repeatedly at 6-hour intervals until a constant weight is achieved). The glassware used to measure volumes and make transfers and dilutions are all NBS Class A to insure accurate measurements. All weighings are carried out on a Sartorius Research Model R160P electronic semi-micro balance supported by a marble table in a separate room from the main analytical laboratory. The balance is calibrated regularly against an NBS Class S-1 weight.

All reagents used in the field and in the laboratory are ACS reagent grade and blanks of these reagents are evaluated for every set of tests. Blanks are taken in the field from the squeeze bottles and not the original container. Records are kept on these blanks to insure consistent quality of the reagents. Prior to use, the IPA is also analyzed to insure no peroxides are present which could lead to high SO_3 and low SO_2 values.

A quality control program consisting of duplicate analyses (to measure precision), spikes (to measure recovery efficiency) or analysis of blind standards supplied by EPA's Quality Assurance Branch (to measure accuracy) is implemented for each test program. Table 6-1 summarizes the results of the QC checks on this program. Records of our lab's participation in the EPA bi-annual audits for SO_2 are kept on file and verify our in-house QA/QC effort.

6.3 QUALITY ASSURANCE OF HYDROCARBON ANALYSES

Each sample container was purged in the field with sample prior to the actual tests. A certified gas was used to calibrate the gas chromatograph used to measure the hydrocarbons. The calibration certificate

for the gas used appears at the end of this section. Duplicate analyses of some samples were conducted. The results of these quality assurance checks are included in Table 6-1.

6.4 CONTINUOUS MONITORS QUALITY ASSURANCE

The NO_x analyzer is calibrated before and after each test using an EPA Protocol 1 gas ($\pm 1\%$) traceable to NBS. The CO, CO₂ and O₂ analyzer are calibrated before and after each test using a NBS certified gas mixture ($\pm 1\%$). Copies of the calibration gas certificates appear in the Appendix of this report.

A sampling system check was performed at the beginning and end of each test day. This was done by introducing an EPA Protocol 1 gas at the sampling probe and measuring the system response. The purpose of this was to check the system for leaks and sample loss.

Multipoint calibration linearity checks of the continuous analyzers were performed on May 15 and 16, 1990. These results were well within CARB limitations of $\pm 2\%$ of full scale. Tables 6-2 through 6-7 list the results of these checks.

All of the EPA Method 20 QA/QC checks (e.g., linearity, interference, response time, converter efficiency, etc.) were performed on the continuous monitoring system and the system passed these requirements.

TABLE 6-1. QA/QC RESULTS

<u>Unit #</u>	<u>Test #</u>	<u>Test Parameter</u>	<u>Dupl. (%)</u>	<u>Rec (%)</u>
101A	1	Filterable Sulfate	107.1	
	2	Filterable Sulfate EPA SO ₂ 0882 6XXX		99.6 99.9
101A	1	Condensable Sulfate	83.3	
	2	Condensable Sulfate EPA SO ₂ 0882 6XXX	99.5	99.9
101B	1	Filterable Sulfate	100.0	
	2	Filterable Sulfate		99.5
101B	1	Condensable Sulfate	100.0	
	2	Condensable Sulfate		99.6

TABLE 6-2. NO_x CALIBRATION AND LINEARITY CHECKS (Concluded)

Range 0 - 100 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	(NO _x) out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9500	—	0	0	0
80% URL	9244.9	257.1	80.5	80.5	0
1	9307.3	193.2	60.5	61.3	+ .8
2	9372.3	129.3	40.5	42	+1.5
3	9437.2	65.1	20.4	21.5	+1.1

TABLE 6-3 CO CALIBRATION AND LINEARITY CHECKS (Concluded)

Range 0 - 20 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	(CO) out ppm	Chart ppm	% Difference +2% Full Scale
Zero	9500	--	0	0	0
80% URL	8735	762	16.01	16.01	0
1	8925.2	571.5	12.01	12.00	- .01
2	9120	381.5	8.02	8.00	- .02
3	9304.8	191.3	4.02	4.1	+ .4

TABLE 6-5 CO CALIBRATION SUMMARY

1. Monitoring Trailer 1 2. Calibration by JP 5/16/90

3. Analyzer ANARAD 4. Calibrator
 Model AR 602 Manufacturer Environics
 S/N 1482 Model 201-1520
 5. CO Standard AAL5660 S/N 1122
 Concentration 9942
 Cylinder Pressure 1550

CO CALIBRATION AND LINEARITY CHECKS

Range 0 - 10,000 ppm

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	(CO) out ppm	Chart ppm	% Difference +2% Full Scale
Zero	1000	—	0	0	0
80% URL	187.2	815.4	8065	8065	0
1	392.0	609.3	6050	6050	0
2	594.4	406.1	4045	4180	+1.35
3	791.7	203.1	2030	2220	+1.9

Form MULTI-4.(6/90)

TABLE 6-6 O₂ CALIBRATION SUMMARY

1. Monitoring Trailer 1 2. Calibration by JP 5/17/90

3. Analyzer Teledyne 4. Calibrator
 Model 326A Manufacturer Enviro-nics
 S/N 36423 Model 201-1520
 5. O₂ Standard A14762 S/N 1122
 Concentration 45%
 Cylinder Pressure _____

O₂ CALIBRATION AND LINEARITY CHECKS

Range 0 - 25 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	(O ₂) out %	Chart %	% Difference +2% Full Scale
Zero	2000	—	0	0	0
80% URL	116.5	890.9	19.97	19.97	0
1	1338.8	668.3	14.98	15.05	+ .28
2	1561.1	445.9	10.00	10.05	+ .2
3	1783.4	223.6	5.01	5.30	+1.16

Range 0 - 10 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	(O ₂) out %	Chart %	% Difference +2% Full Scale
Zero	2000	—	0	0	0
80% URL	1648.5	357.1	8.00	8.00	0
1	1738.5	268.2	6.00	6.12	+1.20
2	1828.4	179.0	4.01	4.20	+1.9
3	1918.3	90.4	2.03	2.2	+1.7

TABLE 6-6 O₂ CALIBRATION AND LINEARITY CHECKS (Concluded)

Range 0 - 5 %

Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	(O ₂) out %	Chart %	% Difference +2% Full Scale
Zero	7000	—	0	0	0
80% URL	6379.7	623.3	4.00	4.00	0
1	6534.6	467.7	3.00	3.05	+1.0
2	6689.5	312.0	2.00	2.05	+1.0
3	6844.3	156.8	1.00	1.09	+1.8

TABLE 6-7 CO₂ CALIBRATION SUMMARY

1. Monitoring Trailer 1 2. Calibration by JP 5/16/90

3. Analyzer ANARAD CO₂ 4. Calibrator
 Model AR602 Manufacturer Environics
 S/N 1482 Model 201-1520
 S/N 1122

5. CO₂ Standard AAL799
 Concentration 20%
 Cylinder Pressure 950

CO₂ CALIBRATION AND LINEARITY CHECKS

Range 0 - 20 %


Calibration Points	Flow, Dil. cc/min	Flow, Std. cc/min	(CO ₂) out %	Chart %	% Difference +2% Full Scale
Zero	1015	---	0	0	0
80% URL	204.7	800.9	15.9	15.9	0
1	399.5	601	12.01	12.01	-.25
2	599.4	400.9	8.02	7.98	-.20
3	794.2	201	4.03	3.92	-.55

Form MULTI-6.(6/90)

APPENDIX A
STEINER ENVIRONMENTAL RAW DATA

SAMPLING POINT LOCATION DATA SHEET

Plant SWEPI COALINGA
 Date 1-28-91
 Test Location HRS6 101A
 Upstream Dist./Dia. 48" / 1.0 ϕ
 Downstream Dist./Dia. 96" / 2.0 ϕ
 No. of Sampling Points 28
 Stack Dimension 47.5 x 47.5
 Coupling Length 7"
7-4 -inch MPT/FPT/Flang



4 chains 100' power
 4 adapters 75' rope

Future tests use A, C, E, G 24 points
 see 101-B


XEQ PNT

Sample Point	Dist	Sample Point	Dist	Sample Point	Dist	Sample Point	Dist
1	12.9						
2	24.8						
3	36.7						
4	48.6						

SAMPLING POINT RELOCATION: NONE

SAMPLING POINT LOCATION DATA SHEET

Plant SWEPI Coalinga
 Date 1/30/91
 Test Location HRS6 101 B
 Upstream Dist./Dia. 48" / 1.0 ϕ
 Downstream Dist./Dia. 96" / 2.0 ϕ
 No. of Sampling Points 24
 Stack Dimension 47.5 x 47.5
 Coupling Length 7
7, 4 -inch MPT/FPT/Flang



XEQ PNT *4 chains 100' power*
4 adaptors 75' rope *Future tests use A, C, E, G 24 points total*

Sample Point	Dist	Sample Point	Dist	Sample Point	Dist	Sample Point	Dist
1	10.4						
2	17.2						
3	24.0						
4	30.8						
5	37.5						
6	44.3						

SAMPLING POINT RELOCATION: *none*

Coalings

Date 1/29/91
 Barometric Pressure 28.81
 Test Location HRS6 OUT
 Static in. wg. - 0.11
 Run Number 101A - 1
 Probe Type/Length G/L1
 Stack Diameter 415.475
 Pitot Coefficient 0.84
 Operator JB
 Meter Box No./X 779/1.0002
 Filter No. 234
 Nozzle No./Size 270/1.3020

Impinger Volumes/Weights				Gas Composition			
Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
80% IPA	626.0	536.3	89.7				
3% H ₂ O	609.2	568.8	40.4				
3% H ₂ O	574.3	550.7	23.6				
S.G.	854.5	791.5	63.0	Leak Rate	cfm	"Hg	
		Total	214.7	Initial		0.018	15
				Final		0.012	8.5

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	Temperature °F				Gas Meter In	Gas Meter Out	Pump Vacuum in. Hg	√ΔP	Comments
					Stack	Probe	Oven	Imp.					
G 1	4:40	0.440	2.26	19.822	283	230	254	42	52	50	5.5	0.632	pitot ok
G 2	5	0.435	2.45	23.810	281	225	263	42	53	45	6.5	0.660	22265
G 3	10	0.425	2.46	27.973	266	254	257	41	58	46	6.5	0.652	22263
G 4	15	0.350	2.10	32.164	244	261	251	41	62	48	6.0	0.592	22262
G 20	20			36.138									
E 1	5:05	0.420	2.51	36.138	245	275	242	40	54	51	6.5	0.648	22256
E 2	5	0.425	2.57	40.338	245	270	270	38	67	53	7.0	0.652	22255
E 3	10	0.425	2.63	44.670	231	261	265	39	68	54	7.5	0.652	22254
E 4	15	0.385	2.40	49.062	227	225	262	39	69	55	7.0	0.620	22253
E 20	20			53.307									
C 1	5:25	0.435	2.63	53.307	243	244	258	40	60	55	8.0	0.660	22252
C 2	5	0.435	2.66	57.655	244	249	267	41	69	57	8.5	0.660	
C 3	10	0.410	2.58	62.105	223	246	250	44	70	58	7.5	0.640	
C 4	15	0.255	1.59	66.450	228	237	230	44	70	57	5.0	0.505	

PLANT SWEPI Coalinga TEST TYPE H5/B FIELD TEST DATA SHEET (Page 2 of 3)
 DATE 1/29/91 RUN NO. 1
 TEST LOCATION 101-A Out OPERATOR jt

Sample Point	Time	AP in wg	AH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F						Pump Vacuum in. Hg	√AP	Comments	
					Stack	Probe	Oven	Imp.	Gas Meter					
									In	Out				
20	20			70.133										
A 1	5:52	0.435	2.53	70.133	270	253	225	40	59	56	6.5	0.660		
2	5	0.415	2.50	74.330	254	248	228	41	70	59	7.0	0.644		
3	10	0.385	2.39	78.619	234	226	225	42	70	58	6.5	0.620		
4	15	0.300	1.84	82.815	236	226	250	40	66	65	5.5	0.548		
	20			86.640										
F 1	6:25	0.420	2.50	86.640	249	268	267	39	55	54	6.0	0.648		
2	8	0.430	2.61	90.880	249	258	270	40	69	57	7.0	0.656		
3	10	0.408	2.49	95.240	240	254	265	40	69	57	7.0	0.636		
4	15	0.355	2.21	99.535	230	249	260	47	70	58	6.0	0.596		
	20			103.677										
D 1	6:58	0.425	2.59	103.677	239	257	239	41	60	56	7.0	0.652		
2	5	0.415	2.53	108.045	244	238	263	44	69	58	7.0	0.644		
3	10	0.415	2.61	112.345	224	247	238	43	69	57	7.0	0.644		
4	15	0.375	2.36	116.698	223	230	261	42	69	58	6.5	0.612		
	20			120.903										

IMPIINGER	VOLUMES/WEIGHTS			GAS COMPOSITION				
	Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
	80% IPA	619.7	541.1	78.6				
	3% H ₂ O ₂	595.5	541.9	53.6				
	3% H ₂ O ₂	550.0	530.1	19.9				
	S.G.	817.5	759.0	58.5	Leakrate			mg
			TOTAL	210.6	Initial	0.003		15
					Final	0.016		8

Date 1/29/91 Barometric Pressure 28.91
 Test Location 101-A Out Static in.wg. -0.16
 Run Number 2 Probe Type/Length 6/6'
 Stack Diameter 47.5 x 47.5 Pitot Coefficient 0.84
 Operator JF Meter Box No./Y 779/1.0002
 Filter No. 234 Nozzle No./Size 270/1.3020

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F						Pump Vacuum in. Hg.	√ΔP	Comments
					Stack	Probe	Oven	Imp.	Gas Meter				
									In	Out			
B 1	8:40	0.435	2.63	151.885	242	244	268	40	57	57	6.0	0.660	airlock
2	5	0.425	2.58	156.266	244	227	263	37	62	67	6.0	0.652	22261
3	10	0.410	2.59	160.662	220	226	275	38	67	57	6.0	0.640	22260
4	15	0.355	2.22	165.028	227	226	256	41	70	58	5.5	0.596	22259
	20			169.188									
D 1	9:00	0.410	2.54	169.188	234	225	249	43	64	61	6.0	0.640	22258
2	5	0.405	2.54	173.568	236	225	275	46	77	64	6.5	0.636	
3	10	0.405	2.60	177.959	218	226	250	49	76	63	6.5	0.636	
4	15	0.375	2.41	182.500	218	226	259	49	77	65	6.0	0.612	22257
	20			186.867									
F 1	9:20	0.410	2.52	186.867	246	228	273	46	70	66	6.0	0.640	22264
2	5	0.400	2.49	191.280	242	230	245	45	78	68	6.0	0.632	
3	10	0.385	2.43	195.730	233	232	274	45	78	68	6.0	0.620	

PLANT SWEPI Cooling TEST TYPE MS/B FIELD TEST DATA SHEET (Page 2 of 3)
 DATE 1/29/91 RUN NO. 2
 TEST LOCATION 101A - Out OPERATOR JR

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F						Pump Vacuum in. Hg	√ΔP	Comments
					Stack	Probe	Oven	Imp.	Gas Meter				
									In	Out			
4	15	0.365	2.34	200.087	223	227	256	47	79	68	5.5	0.604	
A	20 9:34			204.347									
1		0.420	2.51	204.347	267	228	260	49	71	68	6.0	0.648	
2	5	0.400	2.39	208.450	273	229	269	50	78	69	6.5	0.632	
3	10	0.390	2.47	212.788	233	229	265	50	80	69	6.5	0.624	
4	15	0.285	1.79	217.220	240	227	275	51	80	69	5.0	0.534	
C	20 10:17			221.121									
1		0.410	2.56	221.121	237	223	249	46	72	68	6.5	0.640	
2	5	0.400	2.51	225.293	241	231	234	50	80	70	8.0	0.632	
3	10	0.400	2.59	229.765	219	230	225	52	80	70	6.5	0.632	
4	15	0.225	1.45	234.251	222	228	247	50	80	70	4.0	0.474	
E	20 10:34			237.794									
1		0.415	2.57	237.794	244	232	253	48	73	70	6.5	0.644	
2	5	0.415	2.58	242.282	245	230	242	46	78	70	6.5	0.644	
3	10	0.415	2.65	246.900	227	230	230	47	79	70	7.0	0.644	
4	15	0.380	2.45	251.315	223	228	241	46	81	70	6.5	0.616	
	20			255.630									

IMPINGER	VOLUMES/WEIGHTS			GAS COMPOSITION				
	Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
	80% IPA	590.5	533.0	57.5				
	3% H ₂ O ₂	597.5	554.3	43.2				
	3% H ₂ O ₂	591.7	566.8	24.9				
	S.G.	817.5	763.1	54.4	Leakrate			
			TOTAL	180.0	Initial	0.010		15
					Final	0.006		6

Date 1/20/91 Barometric Pressure 28.92
 Test Location HRSG-101B Static in.wg. -20
 Run Number 1 Probe Type/Length 6/6'
 Stack Diameter 42.5x47.5 Pitot Coefficient 0.84
 Operator JG Meter Box No./Y 779/1.0002
 Filter No. 243 Nozzle No./Size 870/1.3020

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	TEMPERATURE °F						Pump Vacuum in. Hg.	ΔP	Comments
					Stack	Probe	Oven	Imp.	Gas. Meter				
									In	Out			
A 1	4:46	0.415	2.41	280.729	225	235	39	40	47	4.5	0.644	pitot ok	
A 2	5	0.415	2.43	284.830	225	234	37	57	48	5.0	0.644	22268	
A 3	10	0.420	2.60	288.974	226	234	36	62	49	5.5	0.656	707-B	
A 4	15	0.420	2.64	293.300	227	250	39	67	52	5.5	0.648	22267	
A 5	20	0.385	2.40	297.580	227	225	38	70	54	5.0	0.620	101-B	
A 6	25	0.340	2.04	301.770	229	234	38	73	56	4.5	0.583	22266	
	30			305.660									
C 1	0	0.420	2.57	305.660	229	275	43	62	57	5.0	0.656	25864	
C 2	5	0.440	2.66	309.925	230	275	44	76	61	5.5	0.663	25863	
C 3	10	0.425	2.66	314.273	229	267	46	76	61	5.5	0.652	25862	
C 4	15	0.425	2.72	318.675	230	226	49	76	62	6.0	0.652	25862	
C 5	20	0.340	2.18	323.132	230	225	52	76	62	5.0	0.583	25861	
C 6	25	0.235	1.46	327.179	230	225	52	77	63	4.0	0.485	25861	
	30			330.647									

Date 1/30/91 Barometric Pressure 29.00
 Test Location 101B-OUT Static in.wg. -0.21
 Run Number 2-101-B Probe Type/Length 6/6'
 Stack Diameter 47.5x72.5 Pitot Coefficient 0.84
 Operator JL Meter Box No./Y 779/1.0002
 Filter No. 236 Nozzle No./Size 270/1.3020

IMPIGGER	VOLUMES/WEIGHTS			GAS COMPOSITION				
	Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
	80% IPA	545.3	539.7	55.6				
	3% H ₂ O	576.6	543.3	53.3				
	3% H ₂ A	555.3	531.5	23.8				
	S.G.	866.8	805.0	61.8	Leakrate			"Hg
			TOTAL	194.5	Initial	0.015		15
					Final	0.005		6

Sample Point	Time	TEMPERATURE °F						Gas Meter Volume Ft ³	ΔH in wg	ΔP in wg	AP in wg	Stack	Probe	Oven	Imp.	Gas Meter		Pump Vacuum in.Hg.	ΔP	Comments
		In	Out																	
				In	Out															
A	7:32															66	65	5.0	0.622	Pitot ok
	0						394.925	2.39	0.400		263	230	225	64		70	60	5.5	0.648	FHWZ 25856
	10						403.370	2.64	0.470		258	235	243	54		76	62	6.0	0.648	JPA 25860
	20						407.715	2.67	0.415		230	240	252	52		79	65	6.0	0.644	BHWZ 25859
	30						412.117	2.47	0.385		220	241	267	52		83	67	5.5	0.620	AMF 25858
	8:15						416.445	1.95	0.215		226	240	269	53		84	70	4.5	0.561	HC 25857
C	0						420.409				253	242	267	53						
	10						420.409	2.67	0.435		252	250	275	61		75	71	5.5	0.660	
	20						424.810	2.88	0.465		254	246	276	59		83	72	6.0	0.682	
	30						429.390	2.77	0.435		233	251	275	57		83	72	6.0	0.660	
	10						433.980	2.84	0.435		218	260	268	59		83	73	6.0	0.660	
	20						438.610	2.37	0.365		219	242	264	59		82	72	5.5	0.604	
	30						442.950	1.58	0.250		237	247	261	59		82	72	4.0	0.500	
							447.116													

BHWZ 23747
 FHWZ 23748
 AMF 23749
 HC 23750
 JPA 23751
 BHWZ 23752
 AMF 23753
 HC 23754
 JPA 23755
 BHWZ 23756
 AMF 23757
 HC 23758
 JPA 23759
 BHWZ 23760
 AMF 23761
 HC 23762
 JPA 23763
 BHWZ 23764
 AMF 23765
 HC 23766
 JPA 23767
 BHWZ 23768
 AMF 23769
 HC 23770
 JPA 23771
 BHWZ 23772
 AMF 23773
 HC 23774
 JPA 23775
 BHWZ 23776
 AMF 23777
 HC 23778
 JPA 23779
 BHWZ 23780
 AMF 23781
 HC 23782
 JPA 23783
 BHWZ 23784
 AMF 23785
 HC 23786
 JPA 23787
 BHWZ 23788
 AMF 23789
 HC 23790
 JPA 23791
 BHWZ 23792
 AMF 23793
 HC 23794
 JPA 23795
 BHWZ 23796
 AMF 23797
 HC 23798
 JPA 23799
 BHWZ 23800

Date 1-29-91 Barometric Pressure 28.81
 Test Location Ind Gas Supply Static in. wg. N/A
 Run Number 1 Probe Type/Length SS-3'
 Stack Diameter N/A Pitot Coefficient N/A
 Operator SM/SC Meter Box No. 18 BIT/9875
 Filter No. N/A Nozzle No./Size STRAIGHT

Impinger Volumes/Weights				Gas Composition			
Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
39/12/2		95.9					
CD 504		106.3					
CD 504		109.1					
S.G.		105.4	Total	Leak Rate		cfm	"Hg
				Initial		.003	MAX
				Final		.004	MAX

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	Stack	Probe	Temperature °F			Imp.	Gas Meter In	Gas Meter Out	Pump Vacuum in. Hg	√ΔP	Comments
							Oven	Imp.	Out						
	0557	N/A	N/A	050.263	N/A	N/A	N/A	56	41	41	N/A				
	0612			058.820			40	43	41						
	0627			063.820			39	44	41						
	0646			068.960			37	44	41						
	0701			072.940			36	43	40						
	0716			077.010			37	44	41						
	0732			080.490			37	45	42						
	0747			088.260			39	47	45						
	0825			093.430			42	49	49						
	0845			097.140			44	54	54						
	0901			099.805			46	56	56						
T/A				49.542					45.50						

25846

Date 1-30-91
 Test Location Fuel Gas Supply
 Run Number 2
 Stack Diameter N/A
 Operator SM/SL
 Filter No. N/A
 Barometric Pressure 28.92
 Static in. wg. N/A
 Probe Type/Length SS-3'
 Pitot Coefficient N/A
 Meter Box No./8 Port / 9875
 Nozzle No./Size STRAIGHT

Impinger Volumes/Weights				Gas Composition			
Contents	Final	Initial	Net	Time	CO ₂	O ₂	CO
S.G.				Leak Rate			
				Initial			
				Final			
	Total						

Sample Point	Time	ΔP in wg	ΔH in wg	Gas Meter Volume Ft ³	Stack	Probe	Temperature °F			Imp.	Gas Meter In	Gas Meter Out	Pump Vacuum in. Hg	√ΔP	Comments
							Oven	Imp.	Out						
0810		N/A	N/A	105.550	N/A	N/A			66	56	53	N/A			
0837				107.037					55	62	60				
0905				108.255					59	62	60				
0928				108.795					61	62	64				
0948				109.850					62	63	68				
1025				111.045					65	67	71				
1029				113.305					58	66	72				
1054				115.373					58	66	72				
1110				117.460					59	65	70				
1125				123.675					57	65	70				
1140				126.554					57	65	70				
T/A				21.004						65	16				

INCREASE FLOW
THAN IMP.

CONTINUOUS MONITOR DATA SHEET

Plant WUEPI CALUMIA / APCD Witness/Number
 Date 1-29-91 Run No. INT CAL 1 Client Rep Ken Riepatrick
 Test Location HRS6 101A OUT Operator DM Generator Type N/A
 Fuel Type AAI Gas Trailer No. 1 Burner Type N/A
 O₂ Controller Type N/A

Time	Sample Point	Dry Uncorrected							Comments	Miscellaneous Information	
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO ₂ ppm				
0315		14.58	8.02	15.75				81.5		High Span Gas Value	NO. 94437, 2207, <small>CO₂ = 2062</small>
		7.22	4.92	8.21				50.9		M.R.	SO ₂ N/A
		0.0	0.0	0.0				0.0		Zero	CO 86236
		14.58	8.02	15.75				81.5		Steadily High	CO/CO ₂ /O ₂ 68762, 6096, 65300
		7.25	4.75	8.04				50.4		High	
		0.0	0.0	0.0				0.0		Zero	
		0.0	0.0	0.0				0.0		INTERFERENCE	Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
		14.25	4.79	8.05				50.4		EXT SPAN	RESPONSE TIME
		.15	-	-				-		EXT ZERO	Upscale: 32.0 Downscale: 34.7
		14.82	3.55	4.00				38.1		Run # 1 101A	Upscale: 37.4 Downscale: 35.3
0440		14.87	3.57	4.00				38.0			Upscale: 37.5 Downscale: 34.4
0450		15.00	3.50	4.15				38.0			Fuel Flow: _____
0510		15.00	3.20	4.05				38.1			Steam Flow: _____
0520		15.00	3.10	4.07				38.2			Rating: _____
0530		15.00	3.30	4.07				38.0			PROCESS DATA
0540		0.0	.05	.05				-1.3		Zero	CONVERTER GAS
		14.45	4.64	8.20				50.2		Span	Cal Gas Values Actual Values
											NO <u>34.57</u> <u>40.1</u>
											NO ₂ <u>17.0</u> <u>18.1</u>
											Conv. Efficiency: <u>93.92%</u>

CONTINUOUS MONITOR DATA SHEET

Plant SWEET COALING A
 Date 1-29-91 Run No. 223
 Test Location HRSG-OUT 101-A
 Operator SM/SC
 Fuel Type NAT GAS Trailer No. 1

APCD Witness/Number _____
 Client Rep KEN KIRKPATRICK
 Generator Type ALLISON CTG "501" KBS
 Burner Type N/A
 O₂ Controller Type N/A

Time	Sample Point	Dry Uncorrected								NO _x ppm	Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	NO _x ppm	NO _x ppm			
		14.58	4.92	8.21			50.9				SPAN GAS VALUES	CALIBRATION GASES SAME AS 19-1
		0.0	0.0	0.0			0.0				ZERO	
0616		14.62	3.56	4.26			38.5				RUN # 2 101-A	
0626		14.62	3.54	4.26			38.5					
0636		14.62	3.53	4.14			38.5					
0646		14.62	3.56	4.32			38.5					
0656		14.62	3.56	4.24			38.2					
0706		14.62	3.56	4.24			38.1					
0716		0.0	0.0	0.0			0.0				ZERO	
		14.27	5.00	8.21			50.6				SPAN	
0830		14.95	3.44	4.10			39.0				RUN # 3 101-A	RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: _____ CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____
0840		14.95	3.44	4.10			40.1					
0850		14.95	3.44	4.40			40.3					
0900		14.95	3.44	4.20			40.9					
0910		14.95	3.44	4.44			40.9					
0920		14.95	3.44	4.70			40.9					
0930		0.0	0.0	0.0			1.50				ZERO	
		14.40	5.00	8.18			52.7				SPAN	

CONTINUOUS MONITOR DATA SHEET

Plant SAEPI COALINGA APCD Witness/Number _____
 Date 1-29-91 Run No. 4 Client Rep GEN KIRKPATRICK
 Test Location HRSG OUT Generator Type ACCISON CTG "501" ABS
 Operator SM/SC Burner Type N/A
 Fuel Type NAT GAS Trailer No. 1 O₂ Controller Type N/A

Time	Sample Point	Dry Uncorrected								Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm				
		14.58	4.92	8.21				50.9		SPAN GAS VALUES	CALIBRATION GASES SAME AS PG. #1 NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____ Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____ RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: _____ CONVERTER GAS Cal Gas Values Actual Values NO _____ _____ NO ₂ _____ _____ Conv. Efficiency: _____
		0.0	0.0	0.0				0.0		ZERO	
1000		14.97	3.46	4.60				39.0		RUN # 4 101-A	
1010		15.00	3.46	4.40				38.0			
1020		15.00	3.48	4.42				38.0			
1030		15.00	3.60	4.40				38.0			
1040		15.00	3.48	4.20				38.1			
1050		15.00	3.50	4.60				38.0			
1100		0.32	0.03	0.0				1.50		ZERO	
		14.50	4.80	8.06				52.6		SPAN	
		14.37	4.92	8.20				51.3		EXT. SPAN	
		0.25	-	-				-		EXT ZERO	

CONTINUOUS MONITOR DATA SHEET

Plant SWEPZ CEALINGA
 Date 1-30-91 Run No. INT CAL 1
 Test Location HR56-OUT 101 B
 Operator SM/SC
 Fuel Type Not Gd Trailer No. 1


APCD Witness/Number _____
 Client Rep Ken Kirkpatrick
 Generator Type ALLISON C76 "501" N35
 Burner Type N/A
 O₂ Controller Type N/A

Time	Sample Point	Dry Uncorrected						NO _x ppm	Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm			
		14.58	4.92	8.21			50.9	Span Gas Value	CALIBRATION GASES NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____ Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____ RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ PROCESS DATA Fuel Flow: _____ Steam Flow: _____ Rating: _____ CONVERTER GAS Cal Gas Values Actual Values NO <u>34.91</u> _____ NO ₂ <u>17.0</u> _____ Conv. Efficiency: _____	
		0.0	0.0	0.0			0.0	Zero		
		14.58	4.50	7.99			50.3	EXT Span		
		15						EXT Zero		
0440		15.22	4.60	3.30			35.5	Run #1 101 B		
0450		15.25	4.66	3.28			36.0			
0500		15.25	4.64	3.28			36.1			
0510		15.25	4.68	3.26			36.3			
0520		15.25	4.60	3.26			36.4			
0530		15.27	4.54	3.26			36.3			
0540		0.0	0.05	0.0			-0.6	Zero		
		14.58	4.74	8.17			50.0	Span		
0600		15.00	3.20	4.66			36.5	Run #2 101-B		
0610		15.07	3.22	4.64			36.8			
0620		15.07	3.24	4.70			36.9			
0630		15.07	3.26	4.56			37.0			
0640		15.12	3.26	4.56			37.0			
0650		15.17	3.26	4.50			37.0			
0700		0.0	-0.25	0.08			0.0	ZERO		
		14.45	4.80	8.20			50.30	SPAN		

CONTINUOUS MONITOR DATA SHEET

Plant SWEPI COALING A APCD Witness/Number _____
 Date 1-30-91 Run No. 3 Client Rep KEN KIRK PATRICK
 Test Location HRS6 OUT 101-B Generator Type ALISON CTG "501" KBS
 Operator SC/SM Burner Type NA
 Fuel Type NAT. GAS Trailer No. 1 O₂ Controller Type N/A

Time	Sample Point	Dry Uncorrected							Comments	Miscellaneous Information
		O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm			
		14.58	4.92	8.21				50.9	SPAN GAS VALUES ZERO	NO _x _____ SO ₂ _____ CO _____ CO/CO ₂ /O ₂ _____ Wet Bulb: _____ Dry Bulb: _____ Barometric Press: _____
0735		14.90	3.18	4.86				40.20	RUN # 3 101-B	
0745		14.90	3.18	4.82				40.20		
0755		14.90	3.18	4.98				40.50		
0805		14.90	3.18	11.20				39.80		
0815		14.90	3.18	17.00				38.00		
0825		14.88	3.19	13.90				38.30		
0835		0.0	0.0	-1.0				1.0	ZERO	RESPONSE TIME Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____ Upscale: _____ Downscale: _____
		14.75	4.43	8.10				51.9	SPAN	
		14.25	4.30	8.22				51.5	EXT SPAN	
		1.35	-	-				-	EXT ZERO	
0902		14.75	3.57	15.40				36.7	Run #4	FUEL FLOW: _____ STEAM FLOW: _____ RATING: _____
0912		14.75	3.58	16.00				35.9		PROCESS DATA
0922		14.78	3.59	12.30				35.6		
0932		14.79	3.64	11.20				36.0		
0943		0.0	0.5	-1.05				-1.2	ZERO	CONVERTER GAS Cal Gas Values Actual Values NO _____ NO ₂ _____ Conv. Efficiency: _____
		14.45	5.20	8.20				46.8	SPAN	



(1527)

CHART NO. 414044

020 020-25% 0450 0460
 NOx=100ppm

SWEE COMING
 Run #1 HR24-OUT 101A
 3rd Hr 1-29-91

020 020-25% 0214.58%
 NOx=100ppm - NOx=80.9 ppm
 DOWNSCALE: 35.5%
 UPSCALE: 37.4%
 DOWNSCALE: 35.5%
 UPSCALE: 37.4%

020 020-25% 0214.25%
 NOx=0 - NOx=81.9 ppm
 NOx=0-100ppm - NOx=81.9 ppm

020 020-25% 0214.58%
 NOx=0 - NOx=81.9 ppm
 NOx=0-100ppm - NOx=81.9 ppm

020 020-25% 0214.58%
 NOx=0 - NOx=81.9 ppm
 NOx=0-100ppm - NOx=81.9 ppm

020 020-25% 0214.58%
 NOx=0 - NOx=81.9 ppm
 NOx=0-100ppm - NOx=81.9 ppm

020 020-25% 0214.58%
 NOx=0 - NOx=81.9 ppm
 NOx=0-100ppm - NOx=81.9 ppm
 NOx INTERFERENCE $\sqrt{= 0.0}$

(1927)


CHART NO. 414044

Chart-INC

(1537)

CHART NO. 414044


Chart-line




(1327)

CHART NO. 414044

Chart-Inc







SUPPLY CONTROL
 Run #4 HESG BUT NOT A
 See file 1-29-91

CHART NO. 414044 (1327)


Charts, Inc.





SWIFT COALING
 Run #1 HRS6-OUT 101B
 Run No. 1-30-91


(1527)







SWIFT COALING
 1-30-91

CHART NO. 414044



Chart-INC



Charts Inc




SNEPI
 Run #2 HRS6-OUT 101.8
 1-30-91



(1327)




CHART NO. 414044

Charts Inc



Sweep HRSG 101 B Run #4

SWEPT HRSG - OUT 101-B 1:30-91 3"/HR RUN #3



(1327)


CHART NO. 414044

Charts-Inc

(1527)


CHART NO. 414044

Charts Inc




(1527)




CHART NO. 414044




Charts, Inc.



SUPER CONLINEA
 Run #2 HRS6-OUT 101A
 Run Hr. 1-29-91



SUPER CONLINEA
 Run #1 HRS6-OUT 101A
 Run Hr. 1-29-91




(1527)

CHART NO. 412044

Charts, Inc.

Chart-Inc



CO₂ CO₂ 20 ppm

CO₂ CO₂ 20 ppm


SURE CALINGA
Run #3 HES6-OUT 101A
Sun Hr 1-29-91

CO₂ 2.0% - CO 2.49%

CO₂ 20 ppm - CO 2.21 ppm

CO₂ 2.0% - CO 2.00%


CO₂ 20 ppm - CO 2.21



CO₂ CO₂ 20%

CO₂ CO₂ 20 ppm

SURE CALINGA
Run #2 HES6-OUT 101A
Sun Hr 1-29-91




CO₂ 20 ppm - CO 2.21 ppm

(1527)

CHART NO. 414044


Chart-Inc



(1527)

CHART NO. 414044


Chart-Log




(1527)


CHART NO. 41404

Charts-Inc






Supers Head 101.0
Run #4



20.50



SNEPI
HRSG - OUT 101-B
1-20-91 3" / HR
RUN #3 SC

A. CALIBRATION AND CORRECTION DATA

Company : SWEPI COALINGA Date : 1/29/91
 Station : HRSG 101-A Test Run : 1
 Test Condition: GAS 100%

Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	14.82	14.83	3.55	3.57	4.00	4.00			38.10	38.15
2	14.87	14.90	3.57	3.62	4.00	3.99			38.00	38.15
3	15.00	15.06	3.50	3.58	4.15	4.14			38.00	38.25
4	15.00	15.08	3.20	3.30	4.05	4.04			38.10	38.45
5	15.00	15.10	3.10	3.22	4.07	4.05			38.20	38.65
6	15.00	15.12	3.30	3.47	4.07	4.05			38.00	38.55
MEAN		15.02		3.46		4.05				38.37

	%O2	%CO2	ppm CO	ppm SO2	ppm NOx
Span Check	14.45	4.64	8.20		50.20
Cal. Gas	14.58	4.92	8.21		50.90
Scf	-0.00149	-0.01118	-0.00122		-0.00131
Zcf	0.00000	0.00833	0.00833		-0.05000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : SWEPI COALINGA

Date : 1/29/91

Test Run : 2

Station : HRSG 101-A

Test Condition: GAS 100%

Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	14.62	14.65	3.56	3.56	4.26				38.50	38.52
2	14.62	14.70	3.54	3.53	4.26				38.50	38.56
3	14.62	14.75	3.54	3.52	4.14				38.50	38.59
4	14.62	14.80	3.56	3.53	4.32				38.50	38.63
5	14.62	14.86	3.56	3.52	4.24				38.20	38.37
6	14.62	14.91	3.56	3.51	4.24				38.10	38.31
MEAN		14.78		3.52	4.24					38.50

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.00		0.00		0.00				0.00
Span Check		14.27		5.00		8.21				50.60
Cal. Gas		14.58		4.92		8.21				50.90
Scf		-0.00354		0.00271						-0.00098
Zcf		0.00000		0.00000						0.00000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : SWEPI COALINGA Date : 1/29/91
 Station : HRSG 101-A Test Run : 3
 Test Condition: GAS 100%

Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	14.95	14.97	3.44	3.44	4.20	4.20			39.00	38.86
2	14.95	15.00	3.44	3.43	4.10	4.10			40.10	39.67
3	14.95	15.03	3.44	3.42	4.46	4.47			40.30	39.58
4	14.95	15.06	3.44	3.41	4.20	4.21			40.90	39.89
5	14.95	15.09	3.44	3.40	4.44	4.45			40.90	39.60
6	14.95	15.12	3.44	3.39	4.20	4.21			40.90	39.31
MEAN		15.04		3.41		4.27				39.48

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.00		0.00		0.00				1.50
Span Check		14.40		5.00		8.18				52.70
Cal. Gas		14.58		4.92		8.21				50.90
Scf		-0.00206		0.00271		-0.00061				0.00098
Zcf		0.00000		0.00000		0.00000				0.25000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : SWEPI COALINGA Date : 1/29/91
 Station : HRSG 101-A Test Run : 4
 Test Condition: GAS 100%

Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	14.97	14.98	3.46	3.47	4.60	4.61			39.00	38.93
2	15.00	15.02	3.46	3.48	4.40	4.42			38.00	37.77
3	15.00	15.04	3.48	3.51	4.42	4.45			38.00	37.62
4	15.00	15.05	3.60	3.65	4.40	4.45			38.00	37.47
5	15.00	15.07	3.48	3.54	4.20	4.26			38.10	37.42
6	15.00	15.09	3.50	3.57	4.60	4.68			38.00	37.16
MEAN		15.04		3.54		4.48				37.73

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.32		0.03		0.00				1.50
Span Check		14.50		4.80		8.06				51.60
Cal. Gas		14.58		4.92		8.21				50.90
Scf		-0.00457		-0.00508		-0.00305				-0.00262
Zcf		0.05333		0.00500		0.00000				0.25000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : SWEPI COALINGA Date : 1/30/91
 Station : HRSG 101-B Test Run : 1
 Test Condition: GAS 100%

Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	15.22		4.60	4.61	3.30	3.30			35.50	35.57
2	15.25		4.66	4.70	3.28	3.28			36.00	36.20
3	15.25		4.64	4.71	3.28	3.29			36.10	36.44
4	15.25		4.68	4.78	3.26	3.27			36.30	36.78
5	15.25		4.60	4.73	3.26	3.27			36.40	37.01
6	15.27		4.54	4.70	3.26	3.27			36.30	37.05
MEAN	15.25		4.71		3.28					36.51

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check	0.00		0.05		0.00					-0.60
Span Check	14.58		4.74		8.17					50.00
Cal. Gas	14.58		4.92		8.21					50.90
Scf			-0.00779		-0.00081					-0.00098
Zcf			0.00833		0.00000					-0.10000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : SWEPI COALINGA Date : 1/30/91
 Station : HRSG 101-B Test Run : 2
 Test Condition: GAS 100%

Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	15.00	15.01	3.20	3.21	4.66	4.66			36.50	36.54
2	15.07	15.10	3.22	3.26	4.64	4.63			36.80	36.91
3	15.07	15.13	3.24	3.31	4.70	4.69			36.90	37.08
4	15.07	15.15	3.26	3.35	4.56	4.54			37.00	37.26
5	15.12	15.22	3.26	3.38	4.56	4.54			37.00	37.33
6	15.17	15.30	3.26	3.41	4.50	4.47			37.00	37.40
MEAN		15.15		3.32		4.59				37.09

	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
Zero Check		0.00		-0.25		0.08				0.00
Span Check		14.45		4.80		8.20				50.30
Cal. Gas		14.58		4.92		8.21				50.90
Scf		-0.00149		0.00440		-0.00183				-0.00196
Zcf		0.00000		-0.04167		0.01333				0.00000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : SWEPI COALINGA Date : 1/30/91
 Station : HRSG 101-B Test Run : 3
 Test Condition: GAS 100%

Point #	Concentration : Drift Uncorrected (A) / Corrected (B)											
	%O2		%CO2		ppm CO		ppm SO2		ppm NOx		ppm NOx	
	A	B	A	B	A	B	A	B	A	B	A	B
1	14.90	14.93	3.18	3.21	4.86	4.87			40.20			
2	14.90	14.98	3.18	3.26	4.82	4.85			40.20			
3	14.90	15.04	3.18	3.32	4.98	5.02			40.30			
4	14.90	15.10	3.18	3.38	11.20	11.27			39.80			
5	14.90	15.16	3.18	3.44	17.00	17.09			38.00			
6	14.88	15.20	3.19	3.51	13.90	14.01			38.30			
MEAN		15.07		3.35		9.52						39.47

	%O2	%CO2	ppm CO	ppm SO2	ppm NOx
Zero Check	0.00	0.00	-0.10		1.00
Span Check	14.25	4.43	8.10		51.90
Cal. Gas	14.58	4.92	8.21		50.90
Scf	-0.00377	-0.01660	-0.00020		
Zcf	0.00000	0.00000	-0.01667		

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

A. CALIBRATION AND CORRECTION DATA

Company : SWEPI COALINGA Date : 1/30/91
 Station : HRSG 101-B Test Run : 4
 Test Condition: GAS 100%

Point #	%O2		%CO2		ppm CO		ppm SO2		ppm NOx	
	A	B	A	B	A	B	A	B	A	B
1	14.75	14.77	3.57	3.54	15.40	15.40			36.70	36.95
2	14.75	14.80	3.58	3.50	16.00	15.99			35.90	36.66
3	14.78	14.86	3.59	3.46	12.30	12.29			35.60	36.86
4	14.79	14.91	3.64	3.45	11.20	11.20			36.00	37.77
MEAN		14.83		3.49		13.72				37.06

	%O2	%CO2	ppm CO	ppm SO2	ppm NOx
Span Check	14.45	5.20	8.20		48.80
Cal. Gas	14.58	4.92	8.21		50.90
Scf	-0.00223	0.01169	0.00122		-0.00147
Zcf	0.00000	0.01250	-0.01250		-0.45000

Scf, Span Drift Correction Factor = (% Drift / 100) / # of Readings
 Zcf, Zero Drift Correction Factor = Zero Drift / # of Readings
 Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]
 B, Corrected Concentration = Cz / [1 + (Scf x (Point # - 0.5))]

B. ZERO AND SPAN DRIFT PERCENT CALCULATIONS

Company : SWEPI COALINGA Date : 1/29/91

Station : HRSG 101-A

Run 1	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	14.58	4.92	8.21		50.90
Measured Span	14.45	4.64	8.20		50.20
Zero Drift	0.00	0.05	0.05		-0.30
Final, Actual Span	14.45	4.59	8.15		50.50
Percent Drift	-0.9	-6.7	-0.7		-0.8

Run 2	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	14.58	4.92	8.21		50.90
Measured Span	14.27	5.00	8.21		50.60
Zero Drift	0.00	0.00	0.00		0.00
Final, Actual Span	14.27	5.00	8.21		50.60
Percent Drift	-2.1	1.6	0.0		-0.6

Run	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span					
Measured Span					
Zero Drift					
Final, Actual Span					
Percent Drift					

Final, Actual Span = Measured Span - Zero Drift

Percent Drift = (Final, Actual Span - Initial Span) / Initial Span x 100

B. ZERO AND SPAN DRIFT PERCENT CALCULATIONS

Company : SWEPI COALINGA

Date : 1/29/91

Station : HRSG 101-A

Run 3	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	14.58	4.92	8.21		50.90
Measured Span	14.40	5.00	8.18		52.70
Zero Drift	0.00	0.00	0.00		1.50
Final, Actual Span	14.40	5.00	8.18		51.20
Percent Drift	-1.2	1.6	-0.4		0.6

Run 4	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	14.58	4.92	8.21		50.90
Measured Span	14.50	4.80	8.06		51.60
Zero Drift	0.32	0.03	0.00		1.50
Final, Actual Span	14.18	4.77	8.06		50.10
Percent Drift	-2.7	-3.0	-1.8		-1.6

Run	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span					
Measured Span					
Zero Drift					
Final, Actual Span					
Percent Drift					

Final, Actual Span = Measured Span - Zero Drift

Percent Drift = (Final, Actual Span - Initial Span) / Initial Span x 100

B. ZERO AND SPAN DRIFT PERCENT CALCULATIONS

Company : SWEPI COALINGA

Date : 1/30/91

Station : HRSG 101-B

Run 1	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	14.58	4.92	8.21		50.90
Measured Span	14.58	4.74	8.17		50.00
Zero Drift	0.00	0.05	0.00		-0.60
Final, Actual Span	14.58	4.69	8.17		50.60
Percent Drift	0.0	-4.7	-0.5		-0.6

Run 2	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	14.58	4.92	8.21		50.90
Measured Span	14.45	4.80	8.20		50.30
Zero Drift	0.00	-0.25	0.08		0.00
Final, Actual Span	14.45	5.05	8.12		50.30
Percent Drift	-0.9	2.6	-1.1		-1.2

Run	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span					
Measured Span					
Zero Drift					
Final, Actual Span					
Percent Drift					

Final, Actual Span = Measured Span - Zero Drift

Percent Drift = (Final, Actual Span - Initial Span) / Initial Span x 100

B. ZERO AND SPAN DRIFT PERCENT CALCULATIONS

Company : SWEPI COALINGA

Date : 1/30/91

Station : HRSG 101-B

Run 3	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	14.58	4.92	8.21		50.90
Measured Span	14.25	4.43	8.10		51.90
Zero Drift	0.00	0.00	-0.10		1.00
Final, Actual Span	14.25	4.43	8.20		50.90
Percent Drift	-2.3	-10.0	-0.1		0.0
*****	*****	*****	*****	*****	*****
Run 4	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span	14.58	4.92	8.21		50.90
Measured Span	14.45	5.20	8.20		48.80
Zero Drift	0.00	0.05	-0.05		-1.80
Final, Actual Span	14.45	5.15	8.25		50.60
Percent Drift	-0.9	4.7	0.5		-0.6
*****	*****	*****	*****	*****	*****
Run	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
Initial Span					
Measured Span					
Zero Drift					
Final, Actual Span					
Percent Drift					

Final, Actual Span = Measured Span - Zero Drift

Percent Drift = (Final, Actual Span - Initial Span) / Initial Span x 100

SAMPLE HANDLING/LOG-IN

Date 1-29-91 Test Location SWEPT-POALINGA H256-OUT

	Sample Type	Volume	Comments
1.	22252 <u>5/8</u> <u>FHW</u> <u>1</u> Meth Sample Test		<u>101 A</u>
2.	22253 <u>5/8</u> <u>MF</u> <u>1</u> Meth Sample Test		<u>101 A</u>
3.	22254 <u>5/8</u> <u>AMF</u> <u>1</u> Meth Sample Test		<u>101 A</u>
4.	22255 <u>5/8</u> <u>IPA</u> <u>1</u> Meth Sample Test		<u>101 A</u>
5.	22256 <u>5/8</u> <u>BHW</u> <u>1</u> Meth Sample Test		<u>101 A</u>
6.	22257 <u>5/8</u> <u>FHW</u> <u>2</u> Meth Sample Test		<u>101 A</u>
7.	22258 <u>5/8</u> <u>MF</u> <u>2</u> Meth Sample Test		<u>101 A</u>
8.	22259 <u>5/8</u> <u>AMF</u> <u>2</u> Meth Sample Test		<u>101 A</u>
9.	22260 <u>5/8</u> <u>IPA</u> <u>2</u> Meth Sample Test		<u>101 A</u>
10.	22261 <u>5/8</u> <u>BHW</u> <u>2</u> Meth Sample Test		<u>101 A</u>

CHAIN OF CUSTODY

Signature	Date/Time	Signature	Date/Time
<u>Scott M. Co.</u>	<u>1-29-91</u>		
<u>W. Amherst</u>	<u>1-31-91</u>		
<u>J.M.</u>	<u>2/9/91</u>		

SAMPLE HANDLING/LOG-IN.

Date 1-30-91

Test Location SWEPI COALINGA ^{HRS} - OUT

	Sample Type	Volume	Comments
1.	22266 <u>GC</u> <u>HC</u> <u>1</u> Meth Sample Test		HC-SAMPLE 101-B-1 101-B
2.	25860 <u>S-8</u> <u>IPA</u> <u>2</u> Meth Sample Test		101-B
3.	25859 <u>S-8</u> <u>BHW</u> <u>2</u> Meth Sample Test		101-B
4.	25858 <u>S-8</u> <u>AMF</u> <u>2</u> Meth Sample Test		101-B
5.	25857 <u>GC</u> <u>HC</u> <u>2</u> Meth Sample Test		HC-SAMPLE 101-B TEST 2
6.	25856 <u>S-8</u> <u>FHW</u> <u>2</u> Meth Sample Test		101-B
7.	25855 <u>S-8</u> <u>MF</u> <u>2</u> Meth Sample Test		101-B
8.	23752 <u>SB</u> <u>BHW</u> <u>ALL</u> Meth Sample Test		BLANK
9.	23751 <u>S-8</u> <u>IPA</u> <u>ALL</u> Meth Sample Test		BLANK
10.	23750 <u>S-8</u> <u>AMF</u> <u>ALL</u> Meth Sample Test		BLANK

CHAIN OF CUSTODY

Signature	Date/Time	Signature	Date/Time
<u>S. Cooper</u>	<u>1-30-91</u>		
<u>Walter B. Cooper</u>	<u>1-31-91</u>		
<u>DM</u>	<u>2/9/91</u>		

SAMPLE HANDLING/LOG-IN

Date 1-29, 30, 1991

Test Location SWEET-COALINGA HRSG-OUT

	Sample Type	Volume	Comments
1.	22262 <u>11</u> <u>DNW</u> <u>1</u> Meth Sample Test		<u>H2S M-11</u>
2.	22263 <u>ASTM</u> <u>N.G.</u> <u>1</u> Meth Sample Test		<u>Fuel Gas Sample 101 A</u>
3.	22265 <u>GC</u> <u>HC</u> <u>1</u> Meth Sample Test		<u>HC SAMPLE 101A-1</u>
4.	22264 <u>GC</u> <u>HC</u> <u>2</u> Meth Sample Test		<u>HC SAMPLE 101A-2</u>
5.	25864 <u>5-8</u> <u>EPA</u> <u>1</u> Meth Sample Test		<u>101-B TEST-1</u>
6.	25863 <u>5-8</u> <u>BITW</u> <u>1</u> Meth Sample Test		<u>101-B</u>
7.	25862 <u>5-8</u> <u>AMP</u> <u>1</u> Meth Sample Test		<u>101-B</u>
8.	25861 <u>ASTM</u> <u>F6</u> <u>1</u> Meth Sample Test		<u>101-B</u>
9.	22268 <u>5-8</u> <u>FHW</u> <u>1</u> Meth Sample Test		<u>101-B</u>
10.	22267 <u>5-8</u> <u>M-F</u> <u>1</u> Meth Sample Test		<u>101-B</u>

CHAIN OF CUSTODY

Signature	Date/Time	Signature	Date/Time
<u>S. Goyhan</u>	<u>1-30-91</u>		
<u>W. Decker</u>	<u>1-31-91</u>		
<u>J-M</u>	<u>2/9/91</u>		

SAMPLE HANDLING/LOG-IN

Date 1-30 91 Test Location SWEPI COALINGA - HRSG OUT

	Sample Type	Volume	Comments
1.	23748 <u>518</u> <u>FHW</u> <u>ALL</u> Meth Sample Test		<u>BLANK</u>
2.	23747 <u>11</u> <u>BHW</u> <u>ALL</u> Meth Sample Test		<u>BLANK</u>
3.	23749 <u>518</u> <u>MF</u> <u>ALL</u> Meth Sample Test		<u>BLANK</u>
4.	25846 <u>11</u> <u>BW</u> <u>2</u> Meth Sample Test		
5.			
6.			
7.			
8.			
9.			
10.			

CHAIN OF CUSTODY

<u>Signature</u>	<u>Date/Time</u>	<u>Signature</u>	<u>Date/Time</u>
<u>S. Croghan</u>	<u>1-30-91</u>		
<u>W. Sanchez</u>	<u>1-31-91</u>		
<u>JM</u>	<u>2/9/91</u>		

PACIFIC GAS TECHNOLOGY



4200 Easton Drive - Suite 5
 Bakersfield, California 93309
 805/324-1317
 Fax: 805/324-2746

RECEIVED
 FEB 01 1991

Ans'd.....

STEINER ENVIRONMENTAL, INC.
 4930 BOYLAN STREET
 BAKERSFIELD, CA 93308

Attention: Mr. Jim Steiner

SAMPLED: 1-(29-30)-91

SUBMITTED: JANUARY 31, 1991

REPORTED: JANUARY 31, 1991

LAB # 3315

=====

HYDROCARBONS ANALYSIS

=====

SWEPI/COALINGA

COMPONENT :	1-29-91	1-29-91	1-30-91	1-30-91
	22264	22265	22266	25857
reported as ppm	HC 101A	HC 101A	HC 101B	HC 101B
	TEST	TEST	TEST	TEST
	# 2	# 1	# 1	# 2
METHANE (C1)	4	4	4	5
ETHANE (C2)	ND < 1	ND < 1	ND < 1	ND < 1
PROPANE (C3)	2	ND < 1	1	1
BUTANE (C4)	ND < 1	ND < 1	ND < 1	ND < 1
PENTANE (C5)	ND < 1	ND < 1	ND < 1	ND < 1
HEXANE+ (C6+)	ND < 1	ND < 1	ND < 1	ND < 1

=====

START

1'59


4'38

STOP

*LAB
BLANK
/*

RUN # 54
NO RUN PEAKS STORED

15 ppm STANDARD



STOP


RUN # 55

AREA%

RT	AREA	TYPE	AR/HT	AREA%
0.27	5578	D BV	0.068	4.142
0.46	10569	D V8	0.068	7.848
0.87	15833	D PB	0.089	11.756
1.90	21127	B6	0.170	15.687
4.42	25809	B8	0.387	19.163
9.71	55764	PB	1.075	41.405

TOTAL AREA= 134680
 MIN FACTOR= 1.00000000

100 ppm STANDARD




STOP

RUN # 57

RT	AREA	TYPE	AR/HT	AREA%
0.23	35866	D PY	0.065	4.955
0.46	76718	D VB	0.063	9.769
0.87	105580	D PB	0.029	14.585
1.90	140410	PB	0.169	19.395
4.42	171660	PB	0.386	23.713
10.05	199680	BB	0.926	27.563

TOTAL AREA= 723910

1000 ppm STANDARD



RUN # 50

RT	AREA	TYPE	AR/HT	AREA%
0.28	353340	D PV	0.065	4.203
0.46	689210	D VB	0.068	9.368
0.87	1003200	D PB	0.089	13.636
1.90	1399100	PB	0.169	19.017
4.42	1764900	BY	0.388	23.989
5.37	8707	VB	0.398	0.118
10.10	2138600	PB	0.927	29.069

TOTAL AREA= 7357100
 MUL FACTOR= 1.000E+00

BLANK

after
1000 ppm
Standard

100

50

STOP

RUN # 59
TIME STOPPED

PS

22264

SWEPT/Coaling
HC 101A
TEST 2



RUN # 65

AREA#

RT	AREA TYPE	AR/HT	AREA#
0.26	1415 PV	0.186	44.248
0.64	1783 D VB	0.105	55.754

TOTAL AREA= 3198

AS 22246

SWEPI/Coalinga
101 B
TEST #1



RUN # 67

AREA%	AREA TYPE	AR/HT	AREA%
0.29	1494 PB	0.118	56.784
0.64	1137 D 88	0.085	43.216

TOTAL AREA= 2631

PS 25857

SWEEP/COALING A
101 B
TEST # 2



RUN # 68

AREA%	AREA TYPE	AR/HT	AREA%
0.29	1985 D BV	0.090	57.007
0.64	1497 D VB	0.807	42.993

TOTAL AREA= 3482

PS 22265

SWEPT/COALING
101A
TEST 1



RUN # 69

AREA%	RT	AREA TYPE	OR/HT	AREA%
0.25	1600	PV	0.201	100.000

TOTAL AREA= 1600


Blank

1157

1157
STOP

RUN # 66

15 PPM STANDARD




STOP

RUN # 76

AREA%	RT	AREA	TYPE	AR/HT	AREA%
	0.28	5459	D BY	0.068	5.081
	0.47	10222	D VB	0.063	9.520
	0.87	15396	D PB	0.089	14.339
	1.90	20643	BB	0.168	19.228
	4.40	25467	PB	0.300	23.719
	10.50	30101	PB	0.911	28.109

TOTAL AREA= 107370
MUL FACTOR= 1.0000E+00


100 ppm STANDARD



RUN # 77

RT	AREA	TYPE	AR/HT	AREA%
0.29	34986	D BY	0.066	5.004
0.46	68648	D VB	0.069	9.819
0.87	183190	D PB	0.083	14.760
1.89	137510	BB	0.167	19.669
4.39	167410	PR	0.382	23.345
18.49	187390	BB	0.988	26.303

1000 ppm STANDARD




RUN # 78

AREA%	RT	AREA	TYPE	AR/HT	AREA%
0.28		346410	D PY	0.063	4.913
0.46		674970	D VB	0.068	9.377
0.87		989440	D PB	0.089	13.746
1.89		1373800	PB	0.167	19.086
4.39		1729900	BV	0.380	24.034
5.33		8731	VB	0.453	0.121
10.47		2074500	BB	0.897	28.822

TOTAL AREA= 7197800
 FACTOR= 1.0000E+00

BLANK



RUN # 29

AREA%	RT	AREA TYPE	AR/HT	AREA%
0.24	0.24	643 PV	0.096	100.000

TOTAL AREA= 643
MUL FACTOR= 1.0000E+00

ANALYTICAL REPORT

SAMPLE TYPE Front Half Wash

DATE 2/9/91

SAMPLE COMPONENT Acetone

ANALYST WHL, JMC, LEM

REQUESTED BY SWEPI Cooling: HRS6 Out 1/29-30/91

ANALYTICAL METHOD Gravimetric (gm)

Sample ID No.	Test No.	Sample Volume	Sample Aliquot	Titer mls or (absorbance)	Analytical Result (total sample)	
					Uncorrected	Corrected
22252	101-A1	150	150	N/A	0.01117	0.01056
22257	101-A2	125	125	↓	0.00686	0.00635
22268	101-B1	134	134		0.00536	0.00481
25856	101-B2	142	142		0.00491	0.00433
23748	B1	100	100		0.00041	N/A

ANALYTICAL REPORT

SAMPLE TYPE Filterable Particulate

DATE 2/9/91

SAMPLE COMPONENT 100 mm Filter

ANALYST W.A. MC, J.M.

REQUESTED BY SWEPI Cooling: HRSG Out 1/29-30/91

ANALYTICAL METHOD Gravimetric (gm)

Sample ID No.	Test No.	Sample Volume	Sample Aliquot	Titer mls or (absorbance)	Analytical Result (total sample)	
					Uncorrected	Corrected
22253	101-A1	N/A	N/A	N/A	-0.00017	-0.00007 *
22258	101-A2	↓	↓	↓	+ 0.00033	0.00043 *
22267	101-B1	↓	↓	↓	-0.00123	-0.00113 *
22855	101-B2	↓	↓	↓	+ 0.00223	0.00233 *
23749	B1	↓	↓	↓	-0.00010 *	N/A

Forms: Analytic (Rev. 1/91)

*All test filters had lots of loose pieces.

ANALYTICAL REPORT

 SAMPLE TYPE Condensible Particulate

 DATE 2/9/91

 SAMPLE COMPONENT 80% IPA + Amf

 ANALYST W.H., M.C., J.M.

 REQUESTED BY SWEPL Cooling: HRSG Out 1/29-30/91

 ANALYTICAL METHOD Gravimetric (gm)

Sample ID No.	Test No.	Sample Volume	Sample Aliquot	Titer mls or (absorbance)	Analytical Result (total sample)	
					Uncorrected	Corrected
22255	101-A1	320	N/A	N/A	0.00506	0.00549
22260	101-A2	310			0.00486	0.00528
25864	101-B1	290			0.00497	0.00536
25860	101-B2	260			0.00865	0.00899
23751	IPA B1	100			-0.00015	N/A
	Amf B1	100			0.00077	0.00005
	Di B1	100	↓	↓	0.00072	N/A

Forms: Analytic (Rev. 1/91)

ANALYTICAL REPORT

SAMPLE TYPE Filterable SO₂

DATE 2/9/91

SAMPLE COMPONENT FHW + MF

ANALYST MC, JTM

REQUESTED BY SWEEP Coolings: HRS604 + 1/29-30/91

ANALYTICAL METHOD BaCl₂ titration (mg H₂SO₄)

Sample ID No.	Test No.	Sample Volume	Sample Aliquot	Titer mls or (absorbance)	Analytical Result (total sample)	
					Uncorrected	Corrected
N/A ↓ ↓ ↓ ↓	101-A1	100 ↓ ↓ ↓ ↓	10	0.15	N/A ↓ ↓ ↓ ↓	0.41 (107.1% dup)
	101-A2		0.14	0.36 (99.6% rec)		
	101-B1		0.17	0.50 (100.0% dup)		
	101-B2		0.20	0.64 (99.5% rec)		
	B1		0.06	0.27		N/A
					$N_{H_2SO_4} = 0.0092936$ EPA SO ₂ QC 0982 6xxx = $20.95/20.98 = 99.9\% \text{ conf.}$	

ANALYTICAL REPORT

SAMPLE TYPE Condensable SO₄

DATE 2/9/91

SAMPLE COMPONENT BHW + Amf

ANALYST MC, WTM

REQUESTED BY SWEPI Cooling: HRSG out 1/29-30/91

ANALYTICAL METHOD BaCl₂ titration (mg H₂SO₄)

Sample ID No.	Test No.	Sample Volume (ml)	Sample Aliquot (ml)	Titer mls or (absorbance)	Analytical Result (total sample)		
					Uncorrected	Corrected	
22255	101-A1	100	10	0.06	N/A	-0.05 (83.3% dup)	
22260	101-A2	↓	↓	0.18	↓	0.50 (99.5% dup)	
25864	101-B1			0.11		0.18 (100.0% dup)	
25860	101-B2			0.11		0.18 (99.6% dup)	
23751	1PA B1			0.07		0.32	N/A
N/A	Amf B1			0.06		N/A	0.00
↓	DI H ₂ O B1	↓	↓	0.06	0.27	N/A	
					$N_{H_2SO_4} = 0.0092936$ EPA SO ₂ QC 0882 6XXX: $20.95 / 20.98 = 99.9\% \text{ conf.}$		

ANALYTICAL REPORT

SAMPLE TYPE SO₂

DATE 2/9/91

SAMPLE COMPONENT 3% H₂O₂

ANALYST MC, JMM

REQUESTED BY SWEPI Cooling: HRS6 Out 1/29-30/91

ANALYTICAL METHOD BaCl₂ titration (mg H₂SO₄)

Sample ID No.	Test No.	Sample Volume	Sample Aliquot	Titer mls or (absorbance)	Analytical Result (total sample)		
					Uncorrected	Corrected	
22256	101-A1	400	10	0.06	N/A	1.09	
22261	101-A2	375	↓	0.07	↓	1.19	
25863	101-B1	370		0.07		1.17	
25859	101-B2	390		0.06		1.06	
23752	Bk	100		0.00		0.00	N/A
$N_{H_2SO_4} = 0.0092336$ EPA SO ₂ QC 0882 6XXX : $20.95/20.98 = 99.9\%$ conf.							

ANALYTICAL REPORT

SAMPLE TYPE Method 11 H₂S

DATE 2/1/91

SAMPLE COMPONENT Cadmium Sulfate Abs. Soln.

ANALYST MC

REQUESTED BY SWEPI/Coalinga 1/29-30/91

ANALYTICAL METHOD Iodometric

Sample ID No.	Test No.	Sample Volume	ml I ₂ Added	Titer mls	Sample Color	Normality of Iodine
22262	1	60	10	9.10	extremely pale yellow	$N_{I_2} = 0.008974 = \frac{(0.01 N Na_2S_2O_3)(22.435 ml Na_2S_2O_3)}{(25 ml)}$
25846	2	110	10	9.07	clear	
23747	Bl	60	10	8.83	clear	

Forms: Analyt-6.frm (rev. 1/91)

SOURCE TEST CALCULATIONS

PLANT : SWEPI COALINGA
 HRSG 101-A

RUN NO.: 1
 DATE : JAN 29, 1991

STANDARD TEMP.: 60 DEG. F

METER TEMP. = 60 DEG. F		STATIC PRESS. = -0.11 in. H2O
STACK TEMP. = 242.71 DEG. F		Cp = 0.840
SQ. RT. dP = 0.6324 in. H2O		STACK I.D. = inch
METER ORIFICE = 2.44 in. H2O		DUCT LENGTH = 47.5 inch
METER VOLUME = 118.375 Cu.Ft.		DUCT WIDTH = 47.5 inch
METER Y = 1.0002		STACK AREA = 15.668 Sq.Ft.
BAR. PRESSURE = 28.81 in.Hg		TEST TIME = 140.00 min.
COND. (Vlc) = 216.7 ml		NOZZLE DIA. = 0.3020 inch
GAS ANALYSIS = 14.90 % O2		0.00 % CO
3.49 % CO2		81.61 % N2

$$\begin{aligned}
 Vm(std) &= [T(std) + 460 / 29.92] \times Vm \times Y \times \\
 &\quad (Pb + (dH / 13.6)) / (Tm + 460) \dots\dots = 114.716 \quad \text{dscf} \\
 Vw(std) &= (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic = 10.046 \quad \text{scf} \\
 Bws &= Vw(std) / (Vm(std) + Vw(std)) \dots\dots = 0.081 \quad \text{Lower} \\
 &\quad \text{Bws} \\
 &\quad \text{value} \\
 Bws @ \text{ Saturated Conditions} &= \text{Vapor Press. of H2O} \\
 @ \text{ Dew Point Temp.} / (Ps, \text{ in.Hg.}) \dots\dots = 1.000 \quad \text{used.} \\
 \%EA &= (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 224.23 \\
 Md &= (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.15 \\
 Ms &= (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots = 28.26 \\
 P(stack) &= Pbar + [Pstatic / 13.6] \dots\dots = 28.80 \text{ in. Hg} \\
 vs &= 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) \\
 &\quad / (Ms \times Ps)] \dots\dots = 42.20 \quad \text{ft/sec} \\
 Qs &= vs \times As \times 60 \dots\dots = 39,672 \quad \text{acf/min} \\
 Qs(std) &= Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \\
 &\quad \times (Ps / 29.92) \dots\dots = 25,984 \quad \text{dscf/min} \\
 I &= (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + \\
 &\quad 460) / 29.92] \times 100 / (Time \times Ps \times An \times vs \times 60) = 99.33 \quad \%
 \end{aligned}$$

SOURCE TEST CALCULATIONS

PLANT : SWEPI COALINGA
 HRSG 101-A

RUN NO.: 2
 DATE : JAN 29, 1991

STANDARD TEMP.: 60 DEG. F

METER TEMP. = 71.18 DEG. F		STATIC PRESS. = -0.16 in. H2O
STACK TEMP. = 240.18 DEG. F		Cp = 0.840
SQ.RT. dP = 0.6232 in. H2O		STACK I.D. = inch
METER ORIFICE = 2.43 in. H2O		DUCT LENGTH = 47.5 inch
METER VOLUME = 120.685 Cu.Ft.		DUCT WIDTH = 47.5 inch
METER Y = 1.0002		STACK AREA = 15.668 Sq.Ft.
BAR. PRESSURE = 28.91 in.Hg		TEST TIME = 140.00 min.
COND. (Vlc) = 210.6 ml		NOZZLE DIA. = 0.3020 inch

GAS ANALYSIS :	15.04 % O2	0.00 % CO	
	3.48 % CO2	81.48 % N2	

Vm(std) = [T(std) + 460 / 29.92] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	114.885	
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vic	=	9.763	scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.078	Lower Bws value used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000	
%EA = (%O2 - 0.5%CO) / (0.264%N2 - (%O2-0.5%CO)) x 100 =	=	232.43	
Md = (.44 x %CO2) + (.32 x %O2) + [.28 x (%N2 + %CO)]	=	29.16	
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	28.28	
P(stack) = Pbar + [Pstatic / 13.6]	=	28.90	in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x Ps)]	=	41.42	ft/sec
Qs = vs x As x 60	=	38,940	acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (Ps/29.92)	=	25,744	dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std)/(Tstd + 460)/ 29.92] x 100 / (Time x Ps x An x vs x 60) =	=	100.41	%

SOURCE TEST CALCULATIONS

PLANT : SWEPI COALINGA
 HRSG 101-B

RUN NO.: 1
 DATE : JAN 30, 1991

STANDARD TEMP.: 60 DEG. F

METER TEMP. = 66.35 DEG. F		STATIC PRESS.= -0.20 in. H2O
STACK TEMP. = 238.33 DEG. F		Cp = 0.840
SQ.RT. dP = 0.6267 in. H2O		STACK I.D. = inch
METER ORIFICE = 2.44 in. H2O		DUCT LENGTH = 47.5 inch
METER VOLUME = 101.711 Cu.Ft.		DUCT WIDTH = 47.5 inch
METER Y = 1.0002		STACK AREA = 15.668 Sq.Ft.
BAR. PRESSURE = 28.92 in.Hg		TEST TIME = 120.00 min.
COND. (Vlc) = 180.0 ml		NOZZLE DIA. = 0.3020 inch
GAS ANALYSIS = 15.20 % O2		0.00 % CO
4.02 % CO2		80.78 % N2

$$Vm(std) = \left[\frac{T(std) + 460}{29.92} \right] \times Vm \times Y \times \frac{Pb + (dH / 13.6)}{(Tm + 460)} \dots = 97.748 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic = 8.344 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots = 0.079 \text{ | Lower Bws value used.}$$

Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 248.13$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.25$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots = 28.37$$

$$P(stack) = Pbar + [Pstatic / 13.6] \dots = 28.91 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots = 41.53 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots = 39,045 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots = 25,879 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92)] \times 100 / (Time \times Ps \times An \times vs \times 60) = 99.15 \%$$

SOURCE TEST CALCULATIONS

PLANT : SWEPI COALINGA
 HRS 101-B

RUN NO.: 2
 DATE : JAN 30, 1991

STANDARD TEMP.: 60 DEG. F

METER TEMP. = 75.04 DEG. F		STATIC PRESS.= -0.21 in. H2O	
STACK TEMP. = 237.04 DEG. F		Cp = 0.840	
SQ.RT. dP = 0.6299 in. H2O		STACK I.D. =	inch
METER ORIFICE = 2.51 in. H2O		DUCT LENGTH = 47.5	inch
METER VOLUME = 105.066 Cu.Ft.		DUCT WIDTH = 47.5	inch
METER Y = 1.0002		STACK AREA = 15.668	Sq.Ft.
BAR. PRESSURE = 29.00 in.Hg		TEST TIME = 120.00	min.
COND. (Vlc) = 194.5 ml		NOZZLE DIA. = 0.3020	inch

GAS ANALYSIS :	14.95 % O2	0.00 % CO	
	3.42 % CO2	81.63 % N2	

$Vm(std) = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots = 99.623 \text{ dscf}$
 $Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vic = 9.016 \text{ scf}$
 $Bws = Vw(std) / (Vm(std) + Vw(std)) \dots = 0.083 \text{ | Lower Bws value used.}$
 $Bws @ \text{ Saturated Conditions} = \text{Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)} \dots = 1.000$
 $\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 226.50$
 $Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.15$
 $Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots = 28.22$
 $P(stack) = Pbar + [Pstatic / 13.6] \dots = 28.98 \text{ in. Hg}$
 $vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times Ps)] \dots = 41.76 \text{ ft/sec}$
 $Qs = vs \times As \times 60 \dots = 39,256 \text{ acf/min}$
 $Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (Ps / 29.92) \dots = 26,015 \text{ dscf/min}$
 $I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (Tstd + 460) / 29.92)] \times 100 / (Time \times Ps \times An \times vs \times 60) = 100.52 \%$

EMISSION RATE CALCULATIONS

PLANT :SWEPI COALINGA
HRS 101-A

RUN NO.: 1
DATE : JAN 29, 1991
O2 CORR.: 15.0 %

STANDARD TEMP. : 60 DEG. F

Front Half Wash (FHW)	0.01056 grams	Vm(std)	114.716 ft3
Mass Filter (MF)	0.00000 grams	Vw(std)	10.046 ft3
Back Half Wash (BHW)	0.00549 grams	Qs(std)	25,984 dscfm
Front Half Sulfate (FHS)	0.41 mg H2SO4	Bws	0.081
Back Half Sulfate (BHS)	0.00 mg H2SO4	CO2	3.49 %
H2O2 Catch (SO2)	1.09 mg H2SO4	O2	14.90 %

F-FACTOR

$$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (\text{Btu/lb}) \times [(T_{\text{std}} + 460)/528] \dots\dots\dots 8474.21 \text{ dscf/MMBtu}$$

FILTERABLE PARTICULATE

15.432 x (FHW + MF) / [Vm(std) + Vw(std)]	0.0013 gr/scf
15.432 x (FHW + MF) / Vm(std)	0.0014 gr/dscf
gr/dscf x (12 / %CO2)	0.0049 @ 12% CO2
0.00857 x Qs(std) x gr/dscf	0.32 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf	0.0060 lb/MMBtu

TOTAL PARTICULATE

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std))]	0.0020 gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std))	0.0022 gr/dscf
gr/dscf x (12 / %CO2)	0.0074 @ 12% CO2
0.00857 x Qs(std) x gr/dscf	0.48 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf	0.0091 lb/MMBtu

TOTAL SULFATE

0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)]	0.0001 gr/scf
0.015432 x (FHS + BHS) / Vm(std)	0.0001 gr/dscf
gr/dscf x (12 / %CO2)	0.0002 @ 12% CO2
0.00857 x Qs(std) x gr/dscf	0.01 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf	0.0002 lb/MMBtu

SULFUR DIOXIDE (SO2)

1.60982 x [T(std) + 460] x (mg H2SO4) / [98.076 x Vm(std)]	0.08 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)]	0.08 @ O2 corr.
ppm x (1 - Bws)	0.07 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460]	0.02 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x [20.9 / (20.9 - %O2)] x ppm	0.0004 lb/MMBtu
lb/hr / (dscfm x 60 min/hr)	1.37E-08 lb/dscf

SULFUR (S)

(lb/MMBtu SO2) / 2	0.0002 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076)	0.0001 lb/MMBtu
Total Sulfur	0.0003 lb/MMBtu

EMISSION RATE CALCULATIONS

PLANT :SWEPI COALINGA
 HRS 101-A

RUN NO.: 2
 DATE : JAN 29,1991
 O2 CORR.: 15.0 %

STANDARD TEMP. : 60 DEG. F

```
*****
Front Half Wash (FHW)      0.00635 grams | Vm(std) 114.885 ft3
Mass Filter (MF)           0.00043 grams | Vw(std)  9.763 ft3
Back Half Wash (BHW)      0.00528 grams | Qs(std) 25,744 dscfm
Front Half Sulfate (FHS)   0.36 mg H2SO4 | Bws      0.078
Back Half Sulfate (BHS)   0.50 mg H2SO4 | CO2      3.48 %
H2O2 Catch (SO2)         1.19 mg H2SO4 | O2       15.04 %
*****
```

F-FACTOR

$$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(T_{\text{std}} + 460)/528] \dots 8474.21 \text{ dscf/MMBtu}$$

FILTERABLE PARTICULATE

```
-----
15.432 x (FHW + MF) / [Vm(std) + Vw(std)] ..... 0.0008 gr/scf
15.432 x (FHW + MF) / Vm(std) ..... 0.0009 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0031 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.20 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0039 lb/MMBtu
```

TOTAL PARTICULATE

```
-----
15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std))] ... 0.0015 gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std)) ..... 0.0016 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0056 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.36 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0070 lb/MMBtu
```

TOTAL SULFATE

```
-----
0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)] ..... 0.0001 gr/scf
0.015432 x (FHS + BHS) / Vm(std) ..... 0.0001 gr/dscf
gr/dscf x (12 / %CO2) ..... 0.0004 @ 12% CO2
0.00857 x Qs(std) x gr/dscf ..... 0.03 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf .. 0.0005 lb/MMBtu
```

SULFUR DIOXIDE (SO2)

```
-----
1.60982 x [T(std) + 460] x (mg H2SO4) / [ 98.076 x
Vm(std)] ..... 0.09 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)] ..... 0.09 @ O2 corr.
ppm x (1 - Bws) ..... 0.08 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460].. 0.02 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x
[20.9 / (20.9 - %O2)] x ppm ..... 0.0005 lb/MMBtu
lb/hr / (dscfm x 60 min/hr) ..... 1.49E-08 lb/dscf
```

SULFUR (S)

```
-----
(lb/MMBtu SO2) / 2 ..... 0.0002 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076) ..... 0.0002 lb/MMBtu
Total Sulfur ..... 0.0004 lb/MMBtu
```

EMISSION RATE CALCULATIONS

PLANT :SWEPI COALINGA
 HRSG 101-B

RUN NO.: 1
 DATE : JAN 30,1991
 O2 CORR.: 15.0 %

STANDARD TEMP. : 60 DEG. F

```

*****
Front Half Wash (FHW)      0.00481 grams | Vm(std) 97.748 ft3
Mass Filter (MF)           0.00000 grams | Vw(std)  8.344 ft3
Back Half Wash (BHW)      0.00536 grams | Qs(std) 25,879 dscfm
Front Half Sulfate (FHS)   0.50 mg H2SO4 | Bws      0.079
Back Half Sulfate (BHS)   0.18 mg H2SO4 | CO2      4.02 %
H2O2 Catch (SO2)         1.17 mg H2SO4 | O2       15.20 %
*****
  
```

F-FACTOR

 $10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528] \dots\dots\dots 8473.94 \text{ dscf/MMBtu}$

FILTERABLE PARTICULATE

 $15.432 \times (FHW + MF) / [Vm(std) + Vw(std)] \dots\dots\dots 0.0007 \text{ gr/scf}$
 $15.432 \times (FHW + MF) / Vm(std) \dots\dots\dots 0.0008 \text{ gr/dscf}$
 $\text{gr/dscf} \times (12 / \%CO2) \dots\dots\dots 0.0023 \text{ @ } 12\% \text{ CO2}$
 $0.00857 \times Qs(std) \times \text{gr/dscf} \dots\dots\dots 0.17 \text{ lb/hr}$
 $F\text{-Fac} \times 1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times \text{gr/dscf} \dots 0.0034 \text{ lb/MMBtu}$

TOTAL PARTICULATE

 $15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std))] \dots 0.0015 \text{ gr/scf}$
 $15.432 \times (FHW + MF + BHW) / (Vm(std)) \dots\dots\dots 0.0016 \text{ gr/dscf}$
 $\text{gr/dscf} \times (12 / \%CO2) \dots\dots\dots 0.0048 \text{ @ } 12\% \text{ CO2}$
 $0.00857 \times Qs(std) \times \text{gr/dscf} \dots\dots\dots 0.36 \text{ lb/hr}$
 $F\text{-Fac} \times 1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times \text{gr/dscf} \dots 0.0071 \text{ lb/MMBtu}$

TOTAL SULFATE

 $0.015432 \times (FHS + BHS) / [Vm(std) + Vw(std)] \dots\dots\dots 0.0001 \text{ gr/scf}$
 $0.015432 \times (FHS + BHS) / Vm(std) \dots\dots\dots 0.0001 \text{ gr/dscf}$
 $\text{gr/dscf} \times (12 / \%CO2) \dots\dots\dots 0.0003 \text{ @ } 12\% \text{ CO2}$
 $0.00857 \times Qs(std) \times \text{gr/dscf} \dots\dots\dots 0.02 \text{ lb/hr}$
 $F\text{-Fac} \times 1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times \text{gr/dscf} \dots 0.0005 \text{ lb/MMBtu}$

SULFUR DIOXIDE (SO2)

 $1.60982 \times [T(std) + 460] \times (\text{mg H2SO4}) / [98.076 \times Vm(std)] \dots\dots\dots 0.10 \text{ ppm}$
 $\text{ppm} \times [(20.9 - \text{Oxygen Corr.}) / (20.9 - \%O2)] \dots\dots\dots 0.11 \text{ @ } O2 \text{ corr.}$
 $\text{ppm} \times (1 - Bws) \dots\dots\dots 0.09 \text{ ppm (wet)}$
 $8.223E-5 \times Qs(std) \times 64.062 \times \text{ppm} / [T(std) + 460] \dots 0.03 \text{ lb/hr}$
 $F\text{-Factor} \times 64.062 \times [1.3711E-6 / [T(std) + 460]] \times [20.9 / (20.9 - \%O2)] \times \text{ppm} \dots\dots\dots 0.0005 \text{ lb/MMBtu}$
 $\text{lb/hr} / (\text{dscfm} \times 60 \text{ min/hr}) \dots\dots\dots 1.72E-08 \text{ lb/dscf}$

SULFUR (S)

(lb/MMBtu SO2) / 2 \dots\dots\dots 0.0003 lb/MMBtu
 (lb/MMBtu Total Sulfate) x (32 / 98.076) \dots\dots\dots 0.0002 lb/MMBtu
 Total Sulfur \dots\dots\dots 0.0004 lb/MMBtu

EMISSION RATE CALCULATIONS

PLANT :SWEPI COALINGA
 HRSG 101-B

RUN NO.: 2
 DATE : JAN 30,1991
 O2 CORR.: 15.0 %

STANDARD TEMP. : 60 DEG. F

Front Half Wash (FHW)	0.00433 grams	Vm(std)	99.623 ft3
Mass Filter (MF)	0.00233 grams	Vw(std)	9.016 ft3
Back Half Wash (BHW)	0.00899 grams	Qs(std)	26,015 dscfm
Front Half Sulfate (FHS)	0.64 mg H2SO4	Bws	0.083
Back Half Sulfate (BHS)	0.18 mg H2SO4	CO2	3.42 %
H2O2 Catch (SO2)	1.06 mg H2SO4	O2	14.95 %

F-FACTOR

$$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (\text{Btu/lb}) \times [(Tstd + 460)/528] \dots\dots\dots 8473.94 \text{ dscf/MMBtu}$$

FILTERABLE PARTICULATE

15.432 x (FHW + MF) / [Vm(std) + Vw(std)]	0.0009 gr/scf
15.432 x (FHW + MF) / Vm(std)	0.0010 gr/dscf
gr/dscf x (12 / %CO2)	0.0036 @ 12% CO2
0.00857 x Qs(std) x gr/dscf	0.23 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf	0.0044 lb/MMBtu

TOTAL PARTICULATE

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std))]	0.0022 gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std))	0.0024 gr/dscf
gr/dscf x (12 / %CO2)	0.0085 @ 12% CO2
0.00857 x Qs(std) x gr/dscf	0.54 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf	0.0103 lb/MMBtu

TOTAL SULFATE

0.015432 x (FHS + BHS) / [Vm(std) + Vw(std)]	0.0001 gr/scf
0.015432 x (FHS + BHS) / Vm(std)	0.0001 gr/dscf
gr/dscf x (12 / %CO2)	0.0004 @ 12% CO2
0.00857 x Qs(std) x gr/dscf	0.03 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf	0.0005 lb/MMBtu

SULFUR DIOXIDE (SO2)

1.60982 x [T(std) + 460] x (mg H2SO4) / [98.076 x Vm(std)]	0.09 ppm
ppm x [(20.9 - Oxygen Corr.) / (20.9 - %O2)]	0.09 @ O2 corr.
ppm x (1 - Bws)	0.08 ppm (wet)
8.223E-5 x Qs(std) x 64.062 x ppm / [T(std) + 460]	0.02 lb/hr
F-Factor x 64.062 x [1.3711E-6 / [T(std)+ 460]] x [20.9 / (20.9 - %O2)] x ppm	0.0005 lb/MMBtu
lb/hr / (dscfm x 60 min/hr)	1.53E-08 lb/dscf

SULFUR (S)

(lb/MMBtu SO2) / 2	0.0002 lb/MMBtu
(lb/MMBtu Total Sulfate) x (32 / 98.076)	0.0002 lb/MMBtu
Total Sulfur	0.0004 lb/MMBtu

EMISSION RATE CALCULATIONS

PLANT : SWEPI COALINGA
 SOURCE : HRSG 101-A

Temp. Std. : 60 dF
 Press. Std.: 29.92 in. Hg. 15 % O2 Correction

Run No.	1	2	AVERAGE
Date	1/29/91	1/29/91	
Oxygen (%)	14.90	15.04	14.97
Qs(std), dscfm	25,984	25,744	25,864
NOx, ppm	38.44	38.61	38.53
SO2, ppm			
CO, ppm	4.15	4.38	4.27
HC, ppm	1.00	2.00	1.50
F-Factor	8474.21	8474.21	8474.21

NOx, MW = 46.005			
NOx, lb/hr	7.27	7.23	7.25
NOx, ppm @ O2	37.80	38.87	38.34
NOx, lb/MMBtu	0.1376	0.1416	0.1396

SO2, MW = 64.058
 SO2, lb/hr
 SO2, ppm @ O2
 SO2, lb/MMBtu

CO, MW = 28.010			
CO, lb/hr	0.48	0.50	0.49
CO, ppm @ O2	4.08	4.41	4.25
CO, lb/MMBtu	0.0090	0.0098	0.0094

HC, MW = 16.043			
HC, lb/hr	0.07	0.13	0.10
HC, ppm @ O2	0.98	2.01	1.50
HC, lb/MMBtu	0.0012	0.0026	0.0019

* $lb/hr = 8.223E-5 \times Qs(std) \times MW \times ppm / (Tstd + 460)$

* $ppm @ O2 = ppm \text{ measured} \times [(20.9 - O2\% \text{ correction}) / (20.9 - \%O2 \text{ measured})]$

* $lb/MMBtu = F-Factor \times MW \times [1.3711E-6 / (Tstd + 460)] \times [20.9 / (20.9 - O2\%)] \times ppm$

* $lb/Bbl = (lb/MMBtu) \times (MMBtu/Bbl)$

EMISSION RATE CALCULATIONS

PLANT : SWEPI COALINGA
 SOURCE : HRSG 101-B

Temp. Std. : 60 dF
 Press. Std.: 29.92 in. Hg. 15 % O2 Correction

Run No.	1	2	AVERAGE
Date	1/30/91	1/30/91	
Oxygen (%)	15.20	14.95	15.08
Qs(std), dscfm	25,879	26,015	25,947
NOx, ppm	36.80	38.27	37.54
SO2, ppm			
CO, ppm	3.94	11.62	7.78
HC, ppm	1.00	1.00	1.00
F-Factor	8473.94	8473.94	8473.94

NOx, MW = 46.005			
NOx, lb/hr	6.93	7.24	7.09
NOx, ppm @ O2	38.09	37.95	38.02
NOx, lb/MMBtu	0.1387	0.1382	0.1384

SO2, MW = 64.058
 SO2, lb/hr
 SO2, ppm @ O2
 SO2, lb/MMBtu

CO, MW = 28.010			
CO, lb/hr	0.45	1.34	0.90
CO, ppm @ O2	4.08	11.52	7.80
CO, lb/MMBtu	0.0090	0.0255	0.0173

HC, MW = 16.043			
HC, lb/hr	0.07	0.07	0.07
HC, ppm @ O2	1.04	0.99	1.01
HC, lb/MMBtu	0.0013	0.0013	0.0013

* $lb/hr = 8.223E-5 \times Qs(std) \times MW \times ppm / (Tstd + 460)$

* $ppm @ O2 = ppm \text{ measured} \times [(20.9 - O2\% \text{ correction}) / (20.9 - \%O2 \text{ measured})]$

* $lb/MMBtu = F-Factor \times MW \times [1.3711E-6 / (Tstd + 460)] \times [20.9 / (20.9 - O2\%)] \times ppm$

* $lb/Bbl = (lb/MMBtu) \times (MMBtu/Bbl)$

H₂S CALCULATIONS AT S_t
(Standard Temperature to be Defined)

$$V_{m, std} = \frac{S_t}{29.92} (\gamma) (Vm) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$$

$$\text{Blank CdSO}_4 = [N_{I_2} (\text{mls } I_2) - N_{Na_2S_2O_3} (\text{mls } Na_2S_2O_3)] [\text{Aliquot Factor}]$$

$$\text{ppm H}_2\text{S} = \frac{0.8039(S_t + 460) \left(\left\{ [N_{I_2} (\text{mls } I_2) - (N_{Na_2S_2O_3}) (\text{mls } Na_2S_2O_3)] \text{Volume Factor} \right\} - \text{Blank} \right)}{V_{m, std}}$$

$$V_{m, std} = \frac{(60 + 460)}{29.92} (0.9875) (49.542) \left(\frac{28.81 + \frac{0}{13.6}}{45.50 + 460} \right)$$

$$= \underline{48.459}$$

$$\text{Blank CdSO}_4 = [0.008914 (10.0) - 0.0100 (8.83)] \left[\frac{1}{1} \right]$$

$$= \underline{0.0014}$$

$$\text{ppm H}_2\text{S} = \frac{0.8039(60 + 460) \left(\left\{ [0.008914 (10.0) - 0.0100 (9.10)] \frac{1}{1} \right\} - 0.0014 \right)}{48.459}$$

$$= \underline{0.00}$$

H₂S CALCULATIONS AT S_t

101 B

(Standard Temperature to be defined)

$$V_{m, std} = \frac{S_t}{29.92} (\gamma) (V_m) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$$

$$\text{Blank CdSO}_4 = [N_{I_2}(\text{mls } I_2) - N_{Na_2S_2O_3}(\text{mls } Na_2S_2O_3)]$$

$$\text{ppm H}_2\text{S} = \frac{0.8039(S_t + 460) \left([N_{I_2}(\text{mls } I_2) - (N_{Na_2S_2O_3})(\text{mls } Na_2S_2O_3)] - \text{Blank} \right)}{V_{m, std}}$$

$$V_{m, std} = \frac{(60 + 460)}{29.92} (0.9875) (21.004) \left(\frac{28.92 + \frac{0}{13.6}}{65.16 + 460} \right)$$

$$= 19.851$$


$$\text{Blank CdSO}_4 = [0.008974 (10.0) - 0.0100 (8.83)]$$

$$= 0.0014$$

$$\text{ppm H}_2\text{S} = \frac{0.8039(60 + 460) \left([0.008974 (10.0) - 0.010 (9.07)] - 0.0014 \right)}{19.851}$$

$$= 0.00$$

NOZZLE CALIBRATION DATA



DIAMETER (in.)

- A 0.3015
- B 0.3000
- C 0.3041
- D 0.3025
- E _____
- F _____

DATE 7-27-89

NOZZLE NO. 270

OPERATOR SM

AVG. 0.3020

DRY GAS METER / ORIFICE METER CALIBRATION DATA

Date 1/25/91
 Bar. Press, in.Hg 29.82
 Meter Box No. 779

Dry Gas Meter No. ... 68190
 Standard Test Meter # 69279
 Operator JP

STANDARD TEST METER			DRY TEST METER				Time t (min)
Press. dHs (in. H2O)	Temp. Ts (dF)	Volume Vs (ft3)	Press. dH (in. H2O)	Temp. Tdi (dF)	Temp. Tdo (dF)	Volume Vd (ft3)	
	65.0	248.576		87	76	921.910	57.0
-1.7	64.0	226.813	0.5	77	73	899.608	
Avg/Net :	64.5	21.763			78	22.302	
	62.0	270.299		84	72	944.224	40.0
-2.7	64.0	249.073	1.0	77	72	922.444	
Avg/Net :	63.0	21.226			76	21.780	
	62.0	293.037		85	73	967.238	34.0
-3.7	62.0	270.691	1.5	79	73	944.616	
Avg/Net :	62.0	22.346			78	22.622	
	62.0	317.148		90	74	991.599	31.0
-4.6	62.0	293.522	2.0	84	76	967.732	
Avg/Net :	62.0	23.626			81	23.867	
	62.0	341.810		83	74	1016.415	26.0
-6.2	63.0	317.845	3.0	84	74	992.297	
Avg/Net :	62.5	23.965			79	24.118	

$$Y = V_s \times (P_{bar} + (dH_s / 13.6)) \times (Avg. T_d + 460) / [V_d \times (P_{bar} + (dH / 13.6)) \times (T_s + 460)]$$

$$K_o = [(V_s/t) \times [(T_{do} + 460) / (T_s + 460)] \times [(P_{bar} + (dH_s/13.6)) / (P_{bar} + (dH/13.6))] / [((T_{do} + 460) \times dH) / (P_{bar} + (dH/13.6)) \times (M_m)]^{0.5}$$

dH :	0.5	1.0	1.5	2.0	3.0	Avg.	Std.Dev.
Y :	0.9960	0.9902	1.0041	1.0093	1.0015	1.0002	0.0066
Ko :	1	0.6823	0.6898	0.6921	0.6786	0.6878	0.0064

Y : 0.66 % Relative Std. Dev.

Ko : 0.93 % Relative Std. Dev.

DRY GAS METER / ORIFICE METER CALIBRATION DATA

Date8/17/90
 Bar. Press, in.Hg 29.68
 Meter Box No. ...PORTABLE

Dry Gas Meter No. ... 6825354
 Standard Test Meter # 69279
 Operator TD

STANDARD TEST METER			DRY TEST METER				Time t (min)
Press. dHs (in. H2O)	Temp. Ts (dF)	Volume Vs (ft3)	Press. dH (in. H2O)	Temp. Tdi (dF)	Temp. Tdo (dF)	Volume Vd (ft3)	
	0.0	0.000		0	0	0.000	0.0
0.0	0.0	0.000	0.5	0	0	0.000	
Avg/Net :	0.0	0.000				0.000	
	0.0	0.000		0	0	0.000	0.0
0.0	0.0	0.000	1.0	0	0	0.000	
Avg/Net :	0.0	0.000				0.000	
	66.0	358.901		84	76	415.874	51.0
-3.4	66.0	330.682	1.5	68	68	387.215	
Avg/Net :	66.0	28.219			74	28.659	
	0.0	0.000		0	0	0.000	0.0
0.0	0.0	0.000	2.0	0	0	0.000	
Avg/Net :	0.0	0.000				0.000	
	0.0	0.000		0	0	0.000	0.0
0.0	0.0	0.000	3.0	0	0	0.000	
Avg/Net :	0.0	0.000				0.000	

$$y = V_s \times (P_{bar} + (dH_s / 13.6)) \times (Avg. T_d + 460) / [V_d \times (P_{bar} + (dH / 13.6)) \times (T_s + 460)]$$

$$K_o = [(V_s/t) \times [(T_{do} + 460) / (T_s + 460)] \times [(P_{bar} + (dH_s/13.6)) / (P_{bar} + (dH/13.6))] / [((T_{do} + 460) \times dH) / (P_{bar} + (dH/13.6)) \times (Mm)]^{0.5}$$

dH :	0.5	1.0	1.5	2.0	3.0	Avg.	Std.Dev.
y :			0.9875			0.9875	0.3950
Ko :			0.5748			0.5748	0.2299
y :	40.00 % Relative Std. Dev.						
Ko :	40.00 % Relative Std. Dev.						



Scott Specialty Gases

a division of

TELEX: 510-100-8831 (ScotGas)

FAX: 714-887-0549

PHONE: 714-887-2571

Scott Environmental Technology Inc. 2600 CAJON BLVD., SAN BERNARDINO, CA 92405

PAPE & STEINER
5801 NORRIS ROAD
BAKERSFIELD, CA 93308
ATTEN: SUE POWERS

Date: 6/7/90
Our Project No.: 7053
Your P.O. No.: SP2546-90 REL# 16

Gentlemen:

Thank you for choosing Scott for your Specialty Gas needs. The analyses for the gases ordered, as reported by our laboratory, are listed below. Results are in volume percent, unless otherwise indicated.

ANALYTICAL REPORT

CGA 590 Cyl. No. <u>ALM-6096</u>	Analytical Accuracy <u>±1%</u>
Component	Concentration
CARBON DIOXIDE	8.020%
TRACEABLE TO CRM2636 CARBON MONOXIDE	201.2 ppm
OXYGEN	14.97%
NITROGEN	BALANCE
*GRAVIMETRIC MASTER GAS	

Cyl. No. _____	Analytical Accuracy _____
Component	Concentration

Cyl. No. _____	Analytical Accuracy _____
Component	Concentration

Cyl. No. _____	Analytical Accuracy _____
Component	Concentration

Analyst _____

Approved By [Signature]

* CERTIFIED TO HAVE BEEN BLENDED AGAINST NIST CERTIFIED WEIGHTS AND VERIFIED TO BE CORRECT BY INDEPENDENT ANALYSIS.

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

PLUMSTEADVILLE, PENNSYLVANIA / TROY, MICHIGAN / HOUSTON, TEXAS / WHEELING, ILLINOIS
SOUTH PLAINFIELD, NEW JERSEY / FREMONT, CALIFORNIA / WAKEFIELD, MASSACHUSETTS / LONGMONT, COLORADO
BOSTON, MASSACHUSETTS / BATON ROUGE, LOUISIANA



SCOTT-MARRIN, INC.

2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
TELEPHONE (714) 784-1240


REPORT OF ANALYSIS NIST TRACEABLE GAS MIXTURES

TO: PAPE01
SUE POWERS
PAPE & STEINER
5801 NORRIS RD.
BAKERSFIELD, CA 93308

DATE: 11/19/90

CUSTOMER ORDER NUMBER: SP2750-90 REL-6

PAGE 1



CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC68761	Carbon Monoxide	76.4 ± 0.8 ppm	SRM 1679c
	Carbon Dioxide	15.39 ± 0.15 %	SRM 1675b
	Oxygen	7.17 ± 0.07 %	SRM 2658a
	Nitrogen	Balance	
CC68762	Carbon Monoxide	76.0 ± 0.8 ppm	SRM 1679c
	Carbon Dioxide	15.49 ± 0.15 %	SRM 1675b
	Oxygen	7.32 ± 0.07 %	SRM 2658a
	Nitrogen	Balance	

ppm = umole/mole % = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

Analyst: M.S. Calhoun
M.S. Calhoun

Approved: J.T. Marrin
J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
TELEPHONE (714) 784-1240

REPORT OF ANALYSIS NIST TRACEABLE GAS MIXTURES

TO: PAPE01
SUE POWERS
PAPE & STEINER ENVIRONMENTAL
5801 NORRIS RD.
BAKERSFIELD, CA 93308

DATE: 11/19/90

CUSTOMER ORDER NUMBER: SP2750-90 REL-8

PAGE 1

CYLINDER NUMBER	COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
CC65300	Carbon Monoxide	15.75 ± 0.16 ppm	SRM 2613a
	Carbon Dioxide	4.92 ± 0.05 %	SRM 1674b
	Oxygen	14.58 ± 0.15 %	SRM 2659
	Nitrogen	Balance	
CC60307	Carbon Monoxide	77.3 ± 0.8 ppm	SRM 1679c
	Carbon Dioxide	15.53 ± 0.16 %	SRM 1675b
	Oxygen	7.36 ± 0.07 %	SRM 2658a
	Nitrogen	Balance	
CC12485	Carbon Monoxide	79.3 ± 0.8 ppm	SRM 1679c
	Carbon Dioxide	7.80 ± 0.08 %	SRM 1674b
	Oxygen	3.97 ± 0.04 %	SRM 2658a
	Nitrogen	Balance	

ppm = umole/mole

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standards listed above. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Report No. MMAP 232.09/202491.

Analyst:

M.S. Calhoun

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

SCOTT - MARRIN, INC.

2001 THIRD ST., UNIT H

RIVERSIDE, CALIFORNIA 92507

REPORT OF ANALYSIS

RECEIVED

JAN -4 1991

CUSTOMER ORDER NUMBER: B1-SP2750-90 Rel. 11

Ans'd.....

CYLINDER NUMBER CC7207

COMPONENT	CONCENTRATION (v/v)	Replicate 12/10/90	50.7 ppm	12/17/90	51.2 ppm
Nitric Oxide	50.9 ± 0.5 ppm	Analysis	50.8 ppm		51.1 ppm
		Data On	<u>50.7 ppm</u>		<u>51.1 ppm</u>
Nitrogen Dioxide	<0.3 ppm	NO: Mean	50.7 ppm		51.1 ppm
Nitrogen*	Balance	Expiration Date NO: 6/17/92			

Cylinder Pressure: 2000 psig

*Oxygen-free.

(The Nitric Oxide analysis was performed in accordance with Section 3.0.4 of the revised EPA traceability protocol No. 1 dated June 9, 1987. The analysis is traceable to the National Institute of Standards & Technology by direct intercomparison with GMIS, cylinder number CC88855 at 50 ppm Nitric Oxide in Oxygen-free Nitrogen. The analysis was performed using a Monitor Labs Model 8440, S/N 136 analyzer with continuous chemiluminescence detection. The last multipoint calibration was performed 10/23/90.)

CYLINDER NUMBER CC12840

COMPONENT	CONCENTRATION (v/v)	Replicate 12/10/90	40.5 ppm	12/17/90	40.4 ppm
Nitric Oxide	40.5 ± 0.4 ppm	Analysis	40.5 ppm		40.5 ppm
		Data On	<u>40.7 ppm</u>		<u>40.4 ppm</u>
Nitrogen Dioxide	<0.2 ppm	NO: Mean	40.6 ppm		40.4 ppm
Nitrogen*	Balance	Expiration Date NO: 6/17/92			

Cylinder Pressure: 2000 psig

*Oxygen-free.

(The Nitric Oxide analysis was performed in accordance with Section 3.0.4 of the revised EPA traceability protocol No. 1 dated June 9, 1987. The analysis is traceable to the National Institute of Standards & Technology by direct intercomparison with GMIS, cylinder number CC88855 at 50 ppm Nitric Oxide in Oxygen-free Nitrogen. The analysis was performed using a Monitor Labs Model 8440, S/N 136 analyzer with continuous chemiluminescence detection. The last multipoint calibration was performed 10/23/90.)



SCOTT-MARRIN, INC.
 2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
 TELEPHONE (714) 784-1240

**REPORT OF ANALYSIS
 EPA PROTOCOL GAS MIXTURES**

PAPE01

TO:

SUE POWERS
 STEINER ENVIRONMENTAL, INC.
 4930 BOYLAN ST.
 BAKERSFIELD, CA 93308

DATE : 12/10/90

CUSTOMER ORDER NUMBER: SP2750-90REL.14

PAGE 1

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA	
CYLINDER NO.: CC94437						
Nitric Oxide	81.5 ± 0.8 ppm	GMS	Monitor Labs Model 8440 S/N 136	06/04/92	<u>11/21/90</u> 81.2 ppm	<u>12/04/90</u> 81.7 ppm
Nitrogen, O ₂ -Free Balance		Cylinder # CC12643	Continuous Chemiluminescence		81.6 ppm	81.6 ppm
Cylinder Pressure: 2000 psig		@ 99.3 ppm	Last Cal Date: 10/23/90		<u>81.2 ppm</u>	<u>81.7 ppm</u>
Mean: 81.3 ppm 81.7 ppm						
CYLINDER NO.: CC94427						
Nitric Oxide	50.5 ± 0.5 ppm	GMS	Monitor Labs Model 8440 S/N 136	06/04/92	<u>11/21/90</u> 50.4 ppm	<u>12/04/90</u> 50.6 ppm
Nitrogen, O ₂ -Free Balance		Cylinder # CC88855	Continuous Chemiluminescence		50.5 ppm	50.3 ppm
Cylinder Pressure: 2000 psig		@ 50.0 ppm	Last Cal Date: 10/23/90		<u>50.5 ppm</u>	<u>50.5 ppm</u>
Mean: 50.5 ppm 50.5 ppm						
CC94437	NO _x = 81.5 ppm					
	NO ₂ < 0.4 ppm					
CC94427	NO _x = 50.5 ppm					
	NO ₂ < 0.3 ppm					

ppm = umole/mole % = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.

Analyst: M.S. Calhoun
 M.S. Calhoun

Approved: J.T. Marrin
 J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.



Scott Specialty Gases

a division of

TELEX: 510-100-8831 (ScotGas)

FAX: 714-887-0549

PHONE: 714-887-2571

Scott Environmental Technology Inc. 2600 CAJON BLVD., SAN BERNARDINO, CA 92405

PAPE & STEINER
5801 NORRIS ROAD
BAKERSFIELD, CA 93308

Date: 4/23/90

Our Project No.: 6264

Your P.O. No.: SP2546-90 REL 12

Gentlemen:

Thank you for choosing Scott for your Specialty Gas needs. The analyses for the gases ordered, as reported by our laboratory, are listed below. Results are in volume percent, unless otherwise indicated.

ANALYTICAL REPORT

CGA 660 Analytical
Cyl. No. AAL-2062 Accuracy +1%/±5%

Cyl. No. _____ Analytical Accuracy _____

Component _____ Concentration _____

Component _____ Concentration _____

NITRIC OXIDE 37.91 ppm

NOX 54.91 ppm

NITROGEN DIOXIDE 17 ppm

NITROGEN BALANCE

NO2=±5%

Cyl. No. _____ Analytical Accuracy _____

Cyl. No. _____ Analytical Accuracy _____

Component _____ Concentration _____

Component _____ Concentration _____

Analyst _____

Approved By [Signature]

The only liability of this Company for gas which fails to comply with this analysis shall be replacement thereof by the Company without extra cost.

PLUMSTEADVILLE, PENNSYLVANIA / TROY, MICHIGAN / HOUSTON, TEXAS / WHEELING, ILLINOIS
SOUTH PLAINFIELD, NEW JERSEY / FREMONT, CALIFORNIA / WAKEFIELD, MASSACHUSETTS / LONGMONT, COLORADO
BOSTON, MASSACHUSETTS / BATON ROUGE, LOUISIANA


APPENDIX B
SWEPI COALINGA COGEN OPERATING DATA

DIAGRAM NUMBER: 2005 VERSION: 0

DATE: 01/29/91 TIME: 04:40:49

TG-101A TURBINE INSTRUMENTATION

29/JAN/91
04:40:48



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/29/91 TIME: 04:41:06

29/JAN/91

GAS TOTALIZERS

04:41:01

FUEL GAS 207.8707 MCF	24 HR RUNNING
FUEL GAS 1062.649 MCF	24 HR PREVIOUS
FUEL GAS 1270.526 MCF	7 DAY RUNNING
FUEL GAS 7592.704 MCF	7 DAY PREVIOUS
FUEL GAS 21850.96 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 214.2018 MCF	24 HR RUNNING
FUEL GAS 1090.296 MCF	24 HR PREVIOUS
FUEL GAS 1304.507 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 29524.13 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.77 RATIO

FUEL GAS 425.5081 MCF	24 HR RUNNING
FUEL GAS 2164.165 MCF	24 HR PREVIOUS
FUEL GAS 2589.799 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 50722.02 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS


0.75 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 2005 VERSION: 0
DATE: 01/29/91 TIME: 05:40:27

TG-101A TURBINE INSTRUMENTATION

29/JAN/91
05:40:23



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0
DATE: 01/29/91 TIME: 05:40:03

29/JAN/91

GAS TOTALIZERS

05:40:01

FUEL GAS 251.7789 MCF	24 HR RUNNING
FUEL GAS 1062.649 MCF	24 HR PREVIOUS
FUEL GAS 1314.438 MCF	7 DAY RUNNING
FUEL GAS 7592.704 MCF	7 DAY PREVIOUS
FUEL GAS 21832.45 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 259.2281 MCF	24 HR RUNNING
FUEL GAS 1098.296 MCF	24 HR PREVIOUS
FUEL GAS 1349.534 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 28569.95 MCF	MONTH RUNNING
FUEL GAS 32568.51 MCF	MONTH PREVIOUS

0.77 RATIO

FUEL GAS 515.2272 MCF	24 HR RUNNING
FUEL GAS 2164.165 MCF	24 HR PREVIOUS
FUEL GAS 2679.632 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 50807.43 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS

0.75 RATIO


COPY IN PROGRESS

DIAGRAM NUMBER: 2005 VERSION: 0

DATE: 01/29/91 TIME: 06:38:49

TG-101A TURBINE INSTRUMENTATION

29/JAN/91
06:38:45



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/29/91 TIME: 06:38:33

29 JAN 91

GAS TOTALIZERS

06:38:33

FUEL GAS 295.4218 MCF	24 HR RUNNING
FUEL GAS 1062.649 MCF	24 HR PREVIOUS
FUEL GAS 1358.085 MCF	7 DAY RUNNING
FUEL GAS 7532.704 MCF	7 DAY PREVIOUS
FUEL GAS 21933.57 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 303.9660 MCF	24 HR RUNNING
FUEL GAS 1090.296 MCF	24 HR PREVIOUS
FUEL GAS 1394.269 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 28616.06 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.77 RATIO

FUEL GAS 604.4728 MCF	24 HR RUNNING
FUEL GAS 2164.165 MCF	24 HR PREVIOUS
FUEL GAS 2768.791 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 50900.07 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS


0.74 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 2005 VERSION: 0
 DATE: 01/29/91 TIME: 07:35:45

TG-101A TURBINE INSTRUMENTATION

29/JAN/91
 07:35:41



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/29/91 TIME: 07:35:29

29/JAN/91

GAS TOTALIZERS

07:35:27

FUEL GAS 337.9608 MCF	24 HR RUNNING
FUEL GAS 1062.649 MCF	24 HR PREVIOUS
FUEL GAS 1400.585 MCF	7 DAY RUNNING
FUEL GAS 7592.704 MCF	7 DAY PREVIOUS
FUEL GAS 21973.60 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 347.5201 MCF	24 HR RUNNING
FUEL GAS 1090.296 MCF	24 HR PREVIOUS
FUEL GAS 1437.825 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 20661.08 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.77 RATIO

FUEL GAS 691.3334 MCF	24 HR RUNNING
FUEL GAS 2164.165 MCF	24 HR PREVIOUS
FUEL GAS 2855.550 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 50390.66 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS


0.73 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 2005 VERSION: 0
DATE: 01/29/91 TIME: 08:40:20

TG-101A TURBINE INSTRUMENTATION

29/JAN/91
08:40:17



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0
 DATE: 01/29/91 TIME: 08:40:03

29/JAN/91

GAS TOTALIZERS

08:40:01

FUEL GAS 385.7537 MCF	24 HR RUNNING
FUEL GAS 1062.649 MCF	24 HR PREVIOUS
FUEL GAS 1448.413 MCF	7 DAY RUNNING
FUEL GAS 7592.704 MCF	7 DAY PREVIOUS
FUEL GAS 22019.02 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 396.8375 MCF	24 HR RUNNING
FUEL GAS 1090.296 MCF	24 HR PREVIOUS
FUEL GAS 1487.132 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 28711.37 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.76 RATIO

FUEL GAS 789.3427 MCF	24 HR RUNNING
FUEL GAS 2164.165 MCF	24 HR PREVIOUS
FUEL GAS 2953.615 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 51083.18 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS


0.74 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 2005 VERSION: 0
 DATE: 01/29/91 TIME: 09:35:42

TG-101A TURBINE INSTRUMENTATION

29/JAN/91
 09:35:39



EVAP COOLER SUPPLY
 EVAP COOLER DRAIN .68GPM

P1 AUTO REQUEST

P2 MANUAL REQUEST

COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/29/91 TIME: 09:35:58

29/JAN/91

GAS TOTALIZERS

09:35:54

FUEL GAS 426.6485 MCF	24 HR RUNNING
FUEL GAS 1062.649 MCF	24 HR PREVIOUS
FUEL GAS 1489.311 MCF	7 DAY RUNNING
FUEL GAS 7532.704 MCF	7 DAY PREVIOUS
FUEL GAS 22058.37 MCF	MONTH RUNNING
FUEL GAS 32378.96 MCF	MONTH PREVIOUS

FUEL GAS 439.2087 MCF	24 HR RUNNING
FUEL GAS 1090.296 MCF	24 HR PREVIOUS
FUEL GAS 1529.529 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 28752.53 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.77 RATIO

FUEL GAS 873.1702 MCF	24 HR RUNNING
FUEL GAS 2164.165 MCF	24 HR PREVIOUS
FUEL GAS 3037.314 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 51161.70 MCF	MONTH RUNNING
FUEL GAS 65384.48 MCF	MONTH PREVIOUS

0.73 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/30/91 TIME: 04:41:03

30/JAN/91

GAS TOTALIZERS

04:40:58

FUEL GAS 206.3277 MCF	24 HR RUNNING
FUEL GAS 1058.914 MCF	24 HR PREVIOUS
FUEL GAS 2327.886 MCF	7 DAY RUNNING
FUEL GAS 7592.704 MCF	7 DAY PREVIOUS
FUEL GAS 22863.44 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 213.7569 MCF	24 HR RUNNING
FUEL GAS 1092.180 MCF	24 HR PREVIOUS
FUEL GAS 2396.216 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 29587.29 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.77 RATIO


FUEL GAS 423.2353 MCF	24 HR RUNNING
FUEL GAS 2163.163 MCF	24 HR PREVIOUS
FUEL GAS 4750.917 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 52771.98 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS

0.74 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 2011 VERSION: 0

DATE: 01/30/91 TIME: 04:40:47



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/30/91 TIME: 05:38:06

30/JAN/91

GAS TOTALIZERS

05:38:04

FUEL GAS 248.4298 MCF	24 HR RUNNING
FUEL GAS 1058.914 MCF	24 HR PREVIOUS
FUEL GAS 2369.954 MCF	7 DAY RUNNING
FUEL GAS 7592.704 MCF	7 DAY PREVIOUS
FUEL GAS 22903.58 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 257.1888 MCF	24 HR RUNNING
FUEL GAS 1092.180 MCF	24 HR PREVIOUS
FUEL GAS 2439.687 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 29630.21 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS


0.76 RATIO

FUEL GAS 509.5195 MCF	24 HR RUNNING
FUEL GAS 2163.163 MCF	24 HR PREVIOUS
FUEL GAS 4837.327 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 52852.28 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS

0.74 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 2011 VERSION: 0
DATE: 01/30/91 TIME: 05:38:25



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/30/91 TIME: 06:37:57

30/JAN/91

GAS TOTALIZERS

06:37:57

FUEL GAS 292.5667 MCF	24 HR RUNNING
FUEL GAS 1058.914 MCF	24 HR PREVIOUS
FUEL GAS 2414.076 MCF	7 DAY RUNNING
FUEL GAS 7592.704 MCF	7 DAY PREVIOUS
FUEL GAS 22945.63 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 302.7342 MCF	24 HR RUNNING
FUEL GAS 1092.180 MCF	24 HR PREVIOUS
FUEL GAS 2485.213 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 29675.77 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.76 RATIO

FUEL GAS 599.8250 MCF	24 HR RUNNING
FUEL GAS 2163.163 MCF	24 HR PREVIOUS
FUEL GAS 4926.118 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 52936.38 MCF	MONTH RUNNING
FUEL GAS 65384.48 MCF	MONTH PREVIOUS

0.74 RATIO


COPY IN PROGRESS

DIAGRAM NUMBER: 2011 VERSION: 0

DATE: 01/30/91 TIME: 06:37:39

TG-101B TURBINE INSTRUMENTATION

30/JAN/91
06:37:39



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/30/91 TIME: 07:41:06

30/JAN/91

GAS TOTALIZERS

07:41:06

FUEL GAS 339.3084 MCF	24 HR RUNNING
FUEL GAS 1058.914 MCF	24 HR PREVIOUS
FUEL GAS 2460.819 MCF	7 DAY RUNNING
FUEL GAS 7532.704 MCF	7 DAY PREVIOUS
FUEL GAS 22990.03 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 350.8921 MCF	24 HR RUNNING
FUEL GAS 1092.180 MCF	24 HR PREVIOUS
FUEL GAS 2533.362 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 29724.49 MCF	MONTH RUNNING
FUEL GAS 32580.51 MCF	MONTH PREVIOUS

0.76 RATIO

FUEL GAS 695.4847 MCF	24 HR RUNNING
FUEL GAS 2183.183 MCF	24 HR PREVIOUS
FUEL GAS 5024.298 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 53025.21 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS


0.74 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 2011 VERSION: 0
 DATE: 01/30/91 TIME: 07:40:50

TG-101B TURBINE INSTRUMENTATION

30/JAN/91
 07:40:47



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0
 DATE: 01/30/91 TIME: 08:37:36

08:37:33

30/JAN/91

GAS TOTALIZERS

FUEL GAS 380.7083 MCF	24 HR RUNNING
FUEL GAS 1058.914 MCF	24 HR PREVIOUS
FUEL GAS 2502.229 MCF	7 DAY RUNNING
FUEL GAS 7592.704 MCF	7 DAY PREVIOUS
FUEL GAS 23029.78 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 393.9765 MCF	24 HR RUNNING
FUEL GAS 1092.190 MCF	24 HR PREVIOUS
FUEL GAS 2576.436 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 29767.82 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.75 RATIO

FUEL GAS 780.5005 MCF	24 HR RUNNING
FUEL GAS 2163.163 MCF	24 HR PREVIOUS
FUEL GAS 5109.256 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 53104.75 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS

0.73 RATIO


COPY IN PROGRESS

DIAGRAM NUMBER: 2011 VERSION: 0

DATE: 01/30/91 TIME: 08:37:54

TG-101B TURBINE INSTRUMENTATION

30/JAN/91
08:37:49



COPY IN PROGRESS

DIAGRAM NUMBER: 3050 VERSION: 0

DATE: 01/30/91 TIME: 09:41:08

30/JAN/91

GAS TOTALIZERS

09:41:08

FUEL GAS 427.7813 MCF	24 HR RUNNING
FUEL GAS 1058.914 MCF	24 HR PREVIOUS
FUEL GAS 2549.308 MCF	7 DAY RUNNING
FUEL GAS 7532.704 MCF	7 DAY PREVIOUS
FUEL GAS 23074.43 MCF	MONTH RUNNING
FUEL GAS 32978.96 MCF	MONTH PREVIOUS

FUEL GAS 442.0926 MCF	24 HR RUNNING
FUEL GAS 1092.180 MCF	24 HR PREVIOUS
FUEL GAS 2624.530 MCF	7 DAY RUNNING
FUEL GAS 7557.798 MCF	7 DAY PREVIOUS
FUEL GAS 29815.03 MCF	MONTH RUNNING
FUEL GAS 32560.51 MCF	MONTH PREVIOUS

0.76 RATIO

FUEL GAS 876.0396 MCF	24 HR RUNNING
FUEL GAS 2163.163 MCF	24 HR PREVIOUS
FUEL GAS 5204.816 MCF	7 DAY RUNNING
FUEL GAS 15217.91 MCF	7 DAY PREVIOUS
FUEL GAS 53193.98 MCF	MONTH RUNNING
FUEL GAS 65984.48 MCF	MONTH PREVIOUS


0.74 RATIO

COPY IN PROGRESS

DIAGRAM NUMBER: 2011 VERSION: 0
DATE: 01/30/91 TIME: 09:40:42

TG-101B TURBINE INSTRUMENTATION

30/JAN/91
09:40:39



COPY IN PROGRESS