

BK019

**AIR POLLUTION SOURCE TESTING AT THE
HIGH SIERRA LIMITED COGENERATION FACILITY,
BAKERSFIELD, CALIFORNIA**

Prepared for:

**Destec Operating Company
34759 Lencioni Avenue
Bakersfield, California 93308**

For Submittal to:

**Kern County Air Pollution Control District
2700 M Street, Suite 275
Bakersfield, California 93301**

Test Dates:

February 12, 1992


Report Date:

March 6, 1992

Prepared by:

**Engineering-Science, Inc.
2520 Pegasus Drive
Bakersfield, California 93308
(805)393-0272**

Endorsed by:


Project Manager
Engineering-Science, Inc.

RECEIVED
MAR 17 1992
KERN COUNTY AIR
POLLUTION CONTROL DISTRICT

Per 3/17/92


SUMMARY OF SOURCE TEST RESULTS

Company : DESTEC HIGH SIERRA COGEN
 Test Date : 12-Feb-92

Permit # 4162001 (B)
 UNIT 1 / HRSG STACK

		gr/scf	gr/scf @12% CO2	ppm(v)	ppm(v) @15% O2	lb/hr	lb/MMBtu
AMMONIA	Run 1			13.54			
	2			12.71			
	Mean			13.13			
SULFATE	Run 1						
	2						
	Mean						
NOx as NO2, dry	Run 1			3.20	2.67	2.50	0.0097
	2			3.04	2.52	2.36	0.0092
	Mean			3.12	2.59	2.43	0.0095
CO	Run 1			30.27	25.22	14.40	0.0560
	2			30.45	25.26	14.41	0.0561
	Mean			30.36	25.24	14.40	0.0561
SO2	Run 1						
	2						
	Mean						
HC (non-methane)	Run 1			0.00	0.00	0.00	0.0000
	2			1.00	0.83	0.27	0.0011
	3			1.00	0.83	0.27	0.0011
	Mean			0.67	0.55	0.18	0.0007

Scrubber Liquor Analysis :
 Chlorides-

Specific Gravity-

Comments : ANNUAL 2001 - POC FAS F 25 MW TURBINE W
 H₂O INS, NH₃/SCR, + CO CAT

For Regulatory Agency Use Only :

A.A.W. 3/25/92

SUMMARY OF SOURCE TEST RESULTS

Company : **DESTEC HIGH SIERRA COGEN**
 Test Date : **12-Feb-92**

Permit # **4162002** (B)
 UNIT 2 / HRSO STACK

	gr/scf	gr/scf @12% CO2	ppm(v)	ppm(v) @15% O2	lb/hr	lb/MMBtu
AMMONIA						
Run 1			10.72			
2			11.49			
Mean			11.11			
SULFATE						
Run 1						
2						
Mean						
NOx as NO2, dry						
Run 1			3.70	3.16	2.90	0.0115
2			3.01	2.54	2.32	0.0093
Mean			3.35	2.85	2.61	0.0104
CO						
Run 1			32.94	28.14	15.74	0.0625
2			37.60	31.74	17.62	0.0705
Mean			35.27	29.94	16.68	0.0665
SO2						
Run 1						
2						
Mean						
HC (non-methane)						
Run 1			2.00	1.71	0.55	0.0022
2			2.00	1.69	0.54	0.0021
3			3.00	2.53	0.81	0.0032
Mean			2.33	1.98	0.63	0.0025

Scrubber Liquor Analysis :
 Chlorides-

Specific Gravity-

Comments : ANNUAL 210.1 - PUC CASE 25 MW TURBINE W
 H2O INJ, NH3/SCR, + CO CAT

For Regulatory Agency Use Only :

Q/A 3/24/92

TABLE OF CONTENTS

SECTION 1	INTRODUCTION
SECTION 2	DATA SUMMARIES
SECTION 3	TEST METHOD CALCULATIONS
SECTION 4	CONTINUOUS TEST METHODS
SECTION 5	LAB ANALYSIS DATA
SECTION 6	TEST METHODOLOGY
SECTION 7	RAW DATA
SECTION 8	QUALITY ASSURANCE

SECTION 1

INTRODUCTION

**AIR POLLUTION SOURCE TESTING AT THE
HIGH SIERRA LIMITED COGENERATION FACILITY,
BAKERSFIELD, CALIFORNIA**

SECTION 1

INTRODUCTION

On February 12, 1992 Engineering-Science, Inc.(ES), Bakersfield, California, conducted air pollution compliance tests on the exhaust stacks of the two gas turbines at the High Sierra Limited cogeneration facility. Testing was performed to demonstrate compliance with Kern County Air Pollution Control District (KCAPCD) Permit Nos. 4162001 and 4162002. This facility is owned and operated by Destec Operating Company and is located north of Bakersfield off of Oilfields Road.

The cogeneration facility is comprised of two natural gas fired, General Electric, Model LM-2500 gas turbines. Steam injection and a Selective Catalytic Reduction (SCR) system using ammonia injection are used to reduce NO_x emissions. A CO catalyst is used for Carbon Monoxide (CO) emission control. Both units were operated at 100% of the rated load during the source testing.

ES used continuous monitors to measure nitrogen oxides (NO_x), carbon monoxide (CO), and oxygen (O₂) concentration levels on each turbine. Two one hour test runs were conducted at the HRSG stack on each turbine. The testing was conducted in accordance CARB Method 1-100. In addition to continuous emissions monitoring, three grab samples of the exhaust gas were collected in Tedlar bags and analyzed for methane/non-methane hydrocarbons in accordance with EPA Method 18 as published in Title 40 CFR, Part 60, Appendix A, revised as of July 1, 1990. The hydrocarbon samples were analyzed by Zalco Laboratories, Inc., Bakersfield, California.

Ammonia slip was determined using wet impingement sampling trains configured in accordance with BAAQMD Method ST-1b. The ammonia samples were analyzed by

SECTION 2

DATA SUMMARIES

SECTION 2

DATA SUMMARIES

The test results for NO_x, CO, NH₃, and HC are presented in the Summary of Source Test Results at the front of this report. Additional data summaries are presented in the following tables of this section to supplement and clarify results. Section 3, Test Method Calculations presents emission calculations for NO_x, CO, NH₃, and HC along with the fuel calculations used for calculating these emissions.

TABLE 2-1
SUMMARY OF GAS COMPONENTS
DESTEC HIGH SIERRA COGEN
BAKERSFIELD, CALIFORNIA
FEBRUARY 11, 1992

RUN #	UNIT 1						UNIT 2						
	O2 %	NOx ppm	NOx lb/hr	NOx lb/MMBtu	CO ppm	CO lb/hr	O2 %	NOx ppm	NOx lb/hr	NOx lb/MMBtu	CO ppm	CO lb/hr	CO lb/MMBtu
1	13.82	3.20	2.50	0.0097	30.27	14.40	13.99	3.70	2.90	0.0115	32.94	15.74	0.0625
2	13.79	3.04	2.36	0.0092	30.45	14.41	13.91	3.01	2.32	0.0093	37.60	17.62	0.0705
AVG	13.81	3.12	2.43	0.0095	30.36	14.40	13.95	3.35	2.61	0.0104	35.27	16.68	0.0665

TABLE 2-2
SUMMARY OF GAS COMPONENTS
DESTEC HIGH SIERRA COGEN
BAKERSFIELD, CALIFORNIA
FEBRUARY 12, 1992

RUN #	UNIT 1					UNIT 2				
	O2 %	NH3 ppm	HC ppm	HC lb/hr	HC lb/MMBtu	O2 %	NH3 ppm	HC ppm	HC lb/hr	HC lb/MMBtu
1	13.82	13.54	0.00	0.00	0.0000	13.99	10.72	2.00	0.55	0.0022
2	13.79	12.71	1.00	0.27	0.0011	13.91	11.49	2.00	0.54	0.0021
3	13.79	-	1.00	0.27	0.0011	13.91	-	3.00	0.81	0.0032
AVG	13.81	13.13	0.67	0.18	0.0007	13.95	11.11	2.33	0.63	0.0025

**EMISSION DATA SUMMARY
GAS COMPONENTS**

**DESTEC HIGH SIERRA COGEN
UNIT 1 / HRSO STACK**

12-Feb-92

NITROGEN DIOXIDE

<u>Run #</u>	<u>% O2</u>	<u>Corrected ppm (dry)</u>	<u>Corrected ppm (dry) @ 15% O2</u>	<u>lb/hr</u>	<u>lb/MMBtu</u>
1	13.82	3.20	2.67	2.50	0.0097
2	13.79	3.04	2.52	2.36	0.0092
Average	13.80	3.12	2.59	2.43	0.0095

CARBON MONOXIDE

<u>Run #</u>	<u>Corrected ppm (dry)</u>	<u>Corrected ppm (dry) @ 15% O2</u>	<u>lb/hr</u>	<u>lb/MMBtu</u>
1	30.27	25.22	14.40	0.0560
2	30.45	25.26	14.41	0.0561
Average	30.36	25.24	14.40	0.0561

SULFUR DIOXIDE

<u>Run #</u>	<u>Corrected ppm (dry)</u>	<u>Corrected ppm (dry) @ 15% O2</u>	<u>lb/hr</u>	<u>lb/MMBtu</u>
1				
2				
Average				

HYDROCARBON (NON-METHANE)

<u>Run #</u>	<u>Corrected ppm (dry)</u>	<u>Corrected ppm (dry) @ 15% O2</u>	<u>lb/hr</u>	<u>lb/MMBtu</u>
1	0.00	0.00	0.00	0.0000
2	1.00	0.83	0.27	0.0011
3	1.00	0.83	0.27	0.0011
Average	0.67	0.55	0.18	0.0007

**EMISSION DATA SUMMARY
GAS COMPONENTS**

DESTEC HIGH SIERRA COGEN
UNIT 2 / HRSG STACK

12-Feb-92

NITROGEN DIOXIDE

<u>Run #</u>	<u>% O2</u>	<u>Corrected ppm (dry)</u>	<u>Corrected ppm (dry) @ 15% O2</u>	<u>lb/hr</u>	<u>lb/MMBtu</u>
1	13.99	3.70	3.16	2.90	0.0115
2	13.91	3.01	2.54	2.32	0.0093
<u>Average</u>	<u>13.94</u>	<u>3.35</u>	<u>2.85</u>	<u>2.61</u>	<u>0.0104</u>

CARBON MONOXIDE

<u>Run #</u>	<u>Corrected ppm (dry)</u>	<u>Corrected ppm (dry) @ 15% O2</u>	<u>lb/hr</u>	<u>lb/MMBtu</u>
1	32.94	28.14	15.74	0.0625
2	37.60	31.74	17.62	0.0705
<u>Average</u>	<u>35.27</u>	<u>29.94</u>	<u>16.68</u>	<u>0.0665</u>

SULFUR DIOXIDE

<u>Run #</u>	<u>Corrected ppm (dry)</u>	<u>Corrected ppm (dry) @ 15% O2</u>	<u>lb/hr</u>	<u>lb/MMBtu</u>
1				
2				
<u>Average</u>				

HYDROCARBON (NON-METHANE)

<u>Run #</u>	<u>Corrected ppm (dry)</u>	<u>Corrected ppm (dry) @ 15% O2</u>	<u>lb/hr</u>	<u>lb/MMBtu</u>
1	2.00	1.71	0.55	0.0022
2	2.00	1.69	0.54	0.0021
3	3.00	2.53	0.81	0.0032
<u>Average</u>	<u>2.33</u>	<u>1.98</u>	<u>0.63</u>	<u>0.0025</u>

SECTION 3

TEST METHOD CALCULATIONS

NOMENCLATURE

A_s	= Cross-sectional area of stack (ft ²)
A_n	= Cross-sectional area of nozzle (ft ²)
B_{ws}	= Water vapor in the gas stream, proportion by volume (dimensionless)
C_p	= Pitot tube coefficient (dimensionless)
dH	= Average pressure differential across the orifice meter (inches of water)
M_d	= Dry molecular weight of stack gas (lb/lb-mole)
M_s	= Wet molecular weight of stack gas (lb/lb-mole)
N	= Normality of titrant (milliequivalents/ml)
dP	= Velocity pressure of stack gas (inches of water)
P_b	= Barometric pressure at sampling site (in. Hg)
P_s	= Absolute stack gas pressure (in. Hg)
P_{std}	= Standard absolute pressure (29.92 in. Hg)
$Q_s(std)$	= Dry volumetric stack gas flow rate, standard conditions (dscfm)
T_s	= Stack temperature (°F)
V_m	= Dry gas volume as measured by dry gas meter (dcf)
$V_m(std)$	= Dry gas volume as measured by dry gas meter, corrected to standard conditions (dscf)
$V_w(std)$	= Volume of water vapor in the gas stream, corrected to standard conditions (scf)
V_{lc}	= Volume of water vapor condensed in impingers and silica gel (ml)
$T(std)$	= Standard temperature (°F)
T_m	= Meter temperature (°F)
$SQ.RT.dP$	= Square root of velocity pressure (dimensionless)
y	= Dry gas meter calibration factor (dimensionless)
P_{static}	= Static pressure of stack (in. H ₂ O)
P_{stack}	= Static pressure of stack (in. Hg)
I	= Isokinetic sample rate (percent)
v_s	= Average velocity of the stack gas (ft/sec)
Q_s	= Actual stack gas flow rate at stack conditions (ft ³ /min)
Θ	= Total sampling time (min)
% O ₂	= Percent oxygen by volume (dry basis)
% CO ₂	= Percent carbon dioxide by volume (dry basis)
% CO	= Percent carbon monoxide by volume (dry basis)
% N ₂	= Percent nitrogen by volume (dry basis)
Z_{cf}	= Zero drift correction factor
S_{cf}	= Span drift correction factor
C_z	= Zero correction concentration
MW	= Molecular weight (lb/lb-mole)
ppm	= Parts per million by volume

lb/MMBtu	= Emission concentration, pounds per million British thermal units
dscf/MMBtu	= Fuel factor, dry standard cubic feet per million British thermal units
gr/scf	= Emission concentration, grains per standard cubic foot
lb/hr	= Emission rate, pounds per hour
FHW	= Front Half Wash of sampling train
MF	= Mass Filter of sampling train
BHW	= Back Half Wash of Sampling train
gr/dscf	= Emission concentration, grains per dry standard cubic foot
ng	= Mass unit, nanograms
mg	= Mass unit, milligrams
g	= Mass unit, grams
ml	= Unit of volume, milliliters
L	= Unit of volume, liters
ul	= Unit of volume, microliters
H ₂ SO ₄	= Chemical formula, sulfuric acid
BaCl ₂	= Chemical formula, barium chloride
NaOH	= Chemical formula, sodium hydroxide
H ₂ S	= Chemical formula, hydrogen sulfide
FHS	= Front Half Sulfate of sampling train
BHS	= Back Half Sulfate of sampling train
F-Factor	= Fuel factor, volume of generated gases per unit of heat content (dscf/MMBtu)
°F	= Degrees Fahrenheit
°R	= Degrees Rankine
°C	= Degrees Celsius
98.076	= Molecular weight of sulfuric acid
64.062	= Molecular weight of sulfur dioxide
46.006	= Molecular weight of nitrogen dioxide
28.010	= Molecular weight of carbon monoxide
60	= Conversion factor, minutes per hour
460	= Conversion factor, °F to °R
15.432	= Conversion factor, grains per gram
0.000143	= Conversion factor, pounds per grain
32/98.076	= Conversion factor, equivalent weight of SO ₂ to MW of H ₂ SO ₄
1.60982	= Ideal Gas Law (lb-mole x dscf/ dscf/ °R x mg)
0.00000137	= Ideal Gas Law (lb-mole x °R/ft ³)
0.280	= Molecular weight of N ₂ or CO, divided by 100
0.320	= Molecular weight of O ₂ , divided by 100
0.440	= Molecular weight of CO ₂ , divided by 100
18.0	= Molecular weight of H ₂ O
32.064	= Equivalent weight of SO ₂
85.49	= Pitot tube constant, ft/sec x [(lb/lb-mole) x (in.Hg)/(°R) x (in.H ₂ O)] ^{0.5}
8.223E-05	= Ideal gas constant (1.37E-06 lb-mole °R/ft ³) x (60 min/hr)

**EMISSION CALCULATIONS
GAS COMPONENTS**

**DESTEC HIGH SIERRA COGEN
UNIT 1 / HRSG STACK**

DATA :	Run 1	Run 2	Run 3	Average
Date	12-Feb-92	12-Feb-92	12-Feb-92	
Oxygen (%)	13.82	13.79	13.79	13.80
Qs(std), dscfm	107,435	106,796	106,796	107,009
F-Factor, dscf/MMBtu	8,493.44	8,493.44	8,493.44	8,493.44
NOx, ppm	3.20	3.04		3.12
CO, ppm	30.27	30.45		30.36
SO2, ppm				
HC (non-methane), ppm	0.00	1.00	1.00	0.67

CALCULATIONS :				
NOx, lb/hr	2.50	2.36		2.43
NOx, ppm @ 15 %O2	2.67	2.52		2.59
NOx, lb/MMBtu	0.0097	0.0092		0.0095
CO, lb/hr	14.40	14.41		14.40
CO, ppm @ 15 %O2	25.22	25.26		25.24
CO, lb/MMBtu	0.0560	0.0561		0.0561
SO2, lb/hr				
SO2, ppm @ 15 %O2				
SO2, lb/MMBtu				
HC, lb/hr	0.00	0.27	0.27	0.18
HC, ppm @ 15 %O2	0.00	0.83	0.83	0.55
HC, lb/MMBtu	0.0000	0.0011	0.0011	0.0007

EQUATIONS :

$$\text{lb/hr} = (0.00000137 \text{ Lb-Mole } ^\circ\text{R} / \text{ft}^3) \times 60 \text{ min/hr} \times \text{Qs(std)} \times \text{MW} \times \text{ppm} / [\text{T(std)} + 460]$$

$$\text{ppm @ 15 \%O}_2 = \text{ppm measured} \times [(20.9 - 15 \%O_2) / (20.9 - \%O_2 \text{ measured})]$$

$$\text{lb/MMBtu} = \text{F-Factor} \times \text{MW} \times [(1.3711\text{E}-6 \text{ Lb-Mole } ^\circ\text{R} / \text{ft}^3) / (\text{T(std)} + 460)] \times [20.9 / (20.9 - \text{O}_2\%)] \times \text{ppm}$$

CONSTANTS :

Standard Temp. T(std): 60 °F
Oxygen Correction : 15 % O2

NOx, MW = 46.005 lb/lb-mole SO2, MW = 64.058 lb/lb-mole
CO, MW = 28.010 lb/lb-mole HC, MW = 16.043 lb/lb-mole

**EMISSION CALCULATIONS
GAS COMPONENTS**

**DESTEC HIGH SIERRA COGEN
UNIT 2 / HRSG STACK**

DATA :				
	Run 1	Run 2	Run 3	Average
Date	12-Feb-92	12-Feb-92	12-Feb-92	
Oxygen (%)	13.99	13.91	13.91	13.94
Qs(std), dscfm	107,877	105,783	105,783	106,481
F-Factor, dscf/MMBtu	8,493.44	8,493.44	8,493.44	8,493.44
NOx, ppm	3.70	3.01		3.35
CO, ppm	32.94	37.60		35.27
SO2, ppm				
HC (non-methane), ppm	2.00	2.00	3.00	2.33

CALCULATIONS :				
NOx, lb/hr	2.90	2.32		2.61
NOx, ppm @ 15 %O2	3.16	2.54		2.85
NOx, lb/MMBtu	0.0115	0.0093		0.0104
CO, lb/hr	15.74	17.62		16.68
CO, ppm @ 15 %O2	28.14	31.74		29.94
CO, lb/MMBtu	0.0625	0.0705		0.0665
SO2, lb/hr				
SO2, ppm @ 15 %O2				
SO2, lb/MMBtu				
HC, lb/hr	0.55	0.54	0.81	0.63
HC, ppm @ 15 %O2	1.71	1.69	2.53	1.98
HC, lb/MMBtu	0.0022	0.0021	0.0032	0.0025

EQUATIONS :

$$\text{lb/hr} = (0.00000137 \text{ Lb-Mole } ^\circ\text{R} / \text{ft}^3) \times 60 \text{ min/hr} \times Qs(\text{std}) \times MW \times \text{ppm} / [T(\text{std}) + 460]$$

$$\text{ppm @ 15 \%O}_2 = \text{ppm measured} \times [(20.9 - 15 \%O_2) / (20.9 - \%O_2 \text{ measured})]$$

$$\text{lb/MMBtu} = \text{F-Factor} \times MW \times [(1.3711\text{E}-6 \text{ Lb-Mole } ^\circ\text{R} / \text{ft}^3) / (T(\text{std}) + 460)] \times [20.9 / (20.9 - O_2\%)] \times \text{ppm}$$

CONSTANTS :

Standard Temp. T(std): 60 °F
Oxygen Correction : 15 % O2

NOx, MW = 46.005 lb/lb-mole SO2, MW = 64.058 lb/lb-mole
CO, MW = 28.010 lb/lb-mole HC, MW = 16.043 lb/lb-mole

AMMONIA CALCULATIONS

Company Name :	DESTEC HIGH SIERRA COGEN	O2 Correction :	15 %
Source :	UNIT 1 / HRSG STACK	Standard Temp. :	60 °F
Date :	12-Feb-92	Standard Press. :	29.92 "Hg

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Run 4</u>	<u>Run 5</u>	<u>Run 6</u>
Tm, °F	57.83	63.33				
Y, meter correction factor	1.0030	1.0030				
Vm, ft3	19.005	18.853				
Pb, in.Hg.	28.74	28.74				
dH, in.H2O	1.50	1.50				
O2, percent	13.82	13.79				
Qs(std), dscfm	107435	106796				
Vm(std), dscf	18.458	18.117				
mg AMMONIA	5.10	4.70				
ppm AMMONIA	13.542	12.714				
ppm AMMONIA @ 15.0 %O2	11.285	10.551				

EQUATIONS :

$$Vm(std), dscf = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460)$$

$$ppm \text{ AMMONIA} = 1.60982 \times (Temp.Std. + 460) \times (mg \text{ AMMONIA}) / (MW \times Vm, std)$$

Where : 1.60982 = Ideal Gas Law Factor

Where MW of AMMONIA = 17.08 Lb/Lb-Mole

$$ppm \text{ AMMONIA @ corrected O2\%} = ppm \text{ AMMONIA} \times [20.9 - O2 \text{ correction} / (20.9 - \%O2 \text{ measured})]$$

$$lb/hr = (0.00000137 \text{ Lb-Mole } ^\circ R / ft^3) \times 60 \text{ min/hr} \times Qs(std) \times MW \times ppm / [T(std) + 460]$$

AMMONIA CALCULATIONS

Company Name : DESTEC HIGH SIERRA COGEN O2 Correction : 15 %
Source : UNIT 2 / HRSG STACK Standard Temp. : 60 °F
Date : 12-Feb-92 Standard Press. : 29.92 *Hg

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Run 4</u>	<u>Run 5</u>	<u>Run 6</u>
Tm, °F	63.50	65.33				
Y, meter correction factor	1.0030	1.0030				
Vm, ft3	19.029	19.142				
Pb, in.Hg.	28.75	28.76				
dH, in.H2O	1.50	1.50				
O2, percent	13.99	13.91				
Qs(std), dscfm	107877	105783				
Vm(std), dscf	18.287	18.338				
mg AMMONIA	4.00	4.30				
ppm AMMONIA	10.720	11.492				
ppm AMMONIA @ 15.0 %O2	9.153	9.700				

EQUATIONS :

$$Vm(std), dscf = [T(std) + 460 / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460)$$

$$ppm \text{ AMMONIA} = 1.60982 \times (Temp.Std. + 460) \times (mg \text{ AMMONIA}) / (MW \times Vm,std)$$

Where : 1.60982 = Ideal Gas Law Factor

Where MW of AMMONIA = 17.08 Lb/Lb-Mole

$$ppm \text{ AMMONIA @ corrected O2\%} = ppm \text{ AMMONIA} \times [20.9 - O2 \text{ correction} / (20.9 - \%O2 \text{ measured})]$$

$$lb/hr = (0.00000137 \text{ Lb-Mole } ^\circ R / ft^3) \times 60 \text{ min/hr} \times Qs(std) \times MW \times ppm / [T(std) + 460]$$

FUEL BASED CALCULATIONS

DESTEC HIGH SIERRA COGEN
UNIT 1 / HRSG STACK

12-Feb-92

FUEL ANALYSIS DATA										
Run #	Fuel Value (%), Moisture & Ash Free					GCV BTU/lb	ft ³ /lb	lb/gal		
	Carbon	Hydrogen	Nitrogen	Oxygen	Sulfur					
1	72.80	23.85	0.91	2.43	0.00	22,867				
2	72.80	23.85	0.91	2.43	0.00	22,867				

CALCULATIONS									
Run #	Stack Gas Oxygen %	Fuel Gas Flowrate		Fuel Oil Flowrate		Solid Fuel lb/hr	Heat Input MMBTU/hr	F-Factor dscf/MMBTU	Qs(std) dscfm
		lb/hr	ft ³ /hr	lb/hr	gal/hr				
1	13.82	11,243					257.100	8,493.44	107,435
2	13.79	11,224					256.654	8,493.44	106,796

Heat Input, MMBTU/hr = (lb/hr fuel gas) x BTU/lb x MM/1E+06
 = (ft³/hr fuel gas) x BTU/lb / (ft³/lb fuel gas) x MM/1E+06
 = (lb/hr fuel oil) x BTU/lb x MM/1E+06
 = (gal/hr fuel oil) x lb/gal x BTU/lb x MM/1E+06
 = (lb/hr solid fuel) x BTU/lb x MM/1E+06

F-Factor, dscf/MMBTU = $1E+06 [3.64 \times (\% H) + 1.53 \times (\% C) + 0.57 \times (\% S) + 0.14 \times (\% N) - 0.46 \times (\% O_2)] / (BTU/lb) \times [(T_{std} + 460) / 528]$

Qs(std), dscfm = MMBTU/hr x [F-Factor x (20.9 / (20.9 - %O₂)) x (hr / 60 min)]

GCV = Gross Calorific Value of fuel

Standard Temperature = 60 °F

FUEL BASED CALCULATIONS

DESTEC HIGH SIERRA COGEN
UNIT 2 / HRSG STACK

12-Feb-92

FUEL ANALYSIS DATA								
Run #	Fuel Value (%), Moisture & Ash Free							
	Carbon	Hydrogen	Nitrogen	Oxygen	Sulfur	GCV BTU/lb	ft3/lb	lb/gal
1	72.80	23.85	0.91	2.43	0.00	22,867		
2	72.80	23.85	0.91	2.43	0.00	22,867		

CALCULATIONS									
Run #	Stack Gas Oxygen %	Fuel Gas Flowrate		Fuel Oil Flowrate		Solid Fuel lb/hr	Heat Input MMBTU/hr	F-Factor dscf/MMBTU	Qs(std) dscfm
		lb/hr	ft3/hr	lb/hr	gal/hr				
1	13.99	11,018					251.959	8,493.44	107,877
2	13.91	10,930					249.927	8,493.44	105,783

$$\begin{aligned}
 \text{Heat Input, MMBTU/hr} &= (\text{lb/hr fuel gas}) \times \text{BTU/lb} \times \text{MM}/1\text{E}+06 \\
 &= (\text{ft}^3/\text{hr fuel gas}) \times \text{BTU/lb} / (\text{ft}^3/\text{lb fuel gas}) \times \text{MM}/1\text{E}+06 \\
 &= (\text{lb/hr fuel oil}) \times \text{BTU/lb} \times \text{MM}/1\text{E}+06 \\
 &= (\text{gal/hr fuel oil}) \times \text{lb/gal} \times \text{BTU/lb} \times \text{MM}/1\text{E}+06 \\
 &= (\text{lb/hr solid fuel}) \times \text{BTU/lb} \times \text{MM}/1\text{E}+06
 \end{aligned}$$

$$\text{F-Factor, dscf/MMBTU} = 1\text{E}+06 [3.64 \times (\% \text{H}) + 1.53 \times (\% \text{C}) + 0.57 \times (\% \text{S}) + 0.14 \times (\% \text{N}) - 0.46 \times (\% \text{O}_2)] / (\text{BTU/lb}) \times [(\text{Tstd} + 460) / 528]$$

$$\text{Qs(std), dscfm} = \text{MMBTU/hr} \times [\text{F-Factor} \times (20.9 / (20.9 - \% \text{O}_2)) \times (\text{hr} / 60 \text{ min})]$$

$$\text{GCV} = \text{Gross Calorific Value of fuel}$$

$$\text{Standard Temperature} = 60 \text{ }^\circ\text{F}$$

SECTION 4

CONTINUOUS TEST METHODS

GAS ANALYZER DATA

DESTEC HIGH SIERRA COGEN
UNIT 1 / HRSG STACK

Date : 12-Feb-92
Run No. : 1

Point #	O2, %		CO2, %		NOx, ppm		CO, ppm		SO2, ppm	
	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading
1	13.80	13.81	4.10	4.09	3.20	3.20	30.50	30.53		
2	13.80	13.82	4.15	4.13	3.15	3.14	30.50	30.58		
3	13.80	13.83	4.17	4.13	3.20	3.18	30.00	30.14		
4	13.80	13.84	4.20	4.14	3.25	3.22	29.80	29.99		
5	13.75	13.80	4.20	4.13	3.30	3.26	29.80	30.05		
6	13.75	13.81	4.20	4.11	3.25	3.20	30.00	30.31		
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
MEAN :	13.82		4.12		3.20		30.27			

Zero Check	-0.05	0.10	0.12	0.00
Span Check	14.00	9.12	5.64	44.50
Initial Span Value	14.07	9.02	5.64	45.00
Drift, Percent	-0.1	-0.0	-2.1	-1.1
Zero Drift, Zcf	-0.00833	0.01667	0.02000	0.00000
Span Drift, Scf	-0.00024	-0.00000	-0.00355	-0.00185

Drift, Percent = [(Span Check - Zero Check) - Calib. Gas] / Calib. Gas x 100

Zero Drift Correction Factor, Zcf = Zero Check / # of Readings

Span Drift Correction Factor, Scf = (% Drift / 100) / # of Readings

Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]

Drift Corrected Reading = Cz / [1 + (Scf x (Point # - 0.5))]

GAS ANALYZER DATA

DESTEC HIGH SIERRA COGEN
UNIT 1 / HRSG STACK

Date : 12-Feb-92
Run No. : 2

Point #	O2, %		CO2, %		NOx, ppm		CO, ppm		SO2, ppm	
	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading
1	13.83	13.82	4.10	4.10	2.97	2.98	31.00	30.97		
2	13.83	13.81	4.10	4.10	2.97	3.00	30.70	30.62		
3	13.83	13.80	4.10	4.10	3.00	3.05	30.50	30.36		
4	13.83	13.78	4.10	4.10	3.05	3.13	30.30	30.11		
5	13.83	13.77	4.10	4.10	2.95	3.05	30.50	30.25		
6	13.83	13.75	4.10	4.10	2.92	3.04	30.70	30.40		
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
MEAN :	13.79		4.10		3.04		30.45			

Zero Check	0.25	0.00	-0.12	1.00
Span Check	14.15	9.02	5.50	45.00
Initial Span Value	14.07	9.02	5.64	45.00
Drift, Percent	-1.2	0.0	-0.4	-2.2
Zero Drift, Zcf	0.04167	0.00000	-0.02000	0.16667
Span Drift, Scf	-0.00201	0.00000	-0.00059	-0.00370

Drift, Percent = [(Span Check - Zero Check) - Calib. Gas] / Calib. Gas x 100

Zero Drift Correction Factor, Zcf = Zero Check / # of Readings

Span Drift Correction Factor, Scf = (% Drift / 100) / # of Readings

Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]

Drift Corrected Reading = Cz / [1 + (Scf x (Point # - 0.5))]

GAS ANALYZER DATA

DESTEC HIGH SIERRA COGEN
UNIT 2 / HRSG STACK

Date : 12-Feb-92
Run No. : 1

Point #	O2, %		CO2, %		NOx, ppm		CO, ppm		SO2, ppm	
	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading
1	13.93	13.95	4.06	4.06	3.60	3.59	35.00	35.07		
2	13.93	13.98	4.06	4.06	3.65	3.62	34.30	34.51		
3	13.93	14.01	4.06	4.06	3.75	3.70	33.00	33.34		
4	13.90	14.01	4.06	4.06	3.80	3.73	32.50	32.97		
5	13.85	13.99	4.06	4.06	3.85	3.76	30.30	30.87		
6	13.85	14.02	4.06	4.06	3.90	3.79	30.20	30.89		
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
MEAN :		13.99		4.06		3.70		32.94		

Zero Check	0.00	0.00	0.29	0.00
Span Check	13.88	9.02	5.67	43.90
Initial Span Value	14.07	9.02	5.64	45.00
Drift, Percent	-1.4	0.0	-4.6	-2.4
Zero Drift, Zcf	0.00000	0.00000	0.04833	0.00000
Span Drift, Scf	-0.00225	0.00000	-0.00768	-0.00407

Drift, Percent = [(Span Check - Zero Check) - Calib. Gas] / Calib. Gas x 100

Zero Drift Correction Factor, Zcf = Zero Check / # of Readings

Span Drift Correction Factor, Scf = (% Drift / 100) / # of Readings

Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]

Drift Corrected Reading = Cz / [1 + (Scf x (Point # - 0.5))]

GAS ANALYZER DATA

DESTEC HIGH SIERRA COGEN
UNIT 2 / HRSG STACK

Date : 12-Feb-92
Run No. : 2

Point #	O2, %		CO2, %		NOx, ppm		CO, ppm		SO2, ppm	
	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading	Instrument Reading	Drift Corrected Reading
1	13.93	13.93	4.06	4.06	2.85	2.85	39.20	39.34		
2	13.93	13.93	4.06	4.06	2.90	2.89	38.50	38.91		
3	13.85	13.85	4.06	4.06	2.97	2.96	44.50	45.34		
4	13.90	13.90	4.06	4.06	3.20	3.19	32.50	33.26		
5	13.93	13.93	4.02	4.02	3.05	3.03	33.50	34.53		
6	13.93	13.93	4.02	4.02	3.15	3.13	33.00	34.24		
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
MEAN :		13.91		4.05		3.01		37.60		

Zero Check	0.25	0.00	-0.02	0.70
Span Check	14.07	9.02	5.70	43.00
Initial Span Value	14.07	9.02	5.64	45.00
Drift, Percent	-1.8	0.0	1.4	-6.0
Zero Drift, Zcf	0.04167	0.00000	-0.00333	0.11667
Span Drift, Scf	-0.00296	0.00000	0.00236	-0.01000

Drift, Percent = [(Span Check - Zero Check) - Calib. Gas] / Calib. Gas x 100

Zero Drift Correction Factor, Zcf = Zero Check / # of Readings

Span Drift Correction Factor, Scf = (% Drift / 100) / # of Readings

Cz, Zero Corr. Concentration = measured value - [Zcf x (Point # - 0.5)]

Drift Corrected Reading = Cz / [1 + (Scf x (Point # - 0.5))]

SECTION 5

LAB ANALYSIS DATA



6060 IRWINDALE AVENUE, SUITE J
 P.O. BOX 2007
 IRWINDALE, CA 91706
 Tel: (818) 969-5758 Fax: (818) 969-4692

REPORT TO: Destec NH₃

DATE: _____

ES NO.: _____

AMMONIA DATA SHEET

STANDARD	
AMMONIA (M)	REL. Mv.
0	+036.3
1X10 ⁻⁵	+003.4
1X10 ⁻⁴	-051.4
1X10 ⁻³	-110.5
1X10 ⁻²	-169.3

ES. NO.	REL. Mv.	AMMONIA (M)	mg./L.	VOL. (L.)	mg./SAMPLE
920241	-088.7	4.1X10 ⁻⁴	6.97	0.445	3.1
920245	-101.3	6.8X10 ⁻⁴	11.6	0.405	4.7
920248	-097.7	6.0X10 ⁻⁴	10.2	0.395	4.0
920253	-093.1	5.1X10 ⁻⁴	8.67	0.445	3.9
920241	-084.7	3.7X10 ⁻⁴	6.29	0.445	2.8
920242	-092.8	4.6X10 ⁻⁴	7.82	0.425	3.3
920243	-094.9	5.4X10 ⁻⁴	9.19	0.400	3.7
920244	-093.7	5.1X10 ⁻⁴	8.67	0.415	3.60



ENGINEERING-SCIENCE, INC.

6060 IRWINDALE AVENUE, SUITE J
P.O. BOX 2007
IRWINDALE, CA 91708
Tel: (818) 969-5758 Fax: (818) 969-4692

REPORT TO: DESTEC NH₃

DATE: _____

ES NO.: _____

AMMONIA DATA SHEET

STANDARD	
AMMONIA (M)	REL. Mv.
0	
1X10 ⁻⁵	
1X10 ⁻⁴	
1X10 ⁻³	
1X10 ⁻²	

ES. NO.	REL. Mv.	AMMONIA (M)	mg. /L.	VOL. (L.)	mg. / SAMPLE
920245	-100.0	6.8 x 10 ⁻⁴	11.56	0.405	4.7
920246	-103.0	7.5 x 10 ⁻⁴	12.75	0.400	5.1
920248	-095.4	5.4 x 10 ⁻⁴	9.18	0.395	3.6
920250	-100.7	6.8 x 10 ⁻⁴	11.56	0.325	3.8
920251	-089.1	4.5 x 10 ⁻⁴	7.65	0.335	2.6
920252	-086.6	3.8 x 10 ⁻⁴	6.46	0.415	2.7
920247	-097.0	6.0 x 10 ⁻⁴	10.2	0.425	4.3
920253	-091.5	4.5 x 10 ⁻⁴	7.65	0.445	3.4

ES**ENGINEERING-SCIENCE, INC.**6060 IRWINDALE AVENUE, SUITE J
P.O. BOX 2007
IRWINDALE, CA 91706
Tel: (818) 969-5758 Fax: (818) 969-4692**NH₃ Spike**

- 1) 50 mL 920244
50 mL 1×10^{-2} M Standard soln.
- 2) 50 mL 920252
50 mL 1×10^{-2} M Standard soln.

Molarity = [(moles A)+(moles B)] / volume L

$$1) \text{ Molarity Spike} = \frac{(0.05\text{L})(5.1 \times 10^{-4} \text{ M/L})}{(0.05\text{L})(1 \times 10^{-2} \text{ M/L})} = \frac{2.6 \times 10^{-6} \text{ m}}{5 \times 10^{-4} \text{ m}}$$

$$= \frac{[(2.6 \times 10^{-6} \text{ m}) + (5 \times 10^{-4} \text{ m})]}{(0.1 \text{ L})}$$

$$= \underline{5.0 \times 10^{-3} \text{ M}}$$

Mv = - 152.5

Molarity from Graph = 5.0×10^{-3} M

$$2) \text{ Molarity Spike} = \frac{(0.05\text{L})(3.8 \times 10^{-4} \text{ M/L})}{(0.05\text{L})(1 \times 10^{-2} \text{ M/L})} = \frac{1.9 \times 10^{-5} \text{ m}}{5 \times 10^{-4} \text{ m}}$$

$$= \frac{[(1.9 \times 10^{-5} \text{ m}) + (5 \times 10^{-4} \text{ m})]}{(0.1 \text{ L})}$$

$$= \underline{5.2 \times 10^{-3} \text{ M}}$$

Mv = - 154.5

Molarity from Graph = 5.2×10^{-3} M



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: 030488_001
Received: Feb 13, 1992
Reported: Feb 14, 1992

Attention: Gary McRae

Sample Description: Destec High Sierra BK202014 Run #1
Unit #1 Gas Turbine 2/12/92

* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)


Components	PPM, Volume
Methane (C1)	35.6
Ethane (C2)	.2
Propane (C3)	<0.1
Butanes (I+N C4)	<0.1
Pentanes (I+N C5)	<0.1
Hexanes+ (C6+)	<0.1
Total Hydrocarbons	35.8
Total Non-Methane Hydrocarbons	0
Total Non-(C1+C2) Hydrocarbons	0
Total Non-Methane Hydrocarbons as C1	0

Kath. Zimmerman
Analyst

Jim Etherton
Jim Etherton
Laboratory Director

Zalco C1-C6 PPM Report

Sample Name : Destec High Sierra BK202014 Run #1
0141, 030488_001, Feb 13, 1992, Unit #1 Gas Turbine 2/12/92
Peak Processor : Genie Multilevel : False
Instrument : ADC_2 Application : Loop
Calculation : ExternalSTD Quantitation: AreaUnits
Result File : /DATA/LOOP/RESULT/ADC_2/ENG30488_001.RES
Run Time : 20.00 Minutes, injected on Fri Feb 14, 1992 9:12:25
Run Status : RunStatusOK
EndOffBaseline



RETENTION TIME	AREA	FACTOR	ppmvol
5.200	5814	6.12552E-03	35.6107
5.817	53	4.06129E-03	.2158
Total Hydrocarbons			35.8264

Report Time: Tue Feb 18, 1992 8:46:03 am
Method: /DATA/LOOP/METHOD/LOWPPMA.MTH
Format File: /DATA/LOOP/FORMAT/SIDE_BY_SIDE.FMT



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: 030488_002
Received: Feb 13, 1992
Reported: Feb 14, 1992

Attention: Gary McRae

Sample Description: Destec High Sierra BK202015 Run #2
Unit #1 Gas Turbine 2/12/92

* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)


Components	PPM, Volume
Methane (C1)	35.9
Ethane (C2)	.5
Propane (C3)	<0.1
Butanes (I+N C4)	<0.1
Pentanes (I+N C5)	<0.1
Hexanes+ (C6+)	<0.1
Total Hydrocarbons	36.4
Total Non-Methane Hydrocarbons	1
Total Non-(C1+C2) Hydrocarbons	0
Total Non-Methane Hydrocarbons as C1	1

Katko Zimmerman
Analyst


Jim Etherton
Jim Etherton
Laboratory Director

Zalco C1-C6 PPM Report

Sample Name : Destec High Sierra BK202015 Run #2
0141, 030488_002, Feb 13, 1992, Unit #1 Gas Turbine 2/12/92
Peak Processor : Genie Multilevel : False
Instrument : ADC_2 Application : Loop
Calculation : ExternalSTD Quantitation: AreaUnits
Result File : /DATA/LOOP/RESULT/ADC_2/ENG30488_002.RES
Run Time : 20.00 Minutes, injected on Fri Feb 14, 1992 9:36:49
Run Status : RunStatusOK
EndOffBaseline



Report Time: Tue Feb 18, 1992 8:48:54 am
Method: /DATA/LOOP/METHOD/LOWPPMA.MTH
Format File: /DATA/LOOP/FORMAT/SIDE_BY_SIDE.FMT



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: 030488_003
Received: Feb 13, 1992
Reported: Feb 14, 1992

Attention: Gary McRae

Sample Description: Destec High Sierra BK202016 Run #3
Unit #1 Gas Turbine 2/12/92

* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)

Components	PPM, Volume
Methane (C1)	34.7
Ethane (C2)	.4
Propane (C3)	<0.1
Butanes (I+N C4)	<0.1
Pentanes (I+N C5)	<0.1
Hexanes+ (C6+)	<0.1
Total Hydrocarbons	35.2
Total Non-Methane Hydrocarbons	0
Total Non-(C1+C2) Hydrocarbons	0
Total Non-Methane Hydrocarbons as C1	1


Kath. Zimmerman
Analyst

Jim Etherton
Jim Etherton
Laboratory Director

Zalco C1-C6 PPM Report

Sample Name : Destec High Sierra BK202016 Run #3
0141, 030488_003, Feb 13, 1992, Unit #1 Gas Turbine 2/12/92
Peak Processor : Genie Multilevel : False
Instrument : ADC_2 Application : Loop
Calculation : ExternalSTD Quantitation: AreaUnits
Result File : /DATA/LOOP/RESULT/ADC_2/ENG30488_003.RES
Run Time : 20.00 Minutes, injected on Fri Feb 14, 1992 10:07:37
Run Status : RunStatusOK
EndOffBaseline

RETENTION TIME	AREA	FACTOR	ppmvol
4.836	131	0.00000E+00	0.0000
5.200	5673	6.12552E-03	34.7478
5.830	106	4.06129E-03	.4321
Total Hydrocarbons			35.1799



Report Time: Tue Feb 18, 1992 8:56:26 am
Method: /DATA/LOOP/METHOD/LOWPPMA.MTH
Format File: /DATA/LOOP/FORMAT/SIDE_BY_SIDE.FMT



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: 030488_004
Received: Feb 13, 1992
Reported: Feb 14, 1992

Attention: Gary McRae

Sample Description: Destec High Sierra BK202017 Run #1
Unit #2 Gas Turbine 2/12/92
* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)

Components	PPM, Volume
Methane (C1)	36.6
Ethane (C2)	1.0
Propane (C3)	<0.1
Butanes (I+N C4)	<0.1
Pentanes (I+N C5)	<0.1
Hexanes+ (C6+)	<0.1
Total Hydrocarbons	37.6
Total Non-Methane Hydrocarbons	1
Total Non-(C1+C2) Hydrocarbons	0
Total Non-Methane Hydrocarbons as C1	2


Kathe Zimmerman
Analyst

Jim Etherton
Jim Etherton
Laboratory Director


Zalco C1-C6 PPM Report

Sample Name : Destec High Sierra BK202017 Run #1
0141, 030488_004, Feb 13, 1992, Unit #2 Gas Turbine 2/12/92
Peak Processor : Genie Multilevel : False
Instrument : ADC_2 Application : Loop
Calculation : ExternalSTD Quantitation: AreaUnits
Result File : /DATA/LOOP/RESULT/ADC_2/ENG30488_004.RES
Run Time : 20.00 Minutes, injected on Fri Feb 14, 1992 10:47:22
Run Status : RunStatusOK
EndOffBaseline

RETENTION TIME	AREA	FACTOR	ppmvol
5.200	5983	6.12552E-03	36.6467
5.831	244	4.06129E-03	.9903
Total Hydrocarbons			37.6370



Report Time: Tue Feb 18, 1992 8:59:40 am
Method: /DATA/LOOP/METHOD/LOWPPMA.MTH
Format File: /DATA/LOOP/FORMAT/SIDE_BY_SIDE.FMT



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: 030488_005
Received: Feb 13, 1992
Reported: Feb 14, 1992

Attention: Gary McRae

Sample Description: Destec High Sierra BK202018 Run #2
Unit #2 Gas Turbine 2/12/92

* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)


Components	PPM, Volume
Methane (C1)	44.1
Ethane (C2)	.9
Propane (C3)	<0.1
Butanes (I+N C4)	<0.1
Pentanes (I+N C5)	<0.1
Hexanes+ (C6+)	<0.1
Total Hydrocarbons	44.9
Total Non-Methane Hydrocarbons	1
Total Non-(C1+C2) Hydrocarbons	0
Total Non-Methane Hydrocarbons as C1	2

Kathy Zimmerman
Analyst


Jim Etherton
Jim Etherton
Laboratory Director

Zalco C1-C6 PPM Report

Sample Name : Destec High Sierra BK202018 Run #2
0141, 030488_005, Feb 13, 1992, Unit #2 Gas Turbine 2/12/92
Peak Processor : Genie Multilevel : False
Instrument : ADC_2 Application : Loop
Calculation : ExternalSTD Quantitation: AreaUnits
Result File : /DATA/LOOP/RESULT/ADC_2/ENG30488_005.RES
Run Time : 20.00 Minutes, injected on Fri Feb 14, 1992 11:11:59
Run Status : RunStatusOK
 EndOffBaseline



Report Time: Tue Feb 18, 1992 9:02:50 am
Method: /DATA/LOOP/METHOD/LOWPPMA.MTH
Format File: /DATA/LOOP/FORMAT/SIDE_BY_SIDE.FMT



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: 030488_006
Received: Feb 13, 1992
Reported: Feb 14, 1992

Attention: Gary McRae


Sample Description: Destec High Sierra BK202019 Run #3
Unit #2 Gas Turbine 2/12/92

* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)

Components

PPM, Volume



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: 030488_006
Received: Feb 13, 1992
Reported: Feb 14, 1992

Attention: Gary McRae

Sample Description: Destec High Sierra BK202019 Run #3
Unit #2 Gas Turbine 2/12/92

* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)

Components	PPM, Volume
Methane (C1)	56.5
Ethane (C2)	1.4
Propane (C3)	<0.1
Butanes (I+N C4)	<0.1
Pentanes (I+N C5)	<0.1
Hexanes+ (C6+)	<0.1
Total Hydrocarbons	57.9
Total Non-Methane Hydrocarbons	1
Total Non-(C1+C2) Hydrocarbons	0
Total Non-Methane Hydrocarbons as C1	3

Katho Zimmerman
Analyst

Jim Etherton
Jim Etherton
Laboratory Director


4309 Armour Avenue Bakersfield, California 93308

(805) 395-0539

FAX (805) 395-3069


Zalco C1-C6 PPM Report

Sample Name : Destec High Sierra BK202019 Run #3
0141, 030488_006, Feb 13, 1992, Unit #2 Gas Turbine 2/12/92
Peak Processor : Genie Multilevel : False
Instrument : ADC_2 Application : Loop
Calculation : ExternalSTD Quantitation: AreaUnits
Result File : /DATA/LOOP/RESULT/ADC_2/ENG30488_006.RES
Run Time : 20.00 Minutes, injected on Fri Feb 14, 1992 11:42:11
Run Status : RunStatusOK
EndOffBaseline



RETENTION TIME	AREA	FACTOR	ppmvol
5.200	9222	6.12552E-03	56.4918
5.849	345	4.06129E-03	1.4026
Total Hydrocarbons			57.8944

Report Time: Tue Feb 18, 1992 9:05:56 am
Method: /DATA/LOOP/METHOD/LOWPPMA.MTH
Format File: /DATA/LOOP/FORMAT/SIDE_BY_SIDE.FMT



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: Cal_2_14_1
Received: Feb 14, 1992
Reported: Feb 14, 1992

Attention: Gary McRae

Sample Description: Scotty's Gas Can Mix #243 2/14/92

* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)

Components	PPM, Volume
Methane (C1)	16.3
Ethane (C2)	16.3
Propane (C3)	16.3
Butanes (I+N C4)	16.3
Pentanes (I+N C5)	16.4
Hexanes+ (C6+)	30.9
Total Hydrocarbons	112.5
Total Non-Methane Hydrocarbons	96
Total Non-(C1+C2) Hydrocarbons	80
Total Non-Methane Hydrocarbons as C1	374

Kathie Zimmerman
Analyst

Jim Etherton
Jim Etherton
Laboratory Director

4309 Armour Avenue Bakersfield, California 93308


(805) 395-0539

FAX (805) 395-3069


Zalco C1-C6 PPM Report

Sample Name : Scotty's Gas Can Mix #243 2/14/92
 0141, Cal_2_14_1, Feb 14, 1992
 Peak Processor : Genie Multilevel : False
 Instrument : ADC_2 Application : Loop
 Calculation : ExternalSTD Quantitation: AreaUnits
 Result File : /DATA/LOOP/RESULT/ADC_2/CAL_2_14_922.RES
 Run Time : 20.00 Minutes, injected on Fri Feb 14, 1992 8:11:46
 Run Status : RunStatusOK

RETENTION TIME	AREA	FACTOR	ppmvol
4.480	29429	1.04997E-03	30.9000
5.200	2661	6.12552E-03	16.3000
5.834	4014	4.06129E-03	16.3000
7.041	6460	2.52312E-03	16.3000
10.254	9913	1.64437E-03	16.3000
14.658	10927	1.50087E-03	16.4000
Total Hydrocarbons			112.5000



Report Time: Tue Feb 18, 1992 8:24:06 am
 Method: /DATA/LOOP/METHOD/LOWPPMA.MTH
 Format File: /DATA/LOOP/FORMAT/SIDE_BY_SIDE.FMT



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: Blank_2_14
Received: Feb 14, 1992
Reported: Feb 14, 1992

Attention: Gary McRae

Sample Description: 100% Helium Gas Blank 2/14/92

* CHROMATOGRAPHIC ANALYSIS (Z 1645) *

(FID with C6+ Backflush to Detector)

Components	PPM, Volume
Methane (C1)	<0.1
Ethane (C2)	<0.1
Propane (C3)	<0.1
Butanes (I+N C4)	<0.1
Pentanes (I+N C5)	<0.1
Hexanes+ (C6+)	<0.1
Total Hydrocarbons	0.0
Total Non-Methane Hydrocarbons	0
Total Non-(C1+C2) Hydrocarbons	0
Total Non-Methane Hydrocarbons as C1	0

Kathy Zimmerman
Analyst

Jim Etherton
Jim Etherton
Laboratory Director


4309 Armour Avenue Bakersfield, California 93308

(805) 395-0539

FAX (805) 395-3069


Zalco C1-C6 PPM Report

Sample Name : 100% Helium Gas Blank 2/14/92
0141, Blank_2_14, Feb 14, 1992
Peak Processor : Genie Multilevel : False
Instrument : ADC_2 Application : Loop
Calculation : ExternalSTD Quantitation: AreaUnits
Result File : /DATA/LOOP/RESULT/ADC_2/BLK_2_14_921.RES
Run Time : 20.00 Minutes, injected on Fri Feb 14, 1992 8:41:26
Run Status : RunStatusOK
 EndOffBaseline
 NoPeaks
 NoReference



Total Hydrocarbons 0.0000

Report Time: Fri Feb 14, 1992 1:17:13 pm
Method: /DATA/LOOP/METHOD/LOWPPMA.MTH
Format File: /DATA/LOOP/FORMAT/SIDE_BY_SIDE.FMT



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

ENGINEERING SCIENCE
2520 Pegasus Drive
Bakersfield, CA 93308

Lab. No.: 030488_007
Received: Feb 13, 1992
Reported: Feb 13, 1992

Attention: Gary McRae

Sample Description: Destec High Sierra BK202020 Fuel Gas
Bomb #17 2/12/92

* CHROMATOGRAPHIC ANALYSIS (Z 1635) *

Components	Mole %	Wt %	CHONS	Wt %
Hydrogen	0.000	0.000	CARBON	72.80
Carbon Dioxide	1.255	3.290	HYDROGEN	23.85
Oxygen	.020	.038	OXYGEN	2.43
Nitrogen	.546	.911	NITROGEN	.91
Carbon Monoxide	0.000	0.000	SULFUR	0.00
Hydrogen Sulfide	0.000	0.000		
Methane	96.259	91.989	Totals	99.99
Ethane	1.643	2.942	Total H/C	.33
Propane	.197	.518		
IsoButane	.022	.075		
N-Butane	.030	.103		
IsoPentane	.010	.044		
N-Pentane	.009	.039		
Hexanes+	.010	.052		
Totals =	100.000	100.000		

SPECIFIC GRAVITY (Air = 1) .5806
 SPECIFIC VOLUME, cu.ft./lb * 22.57
 GROSS CALORIFIC VALUE, BTU/cu.ft. * 995.97
 GROSS CALORIFIC VALUE, BTU/cu.ft. ** 1013.19
 GROSS CALORIFIC VALUE, BTU/lb ** 22867.02
 NET CALORIFIC VALUE, BTU/cu.ft. ** 912.86
 NET CALORIFIC VALUE, BTU/lb ** 20602.51
 DSCF EXHAUST PER SCF FUEL (0% Oxygen) 8.5870
 COMPRESSIBILITY FACTOR 'Z' (60 F, 1 ATM) .9980
 EPA 'F' Factor @ 68 F: 8624.060 DSCF / MM Btu.
 KCAPCD 'F' Factor @ 60 F: 8494.700 DSCF / MM Btu.

* Water Saturated

** Dry Gas @ 60 F, 14.73 psia

Kathy Zimmerman
Analyst

Jim Etherton
Laboratory Director

4309 Armour Avenue Bakersfield, California 93308

SECTION 6

TEST METHODOLOGY

SECTION 6
METHODOLOGY

Continuous Emissions Monitoring

Sample Extraction and Conditioning

Sampling was performed using a system which delivers a conditioned, continuous gas sample to the gas analyzers. The gas sample was extracted through a stainless steel probe, then passed through a heated (250°F) teflon sample line, a sample condenser (for moisture removal), an in-line filter (for particulate removal), and a stainless steel pump. The clean, dry sample was then transported via unheated teflon line to the analyzer manifold (located within the mobile van) for sample distribution to the continuous emissions monitors.

Continuous Emissions Monitors (CEMS)

Table 1 describes the CEMS used in the mobile van to analyze the exhaust gases. Calibrations of the CEMS were performed using EPA Protocol 1 or NIST certified calibration gases. Copies of the gas certification are included in the appendix of this report.

Prior to performing the emissions testing, a leak check of the sample system was performed. A check of sampling system bias was performed by injecting calibration gas (for each parameter) at the sample probe and then observing instrument response. A response within ± 5 percent of instrument range was considered acceptable. The leak check was repeated at the conclusion of the test day to verify the validity of the tests.

Before each test run, an initial calibration of the analyzers was performed by introducing zero and span gases and making appropriate adjustments. During each test run, analyzer response data was recorded for each instrument. At the conclusion of the test run, a calibration check was performed to verify acceptable zero and span drift limits.

Ammonia Emissions Test

General

Ammonia testing was performed concurrently with the CEM testing. Ammonia slip testing is required when pollutant emissions are being controlled by ammonia injection. Testing was conducted in accordance with BAAQMD ST-1b.

Sampling Train

The impinger train was kept in an icebath during the test run. Impingers 1 and 2 contained 100 milliliters of 0.1 N HCl, impinger 3 was empty, and impinger 4 contained a tared amount of silica gel. The impingers were weighed before and after sampling to allow calculation of percent moisture in the gas stream. The probe and sample box were connected to the control module using an umbilical line. The control module consists of a vacuum pump, a calibrated dry gas meter, and a calibrated orifice meter. The control module components measure pressure, temperature, and flowrate throughout the train.

Sampling Procedure

A leak check was performed before sampling began by bringing the sample train to 15-inches of mercury vacuum. Leakage had to be less than 0.02 cfm or 4% of the average sampling rate prior to beginning a test. A leak check was also done on the S-type Pitot tube. After sampling was complete, a final leak check was performed on both the train and S-type Pitot tube. This leak check was performed at 15-inches of mercury vacuum or at the highest vacuum achieved during the test. All pertinent data was recorded on field data sheets and is included in this report.

Sample Recovery

Each impinger was removed from the icebath, wiped dry, and weighed to allow calculation of percent moisture in the gas stream. A polyethylene bottle labeled as NH_3 was used to collect the contents of the impingers and the distilled water rinses of the impingers and their connectors. A chain-of-custody form was filled out with sample numbers for tracking purposes.

Sample Analysis for Ammonia

The volume of the NH_3 sample bottle was measured and an aliquot was transferred to a 250 milliliter beaker using a 100 milliliter NBS class A pipet. A Teflon stir bar was carefully placed in the beaker and NH_3 ionic strength adjuster (ISA) solution was added until a blue color persisted. The ammonia content was determined using a specific ion electrode. The electrode was rinsed with distilled water, immersed in the liquid, and allowed to reach a stable millivolt reading. The ammonia content was determined by graphing the sample millivolts onto the semi-log calibration graph. A blank of the 0.1 N HCl impinger solution was also done.

Speciated Hydrocarbons: EPA Method 18

Integrated hydrocarbon samples were collected through a 316 stainless steel and teflon line directly into a new Tedlar bag by utilizing an evacuated chamber to draw the exhaust into the bag. The Tedlar bags were purged twice with the exhaust gas before collecting each sample. At the conclusion of sampling, the tedlar bag was closed off, labeled, and delivered to the laboratory along with a chain-of-custody form. The samples were analyzed by FID packed column gas chromatography for methane/non-methane hydrocarbons in accordance with EPA Method 18.

Fuel Gas

A fuel gas sample was collected in a stainless steel gas sample cylinder, properly labeled, and delivered to the laboratory with the accompanying chain-of-custody form. The samples were analyzed by gas chromatography for CHONS (carbon, hydrogen, oxygen, nitrogen, and sulfur) and heating value in accordance with ASTM Method D-3588.

SECTION 7

RAW DATA

ENGINEERING-SCIENCE, INC.
CEM FIELD DATA SHEET

PLANT DESTEC: HIGH SIERRA COGEM VAN NO. 2
TEST LOCATION UNIT 1 and 2

DATE 2-12-92
OPERATOR T. DEARNO

O2, %

Calibration Gases:

High	20.9	Cyl. #	CC 83872
Mid	14.07	Cyl. #	CC 12438
Low	0.0	Cyl. #	CC 28366

CO2, %

Calibration Gases:

High	9.02	Cyl. #	CC 28366
Mid	9.02	Cyl. #	CC 28366
Low	0.0	Cyl. #	CC 28366

NOx, ppm

Calibration Gases:

High	9.29	Cyl. #	CC 5694
Mid	5.64	Cyl. #	CC 49684
Low	0.0	Cyl. #	CC 83872

CO, ppm

Calibration Gases:

High	90.3	Cyl. #	CC 12438
Mid	45.0	Cyl. #	CC 12295
Low	22.90	Cyl. #	CC 28073

SO2, ppm

Calibration Gases:

High	45.0	Cyl. #	
Mid	44.3	Cyl. #	
Low	21.7	Cyl. #	

Calibration Gases:

High		Cyl. #	
Mid		Cyl. #	
Low		Cyl. #	


TIME	SAMPLE POINT	O2 (%)	CO2 (%)	NOx (ppm)	CO (ppm)	SO2 (ppm)	COMMENTS / RUN #
		14.07	9.02	5.64	45.0	N/A	Span gas values used for test.
		20.9	9.02	9.29	90.3		HIGH LINEARITY CHECK
		14.07		5.53	44.3		MID
		-0.1		0.0	21.7		LOW
							DATE ✓ = 0.0 @ 20" Hg
0810	UNIT #1	13.8	4.1	3.2	30.5		RUN #1, UNIT #1
20		13.8	4.15	3.15	30.5		
30		13.8	4.17	3.2	30.0		
40		13.8	4.20	3.25	29.8		
50		13.75	4.20	3.30	29.8		
0900		13.75	4.20	3.25	30.0		
0910	CAL	-0.05	0.10	0.12	0.0		ZERO CHECK
		14.0	9.12	5.64	44.5		SPAN CHECK

ENGINEERING-SCIENCE, INC.
CEM FIELD DATA SHEET

PLANT TEST LOCATION DESTEC: HIGH SIERRA COPPER CEM VAN NO. 2
UNIT 1+2 Stack

DATE 2-12-92
OPERATOR TD

TIME	SAMPLE POINT	O2 (%)	CO2 (%)	NOX (ppm)	CO (ppm)	SO2 (ppm)	COMMENTS / RUN #
0		14.67	9.02	5.64	45.0	N/A	Span gas values used for test.
0925	UNIT 1	13.83	4.1	2.97	31.0		RUN-2, UNIT 1
35		13.83	4.1	2.97	30.7		
45		13.83	4.1	3.0	30.5		
55		13.83	4.1	3.05	30.3		
1005		13.83	4.1	2.95	30.5		
1015		13.83	4.1	2.92	30.7		
1025	CAL	0.0	0.0	-0.12	1.0		ZERO check
		14.15	9.02	5.50	45.0		SPAN check
1130	UNIT -2	13.93	4.06	3.60	35.0		RUN -1, UNIT-2
40		13.93	4.06	3.65	34.3		
50		13.93	4.06	3.75	33.0		
1200		13.90	4.06	3.80	32.5		
10		13.85	4.06	3.85	30.3		
20		13.85	4.06	3.90	30.2		
1230	CAL	0.0	0.0	0.29	0.0		ZERO check
		13.88	9.02	5.67	43.9		SPAN check
1245		13.93	4.06	2.85	39.2		RUN-2, UNIT-2
55		13.93	4.06	2.90	38.5		
1305		13.85	4.06	2.97	44.5		
15		13.90	4.06	3.2	32.5		
25		13.93	4.02	3.05	33.5		
35		13.93	4.02	3.15	33.0		
1345	CAL	0.0	0.0	-0.02	0.7		ZERO CHECK
		14.07	9.02	5.70	43.0		SPAN CHECK
		14.0	9.0	5.57	43.8		EXTERNAL RESPONSE Check



0940 DESTEC HIGH SIERRA

UNIT #
RUN -
OUTLET STAGE
2-12-92

chart speed =
20CM
HR

0830

0830

NO₂ = (0-100ppm) 1/5

0810

0830

02 = (0-25%) 1/5

CO = (0-100ppm) 1/5

0810

0810


0810

0810


CO₂ = (0-20%) 1/5

CO = 0.0

NO_x = 5.64 ppm










2.12.92









← EXT. O₂ = 14.0%

← EXT. CO₂ = 9.0%

← EXT. CO₂ H₂O = 14.0%

← EXT. MIX = 5.57 MPa

SAMPLE SYSTEM BIAS CHECK

← NO₂ = 5.10 MPa

← CO₂ H₂O = 14.0%

← CO = 0.7 MPa

← CO₂ = 0.9 MPa

← O₂ = 0.0 MPa

← CO₂ H₂O = 14.0%

N₂ = 0.9 MPa



FIELD DATA SHEET

Company DESTEC: HIGH SIERRA COGEN. Run # 1
 Test Location UNIT # 1 Date 2-12-92
 Test Method / Parameter BAAGMD SFIB/AH3 Operator GRM

ENGINEERING-SCIENCE, INC.

Stack Dimensions
 Barometric Pressure 28.74 "Hg
 Static Pressure _____ "H2O
 Pitot Coeff. 0.84
 Filter # UNTRAPED
 Control Box # BR IV
 Orifice dH@ / y 1.88 / 1.003
 Probe Type / Length GL / 6'
 Nozzle # / Size N/A

Impinger	IMPINGER CONTENTS, ml/grams			GAS COMPOSITION			
	Contents	Final	Initial	Time	O2	CO2	CO
1	0.1MML	664.9	583.6	81.3			
2	0.1MML	600.6	597.8	8.8			
3	Dry	473.5	472.7	0.8			
4							
5	Silica Gel	759.0	754.7	4.3			
TOTAL:				<u>92.54</u>			

LEAK RATE (cfm) lpm "Hg Vacuum
 Initial .004 15"
 Final .001 5"

Sample Point	Time	Gas Meter (ft ³) (liters)	dP "H2O	dH "H2O	Temperature, °F			Impinger	Rotameter (liters/min)	Comments
					Stack	Probe	Oven			
Center	0	417.750		1.5		260	255	50	2	
	5	420.9				265	253	47	2	
	10	424.0				260	255	45	2	
	15	427.2				258	254	43	2	
	20	430.4				257	253	45	2	
	25	433.6				255	255	45	2	
	30	436.755								
Totl/Avg:	30.0	19.005		1.50				57.83		

FIELD DATA SHEET

Company DESTIL - High Sierra Copper Run # 2 ENGINEERING-SCIENCE, INC.
 Test Location UNIT # 1 Date 2-12-92
 Test Method / Parameter BAARM/D STEIB / NH₃ Operator GWM

Stack Dimensions

Barometric Pressure 28.74 "Hg
 Static Pressure _____ "H₂O
 Pitot Coeff. 0.84
 Filter # UNTRACED
 Control Box # BKIV
 Orifice dH@ / y 1.88 / 1.003
 Probe Type / Length GL / 6'
 Nozzle # / Size N/A

Impinger	IMPINGER CONTENTS, ml (grams)			GAS COMPOSITION				
	Contents	Final	Initial	Net	Time	O ₂	CO ₂	CO
1	0.1 NH ₃	650.0	589.0	61.0				
2	0.1 NH ₃	630.1	600.5	29.6				
3	DM	481.7	480.3	1.4				
4								
5								
Silica Gel				796.2	785.3	4.9		
				TOTAL:	96.9			

LEAK RATE CM³/min "Hg Vacuum
 Initial 0.05 " " "
 Final 0.03 " " "

Sample Point	Time	Gas Meter (ft ³) liters)	dH "H ₂ O	dP "H ₂ O	Temperature, °F			Vacuum "Hg	Rotameter (liters/min)	Comments
					Meter	Stack	Probe			
center	0	436.850	1.5			258	251	49	3.0	
	5	439.9				256	254	47	3.0	
	10	443.1				261	253	45	3.0	
	15	446.3				249	253	43	3.0	
	20	449.4				256	252	43	3.0	
	25	452.6				255	253	42	3.0	
	30	455.703								
TOTAL/AVG	30.0	18.853	1.50	63.33						

FIELD DATA SHEET

Company DESTEC HIGH SIEGAA
 Test Location UNIT 2 - DOWNLET STAKE
 Test Method / Parameter DAQ @ MD - ST-1B

Run # 81 - UNIT 2
 Date 2-12-92
 Operator GWM

ENGINEERING-SCIENCE, INC.

Stack Dimensions
 Barometric Pressure 28.75 "Hg
 Static Pressure _____ "H2O
 Pitot Coeff. 0.84
 Filter # UNFILTERED
 Control Box # BE IV
 Orifice dH@ / y 1.88 / 1.003
 Probe Type / Length GL / 6'
 Nozzle # / Size 1

IMPINGER CONTENTS, ml / grams				GAS COMPOSITION				
Impinger	Contents	Final	Initial	Net	Time	O2	CO2	CO
1	0.1N HCl	640.6	583.2	55.6				
2	0.1N HCl	626.0	598.6	27.4				
3	Any	473.0	473.0	0.0				
4								
5	Silica Gel	795.4	790.2	5.2				
TOTAL: <u>88.2</u>								

LEAK RATE (cfm) / lpm "Hg Vacuum
 Initial .005 15"
 Final .004 8"

Sample Point	Time	Gas Meter (ft ³) / liters	dP "H2O	dH "H2O	Temperature, °F			Vacuum "Hg	Rotameter (liters/min)	Comments
					Meter	Stack	Oven			
	0	455.890		1.5	256	253		2.0		
	5	458.9			257	252		2.0		
	10	462.1			263	252		2.0		
	15	465.3			253	251		2.0		
	20	468.5			257	253		2.0		
	25	471.6			249	252		2.0		
	30	474.867								
TOTAL / AVG	30.0	19.029		1.50						

- 1 GT-1 HATTS
- 2 GAS FUEL FLOW
- 3 STEAM NOZZLE LOW FLOW ALARM
- 4 TURBINE 1 FUEL TO STEAM RATIO
- 5 STEAM CDP LOW FLOW ALARM
- 6 INLET CO CATALYTIC CONVERTER
- 7 SRC REACTOR INLET LOW TEMP SEL
- 8 TOTAL FUEL GAS FLOW TURBINE 1
- 9
- 10
- 11
- 12

HH:MM:SS	1	2	3	4	5	6	7	8	9	10	11	12
	J11964	W11RX	W11BU	W1STOF	W11RV	TE1402	T11456	GT11GTOT				
	MM	AVG	AVG	RATIO	AVG	DEG F	DEG F	HMPPH				
	AVG	AVG	AVG	AVG	AVG	AVG	AVG	AVG				
14:00:00	25.1	11150.6	23330.8	2.09	26466.0	989.6	755.3	0.00				
15:00:00	25.1	11141.7	23284.8	2.09	26451.0	989.6	755.5	0.00				
16:00:00	25.1	11144.3	23336.0	2.09	26444.1	989.8	755.7	0.00				
17:00:00	25.1	11116.9	23216.5	2.09	26410.7	989.7	755.8	0.00				
18:00:00	25.0	11092.6	23125.0	2.08	26439.4	989.4	755.5	0.00				
19:00:00	25.1	11084.0	23100.6	2.08	26439.4	989.2	755.4	0.00				
20:00:00	25.1	11099.1	23206.6	2.09	26433.9	988.2	755.0	0.00				
21:00:00	25.3	11161.8	23383.8	2.10	26397.1	987.0	755.3	0.00				
22:00:00	25.3	11172.6	23409.4	2.10	26470.7	987.1	755.5	0.00				
23:00:00	25.3	11177.2	23355.0	2.09	26463.1	986.6	755.0	0.00				
00:00:00	25.3	11213.6	23399.6	2.09	26449.2	986.4	755.3	0.00				
01:00:00	25.3	11216.2	23419.7	2.09	26418.9	986.3	755.9	0.00				
02:00:00	25.4	11231.5	23438.8	2.09	26489.5	986.0	756.9	0.00				
03:00:00	25.4	11239.0	23423.6	2.08	26463.9	985.7	757.4	0.00				
04:00:00	25.4	11227.9	23446.5	2.09	26476.1	985.5	757.0	0.00				
05:00:00	25.4	11209.8	23458.7	2.09	26412.5	985.8	755.8	0.00				
06:00:00	25.3	11199.0	23416.4	2.09	26415.2	985.5	756.0	0.00				
07:00:00	25.4	11212.6	23387.4	2.09	26457.0	985.7	756.8	0.00				
08:00:00	25.4	11218.7	23397.8	2.09	26473.1	985.9	757.3	0.00				
09:00:00	25.4	11244.2	23467.9	2.09	26442.3	985.5	755.4	0.00	Run #1			
10:00:00	25.4	11242.3	23433.9	2.08	26464.0	984.3	754.4	0.00	11,243.256/hr			
11:00:00	25.3	11205.2	22687.7	2.02	26075.4	985.3	753.2	0.00	Run #2			
12:00:00	25.1	11160.9	21760.7	1.95	25230.8	987.6	754.3	0.00	11,223.756/hr			
13:00:00	25.5	11271.4	22214.2	1.97	27846.2	986.6	755.8	0.00				

SUMMARY DATA

AVG	25.3	11184.7	23212.6	2.08	26440.8	987.1	755.6	0.00				
MAX	25.5	11271.4	23467.9	2.10	27246.2	989.8	757.4	0.00				
TMAX	13:00:00	13:00:00	9:00:00	22:00:00	13:00:00	16:00:00	3:00:00	14:00:00				
MIN	25.0	11034.0	21760.7	1.95	25230.8	984.3	753.2	0.00				
TMIN	18:00:00	19:00:00	12:00:00	12:00:00	12:00:00	10:00:00	11:00:00	14:00:00				

HH:MM:SS	1	2	3	4	5	6	7	8	9	10	11	12
	J12964	WZ1RX	WZ1RU	WZS10F	WZ1RV	1E240Z	BLKZNOCR	BLPZCOCK	672FG10T	XS1932		
	MM	AVG	AVG	RATIO	AVG	DEG F	PPMVD	PPMVD	NMPPH	CALIBR		
14:00:00	25.0	11179.8	17753.3	1.59	26961.3	983.38	2.3	27.1	150799.5	NORMAL		
15:00:00	24.9	11159.0	17679.5	1.58	26972.2	983.40	2.4	26.7	161771.7	NORMAL		
16:00:00	25.0	11180.2	17786.4	1.59	26982.2	983.17	2.2	27.2	173130.5	NORMAL		
17:00:00	25.1	11205.2	17792.0	1.59	26956.2	982.31	2.3	27.5	184387.1	NORMAL		
18:00:00	25.1	11199.5	17720.5	1.58	26985.2	981.82	2.4	27.6	195567.9	NORMAL		
19:00:00	25.1	11200.3	17722.8	1.58	26984.5	981.50	2.3	27.3	206780.3	NORMAL		
20:00:00	25.1	11191.4	17733.3	1.58	27018.0	980.63	2.5	27.1	217936.5	NORMAL		
21:00:00	25.1	11199.0	17724.5	1.58	27050.7	980.55	2.5	27.0	229191.3	NORMAL		
22:00:00	25.0	11157.4	17602.5	1.58	26995.0	981.51	2.4	26.6	240381.0	NORMAL		
23:00:00	24.7	11063.6	17240.2	1.56	27034.7	982.51	2.5	25.0	251487.7	NORMAL		
00:00:00	25.1	11201.7	17623.0	1.57	27004.6	981.53	2.4	26.9	262634.9	NORMAL		
01:00:00	24.9	11142.5	16756.6	1.50	26301.2	982.81	2.8	24.4	26639.42	NORMAL		
02:00:00	24.8	11103.6	16334.7	1.47	25961.5	983.65	3.1	21.4	16729.51	NORMAL		
03:00:00	24.9	11156.4	16493.3	1.48	25922.3	982.82	3.1	21.3	27874.29	NORMAL		
04:00:00	24.9	11136.6	16511.4	1.48	25901.3	982.46	3.2	21.2	39025.67	NORMAL		
05:00:00	24.8	11098.9	16369.9	1.47	25965.5	982.66	3.1	20.9	50161.18	NORMAL		
06:00:00	24.8	11126.5	16404.8	1.47	25920.2	982.53	3.1	21.0	61272.12	NORMAL		
07:00:00	24.9	11132.8	16461.4	1.48	25891.9	982.21	3.0	21.2	72415.98	NORMAL		
08:00:00	25.1	11195.3	16781.2	1.48	25933.3	976.79	3.0	22.1	83574.01	CALIBR		
09:00:00	22.3	10404.6	15428.9	1.46	14270.7	967.84	2.8	29.9	94566.93	NORMAL		
10:00:00	24.8	11094.3	17384.0	1.57	25228.4	936.96	2.3	28.0	105103.7	NORMAL		
11:00:00	25.1	11194.5	17259.0	1.54	26475.2	965.62	2.6	26.5	116318.1	NORMAL		
12:00:00	24.8	11107.8	17022.6	1.53	25848.8	977.13	2.3	25.2	127490.2	NORMAL		
13:00:00	24.3	10929.6	17157.8	1.57	26565.8	978.41	2.7	26.0	138497.5	NORMAL		

SUMMARY DATA

AVG	24.8	11115.2	17114.3	1.54	25963.8	978.51	2.7	25.2	133915.7			
MAX	25.1	11205.2	17792.0	1.59	27050.7	983.65	3.2	29.9	262634.9			
TMAX	21:00:00	17:00:00	16:00:00	16:00:00	21:00:00	2:00:00	4:00:00	9:00:00	0:00:00			
MIN	22.3	10404.6	15428.9	1.46	14270.7	936.96	2.2	20.9	6639.42			
TMIN	9:00:00	9:00:00	9:00:00	9:00:00	9:00:00	10:00:00	16:00:00	6:00:00	1:00:00			

Run#1 11,018.45 lb/sec

Run#2 10,929.6 lb/hr

EMISSIONS MONITORING LOG1
HIGH SIERRA - L067 (12HR)

12FE892 13:47:38

1 NOX LEVEL AT STACK 01-101
 2 CO LEVEL AT STACK 01-101
 3 CDR NOX LEVEL AT STACK 01-101
 4 CDR CO LEVEL AT STACK 01-101
 5 O2 LEVEL AT STACK 01-101
 6 NOX LEVEL AT STACK 02-101
 7 CO LEVEL AT STACK 02-101
 8 CDR NOX LEVEL AT STACK 02-101
 9 CDR CO LEVEL AT STACK 02-101
 10 O2 LEVEL AT STACK 02-101
 11 CEM SYSTEM IN CALIBRATION

HH:MM:SS	1	2	3	4	5	6	7	8	9	10	11	12
	BLR1NOX PPMVD AVG	BLR1CO PPMVD AVG	BLR1NOCR PPMVD AVG	BLR1COCR PPMVD AVG	BLR1O2 PPMVD AVG	BLR2NOX PPMVD AVG	BLR2CO PPMVD AVG	BLR2NOCR PPMVD AVG	BLR2COCR PPMVD AVG	BLR2O2 PPMVD AVG	XS1932 CALIBR	
02:00:00	3.22	27.62	2.5	21.2	13.17	3.99	27.04	3.0	21.1	13.28	NORMAL	
02:15:00	3.21	27.32	2.5	21.0	13.17	3.96	26.98	3.0	21.0	13.26	NORMAL	
02:30:00	3.22	27.40	2.5	21.1	13.17	3.96	27.58	3.0	21.4	13.24	NORMAL	
02:45:00	3.22	27.28	2.5	21.0	13.17	3.96	27.61	3.1	21.6	13.31	NORMAL	
03:00:00	3.21	27.18	2.5	20.9	13.17	4.07	27.02	3.2	21.2	13.33	NORMAL	
03:15:00	3.21	27.13	2.5	20.9	13.17	4.17	26.63	3.2	20.9	13.31	NORMAL	
03:30:00	3.20	27.10	2.5	20.9	13.17	4.15	26.97	3.2	21.3	13.37	NORMAL	
03:45:00	3.21	26.89	2.5	20.7	13.17	4.10	27.33	3.2	21.5	13.36	NORMAL	
04:00:00	3.22	26.89	2.5	20.7	13.17	4.03	27.20	3.0	21.2	13.27	NORMAL	
04:15:00	3.22	26.76	2.5	20.6	13.17	4.05	27.11	3.1	21.2	13.30	NORMAL	
04:30:00	3.22	26.98	2.5	20.7	13.17	4.22	26.61	3.2	20.9	13.33	NORMAL	
04:45:00	3.21	26.73	2.5	20.6	13.17	4.12	26.43	3.2	20.6	13.27	NORMAL	
05:00:00	3.22	26.89	2.5	20.7	13.17	3.96	26.95	3.1	21.1	13.31	NORMAL	
05:15:00	3.22	27.10	2.5	20.9	13.14	3.96	27.13	3.2	21.3	13.34	NORMAL	
05:30:00	3.21	26.92	2.5	20.7	13.17	4.04	26.67	3.1	20.7	13.24	NORMAL	
05:45:00	3.22	27.09	2.5	20.8	13.17	4.09	26.68	3.1	20.6	13.20	NORMAL	
06:00:00	3.22	26.96	2.5	20.7	13.17	3.96	26.95	3.0	20.9	13.23	NORMAL	
06:15:00	3.22	26.67	2.5	20.3	13.10	4.01	27.05	3.0	21.1	13.30	NORMAL	
06:30:00	3.22	26.53	2.5	20.3	13.17	4.11	26.90	3.1	21.1	13.32	NORMAL	
06:45:00	3.22	26.86	2.5	20.6	13.17	3.96	27.12	3.0	21.1	13.27	NORMAL	
07:00:00	3.21	26.98	2.5	20.8	13.17	3.96	27.35	3.0	21.3	13.27	NORMAL	
07:15:00	3.22	26.91	2.5	20.6	13.17	3.96	27.19	3.0	21.2	13.27	NORMAL	
07:30:00	3.21	26.94	2.5	20.5	13.11	3.96	27.34	3.0	21.3	13.27	NORMAL	
07:45:00	3.22	27.17	2.5	20.8	13.16	3.91	28.45	3.0	22.2	13.28	NORMAL	
08:00:00	3.22	27.22	2.5	20.9	13.17	3.71	30.73	3.0	23.9	13.27	CALIBR	
08:15:00	3.22	27.74	2.5	21.3	13.17	3.64	31.18	2.9	24.3	13.27	NORMAL	
08:30:00	3.22	28.39	2.5	21.8	13.16	5.08	28.86	4.2	22.8	13.43	NORMAL	
08:45:00	3.22	27.90	2.5	21.4	13.17	3.02	42.11	2.5	33.7	13.45	NORMAL	
09:00:00	3.22	27.58	2.5	21.1	13.13	1.72	46.65	1.5	39.0	13.81	NORMAL	
09:15:00	3.22	28.03	2.5	21.3	13.09	2.16	38.42	1.8	31.8	13.70	NORMAL	
09:30:00	3.17	28.66	2.4	21.9	13.13	3.28	34.55	2.5	26.7	13.35	NORMAL	
09:45:00	3.22	28.37	2.5	21.8	13.17	3.23	34.20	2.5	26.2	13.28	NORMAL	
10:00:00	3.22	28.35	2.5	21.8	13.17	3.24	33.36	2.5	26.4	13.37	NORMAL	
10:15:00	3.22	28.40	2.5	21.9	13.17	3.24	34.17	2.5	26.9	13.36	NORMAL	
10:30:00	3.22	28.27	2.5	21.7	13.17	3.22	34.12	2.5	26.9	13.30	NORMAL	
10:45:00	3.52	25.94	2.6	19.8	13.13	3.28	33.45	2.6	26.2	13.36	NORMAL	
11:00:00	3.96	23.59	3.0	18.1	13.15	3.47	32.80	2.7	25.9	13.37	NORMAL	
11:15:00	3.97	23.61	3.0	18.1	13.17	3.47	32.54	2.7	25.7	13.37	NORMAL	
11:30:00	3.97	23.57	3.0	18.1	13.13	3.47	32.43	2.7	25.6	13.38	NORMAL	
11:45:00	3.97	23.44	3.0	18.0	13.18	3.47	32.07	2.7	25.3	13.38	NORMAL	
12:00:00	4.14	23.04	3.2	17.7	13.18	3.54	30.67	2.8	24.2	13.38	NORMAL	
12:15:00	4.09	22.62	3.1	17.3	13.12	3.60	27.98	3.1	22.1	13.37	NORMAL	
12:30:00	3.97	23.78	3.0	18.1	13.08	3.91	27.15	3.2	21.5	13.37	NORMAL	
12:45:00	3.97	24.36	3.0	18.5	13.08	2.91	38.82	2.2	30.6	13.37	NORMAL	
13:00:00	3.97	24.12	3.0	18.3	13.07	2.76	38.01	2.2	30.0	13.38	NORMAL	
13:15:00	3.97	23.33	3.0	17.9	13.16	2.89	37.38	2.2	29.5	13.36	NORMAL	

HH:MM:SS	1	2	3	4	5	6	7	8	9	10	11	12
	BLR1NOX	BLR1CO	BLR1NOCR	BLR1COCR	BLR1O2	BLR2NOX	BLR2CO	BLR2NOCR	BLR2COCR	BLR2D2	XS1932	
	PPMVD	PPMVD	PPMVD	PPMVD	PPMVD	PPMVD	PPMVD	PPMVD	PPMVD	PPMVD	CALIBR	
	AVG	AVG	AVG	AVG	AVG	AVG	AVG	AVG	AVG	AVG		
13:45:00	3.97	23.36	3.0	18.0	13.17	3.47	30.82	2.7	24.3	13.38	NORMAL	

SUMMARY DATA

AVG	3.42	26.36	2.6	20.2	13.16	3.67	30.51	2.9	24.0	13.34		
MAX	4.14	28.66	3.2	21.9	13.13	5.08	46.65	4.2	39.0	13.81		
TMAX	12:00:00	9:30:00	12:00:00	9:30:00	12:00:00	8:30:00	9:00:00	8:30:00	9:00:00	9:00:00		
MIN	3.17	22.62	2.4	17.3	13.07	1.72	26.43	1.5	20.6	13.20		
TMIN	9:30:00	12:15:00	9:30:00	12:15:00	13:00:00	9:00:00	4:45:00	9:00:00	5:45:00	5:45:00		

SECTION 8
QUALITY ASSURANCE

SECTION 8

QUALITY ASSURANCE

This report has been reviewed for technical and editorial quality and for compliance with project requirements.

All equipment used in testing has been checked for proper maintenance and calibrated prior to testing. Test equipment calibrations have been included in the appendix of this report. The dry gas meter accuracy was expressed as gamma and was determined as the difference between the meter box dry gas meter and the wet test meter used for calibration. The results of the orifice calibration are expressed as the delta H@ (dH@) at various pressure drops (inches of water), as specified in EPA publication APTD-0576. EPA Quality Assurance Branch annual audits are performed with an orifice check of each of the dry gas meters used for volumetric sampling.

Sample probe, filter, meter and impinger temperatures were monitored using a type-K thermocouple connected to a digital readout. The temperature readout and thermocouples were calibrated against an NIST certified thermometer. The calibrations are performed every six months using the procedures specified in the EPA Quality Assurance Handbook For Air Pollution Measurement Systems, 600/4-77-027b, Volume III, Stationary Source Methods.

At the conclusion of each test run the sampling train was leak checked at a vacuum equal to or greater than the highest vacuum observed during the test. The sampling train was considered leak free if the leak rate was less than 0.02 CFM, or 4% of sampling rate, whichever was less.

The analyzers employed for continuous monitoring of NO_x, CO, CO₂, and O₂ were California Air Resources Board (CARB) approved instruments. Sampling system bias checks of the continuous monitor sampling system was performed using either the EPA protocol 1 or NIST certified calibration gases (certificate copies included). All

other checks of the continuous monitor system required by the regulatory agency methodology were also performed.

All field samples were labeled and logged in on a chain-of-custody sheet. Chain-of-custody sheets remained with samples and documented sample movement. All laboratory data were recorded in bound laboratory notebooks. All weights were conducted on a calibrated Sartorius digital analytical balance. All analytical glassware used was NBS Class A. All reagents used in the field and in the laboratory were at least ACS reagent grade. Blanks of these reagents were evaluated for every set of tests.

SAMPLE SYSTEM BIAS CHECK

COMPANY High Sierra Cogen
 TEST LOCATION Outlet Stack

DATE 2-12-92
 OPERATOR T. Delfino

Parameter	Instrument Full Scale	Span Gas Value	Scale	Internal Response	System Response	Percent Difference
O ₂	25%		Zero	0.00		
		14.07	Upscale	14.07	14.00	0.50
CO ₂	26%		Zero	0.00		
		9.02	Upscale	9.02	9.00	0.22
NO _x	10 ppm		Zero	-0.02		
		5.64	Upscale	5.70	5.57	2.28
CO	100 ppm		Zero	0.70		
		45.0	Upscale	43.0	43.8	1.86
SO ₂			Zero			
			Upscale			
HC			Zero			
			Upscale			
			Zero			
			Upscale			

For EPA :
 Percent Difference = [(System Response - Internal Response) / Instrument Full Scale] x 100

For Kern County :
 Percent Difference = [(Internal Response - System Response) / Internal Response] x 100

DRY GAS METER AND ORIFICE CALIBRATION

Meter Box # Brown IV Barometric Press. 29.60 IN. HG.

Date 31-Dec-91 Performed by G. McRae

Calibration Meter Y 1.00014

	RUN 1	RUN 2	RUN 3	RUN 4	RUN 5	RUN 6
VACUUM (°Hg)	0	0	0	0	0	0
dHw (°H2O)	0.00	0.00	0.00	0.00	0.00	0.00
dHd (°H2O)	0.50	1.00	1.50	2.00	3.00	4.00
INITIAL WTM	443.226	409.808	451.371	465.292	480.789	499.808
FINAL WTM	451.022	421.671	464.948	480.325	499.425	521.040
INITIAL DGM	112.025	78.138	120.312	134.419	150.112	169.334
FINAL DGM	119.957	90.152	134.081	149.645	168.949	190.771
TEMP. WTM (°F)	64.5	49.5	54.5	56.5	57.5	58.5
TEMP. DGM (°F)	65.0	61.8	67.3	70.3	64.8	77.3
TEST TIME (MIN.)	20.0	22.0	21.0	20.0	20.0	20.0
CALCULATIONS :						
NET VOLUME WTM (Vw)	7.797	11.865	13.579	15.035	18.639	21.235
NET VOLUME DGM (Vd)	7.932	12.014	13.769	15.226	18.837	21.437
Y	0.983	1.009	1.007	1.009	0.996	1.016
ACCEPTABLE Y RANGE = 0.983 TO 1.023						
dH@	1.85	1.83	1.93	1.91	1.89	1.90
ACCEPTABLE dH@ RANGE = 1.73 TO 2.03						

AVERAGE Y = 1.003

AVERAGE dH@ = 1.88

CALCULATIONS :

$$Y = (Vw (Pb - (dHw / 13.6)) \times (Td + 460)) / (Vd (Pb + (dHd / 13.6)) \times (Tw + 460))$$

$$dH@ = 0.0317 \times dHd / (Pb (Td + 460)) \times ((Tw + 460) \times \text{time}) / Vw \wedge 2$$

Thermometer / Pyrometer Calibration

Date : Jan 3, 1992

I.D. : Brown IV Pyrometer

Calibrated by : *C. W. McRae*

Reference Point #	Reference * Temperature °F	Pyrometer Temperature °F	Temperature difference ** %
1	33	33	0.00
2	89	90	-1.12
3	197	198	-0.51
4	298	299	-0.34
5	401	401	0.00
6	500	499	0.20
7	602	603	-0.17
8	699	699	0.00
9	804	804	0.00
10	900	899	0.11
11	1001	1000	0.10
12	1198	1197	0.08
13	1400	1398	0.14
14	1600	1596	0.25
15	1800	1795	0.28
16	1998	1997	0.05

* Digital Calibrator Thermometer, S/N 28494/991
-60 °F to 1999 °F

** Allowable % difference = 5 %



SCOTT-MARRIN, INC.

2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
TELEPHONE (714) 784-1240

(714) 653-6780

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

ENSI01

TO:

T.J. WIEMAN
ENGINEERING SCIENCES, INC.
P.O. BOX 2007
IRWINDALE, CA 91706

DATE : 10/08/91

CUSTOMER ORDER NUMBER: VERBAL C.HOLT

PAGE 1

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.: CC28366					
Oxygen	14.07 ± 0.14 %	GIS Cylinder # CC12213 @ 23.89 %	Varian Model 1866 S/N None Thermal Conductivity Gas Chromatography Last Cal Date: 10/04/91	03/17/93	09/17/91 14.18 % 14.05 % 14.66 % Mean: 14.07 %
Carbon Dioxide	9.02 ± 0.09 %	GIS Cylinder # CC60263 @ 17.60 %	Varian Model 1866 S/N None Thermal Conductivity Gas Chromatography Last Cal Date: 08/21/91	03/13/93	09/13/91 8.99 % 9.04 % 9.03 % Mean: 9.02 %
Nitrogen	Balance				
Cylinder Pressure: 2000 psig					
CYLINDER NO.: CC81191					
Oxygen	14.06 ± 0.14 %	GIS Cylinder # CC12213 @ 23.89 %	Varian Model 1866 S/N None Thermal Conductivity Gas Chromatography Last Cal Date: 10/04/91	03/17/93	09/17/91 14.05 % 14.07 % 14.04 % Mean: 14.06 %
Carbon Dioxide	8.97 ± 0.09 %	GIS Cylinder # CC60263 @ 17.60 %	Varian Model 1866 S/N None Thermal Conductivity Gas Chromatography Last Cal Date: 08/21/91	03/13/93	09/13/91 8.97 % 8.96 % 8.97 % Mean: 8.97 %
Nitrogen	Balance				
Cylinder Pressure: 2000 psig					

ppm = umole/mole

% = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol 1, Section 3.0.4, Procedure G1.

Analyst:

M.S. Calhoun

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

REPORT OF ANALYSIS

PAGE 2

CUSTOMER ORDER NUMBER: FI-1144-26

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYSER MAKE, MODEL, S/N, DESCRIPTION	EXPIRATION DATE	DUPLICATE ANALYSIS DATA	
CYLINDER NO.: CC12823						
Carbon Monoxide	8.83 ± 0.18 ppm	GCX Cylinder # CC123	Carla Insts Model 8800 S/N 8249 Methodion/713 Gas Chromatography	18/02/91	01/25/91 8.80 ppm	04/02/91 8.85 ppm
Nitrogen	Balance	0 9.85 ppm	Last Cal Date: 04/16/91		Mean: 8.80 ppm	8.82 ppm
Cylinder Pressure: 2000 psig						
CYLINDER NO.: CC56894						
Nitric Oxide	9.29 ± 0.19 ppm	GCX Cylinder # CC7365	Monitor Labs Model 8448 S/N 136 Continuum Chemiluminescence	18/02/91	01/24/91 9.27 ppm	04/02/91 9.27 ppm
Nitrogen, O ₂ -Free	Balance	0 10.83 ppm	Last Cal Date: 01/31/91		Mean: 9.26 ppm	9.28 ppm
Cylinder Pressure: 2000 psig						
CYLINDER NO.: CC28278						
Nitric Oxide	13.17 ± 0.26 ppm	GCX Cylinder # CC8863	Monitor Labs Model 8448 S/N 136 Continuum Chemiluminescence	18/02/91	01/20/91 13.21 ppm	04/02/91 13.14 ppm
		0 10.21 ppm	Last Cal Date: 01/31/91		Mean: 13.20 ppm	13.13 ppm
Carbon Monoxide	13.85 ± 0.26 ppm	GCX Cylinder # CC12108	Carla Insts Model 8800 S/N 8249 Methodion/713 Gas Chromatography	18/02/91	01/27/91 13.16 ppm	04/02/91 13.84 ppm
Nitrogen, O ₂ -Free	Balance	0 17.79 ppm	Last Cal Date: 04/16/91		Mean: 13.84 ppm	13.85 ppm
Cylinder Pressure: 2000 psig						

ppm = umols/mols

0 = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.6.4, Procedure G1.



SCOTT-MARRIN, INC.

2001 THIRD ST. • UNIT H • RIVERSIDE, CA 92507
TELEPHONE (714) 784-1240

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

EN6181

TO: HUBERT DERIADA
ENGINEERING SCIENCES, INC.
6666 N. IRVINDALE AVE.
SUITE J
IRVINDALE, CA 96667

DATE: 04/05/91

CUSTOMER ORDER NUMBER: VI-1144-26

PAGE 1

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYSER MFR., MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA	
CYLINDER NO.: CC7219						
Nitric Oxide	23.26 ± 0.23 ppm	GDS Cylinder # CC8845 0 89.0 ppm	Monitor Lab Model 8448 S/N 136 Continuous Chemiluminescence Last Cal Date: 01/21/91	10/09/91	01/24/91	04/02/91
					23.28 ppm	23.18 ppm
					23.24 ppm	23.22 ppm
					23.24 ppm	23.18 ppm
					Mean: 23.21 ppm	23.20 ppm
Carbon Monoxide	23.26 ± 0.23 ppm	GDS Cylinder # CC8843 0 41.9 ppm	Carle Insts Model 8890 S/N 8249 Methanation/FID Gas Chromatography Last Cal Date: 04/16/91	10/05/91	01/28/91	04/02/91
					23.06 ppm	23.16 ppm
					22.97 ppm	23.23 ppm
					23.21 ppm	23.22 ppm
					Mean: 23.18 ppm	23.27 ppm
CYLINDER NO.: CC49684						
Nitric Oxide	5.63 ± 0.11 ppm	GDS Cylinder # CC7385 0 18.03 ppm	Monitor Lab Model 8448 S/N 136 Continuous Chemiluminescence Last Cal Date: 01/21/91	10/09/91	01/25/91	04/02/91
					5.64 ppm	5.66 ppm
					5.63 ppm	5.64 ppm
					5.61 ppm	5.64 ppm
					Mean: 5.63 ppm	5.63 ppm
Carbon Monoxide	6.24 ± 0.12 ppm	GDS Cylinder # CC163 0 9.18 ppm	Carle Insts Model 8890 S/N 8249 Methanation/FID Gas Chromatography Last Cal Date: 04/16/91	10/03/91	01/27/91	04/02/91
					6.25 ppm	6.21 ppm
					6.18 ppm	6.25 ppm
					6.22 ppm	6.27 ppm
					Mean: 6.22 ppm	6.25 ppm

ppm = umole/mole

t = mole-%

The above analyses were performed in accordance with EPA-1987 Traceability Protocol § 1, Section 3.8.4, Procedure G1.

Analyst:

Mark Monson

M.J. Monson

Approved:

J.T. Marrin

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

REPORT OF ANALYSIS

CUSTOMER ORDER NUMBER: FI-1216-24

PAGE 2

COMPONENT	CONCENTRATION (v/v)	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.:					
			Monitor Labs Model 8448		<u>88/28/91</u> <u>89/04/91</u>
		GMIS	S/N 136	03/04/92	90.8 ppm 90.9 ppm
		Cylinder #	Continuous		90.8 ppm 91.1 ppm
		CCS8868	Chemiluminescence		<u>90.6 ppm</u> <u>90.8 ppm</u>
		0 102.4 ppm	Last Cal Date: 08/07/91	Mean: 90.8 ppm	91.0 ppm
Carbon Monoxide	90.3 ± 0.9 ppm	GMIS	Carle Insts Model 8668		<u>89/04/91</u> <u>89/11/91</u>
		Cylinder #	S/N 8249	01/11/92	90.5 ppm 90.6 ppm
Nitrogen, O ₂ -Free Balance		CCS1223	Methanation/FID		90.8 ppm 90.1 ppm
Cylinder Pressure: 2000 psig		0 100.7 ppm	Gas Chromatography		<u>90.2 ppm</u> <u>91.0 ppm</u>
			Last Cal Date: 09/10/91	Mean: 90.2 ppm	90.3 ppm

ppm = umole/mole

‡ = mole-‡

The above analyses were performed in accordance with EPA-1987 Traceability Protocol # 1, Section 3.0.4, Procedure G1.

SCOTT - MARRIN, INC.

2001 THIRD ST., UNIT H

RIVERSIDE, CALIFORNIA 92507

REPORT OF ANALYSIS

CUSTOMER ORDER NUMBER: Nik Nielsen/Reanalysis

CYLINDER NUMBER GC12295

COMPONENT CONCENTRATION (v/v)

Carbon Monoxide 45.0 ± 0.5 ppm

Nitrogen* Balance

*Oxygen-Free

Cylinder Pressure: 1500 psig

Replicate	5/14/91	45.2 ppm
Analysis		45.3 ppm
Data On		<u>45.7 ppm</u>
CO:	Mean	45.4 ppm

Expiration Date CO: 11/14/91

Replicate	5/21/91	89.7 ppm
Analysis		89.4 ppm
Data On		<u>89.4 ppm</u>
NO:	Mean	89.5 ppm

Expiration Date NO: 5/1/91

SCOTT - MARRIN, INC.

2001 THIRD ST., UNIT H

RIVERSIDE, CALIFORNIA 92507

REPORT OF ANALYSIS

CUSTOMER ORDER NUMBER: Nik Nielsen/Reanalysis

CYLINDER NUMBER ~~CC1229X~~

CYLINDER NUMBER _____

COMPONENT CONCENTRATION (v/v)

COMPONENT CONCENTRATION (v/v)

(The Carbon Monoxide analysis was performed in accordance with Section 3.0.4 of the)
(revised EPA traceability protocol No. 1 dated June 9, 1987. The analysis is)
(traceable to the National Institute of Standards and Technology by direct)
(intercomparison with GMIS, cylinder number CC66863 at 42.1 ppm Carbon Monoxide in)
(Ultrapure Air. The analysis was performed using a Carle Model 8000 gas chromato-)
(graph with catalytic methanation/flame ionization detection. The last multipoint)
(calibration was performed 4/16/91.)

CYLINDER NUMBER ~~CC1229X~~

CYLINDER NUMBER _____

COMPONENT CONCENTRATION (v/v)

COMPONENT CONCENTRATION (v/v)

(The Nitric Oxide analysis was performed in accordance with Section 3.0.4 of the)
(revised EPA traceability protocol No. 1 dated June 9, 1987. The analysis is)
(traceable to the National Institute of Standards and Technology by direct)
(intercomparison with GMIS, cylinder number CC12643 at 99.4 ppm Nitric Oxide in)
(Oxygen-Free Nitrogen. The analysis was performed using a Monitor Labs Model 8440,)
(S/N 136 analyzer with continuous chemiluminescence detection. The last multipoint)
(calibration was performed 5/1/91.)

CYLINDER NUMBER _____

CYLINDER NUMBER _____

COMPONENT CONCENTRATION (v/v)

COMPONENT CONCENTRATION (v/v)

CYLINDER NUMBER _____

CYLINDER NUMBER _____

COMPONENT CONCENTRATION (v/v)

COMPONENT CONCENTRATION (v/v)

SCOTT - MARRIN, INC.

2001 THIRD ST., UNIT H

RIVERSIDE, CALIFORNIA 92507


REPORT OF ANALYSIS

CUSTOMER ORDER NUMBER: Nik Nielson/Reanalysis



CHRONOLOGICAL RECORD OF CERTIFIED CONCENTRATIONS

CYLINDER NUMBER: 

DATE	<u>Carbon Monoxide</u>	<u>Nitric Oxide</u>	<u> </u>
3/6/90	44.9 ppm	89.1 ppm	
3/15/90		89.4 ppm	
3/19/90	44.6 ppm		
10/29/90		89.3 ppm	
11/01/90	44.9 ppm		
5/14/91	45.4 ppm		
5/21/91		89.5 ppm	
AVERAGE	<u> </u>	<u> </u>	<u> </u>
		89.3 ppm	

CHAIN OF CUSTODY RECORD

Project No.	Project Name	Project Manager	Samples Sent To:	Analysis Required
BK9202022	Destec G. McRae	G. McRae	ES in Irwindale	M #2
Samples Collected By		BY: L. McRae		
Regulatory Agency (EPA, CARB, SCAQMD, etc.)		Comments		
KCAPCD		use Destec Kern Front Blank		
ES Lab Control No.	Test Date	Field Sample ID (Method-Run#-Sample Source)	Sample Amount	Sample Medium
BK9202022	2/12/92	BAAQMD ST-1B - Run #1 - High Sierra Gas Turbine Unit #1	Marked	.1NHCl
BK9202023		BAAQMD ST-1B - Run #2 - Gas Turbine Unit #1		
BK9202024		BAAQMD ST-1B - Run #1 - Gas Turbine Unit #2		
BK9202025		BAAQMD ST-1B - Run #2 - Gas Turbine Unit #2		
		Double C		
BK9202026	2/13/92	BAAQMD ST-1B - Run #1 - Gas Turbine Unit #1	Marked	.1NHCl
BK9202027		BAAQMD ST-1B - Run #2 - Gas Turbine Unit #1		
BK9202028		BAAQMD ST-1B - Run #1 - Gas Turbine Unit #2		
BK9202029		BAAQMD ST-1B - Run #2 - Gas Turbine Unit #2		
Relinquished By: (Sign & Print)		Received By: (Sign & Print)		
L. McRae		Linda McRae		
Phone: (805) 393-0272		Of: ES		
Relinquished By: (Sign & Print)		Received By: (Sign & Print)		
Linda McRae		Comments:		
Phone: (805) 393-0272		Of:		
Relinquished By: (Sign & Print)		Received By: (Sign & Print)		
Linda McRae		Comments:		
Phone: (805) 393-0272		Of:		
Relinquished By: (Sign & Print)		Received By: (Sign & Print)		
Linda McRae		Comments:		
Phone:		Of:		

CHAIN OF CUSTODY RECORD

Project No.		Project Name		Project Manager		Samples Sent To:		Analysis Required	
BK019		Destec Kern Front		G. McRae		ES in Irwindale		M H2	
Samples collected By G. McRae		Regulatory Agency (EPA, CARB, SCAQMD, etc.) KCAPCD		Sample Amount		Sample Medium		Comments	
ES Lab Control No.	Test Date	Field Sample ID (Method-Run#-Sample Source)		Sample Amount	Sample Medium	Comments			
BK9202009	2/11/92	BAAQMD Run - #1 Gas Turbine ST-1B		Marked	.1N HCl			X	
BK9202010	2/11/92	BAAQMD Run - #2 Gas Turbine ST-1B						X	
BK9202011	2/11/92	BAAQMD Run - #1 Gas Turbine ST-1B						X	
BK9202012	2/11/92	BAAQMD Run - #2 Gas Turbine ST-1B						X	
BK9202013	2/11/92	BAAQMD - Blank - units ST-1B						X	
Relinquished By: (Sign & Print)		Date/Time		Received By: (Sign & Print)		Comments:			
Phone: (805) 393-0272		2/11/92		Linda McRae Linda McRae					
Relinquished By: (Sign & Print)		Date/Time		Received By: (Sign & Print)		Comments:			
Phone: (805) 393-0272									
Relinquished By: (Sign & Print)		Date/Time		Received By: (Sign & Print)		Comments:			
Phone: (805) 393-0272									

ENGINEERING SCIENCE, INC.
 2520 Regasus Drive
 Bakersfield, CA 93308
 (805) 393-0272

30488

CHAIN OF CUSTODY RECORD

Project No.	Project Name	Project Manager	Samples Sent To:	Analysis Required			
BK018	Destec - High Sierra	G. McRae	Zalco Laboratories	CHOLS	Btu	GCV	
Samples Collected By G. McRae		Regulatory Agency (EPA, CARB, SCAQMD, etc.) KCAPCD		#C			
ES Lab Control No.	Test Date	Field Sample ID (Method-Run#-Sample Source)	Sample Amount	Sample Medium	Comments		
BK9202014	2/12/92	EPA Run# - Unit #1 M18 - Run #1 - Gas Turbine		Air	Tedlar Bag	X	
BK9202015		EPA Run# - Unit #1 M18 - Run #2 - Gas Turbine				X	
BK9202016		EPA Run# - Unit #1 M18 - Run #3 - Gas Turbine				X	
BK9202017		EPA Run# - Unit #2 M18 - Run #1 - Gas Turbine				X	
BK9202018		EPA Run# - Unit #2 M18 - Run #2 - Gas Turbine				X	
BK9202019		EPA Run# - Unit #2 M18 - Run #3 - Gas Turbine				X	
BK9202020	2/12/92	Fuel Gas - High Sierra		Fuel	Bomb # 17	X	
BK9202021		Fuel Gas - High Sierra			Bomb # 23	X	
						Back-up only	
Relinquished By: (Sign & Print)		Date/Time	Received By: (Sign & Print)				Comments:
Phone: (805) 393-0272		2/12/92	L. McRae				
Relinquished By: (Sign & Print)		Date/Time	Received By: (Sign & Print)				Comments:
Phone: (805) 393-0272		2/13/92	SHEILA RAWLINS				
Relinquished By: (Sign & Print)		Date/Time	Received By: (Sign & Print)				Comments:
Phone: (805) 393-0272			ZALCO 2-13-92 8:25				
Relinquished By: (Sign & Print)		Date/Time	Received By: (Sign & Print)				Comments:
Phone:							