

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

272

Ref. 17a.  
"B"

CO  
NO<sub>x</sub> Info.  
CO  
NO<sub>x</sub> outlet.  
ROG  
MM<sub>3</sub>.

## EMISSION TESTING AT THE BONNEVILLE PACIFIC COGENERATION PLANT

February 26 and 27, 1992

3-1

Prepared for:

Bonneville Pacific Corporation  
732 Hanson Way  
Santa Maria, California 93454

March 1992

Prepared by:

Steiner Environmental, Inc.  
4930 Boylan Street  
Bakersfield, California 93308

Report PS-92-2702/Project 7141-92

## SECTION 1

### INTRODUCTION

At the request of Bonneville Pacific Corporation, Steiner Environmental, Inc. undertook a series of emission measurements at the inlet and outlet of the SCR catalyst at the cogeneration plant located in Santa Maria, California on February 26 and 27, 1992. The purpose of these tests was to determine compliance with Santa Barbara County APCD Rules and Regulations.

The plant is governed by conditions in Authority to Construct Permit Application No. 6116 and the Final Decision Document dated March 3, 1987.

#### 1.1 GENERAL DESCRIPTION

The Santa Maria Cogeneration Plant consists of a nominal 9 MW combustion gas turbine generator (CGTG) operated as a base load facility with 43,500 lb/hr design capacity heat recovery steam generator (HRSG) which is unfired. Steam is produced in the HRSG at 175 psig, saturated and supplies the motive fluid for a 890 ton capacity, ~33°F Aqua Ammonia Absorption Refrigeration System (AAAR). Refrigeration is supplied to a frozen vegetable processing plant owned by Bonneville Pacific Corporation and operated under a service contract by ALPAC Foods, Inc., located in Santa Maria, California. In addition, steam is supplied directly from the plant for use in the vegetable blanching process at the food

operations at the rate of 10,000 lb/hr. The net electrical output of the plant is supplied to Pacific Gas & Electric Company (PG&E). The plant meets the air quality requirements for the County of Santa Barbara Air Pollution Control District (SBAPCD) utilizing best available control technology (BACT). BACT, in California, for a CGTG is water injection and a selective catalytic reduction system (SCR) on the discharge of the CGTG for 80% reduction of nitrogen oxides.

Water injection into the turbine (0.8 lb H<sub>2</sub>O:1.0 lb Fuel) reduces NO<sub>x</sub> emissions from the turbine by 50%. The SCR is supplied by W. R. Grace (using CAMET technology) and is a low temperature (420°F  $\pm 20^{\circ}\text{F}$ ) platinum based catalyst which provides an overall 80% reduction in NO<sub>x</sub> and a significant reduction in CO and hydrocarbon as well.

Hot exhaust gases from the turbine (950°F) enter a transition duct which contains the NH<sub>3</sub> injection grid (6 horizontal tubes with reserve side holes). The exhaust gases are mixed with NH<sub>3</sub>, diluted with ambient air (2% mix) at a 1.1 lb/mole NH<sub>3</sub>:1.0 lb/mole NO<sub>x</sub> ratio, and pass over boiler tubes to remove some of the heat from the exhaust gases. The gases enter the SCR transition duct which contains flow straighteners to properly distribute the gases across the next section of boiler tubes. These tubes reduce the temperature of the exhaust gases to 420°F and provide additional mixing to insure uniform distribution of exhaust gases across the catalyst. The catalyst consists of 24.5-inch x 22-inch blocks (total 40) in a steel frame. The exhaust gases then leave the HRSG and enter the stack.

A CEMS has been installed to provide control for the NH<sub>3</sub> injection system and to monitor emissions from the stack. The CEMS is supplied

by PACE Associates and is an extractive system which monitors NO<sub>x</sub> at the turbine exhaust and NO<sub>x</sub> and O<sub>2</sub> at the stack exhaust. All concentrations are measured on a dry basis utilizing a TECO Model 10S NO<sub>x</sub> analyzer and a Thermax Model LS O<sub>2</sub> analyzer. A Dietrich-Standard annubar is installed in the stack to convert the concentration data to lb/hr.

### 1.2 COMPLIANCE TESTING

Compliance tests were conducted upstream of the SCR for NO<sub>x</sub> and downstream of the SCR for NO<sub>x</sub>, CO, ROG, NH<sub>3</sub> and flowrate at different loads, with water injection. Testing upstream and downstream of the SCR was performed simultaneously using the average of three tests to determine compliance.

### 1.3 CEMS CERTIFICATION

Nine relative accuracy tests were extracted from the compliance testing data and used to certify the inlet and stack NO<sub>x</sub> and the stack O<sub>2</sub> analyzers using EPA Performance Specifications 2 and 3.

Section 2 of this report describes the test matrix for this program.

## SECTION 3

### TEST RESULTS

Tables 3-1 to 3-6 summarize the results of the emission tests performed at the inlet and outlet of the SCR. Tables 3-7 to 3-11 summarize the results of the relative accuracy tests performed on the NO<sub>x</sub> and O<sub>2</sub> continuous emission monitors located at the inlet and outlet of the SCR and the annubar installed in the stack.

#### 3.1 COMPLIANCE TESTING

Emissions from the cogen are limited to 5.90 lb/hr NO<sub>x</sub> and 48 ppm NO<sub>x</sub> at 3% O<sub>2</sub>, 5.70 lb/hr CO and 0.40 lb/hr ROG. NO<sub>x</sub> and CO were within the permit limits. The average ROG met the lb/hr limit for the 100% load tests.

#### 3.2 RELATIVE ACCURACY TESTING

The stack NO<sub>x</sub> analyzer failed the  $\pm 20\%$  limit for relative accuracy. However, using the 5.9 lb/hr limit for NO<sub>x</sub> and back calculating a corresponding ppm limit (11.81 ppm), the stack NO<sub>x</sub> analyzer passed the  $\pm 10\%$  limit of the standard allowed by EPA Performance Specification 2. The stack O<sub>2</sub> monitor passed the relative accuracy limit of  $\pm 20\%$  and the stack annubar passed the  $\pm 20\%$  relative accuracy limit.

#### 3.3 NO<sub>x</sub> REDUCTION EFFICIENCY

With the turbine operating at 100% load and the water injection on (0.85:1.0), the SCR inlet NO<sub>x</sub> measured 137.57 ppm, 139.49 ppm and

132.45 ppm at 3% O<sub>2</sub>. At the same time, NO<sub>x</sub> measured at the SCR outlet was 14.39 ppm, 11.82 ppm and 11.64 pm at 3% O<sub>2</sub> with an ammonia injection rate of 1.4:1.0. Reduction efficiencies of 89.54%, 91.53% and 91.21% were achieved across the SCR.

TABLE 3-1. SUMMARY OF SOURCE EMISSION TESTS

Unit Tested: Bonneville Pacific Corp.  
HRSG Inlet

Date: February 26, 1992

Test Number	1	2	3	Average
Test Condition	100% Gas	100% Gas	100% Gas	
F-Factor	8510.55	8510.55	8510.55	8510.55

W.I. #15.

## GAS DATA

### Gas Analysis (Dry % Basis)

Carbon Dioxide	3.26	3.32	3.31	3.30
Oxygen	15.46	15.45	15.39	15.43

**EMISSION CONCENTRATION - ppm**

CO	5.39	5.40	5.90	5.56
NO <sub>x</sub>	41.81	42.47	40.77	41.68

**EMISSION FACTOR - 1b/MMBtu**

CO	0.0130	0.0130	0.0141	0.0134
NO <sub>x</sub>	0.1659	0.1682	0.1595	0.1646

**EMISSION FACTOR - ppm @ 3% O<sub>2</sub>**

CO	17.74	17.74	19.17	18.19
NO <sub>x</sub>	137.57	139.49	132.45	136.39

Q510 = 68,642 DSC FA<sup>m</sup>  
area:  
5,34  
3 rows

TABLE 3-2. SUMMARY OF SOURCE EMISSION TESTS

Unit Tested: Bonneville Pacific Corp.  
HRSG Inlet

Date: February 26, 1992

Test Number	4	5	6	Average
Test Condition	75% Gas	75% Gas	75% Gas	
F-Factor	8510.55	8510.55	8510.55	8510.55

## GAS DATA

### Gas Analysis (Dry % Basis)

	Carbon Dioxide	3.01	3.00	3.00	3.00
	Oxygen	15.96	16.04	16.05	16.01

**EMISSION CONCENTRATION - ppm**

CO	14.05	13.96	16.23	14.75
NO <sub>x</sub>	27.98	27.58	26.58	27.38

**EMISSION FACTOR - 1b/MMBtu**

CO	0.0374	0.0377	0.0439	0.0397
NO <sub>x</sub>	0.1222	0.1224	0.1182	0.1209

**EMISSION FACTOR - ppm @ 3% O<sub>2</sub>**

CO	50.91	51.42	59.90	53.99
NO <sub>x</sub>	101.39	101.58	98.10	100.23

TABLE 3-3. SUMMARY OF SOURCE EMISSION TESTS

Unit Tested: Bonneville Pacific Corp.  
HRSG Inlet

Date: February 26, 1992

Test Number	7	8	9	Average
Test Condition	50% Gas	50% Gas	50% Gas	
F-Factor	8510.55	8510.55	8510.55	8510.55

## GAS DATA

### Gas Analysis (Dry % Basis)

Gas Analysis (dry % basis)  
 Carbon Dioxide 2.78 2.74 2.77 2.76  
 Oxygen 16.43 16.21 16.35 16.33

**EMISSION CONCENTRATION - ppm**

CO	32.38	28.20	36.28	32.39
NO <sub>x</sub>	21.26	21.69	20.67	21.21

**EMISSION FACTOR - 1b/MMBtu**

CO	0.0952	0.0789	0.1049	0.0930
NO <sub>x</sub>	0.1027	0.0997	0.0981	0.1002

**EMISSION FACTOR - ppm @ 3% O<sub>2</sub>**

CO	129.66	107.63	142.73	126.87
NO <sub>x</sub>	85.14	82.78	81.32	83.08

TABLE 3-4. SUMMARY OF SOURCE EMISSION TESTS

Unit Tested: Bonneville Pacific Corp.  
HRSG Stack

Date: February 26, 1992

Test Number	1	2	3	Average
Test Condition	100% Gas	100% Gas	100% Gas	
Barometric Pressure (in. Hg)	30.20	30.18	30.21	30.20
Stack Pressure (in. Hg)	30.16	30.11	30.16	30.14
Stack Area (ft <sup>2</sup> )	23.758	23.758	23.758	23.758
Elapsed Sampling Time (min.)	62.50	62.50	62.50	62.50
Volume Gas Sampled (dscf)	51.765	51.008	52.047	51.607
F-Factor	8510.55	8510.55	8510.55	8510.55

## GAS DATA

Average Gas Velocity (fps)	83.50	84.71	86.00	84.74
Average Gas Temperature (°F)	384.29	387.50	391.38	387.72
Gas Flowrate (dscfm)	68,088	68,550	69,288	68,642
Gas Analysis (Dry % Basis)				
Carbon Dioxide	3.10	3.12	3.09	3.10
Oxygen	15.54	15.48	15.47	15.50
Water	7.90	8.00	8.20	8.03

## EMISSION CONCENTRATION - ppm

CO	0.00	0.16	0.01	0.06
>C <sub>1</sub> HC	1.28	3.16	2.49	2.31
NH <sub>3</sub>	4.61	4.95	4.13	4.56
NO <sub>x</sub>	4.31	3.58	3.53	3.81

## EMISSION RATE - 1b/hr

CO	0.00	0.05	0.003	0.02
>C <sub>1</sub> HC	0.22	0.55	0.44	0.40
NH <sub>3</sub>	0.85	0.92	0.77	0.85
NO <sub>x</sub>	2.14	1.79	1.78	1.90

## EMISSION FACTOR - 1b/MMBtu

CO	0.0000	0.0004	0.00002	0.0001
>C <sub>1</sub> HC	0.0018	0.0044	0.0034	0.0032
NH <sub>3</sub>	0.0069	0.0073	0.0061	0.0068
NO <sub>x</sub>	0.0173	0.0143	0.0140	0.0152

EMISSION FACTOR - ppm @ 3% O<sub>2</sub>

CO	0.00	0.53	0.03	0.19
>C <sub>1</sub> HC	4.27	10.44	8.21	7.64
NH <sub>3</sub>	15.39	16.35	13.61	15.12
NO <sub>x</sub>	14.39	11.82	11.64	12.62

TABLE 3-5. SUMMARY OF SOURCE EMISSION TESTS

Unit Tested: Bonneville Pacific Corp.  
HRSG Stack

Date: February 26, 1992

Test Number	4	5	6	Average
Test Condition	75% Gas	75% Gas	75% Gas	
Barometric Pressure (in. Hg)	30.15	30.13	30.18	30.15
Stack Pressure (in. Hg)	30.12	30.10	30.15	30.12
Stack Area (ft <sup>2</sup> )	23.758	23.758	23.758	23.758
Elapsed Sampling Time (min.)	62.50	62.50	62.50	62.50
Volume Gas Sampled (dscf)	53.336	53.613	53.505	53.485
F-Factor	8510.55	8510.55	8510.55	8510.55

## GAS DATA

Average Gas Velocity (fps)	75.12	75.42	75.99	75.51
Average Gas Temperature (°F)	379.92	381.67	382.54	381.38
Gas Flowrate (dscfm)	61,930	62,130	62,553	62,204
Gas Analysis (Dry % Basis)				
Carbon Dioxide	2.77	2.77	2.74	2.76
Oxygen	15.99	16.02	16.05	16.02
Water	7.20	7.00	7.20	7.13

## EMISSION CONCENTRATION - ppm

CO	0.31	0.50	0.93	0.58
NH <sub>3</sub>	4.67	4.29	3.99	4.32
NO <sub>x</sub>	2.03	2.06	2.27	2.12

## EMISSION RATE - lb/hr

CO	0.09	0.14	0.26	0.16
NH <sub>3</sub>	0.78	0.72	0.67	0.72
NO <sub>x</sub>	0.91	0.93	1.03	0.96

## EMISSION FACTOR - lb/MMBtu

CO	0.0008	0.0013	0.0025	0.0016
NH <sub>3</sub>	0.0076	0.0070	0.0066	0.0071
NO <sub>x</sub>	0.0089	0.0091	0.0101	0.0094

EMISSION FACTOR - ppm @ 3% O<sub>2</sub>

CO	1.13	1.83	3.43	2.13
NH <sub>3</sub>	17.03	15.74	14.73	15.83
NO <sub>x</sub>	7.40	7.56	8.38	7.78

TABLE 3-6. SUMMARY OF SOURCE EMISSION TESTS

Unit Tested: Bonneville Pacific Corp.  
HRSG Stack

Date: February 27, 1992

Test Number	1	2	3	Average
Test Condition	50% Gas	50% Gas	50% Gas	
Barometric Pressure (in. Hg)	30.20	30.21	30.21	30.21
Stack Pressure (in. Hg)	30.15	30.18	30.18	30.18
Stack Area (ft <sup>2</sup> )	23.758	23.758	23.758	23.758
Elapsed Sampling Time (min.)	62.50	62.50	62.50	62.50
Volume Gas Sampled (dscf)	53.689	51.382	51.106	52.059
F-Factor	8510.55	8510.55	8510.55	8510.55

**GAS DATA**

Average Gas Velocity (fps)	62.92	63.59	63.82	63.44
Average Gas Temperature (°F)	373.75	377.96	371.38	374.36
Gas Flowrate (dscfm)	52,601	53,052	53,655	53,103
Gas Analysis (Dry % Basis)				
Carbon Dioxide	2.49	2.50	2.50	2.50
Oxygen	16.45	16.42	16.34	16.40
Water	6.70	6.50	6.50	6.57

**EMISSION CONCENTRATION - ppm**

CO	1.59	1.24	2.52	1.78
NH <sub>3</sub>	4.56	3.94	4.65	4.38
NO <sub>x</sub>	1.76	1.90	1.64	1.77

**EMISSION RATE - 1b/hr**

CO	0.37	0.29	0.60	0.42
NH <sub>3</sub>	0.65	0.56	0.67	0.63
NO <sub>x</sub>	0.67	0.73	0.64	0.68

**EMISSION FACTOR - 1b/MMBtu**

CO	0.0047	0.0036	0.0072	0.0052
NH <sub>3</sub>	0.0082	0.0070	0.0082	0.0078
NO <sub>x</sub>	0.0085	0.0091	0.0078	0.0085

**EMISSION FACTOR - ppm @ 3% O<sub>2</sub>**

CO	6.40	4.95	9.89	7.08
NH <sub>3</sub>	18.34	15.74	18.25	17.42
NO <sub>x</sub>	7.08	7.59	6.44	7.04