

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

PET
AP-42
Section 5.13.2
Reference Number
18

MEMORANDUM

August 20, 1984


TO: Polymer Manufacturing NSPS File

FROM: Ken Meardon, Pacific Environmental Services, Inc.

SUBJECT: Revised Costs for PET Regulatory Alternatives

The purpose of this memo is to present the assumptions and calculations used to determine the ethylene glycol (EG) control costs associated with the regulatory alternatives for the poly(ethylene terephthalate) (PET) model plants. The revisions were made as a result of comments and additional information from Allied Fibers and Plastics since May 19, 1983. This memorandum supercedes Docket Entry No. II-B-62, which contains the original calculations.

Attachment I details the derivation of equipment sizing and costs for the baseline system for PET plants producing a low viscosity product, or a high viscosity product using a single end finisher. Attachment II details the equipment sizing and costs for the regulatory alternatives beyond baseline for the PET model plants. The baseline system for PET plants producing a high viscosity product using multiple end finishers is discussed in the footnotes to Table E-16 in the background information document.



Baseline System for Low Viscosity
PET Plants or High Viscosity PET
Plants with a single end finisher
per process line

- Assumptions: 1) spray condenser 1 is 99% efficient, outlet = 0.155 lb/1000 lb prod.
 spray condenser 2 is 90% efficient, outlet = 0.140 lb/1000 lb prod.
 $\therefore \text{system} = 1 - \frac{.155 + .14}{15.5 + 1.4} = 98.3\% \text{ efficient, outlet} = 0.295 \text{ lb/1000 lb prod.}$
- 2) Spray condenser 1 $\Delta p = 1 \text{ torr}$
 spray condenser 2 $\Delta p = 0.1 \text{ torr}$
- 3) All vessel streams + pressures identical to baseline system

I. Prefinisher Spray Condenser System

A. Exhaust from prefinisher

$$T = 290^{\circ}\text{C} \quad (554^{\circ}\text{F})$$

$$\text{Glycol} = 15.5 \text{ lb}/1000 \text{ lb product} = 15.5 (3.8) = 58.9 \text{ lb/hr}$$

$$\text{H}_2\text{O} + \text{Air} = 20\% \text{ of volume}$$

1. Assuming ideal gas behavior for all components: $PV = nRT$

$$V = \frac{nRT}{P}$$

$$V \propto K n$$

$$\text{since } K \left(\frac{RT}{P} \right) \text{ is fixed} \quad \frac{V_{EG}}{n_{EG}} = \frac{V_{H_2O}}{n_{H_2O}} = \frac{V_{AIR}}{n_{AIR}}$$

$$n_{EG} = 58.9 \text{ lb EG/hr} / 62 \text{ lb/lb mole} = 0.95 \text{ lb mole/hr}$$

$$\text{since } V_{H_2O} = 0.1 V_{EG} \quad , \quad H_2O = 0.095 \text{ lb mole/hr} \quad \times 18 \text{ lb/mole} = 1.71 \text{ lb/hr}$$

$$V_{AIR} = 0.1 V_{EG} \quad , \quad \text{Air} = 0.095 \text{ lb mole/hr} \quad \times 28.9 \text{ lb/mole} = 2.74 \text{ lb/hr}$$

$$\text{m. wt} = 55.6$$

2. Partial pressures $\neq$ molar content

$$\therefore P_{EG} = 0.8 \times 2 \text{ torr} = 1.60 \text{ torr}$$

$$P_{H_2O} = 0.1 \times 2 \text{ torr} = 0.20 \text{ torr}$$

$$P_{AIR} = 0.1 \times 2 \text{ torr} = 0.20 \text{ torr}$$

3. Condensation temperature calculation

Assuming 1) Spray condenser pressure drop = 0.1 torr

2) Air intake of 10 lb/hr

3) 99% E.G. removal

∴ Desired spray condenser outlet parameters

$$\begin{aligned}
 H_2O &= 1.71 \text{ lb/hr} \\
 \text{Air} &= 2.74 + 10 = 12.74 \text{ lb/hr} \\
 \text{E.G.} &= 0.01 \times 58.9 = 0.589 \text{ lb/hr} \\
 \text{Pressure} &= 20 - 0.1 = 19.0 \text{ torr} \\
 \text{MW} &= \frac{1.71 + 12.74 + 0.589}{\frac{1.71}{18} + \frac{12.74}{28.8} + \frac{0.589}{62}} = 27.5 \text{ lb/lb mole}
 \end{aligned}$$

given p_a & n_a

$$\begin{aligned}
 n_{\text{E.G.}} &= 0.589 \text{ lb/hr} / 62 \frac{\text{lb}}{\text{mole}} = 0.0095 \text{ lb mole/hr} \\
 n_{\text{air}} &= 12.74 \text{ lb/hr} / 28.8 = 0.442 \text{ lb mole/hr} \\
 n_{\text{H}_2\text{O}} &= 1.71 \text{ lb/hr} / 18 = 0.095 \text{ lb mole/hr} \\
 \text{total} &= 0.5465 \text{ lb mole/hr}
 \end{aligned}$$

$$\begin{aligned}
 \therefore p_{\text{EG}} &= 0.0095 / 0.5465 \times 1.9 = 0.033 \text{ torr} \\
 p_{\text{H}_2\text{O}} &= 0.095 / 0.5465 \times 1.9 = 0.330 \text{ torr} \\
 p_{\text{air}} &= 0.442 / 0.5465 \times 1.9 = 1.537 \text{ torr} \\
 \text{total} &= 1.900 \quad \checkmark
 \end{aligned}$$

required temperature is controlled by glycol vapor pressure:

Clausius Clapeyron solution for E.G.

$$\begin{aligned}
 \ln P_{\text{mmHg}} &= - 7023.5073 \frac{1}{T^{\circ}\text{K}} + 21.53825 \\
 \text{or } T (^{\circ}\text{K}) &= \frac{7023.5073}{21.53825 - \ln P} \\
 &= \frac{7023.5073}{21.53825 - \ln (0.033)} \\
 &= 281.5^{\circ}\text{K} = 8.5^{\circ}\text{C} = 47.3^{\circ}\text{F}
 \end{aligned}$$

∴ will use 45°F as design temperature

4. Required cooling

a. ethylene glycol condensation:

$$\Delta H_v = 191.12 \text{ cal/gm} \times 9/5 = 344 \text{ BTU/lb}$$

$$Q = \Delta H_v \times m = 344 \text{ BTU/lb} \times (58.9 - 0.589) = 20,060 \text{ BTU/hr}$$

b. ethylene glycol cooling

$$Q = C_p \Delta T m \quad C_p = 0.695 \text{ BTU/lb}^\circ\text{F}$$

$$Q = 0.695 \frac{\text{BTU}}{\text{lb}^\circ\text{F}} \times (554^\circ\text{F} - 45^\circ\text{F}) \times 58.9 \frac{\text{lb}}{\text{hr}} = 20,836 \text{ BTU/hr}$$

c. Overhead air cooling

$$Q = C_p \Delta T m \quad \overline{C_p} = 0.265 \text{ BTU/lb}^\circ\text{F}$$

$$Q = 0.265 \times (554 - 45) \times 2.74 \text{ lb/hr} = 370 \text{ BTU/hr}$$

d. Inleakage air cooling (assuming $T_{\text{amb}} = 90^\circ\text{F}$)

$$Q = 0.265 \times (90 - 45) \times 12 \text{ lb/hr} = 120 \text{ BTU/hr}$$

e. Overhead water vapor cooling

$$\overline{C_p} = \frac{0.165 + 0.23}{2} = 0.198$$

$$Q = 0.198 \times (554 - 45) \times 1.71 \text{ lb/hr} = 172 \text{ BTU/hr}$$

$$\therefore \text{TOTAL COOLING REQUIRED} = 41,558 \text{ BTU/hr}$$

5. Heat exchanger sizing

Spray condenser outlet temp. = 45°F

Will use inlet glycol temperature of 40°F

Required glycol flow =

$$Q = \dot{m} \bar{C}_p \Delta T$$

$$Q = 41,600 \text{ BTU/hr} \quad \Delta T = 5^{\circ}\text{F}$$

$$\bar{C}_p = 0.565 \text{ BTU/lb}^{\circ}\text{F}$$

(McCabe+Smith, p.986)


$$\dot{m} = \frac{Q}{\bar{C}_p \Delta T} = \frac{41,600}{0.565 \times 5} = 14,725 \text{ lb/hr}$$

Using Cooling medium as chilled water at 32°F inlet, 40°F outlet


$$Q = \dot{m} \bar{C}_p \Delta T \quad \text{required water flow}$$

$$\dot{m} = \frac{Q}{\bar{C}_p \Delta T} = \frac{41,600 \text{ BTU/hr}}{1 \text{ BTU/lb}^{\circ}\text{F} \times 8^{\circ}\text{F}} = 5,200 \text{ lb/hr}$$

$\therefore$ System parameters are:



Using scraped surface heat exchanger:



$$h_i = \frac{Q_T}{t_T A (T_s - T_a)} = 2 \sqrt{\frac{k_{EG} \rho n B}{\pi}} \quad \text{McCabe & Smith p 433-434}$$

assuming $B = 4$ (blades), $n = 1 \times 60 = 60$ r/hr $\therefore nB = 240$ hr⁻¹

$$h_i = 2 \sqrt{\frac{k_{EG} \rho 240}{\pi}}$$

$$C_p = 0.565 \text{ BTU/lb}^\circ\text{F}$$

$$\rho = 70.2 \text{ lb/ft}^3$$

$$k_{EG} = 0.153 \text{ BTU/ft}^\circ\text{F} \text{ (M+S, p 984)}$$

$$= 2 \sqrt{\frac{.153 \text{ BTU/ft}^\circ\text{F} \times 0.565 \text{ BTU/lb}^\circ\text{F} \times 70.2 \text{ lb/ft}^3 \times 240 \text{ 1/hr}}{\pi}}$$

$$= 43 \text{ BTU/ft}^2 \text{ hr}^\circ\text{F}$$

$$T_s - T_a = T_{H_2O} - T_{EG} = \Delta T_{LM} = \frac{\Delta T_{in} - \Delta T_{out}}{\ln(\Delta T_{in}/\Delta T_{out})} = \frac{8.5}{\ln 9/5} = 6.38^\circ\text{F}$$

$$A = \frac{Q_T}{t_T h_i \Delta T}, \quad t_T = 1/nB = .004167 \text{ hrs}, \quad Q_T/t_T = 41,600 \text{ BTU/hr}$$

$$A = \frac{41,600 \text{ BTU/hr}}{43 \text{ BTU/ft}^2 \text{ hr}^\circ\text{F} \times 6.4^\circ\text{F}} = 151.2 \text{ ft}^2$$

12" ID tube, $L = 193 \text{ ft}$ (12x24) 4, 50' passes

assuming 24" ID Tube, $L = 48 \text{ ft}$

assuming 36" ID tube, $L = 21.4 \text{ ft}$

1-1
calculated scraped surface exchanger is 36" ID tube, 21.4 ft long
will use 50% oversize to allow for oligomer fouling,


$\therefore$ 3' ID scraped tube, 30' long

assuming h_i is controlling factor (i.e. $h_o \text{ water} > 50$)

6. Recycle Pump Sizing

Assumptions:

1. Spray Condenser 50 feet high
2. Pump at ground level
3. Heat exchanger pressure drop negligible
4. 40' of 2" pipe total in pump loop:



5. Nozzle pressure 1 psia

6. Pumped fluid is ethylene glycol at 45°F, 14,725 lbm/hr

∴ Pump work = head lift work + ΔP work + PIPE LOSS WORK + KINETIC ENERGY

$$\therefore \dot{W}_p = \frac{P_b - P_a}{\rho} + \frac{g}{g_c} (z_b - z_a) + \frac{\bar{V}_b^2 - \bar{V}_a^2}{2g_c} + h_f$$

given -

$$\rho \text{ E.G.} = SpG \times \rho_{H_2O} = 1.0821 \times 62.425 = 67.55 \text{ lb/ft}^3$$

$$\bar{V}_b^2 = \bar{V}_a^2 \quad (\text{both } 2'' \text{ pipe})$$

assuming friction is negligible

$$\eta W_p = \frac{g}{g_c} (Z_b - Z_a) + \frac{P_b - P_a}{\rho}$$

$$Z_b = 50 \text{ ft}, Z_a = 0 \text{ ft}, P_b = 1 \text{ psia} = 144 \text{ lb/ft}^2, P_a = 14.7 \text{ psia} = 2117 \text{ lb/ft}^2$$

$$\begin{aligned} \therefore \eta W_p &= 50 + \frac{144 - 2117}{67.55} \quad \left(\frac{\text{ft} \cdot \text{lb}_f}{\text{lb}_m} \right) \\ &= 20.8 \text{ ft} \cdot \text{lb}_f / \text{lb}_m \end{aligned}$$

$$20.8 \times 14725 \text{ lb}_m / \text{hr} \times \frac{1 \text{ hr}}{3600 \text{ sec}} = 85.08 \text{ ft} \cdot \text{lb}_f / \text{sec}$$

$$\div 550 = .155 \text{ hp } (\eta W)$$

assuming $\eta = 0.25$ (50% pump hp, 50% motor hp)

$$\text{PUMP SIZE} = 0.62 \text{ hp}$$

$\therefore$ will specify 1 horsepower pump to allow for friction, etc.

neglected

II Finisher Condenser System

A. Exhaust From Finisher

$$T = 290^{\circ}\text{C} \text{ (554}^{\circ}\text{F)}$$

$$\text{Glycol} = 1.4 \text{ lb/1000 lb product} \quad , \quad 1.4 (3.8) = 5.32 \text{ lb/hr}$$

$$\text{Air} = 10\% \text{ volume}$$

$$\underline{\text{No H}_2\text{O}}$$

assuming ideal gas behavior:

$$\frac{V_{EG}}{V_{Air}} = \frac{n_{EG}}{n_{Air}}$$

$$n_{EG} = 5.32 \text{ lb/hr} / 62 \text{ lb/lb mole} = 0.085 \text{ lb/hr}^{\text{mole}}$$

$$n_{Air} = n_{EG} \frac{V_{Air}}{V_{EG}} = 0.085 \times \frac{0.1}{0.9} = .00944 \text{ mole/hr}$$

$$\times 28.8 \text{ lb/lb mole} = 0.272 \text{ lb/hr}$$

$$\text{MW} = 59.24 \quad , \quad \text{flow} = 5.32 + 0.272 = 5.592 \text{ lb/hr}$$

B. Partial Pressures & molar content

$$\therefore P_{EG} = .9 \times 0.2 \text{ torr} = 0.18 \text{ torr}$$

$$P_{Air} = .1 \times 0.2 \text{ torr} = 0.02 \text{ torr}$$

C. Condensation temperature calculation

- Assuming
- 1) spray condenser $\Delta P = 0.1 \text{ torr}$
 - 2) air leakage = 5 lb/hr
 - 3) 90% EG removal

∴ Desired spray condenser outlet

$$\text{Air} = 5 + 0.272 = 5.272 \text{ lb/hr}$$

$$\text{E.G.} = 5.32 \times 0.1 = 0.532 \text{ lb/hr}$$

$$P = 0.1 \text{ torr}$$

Since $p_a \approx n_a$

$$n_{\text{air}} = 5.272 \div 28.9 = 0.183 \text{ lb mole/hr}$$

$$n_{\text{eq.}} = 0.532 \div 62 = 0.0086 \text{ lb mole/hr}$$

$$\text{total} = 0.1916 \text{ lb mole/hr}$$

$$p_{\text{air}} = .183 / .1916 \times 0.1 \text{ torr} = .0955 \text{ torr}$$

$$p_{\text{E.G.}} = .0086 / .1916 \times 0.1 \text{ torr} = .0045 \text{ torr}$$

required temperature is controlled by $p_{\text{E.G.}}$

$$\ln P_{\text{torr}} = -7023.5073 \frac{1}{T^{\circ}\text{K}} + 21.53825$$

$$\text{or } T(^{\circ}\text{K}) = \frac{7023.5073}{21.53825 - \ln P}$$

$$\therefore T^{\circ}\text{K} = 260.7 = -12.4^{\circ}\text{C} \approx 10^{\circ}\text{F}$$

will use 0°F as design temperature for spray inlet

D. Required cooling = glycol condensation + glycol cooling + exhaust air cooling + intake air cooling

$$= \Delta H_{\text{v.E.G.}} \times \text{Cond. e.g.} + c_{p_{\text{EG}}} \times \dot{m}_{\text{EG}} \Delta T + c_{p_{\text{Air}}} (\dot{m}_{\text{air ex}} \Delta T + \dot{m}_{\text{air in}} \Delta T)$$

$$= 344 \times (0.9 \times 5.32) + [695 \times 554^{\circ}\text{F} \times 5.32] + 0.265 [5 \times 70^{\circ}\text{F} + .27 \times 554^{\circ}\text{F}]$$

$$= 3828 \text{ BTU/hr}$$

E. Scraped surface exchanger sizing

assuming $B = 4$, $n = 1 \text{ rpm}$ (60 rph)

$$nB = 240 \text{ hr}^{-1}$$

$$h_i = 2 \sqrt{\frac{K c_p \rho \pi B}{\pi}}$$

$$= 2 \sqrt{\frac{.153 \text{ BTU/ft}^2 \text{ hr}^\circ\text{F} \times 0.565 \text{ BTU/lb}^\circ\text{F} \times 70.2 \text{ lb/ft}^3 \times 240 \text{ hr}^{-1}}{\pi}}$$

$$= 43.06 \text{ BTU/ft}^2 \text{ hr}^\circ\text{F}$$

assuming glycol temp in = 10°F , out = 0°F
 coolant temp in = -20°F , out = 0°F

$$\Delta T_{LM} = \frac{(10 - 0) - [0 - (-20)]}{\ln(10/20)} = 14.4^\circ\text{F}$$

$$A = \frac{Q_T}{h_i \Delta T} = \frac{4,000 \text{ BTU/hr}}{43 \text{ BTU/ft}^2 \text{ hr}^\circ\text{F} \times 14.4^\circ\text{F}} = 6.5 \text{ ft}^2$$

$$\text{Assuming } 12'' \text{ I.D. TUBE, } L = A/s = \frac{6.5 \text{ ft}^2}{\left[\frac{\pi \left(\frac{11}{16} \right)^2}{4} \right]} = 8.3 \text{ ft}$$

F. Glycol spray flow

$$Q = m C_p \Delta T$$

$$C_p = 0.565 \text{ BTU/lb}^\circ\text{F}$$

$$\Delta T = 10^\circ\text{F}$$

$$Q = 4,000 \text{ BTU/hr}$$

$$\dot{m} = \frac{4000}{0.565 \times 10} = 708 \text{ lb/hr}$$

G. Pump Size

E.G. recycle flow is $\ll$ than prefinisher system flow
therefore, 1 HP pump will be more than adequate

III. System Costs

Capital Cost Items ARE:

- 1) Spray condensers
- 2) Recycle Pumps
- 3) Scraped Surface Exchangers
- 4) Recovery Tank
- 5) Refrigeration Systems
- 6) Vacuum System Components for pressure drop correction

Annual Cost Items are:

- 1) Refrigeration Electricity
- 2) Labor
- 3) Scraped Surface Exchanger rotor electricity
- 4) Recycle Pump Electricity
- 5) Vacuum system increased operating costs
- 6) Maintenance Parts + Labor
- 7) Glycol recovery savings

Capital Cost Items:

I) Scraped Surface Exchangers

Double Pipe Exchanger Cost

Peters & Timmerhaus Fig 14-17 p 671, Jan '79 \$

316 S.S. Tubes -

Plot of Form $\log P(\$) = K \log A(\text{ft}^2) + m$

data	1 ft ² = \$820	$\log A = 0$	$\log P = 2.914$
	100 ft ² = \$1800	2	3.255

$$K = \frac{\Delta \log P}{\Delta \log A} = \frac{0.341}{2} = 0.1705$$

$$m = 2.914$$

$$\therefore \log P = 0.1705 \log A + 2.914$$

Prefinisher exchanger = 150 ft², PRICE ≈ \$1930 (Jan '79)

Finisher exchanger A = 6.5 ft², PRICE ≈ \$1130 (Jan '79)

Will estimate motor, wiper, etc at 100% of exchanger cost,

So	Prefinisher exchanger = \$3860	(Jan 79)		\$4362	Jan '80
	finisher exchanger = \$2260	(Jan 79)		\$2554	Jan '80

C/E cost index - Jan 79 - 229.8 (4/23/79) Factor = 1.13

June 80 - 259.2 (11/17/80)

II) PUMPS - each 1 HP

Per Hall, et al. "Current Costs of Process Equipment"
Ch. Engineering, 4/5/82 Vol. 89 No. 7

Fig 30

Asymptotic Cost for small pumps of \$1,000 ea. Jan '82

Index	Jan. 82	311.8
	Jun. 80	259.2

Ratio = 0.831

Cost = \$1,000 $\times$ 0.831 = \$831

III) Refrigeration System

Per Envirosciences

20°F System, 4 TON SYSTEM (48,000 BTU/hr) = \$10,000 installed, DEC
- 20°F System, 1 TON SYSTEM (12,000 BTU/hr) = \$9,800 installed, DEC '79

descalation $\frac{259.2}{279.6} = 0.928$

4 TON, 20°F = \$9283

1 TON, -20°F = \$9100

* April 21, 1980 Ch. E.

IV) Ethylene Glycol Recovery System

Per previous submittal - \$386,300

V Spray Condensers

21,200 ea descalation factor = 0.82

June 80 cost = \$17,384

REGULATORY ALTERNATIVE COSTS

CAPITAL COSTS

I. Prefinisher Spray Condenser System (all equipment spared)

June 1980 dollars

A. Spray Condensers 14 @ 17,384 = \$243,376

B. Scraped Surface Exchangers 14 @ 1,930 = 27,020

C. Pumps 14 @ 831 = 11,634

D. EG Recovery Components 1 @ 386,300 = 386,300

Subtotal \$668,330

Installation 3.24 x equipment = \$2,165,390

Subtotal Installed \$2,833,720

E. Refrigeration Systems (Installed) 7 @ 9,283 = 64,981

TOTAL PREFINISHER SYSTEM CAPITAL = \$2,898,700

II. Finisher Spray Condenser System

A. Condensers 14 @ 17,384 = \$243,376

B. Exchangers 14 @ 1,130 = 15,820

C. Pumps 14 @ 831 = 11,634

Subtotal \$270,830

Installation 3.24 x equipment = 877,489

Subtotal Installed \$1,148,319

D. Refrigeration Systems (Installed) 7 @ 9,100 = 63,700

TOTAL FINISHER SYSTEM CAPITAL = \$1,212,019

III. Esterifiers

A. Exchangers	14 @ 1,530*	= \$ 21,420
B. Reflux condensers	14 @ 17,834**	= <u>243,376</u>
Subtotal		\$ 264,796
Installation	3.24 x equipment	<u>857,939</u>
TOTAL ESTERIFIER SYSTEM CAPITAL		<u>1,122,735</u>

* Assumed to be equal to average of exchanger costs for the prefinisher & finisher systems.

** Assumed equal to spray condenser costs.

ANNUALIZED COSTS

I. Prefinisher and E.G. Recovery System

A. Operating Labor	\$ 154,800 ^a
B. Maintenance Materials and Labor	21,700 ^a
C. Capital Recovery (0.163 x capital)	472,488
D. Taxes, Ins., & Admin (0.04 x capital)	115,948
E. Electricity	49,820 ^b
F. Steam	880,792 ^c
G. Water	4,650 ^a

^a/from earlier approximation

b/ 1) Pump Electricity = 14 pumps @ 1 hp

$$14 \times 1 \text{ HP} \times \frac{.746 \text{ kW}}{\text{HP}} \times 8760 \text{ hr/yr} = 45,745 \text{ kWh/yr}$$

$$45,745 \text{ kWh/yr} \times \$0.049/\text{kWh} = \$2,240/\text{yr}$$

2) Refrigeration electricity = 7 systems @ 10 tons, 1.22 HP/ton (Enviroscience)

$$= 7 \times 10 \times 1.22 \times 0.746 \times 8760 \times 0.049 = \$27,350/\text{yr}$$

3) Recovery System = $412,800 \text{ kWh/yr}^a \times 0.049 = \$20,230/\text{yr}$

c/ Steam increase for vacuum jets

Baseline system = 63.4 lb/hr @ 2.0 torr $\approx$ 5% uncondensables

w/ spray condenser = 15.04 lb/hr @ 1.9 torr $\approx$ 98% uncondensables

per Attachment I, increase = $8.523 \times 10^6 \text{ #/yr}$

E.G. recovery system steam^a = $1.34 \times 10^8 \text{ #/yr}$

TOTAL STEAM INCREASE = $1.42523 \times 10^8 \text{ #/yr} \times \$6.18/1000 \text{ lb} = \$880,792$

II. FINISHER SYSTEM^a

A. Operating Labor	\$18,720 ^b
B. Maintenance Labor & Materials	^c
C. Capital Recovery ($0.163 \times \text{capital}$)	197,559
D. Taxes, Ins., & Admi ($0.04 \times \text{capital}$)	48,481
E. Electricity	7,240 ^d
F. Steam Increase	37,138

a/ Costs assume the prefinisher system, and hence the E.G. recovery system already installed.

b/ Based on 20 hrs/wk added labor @ \$18/hr: $20 \times 52 \times 18 = \$18,720$

c/ Assumed included in prefinisher system costs.

d/ Pump electricity = \$2,240/yr as in prefinisher system

Refrigeration electricity = 7 systems $\times$ 1 ton each $\times$ $2.23 \frac{\text{HP}}{\text{ton}} \times .746 \times 8760 \times .09$
 $= \$5,000/\text{yr}$

e/ Steam jet increase per attachment II

$7 \times 98 \text{ #/hr} \times 8760 \text{ hr/yr} \times \$6.18/1,000 \text{ lb} = \$37,138$

III. ESTERIFIER SYSTEM

A. Electricity	\$29,590 ^a
B. Capital Recovery ($0.163 \times \text{capital}$)	183,005
C. Taxes, Ins., & Admin. ($0.04 \times \text{capital}$)	44,909

a/ Assumed to be same as for spray condenser system on prefinishers (i.e., pump electricity + refrigeration electricity).

COST SUMMARY

	Prefinisher	Finisher	Esterifier	<u>Total</u>
Capital	2,898,700	1,212,019	1,122,735	5,233,454
Annualized	1,700,198	309,138	257,504	2,266,840

REGULATORY ALTERNATIVES BEYOND BASELINE FOR PET PLANTS

High Viscosity PET Production Using Multiple End Finishers

The regulatory alternatives for this model plant consisted of sending additional amounts of cooling water to the existing distillation column. Table II-1 summarizes the relevant parameters for determining the flow to the distillation column and ethylene glycol (EG) emissions to the atmosphere.

As the flow to the distillation column changes, the size of the column required and its cost will also vary. Based on information provided by industry and scaled to this model plant size, the total flow to the distillation column is 2.187 gpm, of which 0.237 gpm comes from the cooling tower and 1.95 gpm from other sources in the process line. The cost of the initial distillation column was estimated to be \$568,000 (June 1980). This estimate was derived from industry supplied information on the cost for a distillation column on a cooling water tower. The capital costs for the various flows beyond baseline were calculated using the following equation:

$$\$ = \left(\frac{1.95 + \text{gpm}}{2.187} \right)^{0.6} \times \$568,000$$

The results of these calculations are included in Table II-2.

Low Viscosity PET Production, and High Viscosity PET Production Using Single End Finishers

Both the PET/DMT and the PET/TPA - single end finisher model plants have a regulatory alternative in which a distillation column is installed to reduce the ethylene glycol (EG) concentration in the cooling tower and, thereby, the ethylene glycol emissions to the atmosphere. For the PET/DMT model plant, EG emissions to the atmosphere are about 4.78 lbs/hr and, for the PET/TPA model plant, about 4.24 lbs/hr. The EG concentration in the cooling tower is assumed to be 0.31 percent for the TPA plant and slightly higher at 0.35 percent for the DMT plant. The

existing cooling tower system is assumed to be in equilibrium so that EG entering the cooling tower is equal to that lost to the atmosphere (i.e., 4.78 lbs/hr for PET/DMT and 4.24 lbs/hr for PET/TPA).

The regulatory alternative based on adding a distillation column is assumed to reduce EG emissions by one-half. This is assumed to occur by decreasing the EG concentration in the cooling tower to about 0.16 percent in the TPA plants and to about 0.18 percent in the DMT plants. Finally, it was assumed that the recovery efficiency of a distillation column on this concentration would be 40 percent.

Based on these assumptions and using the procedures outlined above for calculating the material balance for ethylene glycol, the following results are obtained:

	<u>DMT</u>	<u>TPA</u>	<u>Equation</u>
Flow to distillation column, gpm	13.26	13.25	
EG recovered, lbs/yr	41,117	36,486	
Capital cost of distillation column	\$1,675,275	\$1,675,275	$\frac{13.25}{10}^{0.6} \times \$1,415,000$
Steam cost	\$323,919	\$288,563	
Recovery credit	\$11,101	\$9,851	
Emission reduction, Mg/yr	18.65	16.55	

These results apply to the model plants as a whole, and not to the cost of control for a single process line. It is unlikely that a separate cooling tower would be built for each of the seven lines in the model plant. For purposes of this analysis it was assumed that the costs associated with a single process line were equal to one-seventh of those costs associated with a distillation column for the whole plant.

TABLE II-1. MATERIAL BALANCE OF ETHYLENE GLYCOL FOR HIGH VISCOSITY PET PLANTS USING MULTIPLE END FINISHERS

(A) Concentration of Ethylene Glycol in Cooling Water in Tower, percent	(B) Ethylene Glycol Emissions to the Atmosphere, lbs/hr ^a	(C) Ethylene Glycol to the Distillation Column, lbs/hr ^b	(D) Ethylene Glycol Recovery Efficiency in Column, percent ^c	(E) Ethylene Glycol Recycled Overhead to Tower, lbs/hr ^d	(F) Ethylene Glycol Recovered, lbs/hr ^e	(G) Flow to Distillation Column, gpm ^f
8.959	17.23	10.71	94.95	0.54	10.17	0.237
8.0	15.39	12.74	94.3	0.73	12.01	0.315
7.0	13.45	14.94	93.4	0.99	13.95	0.423
6.0	11.51	17.23	92.2	1.34	15.89	0.570
5.5	10.55	18.45	91.35	1.60	16.85	0.666
5.0	9.58	19.69	90.5	1.87	17.82	0.783
4.0	7.66	22.43	88.0	2.69	19.74	1.117

^aBased on a circulation rate of ~~1,100~~ ^{1,270} gallons per minute and a windage rate of ~~0.045~~ ^{0.03} percent.

Example: $17.23 = (0.0895 \times 1,270 \text{ g/m} \times 60 \text{ m/hr} \times 0.0003) \times (9.25 \times \%EG + 8.34 \times \%H_2O)$
where $\%EG = 0.0895$; $\%H_2O = 0.9105$.

^bBased on an initial flow of 27.4 lbs/hr of EG to the cooling water tower from the finishers (derived from industry data) and calculated as follows:

Example: $\frac{10.71}{27.4 - 17.23} = \frac{10.71}{10.17} = 0.9495$

^cDerived from industry data.

^dColumn E = Column C x $\frac{(100 - \text{Column D})}{100}$

^eColumn F = Column C x Column D

^fColumn G = Column C ÷ (Column A x 60 min/hr x (9.25 x %EG + 8.34 x % H₂O))

Example:
 $0.237 = \frac{10.71}{(0.0895 \times 60 \times (9.25 \times 0.0895 + 8.34 \times 0.9105))}$

^gThe figures in this row represent the baseline situation.

TABLE II-2. SUMMARY OF CAPITAL AND ANNUAL OPERATING COSTS FOR
HIGH VISCOSITY PET PLANTS USING MULTIPLE END FINISHERS

Ethylene Glycol Concentration, percent	Flow, gpm	Cost Item	
		Distillation Column	Steam
8.95	0.237	\$568,456	\$5,344
8.0	0.315	\$580,535	\$7,167
7.0	0.423	\$596,989	\$9,719
6.0	0.570	\$618,911	\$13,230
5.5	0.666	\$632,951	\$15,545
5.0	0.783	\$649,788	\$18,354
4.0	1.117	\$696,331	\$26,435