

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.



EVALUATOR CNC

EVALUATION DATE 7/13/92

METHOD 5: SECONDARY EMISSIONS TEST REPORT EVALUATION

STATE: WY

FACILITY: Phone-Poolene WY Inc.

TEST DATE: 5/9/90

PROCESS(ES) TESTED: 2 Hot Air Dryers 45C-10

trans ore calciner, w/ cyclone & scrubber

SAMPLING DURATION

must have at least 3 runs, each ≥ 1 hour duration, with sampling ≥ 2 minutes at each traverse point, and total sampling volume ≥ 30 dscf

run 3 27 dscf - ✓

SAMPLING TEMPERATURE

both probe and filter must be maintained at $248 \pm 25^\circ\text{F}$ or other temperature specified in NSPS

PRODUCTION RATE

is process or production rate during testing representative of normal rates

CONTROL DEVICE(S)

are devices described, and their efficiencies given

no

BACK-HALF

if any, what method was used to catch and recover condensable matter

WY - water

EQUIPMENT were a borosilicate glass probe liner and a glass fiber filter used

CALIBRATION were both pre- and post-test calibrations performed for meter box

pitot tube

temperature sensor

nozzle (3 #)

LEAK CHECKS both pre- and post-test

BLANKS were filter and reagent blanks analyzed, and were any problems addressed

SAMPLE PREP

filter desiccation and tare weights documented

BOILER TESTS

calculation of F_0 from Orsat accurate

ISOKINETICS within $100 \pm 10\%$ for all runs

EVALUATOR CMEEVALUATION DATE 7/13/92

METHOD 5: SECONDARY EMISSIONS TEST REPORT EVALUATION

STATE: WY FACILITY: Rhone-Poulenc WYTEST DATE: 5/10/90PROCESS(ES) TESTED: 4 SC-12Asoda ash dryer w/ cyclone & scrubber

SAMPLING DURATION

must have at least 3 runs, each ≥ 1 hour duration, with sampling ≥ 2 minutes at each traverse point, and total sampling volume ≥ 30 dscf3

SAMPLING TEMPERATURE

both probe and filter must be maintained at $248 \pm 25^\circ\text{F}$ or other temperature specified in NSPS3

PRODUCTION RATE

is process or production rate during testing representative of normal rates

3

BACK-HALF

if any, what method was used to catch and recover condensable matter

3WY - H₂O

CONTROL DEVICE(S)

are devices described, and their efficiencies given

290

EQUIPMENT were a borosilicate glass probe liner and a glass fiber filter used

3

METHOD 1

are calculations accurate, and is figure provided

3

CALIBRATION were both pre- and post-test calibrations performed for meter box

3

pitot tube

3

METHODS 2,3

are data and calculations included for gas velocity, cyclonic flow, and molecular weight determination, and is source of barometric pressure noted

3

temperature sensor

3

nozzle (3 #)

3

METHOD 4

are data and calculations included for moisture content determination, and is moisture content realistic ($< \text{saturation}$)3

LEAK CHECKS both pre- and post-test

3

FIELD DATA is field data on standard forms, and does raw data correspond with printout

3

BLANKS were filter and reagent blanks analyzed, and were any problems addressed

3

SAMPLE PREP

filter desiccation and tare weights documented

3

BOILER TESTS

calculation of F_0 from Orsat accurateN/AISOKINETICS within $100 \pm 10\%$ for all runs3

EVALUATOR CMCEVALUATION DATE 7/13/92

METHOD 5: SECONDARY EMISSIONS TEST REPORT EVALUATION

STATE: WYFACILITY: Rhone-Poulenc WYTEST DATE: 5/11/90PROCESS(ES) TESTED: 5 IS-10trona ore calciner w/ cyclone & ESP

SAMPLING DURATION

must have at least 3 runs, each $\geq$ 1 hour duration, with sampling $\geq$ 12 minutes at each traverse point, and total sampling volume $\geq$ 30 dscf3

SAMPLING TEMPERATURE

both probe and filter must be maintained at $248 \pm 25^\circ\text{F}$ or other temperature specified in NSPS3

PRODUCTION RATE

is process or production rate during testing representative of normal rates

3

BACK-HALF

if any, what method was used to catch and recover condensable matter

3WY - H₂O

CONTROL DEVICE(S)

are devices described, and their efficiencies given

2no

EQUIPMENT were a borosilicate glass probe liner and a glass fiber filter used

3

METHOD 1

are calculations accurate, and is figure provided

3

CALIBRATION were both pre- and post-test calibrations performed for meter box

3

METHODS 2,3

are data and calculations included for gas velocity, cyclonic flow, and molecular weight determination, and is source of barometric pressure noted

3

pitot tube

3

temperature sensor

3

nozzle (3 #)

3

METHOD 4

are data and calculations included for moisture content determination, and is moisture content realistic ($<$ saturation)3

LEAK CHECKS both pre- and post-test

3

BLANKS were filter and reagent blanks analyzed, and were any problems addressed

3

FIELD DATA is field data on standard forms, and does raw data correspond with printout

3

SAMPLE PREP

filter desiccation and tare weights documented

3

BOILER TESTS

calculation of F_0 from Orsat accurateN/AISOKINETICS within $100 \pm 10\%$ for all runs3

EVALUATOR CMCEVALUATION DATE 7/13/92

METHOD 5: SECONDARY EMISSIONS TEST REPORT EVALUATION

STATE: WYFACILITY: Phone-Poulenc WYTEST DATE: 5/12/90PROCESS(ES) TESTED: SES-12sake ash dryer w/ cyclone & cooler w/ baghouse & cyclone, all vented to ESP

SAMPLING DURATION

3
must have at least 3 runs, each ≥ 1 hour duration, with sampling ≥ 2 minutes at each traverse point, and total sampling volume ≥ 30 dscf

SAMPLING TEMPERATURE

3
both probe and filter must be maintained at $248 \pm 25^\circ\text{F}$ or other temperature specified in NSPS

PRODUCTION RATE

3
is process or production rate during testing representative of normal rates

BACK-HALF

3
if any, what method was used to catch and recover condensable matterH₂O - WY

CONTROL DEVICE(S)

2
are devices described, and their efficiencies given
noEQUIPMENT were a borosilicate glass probe liner and a glass fiber filter used 3

METHOD 1

3
are calculations accurate, and is figure providedCALIBRATION were both pre- and post-test calibrations performed for meter box 3

METHODS 2,3

3
are data and calculations included for gas velocity, cyclonic flow, and molecular weight determination, and is source of barometric pressure notedpitot tube 3temperature sensor 3nozzle (3 #) 3

METHOD 4

3
are data and calculations included for moisture content determination, and is moisture content realistic ($< \text{saturation}$)LEAK CHECKS both pre- and post-test 3FIELD DATA is field data on standard forms, and does raw data correspond with printout 3BLANKS were filter and reagent blanks analyzed, and were any problems addressed 3


BOILER TESTS

calculation of F_0 from Orsat accurate N/A

SAMPLE PREP

3
filter desiccation and tare weights documentedISOKINETICS within $100 \pm 10\%$ for all runs 3

RHONE-POULENC WYOMING CO.
PARTICULATE EMISSION COMPLIANCE PROGRAM
UNIT 4 ; CALCINER and DRIER KILN SCRUBBER EXHAUST
UNIT 5 ; CALCINER and DRIER KILN PRECIPITATOR EXHAUST



Prepared for:

RHONE-POULENC WYOMING CO.
P.O Box 513
Green River, Wyoming 82935

Prepared By:

TRC ENVIRONMENTAL MEASUREMENTS DIVISION
7002 S. Revere Parkway
Suite 60
Englewood, Colorado 80112

TRC Project Reference No. 7700-E32

May 21, 1990

TRC
Environmental
Consultants

7002 South Revere Parkway
Suite 60
Englewood, CO 80112

(303) 792-5555

A **TRC** Company

→ ~~Church~~
Lee
File

MEMORANDUM

TO: RHONE-POULENC COMPLIANCE FILE
THROUGH: BERNIE DAILEY, ^{PR}ENGINEERING SUPERVISOR
FROM: DAN OLSON, COMPLIANCE OFFICER *D Olson*
DATE: JUNE 11, 1990
SUBJECT: PARTICULATE STACK TESTS ON SOURCES 4SC-10, 4SC-12A, 5ES-10 AND
5ES-12 CONDUCTED THE WEEK OF MAY 7, 1990

The subject stack test report was received by the Division on May 31, 1990. The tests were performed by TRC Environmental Consultants of Englewood, Colorado during the week of May 7, 1990.

The test report was reviewed for consistency with the requirements of Reference Methods 1-5 for particulate. For each of the four separate test series the placement and number of sampling points correctly followed the guidelines. Test procedures appear to have been followed correctly in each case.

The raw test data included with the test report was independently analyzed for comparison with the results obtained by the testing firm. The calculations on an individual basis generally agreed, however, for the third test on source 4SC-10 the test data indicated a collected water volume of 369.2 ml while TRC utilized a value of 303.2 in their calculations. This was enough of a difference to boost the tested average over the allowable in the TRC calculations. I placed a call to TRC on June 11, 1990 and spoke to a Mr. Kurt Parker asking for verification of the correct value of collected water for this test. He returned my call later in the day and indicated that the correct value was 369.2 ml.

Another discrepancy in the report was also found in that all of the summary tables (3-1, 3-2, 3-3, and 3-4) incorrectly presented the three test average results. Rather than presenting the true average of the three tests, the TRC computer program averaged only the first two tests in each case. Mr. Parker was also advised of this problem. He indicated that an errata would be forthcoming.

The results of the analysis performed by the Division together with the corrected average results obtained by TRC is given in the table below. These results are for the total particulate catch, including front and back halves.

EMISSION RATES (lb/hr)

SOURCE	TRC	AQD	ALLOWABLE
SCRUBBER(4SC-10)	53.33	52.29	52.6
SCRUBBER(4SC-12A)	45.35	46.81	51.6
PRECIPITATOR(5ES-10)	21.53	21.53	23.1
PRECIPITATOR(5ES-12)	3.89	3.89	12.0

(NOTE: The AQD results for source 4SC-12A represent an average of only two tests since field data from the first test was not included in our copy of the report. TRC's 1st test results were comparable to the other two however so the three test average should be also.)

The results of this analysis indicate that all sources tested are in compliance with applicable particulate limits. However, source 4SC-10 is very marginal in performance. Rhone-Poulenc has indicated that they suspect an inadequate spray distribution on this unit and that they are investigating this possibility. I would suggest that this source because of its marginal operation should be subjected to an additional test after the company's evaluation of this possible problem.

cc: Lee Gribovicz

Rhône-Poulenc

Scrubber 4SC-10

5/9/90

Data Sheet $P_{std} = 29.92 \text{ in Hg}$ $T_{std} = 530^{\circ} \text{ R}$

24 pts

	Test 1	Test 2	Test 3
P_{bar} = barometric pressure at site (in Hg)	<u>24.05</u>	<u>24.05</u>	<u>24.07</u>
P_s = absolute stack gas pressure (in Hg)	<u>24.04</u>	<u>24.043</u>	<u>24.062</u>
T_s = absolute average stack gas temp. (°R)	<u>615.4</u>	<u>615.7</u>	<u>615.8</u>
T_m = absolute average dry gas meter temp. (°R)	<u>530.8</u>	<u>536.6</u>	<u>537.4</u>
V_{ic} = total volume of water collected (ml)	<u>426.2</u>	<u>369.2</u>	<u>369.2</u>
V_m = volume of gas through dry gas meter (ft ³)	<u>45.93</u>	<u>38.206</u>	<u>34.721</u>
ΔH = average pressure drop across orifice (in H ₂ O)	<u>1.9954</u>	<u>1.2713</u>	<u>0.9871</u>
C_p = pitot tube coefficient	<u>0.84</u>	<u>0.84</u>	<u>0.84</u>
$(\overline{\Delta P})_{ave}$ = average velocity head of stack gas (in H ₂ O)	<u>0.4159</u>	<u>0.3640</u>	<u>0.3208</u>
A_s = cross-sectional area of stack (ft ²)	<u>63.62</u>	<u>63.62</u>	<u>63.62</u>
M_n = total amount of ^{FRONT} particulate collected (g)	<u>0.2646</u> <u>0.2702</u>	<u>0.2967</u> <u>0.3036</u>	<u>0.2660</u> <u>0.2775</u>
Q = total sampling time (min.)	<u>60.</u>	<u>60</u>	<u>60</u>
A_n = cross-sectional area of nozzle (ft ²)	<u>0.0007467</u>	<u>—</u>	<u>—</u>

(FAIL)

Orsat Analysis

	Test 1	Test 2	Test 3
% CO ₂	<u>8.0</u>	<u>7.4</u>	<u>7.4</u>
% O ₂	<u>10.4</u>	<u>9.8</u>	<u>10.2</u>
% CO	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
% N ₂	<u>81.6</u>	<u>82.8</u>	<u>82.4</u>

STACK TEST CALCULATIONS

*
*
*
*
*
*
*
*
*
*
*

SOURCE: RHONE-POULENC, SCRUBBER 4SC-10 (FRONT HALF)

TESTED BY: SMITH & HAWLEY
TRC

DATE TESTED: 05/09/90

OBSERVED BY: LEE GRIBOVICZ

EVALUATED BY: DAN OLSON

	TEST #1	TEST #2	TEST #3
AMBIENT PRESSURE (in Hg)	2.405E+01	2.405E+01	2.407E+01
ABS. STACK GAS PRESSURE (in Hg)	2.404E+01	2.404E+01	2.406E+01
ABS. AVE. STACK GAS TEMP (*R)	6.154E+02	6.157E+02	6.158E+02
ABS. AVE. DGM TEMP (*R)	5.308E+02	5.366E+02	5.374E+02
TOT. VOL. H2O COLLECTED (ml)	4.262E+02	3.692E+02	3.692E+02
VOL. THRU DGM (ft3)	4.593E+01	3.871E+01	3.472E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	1.995E+00	1.278E+00	9.871E-01
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	4.159E-01	3.640E-01	3.208E-01
STD VOL. SAMPLED (scf)	3.693E+01	3.072E+01	2.752E+01
H2O VAPOR IN GAS @STP (ft3)	2.006E+01	1.738E+01	1.738E+01
MOL. WT. WET (lb/lb mole)	2.558E+01	2.539E+01	2.510E+01
MOL. WT. DRY (lb/lb mole)	2.970E+01	2.958E+01	2.959E+01
VEL. STACK GAS (fps)	2.987E+01	2.625E+01	2.326E+01
FLOW RATE, DRY @ STP (scfm)	5.094E+04	4.410E+04	3.752E+04
CONCENTRATION (gr/scf)	1.105E-01	1.489E-01	1.491E-01
CONCENTRATION (lb/scf)	1.578E-05	2.128E-05	2.130E-05
EMISSION RATE (lb/hr)	4.824E+01	5.629E+01	4.794E+01
% ISOKINETIC	1.030E+02	9.901E+01	1.042E+02

Ave: 50.82¹⁵/₁₄₂

STACK TEST CALCULATIONS

```

*****
*
* SOURCE:      RHONE-POULENC, SCRUBBER 4SC-10 (TOTAL)
*
* TESTED BY:   SMITH & HAWLEY
*              TRC
*
* DATE TESTED: 05/09/90
*
* OBSERVED BY: LEE GRIBOVICZ
*
* EVALUATED BY: DAN OLSON
*
*****

```

	TEST #1	TEST #2	TEST #3
AMBIENT PRESSURE (in Hg)	2.405E+01	2.405E+01	2.407E+01
ABS. STACK GAS PRESSURE (in Hg)	2.404E+01	2.404E+01	2.406E+01
ABS. AVE. STACK GAS TEMP (*R)	6.154E+02	6.157E+02	6.158E+02
ABS. AVE. DGM TEMP (*R)	5.308E+02	5.366E+02	5.374E+02
TOT. VOL. H2O COLLECTED (ml)	4.262E+02	3.692E+02	3.692E+02
VOL. THRU DGM (ft3)	4.593E+01	3.871E+01	3.472E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	1.995E+00	1.278E+00	9.871E-01
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	4.159E-01	3.640E-01	3.208E-01
STD VOL. SAMPLED (scf)	3.693E+01	3.072E+01	2.752E+01
H2O VAPOR IN GAS @STP (ft3)	2.006E+01	1.738E+01	1.738E+01
MOL. WT. WET (lb/lb mole)	2.558E+01	2.539E+01	2.510E+01
MOL. WT. DRY (lb/lb mole)	2.970E+01	2.958E+01	2.959E+01
VEL. STACK GAS (fps)	2.987E+01	2.625E+01	2.326E+01
FLOW RATE, DRY @ STP (scfm)	5.094E+04	4.410E+04	3.752E+04
CONCENTRATION (gr/scf)	1.128E-01	1.524E-01	1.555E-01
CONCENTRATION (lb/scf)	1.612E-05	2.177E-05	2.222E-05
EMISSION RATE (lb/hr)	4.926E+01	5.760E+01	5.002E+01
% ISOKINETIC	1.030E+02	9.901E+01	1.042E+02

$$Q_{flow} = 63.62 \text{ ft}^3 \times \frac{60 \text{ sec}}{\text{min}} \times \text{Vel Stack Gas (fps)}$$

Ave: 52.29 ¹⁶/_{hr}.
 Permitted: 50 ¹⁵/_{hr}

29.87 = 114,020
 26.75 = 100,202
 23.26 = 88,788
101,003 avg

Phone-Pauline.

Scraper 4SC-12A

5/10/90

12PD

Data Sheet

$P_{std} = 29.92$ in Hg

$T_{std} = 530^{\circ}$ R

Data missing

	Test 1	Test 2	Test 3
P_{bar} = barometric pressure at site (in Hg)		<u>23.62</u>	<u>23.64</u>
P_s = absolute stack gas pressure (in Hg)		<u>23.631</u>	<u>23.651</u>
T_s = absolute average stack gas temp. (OR)		<u>621.9</u>	<u>622.0</u>
T_m = absolute average dry gas meter temp. (OR)		<u>546.8</u>	<u>552.7</u>
V_{ic} = total volume of water collected (ml)		<u>459</u>	<u>455.1</u>
V_m = volume of gas through dry gas meter (ft ³)		<u>39.524</u>	<u>39.086</u>
ΔH = average pressure drop across orifice (in H ₂ O)		<u>1.180</u>	<u>1.175</u>
C_p = pitot tube coefficient		<u>0.84</u>	<u>0.84</u>
$(\sqrt{\Delta P})_{ave}$ = average velocity head of stack gas (in H ₂ O)		<u>0.6293</u>	<u>0.6255</u>
A_s = cross-sectional area of stack (ft ²)		<u>23.76</u>	<u>23.76</u>
M_h = total amount of particulate collected (g) <i>Front</i>		<u>0.4099</u> <u>0.4111</u>	<u>0.4067</u> <u>0.4074</u>
Q = total sampling time (min.)		<u>60.0</u>	<u>60.0</u>
A_n = cross-sectional area of nozzle (ft ²)		<u>0.0004493</u>	<u>0.0004493</u>

Orsat Analysis

Process Rate
(TPH)

Test 1

Test 2

Test 3

% CO₂

% O₂

% CO

% N₂

6.0

11.8

0.0

82.2

6.0

12.0

0.0

82.0

(PASS)

89 TPH avg

85

89

94

STACK TEST CALCULATIONS

X

X SOURCE: RHONE-POULENC, SCRUBBER 4SC-12A (FRONT HALF)

X

X TESTED BY: SMITH & HAWLEY
X TRC

X

X DATE TESTED: 05/10/90

X

X OBSERVED BY: LEE GRIBOVICZ

X

X EVALUATED BY: DAN OLSON

X

	TEST #1	TEST #2
AMBIENT PRESSURE (in Hg)	2.362E+01	2.364E+01
ABS. STACK GAS PRESSURE (in Hg)	2.363E+01	2.365E+01
ABS. AVE. STACK GAS TEMP (*R)	6.219E+02	6.224E+02
ABS. AVE. DGM TEMP (*R)	5.468E+02	5.527E+02
TOT. VOL. H2O COLLECTED (ml)	4.590E+02	4.551E+02
VOL. THRU DGM (ft3)	3.952E+01	3.909E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	1.180E+00	1.175E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	6.293E-01	6.255E-01
STD VOL. SAMPLED (scf)	3.023E+01	2.960E+01
H2O VAPOR IN GAS @STP (ft3)	2.161E+01	2.142E+01
MOL. WT. WET (lb/lb mole)	2.467E+01	2.464E+01
MOL. WT. DRY (lb/lb mole)	2.943E+01	2.944E+01
VEL. STACK GAS (fps)	4.667E+01	4.642E+01
FLOW RATE, DRY @ STP (scfm)	2.602E+04	2.574E+04
CONCENTRATION (gr/scf)	2.090E-01	2.119E-01
CONCENTRATION (lb/scf)	2.986E-05	3.027E-05
EMISSION RATE (lb/hr)	4.661E+01	4.676E+01
% ISOKINETIC	1.025E+02	1.014E+02

Ave: 46.69 ¹⁵/_{hr}

STACK TEST CALCULATIONS

 *
 * SOURCE: RHONE-POULENC, SCRUBBER 4SC-12A (TOTAL)
 *
 * TESTED BY: SMITH & HAWLEY
 * TRC
 *
 * DATE TESTED: 05/10/90
 *
 * OBSERVED BY: LEE GRIBOVICZ
 *
 * EVALUATED BY: DAN OLSON
 *

	TEST #1	TEST #2
AMBIENT PRESSURE (in Hg)	2.362E+01	2.364E+01
ABS. STACK GAS PRESSURE (in Hg)	2.363E+01	2.365E+01
ABS. AVE. STACK GAS TEMP (*R)	6.219E+02	6.224E+02
ABS. AVE. DGM TEMP (*R)	5.468E+02	5.527E+02
TOT. VOL. H2O COLLECTED (ml)	4.590E+02	4.551E+02
VOL. THRU DGM (ft3)	3.952E+01	3.909E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	1.180E+00	1.175E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	6.293E-01	6.255E-01
STD VOL. SAMPLED (scf)	3.023E+01	2.960E+01
H2O VAPOR IN GAS @STP (ft3)	2.161E+01	2.142E+01
MOL. WT. WET (lb/lb mole)	2.467E+01	2.464E+01
MOL. WT. DRY (lb/lb mole)	2.943E+01	2.944E+01
VEL. STACK GAS (fps)	4.667E+01	4.642E+01
FLOW RATE, DRY @ STP (scfm)	2.602E+04	2.574E+04
CONCENTRATION (gr/scf)	2.097E-01	2.123E-01
CONCENTRATION (lb/scf)	2.996E-05	3.032E-05
EMISSION RATE (lb/hr)	4.677E+01	4.684E+01
% ISOKINETIC	1.025E+02	1.014E+02

$$Q_{scfm} = 23.76 \text{ ft}^2 \times \frac{60 \text{ sec}}{\text{min}} \times \frac{1}{2} \text{ Vel Stack Gas (fps)}$$

$$46.67 = 66,533$$

$$46.42 = 66,176$$

$$\frac{66,355 \text{ avg}}{Q_{scfm}}$$

Ave: 46.81 ¹⁶/_{hr}
 Permitted: 50 ¹⁵/_{hr}

Rhône-Paulenc Precip. Intake - 555-10 5/11/90

Data Sheet

24pts.

$P_{std} = 29.92$ in Hg

$T_{std} = 530^{\circ}$ R

	Test 1	Test 2	Test 3
P_{bar} = barometric pressure at site (in Hg)	<u>23.54</u>	<u>23.50</u>	<u>23.47</u>
P_s = absolute stack gas pressure (in Hg)	<u>23.524</u>	<u>23.484</u>	<u>23.454</u>
T_s = absolute average stack gas temp. ($^{\circ}$ R)	<u>849.5</u>	<u>851.3</u>	<u>854.3</u>
T_m = absolute average dry gas meter temp. ($^{\circ}$ R)	<u>507.4</u>	<u>514.1</u>	<u>528.9</u>
V_{ic} = total volume of water collected (ml)	<u>259.5</u>	<u>251.4</u>	<u>241.2</u>
V_m = volume of gas through dry gas meter (ft ³)	<u>40.12</u>	<u>37.696</u>	<u>39.20</u>
ΔH = average pressure drop across orifice (in H ₂ O)	<u>1.265</u>	<u>1.1583</u>	<u>1.2104</u>
C_p = pitot tube coefficient	<u>0.84</u>	<u>0.84</u>	<u>0.84</u>
$(\sqrt{\Delta P})_{ave}$ = average velocity head of stack gas (in H ₂ O)	<u>0.6163</u>	<u>0.6169</u>	<u>0.6237</u>
A_s = cross-sectional area of stack (ft ²)	<u>62.49</u>	<u>62.49</u>	<u>62.49</u>
M_h = total amount of particulate collected (g) <i>front half</i>	<u>0.0808</u> <u>0.0826</u>	<u>0.0585</u> <u>0.0630</u>	<u>0.0761</u> <u>0.0779</u>
Q = total sampling time (min.)	<u>60.0</u>	<u>60.0</u>	<u>60.0</u>
A_n = cross-sectional area of nozzle (ft ²)	<u>0.0004789</u>	<u>—————→</u>	

TPH Gross Rate

140 TPH avg

Orsat Analysis

	Test 1	Test 2	Test 3
% CO ₂	<u>9.8</u>	<u>9.2</u>	<u>9.4</u>
% O ₂	<u>8.8</u>	<u>9.8</u>	<u>9.2</u>
% CO	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
% N ₂	<u>81.4</u>	<u>81.0</u>	<u>81.4</u>

139

138

142

(PASS)

STACK TEST CALCULATIONS

SOURCE: RHONE-POULENC, PRECIPITATOR SES-10 (FRONT HALF)
 TESTED BY: SMITH & HAWLEY
 TRC
 DATE TESTED: 05/11/90
 OBSERVED BY: LEE GRIBOVICZ
 EVALUATED BY: DAN OLSON

	TEST #1	TEST #2	TEST #3
AMBIENT PRESSURE (in Hg)	2.354E+01	2.350E+01	2.347E+01
ABS. STACK GAS PRESSURE (in Hg)	2.352E+01	2.348E+01	2.345E+01
ABS. AVE. STACK GAS TEMP (*R)	8.495E+02	8.513E+02	8.543E+02
ABS. AVE. DGM TEMP (*R)	5.074E+02	5.141E+02	5.299E+02
TOT. VOL. H2O COLLECTED (ml)	2.595E+02	2.514E+02	3.412E+02
VOL. THRU DGM (ft3)	4.012E+01	3.770E+01	3.920E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	1.265E+00	1.158E+00	1.210E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	6.163E-01	6.169E-01	6.237E-01
STD VOL. SAMPLED (scf)	3.296E+01	3.051E+01	3.080E+01
H2O VAPOR IN GAS @STP (ft3)	1.221E+01	1.183E+01	1.606E+01
MOL. WT. WET (lb/lb mole)	2.670E+01	2.655E+01	2.580E+01
MOL. WT. DRY (lb/lb mole)	2.992E+01	2.986E+01	2.987E+01
VEL. STACK GAS (fps)	5.147E+01	5.176E+01	5.321E+01
FLOW RATE, DRY @ STP (scfm)	6.880E+04	6.807E+04	6.353E+04
CONCENTRATION (gr/scf)	3.780E-02	2.957E-02	3.810E-02
CONCENTRATION (lb/scf)	5.400E-06	4.225E-06	5.443E-06
EMISSION RATE (lb/hr)	2.229E+01	1.725E+01	2.075E+01
% ISOKINETIC	1.043E+02	9.754E+01	1.055E+02

Ave: 20.10 lb/hr

STACK TEST CALCULATIONS

SOURCE: RHONE-POULENC, PRECIPITATOR SES-10 (TOTAL)

TESTED BY: SMITH & HAWLEY
TRC

DATE TESTED: 05/11/90

OBSERVED BY: LEE GRIBOVICZ

EVALUATED BY: DAN OLSON

	TEST #1	TEST #2	TEST #3
AMBIENT PRESSURE (in Hg)	2.354E+01	2.350E+01	2.347E+01
ABS. STACK GAS PRESSURE (in Hg)	2.352E+01	2.348E+01	2.345E+01
ABS. AVE. STACK GAS TEMP (*R)	8.495E+02	8.513E+02	8.543E+02
ABS. AVE. DGM TEMP (*R)	5.074E+02	5.141E+02	5.289E+02
TOT. VOL. H2O COLLECTED (ml)	2.595E+02	2.514E+02	2.412E+02
VOL. THRU DGM (ft3)	4.012E+01	3.770E+01	3.920E+01
AVE. DEL P ACROSS GRIFICE (in H2O)	1.265E+00	1.158E+00	1.210E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	6.163E-01	6.169E-01	6.237E-01
STD VOL. SAMPLED (scf)	3.296E+01	3.051E+01	3.080E+01
H2O VAPOR IN GAS @STP (ft3)	1.221E+01	1.183E+01	1.135E+01
MOL. WT. WET (lb/lb mole)	2.670E+01	2.655E+01	2.667E+01
MOL. WT. DRY (lb/lb mole)	2.992E+01	2.986E+01	2.987E+01
VEL. STACK GAS (fps)	5.147E+01	5.176E+01	5.233E+01
FLOW RATE, DRY @ STP (scfm)	6.880E+04	6.807E+04	6.946E+04
CONCENTRATION (gr/scf)	3.864E-02	3.185E-02	3.900E-02
CONCENTRATION (lb/scf)	5.520E-06	4.550E-06	5.572E-06
EMISSION RATE (lb/hr)	2.279E+01	1.858E+01	2.322E+01
% ISOKINETIC	1.043E+02	9.754E+01	9.651E+01

$$A_g = 62.49 \text{ ft}^2 \times \frac{60 \text{ sec}}{\text{min}} \times \text{vel of gas (fps)}$$

$$\begin{aligned} 51.47 &= 192,982 \\ 51.76 &= 194,069 \\ 52.33 &= 196,206 \\ \hline &194,419 \text{ avg} \end{aligned}$$

$$\text{Ave: } \frac{20.87}{21.53} \text{ }^{15}/\text{hr}$$

$$\text{Resulted: } 23.0 \text{ }^{15}/\text{hr.}$$

Rhône-Poulenc

Precipitator SES-12

5/12/90

12 pts

Data Sheet $P_{std} = 29.92$ in Hg $T_{std} = 530^{\circ}$ R

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>
P_{bar} = barometric pressure at site (in Hg)	<u>23.69</u>	<u>23.70</u>	<u>23.71</u>
P_s = absolute stack gas pressure (in Hg)	<u>23.698</u>	<u>23.708</u>	<u>23.718</u>
T_s = absolute average stack gas temp. (OR)	<u>696.8</u>	<u>705.6</u>	<u>705.4</u>
T_m = absolute average dry gas meter temp. (OR)	<u>519.2</u>	<u>533</u>	<u>539.6</u>
V_{ic} = total volume of water collected (ml)	<u>271</u>	<u>366.3</u>	<u>333.2</u>
V_m = volume of gas through dry gas meter (ft ³)	<u>42.683</u>	<u>57.431</u>	<u>60.78</u>
ΔH = average pressure drop across orifice (in H ₂ O)	<u>1.458</u>	<u>2.440</u>	<u>2.681</u>
C_p = pitot tube coefficient	<u>0.84</u>	<u>0.84</u>	<u>0.84</u>
$(\sqrt{\Delta P})_{ave}$ = average velocity head of stack gas (in H ₂ O)	<u>0.4047</u>	<u>0.5348</u>	<u>0.5560</u>
A_s = cross-sectional area of stack (ft ²)	<u>28.27</u>	<u>—————→</u>	
M_n = ^{From half} total amount of particulate collected (g)	<u>.0422</u> <u>4.0434</u>	<u>0.0522</u> <u>0.0335</u>	<u>0.0477</u> <u>0.0566</u>
Q = total sampling time (min.)	<u>60</u>	<u>60</u>	<u>60</u>
A_n = cross-sectional area of nozzle (ft ²)	<u>0.0007.266</u>	<u>—————→</u>	

Orsat Analysis

TPH Process Rate

51 avg TPH

49 50 55

(PASS)

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>
% CO ₂	<u>8.4</u>	<u>8.6</u>	<u>8.6</u>
% O ₂	<u>9.8</u>	<u>10.0</u>	<u>10.0</u>
% CO	<u>—</u>	<u>—</u>	<u>—</u>
% N ₂	<u>81.8</u>	<u>81.4</u>	<u>81.4</u>

STACK TEST CALCULATIONS

SOURCE: RHONE-POULENC, PRECIPITATOR SES-12 Feant half

TESTED BY: SMITH & HAWLEY
TRC

DATE TESTED: 05/12/90

OBSERVED BY: LEE GRIBOVICZ

EVALUATED BY: DAN OLSON

	TEST #1	TEST #2	TEST #3
AMBIENT PRESSURE (in Hg)	2.369E+01	2.370E+01	2.371E+01
ABS. STACK GAS PRESSURE (in Hg)	2.370E+01	2.371E+01	2.372E+01
ABS. AVE. STACK GAS TEMP (*R)	6.968E+02	7.056E+02	7.054E+02
ABS. AVE. DGM TEMP (*R)	5.192E+02	5.330E+02	5.396E+02
TOT. VOL. H2O COLLECTED (ml)	2.710E+02	3.663E+02	3.332E+02
VOL. THRU DGM (ft3)	4.268E+01	5.743E+01	6.078E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	1.416E+00	2.440E+00	2.681E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	4.047E-01	5.348E-01	5.560E-01
STD VOL. SAMPLED (scf)	3.451E+01	4.539E+01	4.750E+01
H2O VAPOR IN GAS @STP (ft3)	1.276E+01	1.724E+01	1.568E+01
MOL. WT. WET (lb/lb mole)	2.657E+01	2.653E+01	2.685E+01
MOL. WT. DRY (lb/lb mole)	2.974E+01	2.978E+01	2.978E+01
VEL. STACK GAS (fps)	3.057E+01	4.067E+01	4.201E+01
FLOW RATE, DRY @ STP (scfm)	2.272E+04	2.964E+04	3.179E+04
CONCENTRATION (gr/scf)	1.886E-02	1.094E-02	1.549E-02
CONCENTRATION (lb/scf)	2.694E-06	1.563E-06	2.212E-06
EMISSION RATE (lb/hr)	3.673E+00	2.780E+00	4.219E+00
% ISOKINETIC	9.855E+01	9.937E+01	9.697E+01

Ave 3.557 lb/hr

STACK TEST CALCULATIONS

```

*****
*
* SOURCE:          RHONE-POULENC, PRECIPITATOR SES-12 (TOTAL)
*
* TESTED BY:       SMITH & HAWLEY
*                  TRC
*
* DATE TESTED:     05/12/90
*
* OBSERVED BY:     LEE GRIBOVICZ
*
* EVALUATED BY:    DAN
*
*****

```

	TEST #1	TEST #2	TEST #3
AMBIENT PRESSURE (in Hg)	2.369E+01	2.370E+01	2.371E+01
ABS. STACK GAS PRESSURE (in Hg)	2.370E+01	2.371E+01	2.372E+01
ABS. AVE. STACK GAS TEMP (*R)	6.968E+02	7.056E+02	7.054E+02
ABS. AVE. DGM TEMP (*R)	5.192E+02	5.330E+02	5.396E+02
TOT. VOL. H2O COLLECTED (ml)	2.710E+02	3.663E+02	3.332E+02
VOL. THRU DGM (ft3)	4.268E+01	5.743E+01	6.078E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	1.416E+00	2.440E+00	2.681E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	4.047E-01	5.348E-01	5.560E-01
STD VOL. SAMPLED (scf)	3.451E+01	4.539E+01	4.750E+01
H2O VAPOR IN GAS @STP (ft3)	1.276E+01	1.724E+01	1.568E+01
MOL. WT. WET (lb/lb mole)	2.657E+01	2.653E+01	2.685E+01
MOL. WT. DRY (lb/lb mole)	2.974E+01	2.973E+01	2.978E+01
VEL. STACK GAS (fps)	3.057E+01	4.067E+01	4.201E+01
FLOW RATE, DRY @ STP (scfm)	2.272E+04	2.964E+04	3.179E+04
CONCENTRATION (gr/scf)	1.940E-02	1.138E-02	1.837E-02
CONCENTRATION (lb/scf)	2.771E-06	1.626E-06	2.625E-06
EMISSION RATE (lb/hr)	3.777E+00	2.892E+00	5.007E+00
% ISOKINETIC	9.855E+01	9.937E+01	9.697E+01

As

$$scfm = 28.27 \frac{ft^2}{min} \times \frac{60 \frac{sec}{min}}{min} \times \text{vel stack gas (fps)}$$

$$\begin{aligned}
 30.57 &= 51,853 \\
 40.67 &= 68,984 \\
 42.01 &= 71,257
 \end{aligned}$$

$$64,031 \text{ avg } scfm$$

$$\text{Ave} = 3.892 \text{ lb/hr}$$

$$\text{Permitted} = 12 \text{ lb/hr}$$



RHÔNE-POULENC OF WYOMING CO.

P.O. BOX 513
GREEN RIVER, WY 82935
TEL: (307) 875-2600

May 25, 1990

*Don M
P.H.*

Mr. Lee Gribovicz, District Engineer
Air Quality Division
Department of Environmental Quality
210 Lincoln Street
Lander, Wyoming 82520

Dear Lee:

Enclosed are the results of emissions' tests performed by TRC on 4SC-10, 4SC-12A, 5ES-10 and 5ES-12. As I reported to you in our phone conversation of 5/25/90, the average emissions from 4SC-10 were approximately one pound over the permitted level. The test results show a change in air flow from about 114,000 DSCFM to 88,000 DSCFM during the three tests. Nothing in the collected control room data indicates this could have happened, so we feel the test results are somewhat suspect; however, we have cut production in Unit 4 Dissolvers from 128 TPH to no more than 120 TPH in an effort to stay in compliance with permitted allowables.

An internal inspection of 4SC-10 showed a possibility that the spray distribution pattern was not adequate. We may further evaluate this possibility next week. I will keep you posted on this matter, and will also inform you of dates for retesting emission rates.


As I reported to you, opacity values did not correlate well with tested emission rates. If you have any information regarding opacity/emission relationship, or why correlation between these two parameters was so poor, we would like to receive it.

If you have any questions regarding this information, please contact me.


Ronald K. Smith
Ronald K. Smith
Environmental Services
Supervisor

RKS/lm

CC: Charles Collins (W/Attachments)



RHONE-POULENC WYOMING CO.
PARTICULATE EMISSION COMPLIANCE PROGRAM
UNIT 4 ; CALCINER and DRIER KILN SCRUBBER EXHAUST
UNIT 5 ; CALCINER and DRIER KILN PRECIPITATOR EXHAUST



Prepared for:

RHONE-POULENC WYOMING CO.
P.O. Box 513
Green River, Wyoming 82935

Prepared By:

TRC ENVIRONMENTAL MEASUREMENTS DIVISION
7002 S. Revere Parkway
Suite 60
Englewood, Colorado 80112

TRC Project Reference No. 7700-E32

May 21, 1990

TRC

**Environmental
Consultants**

7002 South Revere Parkway
Suite 60
Englewood, CO 80112

(303) 792-5555

A **TRC** Company

TABLE OF CONTENTS

<i>Section Number</i>	<i>Page No.</i>
1.0 INTRODUCTION	1
2.0 SUMMARY OF RESULTS	2
3.0 DISCUSSION OF RESULTS	3
3.1 Scrubber Particulate Tests	3
3.2 Precipitator Particulate Tests	6
4.0 PROCESS DESCRIPTION	11
4.1 Scrubber 4SC-10	11
4.2 Scrubber 4SC-12A	11
4.3 Electrostatic Precipitator 5ES-10	11
4.4 Electrostatic Precipitator 5ES-12	11
4.5 Process Operation During Test Program	12
5.0 TEST PROGRAM DESCRIPTION	13
5.1 Selection of Traverse Points	13
5.2 Molecular Weight Determination	13
5.3 Flow Rate Determination	14
5.4 Moisture Determination	14
5.5 Particulate Determination	14
6.0 SAMPLING INSTRUMENTATION AND EQUIPMENT	17
6.1 Flow Rate Measurements	17
6.2 Particulate Measurements	18
7.0 QUALITY ASSURANCE	19
APPENDICES	
A. Calculation Summaries	
B. Laboratory and QA/QC Data	
C. Plant and Process Data	
D. Field Data Sheets	

1.0 INTRODUCTION

The Rhone-Poulenc of Wyoming Co. operates a trona mining and processing facility is located in southwestern Wyoming near Green River, Wyoming. The facility is required by Wyoming Department of Environmental Quality (WDEQ) to demonstrate particulate emission compliance for selected control equipment. Particulate emissions from the following control equipment was evaluated during this compliance program:

<i>4SC-10</i>	<i>Scrubber</i>	<i>Unit 4</i>
<i>4SC-12A</i>	<i>Scrubber</i>	<i>Unit 4</i>
<i>5ES-10</i>	<i>Precipitator</i>	<i>Unit 5</i>
<i>5ES-12</i>	<i>Precipitator</i>	<i>Unit 5</i>

TRC Environmental Consultants, Inc. was retained by the Rhone-Poulenc of Wyoming Co., to provide the required particulate compliance program for the four (4) sources. The test program was conducted during the week of May 7, 1990 by the Environmental Measurements Division of the TRC Englewood, Colorado office. Coordination of the test effort and collection of the process data was provided by Mr. Ron Smith and Mr. John Hawley of the Rhone-Poulenc of Wyoming Co., facility. Observing the field test methods and procedures was Mr. Lee Gribovicz, District Air Quality Engineer representing Wyoming DEQ.

Testing was performed following established procedures of the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III, Stationary Source Specific Methods, EPA-600/4-77-027B, August 1977, Code of Federal Register, Title 40 part 60 Appendix A, and the Wyoming Department of Environmental Quality Source Testing Manual.

2.0 SUMMARY OF RESULTS


The Rhone-Poulenc of Wyoming Co. facility test program encompassed the field effort for determination of particulate pollutant emission compliance from four separate sources. The following section presents a summary of the overall average compliance test results for each unit and a comparison of the to the permitted emission limits established for the facility. Proceeding sections in this report detail individual Reference Method test results for each unit, the specific test procedures and test methodology, instrumentation utilized in the field effort, and quality assurance. Corresponding calculational summaries, laboratory data, process data, and raw field data are provided in the appendix of this report.

The emission test program was conducted to independently evaluate particulate measurements from the individual exhaust stacks of Unit 4 scrubbers (4SC-10 and 4SC-12A) and the Unit 5 electrostatic precipitators ((5ES-10 and 5ES-12). An overall summary of the test results from each source is provided in Table 2-1 below. Average mass pollutant emission rates in pounds per hour (lbs/hr) are presented for each source. In addition, Figure 2-1 provides a graphic illustration of the comparison of particulate emission levels to the permitted levels.

Table 2-1

<i>Source</i>	<i>Flow Rate (DSCFM)</i>	<i>Temperature (F)</i>	<i>Measured Emissions (lbs/hr)</i>	<i>Permitted Emissions (lbs/hr)</i>
4SC-10	107,140	155.5	53.41	50.0
4SC-12A	25,488	160.8	45.33	50.0
5ES-10	68,375	390.4	20.68	23.0
5ES-12	26,160	241.2	3.34	12.0

Figure 2-1



3.0 DISCUSSION OF RESULTS

The following section provides a general discussion of the individual test results obtained during the particulate compliance test program for each source. Detailed descriptions of the Reference Method test procedures and the laboratory analyses provided for the program is provided in Section 5.0 of this report. All sample analyses for particulate mass loading, including both front and back half analyses, was performed in TRC's Englewood, Colorado laboratory on May 13 through 15, 1990.

3.1 Scrubber Particulate Tests

Emission testing for particulate was completed for the Unit 4 scrubbers between May 9, 1990 and May 10, 1990. Tests for the scrubber associated with the dissolver section (4SC-10) were designated 4SE10-2 through 4SE10-4 and conducted on May 9, 1990. Tests for the scrubber associated with the evaporator section (4SC-12A) were designated 4SE12A-1 through 4SE12A-3 and were conducted on May 10, 1990. Particulate tests for each source were comprised of Reference Method 5 procedure consisting of collecting three independent samples. The total extraction time for each test was sixty (60) minutes utilizing two ports at the sampling location.

3.1.1 Scrubber 4SC-10

Four particulate tests were initiated for this unit. Test 4SE10-1 was voided due to process down time fifteen minutes in the test sequence. Due to insufficient sample time, the test was not recovered and analyzed. The particulate emission test for the following triplicate test series revealed variation in the calculated particulate levels. The calculated particulate emissions ranged from 49.24 (Test 4SE10-2) to 57.58 lbs/hr (4SE10-3). Immediately after sampling was completed, field personnel investigated the condition of the sample train. The glass fibre filter indicated slight discoloration and the initial impinger of the condensate train was found to be cloudy.

During the sampling program for this source, it was evident that the wind played a significant role in the velocity measurements collected during the sampling traverse. This was evident during the second and third tests of the triplicate series. Twenty-four total (12 on each port) points were used to assist in reducing the relative flow measurement error influenced by the wind conditions. As indicated from the results, the calculated flow varied from 114,067 DSCFM to 87,877 DSCFM for the first to the third test, respectively. At the conclusion of each sample run, filters and each probe wash were labeled, sealed and transported to the TRC laboratory for analysis. Prior to transport from the plant, chain of custody forms were completed and signed by the test crew.

Table 3-1 presents the results of the triplicate test series for Unit 4 SC-10 particulate emission results along with specific source parameters collected during the test. Associated with Table 3-1, Figure 3-1 provides an illustration of the triplicate test results for the source. The overall average particulate emission for the source was determined to be 53.41 pounds per hour.

Table 3-1


Table 3-1
SUMMARY OF PARTICULATE EMISSIONS
CALCINER KILN SCRUBBER EXHAUST : 4SC-10
RHONE-POULENK COMPANY
GREEN RIVER, WYOMING

TEST NO.	4SE10-2	4SE10-3	4SE10-4	
DATE	05-09-90	05-09-90	05-09-90	
TIME (HRS)	1410-1513	1601-1705	1734-1838	AVERAGE
<u>SAMPLE CONDITIONS</u>				
SAMPLE TIME (MIN)	60	60	60	60
VOLUME (DSCF)	36.94	30.72	27.51	33.83
NONCONDENSIBLE PARTICULATE (mg)	264.6	296.7	266.0	280.7
CONDENSIBLE PARTICULATE (mg)	5.6	6.9	11.5	6.3
TOTAL PARTICULATE (mg)	270.2	303.6	277.5	286.9
<u>SOURCE CONDITIONS</u>				
FLOWRATE (ACFM)	114,067	100,212	87,877	107,140
FLOWRATE (DSCFM)	50,886	44,048	39,849	47,467
STACK TEMPERATURE (F)	155.4	155.7	155.8	155.5
ISOKINETICS (%)	103.09	99.06	98.07	101.1
MOISTURE (%)	35.26	36.19	34.22	35.7
OXYGEN (%)	10.4	9.8	10.2	10.1
CARBON DIOXIDE (%)	8.0	7.4	7.4	7.7
NITROGEN (%)	81.6	82.8	82.4	82.2
<u>TOTAL PARTICULATE EMISSIONS</u>				
CONCENTRATION (GRAINS/DSCF)	1.13E-01	1.53E-01	1.56E-01	1.33E-01
CONCENTRATION (LBS/DSCF)	1.61E-05	2.18E-05	2.22E-05	1.90E-05
NONCONDENSIBLE EMISSIONS (LBS/HR)	48.22	56.27	50.96	52.25
CONDENSIBLE EMISSIONS (LBS/HR)	1.02	1.31	2.20	1.16
TOTAL EMISSIONS (LBS/HR)	49.24	57.58	53.16	53.41
TOTAL EMISSIONS (TONS/YR)	215.67	252.20	232.86	233.94

Figure 3-1


RHONE-POULENC

Summary of Scrubber Particulate Emissions (lbs/hr)



RHONE-POULENC

Summary of Precipitator Particulate Emissions (lbs/hr)



3.1.2 Scrubber 4SC-12A

The particulate emission test results for this source indicated minimal variation in the calculated particulate emission results. The overall average for the triplicate test series was calculated at 45.33 pounds per hour. Variation between the triplicate tests were found from 44.33 (4SE12A-1 and 4SE12A-2) and 45.4 pounds per hour for the third test 4SE12A-3. Table 3-2 presents the particulate emission test results along with specific process parameters collected during the test series. In addition, Figure 3-1 provides an illustration of the triplicate test results for the source.

At the conclusion of each sample run, filters and each probe wash were examined then transferred to labeled containers for transport to the TRC Englewood, Colorado laboratory for analysis. The glass fibre filters from the test series was found to have a slight discoloration with a corresponding cloudy first impinger of the condenser assembly.

3.2 Precipitator Particulate Tests

Emission testing for particulate was completed for the Unit 5 electrostatic precipitators between May 11, 1990 and May 12, 1990. Tests for the precipitator associated with the dissolver section (5ES-10) were designated 5SE10-1 through 4SE10-3 and conducted on May 11, 1990. Tests for the scrubber associated with the evaporator section (5ES-12) were designated 5ES12-1 through 5ES12-3 and were conducted on May 12, 1990. Particulate tests for each source were followed that of the previous scrubber series using Reference Method 5 procedures consisting of collecting three independent samples. The total extraction time for each test was sixty (60) minutes utilizing two ports at the sampling location.

3.2.1 Precipitator 5ES-10

Particulate emission testing was accomplished at the Unit 5 ESP during normal operations between the period of 0754 through 1208 on May 11, 1990. No process upsets were experienced throughout the test series. The results of the particulate emissions were variable for the triplicate series. The test results varied from 18.58 lbs/hr for the second test (5ES10-2) to 23.21 lbs/hr for the third test (5ES10-3).

Table 3-3 presents the calculated particulate emission results for the triplicate tests performed at Dissolver section precipitator. Test parameters collected in conjunction with the particulate test are included with the resultant concentrations and emissions. Figure 3-2a provide a graphic illustration of the particulate test results this precipitator source. The average particulate emission for this source was determined to be 20.68 pounds per hour.

Table 3-2

Table 3-2
SUMMARY OF PARTICULATE EMISSIONS
DRIER KILN SCRUBBER EXHAUST - 4SC-12A
RHONE-POULENK COMPANY
GREEN RIVER, WYOMING

TEST NO.	4SE12A-1	4SE12A-2	4SE12A-3	
DATE	05-10-90	05-10-90	05-10-90	
TIME (HRS)	1117-1221	1250-1352	1105-1208	AVERAGE
<u>SAMPLE CONDITIONS</u>				
SAMPLE TIME (MIN)	60	60	60	60
VOLUME (DSCF)	31.04	30.23	29.60	30.64
NONCONDENSIBLE PARTICULATE (mg)	404.7	409.7	406.7	407.2
CONDENSIBLE PARTICULATE (mg)	8.0	1.4	0.7	4.7
TOTAL PARTICULATE (mg)	412.7	411.1	407.4	411.9
<u>SOURCE CONDITIONS</u>				
FLOWRATE (ACFM)	63,464	64,549	64,198	64,007
FLOWRATE (DSCFM)	25,772	25,203	24,934	25,488
STACK TEMPERATURE (F)	159.8	161.9	162.4	160.8
ISOKINETICS (%)	102.98	102.56	101.49	102.8
MOISTURE (%)	39.88	41.75	42.05	40.8
OXYGEN (%)	12	11.8	12.0	11.9
CARBON DIOXIDE (%)	6.2	6.0	6.0	6.1
NITROGEN (%)	81.8	82.2	82	82.0
<u>TOTAL PARTICULATE EMISSIONS</u>				
CONCENTRATION (GRAINS/DSCF)	2.05E-01	2.10E-01	2.12E-01	2.08E-01
CONCENTRATION (LBS/DSCF)	2.93E-05	3.00E-05	3.03E-05	2.96E-05
NONCONDENSIBLE EMISSIONS (LBS/HR)	44.45	45.18	45.32	44.81
CONDENSIBLE EMISSIONS (LBS/HR)	0.88	0.15	0.08	0.52
TOTAL EMISSIONS (LBS/HR)	45.33	45.33	45.40	45.33
TOTAL EMISSIONS (TONS/YR)	198.53	198.56	198.85	198.55

Table 3-3

Table 3-3
SUMMARY OF PARTICULATE EMISSIONS
CALCINER KILN PRECIPITATOR - 5ES-10
RHONE-POULENK COMPANY
GREEN RIVER, WYOMING

TEST NO.	5ES10-1	5ES10-2	5ES10-3	
DATE	05-11-90	05-11-90	05-11-90	
TIME (HRS)	0754-0858	0936-1034	1105-1208	AVERAGE
<u>SAMPLE CONDITIONS</u>				
SAMPLE TIME (MIN)	60	60	60	60
VOLUME (DSCF)	32.96	30.51	30.80	31.73
NONCONDENSIBLE PARTICULATE (mg)	80.8	58.5	76.1	69.7
CONDENSIBLE PARTICULATE (mg)	1.8	4.5	1.8	3.2
TOTAL PARTICULATE (mg)	82.6	63.0	77.9	72.8
<u>SOURCE CONDITIONS</u>				
FLOWRATE (ACFM)	193,013	194,112	196,259	193,563
FLOWRATE (DSCFM)	68,742	68,009	69,398	68,375
STACK TEMPERATURE (F)	389.5	391.3	394.3	390.4
ISOKINETICS (%)	104.31	97.58	96.56	100.9
MOISTURE (%)	27.09	28	26.99	27.5
OXYGEN (%)	8.8	9.8	9.2	9.3
CARBON DIOXIDE (%)	9.8	9.2	9.4	9.5
NITROGEN (%)	81.4	81	81.4	81.2
<u>TOTAL PARTICULATE EMISSIONS</u>				
CONCENTRATION (GRAINS/DSCF)	3.87E-02	3.19E-02	3.90E-02	3.53E-02
CONCENTRATION (LBS/DSCF)	5.52E-06	4.55E-06	5.58E-06	5.04E-06
NONCONDENSIBLE EMISSIONS (LBS/HR)	22.29	17.25	22.68	19.77
CONDENSIBLE EMISSIONS (LBS/HR)	0.50	1.33	0.54	0.91
TOTAL EMISSIONS (LBS/HR)	22.79	18.58	23.21	20.68
TOTAL EMISSIONS (TONS/YR)	99.80	81.37	101.68	90.59

3.2.2 Precipitator SES-12

Particulate emission testing was conducted at the precipitator associated with the evaporator section of Unit 5 on May 12, 1990 during normal load operations. No process upsets were experienced throughout the test series. The triplicate test series revealed variation between the individual tests but demonstrated overall, reduced particulate emissions from the previous sources. The system emissions varied from 2.89 lbs/hr for the second test of the series to 5.01 lb/hr for the final test of the series. Variability was demonstrated in the measured flow rates for this source with a relative range of 51,875 to 71,293 DSCFM. The flow rates were found to increase from the beginning to the end of the test series.

Table 3-4 provides the calculated particulate emission results and associated source parameters collected during the period of 0716 through 1132. Figure 3-2 provides a similar graphic illustration of the test series for this precipitator. Test parameters collected in conjunction with the particulate test are included with the tabulated particulate concentrations and emissions.

All filters and probe wash samples collected for this source were labeled and sealed for transport to the TRC Englewood, Colorado laboratory. Prior to removing the collected samples from the facility, chain of custody forms were completed and signed by the field test crew.

Table 3-4

Table 3-4
SUMMARY OF PARTICULATE EMISSIONS
DRIER KILN PRECIPITATOR : SES-12
RHONE-POULENK COMPANY
GREEN RIVER, WYOMING

TEST NO.	SES12-1	SES12-2	SES12-3	
DATE	05-12-90	05-12-90	05-12-90	
TIME (HRS)	0716-0818	0904-1006	1030-1132	AVERAGE
<u>SAMPLE CONDITIONS</u>				
SAMPLE TIME (MIN)	60	60	60	60
VOLUME (DSCF)	34.48	45.39	47.50	39.93
NONCONDENSIBLE PARTICULATE (mg)	42.2	32.2	47.7	37.20
CONDENSIBLE PARTICULATE (mg)	1.2	1.3	8.9	1.25
TOTAL PARTICULATE (mg)	43.4	33.5	56.6	38.45
<u>SOURCE CONDITIONS</u>				
FLOWRATE (ACFM)	51,875	69,009	71,293	60,442
FLOWRATE (DSCFM)	22,699	29,620	31,767	26,160
STACK TEMPERATURE (F)	236.8	245.6	245.2	241.2
ISOKINETICS (%)	98.36	99.23	96.84	98.8
MOISTURE (%)	27.06	27.85	24.87	27.5
OXYGEN (%)	9.8	10.0	10.0	9.9
CARBON DIOXIDE (%)	8.4	8.6	8.6	8.5
NITROGEN (%)	81.8	81.4	81.4	81.6
<u>TOTAL PARTICULATE EMISSIONS</u>				
CONCENTRATION (GRAINS/DSCF)	1.94E-02	1.14E-02	1.84E-02	1.54E-02
CONCENTRATION (LBS/DSCF)	2.78E-06	1.63E-06	2.63E-06	2.20E-06
NONCONDENSIBLE EMISSIONS (LBS/HR)	3.68	2.78	4.22	3.23
CONDENSIBLE EMISSIONS (LBS/HR)	0.10	0.11	0.79	0.11
TOTAL EMISSIONS (LBS/HR)	3.78	2.89	5.01	3.34
TOTAL EMISSIONS (TONS/YR)	16.55	12.67	21.93	14.61

4.0 PROCESS DESCRIPTIONS

The Rhone-Poulenc Facility Test Program included the evaluation of pollution control equipment for Unit 4 and Unit 5. The compliance program included the evaluation of particulate pollutant emissions during representative operations of the Units. This section provides a brief description of the individual control devices that were evaluated.

4.1 Scrubber 4SC-10

4SC-10 is a venturi scrubber controls the particulate emissions from the dissolver section of Unit 4. The unit is connected to a Kiln (4K-1) with a cyclone (4CY-1) in between. The kiln is used to calcine trona ore. The scrubber offgas is discharged through a nine foot stack with the sampling ports located at approximately 1.8 diameters upstream (196.5") and 3.92 diameters downstream (432.5") from the nearest disturbance.

4.2 Scrubber 4SC-12A

4SC-12A is a venturi scrubber controls the particulate emissions from the evaporator section of Unit 4. The unit is connected to a Kiln (4K-2) with a cyclone (4CY-2) in between. The kiln is used to dry soda ash. The scrubber offgas is discharged through a sixty five inch (65") stack with the sampling ports located at approximately 4.7 diameters upstream (306") and 8.9 diameters downstream (582.0") from the nearest disturbance.

4.3 Precipitator 5ES-10

5ES-12 is an electrostatic precipitator that controls the particulate emissions from the dissolver section of Unit 5. The unit is connected to a Kiln (5K-1) with a cyclone (5CY-1) in between. The kiln is used to dry trona ore. The precipitator offgas is discharged through a one hundred and seven inch (107") stack with the sampling ports located at approximately 0.45 diameters upstream (48") and 3.3 diameters downstream (353") from the nearest disturbance.

4.4 Precipitator 5ES-12

5ES-12 is an electrostatic precipitator that controls the particulate emissions from the evaporator section of Unit 5. The unit is connected to a Kiln (5K-2) with a cyclone (5CY-2) in between. The kiln is used to dry soda ash. The five and one half (5.5") stack that receives the discharge from the 5ES-12 also receives the soda ash dust from a baghouse (5BH-13) from the cooler-classifiers with a cyclone in between (5CY-4). A portion of this exhaust gas is returned to the front of the Kiln (5K-2) with the remainder being exhausted to the stack.

4.2 Process Operation During Test(s)

During the particulate testing each unit was operated at representative conditions according to established operating procedures. Process operations were as continuous and steady as possible. Appropriate documentation of individual test start and stop times, along with documentation of process operations, which include pertinent operating conditions, were monitored and collected.

During the test program, plant personnel were designated for specific data collection responsibilities. In coordination with the particulate sampling conducted by TRC, designated Rhone-Poulenc personnel collected process data on the unit operation(s) as well as visually measured opacity.

5.0 TEST PROGRAM DESCRIPTION

Particulate emission compliance testing was performed in a manner to assure accurate and reliable data. All Reference Method tests were performed in triplicate. For purposes of reporting compliance, the arithmetic mean of the triplicate tests were utilized. In addition to the data reporting requirements, for purposes of acceptance of the particulate sampling, the isokinetics (normalized extraction rate) was required to be within ten percent of the expected rate (100% +/- 10%).

The primary methods utilized in this emission test program included the necessary procedures for determining the pollutant emissions based upon established Reference Methods 1 through 5. The following section provides a general discussion of the individual methods and test procedures that were incorporated into this annual compliance test program. Reference Method 1 was performed prior to the unit(s) test program to assist in qualifying the measurement and traverse locations for the particulate tests.

5.1 Selection of Traverse Points

EPA Reference Method 1, "Sample and Velocity Traverses for Stationary Sources," amended June, 1986, was utilized to determine the proper pollutant measurement points at the each test location of the four units. This was performed by taking the cross-section of the stack (inside diameter), at the measurement location, and dividing the calculated area into a number of equal areas.

The applicability of this method was to provide the proper number of traverse points for representative particulate sampling based upon the existing test port locations of the stack. Particulate sampling and volumetric flow rate measurements (velocity) are optimally performed at the test location that is at least eight stack diameters downstream and two diameters upstream from any flow disturbance such as a bend, expansion joint, or elbow. Sampling for RM 5 was provided on two separate traverses from the two sample ports aligned at ninety degrees to one another.

5.2 Flow Rate Determination

EPA Reference Method 2 "Determination of Stack Gas Velocity and Volumetric Flow rate (Type S Pitot Tube)," amended June, 1986, was utilized to measure and quantify the volumetric flow rate from each stack measurement location. A stainless steel type-S pitot tube was interconnected to an inclined oil manometer (differential pressure gauge) with an effective inclined range of 0-1 inch (0.01 resolution) and a vertical range of 1-10 inches (0.1 resolution).

Differential pressure measurements were taken at the selected traverse point locations (according to RM1) utilizing this instrument configuration. In addition, simultaneous effluent gas temperature were measured and recorded with the pressure measurements. The temperature was measured with a type-K thermocouple attached at the measurement tip of the pitot tube (in the same measurement plane). The Type-K thermocouple was interconnected to a calibrated digital temperature indicator providing accurate real time temperature measurements.

5.3 Molecular Weight Determination

EPA Reference Method 3, "Gas analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight," was provided for this measurement for each test series at the four unit stack outlets. Integrated gas samples were collected into clean, dry Tedlar bags from a stainless steel probe and a squeeze bulb. The integrated sample(s) were collected during each test series and subjected to analysis after the completion of each test.

The analysis was provided by the use of a Hays Republic Orsat Analyzer. The "orsat" is designed to measure carbon dioxide and oxygen concentrations of collected samples. Carbon monoxide analysis was not provided from this method as it was estimated the concentrations were well below the acceptable measurement limits of the analyzer (0.5%).

5.4 Percent Moisture Determination

EPA Reference Method 4 "Determination of Moisture Content in Stack Gases," was utilized and incorporated into the particulate sample system. The moisture determination procedure, as a "stand alone" procedure, utilizes a condenser assembly (glass bottle impingers partially immersed in an ice bath), interconnected in between a heated extraction probe and extraction pump.

The condenser assembly is comprised of four glass bottle impingers set in an ice bath. The first two interconnected impingers that come into contact with the extracted effluent stream contain a measured amount (volume) of deionized water. The third bottle is left empty to "catch" any potential condensate carryover, and the fourth impinger contains a pre-weighed amount of silica gel to act as the "absolute" collector of residual condensate and to protect the extraction pump from heavily saturated streams.

A known volume of stack gas (measured by a metering system connected to the extraction pump) is passed through a heated probe (to eliminate possible condensation) and directed to the condenser assembly over a selected time period. After the extraction has been completed, the amount of liquid (condensate) in the first three impingers is measured volumetrically and the net gain is determined. The fourth impinger net gain is determined gravimetrically. The total condensate gain of the condenser assembly is determined and incorporated with the calculated volume of gas that was directed through the system. The subsequent moisture content is determined from these collected variables.

5.5 Particulate Determination

EPA Reference Method 5 "Determination of Particulate Emissions from Stationary Sources," was performed to determine actual particulate emission rates of each unit effluent. This method required the isokinetic extraction of particulate matter from each stack. The extracted particulate was collected on a

glass fiber filter maintained at a controlled temperature range of 248 +/-25 degrees Fahrenheit. The condensible particulate fraction was collected in the back half of the sample train (unheated). The total particulate mass, which included the noncondensable (at or above the filtration temperature) and condensible fractions. The total mass was determined gravimetrically, after the removal of uncombined water.

A Nutech sampling system that incorporated a calibrated stainless steel nozzle, heated stainless steel probe, heated oven (housing the filter holder and substrate), a condenser assembly (as detailed in RM 4), and a calibrated extraction system was utilized for RM 5 sampling. The system is designed to operate under a vacuum for sample collection through all the leak free components of the sample system. The entire system was "leak checked" before and after each individual test to verify the integrity of all the components throughout the sample period.

An initial extraction (sampling) rate was determined for the stack conditions based upon preliminary measurements of temperature, flow rate, pressure, and estimated moisture collected prior to the sampling program. The sampling rate was calculated from these variables to assist in providing and maintaining isokinetic sampling throughout the entire test period. At isokinetic conditions, the velocity of the stack gas entering the nozzle, of the extraction system, is equal to the effluent velocity at the sample point. The extraction system is designed to provide for a proper manual adjustment of the sample rate when a change in any of the designated variables that would affect isokinetically have occurred. TRC incorporated the use of programmable hand-held HP-41CV calculators to provide immediate feedback on parameter changes and subsequent flow rate adjustments required to maintain isokinetic sampling.

The individual stack flow rates and the selection of the proper sample nozzle dictated the required sample time. Sampling was provided at equal time intervals along the selected traverse points as determined by RM1. Based upon the sample location, a minimum of six (6) or twelve (12) points on each traverse were utilized. The test(s) were conducted for a minimum of 60 minutes.

After the completion of each individual test, the particulate sample was carefully recovered. The collected sample was comprised of the particulate that had been deposited inside the extraction nozzle, heated probe, and filter holder, as well as the particulate collected on the filter substrate (designated as the front half). In addition to the front half collection, the condensible fraction, collected in the impinger train was retained to determine total particulate collection.

For particulate sample recovery, the filter was removed from its respective sample holder (after sufficient time had been provided to allow the glass filter holder to cool) with tweezers, and placed in a labeled petri dish, and sealed accordingly. The front half was washed with distilled water and the washing collected in a glass jar. A probe brush was utilized to assist in removing particulate which adhered to the inner walls of the front half components. The condensate, collected in the back-half impinger train, was measured volumetrically then transferred to sample bottles for transport to the laboratory.

Filters from the individual test runs were removed from their respective containers and placed in a desiccating chamber for a minimum of twenty-four hours for conditioning. After the conditioning criteria had been met, the filters were subjected to repeated weighing until a constant weight achieved. A constant weight is determined by the difference of two consecutive weighing not deviating more than ± 0.5 milligrams.

The front-half and back-half washing were separately and quantitatively transferred to conditioned (desiccated) and tared glass beakers. The final volumes of the collected washing were recorded in the laboratory notebook. The beakers were placed under a controlled laboratory fume hood and evaporated to dryness. The beakers were then returned to the desiccator for final conditioning before weighing to a constant weight. A "blank sample" retained from the distilled water lot utilized in the field was subjected to the same recovery procedure as the samples. Any residual weight gain from the water blank was applied to each sample gain to derive the final net particulate gain for the front half.

The two net gains (front-half and back-half) were totaled and the particulate concentration calculated based upon the field test data collected and calculated laboratory data. For purposes of comparison, the front-half (non-condensable) and back-half (condensable) fractions were reported separately and in total.

6.0 INSTRUMENTATION AND EQUIPMENT

Key to the completion of required Reference Method and equivalent test procedures in the field was the equipment and instrumentation utilized in the field. The instrumentation specific for each selected method, was integrated into the sample program to provide quality assured and representative information on the specific source components, namely flow rate, moisture, and pollutant concentrations.

The following provides a brief description of the key components utilized in the selected method test procedures for this emission evaluation program. All instrumentation, equipment, and calibration procedures provided for this field effort conformed to the minimum requirements, as established in the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III, Stationary Source Specific Methods, where applicable.

6.1 Flow Rate Measurements

6.1.1 Type-S pitot. The pitot tube is constructed of 316 stainless steel tubing with an outside diameter of 3/8 inch. The pitot tubes utilized in this measurement program are supplied by NuTech Corporation. The tubes are configured and calibrated according to the requirements provided in 40CFR60 Appendix A RM 2 section 4.0 (alignment procedures).

6.1.2 Differential pressure gauge. The manometer utilized for velocity measurements is a ten (10) inch inclined manometer. The manometer, manufactured by Dwyer, and incorporated into the extraction control console, has an incline range of 0, to 1.00 inch and a vertical range of 2.0 to 10.0 inches of water. The manometer utilized 0.826 red gauge oil and is calibrated for direct reading in inches of water.

6.1.3 Temperature sensor. The temperature of the gas stream is measured with a Type-K (Chromel/Alumel) thermocouple. The Type-K thermocouple is attached to the pitot tube and is interconnected to a digital compensator/indicator. The indicator has a dynamic operating range of 0-1999 degrees fahrenheit with a +/- 5 degree accuracy and one degree resolution. The temperature indicator is also integrated into the extraction control console.

6.1.4 Orsat. Gas samples are analyzed using a Hays Orsat model 621-A analyzer. The orsat allows for sampled gas to be passed through a series of absorbing reagents that have a specificity for carbon dioxide and oxygen. The collected sample is first passed through the Cardiosorber to determine volume of carbon dioxide, then the residue is passed through SEEZO2 to determine oxygen concentration. The system has an operational range of 0 to 25% with a buret (volumetric reading) accuracy of +/- 0.2%.

6.1.5 Collection Bags. Gas samples are collected in NuTech model 219 Tedlar (PVF) bags having a nominal capacity of four liters. The bags are non-reactive and have a low permeability. A leak tight stainless Roberts valve is provided on each bag to assist in filling and depleting sample from the bag.

6.2 Particulate Sampling

6.2.1 Control console. The sample gas is extracted utilizing a NuTech modular 2010 Isokinetic control console. The console houses the extraction pump (Gast fiber vane pump), manometer (Dwyer incline), temperature indicators (Datel Systems), dry gas meter (Rockwell), and solid state temperature controllers (NuTech).

6.2.2 Probe. The extraction probe is constructed of 3/8" O.D. stainless steel liner heat traced with 22 gauge coated nichrome wire and protected by a 316 stainless sheath. The inner glass liner is held in the outer sheath by a 5/8" stainless steel Swagelok union with Teflon ferrules.

6.2.3 Filter Holder. A glass filter holder assembly of "double bell" configuration is used in this sampling scheme. The glass fiber filter (110 mm) is supported on a stainless steel frit and then is sandwiched together by the inlet and outlet halves of the glass holder. The system (halves and frit) are held together by a screw-type retainer ring that, when tightened, pulls each filter half against the gasket material on the outer edge of the support frit to provide a leak tight joint.

6.2.4 Filter Holder Oven. Associated with the control console is a NuTech model 202-700 modular sample case that provides an insulated filter box (oven) for operation and maintenance of the filter holder assembly at an elevated temperature. Solid state heaters and controls, for the system, is provided on the control console.

6.2.5 Condensate trap. A impinger train, to remove moisture from the extracted gas stream and to collect the condensible fraction of the gas stream, is comprised of a set of four (4) glass impinger bottles and inserts interconnected to the filter holder and the extraction pump (control console). The impingers are interconnected by a glass "U" tube and maintained in a leak free configuration by the use of ground glass 28/15 ball and socket joints. The impingers are partially immersed in an ice bath to assist in condensing water vapor in the extracted gas stream.

7.0 QUALITY ASSURANCE

The TRC Quality Assurance Program is designed to ensure that emission measurement work is performed by qualified persons using proper equipment and following written procedures, in order to provide accurate, defensible data. The program is based upon the EPA Quality Assurance Handbook for Air Pollution Measurement Systems, Volumes I and III.

Methods 2, 3, 4, and 5 quality control specifications for sampling and analysis were performed as described in 40 CFR 60, Appendix A, June 1986. In the field, sampling was performed to assure data precision. Data was recorded on standard forms, and field notebooks were utilized to record observations, pertinent information, and calculations.

In the laboratory, analysts recorded calibration and analysis data in notebooks and summarized specific data on prepared data sheets. Resultant data sheets and calculations were reviewed by the Project Manager. Other quality control aspects of the Reference Method Tests are as follows:

- *Instrumentation is uniquely identified and the history of each unit's calibration and/or maintenance is recorded and maintained in an instrument history file.*
- *Control units (Dry gas meters) are calibrated before and after each field effort and documented in project files.*
- *Temperature measurement instrumentation is calibrated and verified for proper operation prior to each field mobilization.*
- *Field and reagent blanks are collected to determine the integrity of the sample media.*

In addition to the quality assurance procedures dictated by TRC policy, periodic blind weighings are performed as well as verification of gravimetric balance accuracy utilizing certified Class-S weights. All laboratory data sheets and support documentation for the analysis of the collected field samples and audit samples are located in Appendix B of this report.

APPENDIX A
CALCULATION SUMMARIES

DATA REDUCTION AND CALCULATIONS

DATA REDUCTION REQUIREMENTS REQUIRED TO SUPPORT THIS TEST PROGRAM IS PROVIDED IN THE FOLLOWING APPENDIX. FOR THE MOST PART, ALL CALCULATIONS AND DATA REDUCTION PROCEDURES FOLLOW THAT PROVIDED IN 40 CFR 60 APPENDIX A FOR THE SPECIFIC REFERENCE METHODS. ALL GASEOUS PARAMETERS ARE REPORTED IN TERMS OF CONCENTRATION (PPM) AND CALCULATED IN UNIT OF EMISSIONS FOR COMPARISON TO APPLICABLE STANDARDS (LBS/HR, LBS/MMBTU, ETC). PARTICULATE EMISSIONS WERE REDUCED AND REPORTED IN TERMS OF THE GRAINS PER DRY STANDARD CUBIC FOOT (GR/DSCF) AND POUNDS PER HOUR. WHERE APPLICABLE, PARTICULATE EMISSIONS RELATED TO PROCESS PRODUCTION RATES TO PROVIDE REPORTED EMISSIONS IN POUNDS OF POLLUTANTS PER PROCESS WEIGHT (I.E. LBS OF POLLUTANT PER TON OF PROCESSED MATERIAL).

INCLUDED WITH EACH CALCULATIONAL SCHEME IS A BRIEF DEFINITION OF TERMS AND GENERAL NOMENCLATURE UTILIZED IN THE DATA REDUCTION PROCESS. SELECTED METHODS ALLOW FOR OVERLAP OR CONCURRENT EVALUATION (I.E. RM 4 CONDUCTED DURING RM 5 SAMPLING) THEREFORE CALCULATIONS FOR SPECIFIC PARAMETERS (I.E. MOISTURE, STANDARD VOLUME) MAY BE FOUND UNDER MULTIPLE METHODS .

EPA REFERENCE METHOD 2 - FLOW RATE DETERMINATION

THE AVERAGE GAS VELOCITY IN A STACK IS DETERMINED FROM THE GAS DENSITY AND FROM MEASUREMENT OF THE AVERAGE VELOCITY HEAD WITH A TYPE-S (STAUSSCHEIBE) PITOT TUBE.

NOMENCLATURE

A	-	CROSS SECTIONAL AREA OF STACK OR DUCT, FT ²
C _P	-	PITOT TUBE COEFFICIENT, DIMENSIONLESS
MW (DRY)	-	MOLECULAR WEIGHT OF GAS, DRY BASIS, LB/LB-MOLE
MW (WET)	-	MOLECULAR WEIGHT OF GAS, MOISTURE CORRECTED, LB/LB-MOLE
P _B	-	UNCORRECTED BAROMETRIC PRESSURE AT SITE, INCHES H _G
P _G	-	STATIC PRESSURE OF GAS, INCHES H ₂ O
P _S	-	ABSOLUTE PRESSURE OF GAS, INCHES H _G
ACFM	-	EFFLUENT FLOW IN ACTUAL CUBIC FEET PER MINUTE
SCFM	-	EFFLUENT FLOW IN STANDARD CUBIC FEET PER MINUTE
T _S	-	ABSOLUTE AVERAGE GAS TEMPERATURE, °R
VPS	-	AVERAGE GAS VELOCITY IN FEET PER SECOND
W _P	-	VELOCITY HEAD OF GAS, INCHES H ₂ O
% CO ₂	-	PERCENT CARBON DIOXIDE BY VOLUME, DRY BASIS
% O ₂	-	PERCENT OXYGEN BY VOLUME, DRY BASIS
% H ₂ O	-	DETERMINED PERCENT MOISTURE OF EFFLUENT SAMPLED

CALCULATIONS

STACK PRESSURE

$$\text{"Hg} \times (P_S) = P_B + \frac{P_S}{13.6}$$

MOL. WEIGHT (DRY)

$$(MW \text{ DRY}) = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (100 - \%CO - \%O_2)$$

MOL. WEIGHT (WET)

$$(MW \text{ WET}) = MW \text{ (DRY)} \times \left(\frac{1 - \%H_2O}{100} \right) + 18 \left(\frac{\%H_2O}{100} \right)$$

VELOCITY (VPS)

$$(VPS) = 85.49 \times (C_P) \times (W_{P \text{ AVE}})^{1/2} \times \left[\frac{T_S}{(P_S)(MW \text{ WET})} \right]^{1/2}$$

FLOW RATE (ACFM)

$$(ACFM) = (VPS) \times (A) \times 60$$

FLOW RATE (SCFM)

$$(SCFM) = 60 \times (17.64) \times \frac{(100 - \%H_2O)}{100} \times \left[\frac{P_S}{T_S} \right] \times (VPS)$$

EPA REFERENCE METHOD 4 - MOISTURE DETERMINATION

A GAS SAMPLE IS EXTRACTED FROM THE SOURCE AND MOISTURE IS REMOVED FROM THE SAMPLE STREAM AND DETERMINED EITHER VOLUMETRICALLY OR GRAVIMETRICALLY.

NOMENCLATURE

B_{WO}	-	WATER VAPOR IN GAS STREAM, PROPORTION BY VOLUME
P_B	-	UNCORRECTED BAROMETRIC PRESSURE AT TESTING SITE, INCHES H_G
T_M	-	ABSOLUTE AVERAGE DRY GAS METER TEMPERATURE, $^{\circ}R$
V_M	-	VOLUME OF GAS SAMPLED AS MEASURED BY DRY GAS METER, DCF
V_{MSTD}	-	VOLUME OF GAS SAMPLED CORRECTED TO STANDARD CONDITIONS, DSCF
V_{H_2O}	-	VOLUME OF WATER COLLECTED IN CONDENSER SYSTEM (ML)
V_{SG}	-	NET GAIN OF WEIGHT OF SILICA GEL IN CONDENSER SYSTEM (G)
V_W	-	VOLUME OF WATER VAPOR
Y	-	DRY GAS METER CALIBRATION FACTOR, DIMENSIONLESS
ΔH	-	AVERAGE PRESSURE DIFFERENTIAL, INCHES H_2O

CALCULATIONS

VOLUME OF H_2O VAPOR

$$(V_W) = 0.04707 (V_{H_2O}) + 0.04715 (V_{SG})$$

FRACTION WATER VAPOR

$$(B_{WO}) = \left[\frac{V_M}{(V_W) + (V_{MSTD})} \right]$$

% MOISTURE

$$\% H_2O = B_{WO} \times 100$$

EPA REFERENCE METHOD 5 - PARTICULATE EMISSIONS

PARTICULATE MATTER IS EXTRACTED ISOKINETICALLY FROM A SOURCE AND COLLECTED ON A HEATED GLASS FIBER FILTER. THE PARTICULATE MASS IS DETERMINED GRAVIMETRICALLY AFTER REMOVAL OF UNCOMBINED WATER. THIS METHOD IS APPLICABLE FOR DETERMINING PARTICULATE EMISSIONS FROM STATIONARY SOURCES.

NOMENCLATURE

V_M	-	TOTAL METER SAMPLE VOLUME
T	-	TOTAL SAMPLE TIME
Y_D	-	DRY GAS METER CALIBRATION FACTOR
T_{STD}	-	STANDARD TEMPERATURE (F)
T_M	-	AVERAGE DRY METER TEMPERATURE
P_B	-	BAROMETRIC PRESSURE (UNCORRECTED)
dH	-	AVERAGE ORIFICE PRESSURE DROP ("H ₂ O)
P_{STD}	-	STANDARD PRESSURE ("Hg)
V_I	-	VOLUME OF CONDENSATE COLLECTED
V_{SG}	-	VOLUME COLLECTED IN SILICA GEL (NET GAIN)
M_D	-	MOLECULAR WEIGHT OF GAS (DRY)
%CO ₂	-	PERCENT CARBON DIOXIDE
%O ₂	-	PERCENT OXYGEN
%CO	-	PERCENT CARBON MONOXIDE
%N ₂	-	PERCENT NITROGEN
P_S	-	AVERAGE DUCT STATIC PRESSURE ("H ₂ O)
T_S	-	AVERAGE DUCT TEMPERATURE (F)
V_S	-	AVERAGE DUCT VELOCITY (FT/MIN)
C_P	-	PITOT TUBE COEFFICIENT
A_S	-	CROSS SECTIONAL AREA OF DUCT
Q	-	VOLUMETRIC FLOW RATE (ACFM)
Q_{STD}	-	VOLUMETRIC FLOW RATE (DSCFM)
D_N	-	DIAMETER OF EXTRACTIVE NOZZLE
C_S	-	ACTUAL PARTICULATE CONCENTRATION (GRAINS/ACF)
ER	-	PARTICULATE EMISSION RATE (LBS/HR)
M_N	-	TOTAL PARTICULATE COLLECTED (MG)

CALCULATIONS

STACK GAS FLOW (STANDARD)

$$Q_S = \frac{1058.8 (V_S) A_S (M_D) P_S}{(T_S + 460)}$$

PERCENT ISOKINETIC

$$\%I = \frac{(T_S + 460) [0.002668 V_W + (V_{MS} / 17.64)]}{60 (T) V_S (P_S) A_N} \times 100$$

DRY PARTICULATE EMISSIONS

GRAINS PER DRY STANDARD CUBIC FOOT

$$GR/DSCF = C(PART) \times (0.0154) / V_{MSTD}$$

POUNDS PER HOUR

$$LB/HR = [(GR/DSCF) \times DSCFM \times 60] / 7000$$

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-09-90
TIME OF TEST	1410-1513
TEST AND RUN NUMBER	4SE10-2
SAMPLE LOCATION	CALCINER KILN SCRUBBER EXHAUST
REMARKS	Final Results

METER VOLUME	45.350	CUBIC FEET
METER Y FACTOR	1.013	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	270.20	MILLIGRAMS
DUCT AREA	63.6200	SQUARE FEET
NOZZLE DIAMETER	0.3700	INCHES
SQR ROOT OF AVG VEL DP	0.4159	
AVG ORIFICE DELTA H	1.995	INCHES H2O
METER TEMPERATURE	70.79	DEGREES F
STACK TEMPERATURE	155.42	DEGREES F
BAROMETRIC PRESSURE	24.05	INCHES HG
STACK PRESSURE	0.13	INCHES H2O NEGATIVE
WATER COLLECTED	426.20	GRAMS OR ML
PITOT COEFFICIENT	0.84	
FUEL CONVERSION FACTOR	0.0	DSCF/MMBTU
OXYGEN	10.40%	
CARBON DIOXIDE	8.00%	
NITROGEN	81.60%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	36.935	DSCF
	1.0409	DSCM
SAMPLE FLOW RATE EQUALS	0.6156	DSCFM
	1.3801	ACFM AT NOZZLE
	0.0173	DSCMM
STACK GAS MOLECULAR WEIGHT	25.57	
PERCENT MOISTURE	35.26%	
PERCENT ISOKINETIC	103.09%	
AVERAGE STACK GAS VELOCITY	29.88	FEET/SEC
STACK GAS FLOW RATE	114067.4	ACFM
	50886.1	DSCFM
PARTICULATE MASS CONCENTRATION	0.1129	GRAINS/DSCF
	0.0503	GRAINS/ACF (STACK)
	0.2596	GRAMS/DSCM
	0.1158	GRAMS/ACM
PARTICULATE MASS EMISSION	49.2253	LBS/HOUR
	161.26E-07	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

**** INPUT DATA ****

CLIENT	RHONE-POLUENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-09-90
TIME OF TEST	1601-1705
TEST AND RUN NUMBER	4SE10-3
SAMPLE LOCATION	CALCINER KILN SCRUBBER EXHAUST
REMARKS	Final Results

METER VOLUME	38.217	CUBIC FEET
METER Y FACTOR	1.013	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	303.60	MILLIGRAMS
DUCT AREA	63.6200	SQUARE FEET
NOZZLE DIAMETER	0.3700	INCHES
SQR ROOT OF AVG VEL DP	0.3640	
AVG ORIFICE DELTA H	1.278	INCHES H2O
METER TEMPERATURE	76.60	DEGREES F
STACK TEMPERATURE	155.67	DEGREES F
BAROMETRIC PRESSURE	24.05	INCHES HG
STACK PRESSURE	0.09	INCHES H2O NEGATIVE
WATER COLLECTED	369.20	GRAMS OR ML
PITOT COEFFICIENT	0.84	
FUEL CONVERSION FACTOR	0.0	DSCF/MMBTU
OXYGEN	9.80%	
CARBON DIOXIDE	7.40%	
NITROGEN	82.80%	

**** RESULTS ****

SAMPLE VOLUME EQUALS	30.721	DSCF
	0.8658	DSCM
SAMPLE FLOW RATE EQUALS	0.5120	DSCFM
	1.1651	ACFM AT NOZZLE
	0.0144	DSCMM
STACK GAS MOLECULAR WEIGHT	25.39	
PERCENT MOISTURE	36.19%	
PERCENT ISOKINETIC	99.06%	
AVERAGE STACK GAS VELOCITY	26.25	FEET/SEC
STACK GAS FLOW RATE	100211.6	ACFM
	44048.3	DSCFM
PARTICULATE MASS CONCENTRATION	0.1525	GRAINS/DSCF
	0.0670	GRAINS/ACF (STACK)
	0.3506	GRAMS/DSCM
	0.1541	GRAMS/ACM
PARTICULATE MASS EMISSION	57.5613	LBS/HOUR
	217.84E-07	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

**** INPUT DATA ****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-09-90
TIME OF TEST	1734-1838
TEST AND RUN NUMBER	4SE10-4
SAMPLE LOCATION	CALCINER KILN SCRUBBER EXHAUST
REMARKS	Final Results

METER VOLUME	34.282	CUBIC FEET
METER Y FACTOR	1.013	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	277.50	MILLIGRAMS
DUCT AREA	63.6200	SQUARE FEET
NOZZLE DIAMETER	0.3700	INCHES
SQR ROOT OF AVG VEL DP	0.3208	
AVG ORIFICE DELTA H	0.987	INCHES H2O
METER TEMPERATURE	77.44	DEGREES F
STACK TEMPERATURE	155.75	DEGREES F
BAROMETRIC PRESSURE	24.07	INCHES HG
STACK PRESSURE	0.11	INCHES H2O NEGATIVE
WATER COLLECTED	303.20	GRAMS OR ML
PITOT COEFFICIENT	0.84	
FUEL CONVERSION FACTOR	12.0	DSCF/MMBTU
OXYGEN	10.20%	
CARBON DIOXIDE	7.40%	
NITROGEN	82.40%	

**** RESULTS ****

SAMPLE VOLUME EQUALS	27.513	DSCF
	0.7754	DSCM
SAMPLE FLOW RATE EQUALS	0.4586	DSCFM
	1.0114	ACFM AT NOZZLE
	0.0129	DSCMM
STACK GAS MOLECULAR WEIGHT	25.63	
PERCENT MOISTURE	34.22%	
PERCENT ISOKINETIC	98.07%	
AVERAGE STACK GAS VELOCITY	23.02	FEET/SEC
STACK GAS FLOW RATE	87876.8	ACFM
	39848.5	DSCFM
PARTICULATE MASS CONCENTRATION	0.1556	GRAINS/DSCF
	0.0706	GRAINS/ACF (STACK)
	0.3579	GRAMS/DSCM
	0.1623	GRAMS/ACM
PARTICULATE MASS EMISSION	53.1460	LBS/HOUR
	222.33E-07	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POLUENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	01-10-90
TIME OF TEST	1117-1221
TEST AND RUN NUMBER	4SE12A-1
SAMPLE LOCATION	DRIER KILN SCRUBBER EXHAUST
REMARKS	Final Data

METER VOLUME	39.745	CUBIC FEET
METER Y FACTOR	1.013	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	412.70	MILLIGRAMS
DUCT AREA	23.0438	SQUARE FEET
NOZZLE DIAMETER	0.2870	INCHES
SQR ROOT OF AVG VEL DP	0.6241	
AVG ORIFICE DELTA H	1.280	INCHES H2O
METER TEMPERATURE	84.79	DEGREES F
STACK TEMPERATURE	159.75	DEGREES F
BAROMETRIC PRESSURE	23.72	INCHES HG
STACK PRESSURE	0.15	INCHES H2O POSITIVE
WATER COLLECTED	436.20	GRAMS OR ML
PITOT COEFFICIENT	0.84	
FUEL CONVERSION FACTOR	0.0	DSCF/MMBTU
OXYGEN	12.00%	
CARBON DIOXIDE	6.20%	
NITROGEN	81.80%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	31.039	DSCF
	0.8748	DSCM
SAMPLE FLOW RATE EQUALS	0.5173	DSCFM
	1.2741	ACFM AT NOZZLE
	0.0146	DSCMM
STACK GAS MOLECULAR WEIGHT	24.90	
PERCENT MOISTURE	39.88%	
PERCENT ISOKINETIC	102.98%	
AVERAGE STACK GAS VELOCITY	45.90	FEET/SEC
STACK GAS FLOW RATE	63464.4	ACFM
	25772.4	DSCFM
PARTICULATE MASS CONCENTRATION	0.2052	GRAINS/DSCF
	0.0833	GRAINS/ACF (STACK)
	0.4718	GRAMS/DSCM
	0.1915	GRAMS/ACM
PARTICULATE MASS EMISSION	45.3124	LBS/HOUR
	293.08E-07	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-10-90
TIME OF TEST	1250-1352
TEST AND RUN NUMBER	4SE12A-2
SAMPLE LOCATION	DRIER KILN SCRUBBER EXHAUST
REMARKS	Final Results

METER VOLUME	39.025	CUBIC FEET
METER Y FACTOR	1.013	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	411.10	MILLIGRAMS
DUCT AREA	23.0438	SQUARE FEET
NOZZLE DIAMETER	0.2870	INCHES
SQR ROOT OF AVG VEL DP	0.6293	
AVG ORIFICE DELTA H	1.180	INCHES H2O
METER TEMPERATURE	86.75	DEGREES F
STACK TEMPERATURE	161.92	DEGREES F
BAROMETRIC PRESSURE	23.62	INCHES HG
STACK PRESSURE	0.15	INCHES H2O POSITIVE
WATER COLLECTED	459.00	GRAMS OR ML
PITOT COEFFICIENT	0.84	
FUEL CONVERSION FACTOR	0.0	DSCF/MMBTU
OXYGEN	11.80%	
CARBON DIOXIDE	6.00%	
NITROGEN	82.20%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	30.231	DSCF
	0.8520	DSCM
SAMPLE FLOW RATE EQUALS	0.5038	DSCFM
	1.2907	ACFM AT NOZZLE
	0.0142	DSCMM
STACK GAS MOLECULAR WEIGHT	24.66	
PERCENT MOISTURE	41.75%	
PERCENT ISOKINETIC	102.56%	
AVERAGE STACK GAS VELOCITY	46.69	FEET/SEC
STACK GAS FLOW RATE	64549.3	ACFM
	25203.3	DSCFM
PARTICULATE MASS CONCENTRATION	0.2098	GRAINS/DSCF
	0.0819	GRAINS/ACF (STACK)
	0.4825	GRAMS/DSCM
	0.1884	GRAMS/ACM
PARTICULATE MASS EMISSION	45.3204	LBS/HOUR
	299.76E-07	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-10-90
TIME OF TEST	1418-1521
TEST AND RUN NUMBER	4SE12A-3
SAMPLE LOCATION	DRIER KILN SCRUBBER EXHAUST
REMARKS	Final Results

METER VOLUME	38.592	CUBIC FEET
METER Y FACTOR	1.013	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	407.40	MILLIGRAMS
DUCT AREA	23.0438	SQUARE FEET
NOZZLE DIAMETER	0.2870	INCHES
SQR ROOT OF AVG VEL DP	0.6255	
AVG ORIFICE DELTA H	1.175	INCHES H2O
METER TEMPERATURE	92.71	DEGREES F
STACK TEMPERATURE	162.42	DEGREES F
BAROMETRIC PRESSURE	23.64	INCHES HG
STACK PRESSURE	0.15	INCHES H2O POSITIVE
WATER COLLECTED	455.10	GRAMS OR ML
PITOT COEFFICIENT	0.84	
FUEL CONVERSION FACTOR	0.0	DSCF/MMBTU
OXYGEN	12.00%	
CARBON DIOXIDE	6.00%	
NITROGEN	82.00%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	29.597	DSCF
	0.8342	DSCM
SAMPLE FLOW RATE EQUALS	0.4933	DSCFM
	1.2703	ACFM AT NOZZLE
	0.0139	DSCMM
STACK GAS MOLECULAR WEIGHT	24.63	
PERCENT MOISTURE	42.05%	
PERCENT ISOKINETIC	101.49%	
AVERAGE STACK GAS VELOCITY	46.43	FEET/SEC
STACK GAS FLOW RATE	64197.9	ACFM
	24934.7	DSCFM
PARTICULATE MASS CONCENTRATION	0.2124	GRAINS/DSCF
	0.0825	GRAINS/ACF (STACK)
	0.4884	GRAMS/DSCM
	0.1897	GRAMS/ACM
PARTICULATE MASS EMISSION	45.3847	LBS/HOUR
	303.41E-07	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-11-90
TIME OF TEST	0754-0858
TEST AND RUN NUMBER	5ES10-1
SAMPLE LOCATION	CALCINER KILN PRECIPITATOR
REMARKS	Final Results

METER VOLUME	39.741	CUBIC FEET
METER Y FACTOR	1.010	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	82.60	MILLIGRAMS
DUCT AREA	62.4900	SQUARE FEET
NOZZLE DIAMETER	0.2963	INCHES
SQR ROOT OF AVG VEL DP	0.6163	
AVG ORIFICE DELTA H	1.265	INCHES H2O
METER TEMPERATURE	47.42	DEGREES F
STACK TEMPERATURE	389.46	DEGREES F
BAROMETRIC PRESSURE	23.54	INCHES HG
STACK PRESSURE	0.22	INCHES H2O NEGATIVE
WATER COLLECTED	259.50	GRAMS OR ML
PITOT COEFFICIENT	0.84	
OXYGEN	8.80%	
CARBON DIOXIDE	9.80%	
NITROGEN	81.40%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	32.961	DSCF
	0.9289	DSCM
SAMPLE FLOW RATE EQUALS	0.5493	DSCFM
	1.5427	ACFM AT NOZZLE
	0.0155	DSCMM
STACK GAS MOLECULAR WEIGHT	26.69	
PERCENT MOISTURE	27.09%	
PERCENT ISOKINETIC	104.31%	
AVERAGE STACK GAS VELOCITY	51.48	FEET/SEC
STACK GAS FLOW RATE	193013.4	ACFM
	68741.9	DSCFM
PARTICULATE MASS CONCENTRATION	0.0387	GRAINS/DSCF
	0.0138	GRAINS/ACF (STACK)
	0.0889	GRAMS/DSCM
	0.0317	GRAMS/ACM
PARTICULATE MASS EMISSION	22.7795	LBS/HOUR
	552.40E-08	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-11-90
TIME OF TEST	0936-1034
TEST AND RUN NUMBER	5ES10-2
SAMPLE LOCATION	CALCINER KILN PRECIPITATOR
REMARKS	Final Results

METER VOLUME	37.341	CUBIC FEET
METER Y FACTOR	1.010	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	63.00	MILLIGRAMS
DUCT AREA	62.4900	SQUARE FEET
NOZZLE DIAMETER	0.2963	INCHES
SQR ROOT OF AVG VEL DP	0.6169	
AVG ORIFICE DELTA H	1.158	INCHES H2O
METER TEMPERATURE	54.10	DEGREES F
STACK TEMPERATURE	391.25	DEGREES F
BAROMETRIC PRESSURE	23.50	INCHES HG
STACK PRESSURE	0.22	INCHES H2O NEGATIVE
WATER COLLECTED	251.40	GRAMS OR ML
PITOT COEFFICIENT	0.84	
OXYGEN	9.80%	
CARBON DIOXIDE	9.20%	
NITROGEN	81.00%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	30.506	DSCF
	0.8598	DSCM
SAMPLE FLOW RATE EQUALS	0.5084	DSCFM
	1.4514	ACFM AT NOZZLE
	0.0143	DSCMM
STACK GAS MOLECULAR WEIGHT	26.54	
PERCENT MOISTURE	28.00%	
PERCENT ISOKINETIC	97.58%	
AVERAGE STACK GAS VELOCITY	51.77	FEET/SEC
STACK GAS FLOW RATE	194112.0	ACFM
	68009.1	DSCFM
PARTICULATE MASS CONCENTRATION	0.0319	GRAINS/DSCF
	0.0112	GRAINS/ACF (STACK)
	0.0733	GRAMS/DSCM
	0.0257	GRAMS/ACM
PARTICULATE MASS EMISSION	18.5722	LBS/HOUR
	455.23E-08	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-11-90
TIME OF TEST	1105-1208
TEST AND RUN NUMBER	5ES10-3
SAMPLE LOCATION	CALCINER KILN PRECIPITATOR
REMARKS	Final Results

METER VOLUME	38.831	CUBIC FEET
METER Y FACTOR	1.010	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	77.90	MILLIGRAMS
DUCT AREA	62.4900	SQUARE FEET
NOZZLE DIAMETER	0.2963	INCHES
SQR ROOT OF AVG VEL DP	0.6237	
AVG ORIFICE DELTA H	1.210	INCHES H2O
METER TEMPERATURE	68.85	DEGREES F
STACK TEMPERATURE	394.29	DEGREES F
BAROMETRIC PRESSURE	23.47	INCHES HG
STACK PRESSURE	0.22	INCHES H2O NEGATIVE
WATER COLLECTED	241.20	GRAMS OR ML
PITOT COEFFICIENT	0.84	
OXYGEN	9.20%	
CARBON DIOXIDE	9.40%	
NITROGEN	81.40%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	30.804	DSCF
	0.8682	DSCM
SAMPLE FLOW RATE EQUALS	0.5134	DSCFM
	1.4522	ACFM AT NOZZLE
	0.0145	DSCMM
STACK GAS MOLECULAR WEIGHT	26.67	
PERCENT MOISTURE	26.99%	
PERCENT ISOKINETIC	96.56%	
AVERAGE STACK GAS VELOCITY	52.34	FEET/SEC
STACK GAS FLOW RATE	196259.2	ACFM
	69398.3	DSCFM
PARTICULATE MASS CONCENTRATION	0.0390	GRAINS/DSCF
	0.0138	GRAINS/ACF (STACK)
	0.0897	GRAMS/DSCM
	0.0317	GRAMS/ACM
PARTICULATE MASS EMISSION	23.2068	LBS/HOUR
	557.44E-08	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-12-90
TIME OF TEST	0716-0818
TEST AND RUN NUMBER	5ES12-1
SAMPLE LOCATION	DRIER KILN PRECIPITATOR
REMARKS	Final Results

METER VOLUME	42.496	CUBIC FEET
METER Y FACTOR	1.004	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	43.40	MILLIGRAMS
DUCT AREA	28.2743	SQUARE FEET
NOZZLE DIAMETER	0.3653	INCHES
SQR ROOT OF AVG VEL DP	0.4047	
AVG ORIFICE DELTA H	1.142	INCHES H2O
METER TEMPERATURE	59.17	DEGREES F
STACK TEMPERATURE	236.83	DEGREES F
BAROMETRIC PRESSURE	23.69	INCHES HG
STACK PRESSURE	0.11	INCHES H2O POSITIVE
WATER COLLECTED	271.00	GRAMS OR ML
PITOT COEFFICIENT	0.84	
OXYGEN	9.80%	
CARBON DIOXIDE	8.40%	
NITROGEN	81.80%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	34.478	DSCF
	0.9717	DSCM
SAMPLE FLOW RATE EQUALS	0.5746	DSCFM
	1.3135	ACFM AT NOZZLE
	0.0162	DSCMM
STACK GAS MOLECULAR WEIGHT	26.56	
PERCENT MOISTURE	27.06%	
PERCENT ISOKINETIC	98.36%	
AVERAGE STACK GAS VELOCITY	30.58	FEET/SEC
STACK GAS FLOW RATE	51875.4	ACFM
	22699.3	DSCFM
PARTICULATE MASS CONCENTRATION	0.0194	GRAINS/DSCF
	0.0085	GRAINS/ACF (STACK)
	0.0447	GRAMS/DSCM
	0.0195	GRAMS/ACM
PARTICULATE MASS EMISSION	3.7783	LBS/HOUR
	277.47E-08	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-12-90
TIME OF TEST	0904-1006
TEST AND RUN NUMBER	5ES12-2
SAMPLE LOCATION	DRIER KILN PRECIPITATOR
REMARKS	Final Results

METER VOLUME	57.179	CUBIC FEET
METER Y FACTOR	1.004	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	33.50	MILLIGRAMS
DUCT AREA	28.2743	SQUARE FEET
NOZZLE DIAMETER	0.3653	INCHES
SQR ROOT OF AVG VEL DP	0.5348	
AVG ORIFICE DELTA H	2.440	INCHES H2O
METER TEMPERATURE	73.00	DEGREES F
STACK TEMPERATURE	245.58	DEGREES F
BAROMETRIC PRESSURE	23.70	INCHES HG
STACK PRESSURE	0.11	INCHES H2O POSITIVE
WATER COLLECTED	366.30	GRAMS OR ML
PITOT COEFFICIENT	0.84	
OXYGEN	10.00%	
CARBON DIOXIDE	8.60%	
NITROGEN	81.40%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	45.388	DSCF
	1.2792	DSCM
SAMPLE FLOW RATE EQUALS	0.7565	DSCFM
	1.7627	ACFM AT NOZZLE
	0.0213	DSCMM
STACK GAS MOLECULAR WEIGHT	26.53	
PERCENT MOISTURE	27.58%	
PERCENT ISOKINETIC	99.23%	
AVERAGE STACK GAS VELOCITY	40.68	FEET/SEC
STACK GAS FLOW RATE	69008.9	ACFM
	29619.9	DSCFM
PARTICULATE MASS CONCENTRATION	0.0114	GRAINS/DSCF
	0.0049	GRAINS/ACF (STACK)
	0.0262	GRAMS/DSCM
	0.0112	GRAMS/ACM
PARTICULATE MASS EMISSION	2.8909	LBS/HOUR
	162.70E-08	LBS/DSCF

***** TRC METHOD 5/17 DATA REDUCTION *****

***** INPUT DATA *****

CLIENT	RHONE-POULENC
PLANT LOCATION	GREEN RIVER, WYOMING
DATE OF TEST	05-12-90
TIME OF TEST	1030-1132
TEST AND RUN NUMBER	5ES12-3
SAMPLE LOCATION	DRIER KILN PRECIPITATOR
REMARKS	Final Results

METER VOLUME	60.514	CUBIC FEET
METER Y FACTOR	1.004	
SAMPLE TIME	60.00	MINUTES
PARTICULATE MASS GAIN	56.60	MILLIGRAMS
DUCT AREA	28.2743	SQUARE FEET
NOZZLE DIAMETER	0.3653	INCHES
SQR ROOT OF AVG VEL DP	0.5560	
AVG ORIFICE DELTA H	2.681	INCHES H2O
METER TEMPERATURE	79.58	DEGREES F
STACK TEMPERATURE	245.42	DEGREES F
BAROMETRIC PRESSURE	23.71	INCHES HG
STACK PRESSURE	0.11	INCHES H2O POSITIVE
WATER COLLECTED	333.20	GRAMS OR ML
PITOT COEFFICIENT	0.84	
OXYGEN	10.00%	
CARBON DIOXIDE	8.60%	
NITROGEN	81.40%	

***** RESULTS *****

SAMPLE VOLUME EQUALS	47.504	DSCF
	1.3388	DSCM
SAMPLE FLOW RATE EQUALS	0.7917	DSCFM
	1.7772	ACFM AT NOZZLE
	0.0223	DSCMM
STACK GAS MOLECULAR WEIGHT	26.85	
PERCENT MOISTURE	24.87%	
PERCENT ISOKINETIC	96.84%	
AVERAGE STACK GAS VELOCITY	42.02	FEET/SEC
STACK GAS FLOW RATE	71293.2	ACFM
	31767.2	DSCFM
PARTICULATE MASS CONCENTRATION	0.0184	GRAINS/DSCF
	0.0082	GRAINS/ACF (STACK)
	0.0423	GRAMS/DSCM
	0.0188	GRAMS/ACM
PARTICULATE MASS EMISSION	5.0050	LBS/HOUR
	262.63E-08	LBS/DSCF

APPENDIX B
LABORATORY and QA/QC DATA

I.O.	RUN #	DATE	TARE	DATE	FINAL	DATE	FINAL
3000	Blank	05-02-90	0.5069	5-15	0.5069	5-16-90	0.5069
3001	4SC10-1		0.5069	5-15	0.5284		0.5283
3002	4SC10-2		0.5071	5-15	0.6943		0.6944
3003	4SC10-3		0.5034	5-15	0.6724		0.6724
3004	4SC10-4		0.5056	5-15	0.6892		0.6893
3005	4SC12A-1		0.5071	5-15	0.8845		0.8846
3006	4SC12A-2		0.5042	5-15	0.8743		0.8742
3007	4SC12A-3		0.5026	5-15	0.8841		0.8840
3008			0.5039				
3009	SES12-1		0.5022	5-15	0.5220	5-16-90	0.5220
3010	SES12-2		0.5055	5-15	0.5255		0.5255
3011	SES10-1		0.5047	5-15	0.5469		0.5470
3012	SES10-2		0.5066	5-15	0.5422		0.5421
3013	SES10-3		0.5105	5-15	0.5501		0.5500
3014	SES12-3		0.5066	16-15	0.5287		0.5287
3015			0.5081				
3016			0.5092				
3017			0.5132				
3018			0.5088				
3019			0.5121				
3020			0.5078				
3021			0.5091				
3022			0.5105				
3023			0.5085				
3024			0.5153				
3025		V	0.5095				
3026		05-12-90	0.5102				
3027							
3028							

Continued on Page

Continued on Page

Read and Understood By

Signed

Date _____

Signed

5-16-90

2

Continued From Page 2 of 2

Blank Convention

Continued on Page

Read and Understood By

5-16-90

DRY GAS METER CALIBRATION SHEET

DATE: 12-21-89
 DRY GAS METER IDENTIFICATION NwTech #2
 STANDARD METER IDENTIFICATION Rockwell 38979
 BAROMETRIC PRESSURE 24.57 in Hg
 LEAK TEST 0.001 CFM AT 19 INCHES OF VACUUM
 TECHNICIAN Hso

VOLUMES				TEMPERATURE				PRESSURE			TIME	FLOW RATE SCFM	STANDARD METRIC (%)	DRY GAS METRIC (%)	dH@
VOLUME OF STANDARD		VOLUME OF DRY GAS METER		STANDARD (F)	DRY GAS METER		STANDARD (F)	DOM dH "H2O							
INITIAL	FINAL	TOTAL	INITIAL		FINAL	TOTAL									
608.398	615.128	6.730	510.390	517.023	6.633	69	64	63	0.50	-0.07	15.0	0.367	1.006	1.008	1.709
615.128	621.880	6.752	517.023	523.701	6.678	70	70	67	0.50	-0.07	15.0	0.3702	1.006	1.013	1.688
621.880	628.612	6.732	523.701	530.444	6.743	71	75	70	0.50	-0.07	15.0	0.3684	1.006	1.010	1.692
629.415	635.653	6.228	531.221	537.460	6.239	69	78	74	1.00	-0.08	10.0	0.5132	1.006	1.014	1.738
635.653	641.831	6.178	537.460	543.683	6.223	69	80	76	1.00	-0.08	10.0	0.5091	1.006	1.012	1.760
641.831	648.034	6.203	543.683	549.943	6.260	68	82	78	1.00	-0.08	10.0	0.5124	1.006	1.016	1.732
648.034	654.263	6.229	550.634	556.858	6.224	70	85	79	2.00	-0.11	10.0	0.6944	1.006	1.012	1.890
654.263	660.497	6.234	556.858	563.070	6.212	70	87	81	2.00	-0.11	10.0	0.6936	1.006	1.014	1.886
660.497	666.725	6.228	563.070	569.221	6.151	70	87	82	2.00	-0.11	10.0	0.6931	1.006	1.015	1.887
666.725	672.958	6.233	569.221	575.473	6.252	70	90	84	3.00	-0.135	10.0	0.8608	1.006	1.014	1.838
672.958	679.191	6.233	575.473	581.716	6.243	70	92	84	3.00	-0.135	10.0	0.8583	1.006	1.012	1.845
679.191	685.424	6.233	581.716	587.944	6.228	70	92	85	3.00	-0.135	10.0	0.8569	1.006	1.011	1.850
AVERAGE										1.7930					



THERMOCOUPLE CALIBRATION
DATA SHEET

7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

Ambient Temperature $^{\circ}\text{R}$ 532 Barometric Pressure
Date 6/30/88 Calibrator RWB
Reference Thermometer No. 5-W Mercury - Glass
NES Calibration Points

TC No.	TC Temperature (°C)	Reference TC(a) Temperature (°C)	Reference Thermometer Temperature (a) (°C)	Difference (%) (b)
IN				
NUTCH #2	531	.	532	0.2
FF216028	515	.	516	0.2
	500	- - -	501	-0.2
Average				0.2

^aReference temperature at $\pm 10\%$ of expected temperature

^b Average Percent Difference $\leq 1.5\%$, Percent Difference = .

$$\frac{\text{Ref. Temp.} - \text{TC Temp.}}{\text{Ref. Temp.}} \times 100$$

Rev. 1.4/25/81



NUtech # 2
OUTlet
THERMOCOUPLE CALIBRATION
DATA SHEET

7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

Ambient Temperature $^{\circ}\text{R}$ 532 Barometric Pressure
Date 6/30/88 Calibrator R.W.B
Reference Thermometer No. S-W Mercury Glass
NES Calibration Points

TC No.	TC Temperature (°C)	Reference TC (a) Temperature (°C)	Reference Thermometer Temperature (a) (°C)	Difference (%)(b)
<u>OUT</u>				
Nutec 2 FR81002P	531		532	0.2
	527		529	0.4
	503		502	-0.2
Average				0.26

^aReference temperature at + 10% of expected temperature

^b Average Percent Difference $\leq 1.5\%$, Percent Difference = .

$$\frac{\text{Ref. Temp.} - \text{TC Temp.}}{\text{Ref. Temp.}} \times 100$$

Rev. 1.4/25/81

DRY GAS METER CALIBRATION SHEET

DATE 03-26-70
 DRY GAS METER IDENTIFICATION NuTech #3
 STANDARD METER IDENTIFICATION Rockwell 38979
 BAROMETRIC PRESSURE 24.64
 LEAK TEST 0.001 CFM AT 15 INCHES OF VACUUM
 TECHNICIAN D. Vick

VOLUMES				TEMPERATURE				PRESSURE				TIME MIN	FLOW RATE SCFM	STANDARD METER (%)	DRY GAS METER (%)	dH@
VOLUME OF STANDARD (%)		VOLUME OF DRY GAS METER (Ndp)		STANDARD (°F)	DRY GAS METER		STANDARD (°F)	DOM dH "H2O								
INITIAL	FINAL	INITIAL	FINAL	F	IN F	OUT F	AVE F	"H2O								
162.202	169.023	6.821	998.974	68	74	70	72.0	-0.075	0.50			16.0	0.3530	1.006	1.002	1.851
169.023	175.420	6.397	005.863	69	78	73	75.5	-0.075	0.50			15.0	0.3531	1.006	1.007	1.837
175.420	181.826	6.406	012.332	69	81	76	78.5	-0.075	0.50			15.0	0.3535	1.006	1.011	1.823
181.826	188.078	6.252	018.821													
188.078	194.059	5.981	025.129	69	84	78	81.0	-0.085	1.00			10.0	0.4933	1.006	1.016	1.869
194.059	200.046	5.987	031.174	69	86	79	82.5	-0.085	1.00			10.0	0.4942	1.006	1.017	1.857
200.046	206.046	6.000	037.217	70	89	81	84.0	-0.085	1.00			10.0	0.4938	1.006	1.020	1.855
206.046	212.277	6.231	043.464	69	80	77	78.5	-0.110	2.00			10.0	0.6247	1.006	1.017	1.861
212.277	218.277	6.000	050.464	71	77	76	76.5	-0.110	2.00			14.0	0.6207	1.006	1.011	1.934
218.277	225.024	6.747	062.202	72	83	77	80.0	-0.110	2.00			10.0	0.6206	1.006	1.011	1.979
225.024	233.308	8.284	070.518													
233.308	244.458	11.150	081.665	73	82	78	80.0	-0.135	3.00			10.0	0.8490	1.006	1.010	1.919
244.458	255.251	11.293	092.973	73	87	80	83.5	-0.135	3.00			11.0	0.8419	1.006	1.015	1.939
255.251	266.016	10.765	103.282	73	90	82	86.0	-0.135	3.00			10.0	0.8418	1.006	1.017	1.931
AVERAGE													1.028			
													1.8962			

TTC



7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 752-5555

Nutech #3
 THERMOCOUPLE CALIBRATION
 DATA SHEET
 # 6845716

Ambient Temperature $^{\circ}\text{R}$ 534 Barometric Pressure
Date 6/30/88 Calibrator RWB
Reference Thermometer No. 5-W Mercury in glass
NES Calibration Points

TC No.	TC Temperature (°C)	Reference TC (a) Temperature (°C)	Reference Thermometer Temperature (a) (°C)	Difference (%) (b)
NUTech 3 DGM IN	494	.	493	0.2
	502	:	501	0.2
	534	- - -	533	0.2
Average				0.20

^aReference temperature at $\pm 10\%$ of expected temperature

^b Average Percent Difference $\leq 1.5\%$, Percent Difference = .

$$\frac{\text{Ref. Temp.} - \text{TC Temp.}}{\text{Ref. Temp.}} \times 100$$

Rev. 1.4/15/61



7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

NOTCH #3
THERMOCOUPLE CALIBRATION
DATA SHEET
6845716

TC No.	TC Temperature (°C)	Reference TC (a) Temperature (°C)	Reference Thermometer Temperature (a) (°C)	Difference (%) (b)
NOTCH #3 DGM OUT	493		491	0.4
	501		500	0.2
	534		533	0.2
Average				0.26

^aReference temperature at $\pm 10\%$ of expected temperature

^b Average Percent Difference $\leq 1.5\%$, Percent Difference =

$$\frac{\text{Ref. Temp.} - \text{TC Temp.}}{\text{Ref. Temp.}} \times 100$$

Rev. 1.4/15/61

DRY GAS METER CALIBRATION SHEET

DATE 12-21-89
 DRY GAS METER IDENTIFICATION N-Tech 44
 STANDARD METER IDENTIFICATION Rockwell 38979
 BAROMETRIC PRESSURE 24.56 in Hg
 LEAK TEST 0.001 CFM AT 18 INCHES OF VACUUM
 TECHNICIAN DU / HSO

VOLUMES					TEMPERATURE				PRESSURE			TIME MIN	FLOW RATE SCFM	STANDARD METER (%)	DRY GAS METER (%)	dH ₂ O
VOLUME OF STANDARD (%)		VOLUME OF DRY GAS METER (%)			STANDARD (%)		DRY GAS METER		STANDARD (%)	dH ₂ O "H ₂ O	dH ₂ O "H ₂ O					
INITIAL	FINAL	INITIAL	FINAL	TOTAL	F	F	IN	OUT	AVE	F	F					
512.402	518.874	6.472	711.002	717.507	6.505	73	71	73.0	-0.07	0.50	0.3541	15.0	0.3541	1.006	1.001	1.833
518.874	525.360	6.486	717.507	724.034	6.527	73	74	76.0	-0.07	0.50	0.3535	15.0	0.3535	1.006	1.004	1.825
525.360	531.842	6.482	724.034	730.610	6.576	70	80	75	77.5	0.50	0.3553	15.0	0.3553	1.005	1.004	1.802
531.842	538.024	6.015	730.610	736.625	6.088	72	84	78	-0.08	1.00	0.4927	10.0	0.4927	1.006	1.007	1.868
538.024	544.054	6.030	736.625	742.690	6.138	72	87	81	-0.08	1.00	0.4939	10.0	0.4939	1.006	1.009	1.848
544.054	550.126	6.072	742.690	748.762	6.166	71	82	81	-0.08	1.00	0.4983	10.0	0.4983	1.006	1.007	1.824
550.126	557.135	8.399	748.762	757.161	8.499	71	85	82	-0.11	2.00	0.6892	10.0	0.6892	1.005	1.011	1.912
557.135	567.512	8.377	757.161	765.539	8.500	71	88	82	-0.11	2.00	0.6873	10.0	0.6873	1.006	1.011	1.916
567.512	575.837	8.361	765.539	773.900	8.498	73	90	83	-0.11	2.00	0.6835	10.0	0.6835	1.006	1.008	1.933
575.837	587.130	10.222	773.900	784.122	10.348	71	92	84	-0.13	3.00	0.8387	10.0	0.8387	1.005	1.016	1.932
587.130	597.380	10.250	784.122	794.372	10.403	71	94	86	-0.13	3.00	0.8410	10.0	0.8410	1.006	1.017	1.914
597.380	607.632	10.252	794.372	804.624	10.429	70	94	87	-0.13	3.00	0.8427	10.0	0.8427	1.006	1.018	1.904
AVERAGE															1.0095	1.876

TTC



7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

Nutech #4
THERMOCOUPLE CALIBRATION
DATA SHEET
6845717

Ambient Temperature $^{\circ}\text{R}$ 533 Barometric Pressure
Date 6/30/88 Calibrator R.W.B.
Reference Thermometer No. S-W Mercury - Glass
NES Calibration Points

TC No.	TC Temperature (°C)	Reference TC (a) Temperature (°C)	Reference Thermometer Temperature (a) (°C)	Difference (%) (b)
Note #7 <i>IN</i>	493	.	494	0.2
	502	.	503	0.2
	534	- - - -	535	- 0.2
Average				0.2

Reference temperature at $\pm 10\%$ of expected temperature

^b Average Percent Difference $\leq 1.5\%$, Percent Difference = .

$$\frac{\text{Ref. Temp.} - \text{TC Temp.}}{\text{Ref. Temp.}} \times 100$$



7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

Notech #4
 THERMOCOUPLE CALIBRATION
 DATA SHEET
 # 6845717

Ambient Temperature $^{\circ}\text{R}$ 533 Barometric Pressure
Date 6/30/88 Calibrator RWB
Reference Thermometer No. S-W Mercury - Glass
NES Calibration Points

TC No.	TC Temperature (°C)	Reference TC (a) Temperature (°C)	Reference Thermometer Temperature (a) (°C)	Difference (%)(b)
Nutech #4 out	493		494	0.2
	502		503	0.2
	534		535	0.2
Average				0.2

^aReference temperature at $\pm 10\%$ of expected temperature
$$^b \text{Average Percent Difference} \leq 1.5\%, \text{ Percent Difference} = \frac{\text{Ref. Temp.} - \text{TC Temp.}}{\text{Ref. Temp.}} \times 100$$


Rev. 1.4/15/81

PITOT TUBE CALIBRATION


PITOT TUBE ID : 9.0'

DATE : 2-28-90

TECHNICIAN : L. Rosberg



$\beta 1 = -0.1^\circ$ $\beta 2 = +1.0$



$Z = -0.2^\circ$



$W = 0.0$



PITOT COEFFICIENT (C_p) = 0.84

PROBE AND PITOT TUBE CALIBRATION

PROBE ID : 9.0'

DATE : 02-28-90


TECHNICIAN : _____



OR

$W = \underline{N/A}$ $Z = \underline{N/A}$

$Z = \underline{\hspace{2cm}}$



$Y = \underline{7.65}$



Environmental
Consultants, Inc.


7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

PROBE AND PITOT TUBE CALIBRATION


PROBE ID : 9.0'

DATE : 02-28-90

TECHNICIAN : J. Rosburg



$D_t = \underline{0.95}$ $x = \underline{2.28}$ $D_n = \underline{1.3}$



Configuration correct ? YES



7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

9: Probe

THERMOCOUPLE CALIBRATION DATA SHEET

Ambient Temperature $^{\circ}\text{C}$ 52.8 Barometric Pressure
Date 1/18/89 Calibrator RB
Reference Thermometer No. SW 80015 Oil Immersion
NES Calibration Points

[illegible]

Average

• 0.686

^aReference temperature at $\pm 10\%$ of expected temperature
$$\text{Average Percent Difference} < 1.5\%, \text{ Percent Difference} = \frac{\text{Ref. Temp.} - \text{IC Temp.}}{\text{Ref. Temp.}} \times 100$$

Rev. 1.4/15/81



Environmental
Consultants, Inc.


7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

PITOT TUBE CALIBRATION

PITOT TUBE ID: 6-2 Feet

DATE: 02-07-90

TECHNICIAN: OV



NOTE:


$$\begin{cases} 1.05 D_t < P < 1.50 D_t \\ P_A = P_B \end{cases}$$

$$0.48 \text{ CM} < D_t \leq 0.95 \text{ CM} \\ (3/16 \text{ IN.}) \quad (3/8 \text{ IN.})$$

$$D_t = \underline{3/8''}$$


$$P_A = \underline{0.5''}$$

$$P_B = \underline{0.5''}$$



$$1 = \underline{< 1^\circ}$$

$$2 = \underline{< 1^\circ}$$



$$1 = \underline{< 1^\circ}$$

$$1 = \underline{< 1^\circ}$$



Environmental
Consultants, Inc.


7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

PITOT TUBE CALIBRATION


PITOT TUBE ID : 0.2 Feet

DATE : 02-07-90


TECHNICIAN : D.V.



$\beta 1 =$ $< 1^\circ$ $\beta 2 =$ $< 1^\circ$



$Z =$ 0.0625"



$W =$ $< 1^\circ$


PITOT COEFFICIENT (C_p) = 0.84

PROBE AND PITOT TUBE CALIBRATION


PROBE ID : 6-2 Feet

DATE : 02-07-90

TECHNICIAN : D.V




OR



W = 4.0" Z = 1.0"

Z = NA



Y = 3.625



Environmental
Consultants, Inc.


7002 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

PITOT TUBE CALIBRATION

PITOT TUBE ID: 9.0'

DATE: 02-28-90

TECHNICIAN: J. Roshier



NOTE:


$$\left\{ \begin{array}{l} 1.05 D_t < P < 1.50 D_t \\ P_A = P_B \end{array} \right.$$

$$0.48 \text{ CM} < D_t < 0.95 \text{ CM} \\ (3/16 \text{ IN.}) < D_t < (3/8 \text{ IN.})$$

$$D_t = \underline{0.95}$$


$$P_A = \underline{1.25}$$

$$P_B = \underline{1.25}$$



$$\alpha_1 = \underline{-1.0^\circ}$$

$$\alpha_2 = \underline{0.0}$$



$$\beta_1 = \underline{-1.0}$$

$$\beta_1 = \underline{-0.20}$$



7022 South Revere Parkway
Suite 60
Englewood, CO 80112
(303) 792-5555

THERMOCOUPLE CALIBRATION DATA SHEET

Ambient Temperature $^{\circ}\text{C}$ 52.8 Barometric Pressure
Date 1/18/89 Calibrator RB
Reference Thermometer No. SW 80015 Oil immersion
NES Calibration Points

TC No.	TC Temperature (°C)	Reference TC (2) Temperature (°C)	Reference Thermometer Temperature (2) (°C)	Difference (%) (3)
6 FT New Prob.	528	.	529	0.189
.	586	.	589	0.509
...	599	- - -	604	0.828
.	648	.	653	0.766
..	694	.	699	0.715
. . .	730	.	736	0.8152
.	.	.	.	.
.	.	.	.	.
.	.	.	.	.
.	.	.	.	.
.	.	.	.	.
.	.	.	.	.
.	.	.	.	.
.	.	.	.	.
.	.	.	.	.
.	.	.	.	.
Average				0.637

Average

0.637

^aReference temperature at $\pm 10\%$ of expected temperature.

b Average Percent Difference $\leq 1.5\%$, Percent Difference =	Ref. Temp. - 10 Temp.	$\times 100$
	Ref. Temp.	

Rev. 1.4/15/61

APPENDIX C
PLANT and PROCESS DATA

RANTEC CORPORATION
P.O. Box 729
RANCHESTER, WYOMING 82839
(307) 655-9565

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY: _____ DATE _____

SCALE _____

STACK TEST

1) STATE ~~WITNESS~~ WITNESS

2) MAY 8th to 12th

3) TRC

4SC-10

4SC-12A

~~4SC-10~~

5ES-10

5ES-12

4) Operating Conditions included

Emissions Testing Control Room Data Sheet
 Test Date: 5-9-90
 Test Start Time: 4:50-10
 Approx. 2:10
 Test Finish Time: Approx. 3:00

Time	Ore Rate (TPH)	Gas Flow Rate (CFM)	Exhaust Temp (OF)	Prod Temp (OF)	Fan Speed (RPM)	4K-1 Draft ("H ₂ O)	Venturi Press. Drop (>32.5") (AP)	(RECIR.) Flow to Top Sprays (GPM)	(MAKE-UP) Flow to Toxigenic (GPM)	Equal Flow To Sprays (Yes/No)	Cyclones (OK or not)	Scrubber Level (%)	Recirc. H ₂ O Specific Gravity
2:10	128/1028	3775	360	285	4237	1.5	35	460	205	YES	OK	97	1.0x08
2:25	128/102	4114	360	289	4223	1.5	35	460	205	YES	OK	97	1.0x08
2:40	128/102	4465	357	290	4223	1.55	35	460	205	YES	OK	94	1.0x08
2:55	128/102	4808	356	295	4199	1.6	35	450	205	YES	OK	92	1.0x08
3:10	128/102	5262	362	295	4215	1.6	34	480	210	YES	OK	91	1.010

Comments: 1:00 PM 3:00 PM
 O₂ stayed at 9-10 through out test

VENTURI:

	E	W	E	W
TOP 1+2	6	8	6	8
TAKE 1+2	9	14	13	14
TAKE 3	12	13	14	14
TOP 3*	2.5	0	2	0

* MAKE UP WATER
 1:00 ALL OPEN
 Signed: John A. Hawley

Emissions Testing Control Room Data Sheet

Test Date 5-9-90

Test Start

5:50 PM

Time Apprx

1:00 PM

Test Finish

Time 4:10

Test 2

Time	Ore Rate (TPM)	Gas Flow Rate (CFM)	Exhaust Temp (OF)	Prod Temp (OF)	Fan Speed (RPM)	4K-1 Draft (H ₂ O)	Venturi Press. Drop (32.5") (AP)	Flow to Top Sprays (GPM)	Flow to Tangential Sprays (GPM)	Equal Flow to Sprays (Yes/No)	Cyclones (on/off)	Scrubber Level (75)	Recurr. H ₂ O Specific Gravity
4:05	128/102	6410	360	292	4224	1.6	34	460	205	Yes	Yes	92	1.068
4:15	128/102	6700	360	294	4216	1.7	35	460	210	Yes	Yes	92	
4:30	128/102	6973	359	291	4174	1.65	34	460	200	Yes	Yes	92	1.01
4:45	128/102	7321	358	286	4212	1.65	34	460	205	Yes	Yes	92	
5:00	128/102	7708	370	296	4243	1.6	34	460	205	Yes	Yes	92	1.01
5:15	128/102	8635	363	295	4228	1.75	35	460	205	Yes	Yes	92.5	

02 stayed between 9 & 10 through out test

VENTURI E W

TOP 1+2 6 8

RANG 1+2 14 15

RANG. 2 3 14 14

TOP 3* 2 0

* MAKE UP WATER 5:00 PM ALL OPEN

Signed

John L. Haskins

Test 3 Test Date 5-9-90 Test Start Time 5:35 Test Finish Time 6:45 Approved.

Emissions Testing Control Room Data Sheet

Time	Ore Rate (TPH)	Gas Flow Rate (CFM)	4K-1 Exhaust Temp (OF)	Prod Temp (OF)	Fan Speed (RPM)	4K-1 Draft ("H ₂ O")	Venturi Press Drop (>32.5") (AP)	Flow to Top (GPM)	Flow to Troughs (GPM)	Equal Flow To Sprays (Yes/No)	Cyclones (ok/not)	Scrubber Level (70)	Breac. H ₂ O Specific Gravity
5:45	128/102	8942	363	294	4221	1.55	34	460	205	Yes	Yes	93	1.016
6:00	128/102	9091	360	303	4182	1.65	34	460	205	Yes	Yes	93.5	
6:15	128/102	9426	362	298	4188	1.65	34	460	205	Yes	Yes	94	1.011
6:30	128/102	9787	362	293	4206	1.5	34	460	210	Yes	Yes	95	
6:45	128/102	0180	363	300	4173	1.6	34	460	210	Yes	Yes	98	1.011

Comments: 6:00 PM

PST

VENTURIS

TOP 1+2 6 8

TAN6. 1+2 14 15

TAN6. 3 13 14

TOP 3* 2 0

* MAKE UP WATER

6:00 PM ALL OPEN

Signed: M. A. Hanks

Emissions Testing Control Room Data Sheet

Test Date 5-9-90 Test Start Time 9:20 AM Test Finish Time

Time	Ore Rate (TPH)	Gas Flow Rate (CFM)	Exhaust Temp (OF)	Prod Temp (OF)	Fan Speed (RPM)	4K-1 Draft (H ₂ O)	Venturi Press Dng (32.5") (AP)	(RECI.) Flow to Sprays (GPM)	(MAKE-UP) Flow to Toilets (GPM)	Equal Flow to Sprays (Yes/No)	Cyclones (OK or not)	Scrubber Level (70)	(K101) Recirc. H ₂ O Specific Gravity
9:15 AM	12.8		351	312	4246	1.3	36	450	220	YES	OK	100	1.008
9:20	128/100%		355	317	4227	1.5	35	420	210	YES	OK	91	1.010
9:35	128/100%												



Abort - YES-31 went down

(MOTOR RUMBLING OUT)

Comments: 8:15
 VENTURI: E W
 TOP 1+2 9 6
 TANG. 1+2 14 14
 TANG. 3 14 13
 TOP 3+ 0 2
 * MAKE UP WATER
 8:15 ALL OPEN

Signed John S. Hadden

~



- | <u>West</u> | <u>EAST</u> |
|-------------|-------------|
| ① TOP 1+2 | ① TOP 1+2 |
| ② TANG 1+2 | ② TANG 1+2 |
| ③ TANG 3 | ③ TANG 3 |
| ④ TOP 3 | ④ TOP 3 |

⇐ BOTH ARE ON MAKE UP WATER (FRESH H₂O)

0.040
2.70

Emissions Testing Control Room Data Sheet

Test Date 5-10-70 Test Start Time 11:15 AM Test Finish Time 12:20 PM

Time	Prod. Rate (GPH)	Exhaust Temp (°F)	Gas Flow Rate (CFM)	Prod. Temp (°F)	Fan Speed (RPM)	YK-1 Draft (W.H.2O)	Venturi Press. Drop (W.H.2O)	(RECIR.) Flow to TdR (GPM)	(MAKEUP) Flow to TdR (GPM)	Equal Flow to Sprays (Yes/No)	Cyclone (In/Out) (Yes/No)	Scrubber Level (%)	Recirc. H2O Specific Gravity (<1.08)
11:15	84.5	341	78415	335	4170	2.6	28.5	360	200	Yes	Yes	25	1.006
11:30	89.0	347	78607	338	4169	2.8	28.0	350	190	Yes	Yes	44	*
11:45	84.0	345	78784	338	4170	3.0	28.0	360	260	Yes	Yes	60	
12:00	87.1	347	78869	336	4170	3.0	28.0	350	190	Yes	Yes	75	
12:15	82.0	345	79133	339	4172	3.0	28.0	360	190	Yes	Yes	87	1.022

YK-10X
Noisy

ADL
27 to
28

Comments:

11:15 AM 12:15 PM

TOP SPARKS ~~30~~ 319
Same

TAN 6.5 > 32 mg/l

* 2 can make up 2 m. water

HECH 86.2 TdR } from TdR

Signed John I. Hawley

Emissions Testing Control Room Data Sheet

Test 2

Test Date 5-10-90 Test Start Time 12:50 PM Test Finish Time 1:55

Time	Prod. Rate (GPH)	Exhaust Temp (°F)	Gas Flow Rate (CFM)	Prod. Temp (°F)	Fan Speed (RPM)	4K-1 Draft (H ₂ O)	Venturi Press Drop (H ₂ O)	(RECIR.) Flow to Sgrays (GPM)	(MAKE-UP) Flow to Tangential (GPM)	Equal Flow to Sgrays (Yes/No)	Cyclones Leuc. (Not record)	Recirc. H ₂ O Specific Gravity (<1.08)
12:45	883	353	79521	342	4170	2.7	28	360	180	Yes	Yes	>100
1:00	840	342	79741	336 331	4170	3.0	28	360	200	Yes	Yes	>100
1:15	91	340	79961	331	4170	2.9	28	300	180	Yes	Yes	>100
1:30 1:30	91	354	80071	345	4172	3.1	28	350	190	Yes	Yes	>100
1:45	87	344	80333	336	4173	3.0	28	360	180	Yes	Yes	>100
2:00	90.2	341	80452	335	4172	2.9	28	350	180	Yes	Yes	>100

Comments:

1:15 PM 2:15 PM

12:00 - 1:00 PM 86.6 TPH

from TDC

708 SPEARS 20 psi 210 1:00 - 2:00 PM 87.3 TPAH

708 G.S. - 32 m³/hr + 32 + 32 At 1:45 4E-2 std. disto was opened - it had been closed due to a higher air flow - prod. should come up

Signed John D. Hendley

Emissions

Testing

Control Room Data Sheet

Test 3

Test Date 5-16-90

Test Start Time 8:20

Test Finish Time

APR 3:30

Time	Prod. Rate (GPH)	Exhaust Temp (°F)	Gas Rate (CFM)	Prod. Temp (°F)	Fan Speed (RPM)	4K-1 Draft (in H ₂ O)	Venturi Press. Drop (in H ₂ O)	(RECIRC.) Flow to Tdg (GPM)	(MAKEUP) Flow to Tdg (GPM)	Equal Flow to Sprays (Yes/No)	Cyclones (In or out)	Scrubber Leach (%)	Recirc. H ₂ O Specific Gravity (<1.08)
2:15	96	327	58033	318	4170	2.7	27-28	180	350	Yes	Yes	2100	1.015
2:30	92	347	58080	335	4168	2.9	27-28	180	350	Yes	Yes	2100	1.015
2:45	92	341	581160	333	4170	2.5	27-28	180	360	Yes	Yes	2100	1.020
3:00	94	334	581290	334	4172	3.0	27-28	190	340	Yes	Yes	2100	1.020
3:15	95	334	581394	321	4171	2.8	27-28	180	350	Yes	Yes	2100	1.020
3:30	95	334	581515	321	4170	2.8	27-28	180	350	Yes	Yes	2100	1.020

Comments: 2:45

701 speeds 20 Pmg

701/65 → 32.9/m²

x 2 on Make up + 2 on Recirc

2:00 - 3:00 RELY Acc. 94 ppm from 100

3:00 - 4:00 " " 95

Signed John A. Hawley

Emission Testing Control Room Data Sheet

Test 1

Test Date 5-11-90

Test Start Time 7:55 AM

Test End Time 9:00 AM

Time	Exhaust		SK-1 Draft (H ₂ O)	Gas		Prod Temp (°F)	Cyclones		DC-19	Precipitator Gauge Readings		SPARKS		V AC		Amps DC		Amps AC	
	Orn Rate (TPH)	Gas Temp (°F)		Field Rate (C.F.M.)			OK or Not												
7:45	135	397	2.2	57809	356	OK	OK	OK	OK	Set 1	42	0	170	0.90		30		38	
8:00	135	396	2.3	58433	356	OK	OK	OK	OK	Set 2	38	0	315	0.73		230		230	
8:15	135	396	2.3	58615	356	OK	OK	OK	OK	Set 3	42	0	295	1.45		230		230	
8:30	135	397	2.2	58971	355	OK	OK	OK	OK										
8:45	150	390	2.2	59396	359	OK	OK	OK	OK										
9:00	142	397	2.1	59835	358	OK	OK	OK	OK										
Final Readings:																			
Set 1											41	0	170	0.90		30			
Set 2											37.5	0	310	0.73		230			
Set 3											40	0	290	1.45		230			

Comments:

135 TPH + fine dump chart

All Rectifier Sets OK? Yes

Signed: W. J. Stanley

Emission Testing Control Room Data Sheet

TEST 2

Test Date 5-11-90

Test Start Time 9:35 AM

Test End Time 10:40 AM

	SK-1 Exhaust	SK-1 Draft	Gas Flow	Prod Temp	Cyclones	DC-19
	Rate (PPH)	Temp (°F)	Rate (CFM)	Temp (°F)	(OK or Not)	(OK or Not)
9:30	3469	398	60546	344	OK	OK
9:45	3503	398	61011	367	OK	OK
10:00	3536	397	61440	370	OK	OK
10:15	3572	396	61856	368	OK	OK
10:30	3605	397	62222	369	OK	OK
10:45	3641	396	62631	370	OK	OK

Precipitator Gauge Readings

Initial Readings: KV DC

STATUS

VAC

Amps DC

Amps AC

Set 1
Set 2
Set 3

0
0
0

0.030
0.13
1.45

30
230
230

Final Readings:

Set 1
Set 2
Set 3

0
0
0

0.90
0.74
1.46

30
230
230

Comments: 9:30 138 9:45 140 10:00 138 10:15 140 10:30 138 10:45 138

All Rectifier Sets OK? yes

Signed: [Signature]

Emission Testing Control Room Data Sheet Test 3

Test Date 5-11-90 Test Start Time 11:05 AM Test Finish Time 12:10 PM

Time	Ore Rate (TPH)	Gas Temp (OF)	SK-1 Draft (H ₂ O)	Gas Flow Rate (CFM)	Prod Temp (TF)	Cyclones (OK or Not)	DC-19 (OK or Not)	Precipitator Gauge Readings	Int'l. Readings: KV DC	Sheet num.	V AC	AMPS DC	kwhrs AC
11:00	3675	397	2.2	6305	369	OK	OK		42	0	170	0.08	30
11:05	3709	396	2.3	6346	370	OK	OK	Set 1	39	0	320	0.73	230
11:30	3745	396	2.2	63910	369	OK	OK	Set 2	41	0	370	1.45	230
11:45	3781	395	2.2	64362	368	OK	OK	Set 3					
12:00 noon	3814	396	2.2	64659	369	OK	OK						
12:15 PM	3851	395	2.2	65064	369	OK	OK	Final Readings:	42	0	170	0.08	30
								Set 1	39	0	320	0.72	230
								Set 2	41	0	295	1.45	230
								Set 3					

Comments: TPH (from draft)

11:00 140
11:05 140
11:30 140
11:45 140
12:00 138

All Rectifier Sets OK YES

Signed:

John A. Hawley

Emissions Testing Control Room Data Sheet

Test 1

Test Date 5-12-90

Test Start Time 7:15 AM

Test Finish Time 8:20 AM

Time	Prod. Rate (TPH)	Gas Flow Rate (CFM)	Exhaust Gas Temp (°F)	SK-2 Draft (W.H. D)	Prod. Temp (°F)	Cyclones (Motor Int)	Bag House (Xcell)	(50H-13) Cooler (mmAL DP)	Precipitator Gauging Readings	Primary			Sparks/min	
										A.C. Volts	Amperes	K. Volts DC Amps		
7:15 AM	49	3900	319	-8.49	310	OK	1.8		Set 1	130	0	25-30	0	50
7:45	50	3910	314	-9.14	304	OK	1.7		Set 2	225	42	32	0.18	5
8:00	50	3907	310	-8.34	303	OK	1.7		Set 3	225	34	40	0.3	0
8:15	49	3910	319	-8.24	309	OK	1.6		Set 4	200	25	30	0.38	38
8:30	45	3911	343	-8.32	325	OK	1.6		Set 4	200	25	30	0.35	38
	Final Readings:													
									Set 1	260	25	32	0.1	24
									Set 2	225	40	30	0.18	4
									Set 3	225	34	38	0.3	0
									Set 4	200	25	30	0.35	38

Comments:

Group 5 1) SK-2 Draft (86)
2) BAG HOUSE (48)

Group 14 1) Temp
2) Exh. Temp
3) Prod. Temp

All Rectifier sets On? 708

Final Readings:

Set 1 260 25 32 0.1 24
Set 2 225 40 30 0.18 4
Set 3 225 34 38 0.3 0
Set 4 200 25 30 0.35 38

Signed M. S. Stanley

Emissions Testing Control Room Data Sheet

Test Date 5-12-90 Test Start Time Approx. 9:00 AM Test Finish Time Approx. 10:10 AM

Time	Prod. Rate (TPH)	Gas Flow Rate (CFM)	Exhaust Gas Temp (°F)	SK-2 Draft (H ₂ O)	Prod. Temp (°F)	Cyclones (OK or Not)	Bag House (H ₂ O)	C/assific (mm AF)	Precipitation Gauge Readings	PLANTARY				Sparks/min
										CO ₂ D. Vent A	14 wvs	DE Amv	14 wvs	
8:45	48	3905	344	-6.99	330	OK	1.6	1.6	Set 1	260	25	32	0.1	24
9:00	49	3910	337	-5.51	324	OK	1.7	1.7	Set 2	225	40	30	0.18	4
9:15	50	3906	328	-5.55	318	OK	1.6	1.6	Set 3	225	34	38	0.3	0
9:30	50	3905	335	-6.00	320	OK	1.6	1.6	Set 4	200	25	30	0.35	38
9:45	48	3901	347	-3.45	338	OK	1.6	1.6	Final Readings:					
10:00	55	3910	324	-1.05	308	OK	1.6	1.6	Set 1	225	0	34	0.05	30
10:15	53	4100	326	-0.99	310	OK	1.6	1.6	Set 2	225	50	30	0.2	5
									Set 3	225	35	39	0.3	0
									Set 4	225	25	32	0.35	40

Comments:

All Rectifier Sets On? yes

Signature: *[Handwritten Signature]*

Emissions Testing Control Room Data Sheet

Test Date 5-12-90

Test Start Time Approx. 10:30 AM

Test Finish Time Approx. 11:35

Test 3

Time	Prod. Rate (TPH)	Gas Flow Rate (CFM)	Exhaust Gas Temp (°F)	SK-2 Draft (W.H.O.)	Prod. Temp (°F)	Cyclones (OK/NT)	Bag House (OK/NT)	Class. (50%+13) Cool/ET (TOTAL ΔP)	Precipitation Gauge	PRIMATELY	COND UNIT A	Sparks MIN.
10:30	55	4500	295	5.6	287	OK	1.7					
10:45	55	4300	307	0.59	303	OK	1.7					
11:00	56	4380	308	0.18	302	OK	1.7					
11:15	56	4337	313	0.58	304	OK	1.8					
11:30	54	4340	315	0.59	307	OK	1.7					
Final Readings: Set 1 160 0 25 0 48 Set 2 225 32 30 1 6 Set 3 225 35 37 3 0 Set 4 200 25 32 35 40												

Comments:

All Rectifier sets OK? Yes

Signed

John A. Hardy

TEST 1A

ABON

7

Test Start Time	2:20 PM
-----------------	---------

Test Finish Time 3:25 PM

Final Readings

↳ DRINK OUTLET PRESS.
Group 14

Group 14/5

All Section sets On? yes

Signed: W. S. Hawley

Emissions Testing Control Room Data Sheet

Test Date _____

Test Start Time _____

Test Finish Time _____

Time (TPH)	Prod. Rate (CFM)	Gas Flow Rate (CFM)	Exhaust Gas Temp (°F)	SK-2 Draft (W.H. O)	Prod. Temp (°F)	Cyclones (OK or Not)	Bag House (OK or Not)	Classifier (50Y-13) (mmL DP)	Cooler	Precipitator Gauge Readings
------------	------------------	---------------------	-----------------------	---------------------	-----------------	----------------------	-----------------------	------------------------------	--------	-----------------------------

Initial Readings:

Final Readings:

All Rectifier sets On? _____

Comments:


Signed _____

APPENDIX D
FIELD DATA SHEETS

EPA REFERENCE METHOD 1 FIELD DATA SHEET

Firm Name: Rhone-Paulenc
 Plant Location: Green River, Wyo
 Sampling Location: SES 10 - Precipitator
 TRC Project No.: _____
 Date: 05-11-90
 Technician: J. Rosburg

Stack Diameter 72"
 Sample Port Diameter 4.0"
 Sample Port Depth 2.0"
 Distance Upstream 276" (Diameter = 5.22)
 Distance Downstream 656" (Diameter = 9.11)



Traverse Point Number	Number Traverse Points On A Diameter																						
	2	4	6	8	10	12	14	16	18	20	22	24											
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1											
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2											
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5											
4			93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7											
5				85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6											
6					95.6	80.6	65.8	55.6	26.9	22.0	18.8	16.5											
7						89.5	77.4	64.4	36.6	28.3	23.6	20.4											
8							96.8	85.4	75.0	63.4	37.5	29.6											
9								91.8	82.3	73.1	62.6	38.2											
10									97.4	88.2	79.9	71.7											
11										93.3	85.4	78.0											
12											97.9	90.1											
13												94.3											
14													98.2										
15														95.1									
16															98.4								
17																92.5							
18																	95.6						
19																		90.3					
20																			98.6				
21																				96.1			
22																					98.1		
23																						96.8	
24																							98.8

Traverse Points	
No.	Distance From Wall
1	3.18
2	10.51
3	21.31
4	50.69
5	61.49
6	68.83
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 1

TEST I.D.

FIRM NAME Pharos-Paulsen
PLANT LOCATION Green River, Wyo
TEST NUMBER 5E12-2, 5E12-1
LOCATION 5E12 - Precipitator
PROJECT NO. _____
DATE 05-12-90
TECHNICIAN J. Roshberg

EQUIPMENT

CONTROL BOX NO. Noted #2
PHONE I.D. 609
NOZZLE I.D. 0.365, 0.361 Area 3653
NOZZLE DIA. 6.15
FILTER TYPE 3009
FILTER NO. _____

SITE I.D.

DUCT DIA. 72"
DUCT AREA 22.245772
TEST DURATION 60.0
TRAVERSE INTERVAL 5.0
FILTER TEMP 248.25
PROBE TEMP 248.25
ASSUMED MOISTURE 28

NOMOGRAPH

BAROMETRIC PRESS 23.67
PILOT COEFFICIENT 0.87
METER Yd 1.0047
ONFACE dH0 1.8035
K FACTOR 8.1688/8.28/6
START TIME 0716
STOP TIME 0818

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT3)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
N	1	0.0	0.0	0.3	4.8	4.8	10.1	235	87.7	225	43	2.0	228
	2	5.0	0.2	1.8	5.2	5.0	10.1	238	90.0	229	43	6.0	232
	3	10.0	0.4	1.9	5.7	5.1	10.1	239	93.4	230	44	7.5	234
	4	15.0	0.7	1.0	5.8	5.2	10.1	240	97.5	233	45	5.0	235
	5	20.0	0.1	1.0	6.2	5.4	10.1	241	100.7	237	46	5.5	235
	6	25.0	0.1	0.9	6.4	5.7	10.1	243	103.9	236	47	5.0	238
E	1	30.0	0.1	0.9	6.7	5.8	10.1	243	107.0	242	50	5.0	237
	2	35.0	0.2	1.8	6.7	6.0	10.1	243	110.0	250	50	7.5	235
	3	40.0	0.2	2.0	6.8	6.0	10.1	243	114.2	253	50	9.0	236
	4	45.0	0.2	2.3	6.8	6.1	10.1	243	118.0	248	52	10.0	238
	5	50.0	0.2	1.6	6.9	6.2	10.1	243	122.6	255	58	8.0	232
	6	55.0	0.1	1.1	6.8	6.2	10.1	243	130.2	254	61	8.0	230
AVERAGE									42.496				

DATE REDUCTION $T_m = 59.17$ $P_s = 0.11$ $T_s = 236.83$
CHECK DATA

MOISTURE DATE

INITIAL

WATER COLLECTED

Impinger 1

Impinger 2

Impinger 3

SIN KCA GEL

TOTAL

288

170

—

213.0

271

VELOCITY

30.53

MOISTURE

26.97 27.02

ISOKINETIC %

98.61

START

0.002

END

0.002

CFM@

15.0

CFM@

13.0

°110

°110

TTC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhine-Poulenc
 PLANT LOCATION Green River, WY
 TEST NO. SES12-1
 SAMPLING LOCATION SES12- Precipitator
 TRC PROJECT NO. _____
 DATE 05-12-90
 TECHNICIAN J. Rosburg

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 23.79
 STACK PRESSURE -0.11
 AMBIENT TEMP 50
 PERCENT MOISTURE ~26
 COLLECTION TIME 0719-0810
 ANALYSIS TIME 0850

ORSAT EQUIPMENT CHECK

ORSAT CHECK: 	PRE-TEST LEAK CHECK: 	INITIAL <u>18.0</u> ML @ 0 MINUTES FINAL <u>18.0</u> ML @ 5 MINUTES PRE-TEST AMBIENT O2 <u>19.8</u>
-----------------------------	-------------------------------------	---

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
	ACTUAL READING		ACTUAL READING		ACTUAL READING		
GAS	ML	%	ML	%	ML	%	%
CO2	8.4	8.4	8.4	8.4			8.4
O2	18.2	9.8	18.2	9.8			9.8
CO							

COMMENTS:

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 1

TEST ID.	11-12-90	EQUIPMENT	CONTROL BOX NO.	11-12-90	SITE ID.	72"	ISOKEITING PRESS	23.70
FIRM NAME	Rhone-Poulenc	PHONE I.D.	11-12-90	DUCT DIA.	72"	PILOT COEFFICIENT	0.84	
PLANT LOCATION	Green River, WY	NOZZLE I.D.	11-12-90	TEST AREA	28.2743 ft ²	METER Yd	1.0047	
TEST NUMBER	5812-2	NOZZLE DIA.	11-12-90	TRANVERSE INTERNAL	5.0	ONCE #10	1.8035	
LOCATION	5812-2	FILTER TYPE	11-12-90	FILTER TEMP	28.425	K FACTOR	2.400	
PROJECT NO.	5812-2	FILTER NO.	11-12-90	PHONE TEMP	28.425	START TIME	0904	
DATE	05-12-90			ASSUMED MOISTURE	28	STOP TIME	1006	
TECHNICIAN	CTH							

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
N	1	00	0.26	2.19	66	64	10.1	242	130.41	228	50.2	9.0	231
	2	05	0.28	2.36	68	65	10.1	243	130.47	230	48	10.0	229
	3	10	0.30	2.53	71	66	10.1	245	130.45	229	49	11.0	229
	4	15	0.31	2.60	72	66	10.1	246	130.32	230	51	8.0	230
	5	20	0.33	2.70	74	68	10.1	247	130.30	230	54	15.0	231
	6	25	0.35	2.95	76	69	10.1	245	130.37	234	57	9.0	232
E	1	30	0.35	2.97	76	71	10.1	242	130.00	247	56	12.0	233
	2	35	0.35	2.97	78	72	10.1	245	130.31	234	56	13.0	232
	3	40	0.27	2.29	80	74	10.1	248	130.54	240	60	11.0	230
	4	45	0.26	2.20	82	75	10.1	249	130.27	237	60	10.5	231
	5	50	0.29	2.46	82	76	10.1	248	130.88	240	60	11.0	233
	6	55	0.30	2.56	84	77	10.1	247	130.78	244	61	12.0	240
AVERAGE									5.7				

$\Delta P = 0.5340$
 $\Delta H = 2.440$
 $T_s = 245.58$
 $T_a = 73.00$
 $P_s = 0.11$
 DATA REDUCTION
 LEAK CHECK DATA

MOISTURE DATE	INITIAL	FINAL
WATER COLLECTED	160	380
Impinger 1	160	167
Impinger 2		
Impinger 3	300	319.3
SILICA GEL		366.3
TOTAL		

VELOCITY	40.64
MOISTURE	27.56
ISOKEITIC %	99.35
STD. VOLUME	

START	0.007	CFME	16.0	%
END	0.005	CFME	17.0	%

TTC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhono-Paulane
 PLANT LOCATION Careen River, WY
 TEST NO. 5651278
 SAMPLING LOCATION SES12 - Precip Stack
 TRC PROJECT NO. _____
 DATE 05-12-98
 TECHNICIAN J. Rosburg

SAMPLE TYPE INTEGRATED
 BAROMETRIC PRESSURE 23.70
 STACK PRESSURE +0.12
 AMBIENT TEMP 48°F
 PERCENT MOISTURE 28%
 COLLECTION TIME 0904-1005
 ANALYSIS TIME 1010

ORSAT EQUIPMENT CHECK

ORSAT CHECK:	PRE-TEST LEAK CHECK:	INITIAL <u>18.0</u> ML	@ 0 MINUTES
		FINAL <u>18.0</u> ML	@ 6 MINUTES
		PRE-TEST AMBIENT O2 <u>19.8</u>	

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		
	ML	%	ML	%	ML	%	%
CO2	8.6	8.6	8.6	8.6			8.6
O2	18.6	10.0	18.6	10.0			10.0
CO							

COMMENTS:

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 1

TEST I.D.

EQUIPMENT

SITE I.D.

NOMOGRAH

FIRM NAME

PLANT LOCATION

TEST NUMBER

LOCATION

PROJECT NO.

DATE

TECHNICIAN

Rhone-Poulenc

Green River, WY

5572-3

5572-3 - Drilling Site

05-12-90

1650

CONTROL BOX NO.

PHONE I.D.

NOZZLE I.D.

NOZZLE D.A.

FILTER TYPE

FILTER NO.

Nutrich #2

6.0 ft

A-11

0.5653

6.0

3014

DUCT DIA.

DUCT AREA

TEST DURATION

TRAVEL INTERVAL

FILTER TEMP

PHONE TEMP

ASSUMED MOISTURE

72"

28.2743 ft²

60 min

5.0 min

248 ± 25

248 ± 25

28

23.74

0.88

1.000

1.000

8.6314

1.080

11.32

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
N	1	60	0.25	2.16	80	79	1.1	244	1.8	232	60	3.5	228
	2	50	0.38	3.27	81	79	1.2	244	1.9	234	50	5.5	229
	3	100	0.28	2.42	83	79	1.0	244	1.9	236	52	5.0	230
	4	150	0.35	3.02	83	78	1.2	244	2.0	243	52	5.5	232
	5	200	0.38	3.27	83	79	1.2	244	2.0	244	53	6.0	235
	6	250	0.26	2.24	82	78	1.0	244	2.1	245	55	5.0	233
E	1	300	0.35	3.02	79	77	1.1	244	2.1	247	54	5.5	232
	2	350	0.29	2.50	79	77	1.0	244	2.2	247	53	5.5	236
	3	400	0.33	2.85	81	79	1.1	244	2.2	254	58	6.0	235
	4	450	0.24	2.07	81	78	1.2	244	2.3	256	60	5.0	231
	5	500	0.30	2.59	81	77	1.0	244	2.3	254	58	5.0	238
	6	550	0.32	2.76	81	77	1.0	244	2.4	256	62	5.5	236
		600							2.48				
AVERAGE									6.0514				

$\sqrt{P} = 0.5560$
 $At = 2.6808$
 $T_m = 79.58$
 $P_s = 0.10$
 $T_s = 245.42$

DATA REDUCTION

LEAK CHECK DATA

MOISTURE DATE

INITIAL

FINAL

WATER COLLECTED

Impinger 1

Impinger 2

Impinger 3

SH KCA GEL

TOTAL

START 0.003 CFM @ 150" H₂O

END 0.002 CFM @ 11.0" H₂O

VELOCITY 41.99

MOISTURE 24.85

ISOKINETIC % 96.75

STD. VOLUME (63.21)

TRC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhone-Paulenc
 PLANT LOCATION Green River, WY
 TEST NO. SES 12-3
 SAMPLING LOCATION SES 12 - Precipitator
 TRC PROJECT NO. _____
 DATE 05-12-90
 TECHNICIAN J. Rosbury

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 23.71
 STACK PRESSURE -0.10
 AMBIENT TEMP 59
 PERCENT MOISTURE 26
 COLLECTION TIME 1034-1128
 ANALYSIS TIME 1155

ORSAT EQUIPMENT CHECK

ORSAT CHECK: 	PRE-TEST LEAK CHECK: 	INITIAL <u>18.0</u> ML @ 0 MINUTES FINAL <u>18.0</u> ML @ 5 MINUTES PRE-TEST AMBIENT O2 <u>17.8</u>	
-----------------------------	-------------------------------------	---	--

MOLECULAR WEIGHT DETERMINATION


RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		%
	ML	%	ML	%	ML	%	
CO2	8.6	8.6	8.6	8.6			8.6
O2	18.6	10.0	18.6	10.0			10.0
CO							

COMMENTS:

EPA REFERENCE METHOD 1 FIELD DATA SHEET

Firm Name: Rhone Pauenc
 Plant Location: Green River, Wyo
 Sampling Location: SES 10 - Precipitator
 TRC Project No.: _____
 Date: 05-11-90
 Technician: J. Rosburg

Stack Diameter 107"
 Sample Port Diameter 4.0"
 Sample Port Depth 2.0"
 Distance Upstream 48" $Di = 0.45$
 Distance Downstream 353" $Di = 3.30$



Traverse Point Number	Number Traverse Points On A Diameter											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7			88.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1	
8			96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4	
9				91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0	
10				97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2	
11					93.3	85.4	78.0	70.4	61.2	39.3	32.3	
12					97.9	90.1	83.1	76.4	69.4	60.7	39.8	
13						94.3	87.5	81.2	75.0	68.5	60.2	
14						98.2	91.5	85.4	79.6	73.8	67.7	
15							95.1	89.1	83.6	78.2	72.8	
16							98.4	92.5	87.1	82.0	77.0	
17								95.6	90.3	85.4	80.6	
18								98.6	93.3	88.4	83.9	
19									96.1	91.3	86.8	
20									98.7	94.0	89.5	
21										96.5	92.1	
22										98.9	94.5	
23											96.8	
24											98.9	

Traverse Points	
No.	Distance From Wall
1	2.25 + port
2	3.17
3	12.63
4	18.94
5	26.75
6	38.09
7	68.91
8	80.25
9	88.06
10	94.37
11	99.83
12	104.75
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	

EPA REFERENCE METHOD 2
FIELD DATA SHEET

FIRM NAME Phare Porteur

PLANT LOCATION Green River

TEST NO. Flow

SAMPLING LOCATION SES 10

TRC PROJECT NO. _____

DATE 05-11-90

TECHNICIAN J. K. 6019

STACK DIMENSIONS 8.92' AREA 62.97

BAROMETRIC PRESSURE 23.54

STACK PRESSURE -0.20

GAS MOLECULAR WEIGHT _____

PERCENT MOISTURE 76.0

PITOT NO. 0.849.0' Cp 0.84

TEST TIME 0730

PORT	POINT	dP	dP	Ts F
S		0.39		371
		0.40		372
		0.42		372
		0.45		373
		0.45		373
		0.44		372
		0.42		38T
		0.38		288
		0.34		386
		0.31		384
		0.28		382
		Average	0.6221	387.2°F

PORT	POINT	dP	dP	Ts F
		Average		F

VELOCITY 52.31 (FPS)

FLOWRATE 195 995 ACFM 67,040 DSCFM _____

EPA REFERENCE METHOD 505
FIELD DATA SHEET

SHEET 1 OF 2

TEST I.D.	EQUIPMENT	SITE I.D.	NO. OF
FORM NAME	CONTROL BOX NO.	DUCT DIA.	BAROMETRIC PRESS
PLANT LOCATION	PHONE I.D.	DUCT AREA	PILOT COEFFICIENT
TEST NUMBER	NOZZLE I.D.	TEST DURATION	METERING
LOCATION	NOZZLE DIA.	TRANSVERSE INTERVAL	ONCE dia
PROJECT NO.	FILTER TYPE	FILTER TEMP	K FACTOR
DATE	FILTER NO.	PHONE TEMP	START TIME
TECHNICIAN		ASSUMED MOISTURE	STOP TIME

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (Ft ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
5	1	00	0.38	1.15	48	49	22	39	41	229	47	4.0	261
	2	05	0.38	1.15	51	49	22	39	41	231	45	4.0	262
	3	10	0.38	1.15	52	50	22	39	41	232	45	4.0	267
	4	15	0.40	1.21	53	50	22	39	41	234	45	4.0	263
	5	20	0.43	1.30	54	50	22	39	41	235	46	4.0	263
	6	25	0.46	1.39	55	51	23	39	41	235	47	4.0	262
	7	30	0.44	1.33	55	51	24	39	41	231	47	4.5	263
	8	35	0.41	1.24	56	52	23	39	41	233	47	4.0	263
	9	40	0.38	1.15	56	52	21	38	41	231	48	4.0	260
	10	45	0.35	1.06	56	52	22	38	41	234	48	4.0	255
	11	50	0.29	0.88	57	52	20	38	41	231	49	3.0	252
	12	55	0.23	0.69	56	52	20	38	41	233	48	3.0	255
E	1	00	0.37	1.12	55	52	21	38	41	233	49	3.5	254
	2	05	0.37	1.12	56	52	21	39	41	235	48	4.0	262
	3	10	0.40	1.21	58	53	23	39	41	242	47	4.0	267
	4	15	0.45	1.36	58	53	24	39	41	244	48	4.0	266
AVERAGE													

MOISTURE DATE	INITIAL	FINAL
WATER COLLECTED	100	313
Impinger 1	100	128
Impinger 2		
Impinger 3	300	310.4
SLKCA GEL		251.4
TOTAL		

LEAK CHECK DATA	DATA REDUCTION
START 0.004 CFM @ 17.0 "HG	VELOCITY
END 0.002 CFM @ 7.0 "HG	MOISTURE
	ISOKINETIC %
	STD. VOLUME

at 4.0
 $\beta = 29.4 \times 10^{-4}$
 down stream

TRC

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 2 OF 2

TEST I.D.

EQUIPMENT

SITE I.D.

NONOUGIWP11

FIRMA NAME
PLANT LOCATION
TEST NUMBER
LOCATION
PROJECT NO.
DATE
TECHNICIAN

Rhone-Poulenc
Carmichael, WI
58870-2
58870-2
05-11-90
P32

CONTROL BOX NO.
PHONE I.D.
NOZZLE I.D.
NOZZLE DIA.
FILTER TYPE
FILTER NO.

Nutley 4
7.077
2-10
0.2963
G.F.
3012

DUCT DIA.
DUCT AREA
TEST DURATION
TRAVEL TIME INTERVAL
FILTER TEMP
PROBE TEMP
ASSUMED MOISTURE

107"
62.4577
6.0 min
2.5 min
247 ± 25
247 ± 25
28

BAROMETRIC PRESS
PYOT COEFFICIENT
METER Yd
ORifice dia
K FACTOR
START TIME
STOP TIME

23.50
0.84
1.0095
1.876
3.0214
0936
1039

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
5	5	40	0.47	1.42	58	54	0.26	39	43	248	48	5.0	268
6	6	42	0.46	1.39	58	53	0.22	39	43	247	48	5.0	269
7	7	45	0.43	1.30	59	53	0.22	39	44	249	49	5.0	273
8	8	47	0.40	1.21	59	54	0.22	39	44	249	49	5.0	271
9	9	50	0.35	1.06	59	54	0.23	39	44	249	50	5.0	270
10	10	52	0.32	0.97	59	54	0.20	39	44	247	50	4.0	270
11	11	55	0.30	0.91	59	54	0.20	39	44	246	50	4.0	268
12	12	57	0.36	1.03	59	55	0.20	38	44	246	50	4.5	266
		60							44				
AVERAGE			0.6167	1.1583		54.10	0.22	39.25	37.3				

MOISTURE DATE

INITIAL

FINAL

WATER COLLECTED

Impinger 1
Impinger 2
Impinger 3
SILICA GEL
TOTAL

100
100
300
310.4
251.4

VELOCITY

51.77

MOISTURE

27.98

ISOKINETIC %

77.61

STD. VOLUME

42.36

LEAK CHECK DATA

START 0.004 CFM @ 13.0 "HG

END 0.002 CFM @ 7.0 "HG

TRC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhone-Poulenc
 PLANT LOCATION Green River, Wyo
 TEST NO. SE810-1
 SAMPLING LOCATION SE810 - Precipitation
 TRC PROJECT NO. _____
 DATE 05-11-90
 TECHNICIAN J. Rosburg

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 23.54
 STACK PRESSURE -0.20
 AMBIENT TEMP 44
 PERCENT MOISTURE 30
 COLLECTION TIME 0754-0850
 ANALYSIS TIME 0940

ORSAT EQUIPMENT CHECK

ORSAT CHECK:	PRE-TEST LEAK CHECK:	INITIAL <u>19.0</u> ML	@ 0 MINUTES
		FINAL <u>18.0</u> ML	@ 5 MINUTES
		PRE-TEST AMBIENT O2 <u>19.8</u>	

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		
	ML	%	ML	%	ML	%	%
CO2	9.8	9.8	7.8	7.8			9.8
O2	18.6	8.8	18.6	8.8			8.8
CO							

COMMENTS:

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 2

TEST I.D.

EQUIPMENT

SITE I.D.

NONOGRAMM

FIRM NAME Blane-Polanc
 PLANT LOCATION Green River, WY
 TEST NUMBER 55810-1
 LOCATION 55810-1 Presp. Harv
 PROJECT NO. 05-11-90
 DATE 1.3.2009
 TEST I.D. 05-11-90
 EQUIPMENT 1.3.2009
 SITE I.D. 05-11-90
 NONOGRAMM 05-11-90
 CONTROL BOX NO. 4
 PHONE I.D. 4
 NOZZLE I.D. 0.10
 NOZZLE DIA. 0.10
 FILTER TYPE 0.10
 FILTERING 0.10
 DUCT DIA. 10"
 DUCT AREA 62.49 ft²
 TEST DURATION 60.0
 TRAVERSE INTERVAL 8.5
 FILTER TEMP 248.25
 PHONE TEMP 248.25
 ASSUMED MOISTURE 22
 BATHOMETER PRESS 23.54
 PILOT COEFFICIENT 0.87
 METER Yd 1.0075
 ONCE Jd 1.836
 K FACTOR 3.4310
 START TIME 0254
 STOP TIME 0358

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
S	1	0.0	0.3	1.3	4.4	4.4	0.2	3.9	3.7	230	43	3.0	260
	2	2.5	0.4	1.3	4.5	4.4	0.2	3.9	3.7	232	44	3.0	300
	3	5.0	0.4	1.4	4.5	4.4	0.2	3.9	3.7	231	44	3.0	260
	4	7.5	0.4	1.5	4.7	4.4	0.2	3.9	3.7	232	44	3.0	265
	5	10.0	0.4	1.5	4.7	4.4	0.2	3.9	3.7	231	44	3.0	266
	6	12.5	0.4	1.5	4.7	4.4	0.2	3.9	3.7	232	45	3.5	266
	7	15.0	0.4	1.4	4.9	4.4	0.2	3.8	3.5	233	50	4.0	262
	8	17.5	0.3	1.2	4.9	4.5	0.2	3.8	3.5	230	52	3.5	260
	9	20.0	0.3	1.1	4.9	4.5	0.2	3.8	3.5	236	54	3.5	248
	10	22.5	0.3	1.0	4.9	4.5	0.2	3.8	3.5	238	55	3.0	246
	11	25.0	0.3	1.0	4.9	4.5	0.2	3.8	3.5	232	56	3.0	243
	12	27.5	0.3	1.0	5.0	4.6	0.2	3.8	3.5	231	56	3.0	244
E	1	30.0	0.3	1.2	4.8	4.6	0.2	3.9	3.5	235	50	3.0	262
	2	32.5	0.3	1.2	4.9	4.6	0.2	3.9	3.5	230	52	3.0	264
	3	35.0	0.3	1.3	5.0	4.6	0.2	3.9	3.5	228	53	3.5	262
	4	37.5	0.3	1.5	5.1	4.7	0.2	3.9	3.5	231	54	4.0	262
AVERAGE													

MOISTURE DATE

INITIAL

FINAL

WATER COLLECTED

Impinger 1

Impinger 2

Impinger 3

SILICA GEL

TOTAL

VELOCITY

MOISTURE

ISOKINETIC %

STD. VOLUME

DATA REDUCTION

LEAK CHECK DATA

START 0.002 CFM @ 12.0" H₂O

END 0.002 CFM @ 20" H₂O

TRC

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 2 OF 2

TEST I.D.

EQUIPMENT

SITE I.D.

MONITORING

PLANT NAME	Alumina Refining	DUCT DIA	10.7"	DATUMETRIC PRESS	23.54
PLANT LOCATION	Green River, WY	DUCT AREA	62.49 ft ²	PLOT COEFFICIENT	0.17
TEST NUMBER	5010-1	TEST DURATION	6.00	METER Vd	1.0075
LOCATION	State - Green River	TIMEWISE INTERVAL	2.5 min	ORIFICE dia	1.876
PROJECT NO.	05-05-11-90	FILTER TEMP	248.25	K FACTOR	1.0096
DATE	05-05-11-90	PHONE TEMP	248.25	START TIME	0757
TECHNICIAN	JS	ASSUMED MOISTURE	2.8	STOP TIME	0858

PORT	PT.	TIME	dp	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
	5	40.0	0.45	1.54	51	47	0.26	393	59.57	234	55	4.0	271
	6	42.5	0.44	1.38	51	47	0.26	393	40.13	236	55	4.0	272
	7	45.0	0.44	1.32	51	47	0.28	393	40.30	237	57	4.0	271
	8	47.5	0.44	1.23	51	47	0.26	390	40.47	238	58	4.0	268
	9	50.0	0.38	1.14	51	47	0.25	389	40.63	239	59	4.0	265
	10	52.5	0.34	1.02	52	48	0.23	388	40.79	240	88	3.5	256
	11	55.0	0.30	0.90	52	48	0.22	386	40.94	237	57	3.0	255
	12	57.5	0.23	0.69	52	48	0.19	383	41.08	237	57	3.0	251
		60.0							41.29				
AVERAGE													
										39.74			

MOISTURE DATE

INITIAL

DATA REDUCTION

LEAK CHECK DATA

WATER COLLECTED

Impinger 1

Impinger 2

Impinger 3

SILICA GEL

TOTAL

VELOCITY 51.48

MOISTURE 27.04

ISOKINETIC % 104.74

STD. VOLUME 4520

START 0.002 CFM@ 13.0 "10

END 0.002 CFM@ 7.0 "10

TTC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhone-Poulenc
 PLANT LOCATION Green River, Wyo
 TEST NO. SES10-2
 SAMPLING LOCATION SES10-Precipitate
 TRC PROJECT NO. _____
 DATE 05-11-90
 TECHNICIAN J. Rosburg

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 23.50
 STACK PRESSURE -0.21
 AMBIENT TEMP 45
 PERCENT MOISTURE 28
 COLLECTION TIME 0940 - 1033
 ANALYSIS TIME 1100

ORSAT EQUIPMENT CHECK

ORSAT CHECK:	PRE-TEST LEAK CHECK:	INITIAL <u>18.0</u> ML	@ 0 MINUTES
		FINAL <u>18.0</u> ML	@ 5 MINUTES
		PRE-TEST AMBIENT O2 <u>14.8</u>	

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
	ACTUAL READING		ACTUAL READING		ACTUAL READING		
	ML	%	ML	%	ML	%	
GAS							
CO2	9.2	9.2	9.2	9.2			9.2
O2	19.0	9.8	19.0	9.8			9.8
CO							

COMMENTS:

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 2

TEST I.D.

EQUIPMENT

SITE I.D.

MONITORING

FIRM NAME

PLANT LOCATION

TEST NUMBER

LOCATION

PROJECT NO.

DATE

TECHNICIAN

Rhone-Poulenc
Gaseous Phase, Wet

SE310-3

SE310 Pre-imp 5 Feb

05-11-90

450

CONTROL BOX NO.

DUCT DIA

DUCT AREA

TEST DURATION

TRaverse INTERVAL

FILTER TEMP

PROBE TEMP

ASSUMED MOISTURE

107"

62.49 ft

6.0 min

2.5 min

248 F

248 F

2%

107"

62.49 ft

6.0 min

2.5 min

248 F

248 F

2%

BAROMETRIC PRESS

PILOT COEFFICIENT

METER Yd

ORifice dia

K FACTOR

START TIME

STOP TIME

23.47

0.81

1.0895

1.876

3.0234 / 3.0234

1:00

12:00

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT3)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
5	1	0 0	0.36	1.10	60	58	0.22	395	449.78	229	55	4.5	263
	2	2 5	0.37	1.13	61	58	0.20	395	451.39	231	53	4.5	266
	3	5 0	0.38	1.16	62	58	0.20	395	452.95	232	54	4.5	263
	4	7 5	0.43	1.31	63	58	0.21	396	454.52	232	54	4.5	265
	5	1 0 0	0.47	1.45	64	59	0.23	397	456.15	231	55	5.0	262
	6	1 2 5	0.47	1.45	66	60	0.23	396	457.87	228	57	5.0	264
	7	1 5 0	0.44	1.36	68	60	0.23	394	459.61	237	60	5.0	262
	8	1 7 5	0.41	1.27	70	61	0.20	393	461.30	241	63	5.0	266
	9	2 0 0	0.35	1.08	71	63	0.23	392	462.96	245	64	4.5	242
	10	2 2 5	0.36	1.11	73	64	0.22	391	464.64	247	66	5.0	242
	11	2 5 0	0.32	0.91	74	65	0.20	390	466.10	248	65	4.0	240
	12	2 7 5	0.27	0.83	75	66	0.20	388	467.53	251	65	4.0	239
E	1	3 0 0	0.39	1.22	74	67	0.22	396	468.92	254	68	4.5	244
	2	3 2 5	0.38	1.19	76	68	0.22	396	470.56	256	66	4.5	245
	3	3 5 0	0.38	1.19	76	68	0.22	397	472.16	257	64	4.5	244
	4	3 7 5	0.43	1.35	77	69	0.24	398	473.77	254	63	4.5	250
AVERAGE													

MOISTURE DATE

INITIAL

FINAL

WATER COLLECTED

Inpinger 1

Inpinger 2

Inpinger 3

SILICA GEL

TOTAL

100

100

-

300

277

152

VELOCITY

MOISTURE

ISOKINETIC %

STD. VOLUME

DATA REDUCTION

LEAK CHECK DATA

START 0.004 CFME

END 0.002 CFME

13.0 INQ

7.0 INQ

TRC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhone-Poulenc
 PLANT LOCATION Green River, Wyo
 TEST NO. 5ES10-3
 SAMPLING LOCATION SE10 Precipitator
 TRC PROJECT NO. _____
 DATE 05-11-90
 TECHNICIAN J. Roberg

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 23.47
 STACK PRESSURE -0.21
 AMBIENT TEMP 50
 PERCENT MOISTURE 32.8
 COLLECTION TIME 1107-1205
 ANALYSIS TIME 1243

ORSAT EQUIPMENT CHECK

ORSAT CHECK: 	PRE-TEST LEAK CHECK: 	INITIAL <u>18.0</u> ML @ 0 MINUTES FINAL <u>18.0</u> ML @ 5 MINUTES PRE-TEST AMBIENT O2 <u>19.8</u>	
----------------------	------------------------------	---	--

MOLECULAR WEIGHT DETERMINATION


RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		%
	ML	%	ML	%	ML	%	
CO2	9.4	9.4	9.4	9.4			9.4
O2	18.6	9.2	18.6	9.2			9.2
CO							

COMMENTS:

EPA REFERENCE METHOD 1
FIELD DATA SHEET

Firm Name: Rhone-Poulenc
Plant Location: Green river, Wyoming
Sampling Location: 43E10
TRC Project No.:
Date: 05-08-90
Technician: J. Rosburg

Stack Diameter	9.0' = 108"
Sample Port Diameter	4.0"
Sample Port Depth	4.0" w/ nipple
Distance Upstream	196.5"
Distance Downstream	423.5"

[illegible]

Traverse Points		
No.	Distance From Wall	
1	8.75	5.80
2	19.77	11.74
3	35.97	17.24
4	80.03	23.62
5	96.23	31.50
6	107.25	42.85
7		54.05
8		85.50
9		93.38
10	47.36	105.26
11		105.26
12		109.67
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		

TTC

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 2

TEST I.D.	EQUIPMENT	SITE I.D.	NO. OF REPLICATES
PHONE - Paulenc	CONTROL BOX NO.	DACT DIA	108"
GREENRIVER, WY.	PHONE I.D.	DACT AREA	63.62 ft ²
45610-Scrubber	NOZZLE I.D.	TEST DURATION	60.0
05-09-90	NOZZLE DIA	TEST DURATION	24.5
J. Rosberg	FILTER TYPE	FILTER TEMP	248.525
	FILTER NO.	PHONE TEMP	248.525
		ASSUMED MOISTURE	30.0
		NOZZLE DIA = 0.2700	0.3700, 0.371
		CALC = 0.367, 0.370, 0.371	

PORT	PT.	TIME	dP	dH	METER TEMP	PS	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
E	1	0.0	0.17	1.3	6.6	0.10	1.57	6.00	229	56	4.0	225
	2	2.5	0.12	1.20	6.6	0.10	1.55	6.00	226	55	4.0	228
	3	5.0	0.12	1.20	6.6	0.10	1.55	6.00	238	54	4.0	229
	4	7.5	0.14	1.41	6.7	0.10	1.55	6.00	244	53	4.0	228
	5	10.0	0.16	1.61	6.8	0.10	1.56	6.00	248	52	4.0	228
	6	12.5	0.13	1.28	6.8	0.11	1.56	6.00	248	52	4.5	228
	7	15.0	0.36	3.56	6.7	0.22	1.56	6.11	248	53	9.0	228
	8	17.5	0.45	4.45	6.7	0.22	1.56	6.13	242	54	4.5	228
	9	20.0	0.48	4.78	6.7	0.24	1.56	6.16	244	55	13.0	227
	10	22.5	0.52	5.17	6.7	0.26	1.56	6.19	228	55	14.0	229
	11	25.0	0.50	4.84	7.5	0.25	1.56	6.22	228	56	14.0	229
	12	27.5	0.48	4.74	7.5	0.22	1.56	6.25	230	57	14.0	229
S	1	30.0	0.05	0.47	7.1	0.08	1.54	6.28	234	58	4.0	228
	2	32.5	0.05	0.49	7.1	0.08	1.54	6.30	229	60	4.0	230
	3	35.0	0.06	0.59	7.1	0.07	1.54	6.31	227	58	4.0	220
	4	37.5	0.06	0.59	7.1	0.07	1.54	6.32	234	55	4.0	228
AVERAGE												

LEAK CHECK DATA Note - Miss last point by 2 inches

DATA REDUCTION

MOISTURE DATE INITIAL FINAL

WATER COLLECTED	100	778
Impinger 1	100	222
Impinger 2	-	-
Impinger 3	300	376.2
4 KCA GEL		426.2
TOTAL		

START 0.004 CFM @ 15.0" H₂O
END 0.002 CFM @ 14.0" H₂O

7/9/90

TRC

EPA REFERENCE METHOD: JD 5
FIELD DATA SHEET

SHEET 2 OF 2

TEST I.D.

EQUIPMENT

SITE I.D.

NONOXYGEN

FIRM NAME: Thane-Pauline
 PLANT LOCATION: Greenville, SC
 TEST NUMBER: 45810-2
 LOCATION: 45810-2
 PROJECT NO.: 45810-2
 DATE: 05-09-90
 TECHNICIAN: J. Barbary

CONTROL BOX NO.: Nutech #3
 PHONE I.D.: 701
 NOZZLE I.D.: 0.3800
 NOZZLE DIA.: 0.3800
 FILTER TYPE: 6.5
 FILTER NO.: 3002

DUCT DIA.: 108"
 DUCT AREA: 63.62 ft²
 TEST DURATION: 60.0
 TRIANGLE INTERVAL: 5.1
 FILTER TEMP: 278 ± 25
 PHONE TEMP: 278 ± 25
 ASSUMED MOISTURE: 20

BAROMETRIC PRESS: 24.05
 PILOT COEFFICIENT: 0.84
 METER Y4: 1.0128
 OFFICE #10: 1.8962
 K FACTOR: 9.8821
 START TIME: 1410
 STOP TIME: 1513

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
5	5	4 0.0	0.0	0.39	71	70	-0.09	1 5 6	6 7 3 4 3	232	55	3.5	228
	6	4 2.6	0.0	0.37	72	71	-0.08	1 5 6	6 7 3 4 1	235	54	3.5	229
	7	4 5.0	0.1	0.39	73	71	-0.12	1 5 6	6 7 3 5 3 5	232	54	6.0	228
	8	4 7.6	0.1	0.58	74	71	-0.11	1 5 6	6 7 3 7 0 6	232	53	6.0	228
	9	5 0.0	0.1	0.78	75	72	-0.11	1 5 5	6 7 3 8 9 1	237	52	6.5	227
	10	5 2.5	0.1	0.48	76	72	-0.10	1 5 5	6 7 4 0 8 5	243	53	6.0	229
	11	5 5.0	0.1	0.68	76	72	-0.09	1 5 5	6 7 4 2 6 0	242	54	6.0	228
	12	5 7.5	0.1	0.37	76	72	-0.08	1 5 5	6 7 4 4 4 9	240	54	6.0	228
		6 0.0							6 7 4 6 2 4 7				
AVERAGE			0.4159	1.9954	70.79		-0.13	15 5.42	4 5 3 5 0				

MOISTURE DATE

INITIAL

FINAL

WATER COLLECTED

Impinger 1

Impinger 2

Impinger 3

CA GEL

AL

DATA REDUCTION

VELOCITY

MOISTURE

ISOKEITHING %

STD. VOLUME

29.82

55.24

103.43

57.03

29.82

55.24

103.43

57.03

LEAK CHECK DATA

START 6.004 CFM @ 15.0 "HG

END 0.002 CFM @ 14.0 "HG

AK 5/9/90

TTC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhanc-Poulenc
 PLANT LOCATION Green River, Wyo
 TEST NO. 45E10-2
 SAMPLING LOCATION 45E10-Scrubber
 TRC PROJECT NO. _____
 DATE 05-09-90
 TECHNICIAN J. Raskin

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 29.05
 STACK PRESSURE -0.13
 AMBIENT TEMP 49
 PERCENT MOISTURE 75
 COLLECTION TIME 1410-1505
 ANALYSIS TIME 1915

ORSAT EQUIPMENT CHECK

ORSAT CHECK:	PRE-TEST LEAK CHECK:	INITIAL <u>18.0</u> ML @ 0 MINUTES FINAL <u>18.0</u> ML @ 5 MINUTES PRE-TEST AMBIENT O2 <u>19.8</u>
--------------	----------------------	---

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		
	ML	%	ML	%	ML	%	%
CO2	8.0	8.0	8.0	8.0			8.0
O2	18.4	10.4	18.4	10.4			10.4
CO							

COMMENTS: _____

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 2 OF 2

TEST I.D.

FIRM NAME Rhone-Poulenc EQUIPMENT COMTECH BOX NO. 1171 SITE I.D. 108
 PLANT LOCATION Green River, WY DUCT DIA. 63.8221 DUCT AREA 63.8221 DUCT PRESS 27.05
 TEST NUMBER 45E10-3 PNOZZLE I.D. 5.0 TEST DURATION 60.0 PNOZZLE COEFFICIENT 0.84
 LOCATION 45E10-3 NOZZLE DIA. 0.7773 TRIANGLE INTERVAL 2.5 OFFICE DIAP 1.0128
 PROJECT NO. 45E10-3 FILTER TYPE 6.5 FILTER TEMP 248.125 K FACTOR 8.4222
 DATE 05-09-96 FILTER NO. 3003 PNOZZLE TEMP 243.125 START TIME 1401
 TECHNICIAN J. R. S. B. G. ASSUMED MOISTURE 20 STOP TIME 1705

PORT	PT.	TIME	dp	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
E	5	40.0	0.0	0.7	77	76	0.0	155	672.9	244	52	5.0	227
	6	42.5	0.0	0.7	78	76	0.0	156	774.1	250	52	5.0	231
	7	45.0	0.1	1.0	78	76	0.0	156	775.4	250	52	6.0	232
	8	47.5	0.1	1.0	78	76	0.0	156	776.7	252	52	8.0	232
	9	50.0	0.2	1.8	78	76	0.1	156	778.7	253	52	7.0	234
	10	52.5	0.1	1.0	79	76	0.1	156	780.2	254	53	5.5	235
	11	55.0	0.0	0.7	79	76	0.1	156	782.5	254	53	5.0	236
	12	57.5	0.0	0.5	78	76	0.0	156	784.6				
		60.0							786.6				
									788.2				
									790.7				
	AVERAGE		0.3640	1.2783			0.09	155.87	38.2				

MOISTURE DATE

INITIAL

WATER COLLECTED

Impinger 1

Impinger 2

Impinger 3

SH KCA GEL

TOTAL

DATA REDUCTION

VELOCITY 26.51

MOISTURE 36.17

ISOKINETIC % 98.12

STD. VOLUME 48.13

START 0.002 CFM @ 16.0 "HG

END 0.001 CFM @ 12.0 "HG

LEAK CHECK DATA

TRC

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 2

TEST ID.	05-07-90	EQUIPMENT	CONTROL BOX NO. <u>Nutech #3</u>	SITE ID.	108"	MONOGRAPH	DAY/METRIC PRESS <u>24.05</u>
FIRM NAME	<u>Rhone-Poulenc</u>	PHONE ID.	<u>9.0</u>	DUCT DIA.	<u>63.62 ft</u>	PILOT COEFFICIENT	<u>0.84</u>
PLANT LOCATION	<u>Greencrivers, WY</u>	NOZZLE ID.	<u>C-12</u>	DUCT AREA	<u>60.0</u>	METRIC Yd	<u>1.0128</u>
TEST NUMBER	<u>45810-3</u>	NOZZLE DIA.	<u>0.344</u>	TEST DURATION	<u>2.5</u>	ORifice dia	<u>1.8762</u>
LOCATION	<u>45810. Scumbar</u>	FILTER TYPE	<u>6.5</u>	TRANSVERSE INTERVAL	<u>2.5</u>	K FACTOR	<u>8.9722</u>
PROJECT NO.	<u>05-07-90</u>	FILTERING	<u>3003</u>	PHONE TEMP	<u>248.25</u>	START TIME	<u>1601</u>
DATE	<u>05-07-90</u>			ASSUMED MOISTURE	<u>70</u>	STOP TIME	<u>1705</u>
TECHNICIAN	<u>J. E. Eschberg</u>						

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT3)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
1	1	0.0	0.1	1.4	7.6	7.6	70.1	156	6.4	227	52	5.0	227
2	2	2.5	0.1	1.3	7.8	7.6	70.1	156	6.4	230	50	5.0	228
3	3	5.0	0.1	1.7	7.7	7.6	70.1	156	6.4	230	50	6.0	228
4	4	7.5	0.2	1.9	7.7	7.6	70.1	156	6.4	230	50	6.0	227
5	5	10.0	0.2	2.6	7.9	7.6	70.1	155	6.4	232	48	6.0	228
6	6	12.5	0.2	2.6	7.9	7.5	70.1	155	6.4	233	48	9.0	227
7	7	15.0	0.2	1.7	7.8	7.5	70.1	156	6.4	234	49	7.0	220
8	8	17.5	0.2	1.7	7.7	7.6	70.1	155	6.4	236	50	7.0	231
9	9	20.0	0.2	1.8	7.7	7.5	70.1	156	6.4	235	51	7.5	232
10	10	22.5	0.2	2.0	7.7	7.4	70.1	155	6.4	237	52	8.0	231
11	11	25.0	0.2	2.0	7.7	7.4	70.1	155	6.4	237	52	6.0	230
12	12	27.5	0.2	2.1	7.6	7.5	70.1	155	6.4	230	52	6.0	230
13	13	30.0	0.2	2.2	7.6	7.5	70.1	155	6.4	230	53	4.0	232
14	14	32.5	0.2	2.4	7.7	7.5	70.1	155	6.4	242	53	4.0	232
15	15	35.0	0.2	2.4	7.7	7.5	70.1	156	6.4	241	54	7.0	231
16	16	37.5	0.2	2.4	7.8	7.6	70.1	156	6.4	242	54	4.0	231
AVERAGE													

MOISTURE DATE	INITIAL	FINAL	LEAK CHECK DATA
WATER COLLECTED			START <u>0002</u> CFME / <u>6.0</u> "HG
Impinger 1	<u>100</u>	<u>403</u>	END <u>0001</u> CFME / <u>12.0</u> "HG
Impinger 2	<u>100</u>	<u>153</u>	
Impinger 3	<u>100</u>	<u>313.2</u>	
SH KCA GEL			
TOTAL			

TRC

**EPA REFERENCE METHOD 3
FIELD DATA SHEET**

FIRM NAME	<u>Pharc-Poulenc</u>	SAMPLE TYPE	<u>Integrated</u>
PLANT LOCATION	<u>Green River, Wyo</u>	BAROMETRIC PRESSURE	<u>24.05</u>
TEST NO.	<u>45C10-3 scrubber</u>	STACK PRESSURE	<u>-0.09</u>
SAMPLING LOCATION	<u>45C10- scrubber</u>	AMBIENT TEMP	<u>48</u>
TRC PROJECT NO.		PERCENT MOISTURE	<u>36</u>
DATE	<u>05-09-90</u>	COLLECTION TIME	<u>1610-1700</u>
TECHNICIAN	<u>J. Rosburg</u>	ANALYSIS TIME	<u>1950</u>

ORSAT EQUIPMENT CHECK

ORSAT CHECK:	PRE-TEST LEAK CHECK:	INITIAL	<u>18.0</u>	ML	@ 0 MINUTES
		FINAL	<u>18.0</u>	ML	@ 5 MINUTES
		PRE-TEST AMBIENT O2	<u>17.8</u>		

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		
	ML	%	ML	%	ML	%	%
CO2	7.4	7.4	7.4	7.4			7.4
O2	17.2	9.8	17.2	9.8			9.8
CO							

COMMENTS:

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 2

TEST I.D.

EQUIPMENT

SITE I.D.

MONITORING

FIRM NAME Rhone-Paulinc CONTROL BOX NO. 43 DUCT DIA. 18" DUCT AREA 62.2412 DUCT LENGTH 2407
 PLANT LOCATION Greenville, WY NOZZLE I.D. 0.128 TEST DURATION 60.0 TEST DURATION INTERVAL 2.5 PUMP VACUUM 7.0
 TEST NUMBER 45810-4 NOZZLE DIA. 0.128 FILTER TYPE 0.5 FILTER TEMP 248 ± 2.5 STOP TIME 1828
 LOCATION 45810-Scrubber FILTER TYPE 0.5 FILTER TEMP 248 ± 2.5 STOP TIME 1828
 PROJECT NO. 05-09-90 FILTER TYPE 0.5 FILTER TEMP 248 ± 2.5 STOP TIME 1828
 DATE 5-18-90 FILTER TYPE 0.5 FILTER TEMP 248 ± 2.5 STOP TIME 1828
 TECHNICIAN J. Barbary

PORT	PT.	TIME	dp	dH	METER TEMP IN OUT	Ps	STACK TEMP (F)	METER VOL. (Ft ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
E	1	0.0	0.0	0.4	76	76	76	68	230	58	7.0	228
	2	2.5	0.0	0.4	77	77	76	68	232	53	4.0	229
	3	5.0	0.0	0.7	77	77	76	68	234	52	5.0	230
	4	7.5	0.0	0.7	78	78	76	68	235	52	5.0	230
	5	10.0	0.1	0.9	78	78	76	68	236	52	6.0	231
	6	12.5	0.1	1.2	79	79	76	68	236	52	7.0	231
	7	15.0	0.1	1.6	79	79	76	68	238	52	7.5	232
	8	17.5	0.1	1.2	79	79	76	68	239	52	7.5	232
	9	20.0	0.1	1.2	79	79	76	68	240	52	8.0	234
	10	22.5	0.0	1.0	80	80	77	68	240	52	5.0	235
	11	25.0	0.0	0.4	80	80	77	68	241	52	6.0	234
	12	27.5	0.0	0.7	80	80	77	68	241	52	4.0	234
S	1	30.0	0.0	0.5	80	80	77	68	242	53	5.0	232
	2	32.5	0.0	0.7	81	81	77	68	243	53	6.0	230
	3	35.0	0.1	0.9	81	81	77	68	241	53	6.0	232
	4	37.5	0.1	0.9	81	81	77	68	241	53	6.0	232
AVERAGE												

MOISTURE DATE

INITIAL

FINAL

WATER COLLECTED

Inflinger 1

Inflinger 2

Inflinger 3

SILICA GEL

TOTAL

DATA REDUCTION

VELOCITY

MOISTURE

ISOKINETIC %

STD. VOLUME

LEAK CHECK DATA

START 0.003 CFM @ 16.0 "H₂O

END 0.001 CFM @ 12.0 "H₂O

TRC

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 2 OF 2

TEST I.D.	EQUIPMENT	SITE I.D.	NOMOGRAH
FIRM NAME	CONTROL BOX NO.	DUCT DIA.	BAROMETRIC PRESS
PLANT LOCATION	PROBE I.D.	DUCT AREA	PILOT COEFFICIENT
TEST NUMBER	NOZZLE I.D.	TEST DURATION	METAL Yd
LOCATION	NOZZLE DIA.	TRAVERSE INTERVAL	ONFACE dH
PROJECT NO.	FILTER TYPE	FILTER TEMP	K FACTOR
DATE	FILTER NO.	PROBE TEMP	START TIME
TECHNICIAN		ASSUMED MOISTURE	STOP TIME

PORT	PT.	TIME	dP	dH	METER TEMP IN OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
5	5	4 0.0	0.47	1.89	77 76	-0.13	157	70587	243	53	7.5	233
	6	4 2.5	0.23	2.08	77 75	-0.13	156	70757	244	54	10.0	234
	7	4 5.0	0.25	2.26	77 75	-0.13	156	70918	244	54	10.5	235
	8	4 7.5	0.19	1.71	77 75	-0.13	155	71142	241	55	10.0	231
	9	5 0.0	0.10	0.90	80 76	-0.12	155	71378	241	54	8.0	235
	10	5 2.5	0.08	0.72	77 75	-0.09	156	71526	242	54	7.0	236
	11	5 5.0	0.08	0.72	78 75	-0.08	156	71655	241	55	7.0	238
	12	5 7.5	0.08	0.72	77 75	-0.08	156	71781	242	55	7.0	237
		1 8.0						71907				
AVERAGE			0.3208	0.9871	77.44	-0.11	155.35	334282				

MOISTURE DATE	INITIAL	FINAL
WATER COLLECTED		
Impinger 1	100	403
Impinger 2	100	156
Impinger 3	-	-
SHICA DEL	100	210.2
TOTAL		383.2

DATA REDUCTION	LEAK CHECK DATA
VELOCITY	START 0.003 CFM @ 16.0 "HG
MOISTURE	END 0.001 CFM @ 12.0 "HG
ISOKINETIC %	
STD. VOLUME	

TRC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhone-Paulenc
 PLANT LOCATION Green River, Wyo
 TEST NO. 45C10-18
 SAMPLING LOCATION 45C10 - Scrubber
 TRC PROJECT NO. _____
 DATE 05-09-90
 TECHNICIAN J. Rosburg

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 29.07
 STACK PRESSURE -0.11
 AMBIENT TEMP 45
 PERCENT MOISTURE 35
 COLLECTION TIME 1740-1832
 ANALYSIS TIME 1955

ORSAT EQUIPMENT CHECK

ORSAT CHECK: _____ 	PRE-TEST LEAK CHECK: _____ 	INITIAL <u>18.0</u> ML @ 0 MINUTES FINAL <u>18.0</u> ML @ 5 MINUTES PRE-TEST AMBIENT O2 <u>17.8</u>	
----------------------------	------------------------------------	---	--

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		%
	ML	%	ML	%	ML	%	
CO2	7.4	7.4	7.4	7.4			7.4
O2	18.6	10.2	17.6	10.2			10.2
CO							

COMMENTS:

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 1

TEST I.D.	EQUIPMENT	SITE I.D.	NOMINATING
FIRM NAME	CONTROL BOX NO.	DUCT DIA.	ISO METRIC PRESS
PLANT LOCATION	PHONE I.D.	DUCT AREA	PILOT COEFFICIENT
TEST NUMBER	NOZZLE I.D.	TEST DURATION	METER Yd
LOCATION	NOZZLE DIA.	TRAVELSE INTERNAL	ONCE d10
PROJECT NO.	FILTER TYPE	FILTER TEMP	K FACTOR
DATE	FILTER NO.	PHONE TEMP	START TIME
TECHNICIAN		ASSUMED MOISTURE	STOP TIME

108" 24.05
 63.62 0.83
 60.0 1.0/28
 5.0 1.0962
 24.25 4.2017/42714
 24.25 0.920
 22

0.293, 0.275, 0.295
 0.293, 0.275, 0.295

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	Ps	STACK TEMP (F)	METER VOL. (FT ³)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
E	1	0.0	0.15	0.67	57	56	10.1	157	593.40	275	50	4.0	228
	2	5.0	0.14	0.60	61	58	10.1	157	596.06	273	49	4.0	230
	3	10.0	0.22	0.94	65	63	10.1	174	598.38	257	48	4.0	270
	4	15.0							600.578				
	5	20.0											
	6	25.0											
S	1	30.0											
	2	35.0											
	3	40.0											
	4	45.0											
	5	50.0											
	6	55.0											
		60.0											
AVERAGE			0.4102	0.7233		60.06	10.13	157	7.175				

MOISTURE DATE	INITIAL	FINAL
WATER COLLECTED		
Inflinger 1	100	103
Inflinger 2	100	100
Inflinger 3	-	-
SILICA GEL	300	2.5
TOTAL		55.5

LEAK CHECK DATA DOWN 0934 VOID TEST
 START 0.002 CFM @ 11.0 "HG
 END CFM @ "HG

DATA INDUCTION
 VELOCITY
 MOISTURE 20.58 70
 ISO METRIC %
 STD. VOLUME

TRC

SHEET **OF**

MONOMER

DATE RECEIVED 29.02

PAID 1.0128

OFFICE FILE 29687

CRIME INDEX

STOP TIME

[illegible]

LEAK CHECK DATA

100

1000

100

END
CJME
-113

DOWNSTREAM = 25.5' 306"


49372600

4.71 upstream down
8.95 diameter up
TRC

EPA REFERENCE METHOD 1 FIELD DATA SHEET

Firm Name: Zone-Pentac
 Plant Location: Green River, WY
 Sampling Location: 45C 12A
 TRC Project No.: _____
 Date: 05-09-90
 Technician: J. Posburg

Stack Diameter 65.0"
 Sample Port Diameter 4.0
 Sample Port Depth 6.0" w/ nipple
 Distance Upstream 306" (47 Diameters)
 Distance Downstream 582" (8.9 Diameters)




Traverse Point Number	Number Traverse Points On A Diameter											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.6	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	60.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	36.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12						97.9	90.1	83.1	76.4	69.4	60.7	39.8
13							94.3	87.5	81.2	75.0	68.5	60.2
14							98.2	91.5	85.4	79.6	73.8	67.7
15								95.1	89.1	83.5	78.2	72.8
16								98.4	92.5	87.1	82.0	77.0
17									95.6	90.3	85.4	80.6
18									98.6	93.3	88.4	83.9
19										96.1	91.3	86.8
20										98.7	94.0	89.5
21											96.5	92.1
22											98.9	94.5
23												96.8
24												98.9

Traverse Points	
No.	Distance From Wall
1	8.86"
2	15.49"
3	25.24"
4	51.76"
5	61.51"
6	68.14"
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	

EPA REFERENCE METHOD 1 FIELD DATA SHEET

Firm Name: Rhone-Poulenc
 Plant Location: Greene River, Wyoming
 Sampling Location: 4 SP 12 A
 TRC Project No.: _____
 Date: 05-08-90
 Technician: J. Rosburg

Stack Diameter 5.5' = 66"
 Sample Port Diameter 4.0"
 Sample Port Depth 8
 Distance Upstream _____
 Distance Downstream _____



Traverse Point Number	Number Traverse Points On A Diameter											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.8	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		93.3	70.4	32.3	22.8	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	38.8	31.6	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12						97.9	90.1	83.1	76.4	69.4	60.7	39.8
13							94.3	87.5	81.2	75.0	68.5	60.2
14							98.2	91.5	85.4	79.6	73.8	67.7
15								95.1	89.1	83.5	78.2	72.8
16								98.4	92.5	87.1	82.0	77.0
17									95.6	90.3	85.4	80.6
18									98.6	93.3	88.4	83.9
19										96.1	91.3	86.8
20										98.7	94.0	89.5
21											96.5	92.1
22											98.9	94.5
23												96.8
24												98.9

Traverse Points	
No.	Distance From Wall
1	2.90" + Bit Depth
2	9.64"
3	19.54"
4	46.46"
5	56.36"
6	62.10"
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhone-Pentac
 PLANT LOCATION Green River, Wyo
 TEST NO. 45C12A-1
 SAMPLING LOCATION 45C12A - Scrubber
 TRC PROJECT NO. _____
 DATE 05-10-90
 TECHNICIAN J. Rosburg

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 23.77
 STACK PRESSURE +0.14
 AMBIENT TEMP 60
 PERCENT MOISTURE ≈ 35.0
 COLLECTION TIME 1117-1210
 ANALYSIS TIME 1230

ORSAT EQUIPMENT CHECK

ORSAT CHECK:	PRE-TEST LEAK CHECK:	INITIAL <u>18.0</u> ML @ 0 MINUTES FINAL <u>18.0</u> ML @ 6 MINUTES PRE-TEST AMBIENT O2 <u>19.8</u>
--------------	----------------------	---

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		%
	ML	%	ML	%	ML	%	
CO2	6.2	6.2	6.2	6.2			6.2
O2	18.2	12.0	18.2	12.0			12.0
CO							

COMMENTS:

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 1

TEST I.D.

EQUIPMENT

SITE I.D.

NOMOGRAPH

FIRM NAME <u>Rhone-Poulenc</u>	CONTROL BOX NO. <u>601</u>	DUCT DIA. <u>6.5"</u>	BAROMETRIC PRESS <u>27.64</u>
PLANT LOCATION <u>Green River, WY</u>	PROBE I.D. <u>1/8"</u>	DUCT AREA <u>60.0</u>	PITOT COEFFICIENT <u>0.84</u>
TEST NUMBER <u>45412A-3</u>	NOZZLE I.D. <u>1/8"</u>	TEST DURATION <u>5.0</u>	METER Yd <u>1.828</u>
LOCATION <u>45412A - Scrubber</u>	NOZZLE DIA. <u>6.5"</u>	TRANSVERSE INTERVAL <u>278.125</u>	ORIFICE dia <u>1.8962</u>
PROJECT NO. <u>05-10-90</u>	FILTER TYPE <u>3007</u>	FILTER TEMP <u>278.125</u>	K FACTOR <u>2.0094</u>
DATE <u>1/27/91</u>	FILTER NO. <u>1521</u>	PROBE TEMP <u>1418</u>	START TIME <u>1521</u>
TECHNICIAN <u>J. Kishner/Hsu</u>		ASSUMED MOISTURE <u>39</u>	STOP TIME

PORT	PT.	TIME	OP	dH	METER TEMP		Ps	STACK TEMP (F)	METER VOL. (FT ³)		FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
F	1	0.0	0.36	1.08	9.2	9.2	10.15	16.2	7.98	6.3	25.9	6.4	5.0	23.0
	2	5.0	0.41	1.23	9.4	9.2	10.14	16.3	8.01	8.0	26.0	6.6	5.5	23.1
	3	10.0	0.43	1.29	9.4	9.2	10.15	16.2	8.05	8.5	26.2	6.4	6.0	23.4
	4	15.0	0.41	1.23	9.5	9.2	10.16	16.2	8.08	4.5	26.6	6.4	6.0	23.5
	5	20.0	0.40	1.20	9.5	9.2	10.15	16.1	8.11	7.8	27.8	6.4	6.0	22.9
	6	25.0	0.35	1.05	9.6	9.3	10.14	16.1	8.15	8.5	25.5	6.2	5.5	23.3
N	1	30.0	0.35	1.05	9.5	9.3	10.15	16.1	8.18	1.6	25.5	6.1	6.0	23.4
	2	35.0	0.39	1.17	9.3	9.1	10.15	16.3	8.21	2.6	25.5	6.1	6.0	23.3
	3	40.0	0.41	1.23	9.3	9.1	10.15	16.3	8.24	3.5	25.2	6.2	6.5	23.1
	4	45.0	0.40	1.20	9.3	9.1	10.15	16.4	8.27	5.8	25.1	6.2	7.0	22.8
	5	50.0	0.44	1.23	9.3	9.1	10.14	16.4	8.30	8.0	25.3	6.6	7.0	23.1
	6	55.0	0.38	1.14	9.2	9.0	10.14	16.3	8.34	4.0	24.9	6.7	6.5	22.9
		60.0							8.37	2.5				
AVERAGE			0.6255	1.1750		9.271	10.15	16.242	38.5	9.2				

MOISTURE DATE

DATA REDUCTION

LEAK CHECK DATA

INITIAL FINAL

WATER COLLECTED

Impinger 1 160
Impinger 2 100
Impinger 3 300
SILICA GEL 217.1
TOTAL 455.1

VELOCITY 44.29-46.93
MOISTURE 42.03
ISOKINETIC % 101.51
STD. VOLUME 51.06

START 0.008 CFME
END 0.001 CFME
17.0 °HG
9.0 °HG

TRC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Rhone-Poulenc
 PLANT LOCATION Green River, WY
 TEST NO. 4SC12A-7
 SAMPLING LOCATION 4SC12A-Scrubber
 TRC PROJECT NO. _____
 DATE 05-10-90
 TECHNICIAN J. Rosburg

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 29.64
 STACK PRESSURE +0.15
 AMBIENT TEMP 65
 PERCENT MOISTURE ~29
 COLLECTION TIME 1418-1510
 ANALYSIS TIME 1600

ORSAT EQUIPMENT CHECK

ORSAT CHECK: 	PRE-TEST LEAK CHECK: 	INITIAL <u>18.0</u> ML @ 0 MINUTES FINAL <u>18.0</u> ML @ 5 MINUTES PRE-TEST AMBIENT O2 <u>19.8</u>	
----------------------	------------------------------	---	--

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		
	ML	%	ML	%	ML	%	%
CO2	6.0	6.0	6.0	6.0			6.0
O2	18.0	12.0	18.0	12.0			12.0
CO							

COMMENTS:

EPA REFERENCE METHOD 5
FIELD DATA SHEET

SHEET 1 OF 1

TEST I.D.

EQUIPMENT

SITE I.D.

NONOXYGEN

FIRM NAME

PLANT LOCATION

TEST NUMBER

LOCATION

PROJECT NO.

DATE

TECHNICIAN

CONTROL BOX NO.

PISTON I.D.

NOZZLE I.D.

NOZZLE DIA.

FILTER TYPE

FILTERING

DUCT DIA.

TEST DURATION

TRAVEL TIME

PISTON TEMP

ASSUMED MOISTURE

DUCT DIA.

TEST DURATION

TRAVEL TIME

PISTON TEMP

ASSUMED MOISTURE

DUCT DIA.

TEST DURATION

TRAVEL TIME

PISTON TEMP

ASSUMED MOISTURE

DUCT DIA.

TEST DURATION

TRAVEL TIME

PISTON TEMP

ASSUMED MOISTURE

DUCT DIA.

TEST DURATION

TRAVEL TIME

PISTON TEMP

ASSUMED MOISTURE

PORT	PT.	TIME	dP	dH	METER TEMP IN	METER TEMP OUT	PS	STACK TEMP (F)	METER VOL. (FT3)	FILTER TEMP	COND. TEMP	PUMP VACUUM	PROBE TEMP
E	1	0.0	0.40	1.19	8.2	8.1	10.1	16.2	7.5	256	69	6.0	223
	2	5.0	0.43	1.28	8.3	8.1	10.1	16.0	7.6	258	57	7.5	226
	3	10.0	0.45	1.33	8.5	8.3	10.1	16.1	7.6	256	56	8.0	229
	4	15.0	0.41	1.22	8.7	8.7	10.1	16.2	7.6	258	57	8.0	230
	5	20.0	0.38	1.13	8.8	8.4	10.1	16.4	7.7	266	58	7.5	237
	6	25.0	0.33	0.99	8.9	8.5	10.1	16.3	7.7	248	58	9.0	235
N	1	20.0	0.36	1.07	8.7	8.6	10.1	16.3	7.7	255	59	7.5	238
	2	25.0	0.39	1.16	9.0	8.6	10.1	16.2	7.8	250	64	7.5	234
	3	30.0	0.42	1.25	9.1	8.7	10.1	16.2	7.8	251	64	8.5	235
	4	35.0	0.41	1.22	9.2	8.8	10.1	16.2	7.8	251	65	8.5	234
	5	40.0	0.40	1.19	9.3	8.8	10.1	16.1	7.9	250	65	8.5	233
	6	45.0	0.38	1.13	9.3	8.8	10.1	16.1	7.9	250	66	8.5	234
		60.0							7.9				
AVERAGE			0.6293	1.1800		86.75	10.15	16.192	37.025				

MOISTURE DATE

INITIAL

FINAL

WATER COLLECTED

Inflinger 1

Inflinger 2

Inflinger 3

SILICA GEL

TOTAL

DATA REDUCTION

VELOCITY

MOISTURE

ISOKINETIC %

STD. VOLUME

LEAK CHECK DATA

START 0.001 CFM@ 14 "HG

END 0.000 CFM@ 10.0 "HG

TRC

EPA REFERENCE METHOD 3 FIELD DATA SHEET

FIRM NAME Phase-Pulenc
 PLANT LOCATION Green River
 TEST NO. 45C12A-2
 SAMPLING LOCATION 45C12A-Scrubber
 TRC PROJECT NO. _____
 DATE 05-10-90
 TECHNICIAN J. Rosburg

SAMPLE TYPE Integrated
 BAROMETRIC PRESSURE 23.62
 STACK PRESSURE +0.14
 AMBIENT TEMP 65
 PERCENT MOISTURE ≈ 39
 COLLECTION TIME 1250-1345
 ANALYSIS TIME 1420

ORSAT EQUIPMENT CHECK

ORSAT CHECK:	PRE-TEST LEAK CHECK:	INITIAL <u>18.0</u> ML @ 0 MINUTES FINAL <u>18.0</u> ML @ 6 MINUTES PRE-TEST AMBIENT O2 <u>19.8</u>
--------------	----------------------	---

MOLECULAR WEIGHT DETERMINATION

RUN	1		2		3		AVERAGE
GAS	ACTUAL READING		ACTUAL READING		ACTUAL READING		%
	ML	%	ML	%	ML	%	
CO2	6.0	6.0	6.0	6.0			6.0
O2	17.8	11.8	17.8	11.8			11.8
CO							

COMMENTS: _____

Opacity data Summary

Unit	Date	Time	Reading
4SC-10	5-9	9:01	17.7
		9:23	16.9
		1:00	16.7
		1:20	15.4
		2:15	17.3
		3:16	19.2
		4:00	18.1
		4:30	17.3
		5:25	16.3
		6:00	18.3

7SC-12A	5-10	9:39	28.3
		10:01	25.2
		10:48	26.1
		11:14	25.0
		12:32	23.3
		1:21	21.5
		2:30	21.7

5ES-10	5-11	7:30	1.7
		9:57	2.3
		11:09	2.5

3S-12	5-11	8:14	11.7	5-12	9:51	13.8
		10:14	15.4		10:59	12.3
		11:00	11.0			
		12:45	7.9			

OPACITY WORKSHEET

STACK ASC-10
 PROD RATE _____TPH
 ΔP _____

DATE 5-7-90
 TECH jm
 TIME 9.01 to 9.09
 WIND SPEED 10-15 MPH
 WIND DIRECTION _____
 RELATIONSHIP TO NORTH

LAYOUT OF AREA



17.7
 24
 17.5
 16.8
 1.70

6-7 H

20.5 - 3.00

READINGS

1. <u>15</u>	9. <u>15</u>	17. <u>20</u>
2. <u>15</u>	10. <u>15</u>	18. <u>25</u>
3. <u>20</u>	11. <u>25</u>	19. <u>20</u>
4. <u>20</u>	12. <u>20</u>	20. <u>20</u>
5. <u>25</u>	13. <u>15</u>	21. <u>15</u>
6. <u>20</u>	14. <u>15</u>	22. <u>15</u>
7. <u>15</u>	15. <u>15</u>	23. <u>15</u>
8. <u>15</u>	16. <u>15</u>	24. <u>15</u>
145	135	145

TOTAL 725 AVERAGE 17.7 % OPACITY

OPACITY WORKSHEET

STACK 451-10

PROD RATE _____ TPH

ΔP _____

LAYOUT OF AREA

DATE 5-9-90

TECH pin

TIME 1.23 to _____

WIND SPEED 10 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH

↑N
→W

16.8
24405
24
165
144
210
192
18

6-7H

cosun

READINGS

1. 15

2. 20

3. 15

4. 15

5. 20

6. 15

7. 20

8. 15

135

9. 25

10. 15

11. 20

12. 15

13. 20

14. 15

15. 15

16. 15

190

17. 15

18. 15

19. 15

20. 15

21. 20

22. 20

23. 15

24. 15

130

TOTAL 405

AVERAGE 16.9 % OPACITY

OPACITY WORKSHEET

STACK ASC-10

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE 5-9-90

TECH im

TIME 1:00 to _____

WIND SPEED 15-20 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH

↑ N
↓ W

16.7
29/400
29
160
144
16

6-7 H

507.5 m

READINGS

1. 15

2. 15

3. 20

4. 15

5. 10

6. 15

7. 15

8. 15

120

9. 25

10. 20

11. 15

12. 20

13. 20

14. 20

15. 15

16. 15

150

17. 20

18. 15

19. 15

20. 15

21. 10

22. 15

23. 20

24. 20

130

TOTAL 400

AVERAGE 16.7 % OPACITY

OPACITY WORKSHEET

STACK 480-10

PROD RATE _____ TPH

ΔP _____

LAYOUT OF AREA

DATE 5-9-70

TECH pin

TIME 120 to _____

WIND SPEED 10-15 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH

↑ N
→ W

15.4
24/365
24/125
120/50
6-7H

0'

50' S W

READINGS

1. 10

2. 10

3. 15

4. 20

5. 15

6. 20

7. 20

8. 20
130

9. 20

10. 15

11. 15

12. 20

13. 15

14. 15

15. 15

16. 20
135

17. 20

18. 15

19. 10

20. 10

21. 10

22. 10

23. 15

24. 10
100

TOTAL 365

AVERAGE 15.4 % OPACITY

OPACITY WORKSHEET

STACK 4SC-10

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE 5-9-90

TECH rm

TIME 215 to _____

WIND SPEED 10-15 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH

12
13

17.3
415
24
175
168
70

20 SUM

READINGS

1. 20

2. 20

3. 20

4. 15

5. 15

6. 20

7. 15

8. 15

140

9. 20

10. 15

11. 15

12. 15

13. 20

14. 20

15. 15

16. 15

135

17. 20

18. 20

19. 15

20. 20

21. 15

22. 20

23. 15

24. 15

140

TOTAL 415

AVERAGE 17.3 % OPACITY

OPACITY WORKSHEET

STACK 4SC-10

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE 5-9-90

TECH jm

TIME 316 to _____


WIND SPEED 10-15 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



17.1
24 460
24
220
216
44
16



READINGS

1. 15

2. 20

3. 25

4. 15

5. 20

6. 10

7. 20

8. 25
150

9. 15

10. 25

11. 20

12. 15

13. 25

14. 20

15. 15

16. 20
155

17. 20

18. 20

19. 25

20. 25

21. 20

22. 20

23. 15

24. 10
155

TOTAL 460

AVERAGE 19.2 % OPACITY

OPACITY WORKSHEET

STACK 4SC-10

PROD RATE _____ TPH

ΔP _____

LAYOUT OF AREA

DATE 5-9-90


TECH irm

TIME 400 to _____

WIND SPEED 10-15 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



18.1
24/435
24/195
192/304
146

6H

203 Sun

READINGS

1. 15
2. 20
3. 25
4. 20
5. 15
6. 20
7. 15
8. 15
145

9. 15
10. 20
11. 15
12. 15
13. 20
14. 20
15. 20
16. 15
140

17. 15
18. 20
19. 20
20. 15
21. 25
22. 20
23. 15
24. 20
150

TOTAL 435

AVERAGE 18.1 % OPACITY

OPACITY WORKSHEET

STACK 45A-10

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE 5-9-70


TECH jm

TIME 430 to _____

WIND SPEED 10-15 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



17.3
24/415
24
175
168/70

4
203-Sun

READINGS

1. 15

2. 15

3. 15

4. 20

5. 20

6. 15

7. 20

8. 15

135

9. 15

10. 15

11. 15

12. 20

13. 20

14. 15

15. 15

16. 15

130

17. 20

18. 25

19. 15

20. 20

21. 20

22. 20

23. 15

24. 15

150

TOTAL 415

AVERAGE 17.3 % OPACITY

OPACITY WORKSHEET

5-9-70

STACK 4SC 10

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE _____

TECH jm

TIME 525 to _____

WIND SPEED 10-15 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH

W →
← N

16.3
24 | 390
24
150
144
6

} 4
Sur

READINGS

1. 15
2. 15
3. 20
4. 15
5. 15
6. 15
7. 15
8. 15
125

9. 15
10. 10
11. 15
12. 20
13. 20
14. 15
15. 10
16. 15
120

17. 20
18. 20
19. 15
20. 20
21. 15
22. 20
23. 20
24. 15
145

TOTAL 390

AVERAGE 16.3 % OPACITY

OPACITY WORKSHEET

STACK 450-10
 PROD RATE _____TPH
 ΔP _____

DATE 5-9-90
 TECH jm
 TIME 600 to _____
 WIND SPEED 10-15 MPH
 WIND DIRECTION _____
 RELATIONSHIP TO NORTH ↖ N ↗

LAYOUT OF AREA

18.3
 24/440
 24
 200
 192
 80
 72

4

 SUN

READINGS

1. <u>20</u>	9. <u>20</u>	17. <u>15</u>
2. <u>20</u>	10. <u>25</u>	18. <u>15</u>
3. <u>25</u>	11. <u>20</u>	19. <u>15</u>
4. <u>20</u>	12. <u>15</u>	20. <u>20</u>
5. <u>20</u>	13. <u>25</u>	21. <u>10</u>
6. <u>15</u>	14. <u>15</u>	22. <u>20</u>
7. <u>15</u>	15. <u>20</u>	23. <u>20</u>
8. <u>15</u>	16. <u>15</u>	24. <u>20</u>
150	15	135

TOTAL 440

AVERAGE 18.3 % OPACITY

282-2367
10/17/70
10/17/70

OPACITY WORKSHEET

STACK 4SC-12A

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE 5-10-70


TECH jm

TIME 939 to _____

WIND SPEED 0-5 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



28.3
241680
48
200
19280
92

4

W. Sun

READINGS

1. 30

2. 35

3. 30

4. 25

5. 20

6. 20

7. 30

8. 35

225

9. 35

10. 25

11. 20

12. 35

13. 25

14. 20

15. 25

16. 35

220

17. 25

18. 30

19. 20

20. 30

21. 35

22. 35

23. 30

24. 30

235

TOTAL 680

AVERAGE 28.3 % OPACITY

OPACITY WORKSHEET

STACK 450-12A

PROD RATE _____TPH

ΔP _____

DATE 5-10-70

TECH jm

TIME 1001 to _____

WIND SPEED 0-5 MPH

WIND DIRECTION _____

RELATIONSHIP TO NORTH _____

LAYOUT OF AREA



25.2
25
247605
48/5
12250
24/1



READINGS

1. 20
2. 25
3. 20
4. 30
5. 20
6. 25
7. 20
8. 30
190

9. 35
10. 25
11. 25
12. 30
13. 30
14. 30
15. 25
16. 20
220

17. 25
18. 30
19. 20
20. 25
21. 25
22. 20
23. 25
24. 25
175

TOTAL 605

AVERAGE 25.2 % OPACITY

OPACITY WORKSHEET

STACK 130-12A

PROD RATE _____ TPH

ΔP _____

LAYOUT OF AREA

DATE 5-10-80


TECH Jim

TIME 1047 to _____

WIND SPEED 0-5 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



26
24 | 625
48
145
145
210



READINGS

1. 25
2. 20
3. 20
4. 15
5. 30
6. 35
7. 25
8. 20
190

9. 30
10. 30
11. 25
12. 30
13. 30
14. 25
15. 30
16. 25
225

17. 20
18. 20
19. 30
20. 25
21. 35
22. 20
23. 35
24. 25
210

TOTAL 625

AVERAGE 26.1 % OPACITY

OPACITY WORKSHEET

STACK 45L-12A

PROD RATE _____ TPH

ΔP _____

LAYOUT OF AREA

DATE 5-10-90

TECH im

TIME 11:14 to _____

WIND SPEED 0-5 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



*Interferens
w/ 38S-10*

*25
24 1600
98
120*

500

READINGS

1. 30
2. 25
3. 25
4. 25
5. 35
6. 20
7. 20
8. 20
200

9. 25
10. 20
11. 25
12. 20
13. 20
14. 25
15. 25
16. 20
170

17. 25
18. 30
19. 30
20. 25
21. 30
22. 20
23. 25
24. 25
210

TOTAL 600

AVERAGE 25 % OPACITY

OPACITY WORKSHEET

STACK 450-12

PROD RATE _____ TPH

ΔP _____

LAYOUT OF AREA

DATE 5-10-90

TECH js

TIME 1232 to _____

WIND SPEED 0-5 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH

↑ N
↘ W

23
24 | 560
48
80
78

4

sun

READINGS

1. 25

2. 20

3. 20

4. 25

5. 20

6. 30

7. 25

8. 20

185

9. 20

10. 30

11. 25

12. 20

13. 15

14. 20

15. 25

16. 35

190

17. 25

18. 20

19. 15

20. 20

21. 30

22. 25

23. 25

24. 15

185

TOTAL 560

AVERAGE 23.3 % OPACITY

OPACITY WORKSHEET

5-10

STACK 430- 12 A

DATE _____

PROD RATE _____ TPH

TECH jm

ΔP _____

TIME 127 to _____

WIND SPEED 5 MPH

WIND DIRECTION _____

LAYOUT OF AREA

RELATIONSHIP TO NORTH



21.4
24/515
48
35
24/0
110
96
14

sun

READINGS

1. 20

9. 20

17. 15

2. 20

10. 25

18. 20

3. 25

11. 25

19. 20

4. 15

12. 20

20. 20

5. 20

13. 25

21. 20

6. 25

14. 25

22. 20

7. 20

15. 30

23. 15

8. 20

16. 25

24. 25

165

175

155

TOTAL 515

AVERAGE 21.5 % OPACITY

OPACITY WORKSHEET

STACK 122-1000

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE _____

TECH 5-10-70

TIME 230 to _____


WIND SPEED 5-10 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



21.7
24/520
48
40
24
160



READINGS

1. 15

2. 20

3. 30

4. 20

5. 15

6. 15

7. 25

8. 20

160

9. 15

10. 25

11. 25

12. 20

13. 15

14. 15

15. 15

16. 25

15

17. 30

18. 25

19. 30

20. 30

21. 25

22. 20

23. 20

24. 25

205

TOTAL 520

AVERAGE 21.7 % OPACITY

OPACITY WORKSHEET

5-11-90

STACK 588 10

DATE _____

TECH 4 m

PROD RATE _____ TPH

TIME 7:30 to _____

ΔP _____

WIND SPEED 5-10 MPH

WIND DIRECTION _____

LAYOUT OF AREA

RELATIONSHIP TO NORTH

*cloudy
hard to read
but looks good*

*21 40
24
1 1/2
144
16*

34

READINGS

1. 0

9. 0

17. 5

2. 5

10. 0

18. 0

3. 0

11. 0

19. 0

4. 0

12. 0

20. 0

5. 0

13. 5

21. 5

6. 5

14. 5

22. 5

7. 5

15. 0

23. 0

8. 0

16. 0

24. 0

15

10

15

TOTAL 40

AVERAGE 1.7 % OPACITY

OPACITY WORKSHEET

STACK 59-10

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE 5-11-70


TECH 100

TIME 8:26 to _____

WIND SPEED 5-10 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



100
Condy

READINGS

1. 5

9. _____

17. _____

2. 5

10. _____

18. _____

3. 5

11. _____

19. _____

4. 5

12. _____

20. _____

5. 0

13. _____

21. _____

6. 0

14. _____

22. _____

7. 0

15. _____

23. _____

8. _____

16. _____

24. _____

TOTAL _____

AVERAGE _____ % OPACITY

OPACITY WORKSHEET

STACK 550 10

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE 5-11-90

TECH Jim

TIME 957 to _____

WIND SPEED 5-15 MPH

WIND DIRECTION 70 ↗ N

RELATIONSHIP TO NORTH

2nd
2155
42
10

34

205 Sum

READINGS

1. 0

2. 5

3. 0

4. 0

5. 5

6. 0

7. 5

8. 5
20

9. 0

10. 5

11. 0

12. 5

13. 5

14. 0

15. 0

16. 5
20

17. 0

18. 5

19. 0

20. 0

21. 0

22. 5

23. 5

24. 0
15

TOTAL 55

AVERAGE 2.3 % OPACITY

OPACITY WORKSHEET

5-11

STACK 50010

PROD RATE _____ TPH

ΔP _____

DATE _____

TECH AM

TIME 1107 to _____

WIND SPEED 10 MPH

WIND DIRECTION ↗ N

LAYOUT OF AREA

RELATIONSHIP TO NORTH

2.5
24/60
42/18

2

READINGS

1. 5

2. 5

3. 5

4. 0

5. 0

6. 0

7. 5

8. 0

9. 0

10. 5

11. 0

12. 0

13. 5

14. 5

15. 5

16. 0

17. 0

18. 5

19. 0

20. 5

21. 5

22. 0

23. 5

24. 0

TOTAL 60

AVERAGE 2.5 % OPACITY

OPACITY WORKSHEET

STACK 588-12

PROD RATE _____TPH

ΔP _____

LAYOUT OF AREA

DATE 5-11-70

TECH mm

TIME 814 to _____

WIND SPEED 5.0 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH

Handwritten notes:
 ↑ W
 ↗ N
 (with additional scribbles)

Handwritten calculations:

$$\begin{array}{r} 11.66 \\ \times 20 \\ \hline 233.20 \\ \times 10 \\ \hline 2332.00 \\ \hline 23320.00 \end{array}$$

Handwritten: 3H

READINGS

1. 10

2. 5

3. 10

4. 10

5. 15

6. 10

7. 5

8. 15
80

9. 10

10. 15

11. 15

12. 15

13. 15

14. 10

15. 15

16. 10
105

17. 10

18. 10

19. 15

20. 10

21. 15

22. 15

23. 10

24. 10
75

TOTAL 280

AVERAGE 11.7 % OPACITY

OPACITY WORKSHEET

STACK 583-12
 PROD RATE _____ TPH
 ΔP _____

DATE _____ 5-11-70
 TECH Jim
 TIME 1014 to _____
 WIND SPEED 10-15 MPH
 WIND DIRECTION _____
 RELATIONSHIP TO NORTH _____

LAYOUT OF AREA

15.4
 24 | 370
 24
 130
 120
 110
 100
 90
 80
 70
 60
 50
 40
 30
 20
 10
 0

7 1/2 ft

READINGS

1. <u>15</u>	9. <u>15</u>	17. <u>10</u>
2. <u>15</u>	10. <u>20</u>	18. <u>10</u>
3. <u>20</u>	11. <u>15</u>	19. <u>15</u>
4. <u>10</u>	12. <u>10</u>	20. <u>10</u>
5. <u>25</u>	13. <u>15</u>	21. <u>10</u>
6. <u>10</u>	14. <u>15</u>	22. <u>15</u>
7. <u>15</u>	15. <u>20</u>	23. <u>20</u>
8. <u>20</u>	16. <u>20</u>	24. <u>20</u>
1130	110	

TOTAL 370

AVERAGE 15.4 % OPACITY

OPACITY WORKSHEET

DATE _____

5-11-70

STACK 58012

TECH irm

PROD RATE _____ TPH

TIME 1100 to _____

ΔP _____

WIND SPEED 10-15 MPH

WIND DIRECTION

7^(W) N

LAYOUT OF AREA

RELATIONSHIP TO NORTH

1100
24 2165
24 58
24 1

3H

READINGS

1. 10

9. 20

17. 10

2. 10

10. 10

18. 10

3. 10

11. 15

19. 10

4. 5

12. 15

20. 5

5. 10

13. 20

21. 10

6. 10

14. 5

22. 10

7. 20

15. 10

23. 10

8. 10

16. 15

24. 5

75

110

110

TOTAL 265

AVERAGE 11.0 % OPACITY

OPACITY WORKSHEET

5-11-70

STACK 5FC-12

DATE _____

PROD RATE _____ TPH

TECH pin

ΔP _____

TIME 1245 to _____

WIND SPEED 5-10 MPH

WIND DIRECTION _____

LAYOUT OF AREA _____

RELATIONSHIP TO NORTH _____

16
↑ N

79.
24 | 190
168
220

107 Sun

READINGS

1. 10

9. 15

17. 10

2. 5

10. 5

18. 5

3. 5

11. 10

19. 10

4. 10

12. 15

20. 5

5. 5

13. 10

21. 5

6. 10

14. 10

22. 10

7. 10

15. 5

23. 5

8. 5

16. 5

24. 5

60

7"

TOTAL 190

AVERAGE 7.9 % OPACITY

OPACITY WORKSHEET

DATE _____

5-12-90

STACK 585R

TECH 100

PROD RATE _____ TPH

TIME 951 to 959

ΔP _____

WIND SPEED 10-15 MPH

WIND DIRECTION _____

RELATIONSHIP TO NORTH _____

LAYOUT OF AREA

10
↑
N

13.7
24 | 330
24
90
72
18
168
12

3

10-15

READINGS

1. 10

9. 15

17. 15

2. 15

10. 10

18. 15

3. 15

11. 15

19. 20

4. 10

12. 15

20. 10

5. 15

13. 15

21. 15

6. 10

14. 10

22. 15

7. 20

15. 10

23. 15

8. 15

16. 10

24. 15

110

100

120

TOTAL 330

AVERAGE 13.8 % OPACITY

OPACITY WORKSHEET

5-12-90

STACK 582 12

PROD RATE _____ TPH

ΔP _____

LAYOUT OF AREA

DATE _____


TECH pm

TIME 1059 to _____

WIND SPEED 10-15 MPH

WIND DIRECTION

RELATIONSHIP TO NORTH



Handwritten:
 24 | 295
 24

 582
 12.3
 40

Handwritten: (S) - Sun

READINGS

1. 10
 2. 10
 3. 15
 4. 15
 5. 10
 6. 10
 7. 10
 8. 10
 90

9. 15
 10. 15
 11. 10
 12. 10
 13. 15
 14. 15
 15. 10
 16. 10
 100

17. 10
 18. 15
 19. 15
 20. 15
 21. 10
 22. 15
 23. 15
 24. 10
 105

TOTAL 295

AVERAGE 12.3 % OPACITY