


The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

MEMORANDUM



TO: GENERAL CHEMICAL COMPANY COMPLIANCE FILE

THROUGH: CHARLES COLLINS, ADMINISTRATOR, AQD
BERNIE DAILEY, ENGINEERING SUPERVISOR, AQD

FROM: DAN OLSON, COMPLIANCE OFFICER, AQD *Dan Olson*

DATE: DECEMBER 7, 1990

SUBJECT: COMPLIANCE TEST FOR GR-3-A CRUSHER STACK (MD-121)

On October 22, 1990, the Division received a copy of the test report for the stack test performed on the GR-3-A emission source located at the General Chemical Trona plant near Green River, Sweetwater County, Wyoming. This test effort was conducted on September 24 and 25, 1990. The test series was a Reference Method 5 series for particulate mass emission rate conducted for General Chemical by The Emission Measurement People (TEMP) of Canon City, Colorado.

Lee Gribovitz, Air Quality District Engineer, was on-site for this test effort and observed the test setup and procedures, which he found to be satisfactory. This source is an NSPS Subpart 000 source which is subject to an emission limit of 0.05 grams/dscm (0.02 gr/dscf), with a maximum of seven (7) percent opacity. Additionally, Air Quality Permit MD-121 places a cap on the mass limit of 2.0 lb/hr. Mr. Gribovitz explained to both General Chemical and TEMP personnel that the Division would require both front and back half analyses on this test. He indicated that the front half would be used for comparison against the NSPS standard and the total catch would be used to compare against the mass emission cap in lb/hr stated in the permit. Throughout the day, Mr. Gribovitz observed the stack with no visible emissions.

The raw test data included with the test report were reviewed for consistency and emission rate calculations were independently performed by the division to compare with those of the testing contractor. No significant differences were noted. The results of this evaluation are summarized below and included as attachments to this memo:

TESTED EMISSION RATES

	<u>AQD</u>	<u>TEMP</u>	<u>ALLOWABLE</u>
FRONT HALF gr/dscf	0.0057	0.0058	0.02 (NSPS)
1b/hr	0.7890	0.7970	-----
TOTAL CATCH gr/dscf	0.0165	0.0167	-----
1b/hr	2.243	2.268	2.0 (MD-121)

Based on the results of this analysis, it appears that the GR-3-A stack on the day of this test series was operating within the requirements of NSPS Subpart 000 for emission rate and opacity but was exceeding the mass cap of 2.0 lb/hr set for this source by permit conditions in MD-121.

cc: Lee Gribovici

STACK TEST CALCULATIONS

SOURCE: General Chemical Company, GR3A Crusher - FRONT HALF

TESTED BY: Ross & Scappaticci
The Emission Measurement People

DATE TESTED: 09/24/90 thru 09/25/90

OBSERVED BY: Lee Gribovicz

EVALUATED BY: Dan Olson

TEST #1 TEST #2 TEST #3

AMBIENT PRESSURE (in Hg)	2.391E+01	2.381E+01	2.382E+01
ABS. STACK GAS PRESSURE (in Hg)	2.396E+01	2.386E+01	2.388E+01
ABS. AVE. STACK GAS TEMP (*R)	5.423E+02	5.503E+02	5.429E+02
ABS. AVE. DGM TEMP (*R)	5.432E+02	5.548E+02	5.505E+02
TOT. VOL. H2O COLLECTED (ml)	6.130E+01	6.470E+01	5.960E+01
VOL. THRU DGM (ft ³)	6.233E+01	7.068E+01	6.871E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	2.252E+00	2.542E+00	2.400E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	7.680E-01	8.190E-01	8.050E-01
STD VOL. SAMPLED (scf)	4.873E+01	5.393E+01	5.283E+01
H2O VAPOR IN GAS @STP (ft ³)	2.885E+00	3.045E+00	2.805E+00
MOL. WT. WET (1b/lb mole)	2.827E+01	2.837E+01	2.829E+01
MOL. WT. DRY (1b/lb mole)	2.888E+01	2.896E+01	2.884E+01
VEL. STACK GAS (fps)	4.934E+01	5.302E+01	5.181E+01
FLOW RATE, DRY @ STP (scfm)	1.540E+04	1.629E+04	1.620E+04
CONCENTRATION (gr/scf)	3.924E-03	2.945E-03	1.035E-02
CONCENTRATION (lb/scf)	5.606E-07	4.207E-07	1.478E-06
EMISSION RATE (lb/hr)	5.181E-01	4.111E-01	1.437E+00
% ISOKINETIC	9.113E+01	9.541E+01	9.397E+01

Average: 0.0057 gr/scf
0.789 lb/hr

STACK TEST CALCULATIONS

* SOURCE: General Chemical Company, GR3A Crusher-- BACK HALF

* TESTED BY: Ross & Scappaticci
The Emission Measurement People

* DATE TESTED: 09/24/90 thru 09/25/90

* OBSERVED BY: Lee Gribovitz

* EVALUATED BY: Dan Olson

	TEST #1	TEST #2	TEST #3
AMBIENT PRESSURE (in Hg)	2.391E+01	2.381E+01	2.382E+01
ABS. STACK GAS PRESSURE (in Hg)	2.396E+01	2.386E+01	2.388E+01
ABS. AVE. STACK GAS TEMP (*R)	5.423E+02	5.503E+02	5.429E+02
ABS. AVE. DGM TEMP (*R)	5.432E+02	5.548E+02	5.505E+02
TOT. VOL. H2O COLLECTED (ml)	6.130E+01	6.470E+01	5.960E+01
VOL. THRU DGM (ft3)	6.233E+01	7.068E+01	6.871E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	2.252E+00	2.542E+00	2.400E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	7.680E-01	8.190E-01	8.050E-01
STD VOL. SAMPLED (scf)	4.873E+01	5.393E+01	5.283E+01
H2O VAPOR IN GAS @STP (ft3)	2.885E+00	3.045E+00	2.805E+00
MOL. WT. WET (lb/lb mole)	2.827E+01	2.837E+01	2.829E+01
MOL. WT. DRY (lb/lb mole)	2.888E+01	2.896E+01	2.884E+01
VEL. STACK GAS (fps)	4.934E+01	5.302E+01	5.181E+01
FLOW RATE, DRY @ STP (scfm)	1.540E+04	1.629E+04	1.620E+04
CONCENTRATION (gr/scf)	1.968E-02	6.090E-03	6.596E-03
CONCENTRATION (lb/scf)	2.812E-06	8.700E-07	9.424E-07
EMISSION RATE (lb/hr)	2.599E+00	8.501E-01	9.158E-01
% ISOKINETIC	9.113E+01	9.541E+01	9.397E+01

Average: 0.0108 gr/dscf
1,455 lb/hr.

STACK TEST CALCULATIONS

SOURCE: General Chemical Company, GR3A Crusher -TOTAL

TESTED BY: Ross & Scappaticci
The Emission Measurement People

DATE TESTED: 09/24/90 thru 09/25/90

OBSERVED BY: Lee Gribovitz

EVALUATED BY: Dan Olson

	TEST #1	TEST #2	TEST #3
AMBIENT PRESSURE (in Hg)	2.391E+01	2.381E+01	2.382E+01
ABS. STACK GAS PRESSURE (in Hg)	2.396E+01	2.386E+01	2.388E+01
ABS. AVE. STACK GAS TEMP (*R)	5.423E+02	5.503E+02	5.429E+02
ABS. AVE. DGM TEMP (*R)	5.432E+02	5.548E+02	5.505E+02
TOT. VOL. H2O COLLECTED (ml)	6.130E+01	6.470E+01	5.960E+01
VOL. THRU DGM (ft3)	6.233E+01	7.068E+01	6.871E+01
AVE. DEL P ACROSS ORIFICE (in H2O)	2.252E+00	2.542E+00	2.400E+00
PITOT TUBE COEFFICIENT	8.400E-01	8.400E-01	8.400E-01
AVE. VEL. HEAD OF STACK GAS (in H2O)	7.680E-01	8.190E-01	8.050E-01
STD VOL. SAMPLED (scf)	4.873E+01	5.393E+01	5.283E+01
H2O VAPOR IN GAS @STP (ft3)	2.885E+00	3.045E+00	2.805E+00
MOL. WT. WET (1b/1b mole)	2.827E+01	2.837E+01	2.829E+01
MOL. WT. DRY (1b/1b mole)	2.888E+01	2.896E+01	2.884E+01
VEL. STACK GAS (fps)	4.934E+01	5.302E+01	5.181E+01
FLOW RATE, DRY @ STP (scfm)	1.540E+04	1.629E+04	1.620E+04
CONCENTRATION (gr/scf)	2.361E-02	9.035E-03	1.693E-02
CONCENTRATION (lb/scf)	3.373E-06	1.291E-06	2.418E-06
EMISSION RATE (lb/hr)	3.117E+00	1.261E+00	2.350E+00
% ISOKINETIC	9.113E+01	9.541E+01	9.397E+01

Average: 0.0165 gr/dscf

2,243 lb/hr.

General Chemical Company

GR3A Crusher

9/24-25/60

Data Sheet

Emission Measurement Report

Ross & ~~Scappaticci~~

P_{std} = 29.92 in Hg

Scappaticci

T_{std} = 550° R

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>
P_{bar} = barometric pressure at site (in Hg)	<u>23.91</u>	<u>23.81</u>	<u>23.82</u>
P_s = absolute stack gas pressure (in Hg)	<u>23.96</u>	<u>23.86</u>	<u>23.88</u>
T_s = absolute average stack gas temp. (°R)	<u>542.3</u>	<u>530.3</u>	<u>542.9</u>
T_m = absolute average dry gas meter temp. (°R)	<u>543.2</u>	<u>534.75</u>	<u>550.5</u>
V_{ic} = total volume of water collected (ml)	<u>61.3</u>	<u>64.7</u>	<u>59.6</u>
V_m = volume of gas through dry gas meter (ft ³)	<u>62.326</u>	<u>70.68</u>	<u>68.71</u>
ΔH = average pressure drop across orifice (in H ₂ O)	<u>2.252</u>	<u>2.542</u>	<u>2.40</u>
C_p = pitot tube coefficient	<u>0.84</u>	<u>0.84</u>	<u>0.84</u>
$(\frac{DP}{L})_{ave}$ = average velocity head of stack gas (in H ₂ O)	<u>0.768</u>	<u>0.819</u>	<u>0.805</u>
A_s = cross-sectional area of stack (ft ²)	<u>7.0686</u>	<u>7.0686</u>	<u>7.0686</u>
M_p = total amount of particulate collected ^{Front Back Half} (lb/m)	<u>0.0124</u>	<u>0.0103</u>	<u>0.03545</u>
t = total sampling time (min.)	<u>72</u>	<u>72</u>	<u>72</u>
A_n = cross-sectional area of nozzle (ft ²)	<u>0.000341</u>		→

Orsat Analysis

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>
% CO ₂	<u>1</u>	<u>2</u>	<u>1</u>
% O ₂	<u>18</u>	<u>16</u>	<u>17</u>
% CO	<u>0</u>	<u>6</u>	<u>0</u>
% N ₂	<u>81</u>	<u>82</u>	<u>82</u>

The Emission Measurement People, Inc.

P.O. Box 935, CANON CITY, CO 81215-0935


Nationwide Watts: 1 800 222-4187

Office Phone: 719 275-0046

October 18, 1990

Wyoming Dept. of Environmental Quality
Division of Air Quality
210 Lincoln Street
L A N D E R, WY 82520

ATTN: Mr. Lee Gribovicz, District Engineer



RE: Submittal of Emission Measurement Test Report
For Particulate Emissions
GR3A Crusher, General Chemical Corporation, Green River, WY

Dear Mr. Gribovicz:

On behalf of General Chemical Corporation, The Emission Measurement People, Inc. are pleased to submit one copy of the subject compliance test report of the emission measurement project which we recently conducted at their GR3A Crusher near Green River.

Should you have any questions about the project or the report, please give us a call anytime. We have enjoyed working with you and General Chemical Corporation.

Very Truly Yours,

Petra LaChance
Petra LaChance
Administrator

JRF/p1

Enclosure(s): (1)

cc: Mr. Mike Wendorf, Environmental Technician, General Chemical Corporation
(2 Report copies)
Mr. Bernard Dailey, Wyoming DEQ, Cheyenne, WY 82002 (1 Report copy)
Mr. John R. Floyd, Principal, The Emission Measurement People, Inc.

FLUNKED

EMISSION MEASUREMENT TEST REPORT

of

GR3A Crusher Compliance Testing for Particulate Emission(s)

GR3A

General Chemical Corporation, Green River, Wyoming
Test Date: September 24-25, 1990

Prepared for:

General Chemical Corporation

West of Green River
GREEN RIVER, WY 82935
Mr. Mike D. Wendorf, Environmental Technician
Phone: 307 872-3621

Submitted to:

Wyoming Department of Environmental Quality Division of Air Quality

210 Lincoln Street
Lander, WY 82520
Mr. Lee Gribovicz, District Engineer
Phone: 307 332-6755.

Prepared by:

The Emission Measurement People, Inc.

P.O. Box 935, CANON CITY, CO 81215-0935
John R. Floyd, Technical Operations Director
Nationwide Watts: 800-222-4187
Office Phone: 719 275-0046

Report Date: October 16, 1990

EMISSION MEASUREMENT TEST REPORT

of

GR3A Crusher Compliance Testing for Particulate Emission(s)

GR3A

General Chemical Corporation, Green River, Wyoming
Test Date: September 24-25, 1990

Prepared for:

General Chemical Corporation

West of Green River
GREEN RIVER, WY 82935

Mr. Mike D. Wendorf, Environmental Technician
Phone: 307 872-3621

Submitted to:

Wyoming Department of Environmental Quality Division of Air Quality

210 Lincoln Street
Lander, WY 82520
Mr. Lee Gribovicz, District Engineer
Phone: 307 332-6755

Prepared by:

The Emission Measurement People, Inc.

P.O. Box 935, CANON CITY, CO 81215-0935
John R. Floyd, Technical Operations Director
Nationwide Watts: 800-222-4187
Office Phone: 719 275-0046

Report Date: October 16, 1990

CONTENTS OF EMISSION MEASUREMENT TEST REPORT

GR3A Crusher
for Particulate Emission(s)
General Chemical Corporation, Green River, Wyoming

<u>Section</u>	<u>Page</u>
Review, Certification, and Acceptance of Report	
<u>1.0 Introduction and Project Overview</u>	1
1.1 Tables for Section 1.0	2
Table 1-1 AGENCY, COMPANY, and PLANT INFORMATION	3
Table 1-2 REGULATIONS, EMISSION LIMITS, and PRIOR TESTS	4
<u>2.0 Results Summary and Conclusions</u>	5
2.1 Determination of Compliance	5
2.2 Tables for Section 2.0	6
Table 2-1 SUMMARY of PROCESS & EMISSION MEASUREMENT RESULTS	7
3.1 Quality Assurance (QA) Documentation	8
3.1.1 <u>Records Reference Document</u>	8
3.1.2 Manual Methods QA	9
3.1.3 Instrumental Methods QA	10
3.1.4 Data Collection and Reduction QA	10
3.1.5 Chain-of-Custody for Data and Sample(s)	11
3.2 Project Activity Log and Personnel	12
3.3 Plant Operation and Production	12
3.4 Location of Test Port(s) and Sampling Point(s)	12
3.5 Sampling and Analytical Procedures and Modifications	13
3.5.1 Description of Sampling Equipment	13
3.5.2 Measurement of Pollutant Emissions	13
3.5.3 Measuring Non-Pollutant Flue Gas Parameters	13
3.5.4 Laboratory Analyses	14
3.6 Detailed Test Results and Discussion	15
3.7 Tables for Section 3.0	16
Table 3-1(a)QA DOCUMENTATION - CALIBRATIONS	17
Table 3-1(b)QA DOCUMENTATION - AUDIT CHECKS	18
Table 3-1(c)QA DOCUMENTATION - QA CHECKS	19
Table 3-2 PROJECT PERSONNEL	20
Table 3-3 PLANT OPERATION and PRODUCTION, by Run	21
Table 3-4 TEST PORT(S) and SAMPLING POINT(S)	22
Table 3-5(a)TEST METHOD SPECIFICATIONS	23
Table 3-5(b)INSTRUMENTAL EQUIPMENT SPECIFICATIONS	24
Table 3-5(c)LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS	25
Table 3-6(R)TEST RESULTS, by RUN	26
Table 3-7(R)SAMPLING and ANALYTICAL DATA, by RUN	27

Figure 3-1 STACK CONFIGURATION and PORT LOCATION(S)	28
<u>4.0 Appendices</u>	29
4.1 Project Documentation	
4.1.1 Correspondence	
4.1.2 Compliance Test Protocol (Title Sheet and Contents)	
4.1.3 <u>Records Reference Document</u> (Title Sheet and Contents)	
4.1.4 Project Activities Log	
4.2 Quality Assurance Documentation	
4.2.1 Q.A. Audit Results (if applicable)	
4.2.2 Post-test Calibrations (if applicable)	
4.2.3 Chain-of-Custody for Data and Sample(s)	
4.3 Plant Operation and Production Data (as available)	
4.4 Field Sampling Data Records	
4.4.1 Data Sheets for Reference Methods	
4.4.2 Emission Data Printouts from CEM Tests	
4.4.3 Drift Records for CEM Tests	
4.5 Laboratory Analytical Results	
4.6 Calculations and Computer Printouts	


CERTIFICATION, REVIEW, and ACCEPTANCE of REPORT

*** This Emission Measurement Compliance Test Report was compiled and prepared by the Project Leader for The Emission Measurement People, Inc., using data collected by The Emission Measurement People, Inc. under contract to the Operating Company, as well as data supplied by the plant operator(s). ***

CERTIFICATION

*** As on site Project Leader for The Emission Measurement People, Inc., I hereby certify that this report and these data are authentic and correct for the emission testing reported here. ***

Project Leader:




Date: OCT. 13 1990

REVIEW

*** As Technical Operations Director for The Emission Measurement People, Inc., I have reviewed the report for accuracy and completeness and find it acceptable and technically correct. ***

Technical Director:



Date: OCT. 13 1990

ACCEPTANCE

*** As a final document, and from my level of involvement, I have reviewed this report and find it accurate, complete, and a fair presentation of the pertinent facts, process records, and emission levels for the subject facility. On behalf of the Operating Company I approve the report for release for purposes of evaluating the compliance status of the facility with applicable air pollution regulations. ***

Signed: _____

Date: _____

Name: _____

Title: _____

1.0 Introduction and Project Overview

The objective of this Emission Measurement Project was to conduct the specified number of valid test runs for certain parameter(s) of the flue gases coming from the plant's specific stack(s) (described in Table 1-1), such that the DEQ, listed in Table 1-1, can make a determination as to the compliance status of the facility with applicable air pollution regulations, emission limitations, permit conditions, and/or permit requirements, listed in Table 1-2, below. The Emission Measurement People, Inc. of Cañon City, Colorado have been retained by General Chemical Corporation to conduct the required air pollution emission tests at the subject plant. This plant may have been tested previously, as given in Table 1-2, in Section 1.1.

Operating Co.:	General Chemical Corporation	
Facility Name:	General Chemical Corporation	Reg. Agency: DEQ
Test Location:	Green River	Test Date: 9/24-25/90
Parameter(s):	Particulate	Particulate
	Front Half, M5	Front & Back Half, MM5
No. Runs Valid:	3	3
Results:	0.797	2.268
Units/Basis:	lbs./hr.	lbs./hr.
Pass:	Yes	N/A

This Emission Measurement Test Report contains the description of the tests conducted, including quality control checks, original copies of all test data and records, and the final test results and production records during the tests. The major points of this report are organized as follows.

<u>Report Topic</u>	<u>Section No.</u>
Results Summary and Conclusion	2.0
Quality Assurance Documentation	3.1
Plant Operation and Production	3.3
Sampling and Analytical Procedures	3.5
Detailed Test Results and Discussion	3.6
Appendices/Data	4.0

A compliance test protocol (plan) was prepared and sent to the DEQ with (or just following) the usual "30-day advance notification to test". The protocol contained critical plant specifications, flue drawing(s), detailed test method descriptions, and the project schedule. It was reviewed, amended (as needed), and approved by the Agency prior to the commencement of testing. There was a short pre-test conference with all key personnel on site just prior to the start of the tests, in order to review the approved test protocol and project plans, and assure concurrence of all parties for testing responsibilities and field schedules, etc. Certain information in the protocol and/or the Records Reference Document (RRD) (described in Section 3.1.1, below) is not repeated in this report, except as it may have changed from the time these documents were issued. Appendix 4.1 contains certain project correspondence and documentation of contents of all related submittals to the DEQ, including:

- Transmittal Letters and Project Activities Log,
- Protocol Submittal and Approval,
- Protocol Title Sheet and Contents, and
- Records Reference Document Title Sheet and Contents

1.1 Tables for Section 1.0

The Emission Measurement People, Inc.

Table 1-1
AGENCY, COMPANY, and PLANT INFORMATION

Air Pollution Control Agency *****

Agency Name:	Wyoming Department of Environmental Quality
Department:	Division of Air Quality
Address/City:	210 Lincoln Street, Lander, WY 82520
Department Manager:	Mr. Bernard Daily, Technical Specialist
Observer Contact:	Mr. Lee Gribovicz, District Engineer
Phone, AC, No., Ext.:	307 332-6755, Ext.: -

Operating Company, Corporate Offices *****

Company:	General Chemical Corporation
Street/City:	West of Green River, GREEN RIVER, WY 82935
Mailing/City:	P.O. Box 551, GREEN RIVER, WY 82935-0551
Contact>Title:	Mr. Mike D. Wendorf, Environmental Technician
Phone, AC, No., Ext.:	307 872-3621, Ext.: -

Facility and Plant Process *****

Facility Name:	General Chemical Corporation	
Street/City:	West of Green River, Green River, Wyoming 82935	
Mailing/City:	P.O. Box 551, Green River, Wyoming 82935	
Contact>Title:	Mr. Mike D., Wendorf	
Phone, AC, No., Ext.:	307 872-3445, Ext.: -	
Directions to Plant:	See Protocol, Appendix 4.1.3	
Base Elevation (ft., MSL):	6239	
Process Tested:	GR3A Crusher	
Stack/Duct ID:	GR3A	
Unit No(s):	1	
Equipment Type:	Trona Ore Crusher	
Burner Type/Model:	N/A	
Max. Rated Capacity (MRC):	300	Units: Tons/hr.
Cap. During Tests, % MRC:	>90%	
Design Flow ACFM:	36688	
Hours of Operation/Year:	8059 hrs (= 336 days/yr @ 24 hrs/day)	
Process Variables:	----- (1) ----- ----- (2) -----	
Feed Type:	Automatic	N/A
Oper. Setpoint:	3/8" - 1/2" grinder (top side)	

Air Pollution Control Equipment *****

Location:	----- Primary -----	--- Secondary ---
Pollutant Removed:		
Type(s)/Design:	Cyclones	Baghouse/Buhl Norfelt
Model(s)/S.N.:		40-CE-320
Oper. Setpoint:	N/A	N/A

The Emission Measurement People, Inc.

Table 1-2
REGULATIONS, EMISSION LIMITS, and PRIOR TESTS
GR3A Crusher

Permit No(s)..:

Parameter: Partic.

Emission Limit : 2.0

Units/Basis: lbs./hr.

Regulation No.:

Results of Prior Tests: 3.96

Units/Basis: lbs./hr.

Prior Tests By (Tester): The Emission Measurement People, Inc.

Test Date: June 15, 1990

Observed By: WY DEQ, Gerald Blackwell

Production Load: >90%

2.0 Results Summary and Conclusions

Table 2-1, in Section 2.2, summarizes the plant production and air pollution emission results for this Emission Measurement Project. The results for this test program are of acceptable quality for purposes of the defined objective of this project (1.0 above, and in Section 1.0 of the protocol). All the procedures for advance Agency notification, test protocol, and quality assurance were applied in this project. All results are presented for each test run in detail in Table 3-6. At least two (2) valid test runs are required (minimum on each stack tested) by the regulations and these were conducted. More may have been conducted as needed to obtain representative results. Any test problems or test (or analytical) method variations for this project are discussed in Section 3.5, below.

All process data and production records for these tests were made by plant personnel and/or the plant process instrumentation system (computer). These data for each test run are presented in Table 3-3 in Section 3.7, and discussed in detail in Section 3.3, below. All emission data were collected by The Emission Measurement People, Inc. personnel. Copies of all raw project data and records are contained in Appendices 4.3 and 4.4. Plant stack opacity may have been recorded by the DEQ observer of these tests. If a copy of this data was available as this report was prepared it is included in Appendix 4.4, below.


There were no major process or test-related upsets or malfunctions during these tests which would cause the results to be unrepresentative of the air pollution emissions of the plant as operated on the date tested. The data should be accepted by the DEQ for purposes of the stated test objective, and are valid for confirming the compliance status of the facility with all applicable air pollution emission requirements for which tests have been conducted at this time. This Emission Measurement Test Report has been reviewed and certified above (following the contents page) for accuracy and correctness by project personnel, both from The Emission Measurement People, Inc., and General Chemical Corporation.

2.1 Determination of Compliance

WRONG

This Emission Measurement Test Report demonstrates that compliance has been attained by General Chemical Corporation (described in Table 1-1, in Section 1.1 above) on the specific process(es)/stack(s) tested. This allows the plant to operate in compliance with the applicable air pollution emission limitation(s), regulation(s), and/or permit renewal requirement(s) at a production load up to 111.11% of the average production rate recorded during the tests, and reported in Table 3-3, in Section 3.7. Any outstanding issues or problems with this compliance determination are specified here.

-- None --



2.2 Tables for Section 2.0

The Emission Measurement People, Inc.

Table 2-1
 SUMMARY of PROCESS & EMISSION MEASUREMENT RESULTS
 GR3A Crusher
 General Chemical Corporation

Stack/Duct ID:	GR3A
Test Condition:	>90% ¹

Plant Process and Production Results *****

Production Ore, TPH:	271.57
Amp., % on Fan:	59-66

Particulate Emission Results (Front Half, M5) ² *****

gr./dscf:	0.0058053
gr./acf:	0.0042620
lbs./hr.:	0.7974809
lbs./10 ⁶ BTU:	4.639E-06
Tons/Year:	3.2135000

Particulate Emission Results (Front & Back Half, M5) ³ *****

gr./dscf:	0.016710
gr./acf:	0.012260
lbs./hr.:	2.268200
lbs./10 ⁶ BTU:	0.000014
Tons/Year:	9.139900

Parametric (Non-Pollutant) Flue Gas Data *****

Pressure, Velocity,	
Delta P, (in. w.g.):	0.63767
Moisture, (% w/w):	5.38885
CO ₂ , Orsat, (% dry, v/v):	1.33
CO ₂ , Orsat, (% wet, v/v):	1.26
O ₂ , Orsat, (% dry, v/v):	17.0
O ₂ , Orsat, (% wet, v/v):	16.13
Temp. of Stack, (°F):	85.16
Velocity, (fps):	51.449
Vol. Flow, (10 ³ DSCFM):	15.970
Vol. Flow, (10 ³ ACFM):	21.819

¹ Average of all valid test runs, see Tables 3-6 and 3-7.

² Tons per year are based on hours per year, as specified in Table 1-1.

³ Tons per year are based on hours per year, as specified in Table 1-1.

3.0 Technical Discussion

3.1 Quality Assurance (QA) Documentation

General - These Emission Measurement Tests have incorporated the procedures of "The Red Book"--*The U.S. EPA Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III - Stationary Source Specific Methods (# EPA 600/4-77-027b), August, 1977 (as updated)*. Appendix 4.2 of this report contains the post-test equipment calibrations, chain-of-custody for data and sample(s) records and any other data involving quality assurance audit checks which may have been made or requested by the Agency observer(s) during (or after) the tests. Tables 3-1(a-d), in Section 3.7, summarize the pre- and post-test equipment calibration(s) and other quality assurance aspects of the tests. The results of all calibrations and audit checks were well within Agency requirements or guidelines. Complete pre-test calibrations of all test equipment and materials were submitted directly to the Agency prior to the test in the Records Reference Document (RRD), discussed below.

3.1.1 Records Reference Document - There are several critical parts of an Emission Measurement Project for verification of data quality. Some of the regulatory specifications, equipment design/schematics and/or calibrations, etc. tend to remain constant for at least a six-month period. These include:

- Qualifications of Emission Test Contractor,
- Pre-test calibrations of test equipment,
- Pre-test tare weights of filter media(e),
- Certification records for calibration gases,
- Forms for recording emission and production data,
- Specifications, schematic(s), and description(s) of test equipment and data reduction software, and
- Agency compliance documentation requirements for the test protocol, emission test report, and quality assurance.

The Emission Measurement People, Inc. update and compile the repetitive records semi-annually into a bound, self-contained Records Reference Document (RRD), and forward a copy directly to each Regulatory Agency overseeing their active projects during that period. See contents of Records Reference Document in Appendix 4.1.3. This action has been received favorably by Agency observers, as it not only supports the Agencies' data requirements for active projects, but also for past projects. As equipment calibrations, etc. are updated in the current Records Reference Document, they are valid for both pre-test records for upcoming projects, and post-test records checks for past projects. This method of transmitting the more repetitious data and information to Agencies and plant operators also helps to minimize bulk in protocol and report files. The current Records Reference Document is:

Volume No./Date: 3.89.1, August 23, 1989
Was forwarded to Agency: DEQ
c/o Name/on Date: Mr. Lee Gribovicz on September 6, 1989

A copy of the Records Reference Document was available on site for review by the project coordinator for the Company, listed in Table 3-2, in Section 3.7. Copies of these transmittals are contained in Appendix 4.1.

3.1.2 Manual Methods QA

Moisture and Volumetric Flowrate (M2, M4) - Specific QA Considerations are listed below:

1. Pitot tube coefficient (C_p) of 0.84 with geometric specifications for pitobe per M2; otherwise, the pitobe/nozzle recalibrated in a wind tunnel (or test redone, if required); Delta P values <0.05 in. w.g. measured with Dwyer "microtector" (hook gauge), accurate to 0.001 in. w.g.
2. Leak check of orsat analyzer; performance check with ambient air; calculation of F_0 factor (each repetition). See F_0 results in Table 3-7, in Section 3.7, below. Field check of console dry gas meter calibration factor (Y_0) with observer's QA critical flow orifice, if requested. Pitot system leak-check after each test run. Special pre-test back side leak-check of pump, dry gas meter, T/Cs, orifice, valves, manometer, and orsat bag-fill system, per "Red Book" Section 3.4.2, paragraph 2.1.2 and Method 5, paragraph 5.6.
3. Current equipment calibration data in Records Reference Document on file with DEQ, and on site. All data available anytime for review and/or copying by Agency or plant.

Annual calibration (or 200 hours) of "Standard Dry Gas Meter" directly against a spirometer. Six month calibration of console dry gas meter rate factor (Y_0) and orifice factor (Delta H_0) against the "Standard Dry Gas Meter", both with triplicate runs at five (5) flow (Delta H) rates (M5, 7.1.1 & 7.1.2). Post-test triplicate calibration check of console dry gas meter rate factor (Y_0) at a single flow near the sampling rate during the tests. Full 5-point re-calibration of the console done if post-test check not within the required 5.0% deviation and 3% range (M5, 5.3.2). All data reduced (by flowrate - tabular and graphically) by computer.

4. Use of Field Micro-Computer (FMC) for data reduction as described in Section 3.1.4, below. Equipment schematic(s) and example data sheets contained in Records Reference Document; 3-part sample labels used, as applicable.

Particulate (M5) - Specific QA Considerations are listed below.

1. Records of evaporation beakers and 3" (90 mm) glass fiber filter(s) tare weights in Records Reference Document on file with Agency prior to, and on site during test.
2. Filter and acetone blank (field & lab) to check handling and analytical procedures. One set (selected at random) offered to the Agency Observer with tare weight(s).

3. Probe(s) and nozzle(s) pre-wash (water and acetone) & dynamic blank (acetone only) on site, to assure clean equipment prior to start of tests. Nozzle(s) diameter specifications rechecked prior to, and after tests.

4. Use of agency analytical forms (including density of acetone). Sample analyses may have been observed at The Emission Measurement People, Inc. laboratory by advance arrangement with Mr. Terrell Hastings at 303 375-1022.

3.1.3 Instrumental Methods QA - Not Applicable

3.1.4 Data Collection and Reduction QA - Among the issues which affect emission data quality for this project, close attention and efficiency in the data reduction and results calculation stages are areas in which virtually all errors should be consistently preventable. Using automated procedures to handle all project data (after they were once recorded and entered into the system manually) has proven to help accomplish a much higher degree of data quality and reporting accuracy. A documentation package for each software subroutine used in this project, as well as a listing of the manual calculations, is contained in the Records Reference Document. Also, due to the digital-based data system used, a chain-of-custody sheet is established for the data, as well as the samples, see Section 3.1.5, below. Specific QA procedure(s) for the two types of data handling for this project are listed below.

Manual Reference Methods QA - To check the software proficiency and repeatability, a "known" set of data accompanied the project run data sets through the entire process from manual data entry in the field through the generation of the report results table(s). The below procedure for automated handling for manual method emission data was followed to assure high precision and accuracy in the data reduction, calculation, and reporting activities.

1. Manually verify and enter all data constants for the project from Table 3-6 of protocol into Field Micro-Computer (FMC) and obtain printout of registers.
2. Manually enter "known" standard run data from data sheet into FMC and save same on magnetic media.
3. Manually record specific test data & variables on a test run data sheet and enter same into FMC as each test run is progressing.
4. At conclusion of each test run, complete leak check and field analytical work, and enter same into FMC. Obtain average(s)/total(s) for each data column on the test run sheet, and obtain optional printout, using Field Thermal Printer (FTP).
5. Save all data for completed test run on hard disk (up to 3 runs) in FMC prior to start of next test run.

6. Complete data recording and entry of test run data for each project test run as in 3 through 5, above.

7. Save field data for all runs (and "known" run) on magnetic media before departure from site (or after each 4 runs, to clear hard disk).

8. Manually record all post-test laboratory analytical activity and/or calibration(s) data on data sheet(s) and enter same into FMC, and save same on magnetic media.

9. Recall all complete data file(s) from magnetic media into FMC and execute "results" subroutines as required by project for each test run and save results on magnetic media. Interface with instrumental methods digital data on magnetic media (as applicable), to obtain gas emission results in proper final units.

10. Recall all results file(s) for each test run (and "known" run) from magnetic media into FMC (with large printer) and compile and print results file table(s) for project report.

11. Compare printed results of "known" run to expected "known" results as a system operational check of the software.

3.1.5 Chain-of-Custody for Data and Sample(s) - A chain-of-custody record for the data and the sample(s) was made and followed throughout the sampling and analysis process. This record shows the when, where, and who, regarding the handling of the critical project samples and data. A copy of this record is contained in Appendix 4.2.2.

3.2 Project Activity Log and Personnel

Table 3-2 provides a listing of all key personnel involved in this project. The tests were observed by the DEQ personnel, as well as by plant and/or third party personnel, as listed. All parties agreed during the testing that, from a plant operation standpoint, as well as the field aspects of sample collection, these emission measurement data should be valid and acceptable for the stated purpose(s) and for evaluating compliance with applicable air pollution emission regulation(s) and/or permit requirement(s).

These tests were conducted by **The Emission Measurement People, Inc.** personnel of Cañon City/Denver, Colorado, whose qualifications and corporate experience are included in Section 5.0 of the Records Reference Document (see Section 3.1.1 and Appendix 4.1.3). A record of the project activities is contained in the Project Activity Log in Appendix 4.1.4.

3.3 Plant Operation and Production

During the emission tests, the plant process operation and production load were at normal maximum and the plant was operated continuously at greater than 90% MRC (Maximum Rated Capacity), as specified in Table 1-1, in Section 1.1. The average production data for each run is listed in Table 3-3, in Section 3.7. A detailed description of the plant process was contained in Section 3.3 of the test protocol.

These production data were reported to **The Emission Measurement People, Inc.** Project Leader (listed in Table 3-2, in Section 3.7) at the conclusion of all test runs. Copies of the plant operator's recorded production data, taken at the required 20-30 minute intervals (or continuously by plant computerized instrumentation during the tests) are contained in Appendix 4.3, and/or at the plant (if not available for this report).

Specific extraordinary process operational issues (if any) during these tests are discussed here.

-- None --

3.4 Location of Test Port(s) and Sampling Point(s)

Table 3-4 and Figure 3-1, in Section 3.7, describe in detail the flue duct (stack) configuration, the sampling port(s) location(s), and the test point(s) used for this Emission Measurement Project. The test location(s) meet(s) the specifications of EPA Method 1 for straight duct length distance (diameters) before (upstream) and after (downstream) of test ports. No adverse conditions involving the sampling location(s) were present which could artificially affect the magnitude (or representativeness) of the final emission results or the overall quality of the data, except as are noted here.

-- None --

3.5 Sampling and Analytical Procedures and Modifications

Tables 3-5(a-c) (as applicable) summarize(s) the basic test methods and specifications applied during these tests. Any modifications or adjustments in the published EPA Reference Methods applied to these tests are described below.

3.5.1 Description of Sampling Equipment

Flowrate & Moisture (M2, M4) - The sampling equipment used for this project was a system of standard design for M5-type sampling and meets the construction guidelines set out by EPA. The unique features of the equipment are described in Section 3.1 of the Records Reference Document, on file with the Agency. The amount of moisture trapped on the silica gel was calculated based on Dalton's Law, as described fully in the RRD.

Molecular Weight (M3) - The gas sample for molecular weight, % CO₂ and % O₂ was taken from the positive tap of the orifice manometer (after the dry gas meter) at a rate of about 200 ccm, by switching a 3-way solenoid valve. If Method 3A was used for O₂, then this sample was for back-up only, see Table 3-5(a). This was done after reading the orifice pressure (Delta H value) at each sample point, and making the needed adjustments in sampling rate, if applicable. Orsat sample system included teflar bag(s), filled by DGM pressure through 3-way solenoid valve, regulating valve, and rotameter, as well as Burrell orsat gas analyzer and chemicals for CO₂ and O₂, with aspirator bulb.

Particulate (M5) - The equipment was the same as M2 and M4, above, with the addition of the heater elements for the probe and filter, a sample nozzle, probe wash recovery, and filter media.

3.5.2 Measurement of Pollutant Emissions

Particulate (M5) - Point-by-point isokinetic values were calculated, recorded and adjusted in the field (as each point was being sampled), sufficiently detailed so as to be suitable for point-by-point Agency audit review. Final isokinetic sampling rates (reported in Table 3-7 in Section 3.7, below) were calculated after each test run following final moisture and orsat analyses. Test method specifications are given in Table 3-5(a) in Section 3.7, below.

3.5.3 Measuring Non-Pollutant Flue Gas Parameters

Moisture (M4) - Moisture sampling specifications using EPA Method 4 are described in Table 3-5(a), below. All requirements of this Method were followed, including a constant sample rate of at least 0.53 cfm (ca. 1.0 Delta H) for at least 21 minutes to obtain at least 7.5 dscf for the moisture tests, which were at the same points, with the same probe and for the same time as the pollutant tests. Should weather or process problems have prevented the full 21 minutes of sampling, the 7.5 dscf may be obtained by using a higher flowrate, above the constant Delta H of at least 1.0. This was done together with Method 5, if applicable (but then at a variable sample rate).

A comparison of the results of moisture collected on the silica gel using Dalton's Law to gravimetric analyses was included in the Records Reference

Document, submitted to the Agency with (or prior to) the test protocol. As specified in EPA Method 4, paragraph 2.1.2, Dalton's Law was used to determine the moisture volume collected on the silica gel. This was discussed in the approved protocol.

Oxygen/Carbon Dioxide/Molecular Weight (M3/M3A) - The back-up gas sample (or main sample if 3A was not conducted) for molecular weight was taken from the positive tap of the orifice manometer (after the dry gas meter) at a rate of about 200 ccm, by switching a 3-way solenoid valve. This was done in the same train as was used for moisture. See Discussion (M4), above. If O_2 was taken using the instrumentation as described above and in Table 3-5(b), the sample was the same as the gaseous pollutant parameters, described in Section 3.5.2, above. CO_2 may have been back-calculated from the F_c combustion factor and fuel type using the digital O_2 value, or from orsat analyses, (see Table 3-5(a) in Section 3.7, below).

Volumetric Flowrate, Velocity, and Temperature (M2) - These tests were conducted for the same time as the moisture and molecular weight tests, above (except at more points, as required by EPA Methods 1 and 2). Point locations are given in Table 3-4.

3.5.4 Laboratory Analyses

Particulate (M5) - The analytical procedures for the acetone evaporations and filter weighings for the front half particulate catches were as provided for in EPA QA Volume III and Method 5. The lab data sheet is included in Appendix 4.6. Specific details of the procedure used are described below. The analyses of the particulate catches were done by The Emission Measurement People, Inc. at their laboratory in Canon City, Colorado following the procedures of Method 5, paragraph 4.1.1, 4.2, and 4.3.

A blank filter and a 200-400 ml. field blank acetone sample were collected in the field along with the regular run samples. To obtain tare weights, all numbered filters (and cleaned, numbered beakers) were dried at 68°F in a desiccator for at least 24 hours and weighed at 6 hour intervals to 0.10 mg. to a constant weight, i.e., when two consecutive weighings agree within 0.5 mg. as required by the method. These tare weight data were included in the Records Reference Document, Section 4.5, for all filters and beakers used in the current 6-month period. Beakers were re-tared before and after each use.

The density of the acetone wash and the volume (from the sample jar label) of each probe/filter bell (and blank) wash were recorded on the lab sheet. The weight of each acetone sample was then calculated (using volume and density) and recorded. The washes were then individually evaporated to dryness at less than the boiling point of acetone (56.2°C) in 250 ml. tared beakers using an infra-red heat lamp. The beakers were then cooled, desiccated, and weighed to a constant weight.

The result of the field blank analysis is given in terms of milligram of blank residue per gram of acetone. By applying the milligram weight of blank residue per gram of acetone to the known grams of acetone in each sample (using the acetone volume and density), a blank correction in milligrams for each acetone wash sample was determined.

3.6 Detailed Test Results and Discussion

Detailed Test Results - All project data are presented tabularly in Tables. Table 3-3 contains all the plant performance, process operation, air pollution abatement system data, and production records for this project. Table 3-6 contains all the pertinent emission test results for each test run in this project. Performance data (by run) on the sampling and analytical equipment are contained in Table 3-7.

The minimum number of required valid runs were completed on each stack tested, as given in Table 3-5(a). More runs were likely conducted only to assure an acceptable set of representative data. All runs were reported in Tables 3-6 and 3-7, and non-valid runs are noted along with the reasons.

The results of these emission tests, as summarized in Table 2-1, in Section 2.2, above, demonstrate compliance with all applicable permit and/or local air pollution emission requirements, as well as the applicable regulations listed in Table 1-2, in Section 1.1. This project has met the objective as defined in Section 1.0, above.

3.7 Tables for Section 3.0

The Emission Measurement People, Inc.

Table 3-1(a)
QA DOCUMENTATION - CALIBRATIONS
 Methods: 1, 2, 3, 4, 5

Make/Vendor	I.D./S.N.	Calibrations/Checks		
		Date	Result ¹	
Barometer	Ultimeter, Mod.12	7A1520	3-12-90	+/- 0.1" Hg.
Standard Gas Meter	Rockwell/S-275	6843916	3-12-90	1.0026
Main Console	TEMP, Inc.	CC-01	-	-
Pump	-	-	-	-
Temperature Meter	Watlow	LCD-1	7-10-90	+/- 2.0 ⁰ F
Vac. Gauge	Gen. Instrument	-	7-10-90	+/- 1.0" Hg
Gas Meter	Rockwell/S-275	6841506	7-10-90	0.3
Orifice Meter (ΔH_a)	TDDC	0.201	7-10-90	ca. 1.510" w.g.
Pitot Tip (geom.)	TDD, Inc.		on site ³	0.84 (C _p)

¹ See actual calibration data in Records Reference Document.

The Emission Measurement People, Inc.

Table 3-1(b)
QA DOCUMENTATION - AUDIT CHECKS
Methods: 1, 2, 3, 4, 5

		Date ¹	Result
M3	- Orsat/CO ₂ Ambient ²	on site	0.0% (+/- 0.2%)
M3	- Orsat/O ₂ Ambient ²	on site	20.9% (+/- 0.2%)
M4	- Critical Flow Device	N/A	-

¹ Not conducted if not available from or requested by Agency observer.
² Ambient air, less than 6 passes, same reagent as runs.

The Emission Measurement People, Inc.

Table 3-1(c)
 QA DOCUMENTATION - QA CHECKS
 Methods: 1, 2, 3, 4, 5

	Date ¹	Result
Sample Vacuum Leak @ Nozzle:	on site	<0.02cfm (or 4.0%)
Sample Pressure Leak @ Meter Outlet:	on site	dead @ 4.0" w.g.
T/C(s), Static System Check:	on site	+/- 5.4°F
Heat Controller(s)	quarterly ²	+/- 5.4°F
Graduated Cylinder:	on site	+/- 1.0 ml. ³
Orsat Leak (+):	on site	dead @ >20 ml.
Orsat Leak (-):	on site	dead @ >20 ml.
Orsat, No. of Passes	-	-
O ₂	on site	<8
CO ₂	on site	<8
F ₀ Calculation	on site	Each Repetition
Bag(s) Leak (+):	quarterly ²	OK, including valves
Pitot Leak (+):	on site	dead @ >3.0" w.c.
Pitot Leak (-):	on site	dead @ >3.0" w.c.
Pitobe Geometric Specifications (all):	quarterly ²	0.840
Manometer Lever/Zero:	dur. test ⁴	OK
Manometer 0.01/0.10" w.g. reading:	on site	Yes ⁵
Pressure Drop, Silica Gel (-12 mesh): ⁵	quarterly ²	Screened
Pressure Drop, Filter Frit:	quarterly ²	Acid-washed
Analytical Balance @ 100.0008 gm.: ⁶	with data,	+/- 0.10 mg.
Analytical Balance, Class "S":	quarterly ²	Range

¹ Recorded on run data sheet and / or in Records Reference Document.

² Checked quarterly, see Records Reference Document.

³ Required precision of reading.

⁴ As needed during run, see data sheet(s).

⁵ Screened to - 12 mesh to reduce pressure drop.

⁶ Certified internal balance weight.

⁷ See Class "S" results quarterly in Records Reference Document.

The Emission Measurement People, Inc.

Table 3-2
PROJECT PERSONNEL

POSITION	NAME/TITLE	COMPANY/Phone
<u>Company</u> *****		
Coordinator	Mr. Mike Wendorf Environmental Technician	GCC 307 872-3621
Observer(s)	Mr. Jerry Justis Environmental Technician	GCC 307 872-3621
	Mr. Ted Kass Senior Engineer	GCC 307 872-3431
	Mr. Gary Merkis Manager, Surface Operations	GCC 307 872-3431
<u>Regulatory Agency</u> *****		
Administrator	Bernard Daily Technical Specialist	DEQ 307 777-7391
Observer(s)	Lee Gribovicz District Engineer	DEQ 307 332-6755
<u>Third Party</u> *****		
	NONE	
<u>Testing Contractor</u> *****		
Project Leader	John R. Floyd Technical Operations Director	The Emission Measurement People, Inc. 719 275-0046
Test Leader	Jess Scappaticci Technician	The Emission Measurement People, Inc. 303 375-1022
Technologist(s)	Tracy Ross	The Emission Measurement People, Inc. 303 375-1022

The Emission Measurement People, Inc.

Table 3-3
PLANT OPERATION and PRODUCTION, by Run
General Chemical Corporation

Plant Name: General Chemical Corporation
Plant Location: Green River, Wyoming
Stack/Duct ID: GR3A

Run Number:	101	102	103	Avg
Date, 1990:	9-25	9-25	9-25	
Time - Start of Clock:	10:50	14:25	17:25	
- End of Clock:	12:10	16:10	19:10	

Test Condition:

Plant Production Data *****

Production Ore, TPH:	291.2	238.5	285.0	271.57
Amp., % on Motor:	60-66	59-65	60-63	59-66

The Emission Measurement People, Inc.

Table 3-4
TEST PORT(S) and SAMPLING POINT(S)
Stack/Duct ID: GR3A

Stack Configuration:	Round		
Applicable Figure No. in Report:	3-1		
Stack Height, above Grade, (ft.):	120		
Height of Test Platform, (ft.):	100	top floor process building	
Flow Direction (@ Test Port(s)): up			
Flue Size(s), Inside Dia., (in.): 36			
Outside Dia., (in.): ¹ 36.5 1/4" thickness			
Straight Flue Distance to Test Port:	in.	ft.	Dia(s).
B, Before: 162	13.5	4.5	
A, After: >72	>6.0	>2.0	
Sample Ports: Type: NPT			
Description: male			
Size, Dia., (in.): 3"			
Nip., Length., (in.): 6" (2) ²			
Quantity Used: 2			
Orientation: 90°			
Sample Train/ID:	Partic.	MW/H ₂ O	Flow ³
No. of Sample Points			
Total: ⁴ 24	24	24	24
Per Port: 12	12	12	12
Required Probe Length, (in. E.L.): 41	41	41	41
Pitobe ID No.: 5-1	5-1	5-1	5-1
Point(s)/Location(s): ⁵	Point No.: %:	Distance to Point from (in.) near Wall	
	1 / 2.1	(1.00)	
	2 / 6.7	(2.41)	
	3 / 11.8	(4.25)	
	4 / 17.7	(6.37)	
	5 / 25.5	(9.00)	
	6 / 35.6	(12.82)	
	7 / 64.4	(23.18)	
	8 / 75.0	(27.00)	
	9 / 82.3	(29.60)	
	10 / 88.2	(31.75)	
	11 / 93.3	(33.60)	
	12 / 97.9	(35.00)	

¹ Including wall thickness and stack wall insulation.

² Port adapter length in parenthesis to be added.

³ Equivalent to metric rule (0.4m., 1.2m., 2.0m.) or 17%, 50%, 83%.

⁴ Half of total points to be on each diameter.

⁵ Distance to point from inside near wall (for each diametric traverse).

The Emission Measurement People, Inc.

Table 3-5(a)
TEST METHOD SPECIFICATIONS
General Chemical Corporation

Method Type	<u>Manual</u>	<u>Manual</u>	<u>Manual</u>
Parameter:	Particulate	MW/H ₂ O	Flow
Method No. (s):	M5	M3/M4	M2
Number of Runs: ¹	3	3	3
Number of Sample Points: ²	24	24	24
Sampling Time/Point, (min.):	3.0	3.0	3.0
Sampling Time/Run, (min.):	72.0	72.0	72.0
Sampling Flowrate, (dscfm):	>.75	-	>.75
Sample Volume, (dscf): ³	>50	-	>50
Clock Time/Run, (min.):	72.0	72.0	72.0
Clock Time/All Runs, (hrs.): ³	4.0	4.0	4.0

¹ Per stack tested.

² See point location(s) in Table 3-4.

³ See Table 3-6 for constants data for methods run.

The Emission Measurement People, Inc.

Table 3-5(b)
INSTRUMENTAL EQUIPMENT SPECIFICATIONS
Methods 3A, 6C, 7E (or 20), and 10

Not Applicable

The Emission Measurement People, Inc.

Table 3-5(c)
LABORATORY ANALYTICAL SPECIFICATIONS/RESULTS
Methods: 5, 6/8
Stack ID: GR3A

Run No.:	101	102	103
Particulate (Front Half, M5) *****			
Weights, Total, (mg.):	12.4170	10.2833	35.4500
Acetone Washes Weight, (mg.):	275.4500	314.8000	354.1500
Filter Cake Weight, (mg.):	5.3000	4.5000	1.9000
Blank Acetone, (mg./g.):	0.0326	0.0326	0.0326
Particulate (Back Half, MM5) *****			
Weights, Total, (mg.):	62.1750	21.2800	22.5875
Water Washes Weight, (mg.):	450.0000	540.0000	525.0000
Blank Water (mg./g.):	0.0005	0.0005	0.0005

The Emission Measurement People, Inc.

Table 3-6(R)
 TEST RESULTS, by RUN
 Methods 1, 2, 3, 4, 5
 GR3A Crusher
 General Chemical Corporation

Stack/Duct ID:	GR3A		
Test Condition:	>90%		
Run Number:	101	102	103
Average ¹			
Plant Process and Production Data *****			
Production Ore, TPH: ²	291.2	238.5	285.0
Amp., % on Motor:	60-66	59-65	60-63
Particulate Emission Results (Front Half, M5) ³ *****			
gr./dscf:	0.00397	0.00298	0.01047
gr./acf:	0.00292	0.00215	0.00771
lbs./hr.:	0.52426	0.41674	1.45144
lbs./10 ⁶ BTU	4.091E-06	1.813E-06	8.013E-06
Tons/Year:	2.1125	1.6792	5.8487
Particulate Emission Results (Front & Back Half, MM5) ⁴ *****			
gr./dscf:	0.02386	0.009134	0.017136
gr./acf:	0.01755	0.006614	0.012620
lbs./hr.:	3.1494	1.2791	2.3762
lbs./10 ⁶ BTU	2.46E-05	5.57E-06	1.31E-05
Tons/Year:	12.6907	5.1542	9.5750
Parametric (Non-Pollutant) Flue Gas Data *****			
Pressure, Velocity,			
Delta P, (in. w.g.):	0.59	0.6756	0.6474
Moisture, (% w/w):	5.67716	5.38984	5.09836
CO ₂ , Orsat, (% dry, v/v):	1	2	1
CO ₂ , Orsat, (% wet, v/v):	.94	1.89	.94
O ₂ , Orsat, (% dry, v/v):	18.0	16.0	17.0
O ₂ , Orsat, (% wet, v/v):	16.97	15.13	16.13
Temp. of Stack, (°F):	82.3	90.3	82.9
Velocity, (fps):	49.347	53.204	51.795
Vol. Flow, (10 ³ DSCFM):	15.394	16.337	16.178
Vol. Flow, (10 ³ ACFM):	20.928	22.564	21.966
			21.819

¹ Average of all valid test runs, as noted in Table 3-7.

² Not available to Tester at time of report.

³ Tons per year are based on hours per year, as specified in Table 1-1.

⁴ Tons per year are based on hours per year, as specified in Table 1-1.

The Emission Measurement People, Inc.

Table 3-7(R)
 SAMPLING and ANALYTICAL DATA, by RUN
 Methods 1, 2, 3, 4, 5
 GR3A Crusher
 General Chemical Corporation


Stack/Duct ID:	GR3A		
Test Condition:	>90%		
Run Number:	101	102	103
Date, 1990:	9-25	9-25	9-25
Run Time, (min.):	72	72	72
Time Start:	10:50	14:25	17:25
Field Data *****			
Volume of Gas Sample, (dscf): ¹	48.227	53.326	52.267
Volume, @ Actual Cond., (acf): ¹	62.326	70.680	68.710
Temp. of Gas Sample (°F):	83.20	94.80	90.50
D H Press. @ Meter, (in. w.g.):	2.21	2.56	2.40
Press. Barom., Abs., (in. Hg.):	23.91	23.81	23.82
Excess Leak, (ACF):	0.000	0.000	0.000
Moisture Determination: ¹			
Press. of H ₂ O Vapor @ Saturat.:	0.5523	0.5369	0.5369
@ S.G., (in. Hg.):	12.41	14.31	14.62
Temp. @ S.G., (°F):	61.60	60.80	60.80
Vacuum @ S.G., (in. Hg.):	11.50	9.50	9.20
Vol. H ₂ O @ Silica Gel, (gm.): ²	61.57	64.43	59.55
Vol. H ₂ O @ Impingers, (ml.):	0.00	6.00	4.00
Molecular Weight, Wet: ³	28.27	28.38	28.30
Particulate Data *****			
Isokinetic Sampling Rate (%): ¹	90.22	94.00	93.04
Point-by-point, (Average):	105.90	96.00	93.60
Point-by-point, (High, %):	332.00	109.72	97.16
Point-by-point, (Low, %):	21.94	92.51	90.51
Nozzle Diameter, (in.):	0.250	0.250	0.250
Rate Factor, (K ₃):	1.000	3.750	3.790
Conclusions *****			
Valid Sample Data?:	yes	yes	yes

¹ All sample volumes and results are already corrected for excessive leak.

² According to Dalton's Law, M4.

³ See CO₂ and O₂ data in Table 3-6, above.

Figure 3-1
STACK CONFIGURATION and PORT LOCATION(S)
GR3A Crusher
General Chemical Corporation



4.0 Appendices

4.1 Project Documentation

- 4.1.1 Project Correspondence
- 4.1.2 Compliance Test Protocol (Title Sheet and Contents)
- 4.1.3 Records Reference Document (Title Sheet and Contents)
- 4.1.4 Project Activities Log

4.2 Quality Assurance Documentation

- 4.2.1 Q.A. Audit Results (if applicable)
- 4.2.2 Chain-of-Custody for Data and Sample(s)
- 4.2.3 Post-test Calibrations (if applicable)

4.3 Plant Operation and Production Data (as available)

4.4 Field Sampling Data Records

- 4.4.1 Data Sheets for Reference Methods
- 4.4.2 Emission Data Printouts from CEM Tests
- 4.4.3 Drift Records for CEM Tests
- 4.4.4 Opacity Observations (as available)

4.5 Calculations and Computer Printouts

4.6 Laboratory Analytical Results

Appendix 4.1

PROJECT DOCUMENTATION

4.1.1 Project Correspondence

4.1.2 Compliance Test Protocol
(Title Sheet and Contents)

4.1.3 Records Reference Document
(Title Sheet and Contents)

4.1.4 Project Activities Log

**OFFICIAL COMPLIANCE TEST PROTOCOL
for
EMISSION MEASUREMENT TEST**

of

1. CEMS Relative Accuracy Test Audit (RATA) of "D" Boiler
for SO₂, NO_x, and O₂ Emissions
2. CEMS Certification of "C" Boiler
for SO₂, NO_x, and O₂ Emissions
3. Compliance Test of GR3 Crusher
for Particulate Emissions

at
General Chemical Corporation, Green River, Wyoming

Prepared for:

General Chemical Corporation

P.O. Box 551
GREEN RIVER, WY 82935-0551
Mr. Dale Jensen, Manager, Technical Services
Phone: 307 872-3445

Submitted to:

**Wyoming Department of Environmental Quality
Division of Air Quality**

210 Lincoln Street
Lander, WY 82520
Mr. Lee Gribovicz, District Engineer
Phone: 307 332-6755

Prepared by:

The Emission Measurement People, Inc.

P.O. Box 935, CANON CITY, CO 81215-0935
John R. Floyd, Technical Operations Director
Nationwide Watts: 800-222-4187
Office Phone: 719 275-0046

Date of Protocol: June 4, 1990

Contents of Compliance Test Protocol

for

EMISSION MEASUREMENT TEST

GR3 Crusher and Steam Boilers
for SO₂, NO_x (Boiler), Particulate (GR3 Crusher) Emission(s)
General Chemical Corporation, Green River, Wyoming

<u>Section</u>	<u>Page</u>
<u>1.0 Introduction and Project Objective</u>	1
1.1 Tables for Section 1.0	2
Table 1-1 AGENCY, COMPANY, and PLANT INFORMATION	3
<u>2.0 Protocol Summary and Regulations</u>	4
2.1 Tables for Section 2.0	5
Table 2-1 PROPOSED PRODUCTION & EMISSION MEASUREMENT DATA	6
Table 2-2 REGULATIONS, EMISSION LIMITS, and PRIOR TESTS	8
<u>3.0 Technical Discussion</u>	9
3.1 Quality Assurance (QA) Documentation	9
3.1.1 Records Reference Document	9
3.1.2 Manual Methods QA	11
3.1.3 Instrumental Methods QA	13
3.1.4 Data Collection and Reduction QA	13
3.1.5 Chain-of-Custody for Data and Sample(s)	15
3.2 Project Personnel and Schedule	16
3.3 Plant Operation and Production	17
3.3.1 Description of Process of Operation	17
3.4 Location of Test Port(s) and Sampling Point(s)	17
3.5 Sampling and Analytical Procedures and Modifications	18
3.5.1 Description of Sampling Equipment	18
3.5.2 Measurement of Pollutant Emissions	20
3.5.3 Measuring Non-Pollutant Flue Gas Parameters	21
3.5.4 Laboratory Analyses	23
3.5.5 Relative Accuracy Tests (RAT)	24
3.6 Expected Parametric Data	25
3.7 Report	25
3.8 Tables for Section 3.0	26
Table 3-1(a)QA DOCUMENTATION - CALIBRATIONS	27
Table 3-1(b)QA DOCUMENTATION - AUDIT CHECKS	28
Table 3-1(c)QA DOCUMENTATION - QA CHECKS	29
Table 3-1(d)QA DOCUMENTATION - "PROTOCOL ONE" CALIBRATION GASES	30
Table 3-2(a)PROJECT PERSONNEL	31
Table 3-2(b)PROJECT SCHEDULE	32
Table 3-3 PROPOSED PLANT OPERATION and PRODUCTION	33
Table 3-4 TEST PORT(S) and SAMPLING POINT(S)	35

Table 3-4 TEST PORT(S) and SAMPLING POINT(S)	36
Table 3-5(a)TEST METHOD SPECIFICATIONS	37
Table 3-5(b)INSTRUMENTAL EQUIPMENT SPECIFICATIONS	38
Table 3-5(c)ANTICIPATED LABORATORY ANALYTICAL SPECIFICATIONS	39
Table 3-6(P)BASIC TEST METHOD CONSTANTS	40
Figure 3-1(a)STACK CONFIGURATION and PORT LOCATION(S) ("C" Boiler) .	41
Figure 3-1(b)STACK CONFIGURATION and PORT LOCATION(S) ("D" Boiler) .	42
Figure 3-1(c)STACK CONFIGURATION and PORT LOCATION(S)(GR3 Crusher)	43
Figure 3-2(a)PLANT PROCESS SCHEMATIC	44
Figure 3-2(b)PLANT PROCESS SCHEMATIC	45
4.0 Appendices	46
4.1 General	
4.1.1 Project Correspondence	
4.1.2 Regulations, Permit Conditions, Protocol Guidelines, and Special Test Methods (as applicable)	
4.1.3 Directions to Plant (Map) and Plant Layout	
4.2 Quality Assurance Documentation	
4.2.1 <u>Records Reference Document</u> , Title Sheet and Contents	
4.2.2 <u>Compliance Test Report</u> , Title Sheet, Contents, and Certification	
4.2.3 Other Pre-test Calibrations (as applicable)	
4.2.4 Chain-of-Custody Form for Data and Sample(s)	
4.2.5 Calculations	
4.3 Plant Schematics, Specifications, and Data Recording Form	

RECORDS REFERENCE DOCUMENT

Volume No.: 3.89.1

Part I - Quality Assurance

Date: August 23, 1989

Submitted to:

Wyoming Dept. Environmental Quality Division of Air Quality

**210 Lincoln Street
LANDER, WY 82520**

**Mr. Lee Gribovicz, District Engineer
Phone: 307 332-9056**

Prepared by:

The Emission Measurement People, Inc.

**P.O. Box 449, PENROSE, CO 81240-0449
John R. Floyd, Technical Operations Director
Nationwide Watts: 800-222-4187
Office Phone: 719 275-0046**

RECORDS REFERENCE DOCUMENT

Volume No.: 3.89.1

Part II - Equipment & Procedures

Date: August 23, 1989

Submitted to:

Wyoming Dept. Environmental Quality Division of Air Quality

210 Lincoln Street
LANDER, WY 82520
Mr. Lee Gribovicz, District Engineer
Phone: 307 332-9056

Prepared by:

The Emission Measurement People, Inc.

P.O. Box 449, PENROSE, CO 81240-0449
John R. Floyd, Technical Operations Director
Nationwide Watts: 800-222-4187
Office Phone: 719 275-0046

The Emission Measurement People, Inc.
P.O. Box 449, Penrose, CO 81240-0449
Nationwide Watts: 1 800 222-4187
Office Phone: 719 275-0046

September 6, 1989

Wyoming Dept. Environmental Quality
Division of Air Quality
210 Lincoln Street
LANDER, WY 82520

ATTN: Mr. Lee Gribovicz, District Engineer

RE: The Emission Measurement People, Inc. Records Reference Document,
Volume No.: 3.89.1 (in 2 Parts)

Dear Mr. Gribovicz:

Enclosed for your reference is our current "Records Reference Document". This document meets the requirements of the Colorado Test Manual. If you need additional information of this type for your protocol, please let us know as soon as possible.

The Emission Measurement People, hope that having this data on file with you, Mr. Gribovicz, and your staff will greatly improve both the coordination and the data quality for our projects in your region. We will update the document twice a year with new calibrations, etc. We also ask that you keep our name on file and put us on your list of testers.

We appreciate your support and look forward to working with you on upcoming projects. Should you have any comments or suggestions feel free to call or write us anytime.

Very Truly Yours,


John R. Floyd, Principal
Technical Operations Director

JRF/pl

Enclosure(s) (2)

Activity Log
for
Particulate Test at General Chemical

9-24-90 Left office at 11:00 and arrived at Little America at 19:00.

9-25-90 Left for General Chemical at 05:30 arrived at plant at 06:00. Was setting up equipment by 07:30. Was completely set up at 09:00. Had to fix the probe heater cord. Started running at 10:50. Agency showed up and wanted a backside wash. All runs went fine. We were done running at 18:32. Jess collected impinger water while Tracy loaded Pick-up. And ran averages. Left plant site at 20:30 to go back to Little America.

9-26-90 Drove Back to Denver

The Emission Measurement People, Inc.

PROJECT LOG

Client Name: General Chemical Date: 9/25/90
 Plant Location: Green River, WY Plant Personnel: _____
 Agency Personnel: _____
 TEMP Personnel: Tracy Ross / Jesse Sapperton

Time/Date <u>19/24</u> <u>19/24</u> <u>19/24</u>	Activity: <u>Travel to Little America</u> Depart Shop: <u>1100</u> Arrive Site: <u>Little America) 1900</u> Complete Set-up: _____	Personnel <u>Tracy</u> <u>Jesse</u>
<u>19/25</u>	Complete Preliminary Run/Ready to Test	_____
<u>19/25</u>	Begin 1st Run <u>Begin first run at 1050</u>	<u>FZ</u>
<u>19/25</u>	End 1st Run <u>1102</u>	_____
<u>19/25</u>	Begin 2nd Run <u>1425</u> 1425	_____
<u>19/25</u>	End 2nd Run <u>1532</u>	_____
<u>19/25</u>	Begin 3rd Run <u>1725</u> <u>1832</u>	_____
<u>19/25</u>	End 3rd Run _____	_____
<u>19/25</u>	Begin 4th Run _____	_____
<u>19/25</u>	End 4th Run _____	_____
<u>19/25</u>	Pick-up Process Data from Plant Operator	_____

Appendix 4.2
QUALITY ASSURANCE DOCUMENTATION

- 4.2.1 Q.A. Audit Results
(if applicable)**
- 4.2.2 Chain-of-Custody
for Data and Sample(s)**
- 4.2.3 Post-test Calibrations
(if applicable)**

QUALITY ASSURANCE FORM

QAF S-351
Revision: One
Originator:
Approved: *gjz*
Effective date:

SAMPLE CHAIN OF CUSTODY RECORD

Project No.: _____ client General Chemicals | Plant: GR3 Crusher Unit: _____

Appendix 4.3
PLANT OPERATION AND PRODUCTION DATA
(as available)

3. (

GR-3-A IMPACTOR FEED DATA FOR COMPLIANCE TEST OF
25 September 1990

The GR-3-A impactor provides crushed trona ore for the GR-3 process facility. In order to document the load on the impactor during the testing period, pertinent readings from two sources were recorded:

1. The motor load current was recorded to verify steady operation of the impactor.
2. The Ramsey belt scale readings were taken at the start and end of each of the three runs. This provides a tonnage total from the impactor to the GR-3 calciner storage bins. These readings were taken in the GR-3 calciner control room.

Run #1

Ramsey belt scale:

finish @ 1218 hrs. = 3025875
start @ 1052 hrs. = 3025477
86 min. = 398 tons = 291.2 tons/hour

Motor load current:

@ 1124 hrs. = 60-66%
@ 1200 hrs. = 60-66%

Run #2

Ramsey belt scale:

finish @ 1545 hrs. = 3026750
start @ 1427 hrs. = 3026440
78 min. = 310 tons = 238.5 tons/hour

Motor load current:

@ 1430 hrs. = 60-65%
@ 1540 hrs. = 59-64%

Run #3

Ramsey belt scale:

finish @ 1845 hrs. = 3027506
start @ 1725 hrs. = 3027126
80 min. = 380 tons = 285.0 tons/hour

Motor load current:

@ 1735 hrs. = 60-63%
@ 1815 hrs. = 60-63%

Appendix 4.4

FIELD SAMPLING DATA RECORDS

- 4.4.1 Data Sheets for Reference Methods**
- 4.4.2 Emission Data Printouts from CEM Tests**
- 4.4.3 Drift Records for CEM Tests**
- 4.4.4 Opacity Observations (as available)**

Field Data Sheet Sept. 1, 25

Bag ID: 1005

Filter I.D. 1

Nozzle I.D. 1

Plant location: Green River

Operator(s): Tracy

Test No. 155 Helperless Scoop Ambient Temperature

Final Meter Leak Rate: 0.0 cfm

Probe Heat Setting: 24 in. Hg.

Anemometer Level: Zero

Time: 04:00

signed: Tracy

Date: Sept. 1, 25

Time: 1005

Location ISO

Time: 1005

Point: 1

Clock: 1005

Head: 0.0

24hr. 0

f.b. 0

No. 1

1005

0.0

800.094

800.094

3.0

.05

892.80

2.5

Probe: 80

Orifice: 80

Index: 0.0

0.0

2.0

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

Run No. 3101 Date: 1990

Plant location: Green River

Operator(s): Tracy

Test No. 155 Helperless Scoop Ambient Temperature

Final Meter Leak Rate: 0.0 cfm

Probe Heat Setting: 24 in. Hg.

Anemometer Level: Zero

Time: 04:00

Date: Sept. 1, 25

Time: 1005

Location ISO

Time: 1005

Point: 2

Clock: 1005

Head: 0.0

24hr. 0

f.b. 0

No. 2

1005

0.0

800.094

800.094

3.0

.05

892.80

2.5

Probe: 80

Orifice: 80

Index: 0.0

0.0

2.0

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

Run No. 3101 Date: 1990

Plant location: Green River

Operator(s): Tracy

Test No. 155 Helperless Scoop Ambient Temperature

Final Meter Leak Rate: 0.0 cfm

Probe Heat Setting: 24 in. Hg.

Anemometer Level: Zero

Time: 04:00

Date: Sept. 1, 25

Time: 1005

Point: 3

Clock: 1005

Head: 0.0

24hr. 0

f.b. 0

No. 3

1005

0.0

800.094

800.094

3.0

.05

892.80

2.5

Probe: 80

Orifice: 80

Index: 0.0

0.0

2.0

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

Run No. 3101 Date: 1990

Plant location: Green River

Operator(s): Tracy

Test No. 155 Helperless Scoop Ambient Temperature

Final Meter Leak Rate: 0.0 cfm

Probe Heat Setting: 24 in. Hg.

Anemometer Level: Zero

Time: 04:00

Date: Sept. 1, 25

Time: 1005

Point: 4

Clock: 1005

Head: 0.0

24hr. 0

f.b. 0

No. 4

1005

0.0

800.094

800.094

3.0

.05

892.80

2.5

Probe: 80

Orifice: 80

Index: 0.0

0.0

2.0

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

80

Run No. 3101 Date: 1990

Plant location: Green River

Operator(s): Tracy

Test No. 155 Helperless Scoop Ambient Temperature

Final Meter Leak Rate: 0.0 cfm

Probe Heat Setting: 24 in. Hg.

Anemometer Level: Zero

Time: 04:00

Date: Sept. 1, 25

Time: 1005

Point: 5

Clock: 1005

Head: 0.0

24hr. 0

f.b. 0

No. 5

1005

0.0

800.094

800.094

3.0

.05

892.80

Field Data Sheet

Run No. 3102 Date: 9/05

Plant General Champaign City, Green River

Operator(s) Tony

Final Water Leak Rate 0.0 cfm • 18 in. Hg.

Manometer Level 1 zero

Bag 1: Filter I.D. 1 2013

Nozzle I.D. 8-1

Ambient Temperature

Probe Heat Setting

Filter Heat Setting

signed: Tony

Constants

Cp. & q assumed.
Alt.

MSAP

Alt.

Tin

Sh. 0

Holes

in (des)

in (act) .250

Pb

in (act) .250

Pst

E399

K34

CALCULATIONS

Pb 23.81 in. Hg.

AH 2.558 in. H₂O

dn. 250 in.

Vol (act) 20.668 F³

Tin 94.8 °F

H₂O S. 33 % (v/v)Vl (act) 1 in. H₂O

Tso 96 °F (act)

Pb 99.99 P

Tin 1.399

K34

Date	Location ISO	Time	Velocity	Gas Meter Read	Orifice	Status	Temperatures (°F)			Volume	Gas Water Index	Pst. in. Hg.	Pst. in. Hg.
							1	2	3				
1	A	10:01	3.0	956.19	2.0	Probe	91	63	84	-	92.3 AT	-	7.5
2	2	10:02	6.0	959.23	3.3	91	61	84	86	Ren	1	2	3
3	3	10:03	9.0	962.53	3.3	91	60	88	88	CH ₃	120		
4	4	10:04	12.0	965.90	3.3	91	60	88	88	Total	120		
5	5	10:05	15.0	969.33	5.5	91	60	90	90	ρ_3	13.0		
6	6	10:06	18.0	972.78	3.5	91	61	91	91	ρ_4	13.0		
7	7	10:07	21.0	976.23	3.3	91	61	92	92	ρ_5	12.0		
8	8	10:08	24.0	979.31	2.6	91	60	93	93	* posn	10.0		
9	9	10:09	27.0	982.35	2.6	91	60	93	93	ρ_{10}	10.0		
10	10	10:10	30.0	985.13	2.3	91	60	94	94	ρ_4	10.0		
11	11	10:11	33.0	987.85	2.7	91	61	94	94	ρ_4	10.0		
12	12	10:12	36.0	990.58	2.2	91	61	95	95	Moisture Analysis	8.0		
13	0	10:13	39.0	993.36	2.7	91	62	94	94	Imp. Final Temp Set	8.0		
14	1	10:14	42.0	996.51	2.6	91	60	96	96	1	250	6	9.5
15	2	10:15	45.0	999.28	2.6	90	60	98	98	2			9.5
16	3	10:16	48.0	1002.21	2.5	90	60	98	98	3			9.2
17	4	10:17	51.0	1005.13	2.3	89	61	100	4	-	56.7	9.0	
18	5	10:18	54.0	1007.85	2.6	89	60	100	4	-	44.7	8.0	
19	6	10:19	57.0	1010.51	2.0	89	61	100	4	-	40.0	8.0	
20	7	10:20	60.0	1013.19	2.0	89	61	100	4	-	35.7	8.0	
21	8	10:21	63.0	1015.90	2.2	89	61	100	4	-	31.7	8.0	
22	9	10:22	66.0	1018.67	2.2	89	62	100	4	-	28.2	8.2	
23	10	10:23	69.0	1021.42	2.2	89	62	100	4	-	25.0	8.2	
24	11	10:24	72.0	1024.19	2.2	89	62	100	4	-	22.0	8.2	
										Totals / Averages			

Field Data Sheet

Run No. 3103 Date: 1990

Plant General Channel City: Green River

Operator(s) Tracy Ross Helper, Ambient Temperature

Final Meter Leak Rate 0.10 cfm 18 in. Hg.

Parameter Level zero Time 0:00 Filter Heat Setting

Bag 1D:

Filter I.D. 1 2009

Nozzle I.D. 1 8-1

Head, Ap 200

24hr. Int. 18

Gas Meter 18

Probe Heat Setting

signed: Tracy Ross

Constants

$T_0 = 82.9$ °F

$P_0 = 23.92$ in. Hg.

$\Delta H = 2.4$ in. Hg.

$V_{select} = 68.710$ ft^3

$V_{actual} = 53.118$ ft^3

$T_0 = 90.5$ °F

$P_0 = 5.03$ in. Hg.

$T_0 = 59.6$ °F

$P_0 = 150$ psig

$T_0 = 93.4$ °F

$P_0 = 73.2$ psig

KJ(b)

KJ(a)

KJ(b)

$T_0 = 82.9$ °F

$P_0 = 23.92$ in. Hg.

$\Delta H = 2.4$ in. Hg.

$V_{select} = 68.710$ ft^3

$V_{actual} = 53.118$ ft^3

$T_0 = 90.5$ °F

$P_0 = 5.03$ in. Hg.

$T_0 = 59.6$ °F

$P_0 = 150$ psig

$T_0 = 93.4$ °F

$P_0 = 73.2$ psig

KJ(b)

KJ(a)

KJ(b)

$T_0 = 82.9$ °F

$P_0 = 23.92$ in. Hg.

$\Delta H = 2.4$ in. Hg.

$V_{select} = 68.710$ ft^3

$V_{actual} = 53.118$ ft^3

$T_0 = 90.5$ °F

$P_0 = 5.03$ in. Hg.

$T_0 = 59.6$ °F

$P_0 = 150$ psig

$T_0 = 93.4$ °F

$P_0 = 73.2$ psig

KJ(b)

KJ(a)

KJ(b)

$T_0 = 82.9$ °F

$P_0 = 23.92$ in. Hg.

$\Delta H = 2.4$ in. Hg.

$V_{select} = 68.710$ ft^3

$V_{actual} = 53.118$ ft^3

$T_0 = 90.5$ °F

$P_0 = 5.03$ in. Hg.

$T_0 = 59.6$ °F

$P_0 = 150$ psig

$T_0 = 93.4$ °F

$P_0 = 73.2$ psig

KJ(b)

KJ(a)

KJ(b)

$T_0 = 82.9$ °F

$P_0 = 23.92$ in. Hg.

$\Delta H = 2.4$ in. Hg.

$V_{select} = 68.710$ ft^3

$V_{actual} = 53.118$ ft^3

$T_0 = 90.5$ °F

$P_0 = 5.03$ in. Hg.

$T_0 = 59.6$ °F

$P_0 = 150$ psig

$T_0 = 93.4$ °F

$P_0 = 73.2$ psig

KJ(b)

KJ(a)

KJ(b)

$T_0 = 82.9$ °F

$P_0 = 23.92$ in. Hg.

$\Delta H = 2.4$ in. Hg.

$V_{select} = 68.710$ ft^3

$V_{actual} = 53.118$ ft^3

$T_0 = 90.5$ °F

$P_0 = 5.03$ in. Hg.

$T_0 = 59.6$ °F

$P_0 = 150$ psig

$T_0 = 93.4$ °F

$P_0 = 73.2$ psig

KJ(b)

KJ(a)

KJ(b)

KJ(a)

KJ(b)

KJ(a)

KJ(b)

FIELD TEST DATA

DATE 9/25/90
 RUN NO. 3101
 EQUIPMENT VENTED
 TYPE ABATEMENT
 EQUIPMENT NUMBER

AMB. TEMP. 23.91
 BAR. PRESSURE
 STACK PRESSURE
 NOZZLE SIZE
 METER RATE FACTOR
 Filter I.D. 7005

start 1050 int. 890.034

ISO 4%

1000 cu.

PT. NO.	SAM. TIME (MIN.)	VEL. HEAD ($\sqrt{\Delta P}$)	DES. SAM. RATE (CFM)	GAS METER RDG FT. ³	METER (ΔP) T.D. 0	STACK TEMP. ° F.	GAS TEMP. @ METER ° F.	SAM. BOX TEMP. ° F.	IMP. IN- LET ° F.	IMP. OUT- LET ° F.
A 1	3.0	.05	2.5	892.80	332.34	80	70		65	10
2	6.0	.10	7.0	895.21	359.11	80	70		63	10
3	9.0	.13	1.0	896.69	124.87	80	71		60	10.5
4	12.0	.15	1.5	897.97	94.4	80	73		60	10.5
5	15.0	.19	1.60	898.37	96.1	80	73		60	5
6	18.0	.25	1.75	900.94	95.7	81	74		61	6
7	21.0	.28	1.0	902.72	94.72	81	74		60	5.5
8	24.0	.30	1.0	904.57	92.76	82	76		61	6.5
9	27.0	.34	1.3	906.69	102.41	82	78		61	7.2
10	30.0	.36	1.3	908.69	90.08	82	82		61	7.5
11	33.0	.40	1.5	910.88	95.92	82	82		61	8.1
12	36.0	.44	1.6	913.17	94.83	82	84		61	8.5
B 13	39.0	.49	2.0	915.66	98.62	82	83		62	10
14	42.0	1.4	2.0	918.20	56.00	82	86		62	10
15	45.0	1.5	2.5	921.01	41.8	82	89		62	12
16	48.0	1.5	3.7	924.42	72.73	82	89		61	17
17	51.0	1.2	3.7	927.91	74.16	82	91		62	17
18	54.0	.90	3.7	931.41	83.81	82	93		62	17
19	57.0	.90	3.7	934.91	95.94	83	93		62	17
20	60.0	.90	3.7	938.39	21.94	85	93		63	17
21	63.0	1.0	3.7	941.90	96.21	85	93		62	17
22	66.0	1.0	3.7	945.40	91.01	85	93		62	17
23	69.0	.90	3.7	948.87	90.23	85	93		62	17
24	72.0	.90	3.5	952.36	95.60	85	93		62	17
		Final CFM					1900.00			
		End Time					Initial Tare 250ml	Final 250ml		
		LOCK CLOCK	0.0 cfm at 24 Hg							
							net	0		
							Mastore S.G.	61.3		
							Total ml	61.3		
TOTAL										
AVG.										

4.6

FIELD TEST DATA

DATE 9/25/00
 RUN NO. 3102
 EQUIPMENT VENTED
 TYPE ABATEMENT
 EQUIPMENT NUMBER

AMB. TEMP.
 BAR. PRESSURE
 STACK PRESSURE
 NOZZLE SIZE
 METER RATE FACTOR
.250

T₁ me 1425 Volume ΔH Int. 953.51 g/TSO

Filter F.D. 7013

VOCC

PT. NO.	SAM. TIME (MIN.)	VEL X HEAD (VΔP)	DES. SAM. ✓ RATE (CFM)	GAS METER RDG FT. ³ *	METER (ΔP ₀) IN. H ₂ O	STACK TEMP. ° F. *	SAM. TEMP. @ METER ° F. *	SAM. BOX TEMP. ° F. *	IMP. IN-LET ° F. *	VOCC %
1	3.0	.90	2.0	956.19	34.20	91	84		63	7.5
2	6.0	.90	3.3	959.23	38.81	91	86		61	12
3	9.0	.90	3.3	962.53	42.00	91	88		60	12
4	12.0	1.0	3.3	965.90	42.86	91	88		60	12
5	15.0	.90	3.5	969.33	41.3	91	90		60	13
6	18.0	.90	3.5	972.78	43.6	91	91		61	13
7	21.0	.70	3.3	976.23	43.56	91	92		61	12
8	24.0	.70	2.6	979.31	44.0	91	93		60	10
9	27.0	.60	2.6	982.75	44.8	91	93		60	10
10	30.0	.60	2.2	985.13	42.20	91	93		60	8
11	33.0	.60	2.2	987.85	41.27	91	94		61	8
12	36.0	.70	2.2	990.58	41.85	91	95		61	8
13	39.0	.70	2.2	993.36	39.52	91	94		62	8
14	42.0	.70	2.4	996.31	41.84	91	96		60	9
15	45.0	.50	2.6	999.28	41.94	90	98		60	9
16	48.0	.60	2.5	1002.21	48.44	90	98		60	9.2
17	51.0	.50	2.3	1005.13	44.30	89	100		60	9.0
18	54.0	.50	2.0	1007.85	45.16	89	100		61	8.0
19	57.0	.50	2.0	1010.51	47.47	89	100		61	8.0
20	60.0	.60	2.0	1013.19	44.50	89	100		61	8.0
21	63.0	.60	2.2	1015.90	41.10	89	100		61	8.2
22	66.0	.60	2.2	1018.67	42.0	89	100		62	8.2
23	69.0	.60	2.2	1021.42	41.70	87	100		62	8.2
24	72.0	.60	2.2	1024.19	42.01	89	100		62	8.2

100% CR. 0.0 CEM
 22 Hg

moisture

tare 250

net 256

5.119
 Gel 58.7

Total 64.7

TOTAL

AVG.

FIELD TEST DATA

DATE 9/25/90
 RUN NO. 3103
 EQUIPMENT VENTED
 TYPE ABATEMENT
 EQUIPMENT NUMBER

AMB. TEMP.
 BAR. PRESSURE
 STACK PRESSURE
 NOZZLE SIZE
 METER RATE FACTOR
 Filter I.D. 7009

23.82

1250

Start
1725

Int. Volume

1024.59

% 150

VACUUM

PT. NO.	SAM. TIME (MIN.)	DP VEL. HEAD (Δ P)	DES. SAM. RATE (CFM)	GAS METER RDG FT. ³	METER (Δ P) IN.H ₂ O	STACK TEMP. ° F.	GAS TEMP. @ METER ° F.	SAM./ BOX TEMP. ° F.	IMP. IN- LET ° F.	IMP. OUT- LET ° F.
A 1	3.0	.60	2.2	027.33	95.73	84	78		61	8.5
2	4.0	.60	2.2	030.07	94.56	84	81		60	8.5
3	5.0	.60	2.2	032.80	1130.24	84	83		58	8.5
4	12.0	.65	2.3	035.51	93.30	84	84		59	8.5
5	15.0	.65	2.4	038.33	93.00	84	84		60	9.0
6	18.0	.70	2.4	041.19	93.90	84	88		60	9.0
7	21.0	.70	2.6	044.11	92.17	84	90		60	9.5
8	24.0	.70	2.6	047.08	93.74	84	90		60	9.8
9	27.0	.70	2.6	050.05	93.58	84	91		61	9.8
10	30.0	.65	2.6	053.02	93.24	84	93		61	9.8
11	33.0	.65	2.4	055.42	94.00	84	95		61	9.5
12	36.0	x .65	2.4	058.79	93.10	84	95		61	9.5
B 13	39.0	.60	2.4	061.69	95.28	84	88		62	9.5
14	42.0	.60	2.2	064.46	93.48	82	91		60	8.9
15	45.0	.65	2.4	067.33	97.16	81	92		60	9.8
16	48.0	.65	2.4	070.22	93.83	81	93		61	9.2
17	51.0	.70	2.6	073.20	90.81	81	93		61	9.5
18	54.0	.70	2.6	076.18	93.29	81	93		62	9.8
19	57.0	.65	2.5	079.19	94.03	81	94		61	9.5
20	60.0	.65	2.4	081.98	92.51	82	94		61	9.3
21	63.0	.65	2.4	084.85	93.10	82	94		61	9.3
22	66.0	.65	2.4	087.72	92.93	82	95		62	9.3
23	69.0	.60	2.3	090.54	91.29	82	95		62	9.0
24	72.0	.60	2.2	093.39	92.63	82	95		62	8.8
TOTAL										
AVG.										

moisture


Tare 250 ml
net 254

5.74
61 55.6

59.6

Appendix 4.5
CALCULATIONS AND COMPUTER PRINTOUTS

5.1



Run
3101

Run 3102
Rerun Data *USED for*
Run Sheet

PORT ENTR	PORT EXIT
1282	1287
1282	1287
BLK TIME	BLK TIME
21.514	21.514
ROT VOL =	ROT VOL =
61.036 FT3	78.036 FT3
LX. RATE (CPM)2	LX. RATE (CPM)2
CORR. VOL =	CORR. VOL =
62.306 FT3	62.306 FT3
AVERAGES	
PGEAR12	PGEAR12
23.91	23.91
PGEAR22	PGEAR22
23.91	23.91
Avg. PGEAR = 23.91	
DEL-T2	15900
	61.776
STK. TEMP	61.526
RUN TIME	72
DEL-T3	2.218
STK. TEMP	62.3
IMP. TEMP	61.3
MTL. TEMP	61.3
MTL. TEMP2	63.2
PLATE VOL	11.7
PGEAR 3102	125.3

PORT ENTR	PORT EXIT	PGEAR22	PGEAR22
PGEAR12	PGEAR12	23.91	23.91
PGEAR22	PGEAR22	23.91	23.91
Avg. PGEAR = 23.91			
DEL-T2	6.6756		
STK. TEMP	70.620		
RUN TIME	72		
DEL-T3	1.354		
STK. TEMP	63.3		
IMP. TEMP	62.3		
MTL. TEMP	62.3		
MTL. TEMP2	63.2		
PLATE VOL	11.7		
PGEAR 3102	125.3		

3101

SAMPLE AT 3102
1282 VOL = 2.58
ROT. VOL = 0.19
K2 = 0.76

SAMPLE AT 3102

3102
1282 VOL = 2.66
ROT. VOL = 0.22
K2 = 0.75
K3 = 3.75

SAMPLE AT 3102

3103
1282 VOL = 2.12
ROT. VOL = 0.21
K2 = 0.73

5.3

CONSTANTS

	AVERAGES	
Plant Name:	General Chem Time Start:	1050
Location:	Green River, Time End:	1210
RUN Number:	3101 Delta P:	0.59
Test Date:	9/25/90 Delta H:	2.21
Stack Id:	GR3 crusher Meter Volume:	62.326
Console Id.:	nutech-2 Stack Temperature:	82.3
Methods Tested:	5 Imp. Temperature:	61.6
No. of points:	24 Meter Temperature:	83.2
No. of Minutes/Point:	3 Meter Vacuum:	11.5
Mtr. Factor, (Yo):	0.987 % Isokinetic (PBP):	105.9
F-Factor, (Fd):	1 Elapsed Minutes:	72
Pitot, (Cp):	0.84 Press. Static , Stac	0.75
Fuel Type:	Press. , Barometric:	23.91
Fo, low:	Ml. H2O condensed:	0
Fo, high:	Leak Rate: cfm.	0
CO2, %dry:	1 Leak Check in.Hg.	24
O2,%dry	18	
SO2, ppmd	0 VARIABLES	
NOx, ppmd	0 Tm	543.20
CO, ppmd	0 Ts	542.30
SO2, %dry	0 Pm	24.0725
CO, %dry	0 Ps	23.96515
Argon, %	0.0078 Tstd	528.00
N2, %	80.9922 Pstd	29.92
	Tstd/Pstd	17.64706
Orifice Delta-Ha:	R	21.85
Altitude of Plant:	1.978 Rho w; density H20	0.0022
Press., Barometric:	Rho a;den. acetone	0.787
**Temp. of Meter:	30. in.Hg. Kp	85.49
**Moisture, Stack:	Mw; Mole wt H20	18.00
**Temp. of Stack:	Mn2	28.013
**Delta-P:	Mco	28.013
**Sample Rate (Delta-H):	Mo2	31.998
**Desired Nozzle, Dia.:	Mco2	44.01
Actual Nozzle, Dia.:	Mso2	64.07
**K3:	0.25 Mar	39.948
Stack Dia., inches	1 Mnox	46.01
Stack Area: sq.ft.	36 Hg. Specific gravity	13.60
Nozzle Area: sq.ft.	7.068375 Con2:RwRTstd/MwPstd	0.04715
	0.000340885	

SO2 LAB	Meter Volume, A	62.326
Blank ml:	0.05 vapor press.	0.552258
H2SO4 ml:	10 Total H2O	61.56556
N. H2SO4:	0.02 Vmstd. dscf	48.22749
TTR Std 1:	20 Vwstd,scf	2.902747
TTR Std 2:	19.95 Bws, moisture	0.056772
Ave. Std. TTR:	19.975 Molecular wt.dr	28.8912
Aliq. Factor:	200 Molecular wt. w	28.27289
VTTR. 1I,ml:	0 Velocity, fps	49.34751
VTTR. 1F,ml:	1 Flow rate,dscf/	923670.4
VTTR. 1Net:	1 DSCFM	15394.51
VTTR. 2I, ml:	0 ACFM	20928.4
VTTR. 2F, ml:	1	
VTTR. 2Net:	1 Fuel Factor F ₀	2.9
VTTR Ave:	1 O2, %dry	18
SO2, ppm:	16.82675 O2, %wet	16.97811
	CO2, %dry	1

SO2 Results(6)

ppm, dry	16.82675	SO2 Results(6C)	
ppm,wet	15.87147	ppm, dry	0
lb./hr.	2.579122	ppm,wet	0
LMBTU	2.01E-05	lb./hr.	0

O2, %dry orsat

CO2, %dry orsat

NOx Results(7E)

ppm, dry	0
ppm, wet	0
lb./hr.	0
LMBTU	0

CO Results(10)

ppm, dry	0
ppm, wet	0
lb./hr.	0
LMBTU	0

Particulate Results

Final Isokinetic	90.2212
probe wash, mg.	7.11667
filter, mg. #	5.3
Total mg	12.41667
gr/scf	0.003973
gr/acf	0.002923
lb/hr	0.524266
LMBTU	4.09E-06
Tons/yr	2.11253

Front	12.4167
Back	62.175
Total mg	74.5917

gr/scf	0.023868
gr/acf	0.017557
lb/hr	3.149467
LMBTU	2.46E-05
Tons/year	12.69078

5.6

CONSTANTS

Plant Name: Green River, Time Start: 1425
 Location: Green River, Time End: 1610
 RUN Number: 3102 Delta P: 0.6756
 Test Date: 9/25/90 Delta H: 2.558
 Stack Id: GR3 crusher Meter Volume: 70.68
 Console Id.: nutech-2 Stack Temperature: 90.3
 Methods Tested: 5 Imp. Temperature: 60.8
 No. of points: 24 Meter Temperature: 94.8
 No. of Minutes/Point: 3 Meter Vacuum: 9.5
 Mtr. Factor, (Yo): 0.987 % Isokinetic (PBP): 96
 F-Factor, (Fd): 1 Elapsed Minutes: 72
 Pitot, (Cp): 0.84 Press. Static , Stack Press. , Barometric: 0.75
 Fuel Type: Ml. H2O condensed: 6
 Fo, low: Leak Rate: cfm. 0
 Fo, high: 2 Leak Check in.Hg. 18
 CO2, %dry: 16
 O2, %dry
 SO2, ppmd
 NOx, ppmd
 CO, ppmd
 SO2, %dry
 CO, %dry
 Argon, %
 N2, %

AVERAGES

General Chem Time Start: 1425
 Green River, Time End: 1610
 3102 Delta P: 0.6756
 9/25/90 Delta H: 2.558
 GR3 crusher Meter Volume: 70.68
 nutech-2 Stack Temperature: 90.3
 5 Imp. Temperature: 60.8
 24 Meter Temperature: 94.8
 3 Meter Vacuum: 9.5
 0.987 % Isokinetic (PBP): 96
 1 Elapsed Minutes: 72
 0.84 Press. Static , Stack Press. , Barometric: 0.75
 Ml. H2O condensed: 6
 Leak Rate: cfm. 0
 2 Leak Check in.Hg. 18
 16
 0 VARIABLES
 0 Tm 554.80
 0 Ts 550.30
 0 Pm 23.99809
 0 Ps 23.86515
 0.0078 Tstd 528.00
 81.9922 Pstd 29.92
 Tstd/Pstd 17.64706
 R 21.85
 Orifice Delta-Ha: 1.978 Rho w; density H20 0.0022
 Altitude of Plant: Rho a;den. acetone 0.787
 Press., Barometric: 30. in.Hg. Kp 85.49
 **Temp. of Meter: Mw; Mole wt H20 18.00
 **Moisture, Stack: Mn2 28.013
 **Temp. of Stack: McO 28.013
 **Delta-P: Mo2 31.998
 **Sample Rate (Delta-H): McO2 44.01
 **Desired Nozzle, Dia.: MsO2 64.07
 Actual Nozzle, Dia.: 0.25 Mar 39.948
 **K3: 3.75 Mnox 46.01
 Stack Dia., inches 36 Hg. Specific gravity 13.60
 Stack Area: sq.ft. 7.068375 Con2:RwRTstd/MWPstd 0.04715
 Nozzle Area: sq.ft. 0.000340885

SO2 LAB	Meter Volume, A	70.68
Blank ml:	0.05 vapor press.	0.536866
H2SO4 ml:	10 Total H2O	64.43302
N. H2SO4:	0.02 Vmstd, dscf	53.32635
TTR Std 1:	20 Vwstd,scf	3.037944
TTR Std 2:	19.95 Bws, moisture	0.053898
Ave. Std. TTR:	19.975 Molecular wt.dr	28.97147
Aliq. Factor:	200 Molecular wt. w	28.38013
VTTR. 1I,ml:	0 Velocity, fps	53.2047
VTTR. 1F,ml:	1 Flow rate,dscf/	980272.4
VTTR. 1Net:	1 DSCFM	16337.87
VTTR. 2I, ml:	0 ACFM	22564.24
VTTR. 2F, ml:	1	
VTTR. 2Net:	1 Fuel Factor Fo	2.45
VTTR Ave:	1 O2, %dry	16
SO2, ppm:	15.21784 O2, %wet	15.13763
	CO2, %dry	2

SO2 Results(6)

ppm, dry	15.21784	SO2 Results(6C)	
ppm,wet	14.39763	ppm, dry	0
lb./hr.	2.475451	ppm,wet	0
LMBTU	1.08E-05	lb./hr.	0

O2, %dry orsat

NOx Results(7E)

CO2, %dry orsat	ppm, dry	0
	ppm, wet	0
	lb./hr.	0
	LMBTU	0

CO Results(10)

ppm, dry	0
ppm, wet	0
lb./hr.	0
LMBTU	0

Particulate Results

Final Isokinetic	93.99961
probe wash, mg.	5.78333
filter, mg. #	4.5
Total mg	10.28333
gr/scf	0.002976
gr/acf	0.002155
lb/hr	0.416738
LMBTU	1.81E-06
Tons/yr	1.679245

Front	10.2833
Back	21.28
Total mg	31.5633

gr/scf	0.009134
gr/acf	0.006614
lb/hr	1.279121
LMBTU	5.57E-06
Tons/year	5.154216

5.9

CONSTANTS			AVERAGES	
Plant Name:	General Chem	Time Start:	1725	
Location:	Green River	Time End:	1910	
RUN Number:	3103	Delta P:	0.6474	
Test Date:	9/25/90	Delta H:	2.4	
Stack Id:	GR3	crusher	Meter Volume:	68.71
Console Id.:	nutech-2		Stack Temperature:	82.9
Methods Tested:			5 Imp. Temperature:	60.8
No. of points:			24 Meter Temperature:	90.5
No. of Minutes/Point:			3 Meter Vacuum:	9.2
Mtr. Factor. (Yo):	0.987	% Isokinetic (PBP):	93.6	
F-Factor. (Fd):		1 Elapsed Minutes:	72	
Pitot. (Cp):	0.84	Press. Static , Stac	0.75	
Fuel Type:		Press. , Barometric:	23.82	
Fo, low:		Ml. H2O condensed:	4	
Fo, high:		Leak Rate: cfm.	0	
CO2, %dry:		1 Leak Check in.Hg.	18	
DO2, %dry	17			
SO2, ppmd		0 VARIABLES		
NOx, ppmd	0	Tm	550.50	
CO, ppmd	0	Ts	542.90	
SO2, %dry	0	Pm	23.99647	
CO, %dry	0	Ps	23.87515	
Argon, %	0.0078	Tstd	528.00	
N2, %	81.9922	Pstd	29.92	
		Tstd/Pstd	17.64706	
		R	21.85	
Orifice Delta-Ha:	1.978	Rho w; density H2O	0.0022	
Altitude of Plant:		Rho a;den. acetone	0.787	
Press., Barometric:	30.	in.Hg. Kp	85.49	
**Temp. of Meter:		Mw; Mole wt H2O	18.00	
**Moisture, Stack:		Mn2	28.013	
**Temp. of Stack:		Mco	28.013	
**Delta-P:		Mo2	31.998	
**Sample Rate (Delta-H):		Mco2	44.01	
**Desired Nozzle, Dia.:		Mso2	64.07	
Actual Nozzle, Dia.:	0.25	Mar	39.948	
**K3:	3.79	Mnox	46.01	
Stack Dia.. inches		36 Hg. Specific gravity	13.60	
Stack Area: sq.ft.	7.068375	Con2:RwRTstd/MwPstd	0.04715	
Nozzle Area: sq.ft.	0.000340885			

57. 10

SO2 LAB	Meter Volume, A	68.71
Blank ml:	0.05	vapor press. 0.536866
H2SO4 ml:	10	Total H2O 59.55399
N. H2SO4:	0.02	Vmstd, dscf 52.2667
TTR Std 1:	20	Vwstd,scf 2.807903
TTR Std 2:	19.95	Bws, moisture 0.050984
Ave. Std. TTR:	19.975	Molecular wt.dr 28.85135
Aliq. Factor:	200	Molecular wt. w 28.29811
VTTR. 1I,ml:	0	Velocity, fps 51.79515
VTTR. 1F,ml:	1	Flow rate,dscf/ 970696.5
VTTR. 1Net:	1	DSCFM 16178.28
VTTR. 2I, ml:	0	ACFM 21966.45
VTTR. 2F, ml:	1	
VTTR. 2Net:	1	Fuel Factor Fo 3.9
VTTR Ave:	1	O2. %dry 17
SO2. ppm:	15.52637	O2. %wet 16.13328
		CO2, %dry 1

SO2 Results(6)

ppm, dry	15.52637
ppm,wet	14.73478
lb./hr.	2.500967
LMBTU	1.38E-05

SO2 Results(6C)

ppm, dry	0
ppm,wet	0
lb./hr.	0
LMBTU	0

O2, %dry orsat

CO2, %dry orsat

NOx Results(7E)

ppm, dry	0
ppm, wet	0
lb./hr.	0
LMBTU	0

CO Results(10)

ppm, dry	0
ppm, wet	0
lb./hr.	0
LMBTU	0

Particulate Results

Final Isokinetic	93.04062
probe wash, mg.	33.55
filter, mg. #	1.9
Total mg	35.45
gr/scf	0.010467
gr/acf	0.007709
lb/hr	1.451439
LMBTU	8.01E-06
Tons/yr	5.848573

Front	35.45
Back	22.5875
Total mg	58.0375

gr/scf	0.017136
gr/acf	0.012621
lb/hr	2.376245
LMBTU	1.31E-05
Tons/year	9.57508

5.12

Appendix 4.6
LABORATORY ANALYTICAL RESULTS

4.1

6.2

Acetone Density(gm/ml)=	6.767	PRIMATE	General Chemical	9/18/90
Acetone Blank				
Beaker ID:	10	Filter Blank		
Wash Volume:	150.0 ml	Filter ID:		
Weight Wash:	118.65 gm	Tare Weight:		
Tare Weight:	101.3513 gm	Tare Weight:		
Tare Weight:	101.3514 gm	Tare Weight:		
Average Tare Wt.:	101.35135 gm	Average Tare Wt.:		
Final Weight:	101.3553 gm	Final Weight:		
Final Weight:	101.3551 gm	Final Weight:		
Final Weight:	101.3552 gm	Average Final Wt.:		
Average Final Wt.:	101.3552 gm	Net Weight:		
Net Weight:	3.65 mg	Net Weight:		
Correction Factor (mg. Blank/gm)	0.032613299	Correction Factor (mg.)	0	

Front Half Run number: 3101

Acetone Sample		Filter Sample	
Beaker ID:	0	Filter ID:	7005
Wash Volume:	350.0 ml	Tare Weight:	
Weight Wash:	275.45 gm	Tare Weight:	
Tare Weight:		Average Tare Wt.:	
Tare Weight:	101.122 gm	Tare Weight:	.3665 gm
Tare Weight:	101.1319 gm	Tare Weight:	.3665 gm
Average Tare Wt.:	101.12195 gm	Average Tare Wt.:	.3665 gm
Final Weight:	101.148 gm	Final Weight:	.3666 gm
Final Weight:	101.1491 gm	Final Weight:	.3666 gm
Average Final Wt.:	101.14865 gm	Average Final Wt.:	.3666 gm
Net Weight:	16.1 mg	Net Weight:	5.3 mg
Blank Correction:	-0.96333 mg	Blank Correction:	0.0 mg
Correct Net Wt.:	7.11667 mg	Correct Net Wt.:	5.3 mg

Actual Total: 12.4167 mg

b.3

Water Density(gm/ml)=	1.00	PROTOKOL	General Chemical	9/18/98
Acetone Blank				
Beaker ID:	11	Filter Blank		
Wash Volume:	200.0 ml	Filter ID:		
Weight Wash:	200.0 gm			
Tare Weight:		Tare Weight:		
Tare Weight:	104.0549 gm	Tare Weight:		
Tare Weight:	104.0549 gm	Tare Weight:		
Average Tare Wt.:	104.0549 gm	Average Tare Wt.:		
Final Weight:		Final Weight:		
Final Weight:	104.0535 gm	Final Weight:		
Final Weight:	104.0535 gm	Final Weight:		
Average Final Wt.:	104.0535 gm	Average Final Wt.:		
Net Weight:	0.1 mg	Net Weight:		
Correction Factor (mg. Blank/gm)	0.0005	Correction Factor (mg.)		

Book Half Run number: 3181

Acetone Sample		Filter Sample		
Beaker ID:	4	Filter ID:		
Wash Volume:	450.0 ml			
Weight Wash:	450.0 gm			
Tare Weight:		Tare Weight:		
Tare Weight:	100.5904 gm	Tare Weight:		
Tare Weight:	100.5905 gm	Tare Weight:		
Average Tare Wt.:	100.5905 gm	Average Tare Wt.:		
Final Weight:		Final Weight:		
Final Weight:	100.6528 gm	Final Weight:		
Final Weight:	100.6527 gm	Final Weight:		
Average Final Wt.:	100.65275 gm	Average Final Wt.:		
Net Weight:	62.4 mg	Net Weight:		
Blank Correction:	-0.225 mg	Blank Correction:		
Correct Net Wt.:	62.175 mg	Correct Net Wt.:		

Actual Total: 62.1750 mg

6.4

Acetone Density(g/ml)=	0.707	INSTRUMENT	General Chemical	9/18/90
Acetone Blank				
Beaker ID:	19	Filter Blank		
Wash Volume:	130.0 ml	Filter ID:		
Weight Wash:	113.05 gm			
Tare Weight:		Tare Weight:		
Tare Weight:	101.5013 gm	Tare Weight:	.4 gm	
Tare Weight:	101.5014 gm	Tare Weight:	.4 gm	
Average Tare Wt.:	101.50135 gm	Average Tare Wt.:	.4 gm	
Final Weight:		Final Weight:		
Final Weight:	101.5053 gm	Final Weight:	.4 gm	
Final Weight:	101.5051 gm	Final Weight:	.4 gm	
Average Final Wt.:	101.5052 gm	Average Final Wt.:	.4 gm	
Net Weight:	3.05 mg	Net Weight:	0.0 mg	
Correction Factor (mg. Blank/gm)	0.02613299	Correction Factor (mg.)	0	

Front Half Run number: 3102

Acetone Sample		Filter Sample		
Beaker ID:	1	Filter ID:	7000	
Wash Volume:	400.0 ml			
Weight Wash:	314.8 gm	Tare Weight:		
Tare Weight:		Tare Weight:	.3397 gm	
Tare Weight:	100.2230 gm	Tare Weight:	.3397 gm	
Tare Weight:	100.2237 gm	Average Tare Wt.:	.3397 gm	
Average Tare Wt.:	100.22375 gm	Final Weight:		
Final Weight:		Final Weight:	.3442 gm	
Final Weight:	100.2390 gm	Final Weight:	.3442 gm	
Final Weight:	100.2390 gm	Average Final Wt.:	.3442 gm	
Average Final Wt.:	100.2390 gm	Net Weight:	4.5 mg	
Net Weight:	16.05 mg	Blank Correction:	0.0 mg	
Blank Correction:	-16.26667 mg	Correct Net Wt.:	4.5 mg	
Correct Net Wt.:	5.78333 mg			

Actual Total: 16.2633 mg

6.5

Water Density(g/ml)=	1.00	FRONTRATE	General Chemical	9/18/98
Acetone Blank				
Beaker ID:	11	Filter Blank		
Wash Volume:	200.0 ml	Filter ID:		
Weight Wash:	200.0 gm			
Tare Weight:		Tare Weight:		
Tare Weight:	104.0549 gm	Tare Weight:		.4 gm
Tare Weight:	104.0549 gm	Tare Weight:		.4 gm
Average Tare Wt.:	104.0549 gm	Average Tare Wt.:		.4 gm
Final Weight:		Final Weight:		.4 gm
Final Weight:	104.055 gm	Final Weight:		.4 gm
Final Weight:	104.055 gm	Final Weight:		.4 gm
Average Final Wt.:	104.055 gm	Average Final Wt.:		.4 gm
Net Weight:	8.1 mg	Net Weight:		0.0 mg
Correction Factor (mg. Blank/gm)	8.0005	Correction Factor (mg.)		0

Book Half Run number: 2102

Acetone Sample				
Beaker ID:	9	Filter Sample		
Wash Volume:	540.0 ml	Filter ID:		
Weight Wash:	540.0 gm			
Tare Weight:		Tare Weight:		
Tare Weight:	99.9108 gm	Tare Weight:		.0 gm
Tare Weight:	99.9107 gm	Tare Weight:		.0 gm
Average Tare Wt.:	99.91075 gm	Average Tare Wt.:		.0 gm
Final Weight:		Final Weight:		.0 gm
Final Weight:	99.9323 gm	Final Weight:		.0 gm
Final Weight:	99.9323 gm	Final Weight:		.0 gm
Average Final Wt.:	99.9323 gm	Average Final Wt.:		.0 gm
Net Weight:	21.35 mg	Net Weight:		0.0 mg
Blank Correction:	-0.27 mg	Blank Correction:		0.0 mg
Correct Net Wt.:	21.28 mg	Correct Net Wt.:		0.0 mg

Actual Total: 21.280 mg

b6

Tetraene Density (g/ml):

6.767

Run Date:

9/18/70

Tetraene Blank

Beaker ID: 18
 Wash Volume: 150.0 ml
 Weight Wash: 116.05 gm
 Tare Weight:
 Tare Weight: 161.5512 gm
 Tare Weight: 161.5514 gm
 Average Tare Wt.: 161.5513 gm
 Final Weight:
 Final Weight: 161.5553 gm
 Final Weight: 161.5551 gm
 Average Final Wt.: 161.5552 gm
 Net Weight: 3.05 mg
 Correction Factor (mg. Blank/gm) 0.02612299

General Control

Filter Blank

Filter ID:
 Tare Weight:
 Tare Weight: .4 gm
 Tare Weight:
 Average Tare Wt.: .4 gm
 Final Weight:
 Final Weight: .4 gm
 Final Weight:
 Average Final Wt.: .4 gm
 Net Weight: 0.0 mg
 Correction Factor (mg.) .1

Front Half Run number: 310

Tetraene Sample

Beaker ID: 2
 Wash Volume: 450.0 ml
 Weight Wash: 354.15 gm
 Tare Weight:
 Tare Weight: 166.2100 gm
 Tare Weight: 166.2107 gm
 Average Tare Wt.: 166.21075 gm
 Final Weight:
 Final Weight: 166.2358 gm
 Final Weight: 166.2357 gm
 Average Final Wt.: 166.23585 gm
 Net Weight: 45.1 mg
 Blank Correction: -11.55 mg
 Correct Net Wt.: 33.55 mg

Filter Sample

Filter ID: 7013
 Tare Weight:
 Tare Weight: .3592 gm
 Tare Weight:
 Average Tare Wt.: .3592 gm
 Final Weight:
 Final Weight: .3611 gm
 Final Weight:
 Average Final Wt.: .3611 gm
 Net Weight: 1.0 mg
 Blank Correction: 0.0 mg
 Correct Net Wt.: 1.0 mg

Actual Total: 35.458 mg

6.7

User Density(gm/ml)=	1.00	PERMATE	General Chemical	9/10/99
Acetone Blank				
Beaker ID:	11	Filter Blank		
Wash Volume:	200.0 ml	Filter ID:		
Wight Wash:	200.0 gm			
Tare Weight:		Tare Weight:		
Tare Weight:	104.0549 gm	Tare Weight:	.4 gm	
Tare Weight:	104.0549 gm	Tare Weight:	.4 gm	
Average Tare Wt.:	104.0549 gm	Average Tare Wt.:	.4 gm	
Final Weight:		Final Weight:		
Final Weight:	104.0555 gm	Final Weight:	.4 gm	
Final Weight:	104.0555 gm	Final Weight:	.4 gm	
Average Final Wt.:	104.0555 gm	Average Final Wt.:	.4 gm	
Net Weight:	0.1 mg	Net Weight:	0.8 mg	
Correction Factor (mg. Blank/gm)	0.0005	Correction Factor (mg.)	0	

Book Half Run number: 2100

Acetone Sample				
Beaker ID:	12	Filter Sample		
Wash Volume:	325.0 ml	Filter ID:		
Wight Wash:	325.0 gm			
Tare Weight:		Tare Weight:		
Tare Weight:	100.4637 gm	Tare Weight:	.0 gm	
Tare Weight:	100.4638 gm	Tare Weight:	.0 gm	
Average Tare Wt.:	100.46375 gm	Average Tare Wt.:	.0 gm	
Final Weight:		Final Weight:		
Final Weight:	100.4606 gm	Final Weight:	.0 gm	
Final Weight:	100.4606 gm	Final Weight:	.0 gm	
Average Final Wt.:	100.4606 gm	Average Final Wt.:	.0 gm	
Net Weight:	22.05 mg	Net Weight:	0.0 mg	
Blank Correction:	-0.2625 mg	Blank Correction:	0.0 mg	
Correct Net Wt.:	22.3075 mg	Correct Net Wt.:	0.0 mg	

Actual Total: 22.3075 mg

b.8