



January 24, 2011

Mr. "Shawn" Chanh Tieu
BP West Coast Products, LLC
2350 East 223rd Street
Carson, California 90810

Sub: Source test report for emissions testing of Tail Gas Unit Incinerator No.2 for CO, PM, and VOC at BP West Coast Products LLC, located in Carson, California (Facility ID: 131003).

Dear Mr. Tieu:

Please find enclosed three copies of the subject source test report. Additionally, a copy of this report has been sent to you electronically. Testing was conducted on December 16, 2010.

If you have any questions or comments regarding the enclosed package, please contact Mr. Charles Figueroa or myself at 714-889-4000.

Sincerely,

A handwritten signature in black ink, appearing to read "Surya".

Surya Adhikari
Project Manager



SOURCE TEST REPORT

Emissions Testing of Tail Gas Unit Incinerator No. 2 for CO, PM, and VOC

Facility ID: 131003

Device ID: C910

Prepared for:

BP West Coast Products, LLC

2350 East 223rd Street

Carson, California 90810

Test Date(s): December 16, 2010

Report Date: January 21, 2011

Project: 9036


Prepared by:

Almega Environmental & Technical Services

5251 McFadden Avenue

Huntington Beach, CA 92649

Prepared by & Title: _____


Surya Adhikari, Project Manager

Reviewed by & Title: _____


Charles Figueroa, Sr. Project Manager

TABLE OF CONTENTS

<u>No.</u>	<u>Section</u>	<u>Page</u>
	Table of Contents	i
1.0	Executive Summary	1
1.1	Summary of Results	2
2.0	Introduction	3
2.1	Document Outline	3
3.0	Test Results and Discussion	4
3.1	Test Discussion	4
3.2	Test Chronology	5
4.0	Equipment and Process Description	6
4.1	Process Description	6
4.2	Operating Conditions During Testing	6
4.3	Sampling Locations	6
5.0	Sampling and Analytical Procedures	8
5.1	SCAQMD Methods 1.1-4.1 – Stack Gas Parameters and Sampling Locations	8
5.2	SCAQMD Method 100.1 – Continuous Monitoring of Gaseous Emissions	11
5.3	SCAQMD Method 5.2 – Particulate Matter Emissions	15
5.4	SCAQMD Method 25.3 – VOC, as TGNMO	18
6.0	Quality Assurance / Quality Control	20
6.1	General QA/QC	20
6.2	Project-Specific QA/QC	20

TABLE OF CONTENTS - Continued

Appendices

Appendix A - General Calculations and Formulae

Appendix B - Approvals and Certifications

B1 - SCAQMD and CARB Testing Approvals

B2 - Certification of No Conflict of Interest

Appendix C - Reference Method Continuous Emissions Monitoring System (RM CEMS)

C1 - RM CEMS – Results and Calculations

C2 - RM CEMS – Strip chart

C3 - RM CEMS – DAS One-minute Data

Appendix D - SCAQMD Method 5.2 – Particulate Matter Emissions

D1 - Particulate Matter Emissions – Results and Calculations

D2 - Particulate Matter Emissions – Field Data

D3 - Particulate Matter Emissions – Laboratory Data

Appendix E - SCAQMD Method 25.3 – VOC, as TGNMO

E1 - VOC, as TGNMO – Results and Calculations

E2 - VOC, as TGNMO – Field Data

E3 - VOC, as TGNMO – Laboratory Data

Appendix F - Quality Assurance and Quality Control (QA/QC)

F1 - Test Equipment Calibration Data

F2 - CEMS Calibration Gas Certificates

Appendix G - Facility Process Data

Appendix H - SCAQMD Permit to Operate

Appendix I - SCAQMD Checklist for Source Test Reports, Form Str.

Attachments

Attachment 1 – Laboratory Report and Data Package for TGNMO per SCAQMD Method 25.3

1.0 EXECUTIVE SUMMARY

Key project information is provided in the summary below. Test results are summarized in Table 1-1.

Customer	BP West Coast Products, LLC. 2350 East 223rd Street Carson, California 90810 Contact: Mr. "Shawn" Chanh Tieu, tel. (310) 847-5644
Equipment Location	Same
Facility ID	131003
Equipment	Tail Gas Unit Incinerator No.2 (TGU-2)
Device ID Number	C910
Test Objective	Measure emissions of carbon monoxide (CO), particulate matter (PM) and volatile organic compounds (VOCs) to satisfy conditions D328.1 of the applicable SCAQMD permit and SCAQMD Rules 404 and 409 respectively.
Test Requested by	Mr. "Shawn" Chanh Tieu of BP West Coast Products, LLC.
Test Date(s)	December 16, 2010
Testing Firm	Almega Environmental & Technical Services 5251 McFadden Avenue Huntington Beach, CA 92649 Contact: Mr. Surya Adhikari, tel (714) 889-4000
Test Personnel	Tom Tran, Dorian Johnson and Bryan Harrison of Almega Environmental & Technical Services
Regulatory Agency	South Coast Air Quality Management District (SCAQMD) 21865 East Copley Drive Diamond Bar, CA 91765-4182 Contact: Mr. Mike Cecconi, tel: (909) 396-2244

TABLE 1-1. SUMMARY OF RESULTS

Facility: BP West Coast Products, LLC
City: Carson, CA
Source: No. 2 TGU
Location: Stack

TEST DATA	Units	Test Results	Allowed Limit
Test Date	m/d/y	12/16/10	
Test Time	hh:mm	10:15-12:26	
Process Data⁽¹⁾			
Firing rate, Rated	MMBtu/hr	44.5	
Sampling Data⁽²⁾			
Stack Temperature	°F	1,268	
Moisture	%	8.82	
Gas Velocity	ft/sec	31.4	
Stack Flow Rate	acfm	106,918	
Stack Flow Rate	dscfm	29,306	
SCAQMD Method 100.1 - CEMS			
<u>Stack Diluent Gases</u>			
Oxygen, O ₂ , as measured	%	8.40	
Carbon Dioxide, as measured	%	4.71	
<u>Carbon Monoxide, CO</u>			
Concentration, as measured	ppmv	481	2000 (Rule 407)
Concentration @ 3% O ₂	ppmv	689	
Emission Rate	lbs/hr	62.4	
SCAQMD Method 5.2 - Particulate Matter			
<u>Total PM</u>			
Total Catch	mg	69.8	0.053 (Rule 404) 0.1 (Rule 409)
Concentration	gr/dscf	0.0121	
Concentration @ 12% CO ₂	gr/dscf @12%	0.0309	
Emission Rate	lbs/hr	3.05	
SCAQMD Method 25.3 - Total Hydrocarbons			
<u>TGNMO, as Methane⁽³⁾</u>			
Reported per AB2588 guidelines			
Condensable			
Concentration ⁽⁴⁾	ppmv	0.54	
Mass Emission Rate	lbs/hr	0.036	
Volatile			
Concentration ⁽⁴⁾	ppmv	0.84	
Mass Emission Rate	lbs/hr	0.056	
Total			
Concentration,	ppmv	1.38	
Mass Emission Rate	lbs/hr	0.092	
<u>TGNMO as Measured⁽⁵⁾</u>			
Concentration,	ppmv	1.24	
Mass Emission Rate	lbs/hr	0.082	

Notes:

(1) Process data was provided by the facility. Unit was operating on refinery fuel gas.

(2) Performed during isokinetic sampling (e.g. SCAQMD Method 5.2).

(3) Used SCAQMD Method 25.3's default MW to Carbon ratio (as hexane) for mass emission rate calculations.

(4) Fraction used "One-half value of the reporting limit" for the ND results as specified in AB2588 guidelines.

(5) Some of the measured values were lower than the reporting limit.

2.0 INTRODUCTION

Almega Environmental & Technical Services (Almega) has been contracted by BP West Coast Products, LLC to conduct stationary source emissions testing of the Tail Gas Unit Incinerator No.2 (TGU-2) at its facility located in Carson, California. The purpose of the test was to measure emissions from the exhaust of this unit for carbon monoxide (CO), particulate matter (PM), and volatile organic compounds (VOCs) to satisfy conditions of the applicable SCAQMD permit requirements.

The CO testing was conducted to satisfy the requirements of SCAQMD Rule 407 as detailed in Condition D328.1. Particulate testing was conducted to demonstrate compliance for SCAQMD Rules 404 and 409. Testing for VOC was conducted for internal reporting purposes.

Table 2-1 lists the test matrix employed during the test.

TABLE 2-1. TEST MATRIX

PARAMETER	LOCATION	TEST METHOD	# OF TEST RUNS	TEST TIME
Stack Traverse Points	Exhaust	SCAQMD Methods 1.1	As Required	--
Stack Gas Flow Rate	Exhaust	SCAQMD Method 2.1	1	120 min.
Molecular Weight and Excess Air	Exhaust	SCAQMD Method 3.1	1	120 min.
Moisture	Exhaust	SCAQMD Method 4.1	1	120 min.
CO, O ₂ , & CO ₂	Exhaust	SCAQMD Method 100.1	1	120 min.
Particulate Matter (PM)	Exhaust	SCAQMD Method 5.2	1	120 min.
VOC as TGNMO	Exhaust	SCAQMD Method 25.3	1 (Dup)	60 min.

Almega performed source testing while the process was operated at its normal operating conditions. Sampling was performed at the exhaust stack. Testing was conducted as specified in the reference methods.

2.1 Document Outline

This report is organized as follows. Section 1.0 is a summary of the project and test results. Section 2.0 describes the project, its objectives and approach. Section 3.0 discusses test results. Section 4.0 describes the equipment tested and applicable sampling locations. Section 5.0 describes the sampling and analytical procedures used to conduct the testing. And Section 6.0 describes Quality Assurance and Quality Control activities performed. The Appendices contain test results, calculated data, raw field data, facility process and test data, calibration records, certification documents, and laboratory data package.

3.0 TEST RESULTS AND DISCUSSION

The testing was conducted after the arrival of Almega's test personnel and set-up of test equipment. The source was operated by plant personnel during testing activities. The testing was conducted at normal operating conditions for the process. No unusual operating conditions were noted during the test periods.

3.1 Test Discussion

Test results are summarized in Table 1-1. Detailed test results are discussed below.

- The measured CO concentration was 481 ppmv, which is less than the limit of 2000 ppmv imposed by Rule 407. The corresponding CO mass emission rate was 62.4 lbs/hr.
- The CO compliance testing was integrated with the NO_x, O₂, and Flow RATA testing conducted at the same time.
- The measured particulate matter (PM) concentration was 0.0121 grains/dscf, and 0.0309 grains/dscf corrected to 12% CO₂. These concentrations are less than the limit of 0.0530 and 0.1 grains/dscf imposed by Rule 404 and 409 respectively. The corresponding PM mass emission rate was 3.05 lbs/hr.
- The reported VOC concentration, TGNMO as methane, was 1.38 ppmv. The corresponding VOC emission rate, calculated as hexane, was 0.092 lbs/hr. Test results for VOC were reported in accordance with the guidelines for source test reporting under California's AB2588, Air Toxics Hot Spots Regulations, which reports the analysis results below the limit of detection (i.e. none detected or ND), substituting with one half of the detection limit.
- The VOC concentration below the reporting limit was also reported for qualitative purposes. The measured VOC concentration, TGNMO as methane, was reported as 1.24 ppmv, which included the analysis values observed below the reporting limit. This corresponding VOC emission rate, calculated as hexane, was 0.082 lbs/hr.
- The run 1A sample leaked (verified by CEMS data) and therefore not used for reporting purposes.

3.1.1 Others

- All measured concentrations were corrected for bias zero and bias calibration drifts according to SCAQMD Method 100.1 (See Appendix C1).

- All instruments performed properly during testing and their performance specifications were within the allowable limits specified in Method 100.1 (See Appendix C1).
- Reference Method CEMS probe was traversed across the stack for the representative sampling (See Strip Chart and DAS).
- Cyclonic flow check was performed prior to the sampling. No cyclonic flow was found (See Appendix D2).

Testing was performed as specified in the reference methods. No modifications to proposed sampling and analysis procedures other than those noted above were required.

3.2 Test Chronology

Testing for CO, O₂, CO₂, PM, VOC, and other performance testing were conducted during the periods listed below:

Parameter-Measurement	Test Date
CO, PM, and VOC	December 16, 2010 (10:15-12:26)

4.0 EQUIPMENT AND PROCESS DESCRIPTION

BP West Coast Products, LLC is a petroleum refining company that refines oil and produces oil products. The process and equipment tested are described below.

4.1 Process Description

The hydrogen sulfide (H₂S) and ammonia (NH₃) from the DEA strippers and sour water strippers are burned in the Claus Plant muffle furnaces and further reacted in downstream catalyst beds to form sulfur, sulfur dioxide (SO₂), and water. Sulfur dioxide that is not converted to sulfur in the Claus Plant is sent to the Tail Gas Unit (TGU) and is converted to hydrogen sulfide in the presence of a catalyst. The hydrogen sulfide is then absorbed using MDEA and sent back to the Claus Plant. Some unrecirculated hydrogen sulfide remains in the tail gas is sent to the incinerators.

The incinerators are used to oxidize the excess hydrogen sulfide in process gases from the gas absorber tower, the tail gas bypass from four Claus Sulfur Plants and the sulfur pit vent gases, to sulfur dioxide in the stack outlet gas.

The thermal oxidizer, No.2 is fired on refinery gas with rated heat input of 44.5 MMBtu/hr.

4.2 Operating Conditions During Test

The process was operated normally during the test period. The unit operates 24 hours a day. Supporting information for process conditions during the testing are found in Appendix F.

4.3 Sampling Locations


The reference method sampling locations are located on the exhaust stack. A schematic of the stack with sampling locations are shown in Figure 4-1. The reference method sampling locations meet the following specifications:

Sampling Location Configuration for Reference Method CEMS Probe:	
Upstream	273 in. (2.68 duct diameter)
Downstream	591 in. (5.79 duct diameter)
Port Length	9 in. (measured from outside of wall)
Port Inside Diameter	4.0 in
Number of Sampling Ports	4 (located at 90° intervals)
Stack Diameter	102 in. (Internal diameter)

The sampling location complies with the requirements of SCAQMD Method 1.1.

Figure 4-1. Stack Schematic

BP - Carson Refinery
Tail Gas Unit #2



5.0 SAMPLING AND ANALYTICAL PROCEDURES

Test measurements were performed according to sampling and analysis procedures promulgated by the South Coast Air Quality Management District (SCAQMD), California Air Resources Board (CARB), or US Environmental Protection Agency (EPA). The sampling and analysis procedures used for this test program are summarized below. Any modifications or deviations not addressed herein are discussed in Section 3 of this report.

- 5.1 SCAQMD Methods 1.1-4.1 – Determination of Stack Gas Volumetric Flow Rate, Molecular Weight, and Moisture Content
 - 5.1.1 SCAQMD Method 1.1 – Sampling Traverse Points
 - 5.1.2 SCAQMD Method 2.1 – Stack Gas Flow Rate
 - 5.1.3 SCAQMD Method 3.1 – Stack Gas Molecular Weight
 - 5.1.4 SCAQMD Method 4.1 – Stack Gas Moisture Content
- 5.2 SCAQMD Method 100.1 – Continuous Monitoring of Gaseous Emissions, CEMS
- 5.3 SCAQMD Method 5.2 – Particulate Matter
- 5.4 SCAQMD Method 25.3 – VOC, as TGNMO (Low-level)

5.1 SCAQMD Methods 1.1-4.1 – Determination of Stack Gas Volumetric Flow Rate, Molecular Weight, and Moisture Content

The fuel gas flow characteristics (i.e. flow rate, molecular weight, and moisture content) were determined according to SCAQMD Methods 1.1 through 4.1. The testing was conducted as follows:

5.1.1 SAMPLING AND VELOCITY TRAVERSE POINTS

The number and location of traverse points were determined according to SCAQMD Method 1 based on the physical dimensions of the sampling location and process parameters. In principle, the stack cross-section is divided into equal areas, each of which was represented by a “traverse point”. Generally, the number of traverse points diminished as the flow profile at the sampling location became uniform. In most cases, the maximum number of sampling points is 24 for particulate testing and 16 for velocity traverses. Fewer traverse points were permitted as described in the method.

5.1.2 STACK GAS VELOCITY AND FLOW RATE

The velocity and volumetric flow rate of the stack gas was determined according to SCAQMD Method 2. In this method, the velocity head (differential pressure) and temperature are measured at the required traverse points. The stack gas differential pressure head was determined using an "S" type pitot tube and inclined manometer as differential pressure gauge. The temperature was measured using a type "K" thermocouple (TC) and digital temperature readout.

Prior to testing, the measurement system was set-up and leak-checked. Then the velocity head and temperature were recorded at predetermined traverse points. After the last traverse was completed, the system was again leak-checked. After completion of the traverse, the static pressure in the stack was determined in the centroid of the stack. The stack gas velocity was calculated using the velocity head, and stack gas temperature, pressure and molecular weight.

QA/QC for the method included field performance checks, and periodic calibrations of test equipment including the pitot tube, differential pressure gauge, TC and TC-readout. A swirl check was also performed to assess cyclonic flow.

5.1.3 STACK GAS MOLECULAR WEIGHT

The stack gas molecular weight (MW) was calculated based on the fraction of its major constituents including: oxygen (O₂), carbon dioxide, (CO₂), nitrogen (N₂), carbon monoxide (CO), and water (H₂O). The dry MW was calculated based on the partial fractions of O₂, CO₂, N₂, and CO. Specifically, the O₂ and CO₂ fractions were determined by CEMS, integrated sampling, or grab sampling, and the balance was assumed to be N₂ and CO. The wet MW was calculated based on the fractions of dry gas and water vapor. The dry and wet MW were calculated according to the following equations:

$$MW_{\text{DRY}} = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (\%N_2 + \%CO)$$

$$MW_{\text{WET}} = 0.18 \times \%H_2O + MW_{\text{DRY}} \times (1 - \%H_2O/100)$$

where:

- MW_{DRY} = stack gas molecular weight, dry-basis
- MW_{WET} = stack gas molecular weight, wet-basis
- 0.32 = molecular weight fraction for O₂
- 0.44 = molecular weight fraction for CO₂
- 0.28 = molecular weight fraction for N₂ and CO
- 0.18 = molecular weight fraction for H₂O (water vapor)
- %X = fraction of X in stack gas, dry basis, where X = O₂, CO₂, N₂, CO
- %H₂O = fraction of water vapor in stack gas, wet-basis

5.1.4 SCAQMD METHOD 4.1- STACK GAS MOISTURE CONTENT

The stack gas moisture content was determined according to SCAQMD Method 4.1. In this method, water vapor is collected in a condenser while the dry stack gas volume is measured using a dry gas meter. The volume of water vapor was calculated from the amount of water condensed and the total gas volume was the sum of water vapor plus dry stack gas. The moisture content was determined as a fraction of the total wet stack gas volume. The following calculations were used.

$$B_{WS} = \frac{V_{W,Std}}{V_{M,Std} + V_{W,Std}}$$

$$V_{W,Std} = K_1 \times V_{H_2O}$$

$$V_{M,Std} = T_{Std}/P_{Std} \times Y_M \times V_M \times P_M/T_M$$

where: B_{WS} = Fraction of water vapor in stack gas
 $V_{W,Std}$ = Volume of water vapor (scf)
 $V_{M,Std}$ = Volume of stack gas sampled (dscf)
 K_1 = Unit volume of water vapor (0.04707 scf @68°F or 0.0464 scf @60°F)
 T_{Std} = Standard Temperature (528°R or 520°R)
 P_{Std} = Standard Pressure, 29.92 in. Hg
 Y_M = Dry gas meter calibration factor
 V_M = Measured volume of stack gas sampled
 P_M = Dry gas meter pressure (in. Hg)
 T_M = Dry gas meter temperature (°R)

Moisture content was determined simultaneously with isokinetic sampling of particulate matter.

5.2 SCAQMD Method 100.1 - Continuous Monitoring of Gaseous Emissions, CEMS

In this method, gaseous components of the stack gas (e.g. NO_x, SO₂, O₂, CO) are measured continuously according to SCAQMD Method 100.1 using Almega's mobile continuous emissions monitoring system (CEMS). Figure 5-1 is a schematic of Almega's CEMS.

The CEMS extracts and conditions a representative stack gas sample and analyzed the gas using one or more analytical instruments. Typical CEMS instrumentation is described in Table 5-1. The extraction and conditioning system consists of a stainless steel heated probe, a short heated TFE sample line, a conditioning system, a TFE-diaphragm pump and a TFE transport (sample) line. The sample conditioning system, consisting of water knockout impingers and/or a thermoelectric condenser, removed moisture before the gas was delivered to the analyzers. Sample flow and delivery are controlled using a flow control panel that included valves, pressure gauges, and flow meters (rotameters). The flow control panel allows the user to deliver sample gas to any and all instruments. Instrument readings are recorded using a real-time strip chart and an electronic data acquisition system (DAS). Other pertinent data such as calibration gas cylinder numbers and concentrations, test location, dates, times, and operator identification are also recorded on the strip chart and on the field data form.

Sampling included pretest and post-test calibration and bias checks for each sampling run. Raw concentration data were corrected for sampling system bias according to Method 100.1 using the following equation:

$$C_{\text{CORR}} = C_{\text{MA}} \times \frac{(C_i - \text{BIAS}_{\text{ZERO}})}{(\text{BIAS}_{\text{SPAN}} - \text{BIAS}_{\text{ZERO}})}$$

Where: C_{CORR} = Concentration, corrected for drift and bias
 C_i = Average measured concentration (raw value)
 $\text{BIAS}_{\text{ZERO}}$ = Average instrument response during zero bias check
 C_{MA} = Certified concentration of applicable span gas
 $\text{BIAS}_{\text{SPAN}}$ = Average instrument response during span bias check

The following QA/QC activities were performed during testing.

- Prior to testing, each individual analyzer was calibrated (adjusted) by introducing zero, hi-span and mid-span gases directly into each analyzer and by making corresponding adjustments.
- Prior to testing, calibration error, linearity and system bias checks were performed on each analyzer. Calibration error and linearity checks were performed by injecting known calibration gases directly to each instrument. System bias checks were performed by injecting calibration gases at the sampling-probe/junction or at the sampling probe tip.

- The system response time for each parameter was determined at the moment when the calibration gas for the bias check reached 95% of its expected concentration value.
- A leak check was conducted before sampling and periodically thereafter to ensure that no leakage occurred in the entire sampling apparatus. The leak check was performed on the vacuum side by sealing the probe tip and increasing vacuum to above 20 inches of mercury. After the vacuum stabilized, it should have held constantly at about 20 in. Hg. On the pressure side, the pressure gauge indicator should have dropped to zero and flow to each individual rotameter also should have dropped to zero to indicate a successful leak check.
- Calibration gases used to span instrumentation conformed to EPA Protocol-1. Certificates of analysis for calibration gases are included in the report.

Figure 5-1. Continuous Emissions Monitoring System




TABLE 5-1. ALMEGA CEMS – GENERAL EQUIPMENT SPECIFICATIONS

ANALYZERS					
Specification	O ₂	CO ₂	NO _x	CO	SO ₂
Manufacturer	Teledyne	Servomex	T-API	Thermo Electron	Western Research
Model	326RA	1400B	200AH	48C	921
Analytical Principle	E-Chemical Cell	NDIR	Chemiluminescent	NDIR-GCC	NDUV
Ranges	%: 0-5, -10, -25	%: 0-5, -10, -20	ppmv: 0-2.5, -10, -25, -50, -100, -250, -1,000	ppmv: 0-20, -50, -100, -200, -500, -1k, x10	ppmv: 0-10, -25, -50, -100, -200, -300
Accuracy, % of Full Scale	+/- 1%	+/- 1%	+/- 1%	+/- 1%	+ 0.5%
Repeatability, % of Full Scale	0.5%	0.5%	0.5%	0.5%	0.5%
Sensitivity, % of Full Scale	0.5%	0.5%	0.5%	0.5%	<2% of Range
Zero/Span Drift, % of Full Scale	+/- 1%, in 24 Hrs	+/- 1%, in 24 Hrs	+/- 1%, in 24 Hrs	+/- 1%, in 24 Hrs	-
Response Time	3 Seconds	<2 Seconds	1.7 Seconds	<2.0 Seconds	30 seconds
Linearity, % of Full Scale	< 1%	< 1%	< 1%	< 1%	< 1%
Output	1V DC, 5V DC	0.1V DC, 1V DC	1V DC, 10V DC	1V DC, 10V DC	0-1V DC
OTHER CEMS EQUIPMENT					
Specification	Sample Conditioner	Strip Chart Recorder			
System used	Primary	System used	Manufacturer	Model	Primary
Manufacturer	Almega	Back-up	Universal	Model 1090	Yokogawa
Model	(in-house)	Refrigeration	Model 1090	Refrigeration	Model HR 2400
Principle	Refrigeration	500 F	500 F	Pen Response	3 sec.
Max. Inlet Temperature	>700 F	50 psi	50 psi	Input Voltage	user-selectable
Max. Inlet Pressure	10 SCFH	50%	7.0 Lpm	Chart Speed	user-selectable
Max. Flow Rate	50%	< 37 F	35 F +/- 2 F	Chart Width	10 inches
Max. Water Concentration			+/- 0.5 F	Output	user-selectable
Outlet Dew-Point Temperature				No. of Channels	30 user-select. 30 calc'd
Dew-Point Stability				Colors	10 color, user-selectable

5.3 SCAQMD Method 5.2 - Total Particulate Matter

A series of preliminary measurements were made prior to conducting the particulate test. SCAQMD Methods 1.1, 2.1, and 4.1 were performed to determine location and number of traverse points, average gas velocity, molecular weight, and moisture content, respectively. The results of these measurements were used to determine the appropriate nozzle size for isokinetic sampling.

Figure 5-1 is a schematic of the sampling train used for SCAQMD Method 5.2. The sampling train consists of a glass nozzle, heated probe, jumper line and filter, a set of glass impingers, umbilical line, a vacuum pump, dry gas meter, and calibrated orifice. Impingers #1 and #2 in the absorption train were charged with 100 ml of distilled water, impinger #3 was left empty, and impinger #4 was filled with approximately 200 g of silica gel. The probe was brushed out, rinsed with acetone. The filter was tarred and placed in the filter holder. The sampling apparatus was sealed and transported to the sampling site where it was assembled and leak tested at 15 inches of mercury (Hg.) vacuum.

After the initial gas meter reading was appropriately recorded, the nozzle was positioned into the gas flow. The vacuum pump was started immediately and adjusted to obtain an isokinetic sample rate. A complete traverse was performed. Stack gas temperature, velocity pressure (dP), meter temperature, gas volume, and meter pressure vacuum were monitored and recorded at each sample point.

Upon completion of sampling, the apparatus was leak checked at a vacuum greater than the highest vacuum observed during testing. After the leak rate was recorded, the apparatus was disassembled, sealed and transported to the laboratory for recovery.

The probe, nozzle and filter housing was washed as instructions per SCAQMD Method 5.2. The wash fluid was subsequently transferred to clean, labeled Nalgene bottles, where the fluid level was appropriately marked.

ANALYSIS

The filter and any loose particulate were carefully removed from the filter holder with tweezers. The filter was placed into a labeled petri dish and secured until analysis. The nozzle, probe and filter housing was rinsed and brushed six times with distilled water. The sample fractions were combined, bottled, labeled and fluid levels marked for transportation to Almega laboratory for analysis. Aliquots of the distilled water were similarly treated for blank analysis.


The absorption train was inspected for abnormalities and subsequently disassembled. The water gain in the impingers was weighed on a digital scale in order to determine percent moisture. The contents of the impingers were quantitatively transferred into separate bottles, sealed, labeled and fluid levels marked for transportation to Almega laboratory for analysis.

Aliquots of the reagent grade impinger contents were saved for blank analysis. The filter was transferred to an oven and heated to 105 deg. C for 2-3 hours and then placed in desiccators for 24 hours. The filter was then weighed on a digital scale to the nearest 0.1 mg and weighed to a constant weight.

The nozzle, probe and filter top was examined for any leakage during transportation and transferred to a tarred evaporation dish. The wash was then evaporated at an elevated temperature, below the boiling point of the wash. The dish and wash residue were then desiccated and weighed to a constant weight.

The contents of the first impinger were recovered and the sample was then evaporated, desiccated and weighed to a constant weight. Additionally, an organic extract of the condensable (back half) was taken, as the organic content was expected to be greater than 5 mg or 5 percent of the combined probe and impinger catch. The net weight of particulate matter was then calculated from both the filter portion and the impingers content.

Figure 5-2. Sampling Apparatus for Particulate Matter



5.4 SCAQMD Method 25.3 – VOC, as TGNMO (Low-level)


This method applies to the measurement of low-concentration (≤ 50 ppmv) Volatile Organic Compounds (VOC) or total gaseous non-methane organics (TGNMO) as carbon in source emissions. In this method, gaseous samples are withdrawn from the gas stream at a constant rate through duplicate chilled condensate traps and collected in evacuated sample tanks. The sampling system is depicted in Figure 5-3. Each sampling train (there are two) consisted of an in-stack filter (optional), sample probe, water-chilled mini-impinger, a flow control system, and an evacuated sample tank. The flow controller incorporated a combination vacuum/pressure gauge, which was connected directly to the canister. The TGNMO was determined by combining the analytical results obtained from independent analyses of the condensate traps (condensable fraction) and the sample tanks (gaseous fraction).

Prior to testing, the sampling system was pre-cleaned and evacuated in preparation for sample collection. On-site, the sampling system was leak-checked and the impingers were placed in an ice-slurry (the impingers are chilled for at least 30 minutes prior to sampling). Then the sample probe was placed in the stack, facing downstream to prevent collection of particulate matter. Pretest data was recorded and the sample valve was opened. The flow controller was based on a critical orifice that was preset to flow at a rate of 80-cc/min $\pm$ 15%. The sample probe was traversed when necessary. Periodically, sampling train readings (i.e. tank vacuum) were recorded on the field data sheet. Sampling was stopped when one hour had elapsed and/or tank vacuum reached 5 inches as indicated by the vacuum gauge. Then, the sampling train was removed from the stack and a leak check was performed. Samples were logged in and delivered to the laboratory for analysis.

The analytical system consisted of two major sub-systems: a total organic carbon (TOC) analyzer capable of differentiating between total carbon (TC) and inorganic carbon (IC) and a non-methane organics (NMO) analyzer. The NMO analyzer was a gas chromatograph (GC) with back flush capability for NMO analysis and was equipped with an oxidation catalyst, reduction catalyst, and flame ionization detector (FID). The system for the recovery and conditioning of the organics captured in the condensate trap consisted of a heat source, oxidation catalyst, non-dispersive infrared (NDIR) CO₂ analyzer and an intermediate collection vessel (ICV).

NMO collected in the water impinger were analyzed in the TOC analyzer. The TOC analyzer determined both TC and IC. And the TOC was calculated as the difference between TC and IC. The organic content of the sample fraction collected in the sampling tank was measured by injecting a gas sample into the GC to separate the NMO from carbon monoxide (CO), CO₂ and CH₄. The NMO were oxidized to CO₂, reduced to CH₄, and measured by the FID. In this manner, the variable response of the FID (associated with different type of organic compounds) was eliminated. The sampling apparatus and sample analysis services were provided by Almega, which is a SCAQMD-approved laboratory.

Figure 5-3. Sampling Apparatus for TGNMO per SCAQMD Method 25.3
(Figure shows one train – actual method was run in duplicate simultaneously)



6.0 QUALITY ASSURANCE AND QUALITY CONTROL

Almega applies stringent quality assurance and quality control (QA/QC) procedures to ensure the validity of measurements for all test methods. The following section discusses general and project-specific QA/QC measures.

6.1 General QA/QC

Almega's QA/QC procedures follow guidelines from the "Quality Assurance Handbook for Air Pollution Measurement Systems," Volume I through III. And, procedures for pretest preparation and calibration of sampling equipment are followed. Standardized written procedures, calculator programs, and computer spreadsheets are used for test planning, pre-survey, equipment checklist, preliminary calculations, testing, data analysis, and reporting. Pretest equipment preparation and maintenance include organization of the following equipment prior to testing:

- Mobile RM CEM test van: Check fluids, fuel, mechanical conditions, verify operation of CEM instruments, sample lines and sample conditioner prior to the date of the source test.
- Sampling Equipment: Check meter boxes, pitot tubes, manometers and thermocouples to ensure in good working conditions and in proper calibrations. Preclean sampling trains and seal all openings prior to use.

Calibrations are performed in accordance with Chapter III of the SCAQMD Source Test Manual (March 1989). Table 6-1 shows the test equipment calibration schedules. Table 6-2 shows the test equipment maintenance schedules.

6.2 Project-Specific QA/QC

This project includes specific QA/QC activities required to validate the test results. These QA/QC activities are based on the test methods discussed in Section 5 and generally acceptable test procedures. Reference Methods used for source testing are promulgated by the South Coast Air Quality Management District (SCAQMD), the California Air Resource Board (CARB), or the US Environmental Protection Agency (EPA). Any deviations from published Methods are approved in advance by the regulatory agency (i.e. SCAQMD), prior to implementation if possible. Project-specific QA/QC activities and results that may have impacted test results are discussed in Section 3.

TABLE 6-1. TEST EQUIPMENT CALIBRATION SCHEDULE

Equipment	Calibration Period	Standard or Method of Calibration
Thermocouples	6 Months and 2 Months	Mercury Thermometer, three point (ice, boiling water, hot oil)
Dry Gas Meters	6 Months and 2 Months	Critical orifice
Field Barometers	6 Months, Check prior to usage	Mercury Barometer
S-Type Pitot	6 Months Check prior to usage	EPA Method 2, Measure physical configuration. Reshape pitot tips or calibrate if configuration does not meet the limits.
Pressure gauges	6 Months	Five-point calibration against manometer
	1 Month	Three-point check
Temp. Meters	6 Months	Precision Potentiometer
CEM Systems	Bimonthly, or as needed	Specified by Manufacturer

TABLE 6-2. TEST EQUIPMENT MAINTENANCE

Equipment	Check For	Correction	Frequency
CEM Systems	Absence of malfunction, noise, drift, conversion efficiency for NO _x analyzer.	As required by the manufacture, or depending on performance	Bimonthly
Pumps	Absence of leakage, flow, proper vacuum	Replace parts, inspect, clean	300 hours of usage
Flow Devices	Levelling, zeroing, obstruction, deformation	Clean, replace, or re-calibrate	300 hours of usage
Calibration Gases	Expiration date, tank pressure	Re-certify, order new gases	2 months and prior to field testing
Regulators	Malfunction, Gauge precision	Repair or replace	3 months and prior to field testing
Gas Divider	Malfunction, precision	Repair or replace	Monthly and before field testing
Condensers	Leakage, temperature	Repair or replace	Monthly and before field testing
Heated lines	Leakage, temperature, cleanliness	Repair, replace, clean	Monthly and before field testing

APPENDICES

APPENDIX A
GENERAL CALCULATIONS AND FORMULAE

GENERAL CALCULATIONS

Standard conditions: 29.92 in.Hg, 60 °F

Gas Moisture at standard conditions (scf): $V_{WTR} = K2 * V_{COND}$
 $K2 = 0.04707 @ 68 °F, 0.0464 @ 60 °F$

Sample volume at standard conditions (scf):
 $V_{mstd} = K1 * V_{macf} * Y_m * (P_{bar} + dH/13.6) / (T_m + 460)$
 $K1 = 17.64 @ 68 °F, 17.38 @ 60 °F$

Percent of water: $\%H_2O = 100 * V_{mstd} / (V_{mstd} + V_{wtr})$

Dry molecular weight: $M_d = (44 * \%CO_2 + 32 * \%O_2 + 28 * (\%N_2 + \%CO)) / 100$

Wet molecular weight: $M_w = M_d * (1 - \%H_2O/100) + 18 * (\%H_2O/100)$

Stack gas pressure (In. Hg): $P_{stk} = P_{bar} + P_{sta}/13.6$

Average velocity head: $Ave. dP = \{SQRT(dP)\}^2$

Stack gas velocity (fps): $V = 85.49 * C_p * SQRT(dP) * SQRT((T_s + 460) / (P_{stk} * M_w))$

Percent of excess air: $\%EXCA = 100 * (\%O_2 - 0.5\%CO) / (0.264(\%N_2 - (\%O_2 - 0.5\%CO)))$

Stack gas flow (scfm): $Q_{stk} = 60(1 - \%H_2O/100) * V * A * (528 / (T_s + 460)) * P_{stk} / 29.92$

Concentration at 3% O₂: $PPM @ 3\% O_2 = PPM_{measured} * 17.9 / (20.9 - \%O_2)$

Emissions lb/MMBtu:
 $lb/MMBtu = PPM * 10^{-6} * (MW \text{ lb/lb-mole}) / SV \text{ Mole} * F_d * 20.9 / (20.9 - \%O_2)$

Emissions lb/hr:
 $lb/hr = PPM * 10^{-6} * ((MW \text{ lb/lb-mole}) / SV) * F_d * FF * (1050 \text{ Btu/scf}) * 20.9 / (20.9 - \%O_2)$

CALCULATIONS FOR METHOD 100.1:

$$\text{Corrected PPM} = (PPM_{measured} - C_o) * C_{ms} / (C_m - C_o)$$

Where: C_o = Average of initial and final bias zeros
 C_m = Average of initial and final bias calibrations
 C_{ms} = Certified gas value used for the bias calibration.

GENERAL CALCULATIONS -- continued

CALCULATIONS FOR METHOD 100.1, continued

Calibration Error=	$100 * (\text{Certified value} - \text{AnlZR response}) / \text{AnlZR range}$
Percent Bias=	$100 * (\text{Direct AnlZR response} - \text{Bias response}) / \text{AnlZR range}$
System Zero/Span Drifts=	$100 * (\text{Final} - \text{Initial}) / \text{AnlZR range}$
Linearity=	$100 * (\text{AnlZR mid. gas response} - \text{Predictive value}) / \text{range}$

Where the Predictive Value for the mid gas is found by a straight line drawn between hi gas and zero gas calibration points which can be calculated from the straight line equation, $Y = mx + b$ where m is the slope of the line and b is the Y-intercept. The calculation is done by a computer spreadsheet for Method 100.1.

DEFINITIONS

A:	Stack cross area, Square feet
Cp:	Pitot coefficient
@h:	Orifice Pressure, In. H ₂ O
MW:	Molecular weight
Md:	Dry molecular weight of flue gas
Mw:	Wet molecular weight of flue gas
Pbar:	Barometric pressure, In. Hg
Psta:	Static Pressure, In. H ₂ O
Pstk:	Stack pressure, In. Hg
P:	Stack differential pressure, In. H ₂ O
Qstk:	Stack gas flow, scfm
Tm:	Meter temperature, F
Ts:	Stack gas temperature, F
Vcond:	Volume of water condensation, ml
Vm:	Meter volume, acf
Vmstd:	Sample gas at standard conditions, scf
Vwtr:	Water vapor volume, scf
Ym:	Meter correction factor
SV:	Specific molar volume, 379.5 dscf/Lb.mole at 60F, or 385.3 dscf/Lb.mole at 68F
FF:	Fuel Flow Rate (SCF/HR)
Fd:	Dry Fuel Factor, for natural gas $F_d = 8710 \text{ Dscf/MMBTU}$ at 68F.

APPENDIX B
APPROVALS AND CERTIFICATIONS

Appendix B1

SCAQMD and CARB Testing Approvals



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

June 22, 2010

Mr. John W. Phillips
Almega Environmental
5251 McFadden Avenue
Huntington Beach, CA 92649

Subject: LAP Approval Notice
Reference # 93LA0827

Dear Mr. Phillips:

We completed our review of the renewal application you submitted for approval under the South Coast Air Quality Management District's Laboratory Approval Program (LAP). We are pleased to inform you that your firm is approved for the period beginning June 30, 2010 and ending June 30, 2011 for the following methods:

SCAQMD Methods 1-4	SCAQMD Method 7.1
SCAQMD Methods 10.1	SCAQMD Method 100.1
SCAQMD Method 25.1 (Analysis)	SCAQMD Rules 1121/1146.2 Protocols
SCAQMD Method 25.1 (Sampling)	SCAQMD Rule 1420 (Ambient Sampling)
SCAQMD Method 25.3 (Analysis)	SCAQMD Rule 1420 (Source Sampling)
SCAQMD Method 5.1	SCAQMD Rule 462 Test
SCAQMD Method 6.1	

Thank you for participating in the LAP program. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions.

You may direct any questions or information to LAP Coordinator, Ramiro Gonzalez. He may be reached by telephone at (909) 396-2228, by facsimile at (909) 396-2099 or via email: rgonzalez@aqmd.gov

Sincerely,

R. Gonzalez
For: Rudy Eden, Senior Manager
Source Test Engineering

RE:RG:av
cc: Ramiro Gonzalez

B1-1



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

June 9, 2010

John W. Phillips
Almega Environmental
5251 McFadden Avenue
Huntington Beach, CA 92649

Dear Mr. Phillips:

Subject: Laboratory Approval Program Approval
Re: Reference # 93LA0827

I am pleased to inform you that your firm is approved under the South Coast Air Quality Management District's Laboratory Approval Program (AQMD LAP) for the period beginning June 9, 2010 and ending June 30, 2011 for the following methods:

USEPA CTM-030
ASTM D6522-00

Thank you for participating in the AQMD LAP. Your cooperation helps us to achieve the goal of the AQMD LAP: to maintain high standards of quality in the sampling and analysis of source emissions.

You may direct any questions or information to AQMD LAP Coordinator Ramiro Gonzalez. He may be reached by telephone at (909)396-2228, by facsimile at (909)396-2099 or by email at rgonzalez@aqmd.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Rudy Eden'.

Rudy Eden, Sr. Manager
Laboratory Services and
Source Testing & Engineering

RWE:RG:av

cc: Ramiro Gonzalez

B1-2


State of California
Air Resources Board
Approved Independent Contractor

Almega Environmental & Technical Services, Incorporated

This is to certify that the company listed above has been approved
by the Air Resources Board to conduct compliance testing
pursuant to California Code of Regulations, title 17, section 91207,
until December 31, 2010, for those test methods listed below:

ARB Source Test Methods:

1, 2, 3, 4, 5, 8, 11, 13B, 17
100(CO, CO₂, NO_x, O₂, SO₂, THC), 410A, 434



Alberto Ayala, Ph.D., M.S.E.
Chief, Monitoring and Laboratory Division

Appendix B2

Certification of No Conflict-of-Interest

Certification of No Conflict-of-Interest

Almega Environmental & Technical Services
5251 McFadden Avenue
Huntington Beach, CA 92649


I certify that I am responsible for the testing operations of Almega and am authorized to sign this certificate on the Company's behalf.

Almega may conduct tests as an independent tester pursuant to SCAQMD Rule 304(k). I further certify that Almega has no conflict-of-interests, and is not related or owned in any way to the company being tested.

Company being tested: BP West Coast Products, LLC.

Facility ID: 131003

Device ID: C910

Signature: 

Name (printed or typed): Surya Adhikari

Title: Project Manager

Date: January 18, 2011

APPENDIX C
REFERENCE METHOD CONTINUOUS EMISSIONS MONITORING SYSTEM
(RM CEMS)

Appendix C1

RM CEMS – Results and Calculations

Reference Method CEMS Summary

Facility: BP West Coast Product, LLC
 Location: Carson, CA
 Source: NG, 2 FGL
 Device ID: C910

Run Information			Flue Gas Composition										Pollutant 1: CO (MW: 28 lb/lb-mole)	
Run No.	Test Date	Start Time	End Time	Moisture %	Flow Rate:				CO2		CO2		dry	dry ppm
					dry scfm	dry scfh	net scfh	net scfm	wet scfh	dry %	wet %	dry %	ppm	lb/hr
1	12/16/10	10:15	12:36	8.82	29,306	1,758,360	32,141	1,929,440	8.40	7.66	4.71	4.30	480.8	62.38

* Based on Standard Conditions of:

60 deg F and
 29.92 in. Hg

Facility: BP West Coast Product, LLC
 Location: Carson, CA
 Source: NO. 1 FGU
 Device ID: C918

Run No.: 1
 Test Date: 12/16/10
 Run Start Time: 10:15
 Run End Time: 12:26

TEST DATA		Pollutant 1	Diluent 1	Diluent 2
VARIABLE	DESCRIPTION	CO	O2	CO2
A	ANALYTICAL RANGE	1000	25	30
	Unit of Measurement	ppm	% dry	% dry
	CALIBRATION GAS INFORMATION			
B	Zero Gas	0.00	0.00	0.00
C	Low Gas Concentration			
	Low Gas Cylinder S/N:			
C	Mid Gas Concentration	446.70	12.09	4.278
	Mid Gas Cylinder S/N:	CC162408	CC274244	CC274244
D	High Gas Concentration	898.00	21.97	8.792
	High Gas Cylinder S/N:	CC34465	CC277612	CC277612
	Primary Gas Cylinder S/N:			
E	UPSCALE CALIBRATION GAS USED	446.70	12.09	4.28
	L=Low, M=Mid, H=High	M	M	M
	INITIAL CALIBRATION ERROR TEST			
F	Zero Gas Response	0.10	0.00	0.00
G	Low Gas Response			
H	Mid Gas Response	448.20	12.05	4.35
I	High Gas Response	894.72	21.93	8.81
	INITIAL SYSTEM CALIBRATION CHECK			
J	Zero Gas Response	1.00	0.00	0.00
J	Upscale Gas Response	448.00	11.95	4.31
	FINAL SYSTEM CALIBRATION CHECK			
K	Zero Gas Response	0.00	0.00	0.11
L	Upscale Gas Response	437.02	12.15	4.40
	FINAL CALIBRATION ERROR CHECK			
M	Zero Gas Response	1.00	0.00	-0.01
N	Low Gas Response			
N	Mid Gas Response	445.40	12.05	4.29
O	High Gas Response	898.35	22.07	8.88
P	AS MEASURED FLUE GAS CONCENTRATION	476.22	8.38	4.79

CALCULATIONS

AVERAGE SYSTEM CALIBRATION		FORMULA			
Q	Zero Response	0.50	0.00	0.06	$(F-K)/2$
R	Upscale Response	447.51	12.05	4.36	$(J-L)/2$
S	CORRECTED CONC.	480.77	8.40	4.71	$E*(P-Q)/(R-Q)$

QA/QC CALCULATIONS

CALIBRATION GAS SELECTION, % of Range					
	Low Gas				C*100/A
	Mid Gas	44.7	48.4	42.8	C*100/A
	High Gas	89.6	87.9	87.9	D*100/A
CALIBRATION ERROR, % of Range					
	Initial Zero Gas Error	0.01	0.00	0.00	(F-B)*100/A
	Initial Low Gas Error				(G-C)*100/A
	Initial Mid Gas Error	0.15	-0.16	0.72	(H-C)*100/A
	Initial High Gas Error	-0.33	-0.16	0.18	(I-D)*100/A
	Final Zero Gas Error	0.10	0.00	-0.10	(M-B)*100/A
	Final Low Gas Error				(N-C)*100/A
	Final Mid Gas Error	-0.13	-0.16	0.12	(N-C)*100/A
	Final High Gas Error	-0.76	0.40	0.08	(O-D)*100/A
LINEARITY, % of Range					
	Initial	0.31	-0.07	0.63	[(G-F)-{(H-F)*C}/D]*100/A
	Final	0.20	-0.38	0.13	[(N-M)-{(O-M)*C}/D]*100/A
SAMPLING SYSTEM BIAS, % of Range					
	Initial Zero Gas Bias	0.09	0.00	0.00	(F-F)*100/A
	Initial Upscale Gas Bias	-0.02	-0.40	-0.40	(J-G) or (J or H)*100/A
	Final Zero Gas Bias	-0.10	0.00	1.20	(K-M)*100/A
	Final Upscale Gas Bias	-0.84	0.40	1.10	(L-N) or (N or O)*100/A
CALIBRATION DRIFT, % of Range					
	Zero	-0.10	0.00	1.10	(K-I)*100/A
	Upscale	-1.10	0.80	0.90	(L-J)*100/A

AETS CEMS Data -- Run-by-Run Basis

#	RUN 1.0			
	Time	CO	O2	CO2
	AVG	476.22	8.38	4.79
1	10:15:01	385.15	8.18	4.81
2	10:16:01	459.52	8.31	4.76
3	10:17:01	487.75	8.30	4.76
4	10:18:01	422.33	8.28	4.77
5	10:19:01	466.08	8.37	4.71
6	10:20:01	466.70	8.29	4.73
7	10:21:01	420.05	8.23	4.77
8	10:22:01	499.27	8.37	4.71
9	10:23:01	455.47	8.23	4.79
10	10:24:01	453.47	8.31	4.75
11	10:25:01	513.62	8.33	4.78
12	10:26:01	397.68	8.23	4.81
13	10:27:01	463.43	8.35	4.77
14	10:28:01	485.53	8.43	4.74
15	10:29:01	479.12	8.29	4.75
16	10:30:01	485.45	8.32	4.74
17	10:31:01	514.46	8.33	4.74
18	10:32:01	447.40	8.25	4.78
19	10:33:01	503.17	8.37	4.73
20	10:34:01	457.82	8.23	4.81
21	10:35:01	457.67	8.33	4.79
22	10:36:01	480.07	8.27	4.83
23	10:37:01	377.87	8.16	4.89
24	10:38:01	446.47	8.31	4.82
25	10:39:01	459.16	8.33	4.79
26	10:40:01	469.16	8.37	4.77
27	10:41:01	511.36	8.45	4.70
28	10:42:01	487.43	8.34	4.73
29	10:43:01	492.88	8.41	4.74
30	10:44:01	471.20	8.30	4.77
32	10:45:01	473.58	8.33	4.77
33	10:46:01	488.45	8.38	4.76
34	10:47:01	471.13	8.28	4.77
35	10:48:01	440.03	8.29	4.79
36	10:49:01	508.67	8.46	4.74
37	10:50:01	469.82	8.35	4.78
38	10:51:01	461.68	8.36	4.78
39	10:52:01	504.62	8.31	4.77
40	10:53:01	476.55	8.29	4.77
41	10:54:01	508.73	8.36	4.77
42	10:55:01	470.73	8.27	4.83
43	10:56:01	429.47	8.28	4.87
44	10:57:01	469.60	8.33	4.84
45	10:58:01	444.33	8.33	4.84
46	10:59:01	441.93	8.33	4.83
47	11:00:01	473.60	8.36	4.82
48	11:01:01	492.67	8.37	4.79
49	11:02:01	495.47	8.37	4.78
50	11:03:01	474.70	8.38	4.78
51	11:04:01	490.83	8.38	4.80
52	11:05:01	445.47	8.31	4.84
53	11:06:01	473.67	8.39	4.83
54	11:07:01	490.28	8.34	4.84
55	11:08:01	418.27	8.30	4.88
56	11:09:01	498.15	8.42	4.83
57	11:10:01	463.72	8.34	4.86
58	11:11:01	447.75	8.38	4.86
59	11:12:01	499.12	8.41	4.82
60	11:13:01	456.05	8.37	4.83
61	11:14:01	435.35	8.40	4.83

AETS CEMS Data -- Run-by-Run Basis

#	RUN 1.0			
	Time	CO	O2	CO2
	AVG	476.22	8.38	4.79
62	11:27:01	233.13	8.42	4.80
63	11:28:01	449.78	8.43	4.82
64	11:29:01	464.95	8.41	4.83
65	11:30:01	426.27	8.33	4.85
66	11:31:01	464.66	8.46	4.79
67	11:32:01	503.20	8.45	4.78
68	11:33:01	481.52	8.42	4.80
69	11:34:01	487.15	8.49	4.80
70	11:35:01	457.92	8.40	4.83
71	11:36:01	459.97	8.46	4.81
72	11:37:01	486.82	8.46	4.80
73	11:38:01	432.77	8.43	4.82
74	11:39:01	452.37	8.45	4.81
75	11:40:01	484.98	8.41	4.81
76	11:41:01	436.38	8.39	4.84
77	11:42:01	485.82	8.49	4.79
78	11:43:01	484.15	8.47	4.80
79	11:44:01	481.87	8.53	4.80
80	11:45:01	488.57	8.47	4.80
81	11:46:01	453.97	8.46	4.80
82	11:47:01	509.33	8.52	4.77
83	11:48:01	471.00	8.37	4.81
84	11:49:01	479.88	8.44	4.81
85	11:50:01	496.38	8.03	4.56
86	11:51:01	457.60	8.36	4.84
87	11:52:01	512.42	8.49	4.78
88	11:53:01	484.75	8.38	4.84
89	11:54:01	460.17	8.42	4.85
90	11:55:01	497.33	8.43	4.85
91	11:56:01	525.30	8.52	4.80
92	11:57:01	520.22	8.44	4.81
93	11:58:01	446.23	8.39	4.85
94	11:59:01	508.98	8.21	4.86
95	12:00:01	541.10	8.43	4.81
96	12:01:01	487.08	8.46	4.84
97	12:02:01	512.27	8.44	4.85
98	12:03:01	529.60	8.41	4.85
99	12:04:01	446.42	8.00	4.80
100	12:05:01	545.33	8.46	4.80
101	12:06:01	547.95	8.43	4.80
102	12:07:01	505.68	8.39	4.80
103	12:08:01	532.87	8.46	4.80
104	12:09:01	522.93	8.43	4.81
105	12:10:01	489.57	8.45	4.82
106	12:11:01	536.13	8.48	4.80
107	12:12:01	470.78	8.44	4.84
108	12:13:01	509.89	8.45	4.83
109	12:14:01	434.25	8.29	4.74
110	12:15:01	511.20	8.50	4.78
111	12:16:01	553.20	8.47	4.79
112	12:17:01	477.03	8.40	4.81
113	12:18:01	539.18	8.52	4.75
114	12:19:01	544.17	8.48	4.75
115	12:20:01	441.90	8.43	4.81
116	12:21:01	488.18	8.54	4.79
117	12:22:01	525.42	8.53	4.77
118	12:23:01	510.53	8.43	4.78
119	12:24:01	476.23	8.48	4.80
120	12:25:01	474.13	8.39	4.86
121	12:26:01	507.28	8.43	4.84

C₇ - 48

Appendix C2

RM CEMS – Strip Chart

4-1

1

04 14.35N03
03 1.000
01 12.0502
Dec. 16 09:35
INITIAL

14.35N03
1.000
12.0502

14.35N03
1.000
12.0502

14.35N03
1.000
12.0502

14.35N03
1.000
12.0502

14.35N03
1.000
12.0502

14.35N03
1.000
12.0502

14.35N03
1.000
12.0502

14.35N03
1.000
12.0502

14.35N03
1.000
12.0502

03 443.000
01 11.8602
Dec. 16 09:20
INITIAL

443.000
11.8602
12.0502

443.000
11.8602
12.0502

443.000
11.8602
12.0502

443.000
11.8602
12.0502

443.000
11.8602
12.0502

443.000
11.8602
12.0502

443.000
11.8602
12.0502

443.000
11.8602
12.0502

443.000
11.8602
12.0502

5-2

04 0.0000
Dec.16 09:50
INTVL 1

04 14.35N0
03 1.000
01 12.0502
Dec.16 09:53
INTVL 1

04 23.89NOV85
 03 413.000 sec
 01 8.2302
 Dec.16 10:20
 INTVL 1

04 28.25NOV85
 03 765.000 sec
 01 8.2302
 Dec.16 10:05
 INTVL 1

01 8.0002
 Dec.16 09:51
 INTVL 1

G-4


04 24.41NDX
03 452.000
01 0.4202
Dec.16 10:05
INTEL 1

04 25.59NDX
03 488.000
01 0.4302
Dec.16 10:06
INTEL 1

2-1

04 26.41NDX
03 460.000
01 0.2302
Dec.16 10:06
INTEL 1

04 23.85NDX
03 413.000
01 0.2302
Dec.16 10:06
INTEL 1




04 23.88NOV
03 473.000
01 8.5202
Dec.16 11:35
INTVL 1

04 23.71NOV
03 473.000
01 8.3202
Dec.16 11:29
INTVL 1

04 24.41NOV
03 492.900
01 8.4202
Dec.16 11:05
INTVL 1

04 25.59NOV
03 492.900
01 8.4202
Dec.16 11:05
INTVL 1




04 23.47N03EPM
03 507.000 LPM
01 8.52024
Dec.16 12:20
INTVL 1

04 25.62N03EPM
03 551.000 LPM
01 8.33024
Dec.16 12:05
INTVL 1

C2-7

04 25.71N03EPM
03 432.800 LPM
01 8.33024
Dec.16 11:50
INTVL 1


04 23.88N03EPM
03 475.000 LPM
01 8.52024
Dec.16 11:35
INTVL 1



[illegible][illegible][illegible]

42-9

BPCAR-00000233



Appendix C3

RM CEMS – One-Minute DAS Data

Reference Method Reduced DAS Data

Client BP West Coast Product, LLC.
 Location Carson, CA
 Unit 2 TGU
 Date/Time 12/16/2010 9:00
 Job Number 9036

Date	Time	O2%	CO2%	CO ppm	
12/16/2010	9:01:01	0.00	0.00	40.82	
12/16/2010	9:02:01	0.00	0.00	0.40	Pre Internal Calibration
12/16/2010	9:03:01	0.00	0.00	0.30	
12/16/2010	9:04:01	0.00	0.00	0.10	
12/16/2010	9:05:01	0.00	0.00	0.30	
12/16/2010	9:06:01	0.00	0.00	0.10	Zero
12/16/2010	9:07:01	0.00	0.00	0.10	
12/16/2010	9:08:01	0.00	0.00	0.30	
12/16/2010	9:09:01	0.00	0.00	0.48	
12/16/2010	9:10:01	0.00	26.98	0.98	
12/16/2010	9:11:01	17.07	14.11	450.97	
12/16/2010	9:12:01	20.07	7.86	705.19	
12/16/2010	9:13:01	22.15	8.84	894.56	
12/16/2010	9:14:01	21.95	8.81	894.43	
12/16/2010	9:15:01	21.93	8.81	894.72	High
12/16/2010	9:16:01	21.93	8.81	894.15	
12/16/2010	9:17:01	21.93	8.81	893.87	
12/16/2010	9:18:01	21.93	8.82	892.37	
12/16/2010	9:19:01	19.89	7.15	781.40	
12/16/2010	9:20:01	12.47	4.20	515.83	
12/16/2010	9:21:01	11.88	4.23	514.23	
12/16/2010	9:22:01	12.05	4.34	443.37	
12/16/2010	9:23:01	12.05	4.35	448.00	
12/16/2010	9:24:01	12.05	4.35	448.20	Mid
12/16/2010	9:25:01	12.05	4.36	447.92	
12/16/2010	9:25:01	12.05	4.36	447.92	
12/16/2010	9:26:01	12.05	4.36	447.60	
12/16/2010	9:27:01	12.05	4.36	447.40	
12/16/2010	9:28:01	12.05	4.36	447.38	
12/16/2010	9:29:01	12.05	4.36	447.40	
12/16/2010	9:30:01	12.05	4.36	447.72	
12/16/2010	9:31:01	12.05	4.37	418.87	
12/16/2010	9:32:01	12.05	4.37	27.17	
12/16/2010	9:33:01	12.05	4.37	1.00	
12/16/2010	9:34:01	12.05	4.37	1.00	
12/16/2010	9:35:01	12.05	4.37	1.00	
12/16/2010	9:36:01	12.05	4.37	1.00	
12/16/2010	9:37:01	12.11	4.37	1.00	
12/16/2010	9:38:01	12.22	4.37	1.00	
12/16/2010	9:39:01	12.42	4.36	1.00	
12/16/2010	9:40:01	12.67	4.35	1.00	
12/16/2010	9:41:01	13.10	4.33	1.00	
12/16/2010	9:42:01	13.80	3.07	5.08	
12/16/2010	9:43:01	1.07	0.07	5.92	
12/16/2010	9:44:01	0.00	0.06	1.00	System Calibration

Reference Method Reduced DAS Data

Client BP West Coast Product, LLC.
 Location Carson, CA
 Unit 2 TGU
 Date/Time 12/16/2010 9:00
 Job Number 9036

Date	Time	O2%	CO2%	CO ppm	
12/16/2010	9:45:01	0.00	0.00	1.00	Bias Zero
12/16/2010	9:46:01	0.41	0.64	1.00	
12/16/2010	9:47:01	11.18	4.28	0.32	
12/16/2010	9:48:01	11.95	4.31	0.00	Bias Mid O2/CO2
12/16/2010	9:49:01	11.95	4.31	0.00	
12/16/2010	9:50:01	4.31	0.80	0.00	
12/16/2010	9:51:01	0.00	0.02	0.58	
12/16/2010	9:52:01	0.00	0.01	0.70	
12/16/2010	9:53:01	0.00	0.01	0.72	
12/16/2010	9:54:01	0.00	0.01	4.73	
12/16/2010	9:55:01	0.00	0.01	381.20	
12/16/2010	9:56:01	0.00	0.01	476.33	
12/16/2010	9:57:01	0.00	0.01	453.47	
12/16/2010	9:58:01	0.00	0.01	448.00	Bias Mid CO
12/16/2010	9:59:01	0.00	0.01	447.32	
12/16/2010	10:00:01	0.13	0.01	419.73	
12/16/2010	10:01:01	0.00	0.01	87.65	
12/16/2010	10:02:01	0.00	0.01	0.82	
12/16/2010	10:03:01	0.00	0.01	0.50	
12/16/2010	10:04:01	0.00	0.01	0.00	
12/16/2010	10:05:01	0.47	1.76	75.80	
12/16/2010	10:06:01	7.83	4.67	800.65	
12/16/2010	10:07:01	8.31	4.72	730.47	
12/16/2010	10:08:01	8.21	4.80	389.10	
12/16/2010	10:09:01	8.23	4.81	369.73	
12/16/2010	10:10:01	8.24	4.80	433.08	
12/16/2010	10:11:01	8.31	4.75	443.60	
12/16/2010	10:12:01	7.43	4.29	375.65	
12/16/2010	10:13:01	7.74	4.42	415.05	
12/16/2010	10:14:01	8.24	4.75	459.97	
12/16/2010	10:15:01	8.18	4.81	385.15	Port A
12/16/2010	10:16:01	8.31	4.76	459.52	
12/16/2010	10:17:01	8.30	4.76	487.75	
12/16/2010	10:18:01	8.28	4.77	422.33	
12/16/2010	10:19:01	8.37	4.71	466.08	Point-1
12/16/2010	10:20:01	8.29	4.73	466.70	
12/16/2010	10:21:01	8.23	4.77	420.05	
12/16/2010	10:22:01	8.37	4.71	499.27	
12/16/2010	10:23:01	8.23	4.79	455.47	
12/16/2010	10:24:01	8.31	4.75	453.47	Point-2
12/16/2010	10:25:01	8.33	4.78	513.62	
12/16/2010	10:26:01	8.23	4.81	397.68	
12/16/2010	10:27:01	8.35	4.77	463.43	
12/16/2010	10:28:01	8.43	4.74	485.53	
12/16/2010	10:29:01	8.29	4.75	479.12	Point-3

Reference Method Reduced DAS Data

Client BP West Coast Product, LLC.
 Location Carson, CA
 Unit 2 TGU
 Date/Time 12/16/2010 9:00
 Job Number 9036

Date	Time	O2%	CO2%	CO ppm	
12/16/2010	10:30:01	8.32	4.74	485.45	
12/16/2010	10:31:01	8.33	4.74	514.45	
12/16/2010	10:32:01	8.25	4.78	447.40	
12/16/2010	10:33:01	8.37	4.73	503.17	
12/16/2010	10:34:01	8.23	4.81	457.82	Point-4
12/16/2010	10:35:01	8.33	4.79	457.67	
12/16/2010	10:36:01	8.27	4.83	480.07	
12/16/2010	10:37:01	8.18	4.89	377.87	
12/16/2010	10:38:01	8.31	4.82	446.47	
12/16/2010	10:39:01	8.33	4.79	459.18	Point-5
12/16/2010	10:40:01	8.37	4.77	469.18	
12/16/2010	10:41:01	8.45	4.70	511.38	
12/16/2010	10:42:01	8.34	4.73	487.43	
12/16/2010	10:43:01	8.41	4.74	492.88	
12/16/2010	10:44:01	8.30	4.77	471.20	Point-6
12/16/2010	10:45:01	8.33	4.77	473.58	
12/16/2010	10:46:01	8.38	4.76	488.45	
12/16/2010	10:47:01	8.28	4.77	471.13	
12/16/2010	10:48:01	8.29	4.79	440.03	
12/16/2010	10:49:01	8.45	4.74	506.67	Point-7
12/16/2010	10:50:01	8.35	4.78	469.82	
12/16/2010	10:51:01	8.36	4.78	461.68	
12/16/2010	10:52:01	8.31	4.77	504.62	
12/16/2010	10:53:01	8.29	4.77	476.55	
12/16/2010	10:54:01	8.36	4.77	508.73	Point-8
12/16/2010	10:55:01	8.27	4.83	470.73	
12/16/2010	10:56:01	8.28	4.87	429.47	
12/16/2010	10:57:01	8.33	4.84	469.60	
12/16/2010	10:58:01	8.33	4.84	444.33	
12/16/2010	10:59:01	8.33	4.83	441.93	Point-9
12/16/2010	11:00:01	8.36	4.82	473.60	
12/16/2010	11:01:01	8.37	4.79	492.67	
12/16/2010	11:02:01	8.37	4.78	495.47	
12/16/2010	11:03:01	8.39	4.78	474.70	
12/16/2010	11:04:01	8.39	4.80	490.83	Point-10
12/16/2010	11:05:01	8.31	4.84	445.47	
12/16/2010	11:06:01	8.39	4.83	473.67	
12/16/2010	11:07:01	8.34	4.84	490.28	
12/16/2010	11:08:01	8.30	4.88	418.27	
12/16/2010	11:09:01	8.42	4.83	498.15	Point-11
12/16/2010	11:10:01	8.34	4.86	463.72	
12/16/2010	11:11:01	8.36	4.86	447.75	
12/16/2010	11:12:01	8.41	4.82	499.12	
12/16/2010	11:13:01	8.37	4.83	456.05	
12/16/2010	11:14:01	8.40	4.83	435.35	Point-12
12/16/2010	11:15:01	8.43	4.81	491.27	Switch Port

C3-3

Reference Method Reduced DAS Data

Client BP West Coast Product, LLC.
 Location Carson, CA
 Unit 2 TGU
 Date/Time 12/16/2010 9:00
 Job Number 9036

Date	Time	O2%	CO2%	CO ppm	
12/16/2010	11:16:01	15.43	1.30	337.62	Switch Port
12/16/2010	11:17:01	21.16	0.79	6.67	Switch Port
12/16/2010	11:18:01	9.79	4.70	331.70	Switch Port
12/16/2010	11:19:01	8.43	4.77	463.88	Switch Port
12/16/2010	11:20:01	8.43	4.78	485.48	Switch Port
12/16/2010	11:21:01	8.35	4.88	450.53	Switch Port
12/16/2010	11:22:01	8.45	4.84	400.75	Switch Port
12/16/2010	11:23:01	8.43	4.83	385.67	Switch Port
12/16/2010	11:24:01	8.36	4.86	254.12	Switch Port
12/16/2010	11:25:01	8.45	4.79	288.55	Switch Port
12/16/2010	11:26:01	8.44	4.78	239.35	Switch Port
12/16/2010	11:27:01	8.42	4.80	233.13	Port B
12/16/2010	11:28:01	8.43	4.82	449.78	
12/16/2010	11:29:01	8.41	4.83	464.95	
12/16/2010	11:30:01	8.33	4.85	426.27	
12/16/2010	11:31:01	8.46	4.79	464.68	Point-1
12/16/2010	11:32:01	8.45	4.78	503.20	
12/16/2010	11:33:01	8.42	4.80	481.52	
12/16/2010	11:34:01	8.49	4.80	497.15	
12/16/2010	11:35:01	8.40	4.83	457.92	
12/16/2010	11:36:01	8.46	4.81	459.97	Point-2
12/16/2010	11:37:01	8.46	4.80	486.82	
12/16/2010	11:38:01	8.43	4.82	432.77	
12/16/2010	11:39:01	8.45	4.81	452.37	
12/16/2010	11:40:01	8.41	4.81	484.98	
12/16/2010	11:41:01	8.39	4.84	436.38	Point-3
12/16/2010	11:42:01	8.49	4.79	485.82	
12/16/2010	11:43:01	8.47	4.80	464.15	
12/16/2010	11:44:01	8.53	4.80	481.87	
12/16/2010	11:45:01	8.47	4.80	488.57	
12/16/2010	11:46:01	8.46	4.80	453.97	Point-4
12/16/2010	11:47:01	8.52	4.77	509.33	
12/16/2010	11:48:01	8.37	4.81	471.00	
12/16/2010	11:49:01	8.44	4.81	479.88	
12/16/2010	11:50:01	8.03	4.56	496.38	
12/16/2010	11:51:01	8.36	4.84	457.60	Point-5
12/16/2010	11:52:01	8.49	4.78	512.42	
12/16/2010	11:53:01	8.38	4.84	484.75	
12/16/2010	11:54:01	8.42	4.85	460.17	
12/16/2010	11:55:01	8.43	4.85	497.33	
12/16/2010	11:56:01	8.52	4.80	525.30	Point-6
12/16/2010	11:57:01	8.44	4.81	520.22	
12/16/2010	11:58:01	8.39	4.85	446.23	
12/16/2010	11:59:01	8.21	4.66	509.98	
12/16/2010	12:00:01	8.43	4.81	541.10	
12/16/2010	12:01:01	8.46	4.84	487.08	Point-7

Reference Method Reduced DAS Data

Client BP West Coast Product, LLC.
Location Carson, CA
Unit 2 TGU
Date/Time 12/16/2010 9:00
Job Number 9036

Date	Time	O2%	CO2%	CO ppm	
12/16/2010	12:02:01	8.44	4.85	512.27	
12/16/2010	12:03:01	8.41	4.85	529.60	
12/16/2010	12:04:01	8.00	4.60	446.42	
12/16/2010	12:05:01	8.45	4.80	545.33	
12/16/2010	12:06:01	8.43	4.80	547.95	Point-8
12/16/2010	12:07:01	8.39	4.80	505.68	
12/16/2010	12:08:01	8.46	4.80	532.87	
12/16/2010	12:09:01	8.43	4.81	522.83	
12/16/2010	12:10:01	8.45	4.82	469.57	
12/16/2010	12:11:01	8.49	4.80	536.13	Point-9
12/16/2010	12:12:01	8.44	4.84	470.78	
12/16/2010	12:13:01	8.45	4.83	509.83	
12/16/2010	12:14:01	8.29	4.74	434.25	
12/16/2010	12:15:01	8.50	4.78	511.20	
12/16/2010	12:16:01	8.47	4.79	553.20	Point-10
12/16/2010	12:17:01	8.40	4.81	477.03	
12/16/2010	12:18:01	8.52	4.75	539.18	
12/16/2010	12:19:01	8.48	4.75	544.17	
12/16/2010	12:20:01	8.43	4.81	441.90	
12/16/2010	12:21:01	8.54	4.79	488.18	Point-11
12/16/2010	12:22:01	8.53	4.77	525.42	
12/16/2010	12:23:01	8.43	4.78	510.53	
12/16/2010	12:24:01	8.48	4.80	476.23	
12/16/2010	12:25:01	8.39	4.86	474.13	
12/16/2010	12:26:01	8.43	4.84	507.28	Point-12
12/16/2010	12:27:01	8.26	4.53	511.25	
12/16/2010	12:28:01	12.06	4.37	178.22	
12/16/2010	12:29:01	12.15	4.39	0.22	
12/16/2010	12:30:01	12.15	4.40	0.00	
12/16/2010	12:31:01	11.54	4.18	0.00	
12/16/2010	12:32:01	11.34	4.11	0.00	System Calibration
12/16/2010	12:33:01	12.15	4.40	0.00	
12/16/2010	12:34:01	12.15	4.40	0.00	Bias Mid O2/CO2
12/16/2010	12:35:01	11.90	3.80	0.00	Bias Zero CO
12/16/2010	12:36:01	1.19	0.15	0.00	
12/16/2010	12:37:01	0.00	0.11	0.00	
12/16/2010	12:38:01	0.00	0.11	0.00	
12/16/2010	12:39:01	0.00	0.11	0.00	
12/16/2010	12:40:01	0.00	0.11	0.00	Bias Zero O2/CO2
12/16/2010	12:41:01	0.00	0.10	0.83	
12/16/2010	12:42:01	0.00	0.10	164.23	
12/16/2010	12:43:01	0.00	0.10	374.18	
12/16/2010	12:44:01	0.00	0.10	431.78	
12/16/2010	12:45:01	0.00	0.10	437.02	Bias Mid CO
12/16/2010	12:46:01	0.00	0.10	436.50	
12/16/2010	12:47:01	0.00	0.10	202.82	

23-5

Reference Method Reduced DAS Data

Client BP West Coast Product, LLC.
 Location Carson, CA
 Unit 2 TGU
 Date/Time 12/16/2010 9:00
 Job Number 9036

Date	Time	O2%	CO2%	CO ppm	
12/16/2010	12:48:01	0.00	0.10	0.25	Post Internal Calibration
12/16/2010	12:49:01	0.00	0.10	0.00	
12/16/2010	12:50:01	0.00	0.07	0.08	
12/16/2010	12:51:01	0.00	-0.01	1.00	
12/16/2010	12:52:01	0.00	-0.01	1.00	Zero
12/16/2010	12:53:01	7.87	4.74	91.89	
12/16/2010	12:54:01	22.10	8.26	664.85	
12/16/2010	12:55:01	20.75	8.04	669.68	
12/16/2010	12:56:01	21.01	8.28	853.87	
12/16/2010	12:57:01	22.12	8.79	889.54	
12/16/2010	12:58:01	22.12	8.79	890.72	
12/16/2010	12:59:01	22.07	8.80	890.35	High
12/16/2010	13:00:01	18.26	6.52	745.89	
12/16/2010	13:01:01	12.01	4.24	443.62	
12/16/2010	13:02:01	12.05	4.28	445.72	
12/16/2010	13:03:01	11.85	4.22	438.07	
12/16/2010	13:04:01	11.05	3.93	408.47	
12/16/2010	13:05:01	12.05	4.29	445.60	
12/16/2010	13:06:01	12.05	4.29	445.40	Mid
12/16/2010	13:07:01	7.50	1.97	-631.08	
12/16/2010	13:08:01	6.19	4.40	-3209.60	

APPENDIX D

SCAQMD METHOD 5.1 – PARTICULATE MATTER

Appendix D1

PARTICULATE MATTER – Results and Calculations

PARTICULATE TEST SUMMARY

No. 2 TGU

Run Number	1
Run Date	12/16/10
Run Start Time	10:15
Run Stop Time	12:26
Test Train Parameters	
Volume of Dry Gas Sample, SCF*	88.696
Flue Gas Parameters	
CO2, Percent By Volume, Dry	4.71
O2, Percent By Volume, Dry	8.40
Temperature, Degrees F	1268
Moisture, %	8.82
Air Flow Rate, Wet ACFM	106,918
Air Flow Rate, Dry SCFM*	29,306
Total Particulate	
Total catch, mg	69.77
Concentration, Gr/DSCF	0.0121
Concentration @ 12% CO2	0.0309
Emission Rate, lb/hr	3.049

* 60 Degrees F and 29.92 Inches of Mercury

Concentration and Mass Emission Tables

SCAQMD RULE 404(a)

	Flow Rate (dscfm)	Concentration Measured (gr/dscf)	Concentration Allowable (gr/dscf)
Table	28,250	XX	0.0537
Measured	29,306	0.0121	0.0530
Table	31,780	XX	0.0515

Concentration at 12% CO2

SCAQMD RULE 409

$$\begin{aligned}\text{Concentration at 12\% CO}_2 &= \text{Concentration (Std)} \times 12 / \text{CO}_2 \text{ Measured} \\ &= 0.0309 \text{ gr/dscf}\end{aligned}$$

D102

ISOKINETIC SAMPLING TRAIN RESULTS - METHOD: SCAQMD M5.2

Client Name	BP West Coast Products, LLC.	Operator		DJ
Plant Name	BP West Coast Products, LLC.	Project #		9036
Sampling Location	NO. 2 TGU	Standard Temperature, °F		60

USE IN AVERAGE OF RUN SET? 1 or 0 =>		1			SET AVERAGE
Run Number		1			
Run Date		12/16/10			
Run Start Time	hh:mm	10:15			
Run Stop Time	hh:mm	12:26			
Meter Calibration Factor	Y	0.9838			
Pitot Tube Coefficient	C _p	0.84			
Actual Nozzle Diameter	in	0.520			
Sample Volume	ft ³	94.040			94.040
Total Sampling Time	min	120			120
Average Meter Temperature	°F	85.7			85.7
Average Stack Temperature	°F	1268.2			1268.2
Barometric Pressure	in Hg	29.98			30.0
Stack/Duct Static Pressure	in H ₂ O	-1.20			-1.20
Absolute Stack/Duct Pressure	in Hg	29.9			29.9
Average Delta H	in H ₂ O	1.82			1.82
Absolute Meter Pressure	in Hg	30.1			30.1
Avg Differential Pressure (Delta P)	in H ₂ O	0.093			0.093
Total Water Volume Collected	mL	185.1			185.1
Volume of Water vapor @ STP	SCF	8.581			8.581
Volume Metered @ STP	DSCF	88.696			88.696
Calculated Stack Moisture	% H ₂ O	8.82			8.8
Saturated Stack Moisture	% H ₂ O	100.0			100.0
Reported Stack Moisture Content	% H ₂ O	8.82			8.82
Carbon Dioxide Percentage	% CO ₂	4.71			4.7
Oxygen Percentage	% O ₂	8.40			8.40
Nitrogen Percentage	% N ₂	86.9			86.9
Dry Mole Fraction	decimal	0.912			0.912
Dry Gas Molecular Weight	lb/lb-mole	29.09			29.09
Wet Stack Gas Molecular Weight	lb/lb-mole	28.11			28.11
Flue Gas Density	lb/ft ³	0.0730			0.0730
Calculated Fuel Factor	F _o	2.65			2.65
Percent Excess Air	% EA	57.8			57.8
Stack Cross-Sectional Area	in ²	8171.3			8171.3
Stack Cross-Sectional Area	ft ²	56.75			56.75
Percent of Isokinetic Rate	% ISO	97.1			97.1

Air Flow Rate Results

Average Stack Gas Velocity	ft/sec	31.40			31.40
Actual Stack Flow/Minute	ACFM	106,918			106,918
Dry Standard Stack Flow/Minute	DSCFM	29,306			29,306

ISOKINETIC SAMPLING TRAIN DATASHEET - METHOD

SCAQMD M5.2

Client Name	BP West Coast Products, LLC	Run #	1		
Plant Name	BP West Coast Products, LLC	Project #	9038	Run Start	10:15
Plant City, State	Carson, CA	Personnel	CJ	Run End	12:26
Test Location	NO. 2 TGU	Tester Signature	Signature on File		
Date of Test	12/16/10	Checked By	TC		

Isokinetic Factor Setup		Pressures		Sampling Equipment		Filter ID & Tares		Actuals
ΔH @ 0.75 SCFM	1.728	Pbar	29.98	Meter Console #	AL-2			CO ₂
Meter Calibration Factor	0.9838	Pstatic	-1.20	Ideal Nozzle Diameter	0.535			4.71
Pitot Tube Coefficient	0.840	Abs P	29.9	Nozzle #	0.520			O ₂
Estimated Dry Gas Meter Temp	90	Tstd, °F	60	Actual Nozzle Diameter	0.520			8.40
Estimated Stack Temp or M2 Avg.	1250	Pstd	29.92	Probe Lgth/ID #	4			CO
Estimated Delta P or M2 Avg.	0.085	Estimates		Liner Material		XAD ID & Tares		
Estimated Moisture Content	12.3	CO ₂	5.0	Filter Box #	NA			N ₂
Estimated Dry Molecular Weight	29.10	O ₂	7.5	Cold Box ID #	NA			86.9
Estimated Velocity, ft/sec	30.1	CO		Umbilical ID #	NA			H ₂ O
K Factor (delta H/delta P)	19.85	N ₂	87.5	TC ID #s	4			185.1

Equipment & Leak Check Data, OK? Y or N					Leak Checks	1	2	3	4	5	6	Status
Tambient			PRE	POST	DGM Initial	845.444						845.444
Thermocouples			Y	Y	Vacuum	15						15
Pitots			Y	Y	Leak Rate	0.001						OK
Tedlar Bag			N	N	DGM final	845.521						845.521

[illegible]

Average Values	120.0	94.040	0.093	1.869	1.817		85.7	1268.2
----------------	-------	--------	-------	-------	-------	--	------	--------

D1-4

	Water 1	Water 2	Empty	SG
Initial	573.0	580.3	567.5	792.8
Final	683.3	623.0	577.1	815.3
H2O gain	110.3	42.7	9.6	22.5
Total H2O	185.1			

Cumul. Percent ISO %	Point Percent ISO %	Square Root DP (in H ₂ O) ^{1/2}	Local Stack Velocity ft/sec	Cumulative Meter Volume scf	Point Meter Volume scf
100.4	100.4	0.316	32.8	3.896	3.896
100.2	100.1	0.332	34.4	7.967	4.071
100.2	100.3	0.300	31.1	11.656	3.690
100.3	100.5	0.283	29.4	15.137	3.482
100.3	100.4	0.283	29.3	18.618	3.482
100.4	101.1	0.200	20.7	21.093	2.481
100.3	100.1	0.332	34.4	25.170	4.074
100.3	100.1	0.346	35.9	29.428	4.252
100.3	100.2	0.332	34.4	33.511	4.079
100.3	100.2	0.332	34.4	37.593	4.079
100.3	100.1	0.316	32.8	41.485	3.890
100.3	100.3	0.245	25.4	44.492	3.019
100.4	102.1	0.332	34.4	48.650	4.152
100.4	100.4	0.332	34.4	52.738	4.084
100.4	100.1	0.316	32.8	56.623	3.883
100.4	100.3	0.316	32.8	60.519	3.894
100.4	100.3	0.316	32.8	64.411	3.891
100.4	100.3	0.332	34.4	68.499	4.083
100.4	100.2	0.332	34.4	72.580	4.077
100.4	100.4	0.316	32.8	76.479	3.897
100.4	100.2	0.283	29.3	79.953	3.481
100.4	100.3	0.283	29.3	83.431	3.484
100.4	100.1	0.300	31.1	87.118	3.688
100.4	100.6	0.245	25.4	90.135	3.026
100.4	100.6	Final Values		90.135	3.026
		0.306	31.6		

D1-5

EXAMPLE CALCULATIONS, RUN 1

ABSOLUTE PRESSURE, INCHES OF MERCURY

$$\begin{aligned} P_s &= P_{bar} + P_g/13.6 \\ &= 29.98 + -1.20/13.6 \\ &= 29.89 \end{aligned}$$

VOLUME OF WATER VAPOR, STANDARD CUBIC FEET

$$\begin{aligned} V_{wstd} &= 0.002667 * [(T_{std} + 460) / P_{std}] * V_{ic} \\ &= 0.002667 * [(60 + 460) / 29.92 * 185.1] \\ &= 8.581 \end{aligned}$$

SAMPLED VOLUME OF SOURCE GAS, DRY STANDARD CUBIC FEET

$$\begin{aligned} V_{mstd} &= [(T_{std} + 460)/P_{std}] * Y * V_m * (P_{bar} + \Delta H/13.6) / (460 + t_m) \\ &= [(60 + 460)/29.92] * 0.9838 * 94.040 * (29.98 + 1.817/13.6) / (460 + 86) \\ &= 88.696 \end{aligned}$$

MOISTURE CONTENT, PERCENT BY VOLUME

$$\begin{aligned} \%H_2O &= V_{wstd} / (V_{wstd} + V_{mstd}) \\ &= 8.581 / (8.581 + 88.696) \\ &= 8.82 \end{aligned}$$

DRY MOLE FRACTION, LB-MOLE/LB-MOLE

$$\begin{aligned} M_{fd} &= 1 - \%H_2O/100 \\ &= 1 - 8.82/100 \\ &= 0.912 \end{aligned}$$

DRY MOLECULAR WEIGHT, LB/LB-MOLE

$$\begin{aligned} M_d &= 44 * (\%CO_2/100) + 32 * (\%O_2/100) + 28 * \{[100 - (\%CO_2 + \%O_2)]/100\} \\ &= 44 * (4.7/100) + 32 * (8.4/100) + 28 * \{[100 - (4.7 + 8.4)]/100\} \\ &= 29.09 \end{aligned}$$

WET MOLECULAR WEIGHT, LB/LB-MOLE

$$\begin{aligned} M_s &= M_d * M_{fd} + 18.0 * \%H_2O/100 \\ &= 29.09 * 0.912 + 18.0 * 8.82/100 \\ &= 28.11 \end{aligned}$$

FUEL FACTOR

$$\begin{aligned} F_o &= (20.9 - \%O_2) / \%CO_2 \\ &= (20.9 - 8.4) / 4.7 \\ &= 2.654 \end{aligned}$$

ISOKINETIC SAMPLING RATE, PERCENT

$$\begin{aligned} \%I &= P_{std}/(T_{std} + 460) * (100/60) * V_{mstd} * (t_s + 460) / [P_s * v_s * M_{fd} * \Theta * (PI * Dia^2 * Dia/576)] \\ &= 29.92/(60 + 460) * (100/60) * 88.696 * (1268 + 460) / [29.89 * 31.40 * 0.912 * 120.00 * (PI * 0.520^2 * 0.520/576)] \\ &= 97.1 \end{aligned}$$

VELOCITY, FEET PER SECOND

$$\begin{aligned} v_s &= 85.49 * C_p * \text{SQRT}[\Delta p * (460 + t_s) / P_s / M_s] \\ &= 85.49 * 0.84 * \text{SQRT}[0.0930 * (460 + 1268) / 29.89 / 28.11] \\ &= 31.40 \end{aligned}$$

VOLUMETRIC FLOW RATE, ACTUAL CUBIC FEET PER MINUTE

$$\begin{aligned} Q_{aw} &= (60/144) * v_s * A \\ &= (60/144) * 31.40 * 8171 \\ &= 106918 \end{aligned}$$

VOLUMETRIC FLOW RATE, DRY STANDARD CUBIC FEET PER MINUTE

$$\begin{aligned} Q_{sd} &= (60/144) * M_{fd} * v_s * A * (T_{std} + 460) / (t_s + 460) * (P_s / P_{std}) \\ &= (60/144) * 0.912 * 31.40 * 8171 * (60 + 460) / (1268 + 460) * (29.89/29.92) \\ &= 29306 \end{aligned}$$

EXAMPLE CALCULATIONS, RUN 1

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT

$$\begin{aligned}\text{gr/DSCF} &= (\text{Catch/Conversion}) * 7,000 / 453.592 / \text{Vmstd} \\ &= (69.77/1000) * 7,000 / 453.592 / 88.696 \\ &= 0.01214\end{aligned}$$

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT @ 12% CO2

$$\begin{aligned}\text{Gr@12\%CO2} &= \text{gr/DSCF} * 12 / \% \text{CO2} \\ &= 0.01214 * 12 / 4.7 \\ &= 0.03093\end{aligned}$$

TOTAL PARTICULATE CONCENTRATION, GRAINS PER DRY STANDARD CUBIC FOOT @ 7% O2

$$\begin{aligned}\text{Gr@7\%O2} &= \text{gr/DSCF} * (20.9-7) / (20.9-\% \text{O2}) \\ &= 0.01214 * (20.9-7) / (20.9-8.40) \\ &= 0.01350\end{aligned}$$

TOTAL PARTICULATE EMISSION RATE, POUNDS PER HOUR

$$\begin{aligned}\text{lb/hr} &= 60 * (\text{Catch/Conversion}) * \text{Qsd} / 453.592 / \text{Vmstd} \\ &= 60 * (69.77/1000) * 29306 / 453.592 / 88.696 \\ &= 3.049\end{aligned}$$

Appendix D2

PARTICULATE MATTER – Field Data

SAMPLING AND VELOCITY TRAVERSE POINT DETERMINATION SCAQMD METHOD 1.1

CLIENT: BP West Coast Products, LLC
CITY, STATE: Carson, CA
SAMPLING LOCATION: No. 2 TGU
TYPE OF TESTING: Compliance

NO. OF PORTS AVAILABLE:
NO. OF PORTS TO BE USED:
PORT INSIDE DIAMETER: inches

DISTANCE FROM FAR WALL TO OUTSIDE OF PORT: 111.00 inches
NIPPLE LENGTH AND/OR WALL THICKNESS: 9.00 inches
DEPTH OF STACK OR DUCT, D: 102.00 inches
STACK OR DUCT WIDTH (IF RECTANGULAR), W: 84.8 inches


EQUIVALENT DIAMETER
 $De = 2 * (DEPTH) * (WIDTH) / (DEPTH + WIDTH) =$ 102.00 inches

STACK/DUCT AREA = 56.75 sq.feet 8171.3 sq.inches

DISTANCE FROM PORT TO FLOW DISTURBANCES	UPSTREAM B	DOWNSTREAM A
# OF INCHES	273.00	57.00
# OF DIAMETERS	2.68	5.79

MINIMUM NUMBER OF TRAVERSE POINTS: 34

POINT NO.	% OF DUCT DEPTH	DISTANCE FROM INSIDE WALL (in.)	DISTANCE FROM OUTSIDE OF PORT (in.)
1	2.1	2.14	11 1/8
2	6.7	6.83	15 7/8
3	11.8	12.04	21
4	17.7	18.05	27
5	25.0	25.50	34 1/2
6	35.6	36.31	45 1/4
7	64.4	65.69	74 3/4
8	75.0	76.50	85 1/2
9	82.3	83.95	93
10	88.2	89.96	99
11	93.3	95.17	104 1/8
12	97.9	99.86	108 7/8



DRAWING NOT TO SCALE

ISOKINETIC DATA FORM, TE COOLER & CYCLONIC FLOW

M 5.2

Run #	1	Pilot ID	4	Impinger #	Initial	Final	Net	Pilot Leak Check
Date	12-16-10	Pilot Coeff.	.84	1	575.0	583.3	110.3	Initial ☒ Final ☒
Client	BP	Meter Box #	AL-2	2	580.5	623.0	412.7	Final ☒ ☒
Unit	No. 2 T64	Meter @ Oh	1.727	3	567.5	574.1	3.6	
Operator	Dorian	Meter Y	.9858	4	792.8	815.3	22.5	
Stack Dia	102"	TC #	4	5				
Amb Press	29.98	Start Time	1015	Nezzle Dia	H2O Gain = 185.1			Meter Box Leak Check
Static Press	-1.2	Stop Time	1226					Rate ☒ HG ☒
								Initial ☒ Final ☒

Traverse Points	Time (Minute)	Della P ("H2O)	Stack Temp (F)	Set della H ("H2O)	Meter Volume (scf)	Mtr Inlet Temp (F)	Mtr Outlet Temp (F)	Oven Temp (F)	Probe Temp (F)	Impinger Temp (F)	Pump Vac ("HG)	TE Cooler Temp (F)	Cyclonic Flow ("H2O)
0					799.461							32	
E 12	5	.10	1268	1.89	805.441	75	73	241	248	58	5	33	0
11	10	.11	1270	2.08	807.602	76	73	245	250	56	5.5	33	1
10	15	.09	1271	1.70	811.388	77	75	248	251	52	4	32	0
9	20	.08	1273	1.51	814.962	77	75	248	249	53	3.5	33	4
8	25	.08	1270	1.52	818.546	78	77	245	250	53	3.5	33	2
7	30	.04	1269	1.76	821.104	78	77	244	251	52	2	33	0
6	35	.11	1268	2.10	825.311	81	79	241	247	53	5.5	34	1
5	40	.12	1270	2.30	827.724	81	82	245	247	53	6	33	1
4	45	.11	1268	2.11	833.963	85	82	248	248	54	5.5	32	0
3	50	.11	1266	2.12	838.266	85	83	250	250	54	5.5	33	0
2	55	.12	1265	1.94	842.273	88	85	249	252	52	5	32	1
1	60	.06	1264	1.17	845.444	89	87	247	251	53	3	32	1
0					845.521								
S 12	5	.11	1271	2.13	849.798	89	88	250	251	54	5.5	33	2
11	10	.11	1270	2.13	854.081	89	88	245	250	55	5.5	32	1
10	15	.10	1270	1.94	858.163	90	89	248	251	53	5	32	3
9	20	.10	1267	1.95	862.160	90	90	245	253	53	5	32	1
8	25	.10	1268	1.94	866.354	91	89	248	250	53	5	33	0
7	30	.11	1268	2.14	870.656	92	90	250	249	55	5.5	33	1
6	35	.11	1269	2.15	874.963	93	92	247	250	54	5.5	33	3
5	40	.10	1268	1.95	879.082	93	92	246	251	54	5	33	0
4	45	.08	1267	1.57	882.774	95	93	246	249	52	3.5	34	1
3	50	.08	1265	1.57	886.473	96	93	248	248	52	3.5	32	0
2	55	.09	1266	1.77	890.383	96	92	251	249	53	4	33	0
1	60	.06	1265	1.17	893.578	93	89	250	251	52	3	32	1

Isokinetic Factor Setup

Estimated Dry Gas Meter Temp. 90

Estimated Stack Temp. 1250

Estimated Della P. .085

Estimated Moisture Content 16.3

Estimated O2 7.5

Estimated CO2 5

Equipment Evaluation, OK? Y or N

Ambient Temp.

TC Check ☒

Pilot Check ☒

Tedlar Bag ☒

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial	845.444					
Vacuum	-15"					
Leak Rate	.02%					
DGM Final	845.521					

ISOKINETIC DATA FORM, TE COOLER & CYCLONIC FLOW

Run #	Pilot ID	Impinger #	Initial	Final	Net	Pilot Leak Check	
Date: 12/16/10	Pilot Coeff.	1	571.2			Initial:	
Client: BP	Meter Box #	2	578.4			Final:	
Unit: T64 #2	Meter @ Ch	3	567.5				
Operator: JTS/BH	Meter Y	4	792.8				
Stack Dia: 102"	TC #	5				Meter Box Leak Check	
Amb. Press: 29.98	Start Time: 0927	Nozzle Dia	H2O Gain =			Initial:	Rate "HG
Static Press: -1.2	Stop Time: 1:52	Filter:	9462			Final:	12"

[illegible]

Isokinetic Factor Setup	
Estimated Dry Gas Meter Temp	
Estimated Stack Temp	
Estimated Delta P	
Estimated Moisture Content	
Estimated CO ₂	
Estimated CO	

Equipment Evaluation, OK? Y or N

Ambient Temp.:	
TC Check:	
Flap Check:	
Teddy Bag:	

Dry Gas Meter Leak Checks

	1	2	3	4	5	6
DGM Initial						
Vacuum						
Leak Rate						
DGM Final						

Appendix D3

PARTICULATE MATTER – Laboratory Data

Calculation Data Sheet for Particulate Matter SCAQMD Method 5.2

LAB ANALYSIS

A.	Filter Catch	32.25	mg
B.	(1) Filter Acid	18.42	mg
	(2) Filter total Sulfate	31.61	mg
C.	Probe Catch	26.56	mg
D.	(1) Probe Acid	6.36	mg
	(2) Probe total Sulfate	13.75	mg
E.	Impinger Catch	105.71	mg
F.	(1) Impinger Acid	70	mg
	(2) Impinger total Sulfate	75.68	mg
G.	Organic Extract	0.03	mg
H.	H ₂ SO ₄ .2H ₂ O from SO _x Train Thimble	NA	mg
I.	Particulate Train corrected Gas Volume Metered	88.696	dscf
J.	SO _x Train corrected Gas Volume Metered		dscf
K.	Prorated H ₂ SO ₄ .2H ₂ O Mass (H*I)/J		mg

FILTER PARTICULATE TEMPERATURE GREATER THAN 200°F

L.	Total particulate (A-B*+C-D*+E-F*+G+K)	69.77	mg
M.	Solid particulate (L-G-K)	69.74	mg
N.	Total Particulate (Corrected for Ammonium Sulfate) (A-B*+C-D*+E-F(1)+G+K-{F(2)-(1)}.132/134)	64.17	mg
O.	Solid Particulate (Corrected for Ammonium Sulfate) (N-G-J)	64.14	mg

LABORATORY REPORT

SCAQMD m5.2

Lab Report No.: A 221
 Client Name: BP
 Unit Tested: TGU #2

Project No.: c 9036
 Date Sampled: 16-Dec-11
 Analyst: DW

Client ID	Run # 1	Field Blank
Container No 1 (Filter)	1	1
Client ID No.:	R1 - Filter	FB - Filter
Lab ID No.:	A 221 - R1 - C1	A 221 - FB - C1
Filter ID #	9465	9462
Filter wt., total, mg (m_T)	32.25	0.70
Filter Acid, mg	18.42	NA
Filter SO ₄ , mg	31.61	NA
Filter wt. net, mg (m_{FN})	32.25	0.70
Container No 2 (Probe) - Water	2	2
Client ID No.:	R1 - FH	FB - FH
Lab ID No.:	A 221 - R1 - C2	A 221 - FB - C2
Volume, ml (V_{WA})	230	175
FH Catch, total, mg (m_{FH})	26.70	7.50
DI Water Blank, mg (W_W)	0.14	0.11
FH Acid, mg (m_{FHAS})	6.36	NA
FH SO ₄ , mg (m_{FHAS})	13.75	NA
FH Catch, net, mg (m_{FHN}) ($m_{FHN} = m_{FH} - W_W$)	26.56	7.39
Container No 3 (Impinger) - Water org	3	3
Client ID No.:	R1 - BH	FB - BH
Lab ID No.:	A 221 - R1 - C3 org	A 221 - FB - C3 org
Volume, ml (V_{WA})	100	100
BH Organic Catch, total, mg (m_{BH})	0.05	0.20
Methylene Chloride Blank, mg (W_M)	0.02	0.02
FH Catch, net, mg (m_{BHN}) ($m_{BHN} = m_{BH} - W_M$)	0.03	0.18
Container No 3 (Impinger) - Water sr	3	3
Client ID No.:	R1 - BH	FB - BH
Lab ID No.:	A 221 - R1 - C3 sr	A 221 - FB - C3 sr
Volume, L (V_{WA})	650	425
BH Solid Residue Catch, total, mg (m_{BH})	106.10	23.20
DI Water Blank, mg (W_W)	0.39	0.26
BH Acid, mg (m_{BHAS})	70.00	NA
BH SO ₄ , mg (m_{BHAS})	75.68	NA
BH Catch, net, mg (m_{BHN}) ($m_{BHN} = m_{BH} - W_W$)	105.71	22.94
Total Particulate mass, net, mg (m_T)	165.10	31.60
Blank correction weight of PM, mg (m_{TB})	164.55	31.22
$m_T = m_{FN} + m_{FHN} + m_{BHN}$		

Checked by:

GA

SULFURIC ACID & SULFUR OXIDES - LABORATORY DATA SHEET

Client: BP Project #: c 9036 Checked by: GA
 Site Location: Unit Tested: TGU #2
 Analyst: GA Date Analyzed: 7-Jan-11

Sample No.	Sample		Factor, F = V/A	Sample Titration			Acid, as H ₂ SO ₄ *2H ₂ O mg	Sulfate, as H ₂ SO ₄ *2H ₂ O mg
	Total, V (mL)	Aliquot, A (mL)		T1 (mL)	T2 (mL)	Avg. V (mL)		
ANALYSIS FOR ACID								
A 221 - R1 - C1	50	10	5	0.55	0.55	0.55	18.42	
A 221 - R1 - C2	50	10	5	0.18	0.20	0.19	6.36	
A 221 - R1 - C3 sr	50	10	5	2.08	2.10	2.09	70.00	
ANALYSIS FOR SULFATE								
A 221 - R1 - C1	50	5	10	4.86	4.88	4.87		31.61
A 221 - R1 - C2	50	10	5	4.24	4.24	4.24		13.75
A 221 - R1 - C3 sr	50	5	10	11.62	11.64	11.63		75.68

No.	Sodium Hydroxide Titration		Barium Chloride Titration		Detection Limit
	KHP (mg)	Volume, V _s (mL)	Aliquot, V _i (10 mL)	Volume, V _i Normality, (mL)	
Blank	-	0.00	-	0.02	Sulfate, as H ₂ SO ₄ *2H ₂ O, mg
1			4	8.28	0.04
2			4	8.30	Acid, as H ₂ SO ₄ *2H ₂ O, mg
Avg.			0.09990	0.00972	0.33

Sulfuric Acid Concentration 0.0201 N
 PolarChem Lot S03468 Exp Jan 2011

Sodium Hydroxide Solution 0.0999 N
 PolarChem Lot U39346 Exp Oct. 2012

CALCULATIONS: $N_B = (V_i \times N_{H_2SO_4}) / (V_T - V_{TB})$

Sulfate as SO₄, mg = $(V_S - V_B) \times N_B \times 134.11 / 2 \times F$
 Acid as SO₄, mg = $(V_S - V_B) \times N_B \times 134.11 / 2 \times F$

SUMMARY
SCAQMD m5.2

Laboratory: Almega
Project: BP
Unit Tested: TGU #2
Lab. ID No.: A 221

Project No.: c 9036
Filter, Beaker Wt. Log Page(s): #24, #238-39

Sample Number	Lab ID	Tare Wt. (avg. g)	Final Wt. (avg. g)	Net Change (mg)	Volume ml	Blank mg	Comments
R1 - Filter	A 221 - R1 - C1	0.3436	0.3758	32.25	-	-	Run # 1
R1 - FH	A 221 - R1 - C2	28.5166	28.5433	26.70	230	0.14	Run # 1
R1 - BH	A 221 - R1 - C3 org	29.6360	29.6360	0.05	100	0.02	Run # 1
R1 - BH	A 221 - R1 - C3 sr	29.3359	29.4420	106.10	650	0.39	Run # 1
FB - Filter	A 221 - FB - C1	0.3431	0.3438	0.70	-	-	Field Blank
FB - FH	A 221 - FB - C2	28.8891	28.8966	7.50	175	0.11	Field Blank
FB - BH	A 221 - FB - C3 org	27.6878	27.6880	0.20	100	0.02	Field Blank
FB - BH	A 221 - FB - C3 sr	28.6932	28.7164	23.20	425	0.26	Field Blank
Reagent Blank		28.3990	28.3991	0.10	500	-	Methylene Chloride
Reagent Blank		27.8972	27.8975	0.30	500	-	DI Water

CALCULATIONS

$$C_A = m_A / (V_A * \rho_A)$$

Where:

C_A - Blank Concentration

m_A - Mass of residue of after evaporation, mg

V_A - Volume of blank, ml

ρ_A - Density, g/ml

$$W_A = C_A * V_{WA} * \rho_A$$

Where:

W_A - Weight of residue, mg

V_{WA} - Volume of liquid use, ml

Reagent Blank

Methylene Chloride

Density of methylene chloride ρ_M , g/ml =

Methylene Chloride blank volume V_M , ml =

Methylene Chloride blank concentration C_M , mg/g =

1.3550

500

0.0001

DI Water

Density of Water ρ_W , g/ml =

Water blank volume V_W , ml =

Water blank concentration C_W , mg/g =


0.998

500

0.0006

MeCl Lot No. 50294

DI Water System - Pure Water Co.

Checked by: 

D3-4

Beakers Weight Record

Laboratory: Almega
 Project: BP
 Project No.: e 9036
 Unit Tested: TCU #2
 Lab. ID No.: A 221

Balance ID: A&D ER-182A
 Serial No.: 4702866
 Last Calibration: 2-Jun-10
 Beaker Weight Log Page(s): #238-39

8 Prefest

(page of)

Sample Number	Lab ID	Beaker ID	Date/Time	By	Wt. 1	Date/Time	By	Wt. 2	Average	D Wt. (mg)	Volume ml	Comments
K1 - FH	A 221 - R1 - C2	6743	12/6/10 16:00	DW	28.5167	12/6/10 8:00	DW	28.5165	28.5166	0.30	230	Run # 1
K1 - RH	A 221 - R1 - C3 org	6893	12/6/10 16:00	DW	29.6361	12/6/10 8:00	DW	29.6348	29.6350	0.30	100	Run # 1
R1 - RH	A 221 - R1 - C3 sr	6846	12/6/10 16:00	DW	29.3357	12/6/10 8:00	DW	29.3361	29.3359	0.40	650	Run # 1
FB - FH	A 221 - FB - C2	5213	12/6/10 16:00	DW	28.8891	12/6/10 8:00	DW	28.8890	28.8891	0.10	175	Field Blank
FB - RH	A 221 - FB - C3 org	7614	12/6/10 16:00	DW	27.6879	12/6/10 8:00	DW	27.6876	27.6878	0.30	100	Field Blank
FB - RH	A 221 - FB - C3 sr	7587	12/6/10 16:00	DW	28.6932	12/6/10 8:00	DW	28.6932	28.6932	0.00	475	Field Blank
Reagent Blank		6771	12/17/10 16:00	DW	28.3990	12/21/10 8:00	DW	28.3990	28.3990	0.00	500	Methylene Chloride
Reagent Blank		7341	3/25/10 9:30	DW	27.8971	3/26/10 10:30	DW	27.8973	27.8972	0.20	500	DH Water

Checked by:

Beakers Weight Record

X Post-test (page of)

Laboratory: Almega
 Project: BP
 Project No.: 09036
 Unit Tested: IGU #2
 Lab. ID No.: A 221

Balanced ID: A&D HR-182A
 Serial No.: 4702866
 Last Calibration: 2-Jan-10
 Beaker Weight Log Page(s): #38-39

Sample Number	Lab ID	Beaker ID	Beaker Weights (g)				D.Wt. (mg)	Volume ml	Comments
			Date/Time	By	Wt. 1	Average			
R1 - FH	A 221 - R1 - C2	6743	12/27/10 14:00	DW	28.5433	28.5433	0.00	230	Run # 1
R1 - BH	A 221 - R1 - C3 avg	6893	12/27/10 14:00	DW	29.6361	29.6360	-0.20	100	Run # 1
R1 - BH	A 221 - R1 - C3 ar	6846	12/27/10 14:00	DW	29.6361	29.4420	0.00	650	Run # 1
FB - FH	A 221 - FB - C2	5213	12/27/10 14:00	DW	28.8965	28.8965	0.10	175	Field Blank
FB - BH	A 221 - FB - C3 avg	7614	12/27/10 14:00	DW	27.6879	27.6880	-0.10	160	Field Blank
FB - BH	A 221 - FB - C3 ar	7587	12/27/10 14:00	DW	28.7163	28.7164	0.20	425	Field Blank
Reagent Blank		6771	12/27/10 14:00	DW	28.3990	28.3992	-0.20	500	Methylene Chloride
Reagent Blank		7941	6/7/10 11:00	DW	27.8974	27.8975	-0.20	500	DI Water

Checked by: BP *only 1 value used*

Filter Weight Record


_____ x _____ Pretest _____ (page _____ of _____)

Laboratory: Almega
 Project: BP
 Project No.: c 9036
 Unit Tested: TGU #2
 Lab. ID No.: A 221

Balanced ID: A&D ER-182A
 Serial No.: 4702866
 Last Calibration: 2-Jun-10
 Filter Weight Log Page(s): #24

Client Sample No.	Lab ID	Filter ID	Filter Weights (g)				D Wt. (mg)	Comments
			Date/Time	By	Wt. 1	Date/Time	By	Average
R1 - Filter	A 221 - R1 - C1	9465	12/8/10 14:00	DW	0.3435	12/13/10 13:00	DW	0.3436
FB - Filter	A 221 - FB - C1	9462	12/8/10 14:00	DW	0.3428	12/13/10 13:00	DW	0.3433
								0.3431
								-0.10
								-0.50
								Field Blank

23-7

Checked By: 

Filter Weight Record


x Post-test (page of)

Laboratory: Almega
 Project: BP
 Project No.: c 9036
 Unit Tested: TGU #2
 Lab. ID No.: A 221

Balanced ID: A&D ER-182A
 Serial No.: 4702866
 Last Calibration: 2-Jun-10
 Filter Weight Log Page(s): #24

Client Sample No.	Lab ID	Filter ID	Filter Weights (g)						D Wt. (mg)	Comments
			Date/Time	By	Wt. 1	Date/Time	By	Wt. 2		
R1 - Filter	A 221 - R1 - C1	9465	12/21/10 15:00	DW	0.3758	1/3/11 13:00	DW	0.3758	0.3758	Run # 1
FB - Filter	A 221 - FB - C1	9462	12/21/10 15:00	DW	0.3438	1/3/11 13:00	DW	0.3437	0.3438	Field Blank

93-8

Checked By: 

Lot # A221



CHAIN OF CUSTODY

RECORDS

INVOICE TO:	REPORT TO:	PO #	Turnaround Time
	ALMEGA Environmental & Technical Services		Standard: _____ Other: _____
	5251 McFadden Ave.		
	Huntington Beach, CA 92649		
ATTN:	(714) 889-4000 Fax (714) 889-7030		
	lab@almegaenvironmental.com		
	Contact:		

Job # 9036		Unit # K4 #2	Client: BP	Location: CAESAR, CA		ANALYSIS REQUESTED		Turnaround Time	
Sample Date		Sample Time		Sample Identification		Lab Sample #		Type Of Sample	
								LIQUID GAS SOLID	
								No of Containers	
12/16/10	0927	FB - FILTER							
		FB - FH							
		FB - BH							
		1015 RI - FILTER							
1055	1055	RI - FH							
		RI - BH							
		A221 - TANK A							
		TANK B							
1055	1055	TRP 154							
		TRP 155							

Relinquished by: <i>[Signature]</i>	Received by: <i>G. Alexandroff</i>	Relinquished by:	Received by:
Date: 12/16/10 Time 18:45	Date: 12/16/10 Time 18:45	Date:	Date:



Standard Receipt
Sample LOG in Checklist

Project No: 9036 BP TGU 2

Lab ID: A 221

Method: S2, 25.3

Sampling Date: 12/16/10

Location: _____ Int: _____

Date & Time Rcd: 12/16/10 18:45

Location: _____ Int: _____

Arrived By: (circle) FedEx UPS Drop Off (Int) ☒ Other _____

Condition of Package(s): (comment): _____

Package Type: Box ☒ Cooler Other: _____

Number of Sample Container(s): 1 FB + 1 LA

Correct Containers (per Method): Y N

Preservation: (circle) ☒ ICE DryICE ICEPacks None

Sample Conditions:

Sample Temp (C): ~4°C

Ambient Temp (C): 21°C

Sample Temp (C): _____

Filter Condition: _____

PH: _____

Components Sealed: Y N

Sample Recovery Completed On: (date & time) _____

Recovered In: (circle) ☒ Field Lab Other _____

Silica Gel Condition: _____

Tedlar Bags -

Condensation: Y N

Comments: Notes #154 - 1mb in vial /
Notes - 3mb in vial

Container(s) Requested: Glass _____ Plastic _____

Additional Comments:

APPENDIX E

SCAQMD METHOD 25.3 – VOC AS TGNMO (LOW-LEVEL)

Appendix E1

VOC AS TGNMO (LOW-LEVEL) – Results and Calculations

TGNMO SOURCE TEST RESULTS

Facility: BP West Coast Products, LLC.
 City: Carson, CA
 Source: No. 2 TGU
 Test Date: 12/16/10

Parameter	units	Run 1		
		1A**	1B	**AVG
Sampling Method		25.3	25.3	25.3
Standard Temperature	deg. F	60	60	60
Stack Gas Parameters				
Barometric Pressure	in. Hg	29.98	29.98	29.98
Temperature	deg.F	1268	1268	1268
O2 Content	%,dry	15.70	7.90	7.90
CO2 content	%,dry	2.90	5.00	5.00
Moisture Content	%	8.82	8.82	8.82
Flow Rate, dry	DSCFM	29,306	29,306	29,306
<u>TGNMO, as Methane *</u>				
CONCENTRATION				
measured as Methane ⁽¹⁾	ppmv	11.85	1.38	1.38
measured as Methane***	ppmv	11.36	1.24	1.24
EMISSION RATE				
measured as Hexane ⁽¹⁾	lb/hr	0.788	0.0921	0.0921
measured as Hexane***	lb/hr	0.756	0.0824	0.0824

* corrected based on carbon number.

Methane = 1

(1) One half of the reporting limit is reported for the ND results specified in AB2588 guidelines.

** Run 1A leaked and therefore not used for reporting purposes.

*** Fractions of the reported values are below reporting limit.

Stack flow rate was measured during isokinetic sampling per SCAQMD Method 5.2.

Test Data Reduction and Calculations for Method 25.3

Facility: BP West Coast Products, LLC.
 City: Carson, CA
 Source: No. 2 TGU
 Location: Stack

Operator: DJ
 Entered by: TG
 Checked by: SA

DATA ENTRY			Test No.	
			1A**	1B
Run Data:	Test Date	**	m/d/y	12/16/10
	Start Time	**	hh:mm	10:55
	End Time	**	hh:mm	11:55
Standard Temperature	**	deg. F	60	60
Standard Pressure	**	in. Hg	29.92	29.92
Molar Volume of Air at Standard Conditions	Vmol	dscM	23.68	23.68
Calculation Factor K1 for Standard Corrections	X1	deg./in. Hg	17.38	17.38
Barometric Pressure	Ps	in. Hg	29.98	29.98
Stack Temperature	Ts	deg. F	1268.3	1268.3
Stack Gas Moisture Content	H2O	%	8.82	8.82
Stack Gas Flow Rate	Qstd	DSCFM	29.306	29.306
Mol. Wt.:	TGNMO, as Hexane *	MW1	g/g-mole	14.36
	METHANE	MW1	g/g-mole	16
LABORATORY DATA			1A**	1B
Canister (tank):	VACUUM, Initial	P1	mm Hg	-763
	VACUUM, Final	P2	mm Hg	-185
	VOLUME of Gas Sample	Vtank	Liters	4.466
Concentration:	OXYGEN	O2	%dry	15.70
	CARBON DIOXIDE	CO2	%dry	2.9
	TGNMO, as Methane	Cl1	ppmv	< 1.62
Condensate:	VOLUME of Condensate Sample	Vtank	ml	1.00
	TGNMO, as Methane	Clc	ppmv	< 1.00
TEST RESULTS			1A**	1B
TGNMO, as Methane *				
CONCENTRATION, measured as Methane ⁽¹⁾		Cl	ppmv	10.91
	corrected for bias factor of 1.086	Cl'	ppmv	11.85
	TGNMO, as Methane *	Clx	ppmv	11.85
MASS RATE:	TGNMO, as Hexane *			
	lb/hr = [TGNMO] x MW x DSCFM x 60 / (379 x Scf)	Mi	lb/hr	0.788
	kg/hr = Mi / 1000 * 453.6	Mi.m	kg/hr	0.358

NOTE: * corrected based on carbon number; Methane = 1

(1) One half of the reporting limit is reported for the ND results specified in AB2588 guidelines.

** Run 1A leaked and therefore not used for reporting purposes.

Test Data Reduction and Calculations for Method 25.3

Facility: BP West Coast Products, LLC.
City: Carson, CA
Source: No. 2 TGU
Location: Stack

Operator: BH
Entered by: TG
Checked by: SA

DATA ENTRY			Test No.	
			1A	1B
Run Data:	Test Date	**	m/d/y	12/16/10
	Start Time	**	hh:mm	10:55
	End Time	**	hh:mm	11:55
Standard Temperature		**	deg. F	60
Standard Pressure		**	in. Hg	29.92
Molar Volume of Air at Standard Conditions	Vmol		dscM	23.68
Calculation Factor K1 for Standard Corrections	X1		deg./in. Hg	17.38
Barometric Pressure	Ps		in. Hg	29.98
Stack Temperature	Ts		deg. F	1268.2
Stack Gas Moisture Content	H2O		%	8.82
Stack Gas Flow Rate	Qstd		DSCFM	29306
Mol. Wt.:	TGNMO, as Hexane *	MW1	g/g-mole	14.36
	METHANE	MW1	g/g-mole	16
LABORATORY DATA				
		Symbol	units	
Canister (tank):	VACUUM, Initial	P1	mm Hg	-763
	VACUUM, Final	P2	mm Hg	-185
	VOLUME of Gas Sample	Vtank	Liters	4.466
Concentration:	OXYGEN	O2	%dry	15.70
	CARBON DIOXIDE	CO2	%dry	2.90
	TGNMO, as Methane	Cl, t	ppmv	** 0.36
Condensate:	VOLUME of Condensate Sample	Vtank	ml	1.00
	TGNMO, as Methane	Cl, c	ppmv	10.1
TEST RESULTS				
		Symbol	units	
TGNMO, as Methane *				
CONCENTRATION, measured as Methane		Cl	ppmv	10.46
corrected for bias factor of 1.086		Cl'	ppmv	11.36
TGNMO, as Methane *		Clx	ppmv	11.36
MASS RATE:	TGNMO, as Hexane *			
	lb/hr = (TGNMO)(MW)(DSCFM)/60(379.5cc)	Mi	lb/hr	0.7558
	kg/hr = Mi/1000*453.6	Mim	kg/hr	0.343

NOTE: * corrected based on carbon number;

Methane = 1

** Reported values are below the reporting limit.

** Run 1A leaked and therefore not used for reporting purposes.

Appendix E2

VOC AS TGNMO (LOW LEVEL) – Field Data

Appendix E3

VOC AS TGNMO (LOW-LEVEL) – Laboratory Data



LABORATORY REPORT

Non-Methane Non-Ethane Organic compound Emissions by SCAQMD Method 25.3 (TCA/FID)

Client: BP
 Project No.: c9036
 Unit Tested: YGU #2
 Sampling Date: 16-Dec-10
 Analyzed Date: 22-Dec-10
 Lab No.: A 221

Client Sample ID	Lab ID	Almega Sample ID		Total* NMNEO ppm	NMNEO	NMNEO	CH ₄	C ₂ H ₆	CO ₂	O ₂
		Tank	Trap		ppm condensable	ppm noncondensable	ppm	ppm	% v/v by TCD	% v/v by TCD
YGU #2										
INK A	A 221 - 011 A	A 119	154	10.7	10.1	< 2.0	8.52	ND	2.9	15.7
INK B	A 221 - 011 B	A2	155	< 2.0	< 1.0	< 2.0	39.8	ND	5.0	7.9
Detection Limit					1	2	2	2	0.3	0.3

* NOTE - the BIAS FACTOR (of 1.056) is NOT applied in these results.

ND: Not Detected

Detection Limit NMNEO noncondensable

Run A Run B
 1.62 1.55

Water Blank : ppmC 0.024

(GNMNEO concentration values are reported in ppm (v/v) as Methane (carbon=1)

The sample cylinder is analyzed for NMNEO, CO, CH₄, CO₂ and C₂H₆. It is then directed to a separation column where all heavy organics (C₄+) separate from the light organics (CO, CO₂, CH₄ and C₂H₆). The light organics are then passed through a reduction catalyst to convert CO and CO₂ to CH₄, and are then directed to a FID for detection and quantification. The heavy organics are backflushed off the holding column, passed through an oxidation catalyst, which convert all organics to CO₂, then through a reduction catalyst to convert CO₂ to CH₄ and then to a FID for detection and quantification.

Reviewed by:

GA

Almega Environmental & Technical Services

4151 McFadden Ave., Huntington Beach CA 92649

Phone 714-899-8980 Fax 714-899-7000

www.almegaenvironmental.com

E-3-1

BPCAR-00000273

CALCULATIONS

Client: BP
Project No.: c9036
Unit Tested: TGU #2
Sampling Date: 16-Dec-10
Date tested: 22-Dec-10

Lab No.: A 221

Parameter	Symbol	Units	Run #1 A	Run #1 B
Sample ID			TNK A	TNK B
Lab ID			A 221 - 011 A	A 221 - 011 B
<u>Sample Tank</u>				
Tank No			A 119	A2
Sample Tank Volume	V_T	L	6.000	6.000
Barometric Pressure	P_b	mm Hg	763	763
Pre-test Pressure	P_{Ti}	mm Hg (abs)	0	0
Pre-test Temperature	T_{Ti}	$^{\circ}\text{C}$	22	22
Abs. Pre-test Temperature	T_{Ti}	$^{\circ}\text{K}$	295	295
Post-test Pressure	P_{Ts}	mm Hg (abs)	578	602
Post-test Temperature	T_{Ts}	$^{\circ}\text{C}$	22	22
Abs. Post-test Temperature	T_{Ts}	$^{\circ}\text{K}$	295	295
Final Pressure	P_{Tf}	mm Hg (abs)	930	926
Abs.Final Temperature	T_{Tf}	$^{\circ}\text{K}$	293	293
Dilution Factor	DF_T		1.62	1.55
Concentration Methane	C_{CH_4}	ppm	5.26	25.67
Concentration Carbon Monoxide	C_{CO}	ppm	39.71	579.24
NMNEO (noncond)	C_{SA}	ppm	0.36	0.24

Sample Volume	V_s	L	4.466	4.652
Methane in Tank($C_{CH_4} \cdot DF_T$)	C_{CH_4T}	ppm	8.52	39.8
Carbon Monoxide in Tank($C_{CO} \cdot DF_T$)	C_{CO_T}	ppm	64.3	897
NMNEO (noncond)	C_{SAT}	ppm	0.58	0.37

Condensate Recovery - Trap

Sample ID			TRP 154	TRP 155
Trap No			154	155
Lab No.:			A 221 - 012 A	A 221 - 012 B
Sample Impinger Volume	V_{DIP}	ml	1.0	3.0
Sample Volume	V_s	L	4.466	4.652
TC Concentration	C_{TC}	mg/L	27.94	18.22
IC Concentration	C_{IC}	mg/L	4.972	17.51
TOC Concentration	C_{TOC}	mg/L	22.97	0.71

NMNEO, Condensable	C_T	ppm	10.15	0.90
TNMNEOC ($C_{SA} + C_T$)	C	ppmC	10.72	1.28

Calculations

$$V_s = k_1 \cdot V_T \cdot (P_{Ts}/T_{Ts} - P_{Ti}/T_{Ti})$$

$$k_1 = (273 + 15.56)/760 = 0.3799$$

$$C_{SAT} = DF \cdot C_{SA}$$

$$C_{CH_4T} = DF \cdot C_{CH_4}$$

$$DF = (P_{Tf}/T_{Tf}) / (P_{Ts}/T_{Ts} - P_{Ti}/T_{Ti})$$

$$C_T = (C_{TOC} \cdot V_{DIP} \cdot V_{W}) / (V_s \cdot A_C)$$

$$V_W = 23.6902 \text{ L/mole}$$

QA/QC SUMMARY
(Repeat Analysis)

Client Project No.: c9036
Sampling Date: 16-Dec-10
Run #1 A

Lab No.: A 221
Analyzed Date: 22-Dec-10

Analyte	Sample ID	Area Count #1	Area Count #2	Area % diff (±20%)	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
Tank Analysis								
CO	A 221 - 011 A	983386	967168	1.63	40.0	39.4	39.7	1.66
CH4	A 221 - 011 A	130832	130074	0.58	5.28	5.25	5.26	0.58
CO2*	A 221 - 011 A	102863	109914	-6.85	1.7	1.8	1.8	-6.63
O2*	A 221 - 011 A	2039493	1955066	4.14	9.9	9.5	9.7	4.23
C2H6	A 221 - 011 A	ND	ND	ND	ND	ND	ND	ND
NMNEO	A 221 - 011 A	8931	8596	3.75	0.36	0.35	0.36	3.82
Analyte	Sample ID	Conc # 1	Conc # 2	Conc # 3	Mean Conc ppm	COV 10%		
Trap Analysis								
TC	A 221 - 012 A	7.412	7.085	6.461	27.94	6.68	DF=4	
IC	A 221 - 012 A	1.260	1.277	1.192	4.972	3.08		
Run #1 B								
Analyte	Sample ID	Area Count #1	Area Count #2	Area % diff (±20%)	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
Tank Analysis								
CO	A 221 - 011 B	14240825	14212617	0.20	580	579	579	0.20
CH4	A 221 - 011 B	662611	610368	7.88	26.7	24.6	25.7	8.21
CO2*	A 221 - 011 B	193954	193711	0.13	3.2	3.2	3.2	0.13
O2*	A 221 - 011 B	1048742	1038693	0.96	5.1	5.1	5.1	0.96
C2H6	A 221 - 011 B	ND	ND	ND	ND	ND	ND	ND
NMNEO	A 221 - 011 B	6148	5691	7.43	0.23	0.23	0.24	7.72
Analyte	Sample ID	Conc # 1	Conc # 2	Conc # 3	Mean Conc ppm	COV 10%		
Trap Analysis								
TC	A 221 - 012 B	14.60	12.73	13.76	18.22	6.91	DF=1.33	
IC	A 221 - 012 B	13.37	13.18	12.94	17.51	1.93		

Water blank

TC 0.068
IC 0.044
TOC 0.024

* - by GC/TCD

Conc_{CO} in tank = MeanConc_{CO} * DF
Conc_{CO2} in tank = MeanConc_{CO2} * DF
Conc_{O2} in tank = MeanConc_{O2} * DF
Conc_{C2H6} in tank = MeanConc_{C2H6} * DF

SAMPLE INVENTORY REPORT

Method 25.3 Sampling Train


Project No.: c9036
Client: BP

Lab No.: A 221
Sampling Date: 16-Dec-10

Laboratory ID	Client ID	Component ID
Run #1 A		
A 221 - 011 A	TNK A	Tank # A 119
A 221 - 012 A	TRP 154	Impinger 154
Run #1 B		
A 221 - 011 B	TNK B	Tank # A2
A 221 - 012 B	TRP 155	Impinger 155

E2-4


Lot # A221



CHAIN OF CUSTODY

RECORDS

INVOICE TO:	REPORT TO:	PO #	Turnaround Time
ALMEGA Environmental & Technical Services	ALMEGA Environmental & Technical Services		Standard: _____ Other: _____
5251 McFadden Ave.	5251 McFadden Ave.		Rush: _____
Huntington Beach, CA 92649	Huntington Beach, CA 92649		Depends on # of Samples
(714) 889-4000 Fax (714) 889-7030	(714) 889-4000 Fax (714) 889-7030		5 - 10 days
lab@almegaenvironmental.com	lab@almegaenvironmental.com		3 - 7 days
ATTN:	Contact:		

Job # 9036		Unit # TG 4 #2		Client: BP		Location: CARSON, CA		ANALYSIS REQUESTED		5 - 10 days	
Samplers: (Signature) 						Unit Information:				3 - 7 days	
Project Manager: T. T. LEW		Sample Identification		Lab Sample #		Type Of Sample				Return or Dispose	
Sample Date		Sample Time				LIQUID GAS SOLID		Value (Conditions)		REMARKS	
12/16/10		0927		FB - FILTER				✓		✓	
↓				FB - FH		✓				✓	
↓				FB - BH		✓				✓	
↓				R1 - FILTER		✓				✓	
↓				R1 - FH		✓				✓	
↓				R1 - BH		✓				✓	
↓				A221-01A		✓				TANK # A119	
↓				011B		✓				TANK # A2	
↓				012A		✓				TANK A	
↓				012B		✓				TANK B	
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											
↓											



Standard Receipt
Sample LOG in Checklist

Project No: 9036 BP TGU 2

Lab ID: A 221

Method: S2, 25.3

Sampling Date: 12/16/10

Location: _____ Int: _____

Date & Time Rcd: 12/16/10 18:45

Location: _____ Int: _____

Arrived By: (circle) FedEx UPS Drop Off (Int) ☒ Other _____

Condition of Package(s): (comment):

Package Type: Box Cooler Other: _____

Number of Sample Container(s): 1 FB + 1 LA

Correct Containers (per Method): Y N

Preservation: (circle) ICE DryICE ICEPacks None

Sample Conditions:

Sample Temp (C): ~4°C

Ambient Temp (C): 21°C

Sample Temp (C): _____

Filter Condition: _____

PH: _____

Components Sealed: Y N

Sample Recovery Completed On: (date & time) _____

Recovered In: (circle) Field Lab Other _____

Silica Gel Condition: _____

Tedlar Bags -

Condensation: Y N

Comments: * 154 - 1 mL

* 155 - 3 mL in Vial

Container(s) Requested: Glass _____ Plastic _____

Additional Comments:

APPENDIX F

QUALITY ASSURANCE AND QUALITY CONTROL (QA/QC)

Appendix F1

Test Equipment Calibration Data

TYPE S PITOT TUBE INSPECTION SHEET

CAL DATE: 11/17/2010

NEXT DUE DATE: May-11

PITOT ID: PT-4

Parameter	Values	Allowable Range
Level and Perpendicular?	Yes OR No	Yes
Obstruction?	Yes OR No	No
Damaged?	Yes OR No	No
α_1	2	$-10^\circ \leq \alpha_1 \leq +10^\circ$
α_2	2	$-10^\circ \leq \alpha_2 \leq +10^\circ$
β_1	2	$-5^\circ \leq \beta_1 \leq +5^\circ$
β_2	2	$-5^\circ \leq \beta_2 \leq +5^\circ$
γ	1	NA
θ	2	NA
$Z = A (\tan \gamma)$	0.014	$\leq 0.125 \text{ in.}$
$W = A (\tan \theta)$	0.027	$\leq 0.031 \text{ in.}$
D_t	0.37	$0.188 \leq D_t \leq 0.375$
A	0.785	NA
$A/2/(D_t)$	1.06	$1.05 \leq PA/D_t \leq 1.5$

Certification:

I certify that this pitot tube meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor C_p of 0.84.

Certified By:

[Signature]

Date: 11/17/2010

ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES
5251 MCFADDEN AVENUE
HUNTINGTON BEACH, CA 92649

STACK TEMPERATURE SENSOR CALIBRATION

TEMPERATURE SENSOR I.D.:	4	REF. IN HG. GLASS THERMOMETER ID: 20-500
READ OUT I.D.:	RO-1	ICE BATH: YES
PITOT TUBE I.D.:	4	BOILING WATER: YES
PITOT TUBE LENGTH:	110"	HOT OIL: YES
DATE:	11/17/2010	CALIBRATED BY: KA <i>[Signature]</i>

ICE BATH			
REF. IN HG. GLASS THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
33.0	33.3	0.3	0.9
33.0	33.2	0.2	0.6
33.0	33.2	0.2	0.6

BOILING WATER			
REF. IN HG. GLASS THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
216.0	214.5	1.5	0.7
216.0	214.0	2.0	0.9
216.0	214.4	1.6	0.7


HOT OIL			
REF. IN HG. GLASS THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	% DIFFERENCE (%)
352.0	351.0	1.0	0.3
352.0	350.5	1.5	0.4
352.0	351.0	1.0	0.3

NOTE:
MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%.
TAKE READING EVERY ONE MINUTE.

Field Dry Gas Meter Calibration*

Calibration Date: 11/10/2010

Orifice Series: 33-73
 Serial Number: AE₁/AE₂
 Office Cal. Date(monthly): 5/7/2010

Calibrated by: KA
 (signature): 

DRY GAS METER CALIBRATION FACTOR Y	ORIFICE CALIBRATION FACTOR dH@
Yds = 0.9838	dH@ = 1.729

DRY GAS METER READINGS										QUALITY CONTROL CHECKS				DGM ID: AL-2
DGM INLET		DGM OUTLET		Meter Reading		Orifice Reading		0.98 < (Y _{ds} /Y _{cal}) < 1.02		Average Coeff. Y _{ds}		dH@ < (dH@ ± 0.15)		Calibration Interval: Semi-Annual: Bi-monthly: Other:
Initial (°F)	Final (°F)	Initial (°F)	Final (°F)	Initial (cu.ft.)	Final (cu.ft.)	Initial (in.H ₂ O)	Final (in.H ₂ O)	(Y _{ds} /Y _{cal}) < 0.010	(Y _{ds} /Y _{cal}) < 0.010	Coef. Y _{ds}	Y _{ds}	Coef. Y _{ds}	Y _{ds}	
71.0	73.0	68.0	70.0	598.995	609.005	0.120	0.120	0.0082	0.0082	0.988	1.587	0.988	1.587	
73.0	75.0	70.0	73.0	806.005	812.086	0.120	0.120	PASS	PASS	PASS	PASS	PASS	PASS	
75.0	77.0	73.0	74.0	812.086	818.132	0.120	0.120	PASS	PASS	PASS	PASS	PASS	PASS	Standard Temperature (deg.F) Tstd = 80 Barometric Pressure (in.Hg) Initial: 30 Final: 30 Paid: 30.00
86.0	84.0	75.0	78.0	618.418	624.765	0.800	0.800	0.0002	0.0002	0.976	1.757	0.976	1.757	
94.0	98.0	70.0	77.0	824.785	831.135	0.800	0.800	PASS	PASS	PASS	PASS	PASS	PASS	
98.0	97.0	77.0	78.0	831.135	837.520	0.800	0.800	PASS	PASS	PASS	PASS	PASS	PASS	
100.0	108.0	78.0	79.0	837.880	843.835	2.000	2.000	0.0068	0.0068	0.987	1.762	0.987	1.762	Initial: 30 Final: 30 Paid: 30.00
108.0	112.0	79.0	81.0	843.835	849.390	2.000	2.000	PASS	PASS	PASS	PASS	PASS	PASS	
112.0	113.0	81.0	82.0	849.390	855.150	2.000	2.000	PASS	PASS	PASS	PASS	PASS	PASS	
116.0	122.0	82.0	83.0	855.803	862.740	3.800	3.800	0.0084	0.0084	0.997	1.788	0.997	1.788	
122.0	124.0	83.0	84.0	862.740	869.535	3.800	3.800	PASS	PASS	PASS	PASS	PASS	PASS	
124.0	125.0	84.0	85.0	869.535	876.372	3.800	3.800	PASS	PASS	PASS	PASS	PASS	PASS	

Orifice Series No.	Run Time (min)	CRITICAL ORIFICE					DRY GAS METER					CALCULATIONS	
		Orifice K-factor	Tested Vacuum (in.Hg)	Ambient Temp. (°F)	Corrected		Orifice dH (in.H ₂ O)	AVG Temp. (°F)	NET Volumes (cu.ft.)	Corrected		Coefficient Y _{ma} (0.95 < Y _{ma} < 1.05)	Orifice dH@ (in.H ₂ O)
					Flowrate Q _{fm} (SCFM)	Volume (cu.ft.)				Flowrate Q _{fm} (SCFM)	Volume (SCF)		
33	28	0.1549	25.0	57.0	0.204	5.724	0.120	70.50	6.010	0.211	5.912	0.9882	1.591
33	28	0.1549	25.0	58.0	0.204	5.718	0.120	72.75	6.081	0.213	5.957	0.9600	1.587
33	28	0.1549	25.0	58.0	0.204	5.719	0.120	74.75	6.048	0.211	5.900	0.9892	1.581
52	12	0.3768	23.0	59.0	0.496	5.858	0.800	83.50	6.349	0.509	6.106	0.9757	1.761
52	12	0.3768	23.0	60.0	0.496	5.852	0.800	85.75	6.370	0.508	6.101	0.9755	1.757
52	12	0.3768	23.0	60.0	0.496	5.862	0.800	87.00	6.385	0.508	6.102	0.9755	1.753
63	7	0.5890	21.0	60.0	0.775	5.428	2.000	91.25	5.745	0.761	5.454	0.9831	1.781
63	7	0.5890	21.0	60.0	0.775	5.428	2.000	95.00	5.755	0.777	5.438	0.9861	1.778
63	7	0.5890	21.0	61.0	0.774	5.421	2.000	97.00	5.780	0.774	5.421	0.9909	1.776
73	6	0.8108	19.0	61.0	1.066	6.397	3.800	100.50	6.837	1.070	6.423	0.9959	1.785
73	6	0.8108	19.0	62.0	1.065	6.390	3.800	95.75	6.795	1.073	6.438	0.9926	1.804
73	6	0.8108	19.0	62.0	1.065	6.390	3.800	104.50	6.837	1.083	6.377	1.0021	1.776

* Critical Orifice used.



NOZZLE CALIBRATION FORM


NOZZLE ID #: , 52

CLIENT: BP

CALIPER ID: CALIPER

DATE: 12/16/10


CALIBRATOR: BRYAN HARRISON

SIGNATURE: 

Measured Diameter A: .52 inch

Measured Diameter B: .52 inch

Measured Diameter C: .52 inch



Nozzle inside diameter

Appendix F2

CEMS Calibration Gas Certificates

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Airgas Specialty Gases
11711 S. Alameda Street
Los Angeles, CA 90059-2130
(323) 357-6881
Fax: (323) 567-3585
www.airgas.com

Part Number: E03NI83E15A3830 Reference Number: 48-124230108-11
Cylinder Number: CC274244 Cylinder Volume: 148 Cu.Fl.
Laboratory: ASG - Los Angeles - CA Cylinder Pressure: 2015 PSIG
Analysis Date: Aug 16, 2010 Valve Outlet: 590

Expiration Date: Aug 16, 2013

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1987)" using the assay procedures listed. Analytical Methodology does not require correction for analytical interferences. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 150 psig i.a. 1 Mega Pascal

ANALYTICAL RESULTS				
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty
CARBON DIOXIDE	4.260 %	4.278 %	G1	+/- 1% NIST Traceable
OXYGEN	12.00 %	12.09 %	G1	+/- 1% NIST Traceable
NITROGEN	Balance			

CALIBRATION STANDARDS				
Type	Lot ID	Cylinder No	Concentration	Expiration Date
NTRM	82658	SG9168290	16.04% OXYGEN/	Dec 01, 2015
NTRM	81674	XC018412B	4.811% CARBON DIOXIDE/	May 15, 2012

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS % CO2	NDIR	Aug 13, 2010
Siemens %O2	PARAMAGNETIC	Aug 13, 2010

Triad Data Available Upon Request

Notes:

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Airgas Specialty Gases
11711 S. Alameda Street
Los Angeles, CA 90060-2130
(323) 357-6881
Fax: (323) 567-3688
www.airgas.com

Part Number: E03NI69E15A3832 Reference Number: 48-124203748-11
Cylinder Number: CC277612 Cylinder Volume: 151 Cu.Ft.
Laboratory: ASG - Los Angeles - CA Cylinder Pressure: 2015 PSIG
Analysis Date: Jan 14, 2010 Valve Outlet: 590

Expiration Date: Jan 14, 2013

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed. Analytical Methodology does not require correction for analytical interferences. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 150 psig, i.e. 1 Mega Pascal

ANALYTICAL RESULTS				
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty
CARBON DIOXIDE	8.750 %	8.782 %	G1	+/- 1% NIST Traceable
OXYGEN	22.00 %	21.87 %	G1	+/- 1% NIST Traceable
NITROGEN	Balance			

CALIBRATION STANDARDS				
Type	Lot ID	Cylinder No	Concentration	Expiration Date
NTRM	060608	CC207779	22.51% OXYGEN/	May 01, 2010
NTRM	970510	SG9198971	10.818% CARBON DIOXIDE/NITROGEN	May 15, 2012

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS % CO2	NDIR	Jan 04, 2010
Siemens %O2	PARAMAGNETIC	Jan 04, 2010

Triad Data Available Upon Request

Notes:

QA Approval

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Airgas Specialty Gases
11711 S. Alameda Street
Los Angeles, CA 90059-2130
(323) 357-8891
Fax: (323) 567-3686
www.airgas.com

Part Number: E02NI99E15A0499 Reference Number: 48-124179252-6
Cylinder Number: CC162408 Cylinder Volume: 144 Cu.Ft.
Laboratory: ASG - Los Angeles - CA Cylinder Pressure: 2015 PSIG
Analysis Date: Jun 16, 2009 Valve Outlet: 350

Expiration Date: Jun 16, 2012

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed. Analytical Methodology does not require correction for analytical interferences. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 150 psig i.e. 1 Mega Pascal

ANALYTICAL RESULTS				
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty
CARBON MONOXIDE	450.0 PPM	446.7 PPM	G1	+/- 1% NIST Traceable
NITROGEN	Balance			

CALIBRATION STANDARDS				
Type	Lot ID	Cylinder No	Concentration	Expiration Date
NTRM	06120508	CC180349	495.8PPM CARBON MONOXIDE/NITROGEN	Feb 02, 2013

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 CO	FTIR	Jun 10, 2009

Triad Data Available Upon Request

Notes:

QA Approval



AIR LIQUIDE

CERTIFICATION OF ANALYSIS

Interference Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section 2.2, Procedure G-1

Cylinder S/N: CC54488

Customer: ALMEGA ENVIRONMENTAL & TECHNICAL
Location: HUNTINGTON BEACH, CA

Shipping Order Number: 32945670

Transfer Number:

Lot Number: SFS130919

Valve: CGA 350

Cylinder Pressure*: 2000 PSIG

* Cylinder should not be used when
gas pressure is below 150 psig

P.O. Number: STOCK REPLACEMENT

Assay Date: 7-Apr-2009

Expiration Date: 7-Apr-2012

Components	Requested Concentration	Assay Concentration
Nitrogen	Balance	Balance
Carbon Monoxide	888 ppm	888 ± 11 ppm

Reference Standard(s) Employed For Analysis

Certified Concentration and Uncertainty	Component	Balance	Cyl. No.	SRM/PRM/Mix No.	Exp. Date	Sample No.	Type
1010 ± 2 ppm	Carbon Monoxide	Nitrogen	AL3127	SFS111119	23-Jul-2010	EE	GA88

Analytical Data

Component: Carbon Monoxide		FIRST TRADE ANALYSIS 31-Mar-2009				SECOND TRADE ANALYSIS 7-Apr-2009			
Analyzer Information		Zero	Trials 1	Trials 2	Trials 3	Zero	Trials 1	Trials 2	Trials 3
Analyzer Type:	Gas Chromatograph	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Manufacturer:	Varian	5508500	5508500	5508500	5508500	5508500	5508500	5508500	5508500
Model Number:	3400A	4900300	4900300	4900300	4900300	4900300	4900300	4900300	4900300
Serial Number:	2306	888.2	888.2	888.2	888.2	888.2	888.2	888.2	888.2
MPR Last Calibrated:	6-Apr-2009	Evaluation	Valid	Valid	Valid	Evaluation	Valid	Valid	Valid
Analytical Principle	FID & TCD	Mean Analytical Result: 888.1 ppm				Mean Analytical Result: 888.9 ppm			

Analyzed:

Eric Barman

Approved by:

Jason Unzueta

AIR LIQUIDE AMERICA, L.P.

Region Office • 8832 Dore Road, Santa Fe Springs, CA 90670-2516
Phone (562) 945-1383 • Fax (562) 693-1150

F2-4

BPCAR-00000289

APPENDIX G
FACILITY PROCESS DATA

6-1

BPCAR-00000291

কুমিল্লা জেলা পরিষদ

PDM NOX	ZINCIN STK NOX	PERCENT	PDM	ZINCIN STK SO2	DEG F	ZINCIN STK SO2 TEMP	WMSCFH	ZINCIN STK SO2 DSCFH	WMSCFH	LBHR		LBHR		ZINCIN SO2 STK EMIS-LBHR	ZINCIN NOX STK EMIS-LBHR		ZINCIN NOX STK EMIS-LBHR	ZINCIN SO2 STK EMIS-LBHR	BIAS	BIAS	2INCIN STK K FACTOR	2INCIN STK K FACTOR
										68FY1990	68FY1990	68FY1990	68FY1990		68FY1990	68FY1990						
DATE/TIME	68A0000A	68A0000B	68A0000C	68A0000D	68A0000E	68A0000F	68A0000G	68A0000H	68A0000I	68A0000J	68A0000K	68A0000L	68A0000M	68A0000N	68A0000O	68A0000P	68A0000Q	68A0000R	68A0000S	68A0000T	68A0000U	68A0000V
12/16/2010 10:54	25.06	8.336	79.72	1255.08	1.76	5.250	22.194	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 10:55	24.97	8.312	78.12	1254.06	1.73	5.170	22.436	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 10:56	25.54	8.362	79.02	1253.01	1.72	5.239	22.157	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 10:57	26.01	8.392	80.62	1255.09	1.73	5.361	23.650	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 10:58	25.74	8.271	80.52	1256.13	1.72	5.281	22.986	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 10:59	26.06	8.340	78.61	1257.17	1.71	5.319	22.291	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:00	25.50	8.362	77.50	1258.91	1.69	5.149	21.935	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:01	24.80	8.371	78.30	1257.87	1.66	4.979	21.909	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:02	24.54	8.371	76.82	1257.17	1.69	4.972	22.117	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:03	25.42	8.362	80.10	1257.17	1.71	5.212	22.812	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:04	24.77	8.420	80.62	1258.08	1.73	5.121	23.194	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:05	24.77	8.420	80.82	1256.06	1.73	5.124	23.104	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:06	25.59	8.369	79.72	1254.05	1.76	5.399	23.288	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:07	25.06	8.340	82.22	1255.89	1.77	5.361	24.201	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:08	25.12	8.369	81.00	1256.13	1.77	5.330	23.888	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:09	25.97	8.330	78.30	1258.13	1.81	5.611	23.506	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:10	25.60	8.291	78.50	1255.13	1.81	5.571	23.610	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:11	25.31	8.292	79.62	1253.09	1.82	5.530	23.932	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:12	25.74	8.302	83.92	1257.17	1.81	5.659	25.208	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:13	24.57	8.361	82.01	1256.13	1.80	5.591	24.617	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:14	25.83	8.362	78.40	1255.89	1.81	5.399	23.610	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:15	25.97	8.481	80.00	1256.13	1.78	5.371	23.819	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:16	25.24	8.351	79.20	1257.17	1.78	5.399	23.810	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:29	25.12	8.399	81.11	1257.17	1.80	5.410	24.305	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:30	24.78	8.362	82.28	1256.13	1.81	5.361	24.791	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:31	25.13	8.330	81.70	1257.17	1.84	5.531	24.899	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:32	25.06	8.319	82.12	1257.17	1.82	5.462	24.665	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:33	24.91	8.399	80.60	1257.17	1.82	5.420	24.400	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:34	25.43	8.399	78.40	1256.13	1.82	5.531	23.716	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:35	25.65	8.340	78.82	1254.05	1.67	5.111	21.905	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:36	25.44	8.420	81.21	1246.88	1.84	5.560	24.791	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:37	26.11	8.312	79.61	1250.92	1.84	5.739	24.395	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:38	25.25	8.400	82.91	1251.87	1.84	5.541	25.312	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:39	25.43	8.399	83.02	1255.09	1.78	5.399	24.513	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:42	25.53	8.319	80.21	1257.57	1.79	5.472	23.898	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:43	25.85	8.362	78.50	1256.13	1.81	5.601	23.715	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:44	25.85	8.362	78.50	1256.13	1.81	5.601	23.715	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:45	25.30	8.392	81.70	1257.17	1.86	5.451	24.519	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:46	26.30	8.362	81.70	1257.17	1.86	5.451	24.519	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:47	26.01	8.371	80.21	1256.13	1.83	5.670	24.305	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840
12/16/2010 11:48	25.17	8.371	85.62	1267.17	1.80	5.410	25.569	1.000	1.000	1.000	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840	0.840

6-2

BPCAR-00000293

APPENDIX H
SCAQMD PERMIT TO OPERATE

FACILITY PERMIT TO OPERATE BP WEST COAST PROD.LLC BP CARSON REF.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 13 : SULFUR RECOVERY					
System 6 : THERMAL OXIDIZERS					
KNOCK OUT POT, RPV-0656, WASTE GAS, HEIGHT: 12 FT; DIAMETER: 9 FT A/N: 457434	D835				
OXIDIZER, THERMAL, NO. 2, WASTE GAS, REFINERY GAS OR NATURAL GAS, J.T.THORPE, 44.5 MMBTU/HR WITH A/N: 457434 BURNER, JOHN ZINK, WITH 2 BURNERS	C910	D790 D893 C896 S912 C2406	NOX: MAJOR SOURCE**; SOX: MAJOR SOURCE**	CO: 2000 PPMV (5) [RULE 407,4-2-1983] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981] ; PM: (9) [RULE 404,2-7-1986]	B61.4, C8.2, D82.2, D90.4, D328.1, H33.1
KNOCK OUT POT, SPIA, WASTE GAS, RW-1009, LENGTH: 23 FT; DIAMETER: 9 FT A/N: 457434	D2745				
KNOCK OUT POT, SPIA, WASTE GAS BLOWCASE, RW-5196, LENGTH: 6 FT 6 IN; DIAMETER: 2 FT 6 IN A/N: 457434	D2746				
FILTER, QUENCH TOWER, RPV 4197, FRAM, HEIGHT: 5 FT 3 IN; DIAMETER: 2 FT 8 IN A/N: 457434	D904				
STACK, HEIGHT: 300 FT; DIAMETER: 6 FT A/N: 457434	S912	C910 C2413			

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE BP WEST COAST PROD.LLC BP CARSON REF.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

B61.2 The operator shall only use butane containing the following specified compounds:

Compound	ppm by volume
Total Sulfur less than	50

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D1226, D1227, D1233, D1234, D1236, D1237, D1239, D1240]

B61.3 The operator shall only use natural gas containing the following specified compounds:

Compound	ppm by volume
Total Sulfur less than	5

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D1226, D1227, D1233, D1234, D1236, D1237, D1239, D1240]

B61.4 The operator shall not use fuel gas, except uncombined natural gas which is not regulated by the condition, containing the following specified compounds:

Compound	ppm by volume
H2S greater than	160

[40CFR 60 Subpart J, 6-24-2008]

[Devices subject to this condition : D27, D29, D31, D33, D67, D69, D151, D153, D155, D250, D252, D416, D417, D418, D419, D421, D423, D425, D532, D535, D538, D539, D541, D570, D625, D626, D627, D628, D629, C910, D1226, D1227, D1233, D1234, D1236, D1237, D1239, D1240, D1262, C1326, D1439, D1465, C2413, D2837]

FACILITY PERMIT TO OPERATE BP WEST COAST PROD.LLC BP CARSON REF.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- C6.2 The operator shall use this equipment in such a manner that the hydrocarbon concentration being monitored, as indicated below, does not exceed 30 percent of the Lower Explosive Limit.

The operator shall use an explosimeter to measure the Lower Explosive Limit (LEL) in the vapor space above the floating roof, twice a year at a 4 to 8 month interval.

The operator shall maintain records in a manner approved by the District, to demonstrate compliance with this condition.

[RULE 1178, 4-7-2006]

[Devices subject to this condition : D1153, D1154, D1155, D1156, D1158, D1161, D1166, D1167, D1168, D1169, D1170, D1171, D1172, D1173, D1174, D1176, D1179, D1180, D1181, D1182, D1183, D1184, D1188, D1190, D1194, D1195, D2850]

- C8.1 The operator shall use this equipment in such a manner that the percent excess air being monitored, as indicated below, is not less than 1 percent.

This condition shall only apply during normal operation. This limit is not applicable during startup, shutdown, or process upset.

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D1465]

- C8.2 The operator shall use this equipment in such a manner that the temperature being monitored, as indicated below, is not less than 1200 Deg F.

To comply with this condition, the operator shall install and maintain a(n) temperature reading device to accurately indicate the temperature in the firebox or in the ductwork immediately downstream from the firebox.

The operator shall also install and maintain a device to continuously record the parameter being measured.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : C910, C2413]

**FACILITY PERMIT TO OPERATE
BP WEST COAST PROD.LLC BP CARSON REF.**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D82.2 The operator shall install and maintain a CEMS to measure the following parameters:

NOX concentration in ppmv

SOX concentration in ppmv

Concentrations shall be corrected to 3 percent oxygen on a dry basis.

The CEMS will convert the actual NOX concentrations to mass emission rates (lbs/hr) and record the hourly emission rates on a continuous basis.

The CEMS will convert the actual SOX concentrations to mass emission rates (lbs/hr) and record the hourly emission rates on a continuous basis.

The CEMS shall be installed and certified no later than 12 months after the initial start up according to the requirements of Rule 2011 for SOx major sources and Rule 2012 for NOx major sources

[RULE 2011, 5-6-2005; RULE 2012, 5-6-2005]

[Devices subject to this condition : C910, C2413]

D82.4 The operator shall install and maintain a CEMS to measure the following parameters:

CO concentration in ppmv

Oxygen concentration in percent volume

[40CFR 63 Subpart UUU, 4-20-2006]

[Devices subject to this condition : D164]

FACILITY PERMIT TO OPERATE BP WEST COAST PROD.LLC BP CARSON REF.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- D90.3 The operator shall periodically analyze the fuel gas for total sulfur content in the refinery gases and butane used in the cogeneration facility according to the following specifications:

The operator shall analyze once every week.

[RULE 2005, 5-6-2005; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D860, D866, D1226, D1227, D1233, D1234, D1236, D1237, D1239, D1240]

- D90.4 The operator shall continuously monitor the H₂S concentration in the fuel gases before being burned in this device according to the following specifications:

The operator shall use Gas Chromatograph meeting the requirements of 40CFR60 Subpart J to monitor the parameter.

The operator shall also install and maintain a device to continuously record the parameter being monitored.

The operator may monitor the H₂S concentration at a single location for fuel combustion devices, if monitoring at this location accurately represents the concentration of H₂S in the fuel gas being burned in this device.

[40CFR 60 Subpart J, 6-24-2008]

[Devices subject to this condition : D27, D29, D31, D33, D67, D69, D151, D153, D155, D250, D252, D313, D416, D417, D418, D419, D421, D423, D425, D532, D535, D538, D539, D541, D570, D625, D626, D627, D628, D629, C910, D1226, D1227, D1233, D1234, D1236, D1237, D1239, D1240, D1262, D1439, C2413, D2837]

H-S

**FACILITY PERMIT TO OPERATE
BP WEST COAST PROD.LLC BP CARSON REF.**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- D328.1 The operator shall determine compliance with the CO emission limit(s) either: (a) conducting a source test at least once every five years using AQMD Method 100.1 or 10.1; or (b) conducting a test at least annually using a portable analyzer and AQMD-approved test method. The test shall be conducted when the equipment is operating under normal conditions to demonstrate compliance with the CO emission limit(s). The operator shall comply with all general testing, reporting, and recordkeeping requirements in Sections E and K of this permit.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997; RULE 407, 4-2-1982]

[Devices subject to this condition : D27, D29, D31, D33, D63, D67, D151, D153, D155, D250, D313, D416, D417, D418, D419, D421, D423, D425, D532, D535, D538, D539, D541, D570, D625, D626, D627, D628, D629, C910, D1262, D1433, D1439, D1465, C2413]

- D330.1 The operator shall have a person that has been trained in accordance with Rule 461 conduct a semi-annual inspection of the gasoline transfer and dispensing equipment. The first inspection shall be in accordance with Rule 461, Attachment B, the second inspection shall be in accordance with Rule 461, Attachment C, and the subsequent inspections shall alternate protocols. The operator shall keep records of the inspection and the repairs in accordance to Rule 461 and Section K of this Permit.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997; RULE 461, 3-7-2008]

[Devices subject to this condition : D1276]

- D332.1 The operator shall determine compliance with the CO emission limit(s) by conducting a test at least once every five years using a portable analyzer and AQMD-approved test method or, if not available, a non-AQMD approved test method. The test shall be conducted when the equipment is operating under normal conditions to demonstrate compliance with the CO emission limit(s). The operator shall comply with all general testing, reporting, and recordkeeping requirements in Sections E and K of this permit.

[RULE 1146.1, 5-13-1994; RULE 1146.1, 9-5-2008; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997; RULE 407, 4-2-1982]

[Devices subject to this condition : D69, D252, D705]

FACILITY PERMIT TO OPERATE BP WEST COAST PROD.LLC BP CARSON REF.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E336.13 The operator shall vent the vent gases from this equipment as follows:

All vent gases under normal operating conditions shall be directed to Thermal Oxidizer No.1 and/or Thermal Oxidizer No.2 of System 6 of Process 13.

This equipment shall not be operated unless either the Thermal Oxidizer No.1 and/or Thermal Oxidizer No.2 of System 6 of Process 13 are in full use and have a valid permit to receive vent gases from this equipment.

[RULE 1176, 9-13-1996]

[Devices subject to this condition : D830, D832]

H. Applicable Rules

H23.1 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
H2S	40CFR60, SUBPART	J

[40CFR 60 Subpart J, 6-24-2008]

[Devices subject to this condition : D27, D29, D31, D33, D67, D69, D151, D153, D155, D250, D252, D313, D416, D417, D418, D419, D421, D423, D425, D532, D535, D538, D539, D541, D570, D625, D626, D627, D628, D629, C910, D1227, D1233, D1234, D1236, D1237, D1239, D1240, D1262, C1326, D1439, D1465, C2413, D2837]

APPENDIX I

SCAQMD CHECKLIST FOR SOURCE TEST REPORTS, FORM STR.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

ENGINEERING FORM STR CHECK LIST FOR SOURCE TEST REPORTS

Please check off all the following items to verify that the information is provided in the source test report, and then send the checklist along with the source test report.

- [X] Brief description of the equipment tested.
- [X] Brief process description, including maximum and normal operating temperatures, pressures, through-put, etc.
- [X] Operating conditions under which test was performed.
- [X] Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, along with upstream and downstream locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
- [X] Field and laboratory data forms, strip charts and analyses.
- [X] Brief description of sampling and analytical methods for each gaseous and particulate constituent measured.
- [X] Calculations for volumetric flow rates and emission rates.
- [X] Description of calibration and quality assurance procedures.
- [X] Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (no conflict of interest).

ATTACHMENTS

Attachment 1

Laboratory Report and Data Package for TGNMO per SCAQMD

Method 25.3



LABORATORY REPORT

Non-Methane Non-Ethane Organic compound Emissions by SCAQMD Method 25.3 (TCA/FID)

Client: BP
 Project No.: 09036
 Unit Tested: TGU #2
 Sampling Date: 16-Dec-10
 Analyzed Date: 22-Dec-10
 Lab No.: A 221

Client Sample ID	Lab ID	Almega Sample ID		Total* NMNEO ppm	NMNEO	NMNEO	CH ₄	C ₂ H ₆	CO ₂	O ₂
		Tank	Trap		ppm condensable	ppm noncondensable	ppm	ppm	% v/v by TCD	% v/v by TCD
TGU #2										
TNK A	A 221 - 011 A	A 119	154	10.7	10.1	< 2.0	8.52	ND	2.9	15.7
TNK B	A 221 - 011 B	A2	155	< 2.0	< 1.0	< 2.0	39.8	ND	5.0	7.9
Detection Limit					1	2	2	2	0.3	0.3

* NOTE: the REAS FACTOR (of 1.000) is NOT applied in these results.

ND: Not Detected

Detection Limit: NMNEO noncondensable

Run A Run B
 1.62 1.58

Water Blank: ppmC 0.024

(NMNEO concentration values are reported in ppm (v/v) as Methane (carbon=1))

The sample cylinder is analyzed for NMNEO, CO, CH₄, CO₂ and C₂H₆. It is then directed to a separation column where all heavy organics (C₂+) separate from the light organics (CO, CO₂, CH₄ and C₂H₆). The light organics are then passed through a reduction catalyst to convert CO and CO₂ to CH₄ and are then directed to a FID for detection and quantification. The heavy organics are backflushed off the holding column, passed through an oxidation catalyst, which convert all organics to CO₂, then through a reduction catalyst to convert CO₂ to CH₄ and then to a FID for detection and quantification.

Reviewed by:

GA

Almega Environmental & Technical Services
 5251 McFadden Ave., Huntington Beach, CA 92649
 Phone 714 580-4000 Fax 714 580-7030
 www.almegaenvironmental.com

CALCULATIONS

Client: BP Lab No.: A 221
 Project No.: c9036
 Unit Tested: TGU #2
 Sampling Date: 16-Dec-10
 Date tested: 22-Dec-10

Parameter	Symbol	Units	Run #1 A	Run #1 B
Sample ID			TNK A	TNK B
Lab ID			A 221 - 011 A	A 221 - 011 B
<u>Sample Tank</u>				
Tank No			A 119	A2
Sample Tank Volume	V_T	L	6.000	6.000
Barometric Pressure	P_b	mm Hg	763	763
Pre-test Pressure	P_{T1}	mm Hg (abs)	0	0
Pre-test Temperature	t_{T1}	$^{\circ}\text{C}$	22	22
Abs. Pre-test Temperature	T_{T1}	$^{\circ}\text{K}$	295	295
Post-test Pressure	P_{T2}	mm Hg (abs)	578	602
Post-test Temperature	t_{T2}	$^{\circ}\text{C}$	22	22
Abs. Post-test Temperature	T_{T2}	$^{\circ}\text{K}$	295	295
Final Pressure	P_{TF}	mm Hg (abs)	930	926
Abs. Final Temperature	T_{TF}	$^{\circ}\text{K}$	293	293
Dilution Factor	DF_T		1.62	1.55
Concentration Methane	C_{CH_4}	ppm	5.26	25.67
Concentration Carbon Monoxide	C_{CO}	ppm	39.71	579.24
NMNEO (noncond)	C_{SA}	ppm	0.36	0.24

Sample Volume	V_S	L	4.466	4.652
Methane in Tank($C_{CH_4} * DF_T$)	C_{CH_4T}	ppm	8.52	39.8
Carbon Monoxide in Tank($C_{CO} * DF_T$)	C_{CO_T}	ppm	64.3	897
NMNEO (noncond)	C_{SAT}	ppm	0.58	0.37

Condensate Recovery - Trap

Sample ID			TRP 154	TRP 155
Trap No			154	155
Lab No.:			A 221 - 012 A	A 221 - 012 B
Sample Impinger Volume	V_{IMP}	ml	1.0	3.0
Sample Volume	V_S	L	4.466	4.652
TC Concentration	C_{TC}	mg/L	27.94	18.22
IC Concentration	C_{IC}	mg/L	4.972	17.51
TOC Concentration	C_{TOC}	mg/L	22.97	0.71

NMNEO, Condensable	C_T	ppm	10.15	0.90
TNMNEOC ($C_{SA} + C_T$)	C	ppmC	10.72	1.28

Calculations

$$V_g = k_1 * V_T * (P_{T2}/T_{T2} - P_{T1}/T_{T1})$$

$$k_1 = (273 + 15.36) / 760 = 0.3799$$

$$C_{SAT} = DF * C_{SA}$$

$$C_{CH_4T} = DF * C_{CH_4}$$

$$DF = (P_{TF}/T_{TF}) / (P_{T2}/T_{T2} - P_{T1}/T_{T1})$$

$$C_T = (C_{TOC} * V_{IMP} * V_{IM}) / (V_S * A_C)$$

$$V_{IM} = 23.6902 \text{ L/mole}$$

QA/QC SUMMARY
(Repeat Analysis)

Client Project No.: e9036
Sampling Date: 16-Dec-10
Run #1 A

Lab No.: A 221
Analyzed Date: 22-Dec-10

Analyte	Sample ID	Area Count #1	Area Count #2	Area % diff (±20%)	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
Tank Analysis								
CO	A 221 - 011 A	983386	967168	1.65	40.0	39.4	39.7	1.66
CH4	A 221 - 011 A	130832	130074	0.58	5.28	5.25	5.26	0.58
CO2*	A 221 - 011 A	102863	109914	-6.85	1.7	1.8	1.8	-6.63
O2*	A 221 - 011 A	2039493	1955066	4.14	9.9	9.5	9.7	4.23
C2H6	A 221 - 011 A	ND	ND	ND	ND	ND	ND	ND
NMNEO	A 221 - 011 A	8931	8596	3.75	0.36	0.35	0.36	3.82
Analyte	Sample ID	Conc # 1	Conc # 2	Conc # 3	Mean Conc ppm	COV 10%		
Trap Analysis								
TC	A 221 - 012 A	7.412	7.085	6.461	27.94	6.68	DF=4	
IC	A 221 - 012 A	1.260	1.277	1.192	4.972	3.08		
Run #1 B								
Analyte	Sample ID	Area Count #1	Area Count #2	Area % diff (±20%)	Conc # 1	Conc # 2	Mean Conc ppm	% diff from Mean
Tank Analysis								
CO	A 221 - 011 B	14240825	14212617	0.20	580	579	579	0.20
CH4	A 221 - 011 B	662611	610368	7.88	26.7	24.6	25.7	8.21
CO2*	A 221 - 011 B	193954	193711	0.13	3.2	3.2	3.2	0.13
O2*	A 221 - 011 B	1048742	1038693	0.96	5.1	5.1	5.1	0.96
C2H6	A 221 - 011 B	ND	ND	ND	ND	ND	ND	ND
NMNEO	A 221 - 011 B	6148	5691	7.43	0.23	0.23	0.24	7.72
Analyte	Sample ID	Conc # 1	Conc # 2	Conc # 3	Mean Conc ppm	COV 10%		
Trap Analysis								
TC	A 221 - 012 B	14.60	13.73	13.76	18.22	6.91	DF=1.33	
IC	A 221 - 012 B	13.37	13.18	12.94	17.51	1.93		

Water blank

TC 0.068
IC 0.044
TOC 0.024

Conc_{CO} in tank = MeanConc_{CO} * DF
Conc_{CO2} in tank = MeanConc_{CO2} * DF
Conc_{O2} in tank = MeanConc_{O2} * DF
Conc_{C2H6} in tank = MeanConc_{C2H6} * DF

* - by GC/TCD

SAMPLE INVENTORY REPORT

Method 25.3 Sampling Train

Project No.: c9036
Client: BP

Lab No.: A 221
Sampling Date: 16-Dec-10

Laboratory ID	Client ID	Component ID
Run #1 A		
A 221 - 011 A	TNK A	Tank # A 119
A 221 - 012 A	TRP 154	Impinger 154
Run #1 B		
A 221 - 011 B	TNK B	Tank # A2
A 221 - 012 B	TRP 155	Impinger 155

Box # A221



CHAIN OF CUSTODY

RECORDS

INVOICE TO:	REPORT TO:	PO #	Turnaround Time
ALMEGA Environmental & Technical Services	ALMEGA Environmental & Technical Services		Standard: _____ Other: _____
5251 McFadden Ave.	5251 McFadden Ave.		Rush: _____
Huntington Beach, CA 92648	Huntington Beach, CA 92648		Depends on # of Samples
(714) 889-4000 Fax (714) 889-7030	(714) 889-4000 Fax (714) 889-7030		5 - 10 days _____
lab@almegaenvironmental.com	lab@almegaenvironmental.com		3 - 7 days _____
ATTN:	Contact:		Return or Dispose

Job # 9036		Unit # T64 #2	Client: BP
Sample Date		Sample Identification	
12/16/10		FB - FILTER	
↓		FB - FH	
↓		FB - BH	
10/15		R1 - FILTER	
↓		R1 - FH	
↓		R1 - BH	
10/31		TANK A	
↓		TANK B	
↓		TRP 154	
↓		TRP 155	

Relinquished by: <i>[Signature]</i>	Received by: <i>G. Alexandroff</i>	Relinquished by:	Received by:
Date: 12/16/10 Time 15:45	Date: 12/16/10 Time 18:45	Date:	Date:



Standard Receipt
Sample LOG in Checklist

Project No: 9036 BP T&U 2

Lab ID: A 221

Method: S2, 25.3

Sampling Date: 12/16/10

Location: _____ Int: _____

Date & Time Rcd: 12/16/10 18:45

Location: _____ Int: _____

Arrived By: (circle) FedEx UPS Drop Off (ini) ✓ Other _____

Condition of Package(s): (comment):

Package Type: Box Cooler Other: _____

Number of Sample Container(s): 1 FB + 1 LA Correct Containers (per Method): Y N

Preservation: (circle) ICE DryICE ICEPacks None

Sample Conditions:

Sample Temp (C): ~4°C

Ambient Temp (C): 21°C

Sample Temp (C): _____

Filter Condition: _____

PH: _____

Components Sealed: Y N

Sample Recovery Completed On: (date & time) _____

Recovered In: (circle) Field Lab Other _____

Silica Gel Condition: _____

Tedlar Bags -

Condensation: Y N

Comments: B 154 - 1 mL

A 155 - 3 mL + Vial

Container(s) Requested: Glass _____ Plastic _____

Additional Comments:

CHROMATOGRAM
TEST SAMPLES

Title : SCAGMD Methods 25.x
 Run File : c:\star\data\2010\dec 10\12-21-2010_10:47:40_a 221 - 011 a dup.run
 Method File : c:\docume-1\user\locals-1\temp\~12-21-2010_07:18:49_lab air-2.tmp
 Sample ID : A 221 - 011 A dup

Injection Date: 12/21/2010 10:47 Calculation Date: 12/21/2010 11:06

Operator : Galina Detector Type: 0800 (10 volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-5588-d6b-21a1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	40.4315	2.340	0.027	967168	BB	5.3	
2	Methane	5.3570	2.780	0.040	130074	BB	5.7	
3	Carbon Dioxi	7544.5029	3.887	-0.053	189359184	BB	17.5	C
4	Ethane		8.326					N
5	NMOC	0.3601	12.927	0.374	8596	BB	10.8	
Totals:		7590.6515		0.388	190465022			

Status Codes:
 M - Missing peak
 C - Out of calibration range

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 1 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: -54 microVolts LSB: 1 microVolts

Noise (used): 224 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Calib. out of range; No Recovery Action Specified

Original Notes:

c98036 BP

Appended Notes:

c98036 BP


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\dec_10\12-21-2010, 10:47:40, a 221 - 011 a dup.run
Method File : c:\docume~1\user\locals-1\temp\~12-21-2010, 07:19:49, lab air-2.tmp
Sample ID : A 221 - 011 A dup

Injection Date: 12/21/2010 10:47 Calculation Date: 12/21/2010 11:06

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 4728 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAGMD Methods 25.x
 Run File : c:\star\data\2010\dec 10\12-21-2010, 10:18:33, A 221 - 011 a.run
 Method File : c:\docume~1\user\locals-1\temp\~12-21-2010, 07:18:49, lab air-2.tmp
 Sample ID : A 221 - 011 A

Injection Date: 12/21/2010 10:18 Calculation Date: 12/21/2010 11:06

Operator : Galina Detector Type: 0800 (10 Volts)
 Workstation: Bus Address : 38
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	41.1095	2.327	0.014	983386	BB	5.3	
2	Methane	5.3882	2.767	0.027	130832	BB	5.7	
3	Carbon Dioxi	7620.8599	3.873	-0.067	191275654	BB	17.7	C
4	Ethane		8.326					M
5	NMOC	0.3741	12.940	0.387	8931	BB	14.5	
Totals:		7667.7317		0.361	192398813			

Status Codes:

M - Missing peak

C - Out of calibration range

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 1 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: ~212 microVolts LSB: 1 microVolts

Noise (used): 407 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Calib. out of range: No Recovery Action Specified

Original Notes:

c9036 BP

Appended Notes:

c9036 BP


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\dec 10\12-21-2010, 10:19:33, a 221 - 011 a.run
Method File : c:\docume~1\user\locals-1\temp\12-21-2010, 07:18:49, lab air-2.tmp
Sample ID : A 221 - 011 A

Injection Date: 12/21/2010 10:19 Calculation Date: 12/21/2010 11:06

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3586-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 4728 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAGMD Methods 25.x
 Run File : c:\star\data\2010\dec_10\12-21-2010, 11:14:14, a 221 - 011 b.run
 Method File : c:\docume~1\user\local~1\temp\~12-21-2010, 07:18:49, lab air-2.tmp
 Sample ID : A 221 - 011 B

Injection Date: 12/21/2010 11:14 Calculation Date: 12/21/2010 11:35

Operator : Galina Detector Type: 0800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 * Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3585-d6b-21a1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	595.3341	2.313	0.000	14240828	BB	5.1	
2	Methane	27.3891	2.753	0.013	662611	BB	5.7	
3	Carbon Dioxi	8517.3428	3.833	-0.107	213776464	BB	19.7	C
4	Ethane		8.328					M
5	NMOC	0.2576	12.940	0.387	6149	BB	11.6	
Totals:		9140.2136		0.293	228686048			

Status Codes:

M - Missing peak

C - Out of calibration range

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 1 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: 43 microVolts LSB: 1 microVolts

Noise (used): 353 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Calib. out of range: No Recovery Action Specified

Original Notes:

c9036 BP

Appended Notes:

c9036 BP


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\dec_10\12-21-2010, 11:14:14, a 221 ~ 011 b.run
Method File : c:\docume~1\user\locals~1\temp\12-21-2010, 07:18:49, lab air-2.tmp
Sample ID : A 221 ~ 011 B

Injection Date: 12/21/2010 11:14 Calculation Date: 12/21/2010 11:35

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 4720 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCROWD Methods 25.x
 Run File : c:\star\data\2010\dec_10\12-21-2010, 11:38:32, a 221 - 011 b dup.run
 Method File : c:\documents-1\user\locals-1\temp\12-21-2010, 07:18:49, lab air-2.tmp
 Sample ID : A 221 - 011 B dup

Injection Date: 12/21/2010 11:38 Calculation Date: 12/21/2010 13:11

Operator : Galina Detector Type: 0800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 = Poreflush 10 Run Time : 15.015 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	594.1448	2.300	-0.013	14312617	BB	5.0	
2	Methane	25.1375	3.740	0.000	810368	BB	5.4	
3	Carbon Dioxi	8498.7549	3.820	-0.120	213259712	BB	19.6	C
4	Ethane		6.326					M
5	NMOC	0.2384	12.940	0.387	5691	BB	13.6	
Totals:		9116.2756		0.254	228088388			

Status Codes:
 M - Missing peak
 C - Out of calibration range

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 1 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: -54 microVolts LSE: 1 microVolts

Noise (used): 361 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Calib. out of range; No Recovery Action Specified

Original Notes:

c9036 BP

Appended Notes:

c9036 BP


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\dec_10\12-21-2010, 11:38:32, a 221 - 011 b dup.run
Method File : c:\docume~1\user\locals-1\temp\~12-21-2010, 07:18:49, lab air-2.tmp
Sample ID : A 221 - 011 B dup


Injection Date: 12/21/2010 11:38 Calculation Date: 12/21/2010 13:11

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 4728 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00





CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1


SAMPLE NO 8

REPORT NO 48

FILE 8
METHOD 41A221
-011A

S. K. M. S.

P<NO	TIME	AREA	NK	IDNO	CONC	NAME
1	3.79	8377282			35.2985	
2	5.984	182863			8.4333	
3	13.828	2839493			8.5917	
4	14.886	13218417	V		55.6845	
TOTAL		23738854			100	



CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1

SAMPLE NO 8

REPORT NO 179

FILE 8
METHOD 41A221
04A
slur

P<NO	TIME	AREA	NK	IDNO	CONC	NAME
1	3.787	8379111			35.526	
2	5.98	189914	V		8.466	
3	12.965	1955866			8.2891	
4	14.711	13141769	V		55.7188	
TOTAL		23585858			100	

5.939	<i>ca</i>	3.792
13	<i>a</i>	14.711

CHROMATOGRAM 1 MEMORIZED

A221
-021B

C-R5A CHROMATOPAC

CHANNEL NO 1

FILE 0

SAMPLE NO 0

METHOD 41

REPORT NO 100

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.792	8193966			35.4436	
2	5.939	193954			0.839	
3	13	1048742			4.5364	
4	14.711	13681681	Y		59.1811	
TOTAL		29116344			100	

5.917	<i>ca</i>	3.779
12.944	<i>ca</i>	14.653

A221
021B
dup

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1

FILE 0

SAMPLE NO 0

METHOD 41

REPORT NO 101

PKNO	TIME	AREA	MK	IDNO	CONC	NAME
1	3.779	8137284			35.4388	
2	5.917	193711			0.8436	
3	12.944	1038693			4.5236	
4	14.653	13591836	Y		59.194	
TOTAL		22961522			100	

051
22-0007-01

QAQC

Title : SCAGMD Methods 25.x
 Run File : c:\star\data\2010\dec_10\12-21-2010_07:18:49_lab air.run
 Method File : c:\docume~1\user\locals~1\temp\~12-21-2010_07:18:49_lab air-2.tmp
 Sample ID : Lab Air

Injection Date: 12/21/2010 07:18 Calculation Date: 12/21/2010 07:48

Operator : Geline Detector Type: 0800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21a1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	4.3486	2.300	-0.013	104024	BB	6.8	
2	Methane	1.8073	2.740	0.000	43883	BB	5.5	
3	Carbon Dioxi	542.8745	3.853	0.013	13625585	BB	9.1	
4	Ethane		8.326					M
5	NMOC		12.553					M
Totals:		543.0304		0.000	13773492			

Status Codes:
 M - Missing peak

Total Unidentified Counts : 0 counts

Detected Peaks: 15 Rejected Peaks: 12 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: 41 microVolts LSB: 1 microVolts

Noise (used): 67 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


111111 : SCRAMO METHODS 25.X
Run File : c:\star\data\2010\dec_10\12-21-2010, 07:18:49, lab air.run
Method File : c:\docume~1\user\locals~1\temp\~12-21-2010, 07:18:49, lab air-2.tmp
Sample ID : Lab Air

Injection Date: 12/21/2010 07:18 Calculation Date: 12/21/2010 07:48

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 654 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAGMD Methods 25.*
 Run File : c:\star\data\2010\dec_10\12-21-2010_07:50:18_n2 blank 39.run
 Method File : c:\docume-1\user\locals-1\temp\12-21-2010_07:18:49_lab air-2.tmp
 Sample ID : N2 Blank 39

Injection Date: 12/21/2010 07:50 Calculation Date: 12/21/2010 08:20

Operator : Galina Detector Type: DB00 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00288-3588-d6b-21e1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	0.4620	2.327	0.014	11051	BB	6.0	
2	Methane		2.740					M
3	Carbon Dioxi	0.7915	3.993	0.053	19866	BB	9.6	
4	Ethane		8.326					M
5	EMOC		12.553					M
Totals:		1.2535		0.067	30917			

Status Codes:
 M - Missing peak

Total Unidentified Counts : 0 counts

Detected Peaks: 9 Rejected Peaks: 7 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: -216 microVolts LSS: 1 microVolts

Noise (used): 83 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


Title : STAR200 Methods 25.X
Run File : c:\star\data\2010\dec_10\12-21-2010, 07:50:18, n2 blank 39.run
Method File : c:\docume~1\user\locals-1\temp\~12-21-2010, 07:18:49, lab air-2.tmp
Sample ID : N2 Blank 39

Injection Date: 12/21/2010 07:50 Calculation Date: 12/21/2010 08:20

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 2 Zero Offset = 15%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAQMD Methods 25.x
 Run File : c:\star\data\2010\dec_10\12-21-2010, 08:22:11, 20ppm mix.run
 Method File : c:\docume~1\user\locals~1\comp\~12-21-2010, 07:18:49, lab mix-2.tmp
 Sample ID : 20ppm mix

Injection Date: 12/21/2010 08:22 Calculation Date: 12/21/2010 08:43

Operator : Galina Detector Type: 0800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21a1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	20.5529	2.327	0.014	491648	BB	5.3	
2	Methana	20.9013	2.767	0.027	507507	BB	5.9	
3	Carbon Dioxi	23.1927	3.980	0.040	582113	BB	9.3	
4	Ethane	20.3467	8.383	0.067	508184	BB	23.2	
5	NMOC	32.2406	12.180	-0.373	769608	BB	18.3	
Totals:		117.2342		-0.225	2859060			

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: -272 microVolts LSE: 1 microVolts

Noise (used): 265 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


FILE : SCAMM Methods 25.x
Run File : c:\star\data\2010\dec_10\12-21-2010, 08:22:11, 20ppm mix.run
Method File : c:\docume-1\user\locals-1\temp\12-21-2010, 07:18:49, lab sir-2.tmp
Sample ID : 20ppm mix

Injection Date: 12/21/2010 08:22 Calculation Date: 12/21/2010 08:43

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 41 Zero Offset = 24
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCQMS Methods 25.x
 Run File : c:\star\data\2010\dec_10\12-21-2010_08:50:10_20ppm mix.run
 Method File : c:\docume~1\user\locals~1\temp\12-21-2010_07:18:49_lab air-2.tmp
 Sample ID : 20ppm mix

Injection Date: 12/21/2010 08:30 Calculation Date: 12/21/2010 08:15

Operator : Galina Detector Type: Q800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21a1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	20.4965	2.313	0.000	480300	BB	5.3	
2	Methane	20.9867	2.753	0.013	508580	BB	5.9	
3	Carbon Dioxi	20.2355	3.967	0.027	507851	BB	9.3	
4	Ethane	19.7120	6.433	0.107	492331	BB	23.5	
5	NMOC	33.0553	12.167	-0.386	789055	BB	18.6	
Totals:		114.4860		-0.239	2789157			

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: -201 microVolts LSE: 1 microVolts

Noise (used): 171 microVolts ~ monitored before this run

Stream: 1 Injection Number: 2 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\dec_10\12-21-2010, 08:50:10, 20ppm mix.run
Method File : c:\docume-1\user\locals-1\temp\~12-21-2010, 07:18:49, lab air-2.tmp
Sample ID : 20ppm mix

Injection Date: 12/21/2010 08:50 Calculation Date: 12/21/2010 09:15

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21a1 **

Chart Speed = 1.33 cm/min Attenuation = 41 Zero Offset = 38
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCQMD Methods 25.x
 Run File : c:\star\data\2010\dec_10\12-21-2010, 09:21:33, n2 blank 34.run
 Method File : C:\star\smoc.mth
 Sample ID : N2 Blank 34

Injection Date: 12/21/2010 09:21 Calculation Date: 12/21/2010 09:36

Operator : Galina Detector Type: 0800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00298-3588-d6b-21e1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	0.4699	2.327	0.014	11240	BB	6.1	
2	Methane		2.740					M
3	Carbon Dioxi	0.8593	3.993	0.053	21566	BB	10.7	
4	Ethane		8.326					M
5	NMOC		12.553					M
Totals:		1.3291		0.067	32806			

Status Codes:
 M - Missing peak

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 4 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: -136 microVolts LSS: 1 microVolts

Noise (used): 179 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Original Notes:


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\dec_10\12-21-2010, 09:21:33, n2 blank 34.run
Method File : C:\star\nmcc.mth
Sample ID : N2 Blank 34

Injection Date: 12/21/2010 09:21 Calculation Date: 12/21/2010 09:36

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 1 Zero Offset = 17%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCRAMD Methods 25.x
 Run File : c:\star\data\2010\dec_10\12-21-2010, 17:29:08, 20 ppm mix.run
 Method File : c:\docume~1\user\locals~1\temp\~12-21-2010, 17:29:08, 20 ppm mix-2.tmp
 Sample ID : 20 ppm mix

Injection Date: 12/21/2010 17:29 Calculation Date: 12/21/2010 17:56

Operator : Galina Detector Type: Q800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21s1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	20.6555	2.340	0.027	494128	SS	3.2	
2	Methane	21.4582	2.767	0.027	521054	SS	3.3	
3	Carbon Dioxi	27.4151	3.980	0.040	888117	SS	9.2	
4	Ethane	20.8621	8.407	0.081	523554	SS	33.4	
5	NMOC	35.8610	12.193	-0.360	856029	SS	18.2	
Totals:		136.3549		-0.195	3082862			

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: -228 microVolts LSB: 1 microVolts

Noise (used): 349 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


File : SCAMM Methods 25.x
Run File : c:\star\data\2010\dec_10\12-21-2010, 17:29:08, 20 ppm mix.run
Method File : c:\docume~1\user\locals~1\temp\12-21-2010, 17:29:08, 20 ppm mix-2.tmp
Sample ID : 20 ppm mix

Injection Date: 12/21/2010 17:29 Calculation Date: 12/21/2010 17:56

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 41 Zero Offset = 3%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAGMD Methods 28.x
 Run File : c:\star\data\2010\dec_10\12-21-2010_17:57:03_20 ppm mix.run
 Method File : c:\dscuma-1\user\locals-1\temp\12-21-2010_17:29:08_20 ppm mix-2.tmp
 Sample ID : 20 ppm mix

Injection Date: 12/21/2010 17:57 Calculation Date: 12/21/2010 18:21

Operator : Galina Detector Type: 0890 (10 volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 8.00 ** 00299-3588-45b-21a1 **

Run Mode : Analysis
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result (ppmC)	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	20.9419	2.313	0.000	500953	BB	5.3	
2	Methane	21.4336	2.740	0.000	520432	BB	8.8	
3	Carbon Dioxi	21.6526	3.987	0.027	543458	BB	9.2	
4	Ethane	20.3833	8.407	0.081	509346	BB	23.5	
5	NMOC	36.7214	12.187	-0.386	876366	BB	18.4	
Totals:		121.1428		-0.276	2950755			

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: 1 Divisor: 1 Unidentified Peak Factor: 0

Baseline Offset: -119 microVolts LSS: 1 microVolts

Noise (used): 224 microVolts - monitored before this run

Stream: 1 Injection Number: 2 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\dec_10\12-21-2010, 17:57:03, 20 ppm mix.run
Method File : c:\docume~1\user\locals~1\temp\~12-21-2010, 17:29:08, 20 ppm mix-2.tmp
Sample ID : 20 ppm mix

Injection Date: 12/21/2010 17:57 Calculation Date: 12/21/2010 18:21


Operator : Galina Detector Type: 5800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 42 Zero Offset = 3%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



22/22



CHROMATOGRAM 1. MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1


FILE 0

SAMPLE NO 0

METHOD 41

REPORT NO 169

PKNO	TIME	AREA	NK	IDNO	CONC	NAME
1	3.884	8765262			35.7319	
2	13.874	4892854			16.6847	
3	14.94	11672518	V		47.5834	
TOTAL		24538634			100	



CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1

FILE 0


SAMPLE NO 0

METHOD 41

REPORT NO 178

PKNO	TIME	AREA	NK	IDNO	CONC	NAME
1	3.8	8702758			35.4317	
2	13.871	4888458			16.6454	
3	14.96	11694654	V		47.6127	
4	38.388	76180			0.3182	
TOTAL		24562048			100	

047



223-02037-01

CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC


CHANNEL NO 1

SAMPLE NO 0

REPORT NO 171

FILE 0
METHOD 41

PKNO	TIME	AREA	HK	IDNO	CONC	NAME
1	3.729	6791073			29.3395	
2	4.16	986857	V		4.2635	
3	5.544	902502			3.8991	
4	12.965	834943			3.6872	
5	14.877	18761300	V		46.492	
6	25.703	2869864			12.3987	
TOTAL		23146536			100	



CHROMATOGRAM 1 MEMORIZED

C-R5A CHROMATOPAC

CHANNEL NO 1


SAMPLE NO 0

REPORT NO 172

FILE 0
METHOD 41

PKNO	TIME	AREA	HK	IDNO	CONC	NAME
1	3.729	6764650			29.2184	
2	4.161	995326	V		4.2979	
3	5.543	910070	V		3.9290	
4	12.956	811819			3.5855	
5	14.874	18791646	V		46.5994	
6	25.708	2884816			12.4569	
TOTAL		23158326			100	

TOC ANALYSIS
on the TRAPS




TIME [min]

SAMPLE# 8 TC
 [x 1, 42µl, C# 7, #WASH 2, SP 0min]
 # AREA ppm C# µl R#
 1-22961 18.01
 2-19233 8.418
 3 16898 7.412
 + 4 16143 7.085
 + 5 14788 6.461

 MN 15934 6.986
 SD 1865 8.483
 CU 6.68 %
 COR CONC DIL 6.986 [x 1.0]
 COR CONC INJ 6.986 [x 1.0]

DATE 12(DEC)-20-2010 16:48




TIME [min]

SAMPLE# 9 TC
 [x 1, 42µl, C# 7, #WASH 2, SP 0min]
 # AREA ppm C# µl R#
 1 33689 14.68
 2-26798 11.65
 3 29326 12.73
 + 4 31726 13.76

 MN 31588 13.69
 SD 2185 8.934
 CU 6.91 %
 COR CONC DIL 13.69 [x 1.0]
 COR CONC INJ 13.69 [x 1.0]

DATE 12(DEC)-20-2010 17:15




TIME [min]

SAMPLE# 8 IC
 [x 1, 53µl, C# 8, #WASH 2, SP 0min]
 # AREA ppm C# µl R#
 1 4688 1.268
 2 4668 1.277
 3 4395 1.192

 MN 4554 1.243
 SD 148 0.844
 CU 3.88 %
 COR CONC DIL 1.243 [x 1.0]
 COR CONC INJ 1.243 [x 1.0]

SAMPLE# 8 TOC(TC-IC) 5.743 ppm

DATE 12(DEC)-20-2010 16:59



TIME [min]

SAMPLE# 9 IC
 [x 1, 53µl, C# 8, #WASH 2, SP 0min]
 # AREA ppm C# µl R#
 1-44971 14.67 H
 2 4914 13.37 6
 3 4831 13.18
 4 4728 12.94

 MN 4824 13.16
 SD 93 0.214
 CU 1.93 %
 COR CONC DIL 13.16 [x 1.0]
 COR CONC INJ 13.16 [x 1.0]

SAMPLE# 9 TOC(TC-IC) 8.538 ppm

DATE 12(DEC)-20-2010 17:25

Almega Environmental Technical Services

SCAQMD Method 25.3
TOC Analysis on the Trap

Calibration Curve No.:

TC


IC

Page: # 195

No	Sample ID	Date	Sample Volume, ml		Dilution Factor	Concentration, ppmC		
			Initial	Final		TC	IC	TOC
1	Blank	12/20	—	—	1	.068	.044	.024
2	TESL		—	—	1	12.11	.158	11.92
3	TESL		—	—	1	14.94	13.56	—
4	LCS		—	—	1	15.88	.291	15.58
5	Blank		—	—	1	.135	.061	.074
108 6	A220 -012A		2	4	2	15.02	14.35	1.670
109 7	-012B		2	4	2	28.08	19.84	5.248
154 8	A221 -012A		2	4	2	6.986	1.243	5.743
155 9	-012B		3	4	1.33	13.69	13.16	.530
101 10	A218 072A		4	4	1	9.109	5.485	3.624
102 11	072B		4	4	1	6.308	3.436	2.869
107 12	082A		4	4	1	5.876	3.853	1.823
108 13	082B		4	4	1	5.241	3.442	1.769
14 14	122A		4	4	1	13.40	10.89	2.570
15 15	122B		4	4	1	13.73	10.17	3.560
16	LCS		—	—	1	26.86	1.691	25.16
17								
18								
19								
20								
21								

Comments

Checked by: _____




TIME [min]

SAMPLE# 1 TC
 [x 1, 42µl, C# 7, #WASH 2, SP 0min]
 # AREA ppm C# µl RG
 1- 3467 1.2371
 2- 2375 0.717
 3 968 0.046
 + 4 1010 0.070
 + 5 1057 0.008

 MN 1014 0.068
 SD 44 0.021
 CV 4.39 %
 COR CONC DIL 0.068 [x 1.0]
 COR CONC INJ 0.068 [x 1.0]

DATE 12(DEC)-20-2010 14:01




TIME [min]

SAMPLE# 1 IC
 [x 1, 53µl, C# 8, #WASH 2, SP 0min]
 # AREA ppm C# µl RG
 1 787 0.047
 2 843 0.065
 3 782 0.020

 MN 777 0.044
 SD 70 0.022
 CV 9.13 %
 COR CONC DIL 0.044 [x 1.0]
 COR CONC INJ 0.044 [x 1.0]

SAMPLE# 1 TOC(TC-IC) 0.024 ppm

DATE 12(DEC)-20-2010 14:12




TIME [min]

SAMPLE# 2 TC
 [x 1, 42µl, C# 7, #WASH 2, SP 0min]
 # AREA ppm C# µl RG
 1-25800 11.26
 2 27500 11.99
 3 28520 12.30
 + 4 27690 12.03

 MN 27871 12.11
 SD 399 0.170
 CV 1.43 %
 COR CONC DIL 12.11 [x 1.0]
 COR CONC INJ 12.11 [x 1.0]

DATE 12(DEC)-20-2010 13:13




TIME [min]

SAMPLE# 2 IC
 [x 1, 53µl, C# 8, #WASH 2, SP 0min]
 # AREA ppm C# µl RG
 1 1109 0.149
 2 1275 0.202
 3- 1676 0.329
 + 4 1309 0.213

 MN 1231 0.180
 SD 107 0.034
 CV 8.69 %
 COR CONC DIL 0.180 [x 1.0]
 COR CONC INJ 0.180 [x 1.0]

SAMPLE# 2 TOC(TC-IC) 11.92 ppm

DATE 12(DEC)-20-2010 13:42




TIME [min]

SAMPLE# 3 TC
 [x 1, 42µl, C# 7, #WASH 2, SP 0min]
 # AREA PPM C# µl RG
 1-29584 12.84
 2 34015 14.74
 3 34678 15.02
 + 4 34791 15.07

 MN 34494 14.94
 SD 419 0.179
 CV 1.21 %
 COR CONC DIL 14.94 [x 1.0]
 COR CONC INJ 14.94 [x 1.0]

DATE 12(DEC)-20-2010 14:28




TIME [min]

SAMPLE# 4 TC
 [x 1, 42µl, C# 7, #WASH 2, SP 0min]
 # AREA PPM C# µl RG
 1-35074 15.47
 2 37695 16.31
 3 36423 15.77
 + 4 35947 15.56

 MN 36688 15.88
 SD 983 0.386
 CV 2.46 %
 COR CONC DIL 15.88 [x 1.0]
 COR CONC INJ 15.88 [x 1.0]

DATE 12(DEC)-20-2010 14:55




TIME [min]

SAMPLE# 3 IC
 [x 1, 53µl, C# 8, #WASH 2, SP 0min]
 # AREA PPM C# µl RG
 1-42176 13.73 H
 2 4981 13.52 6
 3 5006 13.58
 4 5002 13.57

 MN 4996 13.56
 SD 13 0.031
 CV 0.26 %
 COR CONC DIL 13.56 [x 1.0]
 COR CONC INJ 13.56 [x 1.0]

SAMPLE# 3 TOC(TC-IC) 1.390 PPM

DATE 12(DEC)-20-2010 14:39




TIME [min]

SAMPLE# 4 IC
 [x 1, 53µl, C# 8, #WASH 2, SP 0min]
 # AREA PPM C# µl RG
 1- 1101 0.147
 2 1628 0.311
 3 1524 0.281
 + 4 1523 0.281

 MN 1555 0.291
 SD 55 0.017
 CV 3.58 %
 COR CONC DIL 0.291 [x 1.0]
 COR CONC INJ 0.291 [x 1.0]

SAMPLE# 4 TOC(TC-IC) 15.58 PPM

DATE 12(DEC)-20-2010 15:05



TIME [min]

SAMPLE# 5 TC
 [x 1, 42A1, C# 7, #WASH 2, SP 0min]
 # AREA ppm C# A1 RG
 1- 6517 2.677T
 2 1063 0.091
 3 1197 0.155
 + 4 1207 0.160


 MN 1155 0.135
 SD 80 0.038
 CV 6.95 %
 COR CONC DIL 0.135 [x 1.0]
 COR CONC INJ 0.135 [x 1.0]

DATE 12(DEC)-20-2010 15:19

TOC-5000 DATA REPORT
 DATE 12(DEC)-20-2010 21:04

SPL#	TC, ppm	RMK	IC, ppm	RMK	TDC, ppm
1	0.068	7****	0.044	8****	0.024
2	12.11	7****	0.188	8****	11.92
3	14.94	7****	13.56	6****	1.388
4	15.08	7****	0.291	8****	15.58
5	0.135	7****	0.061	8****	0.074
6	16.02	7****	14.35	6****	1.670
7	25.08	5****	19.84	6****	5.240
8	6.986	7****	1.243	8****	5.743
9	13.69	7****	13.16	6****	0.530
10	9.109	7****	5.405	8****	3.624
11	6.305	7****	3.436	8****	2.869
12	5.676	7****	3.853	8****	1.823
13	5.241	7****	3.472	8****	1.769
14	13.40	7****	10.09	8****	2.510
15	13.73	7****	10.17	8****	3.560
16	26.86	5****	1.691	8****	25.16

ANALYST :
 SAMPLE :




TIME [min]

SAMPLE# 5 IC
 [x 1, 53A1, C# 8, #WASH 2, SP 0min]
 # AREA ppm C# A1 RG
 1 839 0.063
 2- 655 0.005
 3 013 0.055
 + 4 044 0.065

 MN 832 0.061
 SD 16 0.005
 CV 2.0 %
 COR CONC DIL 0.061 [x 1.0]
 COR CONC INJ 0.061 [x 1.0]

SAMPLE# 5 TOC(TC-IC) 0.074 ppm

DATE 12(DEC)-20-2010 15:31




SAMPLE# 16 TC
 [x 1, 42µl, C# 7, #WASH 2, SP 0min]

#	AREA	PPM	C#	µl	RG
1	53666	23.14TH			
2	6558	27.89	5		
3	6545	27.83			
4	6487	26.45			

MN 6583 26.86
 SD 83 0.351
 CU 1.28 %
 COR CONC DIL 26.86 [x 1.0]
 COR CONC INJ 26.86 [x 1.0]

DATE 12(DEC)-20-2010 20:55



TIME [min]
 SAMPLE# 16 IC
 [x 1, 53µl, C# 8, #WASH 2, SP 0min]

#	AREA	PPM	C#	µl	RG
1	5815	1.643			
2	6312	1.881			
3	5767	1.628			

MN 5964 1.691
 SD 381 0.895
 CU 5.05 %
 COR CONC DIL 1.691 [x 1.0]
 COR CONC INJ 1.691 [x 1.0]

SAMPLE# 16 TOC(TC-IC) 25.16 ppm

DATE 12(DEC)-20-2010 21:04

TANK PREPARATION

TANK PREPARATIONS

Client: BP Lab No.: A 221
 Project No.: c9036
 Unit Tested: TGU #2
 Sampling Date: 16-Dec-10
 Date pressurized: 16-Dec-10

Tank ID	Sample ID	Pre-test pressure mm Hg		Post-test pressure mm Hg	Final Pressure	Comments
		1	2			
A 119	A 221 - 011 A	-760	-760	-182 *	170	Run #1 A
A2	A 221 - 011 B	-760	-760	-158 *	166	Run #1 B

* - Post -test Pressure is less then 200 mm Hg.

CALIBRATIONS

28-Sep-10
Current

	100 ppm mix					1000 ppm mix					10000 ppm mix					Ave	RSD
	conc	area 1	area 2	RF 1	RF 2	conc	area 1	area 2	RF 1	RF 2	conc	area 1	area 2	RF 1	RF 2		
Carbon Monoxide	98.6	2495559	2489559	3.99E-05	4.01E-05	1007	24985054	25333468	4.03E-05	3.99E-05	1984	45244456	49219680	4.39E-05	4.03E-05	4.07E-05	
Methane	102.4	2547658	2542384	4.02E-05	4.03E-05	1017	25244622	24999134	3.94E-05	3.91E-05	2072	46688044	50873792	4.33E-05	3.98E-05	4.03E-05	
Carbon Dioxide	109.5	2671168	2656793	4.10E-05	4.12E-05	1004	26881684	26518945	3.78E-05	3.79E-05	2006	47892776	52193728	4.19E-05	3.84E-05	3.97E-05	
Ethane	102.9	2661568	2646777	3.87E-05	3.89E-05	1014	26703788	26659332	3.80E-05	3.80E-05	2034	48093788	52482794	4.21E-05	3.86E-05	3.90E-05	
TCBMEO	101.2	2514039	2527613	4.03E-05	4.00E-05	1012	25557582	25464488	3.94E-05	3.97E-05	2038	45999992	49876556	4.39E-05	4.04E-05	4.07E-05	
Average		2598656	2573492	4.00E-05	4.01E-05	Average	39939506	28975116	3.98E-05	3.89E-05	Average	46723641	50863376	4.30E-05	3.95E-05		
RSD%				4.01E-05	4.1				3.90E-05	3.5				4.13E-05	3.7		

RSD %	
RSD _{CO} %	2.641
RSD _{CH₄} %	2.785
RSD _{CO₂} %	3.563
RSD _{C₂H₆} %	6.412
RSD _{TCBMEO} %	2.629


45

Carbon Monoxide

External Standard Analysis
 Curve Type: Linear
 Origin: Force

Resp. Fact. RSD: 2.641%
 Coeff. Det.(r²): 0.995209

$$y = +2.403887e+004x$$




Methane

External Standard Analysis
 Curve Type: Linear
 Origin: Force

Resp. Fact. RSD: 2.785%
 Coeff. Det.(r²): 0.995849

$$y = +2.439119e+004x$$




Carbon Dioxide

External Standard Analysis
 Curve Type: Linear
 Origin: Force

Resp. Fact. RSD: 3.563%
 Coeff. Det.(r²): 0.995712

$$y = +2.524946e+004x$$



Ethane

External Standard Analysis


Curve Type: Linear

Origin: Force

y = +2.512665e+004x

Resp. Fact. RSD: 3.188%

Coeff. Det.(r²): 0.995719



NMOC

External Standard Analysis


Curve Type: Linear

Origin: Force

y = +2.404997e+004x

Resp. Fact. RSD: 3.425%

Coeff. Det.(r²): 0.995809



Title : SCAQMD Methods 25.x
 Run File : c:\star\data\2010\sept_10\9-28-2010_09:38:00_100ppm mix.run
 Method File : c:\docume~1\user\locals~1\temp\~nmoc.tmp
 Sample ID : 100ppm mix

Injection Date: 9/28/2010 09:38 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21a1 **

Run Mode : Calibration
 Peak Measurement: Peak Area
 Calculation Type: External Standard
 Level : 3

Peak No.	Peak Name	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	2.340	0.027	2495959	BB	5.1	
2	Methane	2.767	0.014	2347858	BB	5.8	
3	Carbon Dioxi	3.980	0.014	2671168	BB	9.2	
4	Ethane	6.393	0.000	2551568	BB	23.4	
5	NMOC	12.567	0.014	2514029	BB	18.8	
Totals:			0.069	12890582			

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: N/A Divisor: N/A Unidentified Peak Factor: 0

Baseline Offset: -148 microVolts LSB: 1 microVolts

Noise (used): 198 microVolts ~ monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010, 09:38:00, 100ppm mix.run
Method File : c:\docume-1\user\locals-1\temp\~nmoc.tmp
Sample ID : 100ppm mix

Injection Date: 9/28/2010 09:38 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 212 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAQMD Methods 25.x
 Run File : c:\star\data\2010\sept_10\9-28-2010_10:02:52_100ppm mix.run
 Method File : c:\docume~1\user\locals-1\temp\~nmoc.tmp
 Sample ID : 100ppm mix

Injection Date: 9/28/2010 10:02 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Run Mode : Calibration
 Peak Measurement: Peak Area
 Calculation Type: External Standard
 Level : 3

Peak No.	Peak Name	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	2.340	0.000	2489550	BB	5.1	
2	Methane	2.780	0.014	2542584	BB	5.8	
3	Carbon Dioxid	3.980	0.000	2656993	BB	9.2	
4	Ethane	8.420	0.027	2646777	BB	23.5	
5	NMOC	12.580	0.014	2527613	BB	18.9	
Totals:			0.055	12863517			

Total Unidentified Counts : 0 counts

Detected Peaks: 5 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: N/A Divisor: N/A Unidentified Peak Factor: 0

Baseline Offset: -166 microVolts LSB: 1 microVolts

Noise (used): 401 microVolts - monitored before this run

Stream: 1 Injection Number: 2 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010, 10:02:52, 100ppm mix.run
Method File : c:\docume~1\user\locals~1\temp\~nmoc.tmp
Sample ID : 100ppm mix

Injection Date: 9/28/2010 10:02 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 212 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010_10:31:41_1000ppm mix.run
Method File : c:\docume-1\user\local3-1\temp\nmcc.tmp
Sample ID : 1000ppm mix

Injection Date: 9/28/2010 10:31 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00288-3588-d6b-21e1 **

Run Mode : Calibration
Peak Measurement: Peak Area
Calculation Type: External Standard
Level : 2

Peak No.	Peak Name	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	2.353	0.013	24980054	BB	5.0	
2	Methane	2.780	0.000	25844622	BB	5.7	
3	Carbon Dioxi	3.993	0.013	26581484	BB	9.1	
4		6.437	0.000	53260	BB	15.4	
5	Ethane	8.433	0.013	26703788	BB	23.5	
6	NMOC	12.580	0.000	25587582	BB	19.0	
Totals:			0.039	129750790			

Total Unidentified Counts : 53260 counts

Detected Peaks: 6 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: N/A Divisor: N/A Unidentified Peak Factor: 0

Baseline Offset: 18 microVolts LSB: 1 microVolts

Noise (used): 184 microVolts ~ monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010, 10:31:41, 1000ppm mix.run
Method File : c:\docume~1\user\locals~1\temp\nmoc.tmp
Sample ID : 1000ppm mix

Injection Date: 9/28/2010 10:31 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 2170 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAGMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010, 10:58:48, 1000ppm mix.run
Method File : c:\documa-1\user\locals-1\temp\~nmoc.tmp
Sample ID : 1000ppm mix

Injection Date: 9/28/2010 10:58 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 - Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 5.00 ** 00299-3588-d6b-21a1 **

Run Mode : Calibration
Peak Measurement: Peak Area
Calculation Type: External Standard
Level : 2

Peak No.	Peak Name	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	2.313	-0.013	25233440	BB	5.1	
2	Methane	2.753	0.000	25989354	BB	5.8	
3	Carbon Dioxi	3.967	0.001	26518842	BB	9.2	
4		6.417	0.000	55944	BB	16.6	
5	Ethane	8.407	-0.013	26659332	BB	23.6	
6	NMOC	12.553	-0.013	25464480	BB	19.2	
Totals:			-0.038	129931492			

Total Unidentified Counts : 55944 counts

Detected Peaks: 6 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: N/A Divisor: N/A Unidentified Peak Factor: 0

Baseline Offset: -318 microVolts LSB: 1 microVolts

Noise (used): 281 microVolts ~ monitored before this run

Stream: 1 Injection Number: 2 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010, 10:58:48, 1000ppm mix.run
Method File : c:\docume-1\user\locals-1\temp\nmcc.tmp
Sample ID : 1000ppm mix

Injection Date: 9/28/2010 10:58 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 5.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 2167 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Print Date: Tue Sep 28 12:11:39 2010

Page 1 of 1

Title : SCAGMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010_11:23:08_2000 ppm mix.run
Method File : c:\docume~1\user\locals~1\temp\nmcc.tmp
Sample ID : 2000 ppm mix

Injection Date: 9/28/2010 11:23 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Run Mode : Calibration
Peak Measurement: Peak Area
Calculation Type: External Standard
Level : 1

Peak No.	Peak Name	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	2.313	0.000	45244455	BB	5.1	
2	Methane	2.753	0.000	45888044	BB	5.7	
3	Carbon Dioxi	3.967	0.001	47892276	BB	9.2	
4		6.413	0.000	98412	BB	16.2	
5	Ethane	8.393	-0.013	48093788	BB	23.5	
6	NMOC	12.553	0.000	45699692	BB	19.3	
Totals:			-0.013	233716668			

Total Unidentified Counts : 98412 counts

Detected Peaks: 6 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: N/A Divisor: N/A Unidentified Peak Factor: 0

Baseline Offset: 10 microVolts LSS: 1 microVolts

Noise (used): 244 microVolts - monitored before this run

Stream: 1 Injection Number: 1 Sampling Time: 0.00 min

Original Notes:

Appended Notes:


Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010, 11:23:08, 2000 ppm mix.run
Method File : c:\docume~1\user\locals~1\temp\~nmoc.tmp
Sample ID : 2000 ppm mix

Injection Date: 9/28/2010 11:23 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 3965 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00



Title : SCAQMD Methods 25.x
 Run File : c:\star\data\2010\sept_10\9-28-2010_11:51:21_2000 ppm mix.run
 Method File : c:\docume~1\user\locals~1\temp\~nmoc.tmp
 Sample ID : 2000 ppm mix

Injection Date: 9/28/2010 11:51 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: O800 (10 Volts)
 Workstation: Bus Address : 88
 Instrument : Varian Star #1 Sample Rate : 1.25 Hz
 Channel : 2 = Forcflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 8.00 ** 00289-3588-d4b-21e1 **

Run Mode : Calibration
 Peak Measurement: Peak Area
 Calculation Type: External Standard
 Level : 1

Peak No.	Peak Name	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	Carbon Monox	2.327	-0.026	45219600	BB	5.1	
2	Methane	2.753	-0.027	50823782	BB	5.8	
3	Carbon Dioxi	3.967	-0.026	52193728	BB	9.2	
4		6.429	0.000	108723	BB	16.2	
5	Ethane	8.420	-0.013	52402704	BB	23.6	
6	NMOC	12.557	-0.013	49676586	BB	19.4	
Totals:			-0.105	254425103			

Total Unidentified Counts : 108723 counts

Detected Peaks: 6 Rejected Peaks: 0 Identified Peaks: 5

Multiplier: N/A Divisor: N/A Unidentified Peak Factor: 0

Baseline Offset: -155 microVolts LSB: 1 microVolts

Noise (used): 212 microVolts - monitored before this run

Stream: 1 Injection Number: 2 Sampling Time: 0.00 min

Original Notes:

Appended Notes:

Title : SCAQMD Methods 25.x
Run File : c:\star\data\2010\sept_10\9-28-2010, 11:51:21, 2000 ppm mix.run
Method File : c:\docume~1\user\locals~1\temp\~nmoc.tmp
Sample ID : 2000 ppm mix

Injection Date: 9/28/2010 11:51 Calculation Date: 9/28/2010 12:10

Operator : Galina Detector Type: 0800 (10 Volts)
Workstation: Bus Address : 88
Instrument : Varian Star #1 Sample Rate : 1.25 Hz
Channel : 2 = Foreflush 10 Run Time : 15.013 min

** Star Chromatography Workstation Version 6.00 ** 00299-3588-d6b-21e1 **

Chart Speed = 1.33 cm/min Attenuation = 4205 Zero Offset = 2%
Start Time = 0.000 min End Time = 15.013 min Min / Tick = 1.00

