

9.5.3

Meat Rendering Plants

Compliance emissions testing of the Supercooker
at IBP, Inc. Dakota City, NE

TRC Environmental Corporation for IBP, Inc.

July 1998

1998 (post section publication) source
test data.

Note: This material is related to a section in AP42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the file number, the AP42 chapter and then the section. The file name "rel01_c01s02.pdf" would mean the file relates to AP42 chapter 1 section 2. The document may be out of date and related to a previous version of the section. The document has been saved for archival and historical purposes. The primary source should always be checked. If current related information is available, it will be posted on the AP42 webpage with the current version of the section.



September 21, 1998

Mr. Dave Meierhenry
Air Quality Compliance Section
Nebraska Department of Environmental Quality
P. O. Box 98922
Lincoln, NE 68509-8922

RE: IBP, inc., Dakota City, Nebraska
Inedible Cooking System VOC, SOx, NOx, CO and PM Test Report

Dear Mr. Meierhenry:

Please find enclosed a copy of the Test Report for VOC, SOx, NOx, CO and PM testing conducted at the IBP Dakota City facility. The testing was conducted on July 22, 1998 by TRC Environmental Corporation. VOC, SOx, NOx, CO and PM testing was completed per the Nebraska Compliance Sampling Methods and was approved through protocol submittals.

If you have any questions concerning the testing results or procedures used, please contact me at 402-241-3647 or you may contact Mr. Scott Miller, TRC Project Manager, at 630-810-1122.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Rechelle Kruse'.

Rechelle Kruse
Air Pollution Control Engineer

c: Tom Trosper (w/o test report)
Angela Gogel (w/test report)
Dallas Seifert (w/test report)

RK98-574/DC-Stack Test

Summary:

IBP created a project to quantify VOC emissions from their rendering processes including blood dryers, edible dryers, and inedible cookers for both beef and pork. The testing was conducted on all three systems under various heating conditions. The intent was to quantify VOC emissions for natural gas system as well as steam systems and to prove or disprove the difference in VOCs from products developed in fuel fired vs. steam heated processes.

VOC, SO_x, NO_x, CO, and PM data was obtained at the outlet of the first packed bed. Testing was conducted at the outlet of the first packed bed due to previous problems in September 1997 sampling at the outlet of the condenser. SO_x, NO_x, and CO data were also obtained at the outlet of the condenser prior to the first packed bed as well.

Emission Data:

Inedible Steam Cooker

Test Data Outlet of Condenser

	VOC	SO _x	NO _x	CO	PM
Test #1	No data taken	0.0562	0.0143	0.0365	No data taken
Test #2	No data taken	0.0346	0.0055	0.0358	No data taken
Test #3	No data taken	0.1098	0.0092	0.0236	No data taken
Average	---	0.0669	0.0097	0.0320	---

Test Data Outlet of First Packed Bed

	VOC	SO _x	NO _x	CO	PM
Test #1	0.833	0.0728	0.0362	0.0216	0.643
Test #2	0.940	0.0401	0.0537	0.0334	0.299
Test #3	0.663	0.0751	0.0149	0.0366	0.205
Average	0.812	0.063	0.035	0.031	0.382

Comparing the difference in the results from the outlet of the condenser to the outlet of the first packed bed for SO_x, NO_x, and CO within the error of the data there is really no change (control efficiency) attributable to the scrubbing of the packed bed scrubber. For practical reasons, IBP will assume the SO_x, NO_x, and CO are the same through the system taking no efficiencies due to scrubbers. SO_x, NO_x, and CO data were obtained to compare with the test results obtained by National By-Products in there December 1994 emission tested conducted in Des Moines, Iowa. TRC has reviewed the test report generated from the National By-Products and has summarized in a letter specific reasons for invalidating the results of that December test (Attachment A).

The Results of December 1994 National By-Products Tests
Samples Taken after Venturi Scrubber Before Boiler Incineration

	VOC	SO _x	NO _x	CO	PM
Test #1	2.60	0.26	0.10	0.03	0.51
Test #2	2.58	0.19	0.13	0.08	0.67
Test #3	3.00	0.19	0.12	0.06	0.45
Average	2.73	0.21	0.12	0.06	0.54

Overall in comparison, the data obtained at IBP showed to much lower for all pollutants and much more reasonable. SO_x, NO_x, and CO pollutants are formed from combustion and with the system being steam heated it is difficult to justify the presence of combustion pollutants.

Process Information During Test:

Head Kill	3,657 hd/day
Inedible Yield	39 lbs/hd finished crax
Inedible Operation Hours	13

Total Inedible Crax Processed: $[(3,657 \text{ hd/day}) \times (39 \text{ lbs/hd})]/13 \text{ hrs/day} = 10,971 \text{ lbs/hr finished crax}$
 $(10,971 \text{ lbs/hr}) \times (1 \text{ ton}/2,000 \text{ lbs}) = 5.49 \text{ tons/hr finished crax}$

Inedible Crax VOC Emission Factor:

Crax Processed	5.49 tons/hr
VOC Emissions from Inedible Cooking	0.812 lbs/hr

$0.812 \text{ lbs/hr}/5.49 \text{ tons/hr} = 0.15 \text{ lbs/ton finished crax}$

Inedible Crax SOx Emission Factor:

Crax Processed	5.49 tons/hr
SOx Emissions from Inedible Cooking	0.0669 lbs/hr

$0.0669 \text{ lbs/hr}/5.49 \text{ tons/hr} = 0.012 \text{ lbs/ton finished crax}$

Inedible Crax NOx Emission Factor:

Crax Processed	5.49 tons/hr
NOx Emissions from Inedible Cooking	0.0349 lbs/hr

$0.0349 \text{ lbs/hr}/5.49 \text{ tons/hr} = 0.006 \text{ lbs/ton finished crax}$

Inedible Crax CO Emission Factor:

Crax Processed	5.49 tons/hr
CO Emissions from Inedible Cooking	0.0320 lbs/hr

$0.0320 \text{ lbs/hr}/5.49 \text{ tons/hr} = 0.006 \text{ lbs/ton finished crax}$

Inedible Crax PM Emission Factor:

Crax Processed	5.49 tons/hr
PM Emissions from Inedible Cooking	0.3823 lbs/hr

$0.3823 \text{ lbs/hr}/5.49 \text{ tons/hr} = 0.07 \text{ lbs/ton finished crax}$

VOC data obtained from the Lexington facility on July 21, 1998

Test Data:	Test #1	1.184 lbs/hr
	Test #2	0.890 lbs/hr
	Test #3	0.928 lbs/hr
	Average	1.00 lbs/hr

Process Information During Test:

Head Kill	4,665 hd/day
Inedible Yield	39.6 lbs/hd finished crax
Inedible Operation	20 hrs

Total Inedible Crax Processed: $[(4,645 \text{ hd/day}) \times (39.6 \text{ lbs/hd})]/20 \text{ hrs/day} = 9,236.7 \text{ lbs/hr finished crax}$
 $(9,236.7 \text{ lbs/hr}) \times (1 \text{ ton}/2,000 \text{ lbs}) = 4.62 \text{ tons/hr finished crax}$

Inedible Crax Emission Factor:

Crax Processed	4.62 tons/hr
VOC Emissions from Blood Drying	1.00 lbs/hr

$1.00 \text{ lbs/hr}/4.62 \text{ tons/hr} = 0.23 \text{ lbs/ton finished crax}$

VOC Emission Factor Average of Dakota City and Lexington data: $(0.15+0.23)/2 = 0.19 \text{ lb/ton finished crax}$

Summary Table of Emission Factors Generated

	VOC, lb/ton finished crax	SOx, lb/ton finished crax	NOx, lb/ton finished crax	CO, lb/ton finished crax	PM, lb/ton finished crax
Emission Factor	0.19	0.012	0.006	0.006	0.070

These emission factors generated by IBP will be used to estimate emissions from steam cooking beef inedible crax and will supersede those emission factors generated by National By Products.

Attachment A
TRC Summary of Test Report and National By Products December 1994 Test Report



September 17, 1998

Ms. Rechelle Kruse
Air Pollution Control Engineer
IBP, Inc
P.O.Box 515 MD #34
Dakota City, NE. 68731

Re: Review of CES test report dated January 5, 1995

Dear Rechelle:

At your request I have reviewed the test report performed by Comprehensive Emission Services (CES) on the Dupps 320U Continuous Cooker at the National By-Products plant in Des Moines, Iowa.

First and foremost I am under the assumption that this is a complete test report as submitted by CES. My comments in this review are based upon my assumption that this is the complete report.

Particulate Sampling

- 1) According to the Preliminary Velocity sheet located in Appendix B cyclonic flow checks performed were only performed at points 4, 5 & 6 which indicate a 40 & 45 degree null angle. Where are points 1, 2 & 3? According to Method 5 if cyclonic flow is >20 degrees corrective action must be taken prior to performing a Method 5 test. This alone would void all performed tests.
- 2) According to the Method 5 data sheets oven temperatures were not applicable (N/A). I would like to see where this is stated in the method. Probe temperatures were only monitored at various points on Run #1, at one point on Run #2 and were never logged on Run #3. According to the method they need to be logged at each point. Also the method states that the temperature must be maintained at 247 degrees +/- 25 degrees. Run #1 Point #2B shows a temperature of 219 degrees which is below the allowed temperature.
- 3) According to Figure 2 on page 7 the stack diameter is 30 inches, all field data reflects a 22 inch stack. This could just be a typing error.

Ms. Rechelle Kruse
September 17, 1998
Page 2

Continuous Emission Monitoring data (CEMS)

- 1) All of the scales used for measuring NO_x, CO, SO₂ and THC are incorrect for the concentrations monitored. I assume NO_x was calibrated on a 0-1000 ppm scale using a 1010 high gas, 415 mid gas and a 221 low gas to measure 10 ppm or less. This is unacceptable. The drift alone was higher than the concentrations measured. The SO₂ was calibrated on the 0-500 ppm scale to measure 31 ppm or less this is unacceptable. The zero calibrations alone on SO₂ are half of the measured concentrations. CO was measured on 0-1000 ppm scale, concentrations of CO were less than 20 ppm. Once again drift alone was higher than most concentrations observed. THC was calibrated on the 0-100 ppm scale measuring concentrations as high as 336 ppm. This is also unacceptable. Reference Method 25 should have been used or 0-1000 ppm span range.
- 2) I did not see any of the Protocol 1 gas certifications in any of the Appendices.
- 3) I did not see any of the calibration drift correction calculations in any part of the report.
- 4) I did not see in the report what the actual scales for the testing was, I had to assume based on cal gases what scale was used.

Process data

- 1) Raw material used relates to what kind of raw material. If the raw material used was a mix of different animal scraps it is very hard to compare this to strictly beef products. It basically compares apples to oranges when it comes to emission rates.

In closing I feel that this is very weak data and should not be used when determining actual emission rates for this type of source. If you or anyone else has comments in regard to this letter please feel free to contact me at (630) 810-1122.

Sincerely,



Scott R. Miller
Manager, Measurements Division

TRC

EMISSION TEST REPORT
on
The Dupps 320U Continuous Cooker
at the
NATIONAL BY-PRODUCTS
facility in Des Moines, Iowa
on
September 20, 1995

**Conducted
By**

**Comprehensive Emission Services
1112 Maple
West Des Moines, Iowa 50265
(515) 225-7372**

Project No. 6995

TABLE OF CONTENTS

CONTENTS

Preface	1
Introduction	2
Summary of Results	3
Sampling and Analytical Procedures	4
Test Results	8

TABLES

Table 1, Summary of Test Results	3
Table 2, Particulate Emission Results	8
Table 3, Continuous Emission Monitoring Results	9


FIGURES

Figure 1, EPA Method 5 Sampling Apparatus	6
Figure 2, Location of Sample Points	7


Appendix A - Example Calculations	
Appendix B - Laboratory Data Forms	
Appendix C - Field Data Forms	
Appendix D - Pretest Calibrations	
Appendix E - Posttest Calibrations	
Appendix F - Process Data	
Appendix G - CEM Data Forms	

PREFACE

This report summarizes the results of the data collected on an emission demonstration test at the National Byproducts facility in Des Moines, Iowa. To the best of our knowledge the data contained in this report is accurate and complete. Any questions concerning this report should be directed to Mr. Douglas J. Ostrander, or Mr. Timothy C. Titus. Mr. Ostrander and Mr. Titus may be reached by phone at (515) 225-7372.



Tim Titus
Test Leader



Mark Titus
Reviewed By

Date: September 29, 1995

John A. Ostrander
John A. Ostrander
Field Data Technician
Field Data Technician
Field Data Technician
Field Data Technician
Field Data Technician

INTRODUCTION

An emission test was conducted by Comprehensive Emission Services on the Dupps 320U Continuous Cooker vapors after the Venturi Scrubber prior to the boiler incinerator at the National By-Products facility in Des Moines, Iowa. Three Iowa Method 5 sampling runs with backhalf were performed. Three Continuous Emission Monitoring (CEM) runs were also conducted in accordance with Method 25A. The testing fulfills the requirements for testing on source #00445 established in the Polk County Construction Permit #704. The testing was performed on September 20, 1995.

Coordinating the field test were:

Tim Titus - Comprehensive Emission Services
Todd Ferrell - National By-Products

Conducting the field test were:

Steve Dinsmore - Comprehensive Emission Services
Tim Titus - Comprehensive Emission Services

The appendices to this report contain the following information and data:

Appendix A: Example Calculations
Appendix B: Laboratory Data Forms
Appendix C: Field Data Forms
Appendix D: Pretest Calibrations
Appendix E: Posttest Calibrations
Appendix F: Process Data
Appendix G: CEM Data Forms

SUMMARY OF RESULTS

Table 1 summarizes the test results for testing on the Dupps 320U Continuous Cooker vapors after the Venturi scrubber prior to the boiler incinerator. The test runs was completed on September 20, 1995.

These values are not blank corrected.

Table 1 Summary of Test Results				
		Run 1	Run 2	Run 3
Particulate Net Weight	g	0.0113	0.0209	0.0120
Particulate Emissions	gr/dscf	0.0049	0.0080	0.0046
Particulate Emission Rate	lb/hr	0.06 24 Tpy	0.10 47 Tpy	0.06 26 Tpy
THC Emission Rate	lb/hr	2.40 10.5 Tpy	3.11 13.4 Tpy	2.39 10.4 Tpy
Flow Rate	dscfm	1,317	1,496	1,479
Production Weight	lb/hr	35,344	35,344	35,344

0.034 lb/hr

0.249 lb/hr

SAMPLING AND ANALYTICAL PROCEDURES

Sampling Procedures

Particulate emissions were determined by U.S. Environmental Protection Agency (EPA) Methods 1, 2, 3, 4, and Iowa Method 5. These methods are titled:

- Method 1 - "Sample and Velocity Traverse for Stationary Sources"
- Method 2 - "Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
- Method 3 - "Gas Analysis for Carbon Dioxide, Oxygen, Excess Air and Dry Molecular weight"
- Method 4 - "Determination of Moisture Content in Stack Gases"
- Method 5 - "Determination of Particulate Emissions From Stationary Sources"

These methods appear in detail in Title 40, Code of Federal Regulations (CFR), Part 60 Appendix A, and in the Iowa Compliance Sampling Manual.

The sampling apparatus is shown in Figure 1 on page 6. All equipment was calibrated at the Comprehensive Emission Services' office prior to shipment to the test site.

The continuous emission monitoring emissions were determined by U.S. Environmental Protection Agency (EPA) Method 25A. This method is titled:

- Method 25A - "Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer."

This Method appears in detail in Title 40 Code of Federal Regulations (CFR), Part 60, Appendix A.

Sampling Locations

A total of 12 sample points were used for determining particulate emissions. The sample time per point was five minutes for a total sampling time of 60 minutes per test run. The stack sampling point locations are shown in Figure 2 on page 7.

Analytical Procedures

Particulate


The particulate emission rate was determined following procedures detailed in Title 40, CFR, Part 60. Particulate samples collected on Whatman glass fiber filters were analyzed gravimetrically. The probe and nozzles were rinsed with acetone. The rinse was transferred to tared beakers and evaporated to dryness. The impinger solutions were analyzed for organic and inorganic particulate using Methylene Chloride. The organic and inorganic solutions were transferred to tared beakers and evaporated to dryness. The beakers and filters were desiccated for 24 hours and weighted to a constant weight. The weight differentials were combined to determine total particulate matter.

Stack Gas Monitoring System

A Gas Sample for the reference CEM system was continuously extracted from the stack through a stainless steel sample probe. The extracted sample was pulled through a series of heated filters to remove any particulate matter. The filters were heated to a temperature high enough to prevent condensation of any moisture in the gas stream. After the filters, a Teflon line was used to transfer the sample to the analyzers. So that the stack gases were measured on a dry basis, the moisture was removed from the sample gas stream by a series of refrigeration dryers. The flow of the stack gas sample was regulated at a constant rate to minimize drift.

Calibration Procedure

At the start of the day, the CEM monitors were checked for calibration error by introducing zero, mid-range, and high-range EPA Protocol 1 gases to the measurement system at a point upstream of the analyzers. Comprehensive Emission Services refers to the calibration error test as the instrument calibration. After the instrument calibration, each protocol gas was introduced into the sampling system to determine the sampling system bias. The gas was injected into the sampling valve located at the outlet of the sampling probe. The bias test was conducted before and after each consecutive test run by introducing zero and upscale calibration gases for each monitor. The upscale calibration gases used for the CEM bias tests were the calibration gases which most closely approximates the effluent concentration monitored during the test runs.



Schematic of Method 5 Sampling Train

Figure 1




Figure 2

Location of Traverse Points

Stack Inside Diameter 30.0 inches

Point	Distance from Stack Wall Inches
1	21.03
2	18.79
3	15.49
4	6.51
5	3.21
6	0.97

TEST RESULTS

Table 2
Particulate Emission Results

Parameters	Unit of Measure	Run 1	Run 2	Run 3
Particulate Emissions				
Actual	gr/dscf	0.0049	0.0080	0.0046
Weight	grams	0.0113	0.0209	0.0120
Particulate Emission Rate				
Emission Rate	lb/hr	0.06	0.10	0.06
Stack Flow Rates				
Actual	acfm	1,371	1,556	1,538
Standard Conditions	dscfm	1,317	1,496	1,479
Velocity	ft/min	519	589	583
Sampling Results				
Isokinetics	%	97.9	97.3	97.6
Sampling Volume	dscf	35.750	40.374	40.019
Avg. Stack Temperature	(F)	76	75	76
Avg. Sq Root Delta P	inches H ₂ O	0.1522	0.1728	0.1709
Avg. Delta H	Inches H ₂ O	1.03	1.31	1.28
Avg. Meter Temperature	(F)	82.5	85.9	87.0
Oxygen	%	21.0	21.0	21.0
Carbon Dioxide	%	0.0	0.0	0.0
Moisture Collected	ml	27.1	54.6	28.2
Moisture	% H ₂ O	3.0	2.9	3.0
Start Time	HH:MM	22:16	1:00	14:28
Sampling Time	min.	60.0	60.0	60.0

Table 3
Continuous Emission Monitor Results

Parameters	Unit of Measure	Run 1	Run 2	Run 3
THC Emissions				
Concentration	ppm	266.60	303.40	236.30
Emission Rate	lb/hr	2.40	3.11	2.39

Appendix A

Example Calculation

NOMENCLATURE

<u>Symbol</u>	<u>Description</u>
acfm	Actual cubic feet per minute
A_s	Area of stack
B_{ws}	Percent water
C_p	Pitot tube calibration coefficient
C_{std}	Concentration of particulate dry basis, standard conditions
D_n	Diameter of nozzle
dscfm	Dry standard cubic feet per minute
gr/dscfm	Grains per dry standard cubic feet per minute
ID	Inside diameter of stack
M_d	Molecular weight, dry stack gas
M_s	Molecular weight, stack gas
Q_{std}	Stack flow rate, dry standard conditions
P_b	Barometric pressure
P_s	Stack pressure
SP	Static pressure
T_m	Average meter temperature
T_s	Temperature of stack gas
V_i	Initial meter reading
V_f	Final meter reading
V_m	Volume meter, actual
$V_{m, std}$	Volume meter, standard conditions
V_s	Average stack gas velocity
W_t	Total moisture collected
$W_{t, gdh}$	Total particulate matter collected
Y	Meter correction factor
θ	Sampling time
% H_2O	Percent moisture by volume
% CO_2	Percent carbon dioxide by volume, dry
% O_2	Percent oxygen by volume, dry
% I	Percent isokinetic
ΔH	Pressure drop across orifice meter
ΔP	Gas velocity pressure

PARTICULATE CALCULATION EQUATIONS

Run 1

1. Volume meter

$$\begin{aligned}V_m &= (V_f - V_i) Y \\&= (163.487 - 126.100) 0.976 \\&= 36.490 \text{ ft}^3\end{aligned}$$

2. Volume meter, standard conditions (70°, 29.92 in. Hg)

$$\begin{aligned}V_{m(\text{std})} &= \frac{17.7 V_m \left(P_b + \frac{\Delta H}{13.6} \right)}{T_m + 460} \\&= \frac{17.7 (36.490) \left(29.95 + \frac{1.03}{13.6} \right)}{82.5 + 460} \\&= 35.750 \text{ ft}^3\end{aligned}$$

3. Percent moisture by volume

$$\begin{aligned}B_{ws} &= \frac{100 \times 0.04707 (W_c)}{0.04707 (W_c) + V_{m(\text{std})}} \\&= \frac{100 \times 0.04707 (27.1)}{0.04707 (27.1) + 35.750} \\&= 3.0 \%\end{aligned}$$

4. Molecular weight, dry stack gas

$$\begin{aligned}M_d &= 0.16 (\% \text{CO}_2) + 0.04 (\% \text{O}_2) + 28.0 \\&= 0.16 (0.0) + 0.04 (21.0) + 28.0 \\&= 28.84\end{aligned}$$

5. Molecular weight, stack gas

$$\begin{aligned}
 M_s &= M_d \left(1 - \frac{B_{ws}}{100} \right) + 18 \left(\frac{B_{ws}}{100} \right) \\
 &= 28.84 \left(1 - \frac{3.0}{100} \right) + 18 \left(\frac{3.0}{100} \right) \\
 &= 28.52
 \end{aligned}$$

6. Stack Pressure

$$\begin{aligned}
 P_s &= P_b + \frac{SP}{13.6} \\
 &= 29.95 + \frac{0.20}{13.6} \\
 &= 29.96 \text{ inch. Hg}
 \end{aligned}$$

7. Velocity of stack gas

$$\begin{aligned}
 V_s &= 60 \times 85.49 C_p \sqrt{\frac{T_s + 460}{P_s \times M_s}} (\sqrt{\Delta p})_{avg} \\
 &= 60 \times 85.49 (0.84) \sqrt{\frac{76 + 460}{29.96 \times 28.52}} (0.1522) \\
 &= 519 \text{ ft/min}
 \end{aligned}$$

8. Percent isokinetic

$$\begin{aligned}
 \% I &= \frac{100 (T_s + 460) V_{m(STD)}}{17.7 \theta V_s P_s \left(1 - \frac{B_w}{100} \right) \pi \left(\frac{D_n}{24} \right)^2} \\
 &= \frac{100 (76 + 460) 35.750}{17.7 (60) (519) 29.96 \left(1 - \frac{3.0}{100} \right) \pi \left(\frac{0.473}{24} \right)^2} \\
 &= 97.9 \%
 \end{aligned}$$

9. Area of stack

$$A_s = \pi \left(\frac{ID}{24} \right)^2$$

$$= \pi \left(\frac{22}{24} \right)^2$$

$$= 2.64 \text{ ft}^2$$

10. Stack volumetric flow rate actual conditions

$$Q_a = V_s A_s$$

$$= (519) (2.64)$$

$$= 1,371 \text{ acfm}$$

11. Stack volumetric flow rate, standard conditions (70°, 29.92 in. Hg)

$$Q_{std} = \frac{17.7 \times V_s A_s P_s \left(1 - \frac{B_{ws}}{100} \right)}{T_s + 460}$$

$$= \frac{17.7 (60)(519) (2.64) (29.96) \left(1 - \frac{3.0}{100} \right)}{76 + 460}$$

$$= 1,317 \text{ dscfm}$$

12. Grains per dry standard cubic feet

$$C_{std} = \frac{15.43 Wt_{\text{gain}}}{V_{\text{m(std)}}}$$

$$= \frac{15.43 (0.0113)}{35.750}$$

$$= 0.0049 \text{ gr/dscf}$$

13. Emission rate

$$\text{lb/hr} = \frac{60 W_{t_{\text{gain}}} (Q_e)}{453.5924 V_{m_{\text{STD}}}}$$

$$= \frac{60 (0.0113) (1,317)}{453.5924 (35.750)}$$

$$= 0.06 \text{ lb/hr}$$

Appendix B

Laboratory Data Forms

Project Number: 6995
 Plant Name: Natural Byproducts
 Date: 9/21/95
 Analysis Type: _____



Run 1				
Type	Identification Number	Final Weight	Tare Weight	Net Weight
Filter	F238	3.0370	3.0364	0.0006
Probe Rinse (ml)	B439	77.2168	77.2156	0.0012
Organic (ml)	B443	77.4629	77.4587	0.0042
Inorganic	D160	175.2589	175.2536	0.0053
Total Net Weight				0.0113
Run 2				
Type	Identification Number	Final Weight	Tare Weight	Net Weight
Filter	F239	3.0546	3.0542	0.0004
Probe Rinse (ml)	B440	66.3829	66.3745	0.0084
Organic (ml)	B446	66.2503	66.2402	0.0001
Inorganic	D161	167.6561	167.6441	0.0120
Total Net Weight				0.0209
Run 3				
Type	Identification Number	Final Weight	Tare Weight	Net Weight
Filter	F240	3.0087	3.0083	0.0004
Probe Rinse (ml)	B441	64.8021	64.8004	0.0017
Organic (ml)	B447	66.9781	66.9745	0.0036
Inorganic	D162	176.9161	176.9098	0.0063
Total Net Weight				0.0120
Blanks				
Type	Identification Number	Final Weight	Tare Weight	Net Weight
Water Blank (ml)				
Acetone Blank (ml)				
MeCl ₂ Blank (ml)				

0.0018

0.0088

0.0021

Identification

F = 3 inch filter P = 47mm filter B = 150ml Beaker C = 250ml Beaker D = 400ml Beaker


[illegible]

CES COMPREHENSIVE EMISSION SERVICES

FINAL WEIGHT WEIGHING SHEET

ID No.	Run	Weighing (grams)					Average Final Weight	Tare Weight	Net Weight
		1	2	3	4	5			
B439		77.2166	77.2169				77.2168		
B440		68.3829	68.3828				68.3829		
B441		64.8020	64.8021				64.8021		
B442		66.1427	66.1429				66.1428		
B443		65.1814	65.1817				65.1816		
B444		67.2815	67.2820				67.2818		
B445									
B446		66.2503	66.2503				66.2503		
B447		66.9779	66.9782				66.9781		

Notes:



Time	18:15	18:30							
Date	6/2/95	6/3/95							
Analyst	HT	HT							
ID No.	Weighing (grams)		Average						
	1	2	3	4	5				
F 228	3.0619	3.0619							3.0619
F 229	3.0735	3.0735							3.0735
F 230	3.0772	3.0772							3.0772
F 231	3.0416	3.0414							3.0415
F 232	3.0749	3.0747							3.0748
F 233	3.0673	3.0672							3.0673
F 234	3.0461	3.0461							3.0461
F 235	3.0542	3.0542							3.0542
F 236	3.0520	3.0520							3.0520
F 237	3.0327	3.0327							3.0327
F 238	3.0361	3.0364							3.0364
F 239	3.0541	3.0543							3.0542
F 240	3.0081	3.0085							3.0083


CES Comprehensive Emission Services

TARE WEIGHT WEIGHING SHEET

Time	14:30	10:45							
Date	6/26	6/27/93							
Analyst	BT	A							
ID No.	Weighing (grams)					Average			
	1	2	3	4	5				
B 432	106.8488	66.5485				66.8487			
B 433	106.5309	66.5305				66.5307			
B 434	106.8182	66.8178				66.8180			
B 435	105.6810	65.6807				65.6809			
B 436	77.0182	77.0178				77.0180			
B 437	77.9539	77.9537				77.9538			
B 438	105.6883	65.6879				65.6881			
B 439	77.2157	77.2154				77.2156			
B 440	106.3746	66.3744				66.3745			
B 441	104.8004	64.8003				64.8004			
B 442	106.1429	66.1427				66.1428			
B 443	105.1817	65.1815				65.1816			

77.0180

Notes



TARE WEIGHT WEIGHING SHEET

Time	Date	Analyst	ID No.	Weighing (grams)					Average
				1	2	3	4	5	
10:30	6/27	11	B 444	67.2823	67.2822				67.2823
	6/27/95		B 445	77.4587	77.4587				77.4587
			B 446	66.2404	66.2400				66.2402
			B 447	66.9746	66.9744				66.9745
			B 448	75.6973	75.6970				75.6972
			B 449	72.7291	72.7289				72.7290
			B 450	66.4193	66.4191				66.4192
			B 451	76.9283	76.9280				76.9282
			B 452	66.6757	66.6755				66.6756
			B 453	64.8040	64.8038				64.8039
			B 454	65.5583	65.5581				65.5582
			B 455	63.0605	63.0603				63.0604

Notes



TARE WEIGHT WEIGHING SHEET

Time	9:20	15:00	7:00	15:30	
Date	9/12/95	9/12	9/13/95	9/13/95	
Analyst	TT	TT	TT	TT	
ID No.	Weighing (grams)				Average
	1	2	3	4	5
0157	170.9703	170.9733	170.9708	170.9706	170.9707
1158	162.1057	162.1090	162.1059	162.1059	162.1059
1159	163.1981	163.2022	163.1984	163.1985	163.1985
1160	175.2531	175.2569	175.2535	175.2536	175.2536
1161	167.6437	167.6471	167.6440	167.6441	167.6441
1162	176.9094	176.9128	176.9099	176.9097	176.9098
1163	178.3508	178.3524	178.3504	178.3507	178.3506
1164	166.2714	166.2748	166.2712	166.2713	166.2713
1165	167.0834	167.0863	167.0834	167.0833	167.0834
1166	162.2681	162.2712	162.2681	162.2681	162.2681
1167	177.4390	177.4415	177.4399	177.4397	177.4398
✓ 1168	170.6276	170.6300	170.6277	170.6276	170.6276

Notes:

Appendix C

Field Data Forms

Run No.

Location:

NBP

Date:

9/19/95

Project #

% Isokinetic=

97.9

Initial Meter Volume (Cubic Feet)=

126.100

Final Meter Volume (Cubic Feet)=

163.487

Meter Factor=

0.976

Final Leak Rate (cu Ft/min)=

0.002

Net meter Volume (Cubic Feet)=

36.490

Gas Volume (Dry Std Cubic Feet 70 Deg)=

35.750

Barometric Pressure (in Hg) =

29.95

Static Pressure (Inches H2O)=

0.20

Stack Pressure (in Hg)=

29.96

Percent Oxygen =

21.00

Percent Carbon Dioxide=

0.00

Moisture Collected (ml)=

27.1

Percent Water=

3.0 Saturated

Average Meter Temperature (F)=

82.5

Average Delta H (in H2O)=

1.03

Average Delta P (inches H2O)=

0.0238

Average Stack Temp (F)=

76

Dry Molecular Weight=

28.84

Wet Molecular Weight=

28.52

Sampling Time (Minutes)=

60.0

Nozzle Diameter (Inches)=

0.473

Stack Diameter (Inches)=

22.00

Stack Area (Square Feet)=

2.64

Pitot Coefficient=

0.84

Average Square Root of Delta P (inches H2O)=

0.1522

Stack Velocity (Actual, ft/min)=

519

Flow Rate (Actual, Cubic ft/min)=

1,371

Flow Rate (Std, Dry, Cubic ft/min 70 Deg)=

1,317

Particulate Loading - Front Half

Particulate Weight Net (g)=

0.0018

Particulate Loading, Dry Std. 70 Deg (gr/scf)=

0.0008

Emission Rate (lb/hr)=

0.01

Particulate Loading - Total Catch Including Impingers

Particulate Weight Net (g)=

0.0113

Particulate Loading, Dry Std. 70 Deg (gr/scf)=

0.0049

Emission Rate (lb/hr)=

0.06

Percent Impinger Catch=

84.07

Run No. 2
Location: NBP
Date: 9/19/95
Project #

* Isokinetic= 97.3

Initial Meter Volume (Cubic Feet)= 178.400
Final Meter Volume (Cubic Feet)= 220.860
Meter Factor= 0.976
Final Leak Rate (cu ft/min)= 0.002
Net meter Volume (Cubic Feet)= 41.441
Gas Volume (Dry Std Cubic Feet 70 Deg)= 40.374

Barometric Pressure (in Hg) = 29.95
Static Pressure (Inches H2O)= 0.20
Stack Pressure (in Hg)= 29.96

Percent Oxygen = 21.00
Percent Carbon Dioxide= 0.00
Moisture Collected(ml)= 54.6
Percent Water= 2.9 Saturated

Average Meter Temperature (F)= 85.9
Average Delta H (in H2O)= 1.31
Average Delta P (inches H2O)= 0.0304
Average Stack Temp (F)= 75
Dry Molecular Weight= 28.84
Wet Molecular Weight= 28.52

Sampling Time (Minutes)= 60.0
Nozzle Diameter(Inches)= 0.473
Stack Diameter (Inches)= 22.00
Stack Area (Square Feet)= 2.64
Pitot Coefficient= 0.84
Average Square Root of Delta P (inches H2O)= 0.1728

Stack Velocity (Actual, ft/min)= 589
Flow Rate (Actual, Cubic ft/min)= 1,556
Flow Rate (Std, Dry, Cubic ft/min 70 Deg)= 1,496

Particulate Loading - Front Half

Particulate Weight Net (g)= 0.0088
Particulate Loading, Dry Std. 70 Deg (gr/scf)= 0.0034
Emission Rate (lb/hr)= 0.04

Particulate Loading - Total Catch Including Impingers

Particulate Weight Net (g)= 0.0209
Particulate Loading, Dry Std. 70 Deg (gr/scf)= 0.0080
Emission Rate (lb/hr)= 0.10
Percent Impinger Catch= 57.89

Run No.

3

Location:

NBP

Date:

9/19/95

Project #

Isokinetic=

97.6

Initial Meter Volume (Cubic Feet)=

221.700

Final Meter Volume (Cubic Feet)=

263.877

Meter Factor=

0.976

Final Leak Rate (cu Ft/min)=

0.003

Net meter Volume (Cubic Feet)=

41.165

Gas Volume (Dry Std Cubic Feet 70 Deg)=

40.019

Barometric Pressure (in Hg) =

29.95

Static Pressure (Inches H2O)=

0.20

Stack Pressure (in Hg)=

29.96

Percent Oxygen =

21.00

Percent Carbon Dioxide=

0.00

Moisture Collected(ml)=

28.2

Percent Water=

3.0 Saturated

Average Meter Temperature (F)=

87.0

Average Delta H (in H2O)=

1.28

Average Delta P (inches H2O)=

0.0296

Average Stack Temp (F)=

76

Dry Molecular Weight=

28.84

Wet Molecular Weight=

28.52

Sampling Time (Minutes)=

60.0

Nozzle Diameter(Inches)=

0.473

Stack Diameter (Inches)=

22.00

Stack Area (Square Feet) =

2.64

Pitot Coefficient=

0.84

Average Square Root of Delta P (inches H2O)=

0.1709

Stack Velocity (Actual, ft/min)=

583

Flow Rate (Actual, Cubic ft/min)=

1,538

Flow Rate (Std, Dry, Cubic ft/min 70 Deg)=

1,479

Particulate Loading - Front Half

Particulate Weight Net (g)=

0.0021

Particulate Loading, Dry Std. 70 Deg (gr/scf)=

0.0008

Emission Rate (lb/hr)=

0.01

Particulate Loading - Total Catch Including Impingers

Particulate Weight Net (g)=

0.0120

Particulate Loading, Dry Std. 70 Deg (gr/scf)=

0.0046

Emission Rate (lb/hr)=

0.06

Percent Impinger Catch=


82.50

C E S COMPREHENSIVE EMISSION SERVICES

Project Number 6995
 Run Number 1
 Date 9/19/93
 Sample Type _____
 Plant Wistana By-Products
 Location Dupps Looker

Project Leader Tim Trams
 Meter Operator TT
 Lab Person TT
 Support Personnel Steve Dinsmore

Assumed Moisture % 4 Meter Number 1
 Minutes Per Point (min.) 5 Oven Number 1
 Sampling Time (min.) 60 Umbilical Number 501
 Meter Factor Y 976 Pitot Number 3A
 Meter ΔH @ 1.525 Probe Number 3A
 Pitot Coefficient C_p .84 Probe Length 3' Glass
 Stack Axis 1 (inch.) 22 Nozzle Type Glass
 Stack Axis 2 (inch.) 22
 Barometric Pressure (in. Hg) 29.95
 Static Pressure (in. H₂O) 0.20
 Nozzle Diameter (inch.) .473



Schematic of Testing Location

Initial Meter Volume (ft ³)	125.000 126.100
Final Meter Volume (ft ³)	163.487
Leak Rate Before	.003 CFM @ ≥ 15 in. Hg
Leak Rate After	.002 CFM @ 8 in. Hg
Pitot Leak Check	pass Before pass After

RECOVERY DATA

Orsat

Titl	%CO ₂	%CO ₂ +%O ₂	%O ₂
1	0.0		21.0
2	0.0		21.0
3			
Avg	0.0		21.0

Impingers

	Final	Initial	Difference
Impinger 1	110	100	10
Impinger 2	105	100	5
Impinger 3	1	0	1
Impinger 4	767.3	756.2	11.1
Condition/Color		Total	27.1

Notes:

Filter Number: F28

Field Data Sheet

Run No. 1083

Run No. _____
Project No. 6993

Location MBP

Date 9/19/95

Operator 7166

Start Time ~~12:16~~ 22:16

Stop Time: _____

[illegible]

Notes:

COMPREHENSIVE EMISSION SERVICES

Project Number 6993
 Run Number 2
 Date 9/20/95
 Sample Type TSP
 Plant NBP
 Location Cookes

Project Leader Tim Titus
 Meter Operator TT
 Lab Person TT
 Support Personnel Steve Dinsmore

Assumed Moisture % 4 Meter Number 1
 Minutes Per Point (min.) 5 Oven Number 1
 Sampling Time (min.) 60 Umbilical Number 501
 Meter Factor Y 976 Pitot Number 3
 Meter $\Delta H@$ 1.525 Probe Number 3A
 Pitot Coefficient C_p .84 Probe Length 3' glass
 Stack Axis 1 (inch.) 22 Nozzle Type glass
 Stack Axis 2 (inch.) 22

Barometric Pressure (in. Hg) 29.95
 Static Pressure (in. H_2O) .20
 Nozzle Diameter (inch.) .473

Schematic of Testing Location

Initial Meter Volume (ft ³)	178.400
Final Meter Volume (ft ³)	220.860
Leak Rate Before	.002 CFM@ 2.15 in. Hg
Leak Rate After	.002 CFM@ 10 in. Hg
Pitot Leak Check	pass Before pass After

RECOVERY DATA

Orsat

Trial	%CO ₂	%CO ₂ +%O ₂	%O ₂
1	0.0		21.0
2	0.0		21.0
3			
Avg	0.0		21.0

Impingers

	Final	Initial	Difference
Impinger 1	126	100	26
Impinger 2	110	100	10
Impinger 3	4	0	4
Impinger 4	790	775.4	14.6
Condition/Color		Total	54.6

Notes:

Filter Number: P239

Field Data Sheet

Run No. 6993
Project No. _____
Location Coches
Date 9/20/93
Operator PI
Start Time 1:00

Stop Time _____

[illegible]

Notes:



COMPREHENSIVE EMISSION SERVICES

Project Number 6993
Run Number 3
Date 9/20/93
Sample Type TSP
Plant HBP
Location Coke

Project Leader Tim Titus
Meter Operator TT
Lab Person TT
Support Personnel Steve Dinares

Assumed Moisture % 4 Meter Number 1
Minutes Per Point (min.) 5 Oven Number 1
Sampling Time (min.) 60 Umbilical Number 501
Meter Factor Y 7.76 Pitot Number 3
Meter ΔH 1.525 Probe Number 3A
Pitot Coefficient Cp .84 Probe Length 8' 9/16"
Stack Axis 1 (inch.) 22 Nozzle Type 9/16"
Stack Axis 2 (inch.) 22
Barometric Pressure (in. Hg) 29.95
Static Pressure (in. H₂O) 1.20
Nozzle Diameter (inch.) 1.473

Schematic of Testing Location

Initial Meter Volume (ft ³)	<u>221.7</u>
Final Meter Volume (ft ³)	<u>763.877</u>
Leak Rate Before	<u>.003</u> CFM @ <u>> 15</u> in. Hg
Leak Rate After	<u>.003</u> CFM @ <u>6</u> in. Hg
Pitot Leak Check	<u>pass</u> Before <u>pass</u> After

RECOVERY DATA

Orsat

Trial	%CO ₂	%CO ₂ +%O ₂	%O ₂
1	<u>0.0</u>		<u>21.0</u>
2	<u>0.0</u>		<u>21.0</u>
3			
Avg	<u>0.0</u>		<u>21.0</u>

Impingers

	Final	Initial	Difference
Impinger 1	<u>114</u>	<u>100</u>	<u>14</u>
Impinger 2	<u>104</u>	<u>100</u>	<u>4</u>
Impinger 3	<u>2</u>	<u>0</u>	<u>2</u>
Impinger 4	<u>201.4</u>	<u>673.2</u>	<u>8.2</u>
Condition/Color		Total	<u>28.2</u>

Notes:

Filter Number: F 240

Field Data Sheet

Run No. 5

Project No. 6993

Location _____

Date 3/20/95

Operator _____

Start Time 17.25

Stop Time _____

[illegible]

Notes:

Appendix D

Pretest Calibrations

METER CALIBRATION

Operator	T.T	K Factor	0.6426
Date	Sept 18, 1995	Meter Number	1
Previous Y Factor	0.979	Orifice Number	2

Meter Volume			RUN 1	RUN 2
	Final	Cubic Feet	105.948	111.944
	Initial	Cubic Feet	100.000	106.000
	Net	Cubic Feet	5.948	5.944

Meter Temperature				
Inlet				
	Initial	Deg. F	63.0	64.0
	Final	Deg. F	64.0	65.0
Outlet				
	Initial	Deg. F	62.0	63.0
	Final	Deg. F	63.0	64.0
Avg. Meter Temp		Deg. F	63.0	64.0

Time	sec	420.0	420.0
Meter Delta H	inches H2O	2.00	2.00
Barometric Pressure	inches Hg	30.25	30.25

Room Temperature				
	Initial	Deg. F	64.0	64.0
	Final	Deg. F	64.0	65.0
Avg. Room Temperature		Deg. F	64.0	64.5

Pump Vacuum	inches Hg	21	21
-------------	-----------	----	----

Vcr (std)	dscf	5.944	5.941
Vm (std)	dscf	6.098	6.082
Y Factor		0.975	0.977
Delta H ₀		1.524	1.526

Average Y	0.976
Average Delta H ₀	1.525

+/- 2% Criteria	
Percent of Avg Y	0.11

PASS

+/- 5% Criteria	
Percent of Final Y	0.33

ORFICE BRACKETING

Operator
Date

T.T.
18-Sep-95

Meter Y Factor 0.976

BRACKET ORFICES:

Orifice No. 1 3
K Factor 0.3271
Orifice No. 2 2
K Factor 0.6426

Meter Volume

Final Cubic Feet
Initial Cubic Feet
Net Cubic Feet

ORFICE #1 ORFICE #2
123.690 117.942
118.000 112.000
5.690 5.942

Meter Temperature

Inlet

Initial Deg. F 63.0 64.0
Final Deg. F 63.0 64.0

Outlet

Initial Deg. F 60.0 62.0
Final Deg. F 61.0 63.0

Avg. Meter Temp Deg. F 61.8 63.3

Time sec 780.0 420.0
Meter Delta H inches H2O 0.53 2.00
Barometric Pressure inches Hg 30.25 30.25

Room Temperature

Initial Deg. F 63.0 64.0
Final Deg. F 63.0 64.0

Avg. Room Temperature Deg. F 63.0 64.0

Pump Vacuum inches Hg 24 20

Vcr (std) dscf 5.625 5.944
Vm (std) dscf 5.827 6.089
Y Factor (brackets) 0.965 0.976

+/- 2% Criteria

Percent of Y 1.10 0.02

PASS

PASS

BRACKETING WORK SHEET

Operator: TT

Meter I.D. 1

Date: 9/18/93

K Factor No. 1 .3271

Previous Y Factor 0.976

K Factor No. 2 .6421

METER VOLUME		Units	1	2
Final		ft ³	123.690	117.942
Initial		ft ³	118.000	112.000
Meter Temperature				
INLET				
Initial		°F	63	64
Final		°F	63	64
OUTLET				
Initial		°F	60	62
Final		°F	61	63
Time		sec	760	420
Meter ΔH		in. H ₂ O	.53	2.0
Barometric Pressure		in. Hg	30.245	30.10 30.25
Room Temperature				
Initial		°F	63	64
Final		°F	63	64
Pump Vacuum		in. Hg	24	20



COMPREHENSIVE
EMISSION
SERVICES

Appendix E

Posttest Calibrations

METER CALIBRATION

Operator	J.T.	K Factor	0.6426
Date	Sepy-25-95	Meter Number	1
Previous Y Factor	0.976	Orifice Number	2

			RUN 1	RUN 2
Meter Volume				
	Final	Cubic Feet	399.658	405.950
	Initial	Cubic Feet	393.700	400.000
	Net	Cubic Feet	5.958	5.950

Meter Temperature

Inlet

Initial	Deg. F	64.0	67.0
Final	Deg. F	66.0	69.0

Outlet

Initial	Deg. F	63.0	65.0
Final	Deg. F	64.0	66.0

Avg. Meter Temp	Deg. F	64.3	66.8
-----------------	--------	------	------

Time	sec	420.0	420.0
Meter Delta H	inches H2O	2.10	2.10
Barometric Pressure	inches Hg	30.00	30.00

Room Temperature

Initial	Deg. F	68.0	67.0
Final	Deg. F	68.0	69.0

Avg. Room Temperature	Deg. F	68.0	68.0
-----------------------	--------	------	------

Pump Vacuum	inches Hg	19	19
-------------	-----------	----	----

Vcr (std)	dscf	5.873	5.873
-----------	------	-------	-------

Vm (std)	dscf	6.045	6.008
----------	------	-------	-------

Y Factor		0.971	0.977
----------	--	-------	-------

Delta H ₀		1.629	1.625
----------------------	--	-------	-------

Average Y		0.974
-----------	--	-------

Average Delta H ₀		1.627
------------------------------	--	-------

+/- 2% Criteria

Percent of Avg Y		0.31
------------------	--	------

PASS

+/- 5% Criteria

Percent of Final Y		0.16
--------------------	--	------

PASS

CONSOLE WORK SHEET

Operator: J.T.

K Factor: 0.6426

Date: 9-25-95

Meter I.D. 1

Previous Y Factor: 0.976

Orifice Number: II

		Run Number	
METER VOLUME	Units	1	2
Final	ft ³	399.658	405.950
Initial	ft ³	393.800	400.000
Meter Temperature			
INLET			
Initial	°F	64	67
Final	°F	66	69
OUTLET			
Initial	°F	63	65
Final	°F	64	66
Time	sec	420	420
Meter ΔH	in. H ₂ O	2.1	2.1
Barometric Pressure	in. Hg	30.00	30.00
Room Temperature			
Initial	°F	68	67
Final	°F	68	69
Pump Vacuum	in. Hg	19	19

ORFICE BRACKETING

Operator
Date

J.T.
Sept-25-95

BRACKET ORFICES:

Orifice No. 1 2
K Factor 0.6426
Orifice No. 2 3
K Factor 0.3271

Meter Y Factor 0.974

ORFICE #1 ORFICE #2

Meter Volume

	Final	Cubic Feet	412.159	418.035
Initial		Cubic Feet	406.200	412.300
Net		Cubic Feet	5.959	5.735

Meter Temperature

Inlet

	Initial	Deg. F	70.0	71.0
	Final	Deg. F	72.0	71.0

Outlet

	Initial	Deg. F	66.0	68.0
	Final	Deg. F	68.0	69.0

	Avg. Meter Temp	Deg. F	69.0	69.8

	Time	sec	420.0	780.0
	Meter Delta H	inches H2O	2.10	0.53
	Barometric Pressure	inches Hg	30.00	30.00

Room Temperature

	Initial	Deg. F	69.0	69.0
	Final	Deg. F	69.0	69.0

	Avg. Room Temperature	Deg. F	69.0	69.0

	Pump Vacuum	inches Hg	19	24

	Vcr (std)	dscf	5.867	5.546
	Vm (std)	dscf	5.992	5.736

	Y Factor (brackets)		0.979	0.967

+/- 2% Criteria

	Percent of Y		0.53	0.73

PASS

PASS

BRACKETING WORK SHEET

Operator: J.T.

Meter I.D. 1

Date: 9-25-95

K Factor No. 1 0.6426 #2

Previous Y Factor 0.974

K Factor No. 2 0.3271 #2

METER VOLUME	Units	1	2
Final	ft ³	412.159	418.035
Initial	ft ³	406.200	412.300
Meter Temperature			
INLET			
Initial	°F	70	71
Final	°F	72	71
OUTLET			
Initial	°F	66	68
Final	°F	68	69
Time	sec	420	780
Meter ΔH	in. H ₂ O	2.1	0.53
Barometric Pressure	in. Hg	30.00	30.00
Room Temperature			
Initial	°F	69	69
Final	°F	69	69
Pump Vacuum	in. Hg	19	24



COMPREHENSIVE
EMISSION
SERVICES

Appendix F

Process Data

NATIONAL
BY-PRODUCTS, INC.

1020 Locust St.
P.O. Box 615
Des Moines, IA 50303
515-288-2166

FAX: 315-288-1007

TO: Mr. Timothy C. Titus

WITH: Comprehensive Emission Services, West Des Moines

FAX NUMBER: (515) 225 - 7894

DATE: September 26, 1995

FROM: J. Todd Ferrell - Plant Coordinator

NO. OF PAGES: 2


SUBJECT: Attached is the Dupps 320U cooker temperature recorder chart for the processing period starting on 9-19-95 afternoon and finishing up the morning of 9-20-95 at the Des Moines N.B.D. plant

For your emission tests:

Begin Processing time : 5:10 PM
End Processing Time: 4:50 AM
Processing Time: 11 hours, 40 minutes (11.67)
Raw Material processed: 412,460 pounds
Raw Material processing rate: 35,344 lb.s/hr.
Raw Material processing rate: 17.7 tons/hr.

Any questions please call.

cc: Mr. Paul Bohlrig - Treasurer, Des Moines
Mr. Bob Bushnell - Plant Superintendent, Des Moines
Mr. Del Lane - Regional Manager, Des Moines
Mr. Mark Myers - District Manager, Des Moines



National By-Products, Inc
Des Moines, IA
9-19-95 → 9-20-95 Processing

Appendix G

CEM DATA

"Comprehensive Emission Services"

"National By-Products "

"Des Moines, Iowa"

"DATE 09-19-1995 "

Run 1

"TIME 21:51:43 "

" Time " VOC "

"sec/day " ppm "

22:08:00	236.5
22:09:00	250.58
22:10:00	245.59
22:11:00	257.27
22:12:00	273.3
22:13:00	294.32
22:14:00	299.9
22:15:00	303.42
22:16:00	291.32
22:17:00	288.71
22:18:00	275.09
22:19:00	282.62
22:20:00	271.73
22:21:00	285.21
22:22:00	286.14
22:23:00	292.39
22:24:00	281.08
22:25:00	276.43
22:26:00	266.5
22:27:00	266.25
22:28:00	261.75
22:29:00	265.63
22:30:00	257.62
22:31:00	260.01
22:32:00	249.77
22:33:00	252.33
22:34:00	245.96
22:35:00	246.42
22:36:00	242.75
22:37:00	255.3
22:38:00	250.93
22:39:00	255.59
22:40:00	256.16
22:41:00	252.71
22:42:00	255.44
22:43:00	247.92
22:44:00	258.65
22:45:00	254.6
22:46:00	265.36
22:47:00	266.91
22:48:00	271.14
22:49:00	277.07
22:50:00	278.05
22:51:00	284.4
22:52:00	276.44
22:53:00	270.32
22:54:00	280.09
22:55:00	287.7
22:56:00	284.4
22:57:00	310.15

Average
Corrected for Cal
lb/hr

268.9
268.6
2.40

Zero

10.7

Span

252.95

DSCFM

1317

"Comprehensive Emission Services"

"National By-Products "

"Des Moines, Iowa"

"DATE 09-19-1995 "

Run 2

"TIME 23:51:04 "

" Time "" VOC "

"sec/day "" ppm "

00:04:00 303.27

00:05:00 285.28

00:06:00 299.25

00:07:00 379.51

00:08:00 415.84

00:09:00 394.32

00:10:00 351.28

00:11:00 349.49

00:12:00 320.55

00:13:00 314.51

00:14:00 304.73

00:15:00 270.45

00:16:00 242.43

00:17:00 212.61

00:18:00 221.59

00:19:00 280.42

00:20:00 316.8

00:21:00 350.59

00:22:00 362.12

00:23:00 327.99

00:24:00 293.07

00:25:00 275.71

00:26:00 279.79

00:27:00 297.26

00:28:00 285.1

00:29:00 292.5

00:30:00 278.5

00:31:00 286.75

00:32:00 280.47

00:33:00 244.95

00:34:00 227.8

00:35:00 219.17

00:36:00 263.69

00:37:00 305.26

00:38:00 299.63

00:39:00 311.99

00:40:00 297.19

00:41:00 287.9

00:42:00 262.32

00:43:00 225.71

00:44:00 218.09

00:45:00 289.74

00:46:00 329.97

00:47:00 329.05

00:48:00	328.43
00:49:00	309.17
00:50:00	312.31
00:51:00	300.59
00:52:00	303.44
00:53:00	294.86
00:54:00	273.6
00:55:00	251.76
00:56:00	269.18
00:57:00	329.31
00:58:00	330.54
00:59:00	338.67
01:00:00	321.01
01:01:00	317.71
01:02:00	310.04
01:03:00	307.93
01:04:00	320.11
01:05:00	320.28
01:06:00	333.14
01:07:00	329.52
01:08:00	289.5
01:09:00	307.7
01:10:00	336.51
01:11:00	329.6
01:12:00	337.63
01:13:00	320.55
01:14:00	317.85
01:15:00	299.6
01:16:00	305.5
01:17:00	290.98
01:18:00	299.99
01:19:00	291.24
01:20:00	299.81
01:21:00	291.59
01:22:00	293.72
01:23:00	309.58
01:24:00	307.84
01:25:00	321.75
01:26:00	318.36
01:27:00	320.25
01:28:00	314.56
01:29:00	326.31
01:30:00	349.46
01:31:00	351.91
01:32:00	362.6
01:33:00	348.36
01:34:00	356.36
01:35:00	336.34
01:36:00	336.36
01:37:00	323.08
01:38:00	344.19

01:39:00	333.08
01:40:00	338.35
01:41:00	322.16
01:42:00	322.36
01:43:00	312.93
01:44:00	310.87
01:45:00	304.61
01:46:00	304.96
01:47:00	300.24
01:48:00	293.73
01:49:00	296.75
01:50:00	311.59
01:51:00	307.89
01:52:00	326.86

	Zero	Span	DSCFM
Average	307.4	20.4	257
Corrected for Cal	303.4		1496
lb/hr	3.11		

"Comprehensive Emission Services"

"National By-Products "

"Des Moines, Iowa"

"DATE 09-20-1995 "

Run 3

"TIME 02:26:34 "

" Time " VOC "

"sec/day " ppm "

02:28:00 255.02

02:29:00 252.06

02:30:00 269.63

02:31:00 249.26

02:32:00 210.63

02:33:00 194.65

02:34:00 182.53

02:35:00 203.96

02:36:00 300.59

02:37:00 321.69

02:38:00 313.72

02:39:00 288.41

02:40:00 283.42

02:41:00 235.24

02:42:00 219.43

02:43:00 235.95

02:44:00 263.73

02:45:00 270.46

02:46:00 259.01

02:47:00 243.97

02:48:00 232.99

02:49:00 209.12

02:50:00 183.64

02:51:00 171.6

02:52:00 193.48

02:53:00 227.27

02:54:00 231.79

02:55:00 234.7

02:56:00 221.52

02:57:00 210.41

02:58:00 200.62

02:59:00 194.12

03:00:00 201.51

03:01:00 236.99

03:02:00 272.29

03:03:00 276.23

03:04:00 256.41

03:05:00 238.57

03:06:00 235.01

03:07:00 243.24

03:08:00 289.51

03:09:00 319.29

03:10:00 323.63

03:11:00 326.66

03:12:00 228.38

Average

Corrected for Cal

lb/hr

244.3

236.3

2.39

Zero

21.75

Span

257.3

DSCFM

1479

"Comprehensive Emission Services"

lcal

"National By-Products "

"Des Moines, Iowa"

"DATE 09-19-1995 "

"TIME 20:48:54 "

"Time " VOC "

"sec/day "" ppm "

20:49:09 851.54

20:49:24 852.46

20:49:39 853.59

20:49:54 851.71

20:50:09 642.23

20:50:24 539.56

20:50:39 546.13

20:50:54 552.31

20:51:09 557.85

20:51:24 452.8

20:51:39 250.61

20:51:54 250.36

20:52:09 247.57

20:52:24 249.37

20:52:39 219.61

20:52:54 18.36

20:53:09 2.65

20:53:24 0.56

20:53:39 -0.04

20:53:54 -0.43

20:54:09 1.31

853.0

High

552.1

Mid

248.5

Low

0.4

Zero

Range 1000 ppm

Standards

250.1

558.2

849.6

F₁ 1,317

F₂ 1,496

F₃ 1,479

"Comprehensive Emission Services"

Cal 1 & 2

"National By-Products "

"Des Moines, Iowa"

"DATE 09-19-1995 "

"TIME 23:41:54 "

" Time "" VOC "

"sec/day "" ppm "

23:42:15 265.7

23:42:30 261.97

23:42:45 261.79

23:43:00 258.53

257.4

Low

23:43:15 257.91

23:43:30 255.65

23:43:45 257.5

23:44:00 255.75

23:44:15 248.56

23:44:30 42.02

23:44:45 22.98

23:45:00 21.13

21.0

Zero

23:45:15 20.78

23:45:30 42.08

23:45:45 254.44

23:46:00 558.54

23:46:15 557.64

23:46:30 558.12

23:46:45 559.91

558.9

mid

23:47:00 558.56

23:47:15 456.2

"Comprehensive Emission Services"

Cal 2 & 3

"National By-Products "

"Des Moines, Iowa"

"DATE 09-20-1995 "

"TIME 02:21:04 "

" Time "" VOC "

"sec/day "" ppm "

02:21:19 559.12

02:21:34 558.85

558.7

mid

02:21:49 558.64

02:22:04 231.56

02:22:19 25.13

02:22:34 18.76

02:22:49 20.64

02:23:04 19.87

19.8

Zero

02:23:19 61.58

02:23:34 194.35

02:23:49 285.19

02:24:04 282.13

02:24:19 266.57

02:24:34 256.93

256.6

Low

02:24:49 256.32

02:25:04 250.8

"Comprehensive Emission Services"

"National By-Products "

"Des Moines, Iowa"

Cal After 3

"DATE 09-19-1995 "

"TIME 03:27:08

" Time "" VOC "

"sec/day "" ppm "

03:28:15 564.32

03:28:30 568.14

03:28:45 557.84

03:29:00 558.21

560.7

mid

03:29:15 566.12

03:29:30 565.14

03:29:45 555.14

03:30:00 547.45

03:30:15 258.41

03:30:30 259.78

03:30:45 258.8

258.0

Low

03:31:00 257.95

03:31:15 257.12

03:31:30 252.31

03:31:45 217.35

03:32:00 69.92

03:32:15 23.74

03:32:30 24.56

03:32:45 23.89

03:33:00 22.73

23.7

High

03:33:15 22.31



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX: (810) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
C A E INSTRUMENT RENTAL
246 WOODWORK LANE
PALATINE, IL 60067

Assay Laboratory
Scott Specialty Gases, Inc
1290 Combermere
Troy, MI 48083

Purchase Order : 11785-71500
Scott Project # : 569024

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

Cylinder Number : ALM047523
Cylinder Pressure + : 1900 psig

Certificate Date : 8/8/94
Previous Certificate Date : None

Expiration Date : 8/8/97

ANALYZED CYLINDER

Components
Propane

Certified Concentration
250.1 ppm

Analytical Uncertainty*
±1% NIST Directly Traceable

Balance Gas: Nitrogen

*Do not use when cylinder pressure is below 150 psig.

*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

REFERENCE STANDARD

Type **Expiration Date**
NTRM 2646 10/14/95

Cylinder Number
AAL18426

Concentration
973.2 ppm Propane in Nitrogen

INSTRUMENTATION

Instrument/Model/Serial #
Beckman/400/1002059

Last Date Calibrated
8/4/94

Analytical Principle
Flame Ionization Detection

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components
Propane

First Triad Analysis

Date: 8/8/94 Response Units: mV
Z1=0.00 R1=97.30 T1=25.00
R2=97.30 Z2=0.00 T2=25.00
Z3=0.00 T3=25.00 R3=97.30
Avg. Conc. of Cal. Cyl. 250.1 ppm

Second Triad Analysis

Calibration Curve

Concentration: $A + Bx + Cx^2 + Dx^3$
 $r=1.00000$ NTRM 2646
Constants: A=0.049241000
B=10.002000000 C=0.000000000
D=0.000000000 E=0.000000000

Special Notes

Analyst

Don Eckley Jr.



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48063

(810) 589-2950 FAX:(810) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

C A E INSTRUMENT RENTAL
246 WOODWORK LANE
PALATINE, IL 60067

Assay Laboratory

Scott Specialty Gases, Inc
1290 Combermere
Troy, MI 48083

Purchase Order : 11785-71500

Scott Project # : 569024

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

Cylinder Number : ALM047565

Certificate Date : 8/8/94

Expiration Date : 8/8/97

Cylinder Pressure + : 1900 psig

Previous Certificate Date : None

ANALYZED CYLINDER

Components

Propane

Certified Concentration

558.2 ppm

Analytical Uncertainty*

±1% NIST Directly Traceable

Balance Gas: Nitrogen

*Do not use when cylinder pressure is below 150 psig.

*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

REFERENCE STANDARD

Type

NTRM 2646

Expiration Date

10/14/95

Cylinder Number

AAL18426

Concentration

973.2 ppm Propane in Nitrogen

INSTRUMENTATION

Instrument/Model/Serial

Beckman/400/1002059

Last Date Calibrated

8/4/94

Analytical Principle

Flame Ionization Detection

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

Propane

First Triad Analysis

Date: 8/8/94 Response Units: mV
Z1=0.00 R1=97.30 T1=55.80
R2=97.30 Z2=0.00 T2=55.80
Z3=0.00 T3=55.80 R3=97.30
Avg. Cons. of Cust. Cyl. 558.2 ppm

Second Triad Analysis

Calibration Curve

Concentration=A-Bx-Cx²+Dx³+Ex⁴
r=1.00000 NTRM 2646
Constant: A=0.043241000
B=10.002000000 C=0.000000000
D=0.000000000 E=0.000000000

Special Notes

Analyst

Don Eichler



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX: (810) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

C A E INSTRUMENT RENTAL
246 WOODWORK LANE
PALATINE, IL 60067

Assay Laboratory

Scott Specialty Gases, Inc
1290 Combermere
Troy, MI 48083

Purchase Order : 12021-71500

Scott Project # : 570587

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

Cylinder Number : ALM005524

Certificate Date : 9/7/94

Expiration Date : 9/7/97

Cylinder Pressure + : 1900 psig

Previous Certificate Date : None

ANALYZED CYLINDER

Components

Propane

Certified Concentration

849.6 ppm

Analytical Uncertainty*

±1% NIST Directly Traceable

Balance Gas: Nitrogen

+Do not use when cylinder pressure is below 150 psig.

*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

REFERENCE STANDARD

Type

NTRM 2646

Expiration Date

10/14/95

Cylinder Number

AAL18426

Concentration

973.2 ppm Propane in Nitrogen

INSTRUMENTATION

Instrument/Model/Serial

Propane : Beckman/400/1002059

Last Date Calibrated

8/15/94

Analytical Principle

Flame Ionization Detection

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

Propane

First Triad Analysis

Date: 9/7/94 Response Units: ruv
Z1=0.00 R1=97.30 T1=65.00
R2=97.30 Z2=0.00 T2=64.90
Z3=0.00 T3=64.90 R3=97.30
Avg. Conc. of Cust. Cyl. 849.6 ppm

Second Triad Analysis

Calibration Curve

Concentrations: $A \cdot C_x^2 + B \cdot C_x + C = D \cdot C_x^2 + E \cdot C_x + F$
r=1.00000 NTRM 2646
Constants: A=0.048241000
B=10.002000000 C=0.000000000
D=0.000000000 E=0.000000000

Special Notes

Not a Base
Analyst



TRC Project No. 22214-12

July 1998



**Compliance Emission Testing of the Supercooker
at IBP, Inc. Dakota City, Nebraska**

Prepared for

IBP, Inc.
P.O. Box 515 Dakota City, Nebraska

Prepared by

TRC ENVIRONMENTAL CORPORATION
Suite 412
1307 Butterfield Road
Downers Grove, Illinois 60515
(630) 810-1122

DISCLAIMER

This report is intended for use solely by IBP, Inc. for the specific purposes described in the contractual documents between TRC Environmental Corporation and IBP, Inc.. All professional services performed and reports generated by TRC have been prepared for IBP, Inc. purposes as described in the contract. The information, statements and conclusions contained in the report have been prepared in accordance with the work statement and contract terms and conditions. The report may be subject to differing interpretations and/or may be misinterpreted by third persons or entities who were not involved in the investigative or consultation process. TRC Environmental Corporation therefore expressly disclaims any liability to persons other than IBP, Inc. who may use or rely upon this report in any way or for any purpose.

TABLE OF CONTENTS

Section	Page
1.0 INTRODUCTION	1
1.1 OVERVIEW	1
1.2 SCOPE OF WORK	1
2.0 SUMMARY OF RESULTS	3
2.1 SUMMARY OF RESULTS	3
3.0 PROCESS DESCRIPTION AND OPERATION	4
3.1 GENERAL PLANT ACTIVITIES	4
4.0 SAMPLING LOCATIONS	5
4.1 FIRST PACKED BED SCRUBBER OUTLET	5
4.2 CONDENSER OUTLET	5
5.0 SAMPLING PROCEDURES	6
5.1 OVERVIEW	6
5.2 FIELD PROGRAM DESCRIPTION	6
5.3 PRESAMPLING ACTIVITIES	6
5.3.1 Equipment Calibration	7
5.3.2 Glassware Preparation	8
5.3.3 Sample Media Preparation	8
5.3.4 Continuous Emissions Monitoring	8
5.3.5 NO ₂ to NO Conversion Efficiency	11
5.4 ONSITE SAMPLING ACTIVITIES	11
5.4.1 Determination of the TCEM System Response Time	11
5.4.2 EPA Methods 1 and 2 for Velocity Measurements and Cyclonic Flow ..	11
5.4.3 EPA Methods 3A for Flue Gas Molecular Weight	12
5.4.4 EPA Method 4 for Moisture	12
5.4.5 EPA Method 5 for Particulate Matter	12
5.4.6 Emissions Testing for O ₂ , CO ₂ , CO, SO ₂ and NO _x	14
5.4.7 Emissions Testing for TGNMO	15
5.4.7.1 EPA Method 25 for TGNMO	15
6.0 ANALYTICAL PROCEDURES AND CALCULATIONS	16
6.1 ANALYTICAL PROCEDURES	16
6.1.1 Particulate Matter	16
6.2 CALCULATIONS	16
6.2.1 Flowrates and Isokinetics	16

6.2.2	Particulate Matter - Grains per Dry Standard Cubic Foot	17
6.2.3	Particulate Matter - Pounds Per Hour	17
6.2.4	SO ₂ - Pounds Per Hour	17
6.2.5	TGNMO - Pounds Per Hour	18
7.0	QUALITY ASSURANCE	19
7.1	OVERVIEW	19
7.2	FIELD QUALITY CONTROL SUMMARY	19
7.2.1	Calibration Gases	19
7.2.2	Instrument Calibrations	19
7.2.3	Calibration Procedures	19
7.2.4	Equipment Leak Checks	20
7.2.5	Cyclonic Flow Check	20
7.2.6	Method Blanks	20
7.3	SAMPLE CHAIN OF CUSTODY	20
7.4	DATA REDUCTION, VALIDATION, AND REPORTING	21
7.4.1	Field Data Reduction	21
7.4.2	Laboratory Analysis Data Reduction	21
7.4.3	Data Validation	21
7.4.4	Data Reporting	22
7.5	EXCEPTIONS	22

TABLES

Number		Page
1-1	Sampling Locations and Test Parameters	2
2-1	Summary of Test Results	3
5-1	Calibration Gas Concentrations	10
5-2	Performance Criteria	10

APPENDICES

A	Field Sampling Data Sheets
B	Sample Calculations
C	Process Data
D	Laboratory Data
E	Equipment Calibration Sheets

SECTION 1.0 INTRODUCTION

1.1 OVERVIEW

IBP, Inc. (IBP) operates a rendering plant located in Dakota City, Nebraska. This test program determined the emission rates of a number of pollutants from the Supercooker.

TRC Environmental Corporation (TRC) of Downers Grove, Illinois was retained by IBP to provide sampling and analytical support to determine the actual emission rates of the Supercooker.

IBP had emissions testing conducted for particulate matter (PM), sulfur dioxide (SO₂), nitrogen oxides (NO_x), Carbon Monoxide (CO), and total gaseous non-methane organics (TGNMO) as carbon.

Sampling and analysis procedures described in this document were conducted using procedures deemed acceptable by the NDEQ and the USEPA. TRC was responsible for the collection and analysis of all flue gas samples.

1.2 SCOPE OF WORK

The test program approach involved conducting a series of three test runs on two sources. Each test determined the concentration and emission rates for O₂, CO₂, NO_x, SO₂, CO, TGNMO, and PM. Velocity and moisture were only determined during testing on the outlet of the first packed bed scrubber for each run. Previous flow and moisture data was used on the Supercooker condenser outlet. Table 1-1 presents the sampling locations and the parameters tested at each location.

The results of the test program are presented in a format acceptable to the NDEQ.

The required measurement parameters and test methods used to accomplish these objectives were:

- 40 CFR Part 60, Appendix A, USEPA Reference Methods (RM)
 - RM 1 & 2 - Velocity and Flowrate
 - RM 3A - Oxygen and Carbon Dioxide
 - RM 4 - Moisture
 - RM 5 - Particulate Matter
 - RM 6C - Sulfur Dioxide
 - RM 7E - Oxides of Nitrogen
 - RM 10 - Carbon Monoxide
 - RM 25- Total Hydrocarbons

TABLE 1-1. SAMPLING LOCATIONS AND TEST PARAMETERS

Sampling Location	Parameters
Supercooker Condenser Outlet	O ₂ , CO ₂ , NO _x , SO ₂ , CO
First Packed bed scrubber outlet	O ₂ , CO ₂ , NO _x , SO ₂ , CO, TGNMO, PM

SECTION 2.0 SUMMARY OF RESULTS

2.1 SUMMARY OF RESULTS

All data are being reported without qualification. All tests on this unit are reported without any anomaly. Previous flow and moisture data was used to calculate lb/hr emission rates on the condenser outlet.

Testing was performed at the outlet of the first packed bed scrubber initially. This location was picked because of its ability to meet Method 1 criteria. It was discovered during this series of tests that this particular location had two unidentified sources also piped into the packed bed scrubber system. At the discretion of the NDEQ observer three one hour tests were also performed at the condenser outlet location for O₂, CO₂, NO_x, SO₂, CO. Previous flowrate and moisture data was deemed acceptable to determine and compare emission rate results from the two locations.

The emission rates calculated were virtually identical except for the NO_x lb/hr. It is determined that the two unidentified source are contributing to the higher NO_x lb/hr number. Table 2-1 summarizes the findings of the test series conducted on July 21, 1998. Supporting data can be found on the field sampling data sheets in Appendix A.

Table 2-1 Summary of Results

Location	NO _x lb/hr	SO ₂ lb/hr	CO lb/hr	TGNMO lb/hr	PM lb/hr
Condenser Outlet	.0097	.0669	.0320	N/A	N/A
Scrubber Outlet	.0349	.0627	.0305	.8122	.3820

SECTION 3.0

PROCESS DESCRIPTION AND OPERATION

3.1 GENERAL PLANT ACTIVITIES

IBP operates a slaughter, processing, plant at Dakota City, Nebraska. The Inedible Supercooker is used to cook raw inedible meat and bone, to produce crax and tallow. Inedible tallow is sold as a product, and inedible crax is blended with LoPro from the edible system to produce inedible meat and bone meal. Flue gas from the inedible Supercooker was tested for O₂, CO₂, NO_x, SO₂, CO, TGNMO, and PM prior to exhausting to the atmosphere.

The plant was operated at normal operating conditions during the series of emission testing. Supporting process data can be found in Appendix C.

SECTION 4.0 SAMPLING LOCATIONS

4.1 FIRST PACKED BED SCRUBBER OUTLET

This location was chosen because of its ability to meet Reference Method 1 criteria. The location was a rooftop location. The sampling ports were 90 degrees offset of each other. The inside stack diameter was 26.0 inches. The ports were located 15 ft upstream and 21 inches downstream of a disturbance. TRC determined the sampling traverse points in accordance with EPA Method 1. A copy of the data sheet can be found in Appendix A.

4.2 CONDENSER OUTLET

Sampling was conducted on Supercooker condenser outlet exhaust. The inside stack dimension was measured to be 6 inches in diameter; therefore, the stack area equals 28.3 square inches. TRC utilized the flowrate and moisture from testing conducted in September of 1997 by TRC Environmental Corporation.

SECTION 5.0

SAMPLING PROCEDURES

5.1 OVERVIEW

This section describes the procedures that TRC followed during the field sampling program. Throughout the program TRC followed EPA Reference Methods 40 CFR Part 60 Appendix A. Any deviations from the specified test methods are fully documented and approved by the NDEQ observer.

The remainder of this section is divided into several subsections: Field Program Description, Presampling Activities, and Onsite Sampling Activities.

5.2 FIELD PROGRAM DESCRIPTION

The field sampling was conducted by TRC during July 1998. The units operated in their normal seasonal operating range. Each test run was 60 minutes in length and consisted of a velocity traverse and effluent sampling as specified for O₂, CO₂, SO₂, CO, NO_x, TGNMO and PM.

The test methods utilized were in accordance with 40 CFR Parts 60, Appendix A and are as follows:

- Method 1 and 2 - Velocity Profile
- Method 4 - Percent Moisture
- Method 6C - SO₂
- Method 25 - Total Gaseous Non-Methane Organics as carbon
- Method 3A - O₂ and CO₂
- Method 5 - Particulate Matter
- Method 7E - NO_x

5.3 PRESAMPLING ACTIVITIES

Presampling activities include equipment calibration, precleaning of the sample train glassware, and other miscellaneous tasks. Each of these activities are described or referenced in the following subsections. Other presampling activities include team meetings, equipment packing, and finalization of all details leading up to the coordinated initiation of the sampling program.

5.3.1 Equipment Calibration

TRC follows an orderly program of positive actions to prevent the failure of equipment or instruments during use. This preventative maintenance and careful calibration helps to ensure accurate measurements from field and laboratory instruments.

Once the equipment has gone through the cleaning and repair process it is then calibrated. All equipment that is scheduled for field use is cleaned and checked prior to calibration. Once the equipment has been calibrated, it is packed and stored to ensure the integrity of the equipment. An adequate supply of spare parts is taken in the field to minimize downtime from equipment failure.

Inspection and calibration of the equipment is a crucial step in ensuring the successful completion of the field effort. All equipment is inspected for proper operation and durability prior to calibration. Calibration of the following equipment is conducted in accordance with the procedures outlined in EPA documents entitled "*Quality Assurance Handbook for Air Pollution Measurement Systems; Volume III - Stationary Source Specific Methods*" (EPA-600/4-77-027b) and 40 CFR Part 60 Appendix A. All calibrations will be performed prior to test program.

- Probe Nozzles (QA Handbook, Vol III, Section 3.4.2, pp. 19) - average three ID measurements of nozzle; difference between high and low ≤ 0.1 mm. Recalibrates, reshape and sharpen when nozzle becomes nicked, dented, or corroded.
- Pitot tubes (QA Handbook, Vol III, Section 3.1.2, pp. 1-13) - measured for appropriate spacing and dimensions or calibrated in a wind tunnel. Rejection criteria given on the calibration sheet. Post-test check - inspect for damage.
- Thermocouples (QA Handbook, Vol III, Section 3.4.2, pp. 12-18) - verified against a mercury-in-glass thermometer at three points including the anticipated measurement range. Acceptance limits - impinger $\pm 2^{\circ}\text{F}$; DGM $\pm 5.4^{\circ}\text{F}$; stack ± 1.5 percent of stack temperature.
- Dry gas meters (EPA 40 CFR Part 60, Method 5, Section 5.3) - calibrated against a wet test meter. Acceptance criteria - pretest $Y_i = Y = \pm 0.02$; post test $Y = \pm 0.05 Y_i$.

- Field barometer (QA Handbook, Vol III, Section 3.4.2, pp. 18-19) - compared against a mercury-in-glass barometer or use Airport Station BP and corrected for elevation. Acceptance criteria - ± 0.02 in. Hg; post-test check - same.
- Analytical balances (QA Handbook, Vol III, Section 3.4.2, pp. 19) - Acceptance criteria - calibrate with Standard Class-S weights within ± 0.5 g of stated value. Rejection criteria: Have manufacturer recalibrates or adjust.
- Method 25 rotometers - (QA Handbook Section 3.17.2, pp. 4-8) - calibrated against a standard bubble meter. Acceptance criteria - pretest $Y_i = 0.05Y$; post-test check - average 3 run theoretical volume $\pm 10\%$ of average 3 run actual volume.

5.3.2 Glassware Preparation

Sample train glassware and sample containers did require specialized precleaning to avoid contamination of the sample from the collection container or devices. The sample train glassware necessary for the Method 5 sampling was precleaned using an alconox soap and water wash with a tap water rinse. Deionized water was used for final rinsing followed by air drying. The glassware was then sealed with parafilm.

5.3.3 Sample Media Preparation

All reagents were checked in accordance with TRC's existing QC Program to minimize the probability of using contaminated solvents. This includes the use of spectro-grade solvents from the same lot and the collection and analysis of the appropriate blanks.

5.3.4 Continuous Emissions Monitoring

TRC conducted continuous emissions monitoring at each source as specified by the permit for oxygen (EPA Method 3A), carbon dioxide (EPA Method 3A), oxides of nitrogen (EPA Method 7E), sulfur dioxide (EPA Method 6C) and carbon monoxide (EPA Method 10) during all test conditions. TRC did follow procedures outlined in the EPA Publication 340/1-83-016 regarding setup and operation of its Transportable Continuous Emissions Monitoring System (TCEMS).

The TCEMS consists of three subsystems: sample acquisition/conditioning, sample analysis, and a data acquisition system. Sample acquisition/conditioning is designed to deliver a representative sample of the stack gas stream to the sample analysis subsystem. Since the gas stream must be clean and dry for the O₂, CO₂, SO₂, CO, and NO_x analyzers, a glass fiber filter and noncontact moisture condenser was used for particulate and moisture removal. The sample line was heat-traced to eliminate inline condensation prior to the condenser.

In each case, accurate interpretation of analyzer response requires the systematic calibration of the instrument against gases of known concentrations.

The data acquisition subsystem consists of a Campbell 21X digital data logger designed to receive and log instrument signals (raw voltages) at user defined intervals. The resulting values are instantaneously accessible. Once the system is set up, the TCEM is connected to a power source and brought online. Sample line and signal wires are strung between the sampling and TCEM locations, and the probe is placed in the duct at the sampling location.

Prior to insertion of the probe into the stack, the sample/acquisition system is leak checked by the following procedure:

- a. plug probe;
- b. observe that flow in rotameter reaches zero Lpm;
- c. observe vacuum; and
- d. confirm that sample vacuum during sampling does not exceed vacuum attained during leak check.

The initial phase of instrumental analysis methods requires calibration of all involved monitors. At the beginning of each day, direct instrument calibrations for zero and upscale gases were performed prior to initiation of testing by direct calibration gas injection. System calibrations were performed both prior to and following each run using zero and one upscale gas concentration. This is accomplished by directing calibration gas through the sample line and conditioning system to assess system bias. Following completion of the required runs, final system calibrations were performed. These procedures allow for determination of initial and final system bias, as well as system drift. Typical calibration gas values and instrument range settings are listed below:

TABLE 5-1 Analyzer Calibrations Gases

Analyzer	Range	Conc.	High	Mid	Low	Zero
NO _x	0 - 100	ppm	84.3	46.0	NA	nitrogen
O ₂	0 - 25	%	18.0	10.2	NA	nitrogen
CO ₂	0 - 20	%	17.7	9.9	NA	nitrogen
CO	0-100	ppm	86.9	30.3	N/A	nitrogen
SO ₂	0-100	ppm	88.7	45.1	N/A	nitrogen

These analyzer ranges were adjusted on the first day of test after preliminary measurements are taken.

Calibration gases used were EPA Protocol 1, traceable to the National Institute of Standards and Technology (NIST). The measurement system performance specifications as stated in 40 CFR 60 Appendix A, for Methods 3A, 6C, 7E, and 10 are listed below and were the performance criteria for this program.

Table 5-2 Performance Criteria.

Procedure	Performance Criteria		
	Nox / SO ₂ M7E/ M6C	O ₂ /CO ₂ M3A	CO M10
Zero Drift, % of range	< ± 3	< ± 3	< ± 3
Calibration Drift, % of range	< ± 3	< ± 3	< ± 3
Response time, seconds	≤ 60	≤ 60	≤ 60
Interference Response, % of range	< ± 2	< ± 2	NA
NO ₂ to NO Converter, % efficiency	> 90	NA	NA
Calibration Error, % of cal gas	< ± 2	< ± 2	< ± 5

5.3.5 NO₂ to NO Conversion Efficiency

The NO₂ to NO converter was checked in the following manner. A mid-level NO gas was introduced into a 30 liter Tedlar bag and diluted one-to-one (1:1) with air. The bag was then hooked up to the sampling system and drawn through the system for 30 minutes. The converter check did meet the method requirements. A copy of the converter check can be found in Appendix E.

5.4 ONSITE SAMPLING ACTIVITIES

Onsite sampling activities included the determination of the response time of the TCEM system at four sources. A copy of this data sheet can be found in Appendix E.

5.4.1 Determination of the TCEM System Response Time

After the TCEM system is set up, response time was determined. Zero gas was introduced at the TCEM system calibration gas valve assembly until a stable zero response was achieved. Once achieved, the calibration gas valve at the manifold was switched to the high span gas. Response Time is the recorded time it takes the analyzer to respond to within 90% of the cal gas value. This upscale response was conducted three times. A down scale response time was also conducted three times starting at a high span calibration value and switching to the zero span gas.

5.4.2 EPA Methods 1 and 2 for Velocity Measurements and Cyclonic Flow

Velocity traverses were conducted at the scrubber outlet sampling location with an S-type pitot assembly in accordance with EPA Reference Methods 1 and 2. An S-type pitot tube with an attached inclined manometer was used to measure the exhaust velocities. An attached Type-K thermocouple with remote digital display was used to determine the flue gas temperature. During the compliance test program, velocity measurements were conducted during each test run. The required number of velocity measurements points for each sampling location were determined following EPA Method 1.

A cyclonic flow check was conducted on the outlet duct in accordance with Section 2.4 of EPA Method 1. This procedure is referred to as the nulling technique. An S-type pitot tube connected to an inclined manometer is used in this method. The pitot tube is positioned at each traverse

point so that the face openings of the pitot tube are perpendicular to the stack cross-sectional plane. This position is called the "0° reference". The velocity pressure (ΔP) measurement are noted. If the ΔP reading is zero, the cyclonic angle is recorded as 0°. If the ΔP reading is not zero, the pitot tube is rotated clockwise or counter clockwise until the ΔP reading becomes zero. This angle is then measured with a leveled protractor and reported to the nearest degree. After this null technique is applied at each traverse point, the average of the cyclonic angles is calculated. If this average is less than 20°, the flow condition in the source is acceptable to test. Cyclonic flow was not present in any of the sources tested. Supporting data sheets can be found in Appendix A.

5.4.3 EPA Methods 3A for Flue Gas Molecular Weight

Oxygen and carbon dioxide concentrations were determined according to EPA Reference Method 3A, *"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)"*.

These concentrations are needed to calculate the molecular weight of the gas streams for calculating the volumetric flow of each sampling location.

5.4.4 EPA Method 4 for Moisture

Moisture was determined according to EPA Reference Method 4, *"Determination of Moisture Content in Stack Gases"*. The principle of this method is to remove the moisture from the sample stream either volumetrically or gravimetrically. Method 4 was used in conjunction with the Method 5 sampling trains.

5.4.5 EPA Method 5 for Particulate Matter

Particulate matter was determined according to EPA Method 5, *"Determination of Particulate Emissions From Stationary Sources"*.

The sampling train consisted of a heated, glass-lined probe, with a stainless steel button-hook nozzle. A thermocouple and S-type pitot tube were attached to the probe for measurement of gas temperature and velocity measurements. The sample gas passed through the probe assembly to a heated glass filter holder assembly containing a quartz fiber filter and a Teflon frit support. The filter holder was maintained at $248^{\circ}\text{F} \pm 25^{\circ}\text{F}$ throughout each test run. Downstream of the

heated filter, the sample gas passed through a series of four ice-cooled impingers kept below 68°F to enable condensation of entrained moisture. The first and second impingers contained 100 mL DI water. The third impinger was empty. The fourth impinger contained 200 grams of silica gel. The impingers were followed by a Nutech Model 2010 dry gas meter, pump, and calibrated orifice meter.

Sampling was conducted under isokinetic (± 10 percent) conditions with readings of flue gas parameters recorded at every sampling point during the traverse.

Leak checks of the entire Method 5 sampling train were performed before and after each sampling run. All leak checks and leakage rates are documented on the relevant field test data sheet. The acceptance criteria for the Method 5 train is a leak rate of ≤ 0.02 cfm at the highest vacuum obtained during the run.

Following the completion of each test run, the Method 5 train was transported to a recovery area onsite. The sample recovery sequence was as follows:

- Remove the sampling train to the recovery area.
- Note the condition of the train (i.e., filter condition, impinger contents color, silica gel color, etc.).
- Sample No. 1 - Disassemble the filter housing and transfer the filter to its original glass petri dish. Seal the container with Teflon[®] tape and label it with the appropriate sample information.
- Sample No. 2 - The front half of the train, nozzle, probe, and front-half filter housing, were brush-rinsed with acetone into an amber glass container with a Teflon-lined cap. The rinse procedure was performed three times after which the container was sealed and labeled.
- Sample No. 3 - The contents of the first, second and third impingers were measured for volume and transferred to a clean polyethylene container. The impingers, right angle, and U-tubes were rinsed with distilled deionized water into the sample container. The container was then sealed and labeled.

- The silica gel is returned to its original container and weighed to obtain a final weight.
- All containers were checked to ensure proper sealing, proper labeling, and that all liquid levels were marked. All samples were then logged onto the chain-of-custody record.

The Method 5 train resulted in the following samples:

- Filter
- Front-Half Acetone Rinse
- Back-Half DI water

5.4.6 Emissions Testing for O₂, CO₂, SO₂, CO and NO_x

TRC conducted continuous emissions monitoring for oxygen (EPA Method 3A), carbon dioxide (EPA Method 3A), sulfur dioxide (EPA Method 6C), oxides of nitrogen (EPA Method 7E) and carbon monoxide (EPA Method 10).

The sampling train starts with a heated (248°F ± 25°F) stainless-steel sampling probe and filter box. The sample stream was then drawn through heated (248°F ± 25°F) Teflon[®] sample line and a sample conditioner to remove the moisture from the gas stream. The sample was then drawn through Teflon[®] tubing by a leak-free Teflon[®] double diaphragm pump to a stainless-steel sample manifold with an atmospheric by-pass rotameter. The O₂, CO₂, SO₂, CO, and NO_x analyzers did draw samples from this manifold.

All TCEMS data was recorded as averages by a Campbell 21X digital data logger designed to receive and log instrument signals. The results will be expressed in ppm for SO₂, CO, NO_x and in percent for O₂ and CO₂.

5.4.7 Emissions Testing for TGNMO

Total hydrocarbons were determined in accordance with EPA Method 25, "*Determination of Total Gaseous Organic Concentration*". Single point sampling was conducted.

5.4.7.1 USEPA Method 25 Train for Total Gaseous Non-Methane Organics

TGNMO sampling as conducted following the criteria of USEPA Reference Test Method 25. Flue gas was sampled from the scrubber exhaust at a constant rate through a heated probe and filter and a chilled condensate trap by means of an evacuated sample tank. The heated probe and oven were kept at a temperature of $\geq 265^{\circ}\text{F}$ and $250 \pm 5^{\circ}\text{F}$ respectively during the sampling. After completion of each test run, the trap and tank were sealed, labeled and documented on the chain-of-custody record. All traps were kept under dry ice until the moment of analysis. Three one-hour tests were conducted. A schematic representation of the sampling train is included as Figure 3-1.

Leak checks on the Method 25 train were performed before each sampling run. All leak checks and leakage rates are documented on the relevant field test data sheet. Copies of the field data sheets and summary calculations are included in Appendix A.

SECTION 6.0

ANALYTICAL PROCEDURES AND CALCULATIONS

This section delineates the analytical procedures and calculations which were used during the IBP Compliance Test Program.

6.1 ANALYTICAL PROCEDURES

6.1.1 Particulate Matter

Particulate sampling was accomplished by following the procedures in EPA Method 5. The sampling of particulate was done with the use of an EPA Method 5 sampling train. Particulate analysis was conducted by TRC Environmental Corporation.

All filters for the test program were labeled on the back side with an identification number. The filters were desiccated to a constant weight. The filters were then placed in glass petri dishes and sealed with Teflon[®] tape. An identification label is placed on the dish. The beakers used for the dry down of the acetone rinse were cleaned and dried in an oven at 225°F. The beakers were desiccated to a constant weight.

The front-half acetone rinse was air dried in a tared beaker and then desiccated and weighed to a constant weight. The filter is desiccated and weighed to constant weight. The sum of the net weights for the probe wash and filter catch is used to calculate the concentration of particulate matter in gr/dscf. The emission rate in lbs/hr was also calculated.

6.2 CALCULATIONS

6.2.1 Flowrates and Isokinetics

Calculations for the determination of gas velocity at stack conditions (afpm), gas volumetric flow rate at stack conditions (acfm), and gas volumetric flow rate at standard conditions (dscfm) and percent isokinetics can be found in Appendix B.

6.2.2 Particulate Matter - Grains per Dry Standard Cubic Foot

Emission rates in terms of grains per dry standard cubic feet (gr/dscf) were calculated using the pollutant emission rate in terms of milligrams (mg) divided by the volume of gas collected (dscf).

$$\text{gr/dscf} = 0.0154 \times \left[\text{mg} \div \left\{ \frac{528 \times (Y) \times (VM) \times (PB + PM)}{29.92 \times (TM + 460)} \right\} \right]$$

where:

dscf	=	Dry standard cubic feet at 68°F (528°R) and 29.92 inches Hg
0.0154	=	0.0154 grains per milligram
Y	=	Dry gas meter calibration factor
VM	=	Volume metered, ft ³
PB	=	Barometric Pressure, inches Hg
PM	=	Average Orifice Pressure Drop, inches Hg (Avg. ΔH inches H ₂ O ÷ 13.6)
TM	=	Average Dry Gas Temperature at Meter, °F

6.2.3 Particulate Matter - Pounds Per Hour

Emission rates in terms of pounds per hour (lbs/hr) were calculated using the particulate matter emission rate in terms of grains per dry standard cubic feet (gr/dscf), outlet stack flowrate - dscfm (Qs), 60 minutes/hour, divided by 7000 grains in a pound (gr/lb).

$$\text{lbs/hr} = \frac{\text{gr/dscf} \times Q_s \times 60}{7000}$$

6.2.4 SO₂, NO_x and CO - Pounds Per Hour

Emission rates in terms of pounds per hour (lbs/hr) were calculated using the emission rate in terms of micrograms per dry standard cubic foot (μg/dscf), flowrate - dscfm (Qs), 60 minutes/hour, divided by 453,600,000 μg/lb.

$$\text{lbs/hr} = (\text{ppmv})(\text{mw})(\text{dscfm})(1.554 \times 10^{-7})$$

NO _x molecular weight =	46
SO ₂ molecular weight=	64
CO molecular weight=	28

6.2.5 TGNMO - Pounds Per Hour

Emission rates in terms of pounds per hour (lbs/hr) THC's were calculated using the pollutant emission rate in terms of parts per million (ppm/dry), flowrate - dscfm (Qs), molecular weight of the pollutant (MW), 60 minutes/hour, divided by 385.3 x 10⁶ dscf/lb-mole @ 68°F (20°C).

$$\text{lbs/hr} = \frac{\text{ppm} \times Q_s \times \text{MW} \times 60}{385.3 \times 10^6}$$

where:

TGNMO as carbon molecular weight = 12

SECTION 7.0 QUALITY ASSURANCE

7.1 OVERVIEW

TRC Environmental Corporation management is fully committed to an effective Quality Assurance/Quality Control Program whose objective is the delivery of a quality product. For much of TRC's work, that product is data resulting from field measurements, sampling and analysis activities, engineering assessments, and the analysis of gathered data for planning purposes. The Quality Assurance Program works to provide complete, precise, accurate, representative data in a timely manner for each project, considering both the project's needs and budget constraints.

This section highlights the specific QA/QC procedures to be followed on this test program.

7.2 FIELD QUALITY CONTROL SUMMARY

7.2.1 Calibration Gases

All calibration gases used to conduct instrument calibrations were prepared in accordance with EPA Protocol 1, or are traceable to NIST.

7.2.2 Instrument Calibrations

All instrument calibrations did meet the performance criteria defined in 40 CFR 60 Appendix A, Methods 3A, 6C, 7E and 10.

7.2.3 Calibration Procedures

Calibration of the field sampling equipment were performed prior to the field sampling effort. Copies of the calibration sheets were submitted to the field team leader to take onsite and for the project file. Calibrations were performed as described in the EPA publications "*Quality Assurance Handbook for Air Pollution Measurement Systems; Volume III - Stationary Source Specific Methods*" (EPA-600/4-77-027b) and EPA 40 CFR Part 60 Appendix A. Equipment calibrated includes the sample metering system, nozzles, thermocouples, and pitot tubes. All

calibrations were available for review at the test program. Copies of the equipment calibration forms can be found in Appendix E.

7.2.4 Equipment Leak Checks

Prior to sampling, each sampling train were leak checked according to the procedures outlined in EPA Reference Method 5. During the course of a test run, a leak check were conducted before and after every test. Final leak checks were performed to ensure that no leaks developed in the train during the course of the test run. All leakage rates, were recorded on the appropriate field data sheet.

7.2.5 Cyclonic Flow Check

The presence of cyclonic flow within the source was checked during preliminary traverses prior to sampling, in accordance with Section 2.4 of EPA Method 1. Cyclonic flow was not detected above 20 degrees in any of the sources tested.

7.2.6 Method Blanks

One Method blank for the Method 5 and Method 25 sampling trains was taken during the field sampling program. This is to ensure sample quality and integrity.

7.3 SAMPLE CHAIN OF CUSTODY

The chain-of-custody of the samples were initiated and maintained as follows:

- Each sample was collected, labeled, sealed, and the liquid level marked on appropriate samples.
- The sample were then recorded on the sample chain-of-custody form.
- Custody of the samples is retained by TRC.

7.4 DATA REDUCTION, VALIDATION, AND REPORTING

Specific QC measures were used to ensure the generation of reliable data from sampling and analysis activities. Proper collection and organization of accurate information followed by clear and concise reporting of the data is a primary goal in all projects.

7.4.1 Field Data Reduction

Data sheets were checked in the field by the field team leader and one other team member to insure they were completed prior to transport to the office. Data was not calculated in the field.

7.4.2 Laboratory Analysis Data Reduction

Analytical results were reduced to concentration units specified by the analytical procedures, using the equation provided in the analytical procedures.

7.4.3 Data Validation

TRC supervisory and QC personnel did use validation methods and criteria appropriate to the type of data and the purpose of the measurement. Records of all data was maintained, including that judged to be an "outlying" or spurious value. The persons validating the data did have sufficient knowledge of the technical work to identify questionable values.

Field sampling data was validated by the Field Team Leader and/or the QC Coordinator based on their review of the adherence to an approved sampling protocol and written sample collection procedure.

The following criteria was used to evaluate the field sampling data:

- Use of approved test procedures;
- Proper operation of the process being tested;
- Use of properly operating and calibrated equipment;
- Leak checks conducted before and after tests;
- Use of reagents conforming to QC specified criteria;
- Proper chain-of-custody maintained.

The criteria listed below was used to evaluate the analytical data:

- Use of approved analytical procedures;
- Use of properly operating and calibrated instrumentation;
- Acceptable results from analyses of QC samples (i.e., the reported values should fall within the 95 percent confidence interval for these samples).

7.4.4 Data Reporting

All data is reported in standard units depending on the measurement and the ultimate use of the data. The bulk of the data is computer processed and reported as follows:

- Exhaust Gas Stream
 - Gas Properties:
 - a. Moisture, dscf and percent by volume
 - b. Flow rate, dscfm and acfm
 - c. Pressure, mm of Hg
 - d. Temperature, °F
 - Particulate:
 - a. gr/dscf and gr/ascf
 - b. lbs/hr
 - Gas Pollutants/Diluents
 - a. O₂, percent
 - b. CO₂, percent
 - d. NO_x, SO₂ and CO ppmvd, lbs/hr
 - e. TGNMO, ppmc, lbs/hr

7.5 EXCEPTIONS

Any deviations from the test plan were approved by the NDEQ on-site observer when present, and are documented in the report.

APPENDIX A
FIELD SAMPLING DATA SHEETS

IBP Dakota City, NE SuperCooker

Run No.	1	2	3	
Date	22-Jul-98	22-Jul-98	22-Jul-98	
Start Time	10:30	18:10	20:20	
Stop Time	11:32	19:13	21:23	AVERAGES
Nozzle Diameter, in.	0.244	0.244	0.244	
Barometric Pressure, in. Hg	29.05	29.05	29.05	29.05
Net Sampling Time, minutes	60.0	60.0	60.0	60.00
Volume Metered, cf	45.869	46.943	44.968	45.927
Avg. DGM Temp, F	76.4	92.7	86.4	85.2
AVG Delta H, in of H2O	1.77	1.86	1.74	1.79
AVG Delta H, in of Hg	0.1301	0.1368	0.1283	0.1317
DGM Calibration Factor	0.982	0.982	0.982	0.982
Volume of Gas Collected, dscf	43.246	42.963	41.618	42.609
Total Water Collected, mL	47.0	46.0	57.0	50.0
Volume of Water Vapor, scf	2.216	2.169	2.688	2.358
Moisture, %	4.9	4.8	6.1	5.2
Dry Mole Fraction, 100-%M	0.9513	0.9519	0.9393	0.9475
CO2 at Stack, % dry	0.20	0.10	0.10	0.13
O2 at Stack, % dry	20.10	20.20	20.20	20.17
CO + N2, % dry	79.70	79.70	79.70	79.70
Dry Molecular Weight, lb/lb mole	28.84	28.82	28.82	28.83
Wet Molecular Weight, lb/lb mole	28.31	28.30	28.17	28.26
Excess Air at Stack, %	2136.5	2402.5	2402.5	2313.8
Stack Area, sq. in.	530.9	530.9	530.9	530.9
Static Pressure, in. of H2O	-12.25	-12.25	-12.25	-12.25
Stack Pressure, in. of Hg	28.15	28.15	28.15	28.15
Avg. Stack Temp., F	80.5	89.7	97.7	89.3
Avg. Sqroot of Delta P	0.7226	0.7396	0.7236	0.7286
SDE Average	16.799	17.340	17.088	17.076
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	2564.5	2647.3	2615.1	2609.0
Stack Flowrate, wet acfm	9,455	9,760	9,641	9,619
Stack Flowrate, dry scfm	8,266	8,396	8,067	8,243
Isokinetics, %	99.0	96.8	97.6	97.8
PARTICULATE DATA -- FRONT HALF ONLY				
Front Half Rinse (FHACE), mg	23.7	10.6	6.7	13.7
Particulate Filter (PF), mg	1.8	1.0	1.3	1.4
Organic, mg	1.1	0.8	0.8	0.9
Total Dissolved Solids, mg	3.0	0.7	5.8	3.2
Total Particulate Collected, mg	25.5	11.6	8.0	15.0
Grain Loading, gr/dscf	0.0091	0.0042	0.0030	0.0054
Grain Loading, gr/acf	0.0079	0.0036	0.0025	0.0047
Grain Loading, gr/dscf @ 7% O2	0.0063	0.0029	0.0020	0.0037
Emission Rate, lb/Hr	0.643	0.299	0.205	0.382

IBP / DC

Tests performed after 1st packed bed scrubber prior to 2nd bed

Run No.	SC-1	SC-2	SC-3	
Date	July 22,1998	July 22,1998	July 22,1998	
Start Time	1030	1810	2020	
Stop Time	1130	1910	2120	AVERAGES
Barometric Pressure, in. Hg	29.05	29.05	29.05	29.05
Net Sampling Time, minutes	30.0	30.0	30.0	30.0
Volume Metered, cf	45.869	46.943	44.968	45.927
Avg. DGM Temp, F	76.4	92.700	86.400	85.2
AVG Delta H, in of H2O	2.00	2.000	2.000	2.00
AVG Delta H, in of Hg	0.1471	0.1471	0.1471	0.1471
DGM Calibration Factor	0.982	0.982	0.982	0.982
Volume of Gas Collected, dscf	43.271	42.978	41.645	42.631
Total Water Collected, mL	47.0	46.0	57.0	50.0
Volume of Water Vapor, scf	2.216	2.169	2.688	2.358
Moisture, %	4.87	4.80	6.06	5.25
Dry Mole Fraction, 100-%M	0.9513	0.9520	0.9394	0.9475
CO2 at Stack, % dry	0.2	0.1	0.1	0.1
O2 at Stack, % dry	20.1	20.2	20.2	20.2
CO + N2, % dry	79.7	79.7	79.7	79.7
Dry Molecular Weight, lb/lb mole	28.83	28.83	28.83	28.83
Wet Molecular Weight, lb/lb mole	28.30	28.31	28.17	28.26
Stack Diameter, in	26	26	26	26.00
Stack Area, sq. in. (@ pitot meas. location)	530.9	530.9	530.9	530.9
Static Pressure, in. of H2O	-12.25	-12.25	-12.25	-12.25
Stack Pressure, in. of Hg	28.15	28.15	28.15	28.15
Avg. Stack Temp., F	80.5	89.7	97.7	89.3
Avg. Sqrroot of Delta P	0.7226	0.7396	0.7236	0.7286
SDE Average	16.799	17.340	17.088	17.076
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	2564.8	2647.1	2614.8	2608.9
Stack Flowrate, wet acfm	9,456	9,760	9,641	9,619
Stack Flowrate, dry scfm	8,268	8,396	8,067	8,243
Stack Flowrate, dry scf/hr	496,056	503,758	483,993	494602.45
Stack Flowrate, wet scf/hr	5.2146E+05	5.2918E+05	5.1523E+05	521956.25
NOx Lb/Hr	0.0362	0.0537	0.0149	0.0349
SO2 Lb/Hr	0.0728	0.0401	0.0751	0.0627
CO Lb/Hr	0.0216	0.0334	0.0366	0.0305
TGNMO Lb/Hr	0.833	0.940	0.663	0.8122

IBP/DC Condenser Outlet prior to packed bed

Flow data from previous testing used to calculate Lb/Hr

Run No.	SC-4	SC-5	SC-6	
Date	July 22,1998	July 22/23,1998	July23,1998	
Start Time	2202	2335	102	
Stop Time	2302	35	202	AVERAGES
Barometric Pressure, in. Hg	29.05	29.05	29.05	29.05
Net Sampling Time, minutes	30.0	30.0	30.0	30.0
Volume Metered, cf	15.415	15.415	15.415	15.415
Avg. DGM Temp, F	84.8	84.8	84.8	84.8
AVG Delta H, in of H2O	2.00	2.00	2.00	2.00
AVG Delta H, in of Hg	0.1471	0.1471	0.1471	0.1471
DGM Calibration Factor	0.982	0.982	0.982	0.982
Volume of Gas Collected, dscf	14.318	14.318	14.318	14.318
Total Water Collected, mL	8.7	8.7	8.7	8.7
Volume of Water Vapor, scf	0.410	0.410	0.410	0.410
Moisture, %	2.79	2.79	2.79	2.79
Dry Mole Fraction, 100-%M	0.9721	0.9721	0.9721	0.9721
CO2 at Stack, % dry	5.1	4.9	2.6	4.2
O2 at Stack, % dry	19.0	19.2	19.8	19.3
CO + N2, % dry	75.9	75.9	77.6	76.5
Dry Molecular Weight, lb/lb mole	29.57	29.55	29.21	29.45
Wet Molecular Weight, lb/lb mole	29.25	29.23	28.90	29.13
Stack Diameter, in	6	6	6	6.00
Stack Area, sq. in. (@ pitot meas. location)	28.3	28.3	28.3	28.3
Static Pressure, in. of H2O	-10.40	-10.40	-10.40	-10.40
Stack Pressure, in. of Hg	28.29	28.29	28.29	28.29
Avg. Stack Temp., F	73.8	73.8	73.8	73.8
Avg. Sqrroot of Delta P	0.7346	0.7346	0.7346	0.7346
SDE Average	16.972	16.972	16.972	16.972
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	2542.7	2543.6	2558.1	2548.1
Stack Flowrate, wet acfm	499	499	502	500
Stack Flowrate, dry scfm	454	454	457	455
Stack Flowrate, dry scf/hr	27,231	27,240	27,396	27288.91
Stack Flowrate, wet scf/hr	2.8011E+04	2.8021E+04	2.8181E+04	28070.74
NOx Lb/Hr	0.0143	0.0055	0.0092	0.0097
SO2 Lb/Hr	0.0562	0.0346	0.1098	0.0669
CO LbHr	0.0365	0.0358	0.0236	0.0320

Traverse Point Location for Circular and Rectangular Ducts

Project Number: 22214 - 0000 - 00012 -

Client: IBP

Date: 7/21/98

Sampling Location: CONDENSER OUTLET

Internal Stack Diameter: 26"

Nipple Length: 2.5


Total Stack Diameter: 28.5

Nearest Upstream Disturbance (C): 15' (180")

Nearest Downstream Disturbance (D): ~~24'~~ 21"


Calculator: DW

Traverse Point Number	Fraction of Stack ID (1/100)	Stack ID	Traverse Point (1 x 2 = Point)	Nipple Length	Traverse Point Location includes nipple
1	.021	26 ^u	.55	2.5 ^k	3.05
2	.067		1.74	"	4.24
3	.118		3.07	"	5.57
4	.177		4.60	"	7.10
5	.250		6.50	"	9.00
6	.356		9.26	"	11.76
7	.644		16.74	"	19.24
8	.750		19.50	"	22.0
9	.823		21.4	"	23.9
10	.892		22.93	"	25.43
11	.933		24.26	"	26.76
12	.979		25.55	"	27.95
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					

[illegible][illegible]

CYCLONIC FLOW CHECK



DATE 7/22/98
 PLANT NAME ZBP
 UNIT NUMBER CONDENSOL OUTLET
 CALCULATIONS PERFORMED BY DW
 CALCULATIONS REVIEWED BY _____
 REVIEW DATE _____



PITOT ANGLE

POINT NUMBER	ANGLE OF PITOT AT NULL READING (DEGREES)	ROTATION TO ANGLE FOR POINT FLOW MEASUREMENT (DEGREES)	ΔP AT FLOW ANGLE	TEMP AT POINT
1	7	clockwise		
2	0	—		
3	10	clockwise		
4	13	clockwise		
5	5	"		
6	2	"		
7	11	counterclockwise		
8	0	—		
9	1	"		
10	4	"		
11	0	—		
12	2	"		
1	5	clockwise		
2	10	clockwise		
3	15	"		
4	15	"		
5	8	"		
6	8	"		
7	4	counterclockwise		
8	5	"		
9	8	"		
10	3	"		
11	3	"		
12	15	"		
AVERAGE	6.42°			

PARTICULATE FIELD DATA



Plant IBP DAKOTA CITY
 Date 7/22/98
 Location DAKOTA CITY
 Operator DW
 Source SUPER COOKER COND. OUT
 Run No. 1
 Sample Box 4
 Meter Box 4
 Meter dH @ 1.9068
 Y = .9821
 Time Start 10:30

Ambient Temperature 75°F
 Barometric Pressure 29.05
 Assumed Moisture % 20 4.0
 Probe Length, in. 5' 6"
 Nozzle Diameter, in. .245, .245, .243
 Stack Diameter, in. 26"
 Probe Heater Setting 248 ± 25
 Oven Heat Setting 248 ± 25
 Pitot Coefficient .84
 Filter No. 585
 Filter Tare Wgt. 601.6

Pre-Test Leak Check
 Meter .001 @ 15" H₂O
 Pitot 0.0 @ 3" H₂O
 Orsat N/A

Point No.	Time	Static Pressure in. H ₂ O	Ts °C	dP in. H ₂ O	Sqr. Rt. dP	dH in. H ₂ O	Vm ft.	Tm Inlet, °F	Tm Outlet, °F	Oven Temp. °F	Imp. Outlet Temp. °F	Vacuum (in. Hg)	PROBE HEAT
1	0	-12.25	80	.50		1.67	717.153	73	73	251	64	5	260
2			80	.56		1.87	718.9	72	72	251	63	6	260
3	5		80	.58		1.94	720.8	73	72	249	61	6	254
4			80	.60		2.00	722.7	76	74	251	50	6	251
5	10		80	.60		2.00	724.8	77	73	255	55	6	253
6			81	.61		2.04	726.9	78	74	250	56	6	251
7	15		80	.56		1.87	728.8	80	75	251	58	6	255
8			80	.46		1.55	730.8	81	76	250	58	6	257
9	20		79	.65		2.20	732.5	82	76	250	58	6	257
10			80	.41		1.39	734.6	83	77	250	59	4	258
11	25		80	.45		1.52	736.4	84	78	251	59	4	259
12			79	.40		1.35	738.2	85	78	250	60	4	260
1	30		81	.48		1.62	739.8	80	77	251	55	5	257
2			80	.50		1.69	742.0	81	77	251	56	6	255
3	35		82	.54		1.83	744.0	81	77	250	56	6	257
4			81	.56		1.89	746.1	82	78	251	59	6	260
5	40		81	.57		1.93	747.8	82	78	250	57	6	254
6			80	.57		1.99	750.0	83	79	249	57	6	256
7	45		80	.54		1.89	751.9	83	78	248	60	6	255
8			78	.47		1.59	753.9	83	79	250	61	5	258
9	50		80	.40		1.35	755.8	85	80	250	63	4	259
10			84	.36		1.22	757.4	87	82	250	67	4	251
11	55		83	.53		1.79	757.1	89	84	251	66	5	261
12			84	.66		2.23	760.9	91	85	250	67	5	258
	60						763.022						
Avg.			80.5			1.726	1.7612	45.869	76.4				

Time End 10:32

Volume of Liquid Water Collected	Impinger Volume ml				Silica Gel Weight g
	1	2	3	4	
Final	120	116	4		207
Initial	100	100	-	-	200
Liquid Collected	20	16	4		7
Total Volume Collected					


Post-Test Leak Check
 Meter .001 @ 11" H₂O
 Pitot 0.0 @ 3" H₂O
 Orsat CEMS

TRC

PARTICULATE FIELD DATA

Plant IBP
 Date 7/22/98
 Location DAKOTA CITY
 Operator DW
 Source Subs. Cooke cond. out
 Run No. 2
 Sample Box _____
 Meter Box 4
 Meter dH @ 1.8068
Y = .9821
 Time Start 18:10

Ambient Temperature 85°F
 Barometric Pressure 29.00
 Assumed Moisture % 4.0
 Probe Length, in. 5' 6"
 Nozzle Diameter, in. .244
 Stack Diameter, in. 26"
 Probe Heater Setting 248 ± 25
 Oven Heat Setting 248 ± 25
 Pitot Coefficient .84
 Filter No. 586
 Filter Tare Wgt. 601.2



Pre-Test Leak Check
 Meter .001 @ 15" H₂O
 Pitot 0.0 @ 3" H₂O
 Orsat N/A (Cons)

K23.37 @ 90/90

K23.40 @ 95/90

K23.43 100/90

Point No.	Time	Static Pressure in. H ₂ O	Ts °C	dP in. H ₂ O	Sqr. R _L dP	dH in. H ₂ O	Vm ft.	Tm Inlet, °F	Tm Outlet, °F	Oven Temp. °F	Imp. Outlet Temp., °F	Vacuum (in. Hg)
1	0	-12.35	91	.50		1.70	765.600	93	92	250	65	15
2			85	.53		1.80	767.3	93	92	250	66	10
3	5		85	.57		1.94	769.5	93	92	249	57	10
4			86	.58		1.97	771.6	94	92	251	54	9
5	10		87	.59		2.00	773.6	94	92	250	61	8
6			88	.61		2.07	775.6	94	91	251	62	8
7	15		87	.61		2.07	777.7	93	90	250	62	8
8			85	.60		2.02	779.8	94	90	250	63	6
9	20		87	.51		1.72	781.8	93	89	251	62	5
10			87	.55		1.85	783.6	95	91	250	65	5
11	25		89	.50		1.70	785.6	96	92	250	66	5
12			88	.47		1.58	787.4	96	92	250	67	5
1	30		90	.52		1.72	789.2	93	91	250	65	5
2			89	.50		1.70	791.2	94	91	249	65	6
3	35		94	.59		2.00	793.0	95	92	250	65	6
4			93	.60		2.04	795.1	96	92	251	66	6
5	40		93	.62		2.11	797.1	94	90	250	65	7
6			94	.62		2.11	799.2	93	89	250	66	14
7	45		94	.57		2.00	801.3	94	90	250	67	10
8			95	.48		1.63	803.3	94	90	250	65	7
9	50		94	.44		1.50	805.1	96	92	251	65	7
10			92	.45		1.53	806.9	95	92	250	67	8
11	55		88	.54		1.84	808.7	95	91	250	67	7
12			87	.53		1.80	810.6	95	91	250	68	7
	60						812.543					
Avg.			89.7	.543	.7396	1.8604	46.943	92.7				

Probe
Heat

Time End 19:13

Volume of Liquid Water Collected	Impinger Volume ml				Silica Gel Weight g
	1	2	3	4	
Final	122	113	5	—	206
Initial	100	100	—	—	200
Liquid Collected	22	13	5		6
Total Volume Collected	46				



Post-Test Leak Check
 Meter .001 @ 15" H₂O
 Pitot 0.0 @ 3" H₂O
 Orsat N/A (Cons)

TRC

PARTICULATE FIELD DATA

Plant IBP
 Date 7/22/94
 Location DAKOTA CITY
 Operator DW
 Source Superconductor Cond. out
 Run No. 3
 Sample Box
 Meter Box 4
 Meter dH @ 1.8068
Y = .9821
 Time Start 20:20

Ambient Temperature 80°F
 Barometric Pressure 29.00
 Assumed Moisture % 4.0
 Probe Length, in. 5' 2 1/4"
 Nozzle Diameter, in. .244
 Stack Diameter, in. 26"
 Probe Heater Setting 248 I 25
 Oven Heat Setting 248 I 25
 Pitot Coefficient .84
 Filter No. 470
 Filter Tare Wgt. 604.3



Pre-Test Leak Check
 Meter .015 @ 15" H₂O
 Pitot 0.0 @ 3" H₂O
 Orsat N/A

K 2 3.37 @ 90/90													3.34 @ 95/90		K 2 3.31 @ 85/95		K 3.31 @ 90/100	
Point No.	Time	Static Pressure in. H ₂ O	Ts °C	dP in. H ₂ O	Sqr. Rt. dP	dH in. H ₂ O	Vm ft.	Tm Inlet, °F	Tm Outlet, °F	Oven Temp. °F	Imp. Outlet Temp. °F	Vacuum (in. Hg)						
1	0	-12.25	97	.51		1.69	812.902	86	85	251	67	11						
2			99	.54		1.79	814.7	88	86	251	60	11						
3	5		101	.58		1.82	816.8	88	86	250	56	11						
4			100	.60		2.00	818.8	90	87	250	52	9						
5	10		101	.61		2.02	820.7	90	86	251	53	9						
6			101	.62		2.05	822.7	91	87	250	55	8						
7	15		100	.63		2.09	824.8	91	86	250	55	8						
8			101	.58		1.92	826.8	91	86	250	56	7						
9	20		102	.51		1.69	828.7	91	85	249	56	5						
10			95	.36		1.19	830.7	90	85	250	59	4.5						
11	25		92	.54		1.79	832.3	90	85	249	57	6						
12			90	.51		1.69	834.1	90	85	250	56	5						
1	30		100	.51		1.69	836.0	87	83	249	54	5						
2			101	.51		1.69	837.8	87	83	250	57	5						
3	35		100	.54		1.79	839.5	87	84	249	56	5						
4			102	.54		1.79	841.3	88	83	250	57	5						
5	40		100	.57		1.89	843.3	88	83	250	57	6						
6			100	.61		2.02	845.3	88	83	251	57	7						
7	45		100	.57		1.89	847.3	88	83	250	57	5						
8			96	.51		1.69	849.2	88	83	250	58	5						
9	50		93	.47		1.56	851.1	88	83	249	59	4						
10			92	.42		1.39	852.8	88	83	251	58	4						
11	55		92	.41		1.36	854.6	87	83	250	58	4						
12			90	.38		1.26	856.3	87	83	249	59	4						
	60						857.870											
Avg.			97.7	.5038	1.7236	1.7442	854.42	86.4										

PAGE
NEXT

Time End 21:23

Volume of Liquid Water Collected	Impinger Volume ml				Silica Gel Weight g
	1	2	3	4	
Final	142	110	-	-	205
Initial	100	100	-	-	200
Liquid Collected	42	10	0		
Total Volume Collected					

Post-Test Leak Check
 Meter .012 @ 15" H₂O
 Pitot 0.0 @ 3" H₂O
 Orsat N/A

TRC

Method 25 Field Data

Client: IBP
 Location: DAKOTA CITY
 Date: 7/22/98

Project Number: 22214-0000-00012
 Sample Location: Super Cooler Condenser out
 Run Number: 1
 Operator: DW

Tank Number: 290 Trap Number: GGC Sample ID: R1

	Tank Vacuum		Barometric Pressure	Ambient Temperature
	Manometer (mm/cm Hg)	Gauge mm/cm Hg/in Hg	(mm/cm Hg/in. Hg)	C/(°F)
Pretest	731.5 mm	3.0	737.9 mm	74
Post Term	75.0 mm	3.0	737.9 mm	80

Pretest Leak Rate (mm/cm Hg/in Hg/5 min): 4 mm Hg 5 min

Clock Time	Sample Time	Gauge Vacuum mm/cm Hg	Flowmeter Setting ml / cm	Temperature		Comments
				Probe (°C/°F)	Box (°C/°F)	
10:30	0	30	60	132	125	
	5	27.5	60	132	125	Normal
	10	25.0	60	134	120	Probe
	15	22.0	60	135	120	heat set
	20	20.0	60	134	120	to 135 C
	25	17.5	60	134	122	
	30	15.0	60	133	121	Box heat
	35	13.0	60	135	121	set to
	40	11.0	60	135	121	120 C
	45	9.0	60	135	121	
	50	7.0	60	133	120	
	55	5.0	60	133	121	
11:32	60	3.0	60	134	122	

TRC
ENVIRONMENTAL

Method 25 Field Data

Client: IBP
 Location: DAKOTA CITY, NE
 Date: 7-22-98

Project Number: 22214-12
 Sample Location: Super Cooker Cond. out
 Run Number: 2
 Operator: DW

Tank Number: 294 Trap Number: FFW Sample ID: R-2

	Tank Vacuum		Barometric Pressure	Ambient Temperature
	Manometer (mm)cm Hg	Gauge mm/cm Hg(in Hg)	(mm)cm Hg/in. Hg	C / F
Pretest	734.06	30.0	736.6	75.0
Post Term	53.3	1.5	736.6	75.0

Pretest Leak Rate (mm)cm Hg/in Hg/5 min): 2.5mm / 5min

Clock Time	Sample Time	Gauge Vacuum mm/cm Hg	Flowmeter Setting ml / cm	Temperature		Comments
				Probe (D)10	Box (D)F	
6:11 pm	0	28.50	60	134	127	
	5	26.0	60	134	118	Normal
6:21	10	24.0	60	134	120	Probe
	15	21.5	60	134	122	heat set
6:31	20	18.5	60	134	122	to 135 C
	25	16.0	60	131	121	
6:41 ^{START}	30	14.0	60	134	121	Box heat
	35	11.5	60	134	121	set to
6:53	40	9.5	60	134	121	120 C
	45	7.5	60	134	121	
7:03	50	5.5	60	134	120	
	55	3.5	60	134	121	
7:13	60	1.5	60	134	121	

TRC
ENVIRONMENTAL

Method 25 Field Data

Client: JBP
 Location: DAKOTA CITY, NE
 Date: 7/22/98

Project Number: 22214-12
 Sample Location: SUPER COOLER COND OUT
 Run Number: 3
 Operator: DW

Tank Number: 295 Trap Number: GGB Sample ID: R3

	Tank Vacuum		Barometric Pressure	Ambient Temperature
	Manometer (mm)/cm Hg	Gauge mm/cm Hg/in Hg	(mm)/cm Hg/in. Hg	C/F
Pretest	734.1	30.0	736.6	75
Post Term	67.7	3.5	736.6	75

Pretest Leak Rate (mm/cm Hg/in Hg/5 min): 2.5 mm Hg / 5 min

Clock Time	Sample Time	Gauge Vacuum mm/cm Hg	Flowmeter Setting (ml)/cm	Temperature		Comments
				Probe C/F	Box C/F	
20:20	0	30.0	60	134	120	
	5	27.5	60	134	121	Normal
20:30	10	25.0	60	134	124	Probe
	15	23.0	60	134	124	heat set
20:40	20	20.5	60	134	121	to 135 C
	25	18.5	60	134	120	
20:50 SM / 20:53 SM	30	16.0	60	134	120	Box heat
	35	14.0	60	134	121	set to
21:03	40	11.5	60	134	120	120 C
	45	9.5	60	134	120	
21:13	50	7.5	60	134	120	
	55	5.5	60	134	120	
21:23	60	3.5	60	134	120	

TRC
ENVIRONMENTAL

Run 1

DATE: July 22, 1998 CLIENT REP: R. KRUSE

PLANT: IBP / DC WITNESSED?: N/A

FUEL TYPE: Steam BURNER TYPE: N/A

OPERATOR: SM/DW GENERATOR TYPE: N/A

TEST LOCATION: SUPER COOKER O2 GENERATOR TYPE: N/A

CALIBRATION GASES

O2	CO2	CO	SO2	THC	NOx
0	0	0	0	0	0
10.2	9.9	30.3	45.1	N/A	46
18	17.7	86.9	88.7	N/A	84.3

END TIME	SAMPLE POINT	O2 %	CO2 %	CO ppm	SO2 ppm	THC ppm	NOx ppm
1050	1	20.1	0.07	1.53	1.2		0.5
1110	2	19.89	0.11	2.18	1.2		0.5
1130	3	20.03	-0.03	1.94	1		0.5
	AVERAGE	20.01	0.05	1.88	1.13	#DIV/0!	0.50

Barometric Pres: 29.05

EFFLUENT GAS CONCENTRATION, % or PPM

	O2	CO2	CO	SO2	THC	NOx
PRE ZERO	0.1	0	1.5	0.3		-0.3
POST ZER	0.1	-0.2	1.1	0.3		0.1
ACT SPAN	18	17.7	30.3	45.1	N/A	46
PRE SPAN	18	17.6	31	43.4		45
POST SPA	17.8	17.5	30.5	42.1		44.9

GAS CONC. 20.13 0.15 0.60 0.89 #DIV/0! 0.61

GAS CONC. 19.15 0.14 0.57 0.84 #DIV/0! 0.58

F-factor (Fc)----

N/A

scf/10e6 btu

lb/hr SO2 0.073

lb/hr NOx

0.036

lb/hr CO 0.022

Stack Flowrate- 5.2146E+05 (wet, scf/hr)

EFFLUENT GAS CONC CALCULATION

$$\text{GAS CONC.} = (\text{Avg Stk Conc} - \text{Avg Zero Cal}) * (\text{Span Conc} / (\text{Avg Span Cal} - \text{Avg Zero Cal}))$$

PLANT: IBP DAKOTA CITY
UNIT: COOKER
TODAYS DATE: 07-22-1998
START/END TIMES: 10:30/10:50
MOISTURE = 3.6%

RUN NUMBER: 1 PAGE 1
OPERATOR: MILLER
MEASUREMENT DATE:
10:50/11:10 11:10/11:30
RESPONSE TIME = 2 MIN

TIME	NOx	NOx	SO2	SO2	CO2	CO2	O2	O2	CO	CO
MIN	CONC	CONC	CONC	CONC	CONC	CONC	CONC	CONC	CONC	CONC
ENDING	DRY	WET	DRY	WET	DRY	WET	DRY	WET	DRY	WET
	ppm	ppm	ppm	ppm	%	%	%	%	ppm	ppm
10:33:00	0.4	0.4	1.2	1.2	0.06	0.06	20.11	19.39	1.34	1.29
10:34:00	0.5	0.5	1.2	1.2	0.06	0.06	20.10	19.38	1.23	1.18
10:35:00	0.5	0.5	1.2	1.2	0.05	0.05	20.10	19.37	1.38	1.33
10:36:00	0.5	0.5	1.3	1.2	0.05	0.05	20.09	19.37	1.50	1.44
10:37:00	0.4	0.4	1.2	1.1	0.06	0.05	20.12	19.39	1.64	1.59
10:38:00	0.4	0.4	1.2	1.2	0.05	0.05	20.11	19.38	1.33	1.28
10:39:00	0.5	0.5	1.2	1.1	0.06	0.05	20.09	19.36	1.38	1.33
10:40:00	0.4	0.4	1.2	1.1	0.06	0.06	20.12	19.40	1.69	1.63
10:41:00	0.4	0.4	1.1	1.1	0.06	0.06	20.12	19.40	1.99	1.92
10:42:00	0.6	0.5	1.2	1.1	0.06	0.06	20.08	19.36	1.85	1.78
10:43:00	0.5	0.5	1.2	1.1	0.07	0.07	20.09	19.37	1.78	1.71
10:44:00	0.5	0.4	1.1	1.1	0.06	0.06	20.10	19.38	1.73	1.66
10:45:00	0.4	0.4	1.1	1.1	0.07	0.07	20.12	19.39	1.64	1.58
10:46:00	0.5	0.5	1.2	1.1	0.08	0.08	20.08	19.36	1.39	1.34
10:47:00	0.4	0.4	1.2	1.1	0.08	0.08	20.11	19.38	1.63	1.57
10:48:00	0.4	0.4	1.1	1.0	0.08	0.08	20.10	19.37	1.39	1.34
10:49:00	0.4	0.4	1.1	1.1	0.09	0.08	20.07	19.35	1.30	1.25
10:50:00	0.5	0.5	1.1	1.1	0.08	0.08	20.07	19.35	1.41	1.36
MEAN	0.5	0.4	1.2	1.1	0.07	0.06	20.10	19.38	1.53	1.48
10:53:00	0.5	0.4	1.2	1.1	0.09	0.09	20.09	19.37	1.73	1.67
10:54:00	0.5	0.4	1.2	1.1	0.08	0.08	20.09	19.36	1.58	1.52
10:55:00	0.5	0.5	1.2	1.2	1.56	1.50	16.82	16.22	4.71	4.54
10:56:00	0.5	0.5	1.2	1.2	0.07	0.07	20.10	19.38	1.98	1.91
10:57:00	0.5	0.4	1.2	1.2	0.07	0.06	20.10	19.38	2.02	1.95
10:58:00	0.5	0.5	1.2	1.2	0.06	0.06	20.07	19.35	2.07	2.00
10:59:00	0.6	0.6	1.2	1.1	0.05	0.04	20.07	19.34	1.81	1.75
11:00:00	0.5	0.5	1.2	1.2	0.04	0.04	20.08	19.36	2.13	2.05
11:01:00	0.6	0.6	1.2	1.1	0.01	0.01	20.06	19.34	1.95	1.88
11:02:00	0.6	0.5	1.2	1.1	0.03	0.02	20.07	19.35	2.02	1.94
11:03:00	0.6	0.5	1.2	1.2	0.01	0.01	20.06	19.34	1.94	1.87
11:04:00	0.5	0.5	1.2	1.1	0.00	0.00	20.07	19.35	2.15	2.08
11:05:00	0.6	0.6	1.1	1.1	-0.00	-0.00	20.05	19.32	1.98	1.91
11:06:00	0.5	0.5	1.1	1.1	-0.01	-0.01	20.07	19.35	2.33	2.24
11:07:00	0.6	0.6	1.2	1.1	-0.01	-0.01	20.05	19.33	2.25	2.17
11:08:00	0.5	0.5	1.1	1.1	-0.01	-0.01	20.06	19.34	2.17	2.09

PLANT: IBP DAKOTA CITY

UNIT: COOKER

TODAYS DATE: 07-22-1998

START/END TIMES: 10:30/10:50

MOISTURE = 3.6%

RUN NUMBER: 1

PAGE 2

OPERATOR: MILLER

MEASUREMENT DATE:

10:50/11:10

11:10/11:30

RESPONSE TIME = 2 MIN

TIME	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
11:09:00	0.5	0.5	1.0	1.0	-0.01	-0.01	20.05	19.33	2.21	2.13
11:10:00	0.5	0.5	1.1	1.1	-0.02	-0.02	20.06	19.34	2.21	2.13
MEAN	0.5	0.5	1.2	1.1	0.11	0.11	19.89	19.18	2.18	2.10
11:13:00	0.6	0.5	1.0	1.0	-0.03	-0.03	20.03	19.31	2.03	1.96
11:14:00	0.4	0.4	1.0	1.0	-0.03	-0.03	20.07	19.34	2.07	2.00
11:15:00	0.5	0.4	0.9	0.9	-0.03	-0.03	20.05	19.33	2.24	2.16
11:16:00	0.6	0.5	1.0	1.0	-0.03	-0.03	20.02	19.30	1.97	1.90
11:17:00	0.4	0.4	1.0	0.9	-0.03	-0.03	20.05	19.32	2.24	2.15
11:18:00	0.4	0.4	1.0	0.9	-0.03	-0.03	20.05	19.32	2.04	1.97
11:19:00	0.5	0.5	1.0	0.9	-0.03	-0.03	20.03	19.31	1.92	1.85
11:20:00	0.4	0.4	1.0	0.9	-0.03	-0.03	20.06	19.34	2.01	1.93
11:21:00	0.4	0.4	1.0	0.9	-0.03	-0.03	20.05	19.33	2.05	1.98
11:22:00	0.5	0.5	1.0	0.9	-0.03	-0.03	20.03	19.31	1.94	1.87
11:23:00	0.5	0.5	1.0	0.9	-0.03	-0.03	20.01	19.29	1.60	1.55
11:24:00	0.4	0.4	1.0	1.0	-0.03	-0.03	20.05	19.33	1.90	1.83
11:25:00	0.5	0.4	0.9	0.9	-0.03	-0.03	20.02	19.30	1.82	1.75
11:26:00	0.6	0.6	0.9	0.9	-0.03	-0.03	20.00	19.28	1.66	1.60
11:27:00	0.5	0.5	0.9	0.9	-0.03	-0.03	20.00	19.28	1.72	1.66
11:28:00	0.4	0.4	0.9	0.9	-0.03	-0.03	20.03	19.31	1.93	1.86
11:29:00	0.5	0.5	0.9	0.8	-0.03	-0.03	20.00	19.28	1.80	1.73
11:30:00	0.5	0.5	1.0	0.9	-0.02	-0.02	20.01	19.29	1.87	1.81
MEAN	0.5	0.5	1.0	0.9	-0.03	-0.03	20.03	19.31	1.94	1.87

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
10:29:00	1.3	12.7	0.1	4.1	0.4	3.8	20.1	805.0	1.3	13.4	22.2
<i>Start</i> 10:30:00	1.3	12.7	0.1	3.4	0.6	5.5	20.1	805.0	1.4	14.1	22.2
10:31:00	1.2	12.4	0.1	3.4	0.4	4.5	20.1	804.0	1.3	13.4	22.2
10:32:00	1.3	12.7	0.1	4.1	0.3	3.4	20.1	805.0	1.5	14.8	22.2
10:33:00	1.1	11.4	0.1	3.4	0.5	4.8	20.1	804.0	1.3	12.7	22.2
10:34:00	1.2	12.0	0.1	3.4	0.4	4.5	20.1	804.0	1.1	11.0	22.3
10:35:00	1.3	12.7	0.1	2.8	0.6	5.5	20.1	804.0	1.5	14.8	22.3
10:36:00	1.2	11.7	0.1	2.8	0.4	4.1	20.1	803.0	1.5	15.1	22.3
10:37:00	1.2	12.0	0.1	2.8	0.4	4.1	20.1	805.0	1.6	16.2	22.3
10:38:00	1.1	11.4	0.1	2.8	0.5	5.2	20.1	804.0	1.3	12.7	22.3
10:39:00	1.2	11.7	0.1	2.8	0.4	4.5	20.1	804.0	1.5	15.5	22.3
10:40:00	1.1	11.0	0.1	3.1	0.4	4.5	20.1	805.0	1.8	17.5	22.4
10:41:00	1.1	11.4	0.1	3.4	0.4	4.5	20.1	804.0	2.3	22.7	22.4
10:42:00	1.3	12.7	0.1	2.8	0.7	6.5	20.1	804.0	1.6	15.8	22.4
10:43:00	1.2	12.0	0.1	3.4	0.4	4.5	20.1	804.0	1.8	17.9	22.4
10:44:00	1.1	11.4	0.1	3.4	0.4	4.1	20.1	804.0	1.8	17.9	22.4
10:45:00	1.1	11.4	0.1	3.4	0.4	4.1	20.1	804.0	1.6	15.8	22.4
10:46:00	1.2	12.0	0.1	4.1	0.5	5.2	20.1	803.0	1.4	14.4	22.4
10:47:00	1.1	11.4	0.1	4.1	0.3	3.4	20.1	804.0	1.6	16.2	22.5
10:48:00	1.1	11.4	0.1	3.4	0.4	4.1	20.1	804.0	1.3	12.7	22.5
10:49:00	1.1	11.0	0.1	4.1	0.4	4.5	20.1	803.0	1.3	12.7	22.5
10:50:00	1.1	11.4	0.1	4.8	0.6	5.8	20.1	803.0	1.5	14.8	22.5
10:51:00	1.0	10.0	0.1	4.5	0.4	3.8	20.1	804.0	1.7	17.2	22.5
10:52:00	1.2	12.0	0.1	4.8	0.6	6.2	20.1	802.0	1.4	14.4	22.6
10:53:00	1.2	11.7	0.1	4.8	0.4	4.1	20.1	804.0	1.7	17.2	22.6
10:54:00	1.2	12.0	0.1	4.1	0.5	4.8	20.1	803.0	1.5	15.1	22.6
10:55:00	1.3	12.7	0.1	4.1	0.6	6.2	20.1	803.0	1.9	18.9	22.6
10:56:00	1.2	12.0	0.1	3.8	0.4	3.8	20.1	804.0	1.9	19.3	22.6
10:57:00	1.1	11.4	0.1	3.4	0.5	4.8	20.1	804.0	2.1	20.6	22.6
10:58:00	1.2	12.0	0.1	2.8	0.6	5.5	20.1	802.0	2.1	21.0	22.7
10:59:00	1.3	12.7	0.0	2.1	0.5	5.2	20.1	804.0	1.9	18.6	22.7
11:00:00	1.2	12.0	0.0	0.7	0.6	6.2	20.1	802.0	2.2	21.7	22.7
11:01:00	1.1	10.7	0.0	0.7	0.6	5.5	20.1	802.0	1.8	18.2	22.8
11:02:00	1.2	12.0	0.0	0.7	0.6	5.5	20.1	804.0	2.1	21.3	22.8
11:03:00	1.1	11.4	0.0	0.0	0.6	5.5	20.1	802.0	1.9	18.9	22.8
11:04:00	1.1	10.7	-0.0	-0.3	0.6	5.5	20.1	803.0	2.1	21.3	22.9
11:05:00	1.1	11.4	0.0	0.0	0.6	6.2	20.1	802.0	2.1	21.3	22.9
11:06:00	1.2	11.7	-0.0	-0.3	0.5	5.2	20.1	803.0	2.4	24.1	22.9
11:07:00	1.1	11.4	-0.0	-0.7	0.6	5.8	20.1	802.0	2.0	19.9	22.9
11:08:00	1.2	11.7	-0.0	-0.7	0.4	4.1	20.1	803.0	2.1	21.3	23.0
11:09:00	1.1	10.7	-0.0	-1.4	0.4	4.5	20.1	803.0	2.1	20.6	23.0
11:10:00	1.1	11.4	-0.0	-1.4	0.4	4.1	20.1	803.0	2.3	22.7	23.0
11:11:00	1.1	11.4	-0.0	-0.7	0.4	3.8	20.1	803.0	2.2	22.0	23.0
11:12:00	1.0	10.0	-0.0	-1.4	0.6	6.2	20.0	801.0	2.1	21.3	23.0

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
11:13:00	1.0	10.3	-0.0	-1.4	0.4	4.5	20.1	802.0	1.9	19.3	23.1
11:14:00	1.1	10.7	-0.0	-1.7	0.5	4.8	20.1	803.0	2.1	21.3	23.1
11:15:00	1.0	10.0	-0.0	-1.7	0.5	4.8	20.0	801.0	2.3	22.7	23.1
11:16:00	0.9	9.3	-0.0	-1.7	0.5	5.2	20.0	801.0	1.9	18.6	23.1
11:17:00	1.0	10.0	-0.0	-0.7	0.6	5.5	20.0	800.0	2.3	22.7	23.2
11:18:00	1.0	10.0	-0.0	-1.4	0.4	4.5	20.1	802.0	2.3	22.7	23.2
11:19:00	0.9	9.3	-0.0	-1.4	0.4	4.1	20.1	802.0	1.8	17.9	23.2
11:20:00	0.9	9.3	-0.0	-1.4	0.3	3.4	20.1	802.0	2.0	20.3	23.3
11:21:00	0.9	9.3	-0.0	-1.4	0.5	4.8	20.1	802.0	2.0	20.3	23.3
11:22:00	0.9	9.3	-0.0	-1.4	0.6	6.2	20.0	800.0	1.8	17.5	23.3
11:23:00	0.9	8.6	-0.0	-1.4	0.4	3.8	20.0	801.0	1.6	16.2	23.4
11:24:00	1.0	10.3	-0.0	-1.4	0.4	4.5	20.1	802.0	2.0	19.9	23.4
11:25:00	0.9	9.3	-0.0	-1.4	0.5	4.8	20.0	800.0	1.6	16.5	23.4
11:26:00	1.0	10.0	-0.0	-1.4	0.6	6.2	20.0	800.0	1.6	16.5	23.4
11:27:00	0.9	9.3	-0.0	-1.4	0.5	5.2	20.0	801.0	1.9	19.3	23.5
11:28:00	1.0	10.0	-0.0	-1.4	0.5	5.2	20.0	800.0	1.7	17.2	23.5
11:29:00	0.9	8.6	-0.0	-0.7	0.5	4.8	20.0	801.0	2.0	20.3	23.5
11:30:00	0.9	9.3	-0.0	-1.0	0.6	5.8	20.0	799.0	1.6	16.5	23.5
11:31:00	0.9	9.3	-0.0	-1.0	0.6	6.2	20.0	799.0	1.6	16.5	23.5
11:32:00	0.6	6.2	-0.2	-8.9	0.2	1.7	0.2	8.9	55.6	556.0	23.6
11:33:00	0.6	5.8	-0.2	-8.9	0.1	1.0	0.1	5.5	1.4	13.8	23.6
11:34:00	0.4	4.5	-0.2	-8.9	0.1	0.7	0.1	4.8	1.2	12.0	23.6
11:35:00	0.3 <i>2us</i>	3.4	-0.2 <i>2us</i>	-8.9	0.1 <i>2us</i>	1.4	0.1 <i>2us</i>	2.8	1.1 <i>2us</i>	10.7	23.7
11:36:00	0.4	4.5	-0.2	-8.9	43.2	432.2	0.1	2.8	0.9	8.6	23.7
11:37:00	0.4	4.5	-0.2	-8.9	44.9 <i>5pm</i>	449.4	0.1	3.4	1.4	14.1	23.7
11:38:00	0.3	3.4	-0.2	-8.9	0.5	4.8	0.1	3.4	2.7	27.2	23.7
11:39:00	0.3	3.1	-0.2	-8.6	0.2	2.1	0.1	2.1	30.5 <i>5pm</i>	304.7	23.8
11:40:00	0.4	3.8	17.3	864.0	0.1	1.0	17.7	708.0	29.3	292.6	23.8
11:41:00	0.4	4.1	17.5	873.0	0.0	0.3	17.8	712.0	0.9	9.3	23.8
11:42:00	0.4	3.8	17.5 <i>5pm</i>	876.0	0.0	0.3	17.7 <i>5pm</i>	709.0	0.6	5.5	23.8
11:43:00	6.5	65.0	0.1	4.8	0.0	0.3	0.4	14.4	1.0	9.6	23.8
11:44:00	30.1	300.9	-0.0	-1.4	0.1	0.7	0.1	3.8	1.3	13.4	23.8
11:45:00	35.1	350.7	-0.1	-2.8	0.0	0.3	0.1	3.1	1.2	12.4	23.9
11:46:00	37.6	375.8	-0.1	-3.4	0.1	0.7	0.1	2.4	1.3	13.4	23.9
11:47:00	39.2	392.0	-0.1	-4.1	0.0	0.3	0.1	2.1	1.3	13.4	23.9
11:48:00	40.7	407.4	-0.1	-4.8	0.0	0.3	0.0	1.7	1.4	14.4	23.9
11:49:00	41.7	417.0	-0.1	-5.2	0.0	0.0	0.1	2.4	1.6	16.2	23.9
11:50:00	42.1 <i>5pm</i>	421.1	-0.1	-5.5	-0.0	-0.3	0.1	2.4	1.8	17.5	24.0

Re-CAL Between R1- & 2 Zero & High Gas

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
17:35:30	2.0	20.3	-0.0	-2.1	0.3	2.7	0.1	5.2	1.3	13.1	28.5
17:36:30	2.1	21.0	-0.0	-2.1	42.6	425.9	0.1	3.8	1.0	10.3	28.5
17:37:30	2.1	21.0	0.0	2.1	9.6	95.5	0.9	35.7	1.6	16.5	28.5
17:38:30	19.7	196.8	-0.0	-2.4	0.3	3.4	0.1	4.5	1.5	15.1	28.5
17:39:30	31.8	317.7	-0.0	-2.4	0.3	2.7	0.1	2.4	1.1	11.3	28.5
17:40:30	9.0	90.0	-0.1	-2.7	0.3	3.1	0.0	1.0	1.1	11.3	28.5
17:41:30	2.2	22.3	-0.1	-2.7	0.2	2.1	0.0	1.0	-0.1	-1.4	28.4
17:42:30	2.1	21.0	0.0	0.0	0.2	1.7	0.0	1.0	-0.2	-1.7	28.4
17:43:30	-0.3 <i>Zero</i>	-3.1	0.0 <i>Zero</i>	0.0	0.1 <i>Zero</i>	1.4	0.0 <i>Zero</i>	1.0	-0.1 <i>Zero</i>	-0.7	28.4
17:44:30	82.4	824.0	0.0	0.0	0.5	5.5	0.0	1.0	0.3	2.7	28.3
17:45:30	88.8 <i>from</i>	888.0	0.0	0.0	0.5	5.2	0.0	1.7	0.5	5.5	28.3
17:46:30	1.8	17.5	17.8	888.0	-0.2	-2.1	17.9	716.0	0.1	1.0	28.3
17:47:30	-0.0	-0.3	17.7	886.0	-0.1	-1.4	17.9	717.0	-0.5	-5.5	28.2
17:48:30	-0.3	-3.4	17.8 <i>from</i>	888.0	-0.2	-2.1	18.0 <i>from</i>	720.0	-0.2	-2.1	28.2
17:49:30	-0.3	-3.1	0.1	6.2	-0.3	-2.7	0.2	7.9	3.8	37.8	28.1
17:50:30	-0.4	-3.8	0.1	4.8	-0.2	-1.7	0.0	1.7	28.1	280.6	28.1
17:51:30	-0.5	-4.8	0.1	4.8	-0.2	-2.4	0.0	1.7	29.9 <i>from</i>	298.5	28.1
17:52:30	-0.3	-3.1	0.1	4.5	-0.3	-2.7	0.1	2.4	13.3	132.6	28.1
17:53:30	1.7	16.8	0.1	4.8	-0.2	-2.4	0.1	3.8	25.5	255.2	28.0
17:54:30	0.9 <i>Zero</i>	9.3	0.1 <i>Zero</i>	4.8	-0.3 <i>Zero</i>	-2.7	0.1 <i>Zero</i>	3.8	1.2 <i>Zero</i>	11.7	28.0
17:55:30	0.5 <i>from</i>	5.2	0.1 <i>from</i>	4.8	-0.3 <i>from</i>	-2.7	0.1	3.4	1.2	11.7	28.0
17:56:30	0.4	4.1	0.1	4.5	42.4	423.5	0.1	3.8	1.1	10.6	27.9
17:57:30	0.4	4.5	0.1	4.5	42.7	426.9	0.1	3.4	1.4	14.1	27.9
17:58:30	21.0	210.2	0.1	4.5	0.1	1.0	0.1	3.1	1.6	15.8	27.9
17:59:30	37.7	376.8	0.1	4.5	0.1	0.7	0.0	1.7	1.1	11.3	27.9
18:00:30	40.0	400.5	0.1	4.5	0.0	0.3	0.1	3.4	1.2	11.7	27.9
18:01:30	41.2 <i>from</i>	411.8	0.1	4.1	-0.0	-0.3	0.1	3.4	1.2	12.0	27.9
18:02:30	16.1	161.1	17.5	875.0	0.0	0.0	18.0	721.0	1.5	15.5	27.9
18:03:30	3.6	36.1	17.7 <i>from</i>	883.0	0.0	0.3	18.0 <i>from</i>	719.0	0.8	7.9	27.9
18:04:30	2.4	23.7	0.4	17.5	0.1	1.0	0.5	18.5	0.5	4.8	27.8
18:05:30	1.5	15.1	0.2	9.3	0.1	1.4	0.1	3.4	30.3 <i>Zero</i>	302.6	27.8

Run 2

DATE:

July 22, 1998

CLIENT REP:

R.KRUSE

PLANT:

IBP / DC

WITNESSED?:

N/A

FUEL TYPE:

Steam

BURNER TYPE:

N/A

OPERATOR:

SM/DW

GENERATOR TYPE:

N/A

TEST LOCATION:

SUPER COOKER

O2 GENERATOR TYPE:

N/A

CALIBRATION GASES

O2	CO2	CO	SO2	THC	NOx
0	0	0	0	0	0
10.2	9.9	30.3	45.1	N/A	46
18	17.7	86.9	88.7	N/A	84.3

END TIME	SAMPLE POINT	O2 %	CO2 %	CO ppm	SO2 ppm	THC ppm	NOx ppm
1830	1	20.17	0.25	1.84	1.20		0.90
1850	2	20.12	0.25	1.67	1.00		0.80
1910	3	20.13	0.22	1.71	0.90		0.50
	AVERAGES	20.14	0.24	1.74	1.03	#DIV/0!	0.73

Barometric Pressure:

29.05

EFFLUENT GAS CONCENTRATION, % or PPM

	O2	CO2	CO	SO2	THC	NOx
PRE ZERO	0.1	0.1	1.2	0.9		-0.3
POST ZER	0.1	0.1	0.5	0.3		0.1
ACT SPAN	18	17.7	30.3	45.1	N/A	46
PRE SPAN	18	17.6	30.3	41.2		42.7
POST SPA	18	17.6	30.4	41.3		42.8

GAS CONC. (

20.15

0.14

0.91

0.48

#DIV/0!

0.89

GAS CONC. (

19.18

0.13

0.87

0.46

#DIV/0!

0.85

F-factor (Fc)-----

N/A

scf/10e6 btu

lb/hr NOx

0.054

lb/hr SO2

lb/hr CO

0.040

0.033

Stack Flowrate-

5.2918E+05

(wet, scf/hr)

EFFLUENT GAS CONC CALCULATION

GAS CONC. = (Avg Stk Conc - Avg Zero Cal) * (Span Conc/(Avg Span Cal - Avg Zero Cal))

PLANT: IBP DAKOTA CITY
UNIT: COOKER
TODAYS DATE: 07-22-1998
START/END TIMES: 18:10/18:30
MOISTURE = 5%

RUN NUMBER: 2 PAGE 1
OPERATOR: MILLR
MEASUREMENT DATE:
18:30/18:50 18:50/19:10
RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
18:13:00	0.6	0.6	1.0	1.0	0.27	0.26	20.30	19.28	1.63	1.55
18:14:00	0.8	0.7	1.1	1.0	0.27	0.25	20.24	19.23	1.61	1.53
18:15:00	0.8	0.7	1.0	0.9	0.27	0.25	20.23	19.22	1.53	1.46
18:16:00	0.8	0.8	1.1	1.1	0.27	0.25	20.22	19.21	1.87	1.77
18:17:00	0.8	0.8	1.1	1.1	0.27	0.25	20.18	19.17	1.52	1.45
18:18:00	0.8	0.8	1.2	1.1	0.27	0.25	20.19	19.18	1.52	1.45
18:19:00	0.8	0.8	1.1	1.1	0.27	0.25	20.20	19.19	1.90	1.81
18:20:00	0.9	0.8	1.2	1.1	0.26	0.25	20.18	19.17	1.94	1.84
18:21:00	0.8	0.8	1.1	1.1	0.26	0.25	20.19	19.18	2.00	1.90
18:22:00	0.9	0.9	1.2	1.1	0.26	0.25	20.14	19.13	1.64	1.56
18:23:00	0.9	0.9	1.2	1.1	0.26	0.25	20.15	19.14	1.66	1.58
18:24:00	0.9	0.9	1.2	1.1	0.26	0.25	20.16	19.15	2.16	2.05
18:25:00	1.0	0.9	1.2	1.2	0.26	0.25	20.13	19.12	1.83	1.74
18:26:00	1.0	0.9	1.3	1.2	0.26	0.25	20.15	19.15	2.19	2.08
18:27:00	1.0	1.0	1.3	1.2	0.26	0.25	20.12	19.11	2.01	1.91
18:28:00	1.0	1.0	1.3	1.2	0.27	0.26	20.13	19.12	2.15	2.04
18:29:00	1.0	1.0	1.4	1.3	0.27	0.26	20.13	19.12	2.00	1.90
18:30:00	1.1	1.1	1.4	1.3	0.27	0.25	20.10	19.10	2.02	1.91
MEAN	0.9	0.8	1.2	1.1	0.27	0.25	20.17	19.17	1.84	1.75
18:33:00	1.1	1.0	1.4	1.4	0.26	0.24	20.13	19.12	2.13	2.02
18:34:00	1.1	1.0	1.3	1.3	0.26	0.24	20.11	19.10	1.91	1.82
18:35:00	1.0	1.0	1.3	1.3	0.26	0.25	20.14	19.13	2.15	2.04
18:36:00	1.0	1.0	1.3	1.2	0.26	0.25	20.13	19.12	1.83	1.74
18:37:00	1.1	1.0	1.2	1.2	0.26	0.25	20.11	19.10	1.96	1.86
18:38:00	1.1	1.0	1.3	1.2	0.26	0.25	20.11	19.10	1.72	1.64
18:39:00	0.7	0.7	1.0	0.9	0.21	0.20	20.15	19.14	1.81	1.72
18:40:00	0.6	0.6	0.8	0.8	0.22	0.21	20.15	19.14	1.65	1.57
18:41:00	0.6	0.6	0.8	0.8	0.23	0.22	20.15	19.14	1.64	1.56
18:42:00	0.6	0.6	0.8	0.8	0.22	0.21	20.10	19.10	1.47	1.40
18:43:00	0.6	0.6	0.7	0.7	0.24	0.23	20.11	19.10	1.18	1.12
18:44:00	0.5	0.5	0.7	0.7	0.25	0.23	20.13	19.12	1.43	1.36
18:45:00	0.5	0.5	0.7	0.7	0.24	0.23	20.13	19.12	1.36	1.29
18:46:00	0.5	0.5	0.7	0.7	0.24	0.23	20.13	19.12	1.41	1.34
18:47:00	0.5	0.5	0.8	0.7	0.24	0.23	20.13	19.12	1.47	1.40
18:48:00	0.6	0.5	0.8	0.8	0.28	0.27	20.12	19.11	1.39	1.32

PLANT: IBP DAKOTA CITY
UNIT: COOKER
TODAYS DATE: 07-22-1998
START/END TIMES: 18:10/18:30
MOISTURE = 5%

RUN NUMBER: 2 PAGE 2
OPERATOR: MILLR
MEASUREMENT DATE:
18:30/18:50 18:50/19:10
RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
18:49:00	0.7	0.7	1.0	0.9	0.27	0.26	20.10	19.10	1.86	1.76
18:50:00	0.7	0.7	1.0	0.9	0.26	0.24	20.13	19.12	1.74	1.65
MEAN	0.8	0.7	1.0	0.9	0.25	0.24	20.12	19.12	1.68	1.59
18:53:00	0.8	0.8	1.1	1.1	0.24	0.23	20.14	19.13	2.09	1.99
18:54:00	0.8	0.7	1.1	1.1	0.25	0.24	20.13	19.12	1.88	1.79
18:55:00	0.8	0.8	1.1	1.1	0.22	0.21	20.12	19.11	2.04	1.94
18:56:00	0.6	0.5	0.8	0.8	0.20	0.19	20.14	19.13	1.78	1.69
18:57:00	0.6	0.6	0.9	0.8	0.21	0.20	20.11	19.10	1.42	1.35
18:58:00	0.6	0.5	0.8	0.8	0.22	0.21	20.12	19.11	1.45	1.38
18:59:00	0.5	0.5	0.9	0.8	0.22	0.21	20.13	19.13	1.68	1.59
19:00:00	0.5	0.5	0.9	0.8	0.23	0.22	20.13	19.12	1.65	1.57
19:01:00	0.5	0.5	0.9	0.8	0.23	0.21	20.13	19.12	1.80	1.71
19:02:00	0.5	0.4	0.9	0.8	0.22	0.21	20.14	19.13	1.72	1.63
19:03:00	0.5	0.5	0.8	0.8	0.22	0.21	20.13	19.12	1.75	1.66
19:04:00	0.5	0.5	0.8	0.8	0.22	0.21	20.13	19.12	1.67	1.58
19:05:00	0.5	0.5	0.8	0.8	0.22	0.21	20.13	19.12	1.60	1.52
19:06:00	0.4	0.4	0.8	0.7	0.22	0.21	20.13	19.12	1.61	1.53
19:07:00	0.4	0.4	0.7	0.7	0.22	0.21	20.15	19.14	1.78	1.69
19:08:00	0.5	0.5	0.8	0.7	0.22	0.21	20.11	19.11	1.48	1.41
19:09:00	0.4	0.4	0.8	0.8	0.22	0.21	20.14	19.13	1.80	1.71
19:10:00	0.5	0.4	0.8	0.8	0.21	0.20	20.11	19.10	1.47	1.39
MEAN	0.5	0.5	0.9	0.8	0.22	0.21	20.13	19.12	1.71	1.62

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
18:08:00	1.4	13.7	0.3	14.4	0.4	3.8	20.6	822.0	1.5	15.5	27.8
18:09:00	1.2	11.7	0.3	14.1	0.5	4.8	20.4	817.0	1.5	15.5	27.8
4ant 18:10:00	1.1	11.0	0.3	14.1	0.5	5.2	20.4	815.0	1.5	15.1	27.8
18:11:00	1.1	10.6	0.3	13.7	0.6	6.2	20.3	813.0	1.3	13.1	27.8
18:12:00	0.9	9.3	0.3	13.7	0.7	6.5	20.3	812.0	1.4	13.7	27.7
18:13:00	1.1	10.6	0.3	13.4	0.7	6.5	20.3	811.0	1.8	17.9	27.7
18:14:00	1.1	10.6	0.3	13.4	0.8	8.2	20.2	809.0	1.5	15.1	27.7
18:15:00	1.1	10.6	0.3	13.4	0.8	7.9	20.3	810.0	1.8	17.5	27.6
18:16:00	1.2	11.7	0.3	13.4	0.8	7.9	20.2	808.0	1.8	17.5	27.6
18:17:00	1.2	11.7	0.3	13.4	0.9	9.3	20.2	808.0	1.4	14.4	27.6
18:18:00	1.1	10.6	0.3	13.1	0.7	6.9	20.2	808.0	1.7	16.8	27.6
18:19:00	1.2	11.7	0.3	13.4	0.9	9.3	20.2	807.0	1.9	18.9	27.6
18:20:00	1.2	11.7	0.3	13.4	0.9	8.6	20.2	807.0	2.0	19.6	27.6
18:21:00	1.1	11.3	0.3	13.1	0.8	8.2	20.2	807.0	1.9	18.9	27.5
18:22:00	1.2	12.0	0.3	13.1	1.0	10.3	20.1	805.0	1.6	16.5	27.5
18:23:00	1.2	11.7	0.3	13.1	0.8	7.9	20.2	807.0	1.8	17.5	27.5
18:24:00	1.3	12.7	0.3	13.1	1.0	10.3	20.1	805.0	2.2	21.6	27.5
18:25:00	1.2	11.7	0.3	13.1	0.9	8.6	20.1	806.0	1.9	18.5	27.5
18:26:00	1.3	13.4	0.3	13.1	1.1	10.6	20.1	806.0	2.3	23.0	27.4
18:27:00	1.3	13.4	0.3	13.1	1.0	10.3	20.1	805.0	1.8	18.2	27.4
18:28:00	1.3	12.7	0.3	13.7	1.0	10.3	20.1	804.0	2.1	21.0	27.4
18:29:00	1.5	14.8	0.3	13.4	1.2	11.7	20.1	805.0	2.3	22.7	27.4
18:30:00	1.3	12.7	0.3	13.1	1.0	10.0	20.1	804.0	1.8	17.9	27.4
18:31:00	1.4	14.1	0.3	13.4	1.1	11.3	20.1	806.0	2.2	22.0	27.3
18:32:00	1.5	14.8	0.3	13.1	1.2	12.0	20.1	804.0	1.7	17.2	27.3
18:33:00	1.4	14.1	0.3	12.7	1.1	11.0	20.1	805.0	2.1	21.3	27.3
18:34:00	1.3	13.4	0.3	12.7	1.1	10.6	20.1	805.0	2.1	20.6	27.3
18:35:00	1.3	13.4	0.3	13.1	1.0	10.0	20.1	805.0	1.9	19.2	27.2
18:36:00	1.3	12.7	0.3	13.1	1.1	10.6	20.1	805.0	1.8	17.9	27.2
18:37:00	1.2	12.0	0.3	12.7	1.0	10.0	20.1	803.0	1.8	17.5	27.2
18:38:00	1.2	12.0	0.3	12.7	1.1	10.6	20.1	805.0	1.7	17.2	27.2
18:39:00	0.8	7.9	0.2	11.0	0.7	6.5	20.1	806.0	1.6	16.5	27.2
18:40:00	0.9	8.6	0.2	11.3	0.5	5.5	20.1	806.0	1.5	15.1	27.2
18:41:00	0.9	8.6	0.2	12.0	0.7	6.9	20.1	805.0	1.7	16.8	27.2
18:42:00	0.8	7.9	0.2	11.3	0.5	5.2	20.1	804.0	1.3	13.4	27.1
18:43:00	0.7	6.9	0.2	12.4	0.5	5.2	20.1	805.0	1.2	11.7	27.1
18:44:00	0.7	7.2	0.2	12.4	0.5	5.5	20.1	804.0	1.2	12.0	27.1
18:45:00	0.7	7.2	0.2	12.0	0.6	5.8	20.1	804.0	1.2	12.4	27.1
18:46:00	0.7	7.2	0.2	12.0	0.6	5.8	20.1	804.0	1.3	13.4	27.1
18:47:00	0.8	8.2	0.2	12.0	0.5	4.8	20.1	804.0	1.8	17.5	27.1
18:48:00	0.9	9.3	0.3	15.1	0.7	6.5	20.1	805.0	1.6	16.1	27.0
18:49:00	0.9	9.3	0.3	12.7	0.7	6.9	20.1	804.0	1.8	17.9	27.0
18:50:00	1.1	11.0	0.2	12.4	0.7	7.2	20.1	806.0	2.0	20.3	27.0
18:51:00	1.1	11.3	0.3	12.7	0.9	8.6	20.1	804.0	1.6	16.5	27.0

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
18:52:00	1.2	12.0	0.2	12.4	0.7	7.2	20.1	806.0	2.0	19.6	27.1
18:53:00	1.1	11.3	0.2	12.4	0.9	9.3	20.1	804.0	2.0	20.3	27.0
18:54:00	1.2	12.0	0.2	12.4	0.7	6.9	20.1	806.0	2.2	22.3	27.0
18:55:00	0.9	9.3	0.2	10.0	0.7	6.9	20.1	805.0	1.7	17.2	27.0
18:56:00	0.9	8.6	0.2	10.3	0.6	5.8	20.1	804.0	1.6	16.5	27.0
18:57:00	0.8	7.9	0.2	11.0	0.5	5.2	20.1	805.0	1.3	13.4	27.0
18:58:00	0.7	7.2	0.2	11.3	0.6	6.2	20.1	804.0	1.4	14.4	26.9
18:59:00	0.9	8.6	0.2	11.0	0.5	5.2	20.1	804.0	1.5	15.1	26.9
19:00:00	0.8	8.3	0.2	11.3	0.5	4.8	20.1	806.0	1.8	18.2	26.9
19:01:00	0.9	8.6	0.2	11.3	0.4	4.1	20.1	806.0	2.0	20.3	26.9
19:02:00	0.9	8.6	0.2	11.3	0.4	3.8	20.1	806.0	1.8	18.2	26.9
19:03:00	0.8	7.9	0.2	11.3	0.5	4.8	20.1	806.0	1.9	18.9	26.9
19:04:00	0.9	8.6	0.2	11.0	0.3	3.4	20.1	806.0	1.9	18.9	26.8
19:05:00	0.6	6.2	0.2	10.6	0.5	4.8	20.1	806.0	1.7	17.2	26.8
19:06:00	0.7	7.2	0.2	11.0	0.4	4.5	20.1	805.0	1.6	16.1	26.8
19:07:00	0.7	6.5	0.2	11.0	0.3	3.4	20.1	806.0	1.6	16.5	26.8
19:08:00	0.8	7.9	0.2	11.0	0.5	5.2	20.1	805.0	1.6	16.5	26.8
19:09:00	0.9	8.6	0.2	10.6	0.3	2.7	20.1	805.0	1.8	17.5	26.7
19:10:00	0.7	6.9	0.2	10.6	0.5	4.8	20.1	805.0	1.6	15.8	26.7
19:11:00	0.8	7.9	0.2	10.6	0.3	3.4	20.1	806.0	1.8	17.5	26.7
19:12:00	0.7	6.5	0.2	10.6	0.4	4.5	20.1	804.0	1.4	13.7	26.7
19:13:00	0.5	5.5	0.1	4.8	0.2	1.7	0.2	7.9	25.8	258.0	26.7
19:14:00	0.5	5.2	0.1	4.5	0.2	1.7	0.1	3.4	0.7	6.9	26.6
19:15:00	0.4	4.1	0.1	4.1	0.1	1.4	0.1	4.8	1.0	9.6	26.6
19:16:00	0.3 <i>200</i>	2.7	0.1 <i>200</i>	3.4	0.1 <i>200</i>	1.0	0.1 <i>200</i>	2.4	0.5 <i>200</i>	5.2	26.6
19:17:00	0.4	4.5	0.1	2.7	42.5	425.4	0.1	2.7	0.7	7.2	26.6
19:18:00	0.4	4.1	0.1	2.7	42.8 <i>for</i>	428.4	0.1	4.1	1.3	13.1	26.6
19:19:00	8.1	80.7	0.0	2.1	0.3	3.1	0.1	3.1	1.0	10.0	26.6
19:20:00	29.6	296.5	0.0	1.7	0.2	2.1	0.1	2.7	0.9	8.9	26.6
19:21:00	35.8	358.3	0.0	1.4	0.1	0.7	0.1	3.4	1.4	13.7	26.5
19:22:00	38.8	387.9	0.0	1.0	0.0	0.3	0.1	3.1	1.3	12.7	26.5
19:23:00	40.4	404.4	0.0	0.7	0.1	0.7	0.0	1.7	0.9	8.6	26.5
19:24:00	41.3 <i>for</i>	412.6	0.0	0.7	-0.0	-0.3	0.1	3.1	1.2	11.7	26.5
19:25:00	14.0	139.8	0.0	0.3	0.1	0.7	0.1	2.7	4.2	41.6	26.5
19:26:00	3.8	37.8	0.0	0.0	0.1	0.7	0.0	1.7	30.4 <i>for</i>	304.1	26.4
19:27:00	2.3	23.4	17.5	873.0	0.0	0.0	18.1	725.0	25.2	252.2	26.4
19:28:00	1.8	17.5	17.6 <i>for</i>	880.0	-0.0	-0.3	18.0 <i>for</i>	720.0	0.3	3.4	26.4

Run 3

DATE:

July 22,1998

CLIENT REP:

R.KRUSE

PLANT:

IBP / DC

WITNESSED?:

N/A

FUEL TYPE:

Steam

BURNER TYPE:

N/A

OPERATOR:

SM/DW

GENERATOR TYPE:

N/A

TEST LOCATION:

SUPER COOKER

O2 GENERATOR TYPE:

N/A

CALIBRATION GASES

O2	CO2	CO	SO2	THC	NOx
0	0	0	0	0	0
10.2	9.9	30.3	45.1	N/A	46
18	17.7	86.9	88.7	N/A	84.3

END TIME	SAMPLE POINT	O2 %	CO2 %	CO ppm	SO2 ppm	THC ppm	NOx ppm
2040	1	20.23	0.17	1.68	0.80		0.30
2100	2	20.22	0.15	1.73	0.70		0.20
2120	3	20.23	0.12	1.60	0.70		0.20
	AVERAGES	20.23	0.15	1.67	0.73	#DIV/0!	0.23

Barometric Pressure:

29.05

EFFLUENT GAS CONCENTRATION, % or PPM

	O2	CO2	CO	SO2	THC	NOx
PRE ZERO	0.1	0.1	0.5	0.3		0.1
POST ZER	0.1	-0.1	0.8	0.3		0.1
ACT SPAN	18	17.7	30.3	88.7	N/A	84.3
PRE SPAN	18	17.6	30.4	41.3		42.8
POST SPA	18.1	17.6	30.1	41.4		44.3

GAS CONC.	20.18	0.15	1.04	0.94	#DIV/0!	0.26
GAS CONC.	18.96	0.14	0.98	0.88	#DIV/0!	0.24

F-factor (Fc)-----

N/A

scf/10e6 btu

lb/hr NOx

0.015

lb/hr SO2

lb/hr CO

0.075

0.037

Stack Flowrate-

5.1523E+05

(wet,scf/hr)

EFFLUENT GAS CONC CALCULATION

GAS CONC. = (Avg Stk Conc - Avg Zero Cal) * (Span Conc/(Avg Span Cal - Avg Zero Cal))

PLANT: IBP DAKOTA CITY

UNIT: COOKER

TODAYS DATE: 07-22-1998

START/END TIMES: 20:20/20:40

MOISTURE = 5%

RUN NUMBER: 3

PAGE 1

OPERATOR: MILLER

MEASUREMENT DATE:

20:40/21:00 21:00/21:20

RESPONSE TIME = 2 MIN

TIME	NOx CONC	NOx CONC	SO2 CONC	SO2 CONC	CO2 CONC	CO2 CONC	O2 CONC	O2 CONC	CO CONC	CO CONC
MIN	DRY	WET	DRY	WET	DRY	WET	DRY	WET	DRY	WET
ENDING	ppm	ppm	ppm	ppm	%	%	%	%	ppm	ppm
20:23:00	0.3	0.3	0.7	0.7	0.17	0.16	20.25	19.24	1.83	1.73
20:24:00	0.3	0.3	0.8	0.8	0.17	0.16	20.26	19.25	1.98	1.88
20:25:00	0.4	0.4	0.8	0.7	0.17	0.16	20.22	19.21	1.66	1.57
20:26:00	0.4	0.4	0.8	0.8	0.17	0.16	20.23	19.21	1.54	1.46
20:27:00	0.4	0.4	0.8	0.7	0.17	0.16	20.22	19.21	1.52	1.44
20:28:00	0.3	0.3	0.8	0.7	0.17	0.16	20.25	19.23	1.82	1.73
20:29:00	0.3	0.3	0.8	0.7	0.17	0.16	20.25	19.24	1.74	1.65
20:30:00	0.4	0.4	0.8	0.7	0.17	0.16	20.23	19.21	1.53	1.45
20:31:00	0.3	0.3	0.8	0.8	0.17	0.16	20.23	19.21	1.65	1.57
20:32:00	0.2	0.2	0.7	0.7	0.16	0.16	20.24	19.23	1.84	1.75
20:33:00	0.3	0.3	0.8	0.8	0.16	0.16	20.22	19.21	1.46	1.39
20:34:00	0.4	0.4	0.8	0.7	0.17	0.16	20.20	19.19	1.47	1.40
20:35:00	0.3	0.3	0.7	0.7	0.16	0.16	20.23	19.22	1.54	1.46
20:36:00	0.3	0.3	0.7	0.7	0.17	0.16	20.22	19.21	1.76	1.68
20:37:00	0.3	0.3	0.8	0.8	0.17	0.16	20.23	19.22	1.78	1.69
20:38:00	0.3	0.3	0.8	0.8	0.17	0.16	20.20	19.19	1.57	1.49
20:39:00	0.3	0.3	0.8	0.7	0.17	0.16	20.24	19.23	1.86	1.76
20:40:00	0.2	0.2	0.8	0.7	0.17	0.16	20.22	19.21	1.60	1.52
MEAN	0.3	0.3	0.8	0.7	0.17	0.16	20.23	19.22	1.68	1.59
20:43:00	0.3	0.2	0.7	0.7	0.16	0.15	20.22	19.21	1.82	1.73
20:44:00	0.3	0.2	0.7	0.7	0.17	0.16	20.22	19.21	1.74	1.65
20:45:00	0.3	0.2	0.8	0.7	0.16	0.15	20.22	19.21	1.75	1.67
20:46:00	0.3	0.3	0.8	0.7	0.16	0.15	20.22	19.21	1.71	1.62
20:47:00	0.2	0.2	0.8	0.8	0.16	0.15	20.23	19.22	1.86	1.76
20:48:00	0.3	0.3	0.8	0.7	0.16	0.15	20.20	19.19	1.66	1.58
20:49:00	0.2	0.2	0.8	0.7	0.15	0.14	20.25	19.23	1.95	1.86
20:50:00	0.2	0.2	0.8	0.7	0.15	0.14	20.22	19.21	1.74	1.65
20:51:00	0.3	0.3	0.8	0.7	0.15	0.14	20.22	19.21	1.72	1.64
20:52:00	0.2	0.2	0.8	0.7	0.14	0.13	20.23	19.22	1.82	1.73
20:53:00	0.2	0.2	0.8	0.7	0.13	0.12	20.23	19.21	1.66	1.58
20:54:00	0.2	0.2	0.7	0.7	0.14	0.13	20.22	19.21	1.46	1.39
20:55:00	0.2	0.2	0.7	0.7	0.15	0.14	20.22	19.21	1.65	1.57
20:56:00	0.3	0.2	0.7	0.6	0.14	0.14	20.22	19.21	1.84	1.75
20:57:00	0.2	0.2	0.7	0.7	0.14	0.13	20.23	19.22	1.68	1.60
20:58:00	0.2	0.2	0.7	0.7	0.14	0.14	20.22	19.21	1.70	1.62

PLANT: IBP DAKOTA CITY

UNIT: COOKER

TODAYS DATE: 07-22-1998

START/END TIMES: 20:20/20:40

MOISTURE = 5%

RUN NUMBER: 3

PAGE 2

OPERATOR: MILLER

MEASUREMENT DATE:

20:40/21:00

21:00/21:20

RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
20:59:00	0.2	0.2	0.8	0.7	0.15	0.14	20.23	19.21	1.71	1.63
21:00:00	0.3	0.3	0.7	0.7	0.15	0.14	20.20	19.19	1.58	1.50
MEAN	0.2	0.2	0.7	0.7	0.15	0.14	20.22	19.21	1.73	1.64
21:03:00	0.2	0.2	0.7	0.6	0.14	0.13	20.23	19.22	1.69	1.60
21:04:00	0.2	0.2	0.7	0.6	0.14	0.13	20.22	19.21	1.67	1.58
21:05:00	0.2	0.2	0.7	0.6	0.14	0.13	20.22	19.21	1.71	1.63
21:06:00	0.2	0.2	0.7	0.6	0.14	0.13	20.24	19.23	1.77	1.68
21:07:00	0.2	0.2	0.7	0.6	0.14	0.13	20.24	19.23	1.72	1.63
21:08:00	0.3	0.2	0.8	0.7	0.14	0.13	20.22	19.21	1.48	1.40
21:09:00	0.3	0.3	0.7	0.7	0.14	0.13	20.22	19.21	1.43	1.36
21:10:00	0.2	0.2	0.7	0.6	0.13	0.12	20.23	19.21	1.56	1.49
21:11:00	0.2	0.2	0.6	0.6	0.13	0.12	20.23	19.22	1.72	1.63
21:12:00	0.2	0.2	0.6	0.6	0.12	0.12	20.22	19.21	1.71	1.63
21:13:00	0.2	0.2	0.7	0.7	0.12	0.12	20.22	19.21	1.36	1.30
21:14:00	0.2	0.2	0.7	0.6	0.12	0.11	20.22	19.21	1.39	1.32
21:15:00	0.2	0.2	0.7	0.6	0.12	0.11	20.24	19.23	1.71	1.62
21:16:00	0.1	0.1	0.7	0.7	0.11	0.11	20.24	19.23	1.58	1.50
21:17:00	0.2	0.2	0.6	0.6	0.11	0.10	20.22	19.21	1.42	1.35
21:18:00	0.1	0.1	0.6	0.5	0.10	0.09	20.26	19.25	1.76	1.67
21:19:00	0.1	0.1	0.6	0.6	0.10	0.09	20.25	19.24	1.64	1.56
21:20:00	0.2	0.2	0.6	0.6	0.09	0.09	20.23	19.22	1.44	1.37
MEAN	0.2	0.2	0.7	0.6	0.12	0.12	20.23	19.22	1.60	1.52

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
20:06:00	0.8	7.9	0.2	7.6	0.3	3.4	20.2	808.0	1.9	18.9	25.6
20:07:00	0.7	7.2	0.2	7.9	0.3	3.4	20.2	807.0	1.5	15.5	25.6
20:08:00	0.7	6.9	0.2	7.9	0.3	3.1	20.2	808.0	1.7	17.2	25.6
20:09:00	0.9	8.6	0.2	8.3	0.2	2.4	20.2	809.0	2.0	19.9	25.6
20:10:00	0.6	6.2	0.2	8.3	0.4	3.8	20.2	809.0	1.9	18.6	25.6
20:11:00	0.7	7.2	0.1	7.2	0.2	1.7	20.2	809.0	1.8	17.9	25.6
20:12:00	0.8	8.3	0.2	7.9	0.3	3.1	20.2	808.0	1.8	17.9	25.6
20:13:00	0.7	7.2	0.2	7.6	0.3	2.7	20.2	809.0	1.9	18.6	25.5
20:14:00	0.8	8.3	0.2	7.6	0.1	1.4	20.3	810.0	1.9	18.6	25.5
20:15:00	0.7	6.5	0.2	7.6	0.3	3.1	20.2	809.0	1.9	18.6	25.5
20:16:00	0.6	5.8	0.2	7.9	0.2	2.1	20.3	810.0	2.0	19.9	25.5
20:17:00	0.7	7.2	0.2	7.9	0.2	2.4	20.3	810.0	2.0	19.9	25.4
20:18:00	0.7	6.5	0.2	8.6	0.4	3.8	20.2	808.0	1.5	15.5	25.4
20:19:00	0.7	6.5	0.2	8.9	0.2	2.4	20.3	810.0	2.0	20.3	25.4
Start 20:20:00	0.7	6.9	0.2	8.3	0.3	3.1	20.3	810.0	2.0	19.9	25.4
20:21:00	0.9	9.3	0.2	8.3	0.3	3.1	20.2	809.0	1.7	16.8	25.4
20:22:00	0.7	6.9	0.2	8.3	0.3	3.4	20.3	810.0	1.9	18.9	25.3
20:23:00	0.7	7.2	0.2	8.6	0.3	3.4	20.3	810.0	1.9	18.6	25.3
20:24:00	0.8	7.9	0.2	8.3	0.4	3.8	20.2	809.0	2.0	19.9	25.3
20:25:00	0.7	7.2	0.2	8.9	0.4	4.1	20.2	809.0	1.4	14.4	25.2
20:26:00	0.9	8.6	0.2	8.3	0.3	3.4	20.2	809.0	1.5	15.5	25.2
20:27:00	0.8	7.6	0.2	8.6	0.4	3.8	20.2	809.0	1.5	15.1	25.1
20:28:00	0.8	8.3	0.2	8.3	0.3	2.7	20.3	811.0	2.0	19.9	25.1
20:29:00	0.7	7.2	0.2	8.3	0.3	3.1	20.2	809.0	1.6	15.8	25.1
20:30:00	0.9	8.9	0.2	8.3	0.4	3.8	20.2	809.0	1.5	15.1	25.1
20:31:00	0.9	8.6	0.2	8.3	0.2	2.4	20.3	810.0	1.9	18.9	25.1
20:32:00	0.8	7.6	0.2	8.3	0.3	3.1	20.2	809.0	1.6	16.5	25.0
20:33:00	0.9	8.6	0.2	8.3	0.3	3.4	20.2	808.0	1.4	14.4	25.0
20:34:00	0.7	6.9	0.2	8.3	0.3	3.4	20.2	808.0	1.4	14.4	25.0
20:35:00	0.7	7.2	0.2	7.9	0.2	2.1	20.3	811.0	1.8	18.2	25.0
20:36:00	0.7	7.2	0.2	8.3	0.3	2.8	20.2	808.0	1.5	14.8	24.9
20:37:00	0.8	7.9	0.2	8.6	0.4	4.5	20.2	808.0	1.8	17.9	24.9
20:38:00	0.9	8.6	0.2	8.3	0.2	2.1	20.2	809.0	1.5	15.5	24.9
20:39:00	0.8	8.3	0.2	8.3	0.3	2.8	20.2	808.0	1.9	19.3	24.9
20:40:00	0.7	6.5	0.2	8.3	0.2	2.4	20.3	810.0	1.8	17.5	24.9
20:41:00	0.7	7.2	0.2	7.9	0.3	2.8	20.2	808.0	1.5	15.5	24.8
20:42:00	0.8	7.6	0.2	7.9	0.2	2.4	20.3	810.0	1.8	18.2	24.8
20:43:00	0.7	6.5	0.2	8.3	0.3	2.8	20.2	808.0	1.6	15.8	24.8
20:44:00	0.7	7.2	0.2	8.3	0.3	3.1	20.2	808.0	1.6	15.8	24.7
20:45:00	0.7	7.2	0.2	7.9	0.3	3.4	20.2	808.0	1.7	17.2	24.7
20:46:00	0.8	7.9	0.2	8.3	0.2	1.7	20.2	808.0	1.5	15.5	24.7
20:47:00	0.7	7.2	0.2	8.3	0.3	3.4	20.2	808.0	2.0	19.6	24.6
20:48:00	0.9	8.6	0.2	7.6	0.2	2.1	20.2	809.0	1.6	15.8	24.6
20:49:00	0.8	7.6	0.2	7.6	0.3	3.1	20.2	809.0	2.0	19.9	24.6

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
20:50:00	0.7	7.2	0.1	6.9	0.2	2.1	20.3	810.0	1.8	18.2	24.6
20:51:00	0.8	7.9	0.2	7.6	0.2	2.1	20.3	810.0	1.6	15.8	24.5
20:52:00	0.7	7.2	0.1	6.5	0.3	2.8	20.3	810.0	2.0	19.6	24.5
20:53:00	0.7	7.2	0.1	6.5	0.2	2.4	20.2	809.0	1.8	17.9	24.5
20:54:00	0.7	6.9	0.1	7.2	0.2	1.7	20.3	810.0	1.6	16.2	24.5
20:55:00	0.7	7.2	0.1	6.9	0.2	2.1	20.3	810.0	1.6	15.8	24.4
20:56:00	0.7	6.5	0.1	7.2	0.3	2.8	20.2	808.0	1.6	16.2	24.4
20:57:00	0.6	6.2	0.2	7.6	0.2	2.4	20.3	810.0	1.9	18.6	24.4
20:58:00	0.8	7.6	0.2	7.6	0.1	0.7	20.3	810.0	1.7	16.8	24.3
20:59:00	0.9	8.6	0.1	6.9	0.2	2.4	20.2	809.0	1.9	18.9	24.3
21:00:00	0.7	6.9	0.2	7.6	0.3	3.4	20.2	808.0	1.3	13.4	24.3
21:01:00	0.8	7.9	0.1	7.2	0.3	2.8	20.2	808.0	1.6	16.5	24.2
21:02:00	0.6	6.2	0.2	7.6	0.2	2.4	20.3	810.0	1.9	18.6	24.2
21:03:00	0.7	7.2	0.1	6.9	0.1	1.0	20.3	810.0	1.9	19.3	24.2
21:04:00	0.7	6.5	0.1	6.9	0.2	2.1	20.3	810.0	1.9	18.6	24.2
21:05:00	0.7	7.2	0.1	6.9	0.3	2.8	20.2	808.0	1.4	14.4	24.2
21:06:00	0.7	6.5	0.1	6.9	0.1	1.0	20.3	810.0	1.8	17.5	24.2
21:07:00	0.8	7.9	0.1	6.9	0.3	2.8	20.2	809.0	1.5	14.8	24.2
21:08:00	0.7	7.2	0.1	6.5	0.2	2.1	20.2	809.0	1.4	14.4	24.2
21:09:00	0.7	6.5	0.1	6.9	0.3	2.8	20.2	808.0	1.5	14.8	24.2
21:10:00	0.8	7.6	0.1	6.5	0.3	2.8	20.2	809.0	1.6	16.5	24.2
21:11:00	0.6	5.8	0.1	6.5	0.2	1.7	20.3	810.0	1.9	18.9	24.2
21:12:00	0.7	6.5	0.1	6.2	0.2	2.4	20.2	808.0	1.5	15.5	24.1
21:13:00	0.7	6.9	0.1	6.2	0.2	1.7	20.2	809.0	1.3	13.1	24.1
21:14:00	0.7	6.5	0.1	5.8	0.3	2.8	20.2	809.0	1.5	14.8	24.1
21:15:00	0.8	7.6	0.1	5.5	0.1	1.0	20.3	810.0	1.8	17.9	24.0
21:16:00	0.5	5.2	0.1	5.5	0.2	2.1	20.2	809.0	1.3	13.1	24.0
21:17:00	0.5	5.2	0.1	4.8	0.2	2.1	20.2	809.0	1.6	16.5	23.9
21:18:00	0.6	5.8	0.1	4.8	0.1	0.7	20.3	810.0	1.8	17.5	23.9
21:19:00	0.7	6.5	0.1	4.8	0.2	1.7	20.2	809.0	1.4	14.4	23.8
21:20:00	0.6	5.8	0.1	4.8	0.1	1.0	20.3	811.0	1.8	17.9	23.8
21:21:00	0.7	6.5	0.1	5.5	0.2	2.1	20.2	809.0	1.4	14.1	23.7
21:22:00	0.7	7.2	0.1	4.8	0.2	2.4	20.2	809.0	1.4	14.1	23.7
21:23:00	0.7	6.5	0.1	4.8	0.2	2.1	20.2	809.0	1.4	14.4	23.6
21:24:00	0.7	6.9	0.1	4.8	0.3	2.8	20.2	809.0	1.4	14.4	23.6
21:25:00	0.6	6.2	0.1	4.8	0.2	2.1	20.2	809.0	1.4	13.8	23.6
21:26:00	0.6	5.8	0.1	4.1	0.1	1.4	20.3	810.0	1.6	15.8	23.6
21:27:00	0.7	7.2	0.1	4.5	0.3	2.8	20.2	809.0	1.5	14.8	23.5
21:28:00	0.6	6.2	0.1	4.1	0.2	1.7	20.2	809.0	1.6	15.8	23.5
21:29:00	0.6	6.2	0.1	4.1	0.2	1.7	20.3	812.0	1.5	15.5	23.5
21:30:00	0.7	6.5	-0.1	-3.4	0.2	2.4	1.1	45.0	3.3	33.3	23.5
21:31:00	0.5	4.8	-0.1	-3.4	0.1	1.0	0.2	6.5	1.8	17.9	23.5
21:32:00	0.3 <i>low</i>	3.4	-0.1 <i>low</i>	-3.4	0.1 <i>low</i>	1.0	0.1 <i>low</i>	3.1	0.8 <i>low</i>	7.9	23.4
21:33:00	0.4	3.8	-0.1	-3.4	44.0	440.1	0.1	2.4	1.0	10.3	23.5
21:34:00	0.3	2.8	-0.1	-3.4	44.3 <i>low</i>	442.5	0.1	4.1	1.5	14.8	23.4

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
21:35:00	3.7	37.1	-0.1	-3.4	0.3	2.8	0.1	3.1	1.1	10.7	23.5
21:36:00	23.6	235.8	-0.1	-3.4	0.2	2.1	0.1	2.1	1.0	10.0	23.5
21:37:00	31.9	319.4	-0.1	-3.4	0.1	0.7	0.1	2.1	1.3	12.7	23.4
21:38:00	35.9	358.9	-0.1	-3.8	0.1	0.7	0.0	1.7	1.1	10.7	23.4
21:39:00	38.3	383.3	-0.1	-3.4	-0.1	-0.7	0.1	3.8	1.1	10.7	23.5
21:40:00	40.2	401.9	-0.1	-3.8	0.0	0.3	0.1	2.4	1.6	15.8	23.5
21:41:00	41.4 <i>sm</i>	414.3	-0.1	-4.1	0.1	0.7	0.0	1.7	1.2	12.4	23.5
21:42:00	34.3	342.8	17.2	858.0	-0.1	-1.4	17.1	684.2	1.4	14.1	23.5
21:43:00	4.2	42.3	17.5	877.0	-0.1	-1.0	18.2	728.0	0.4	3.8	23.4
21:44:00	2.6	25.8	17.6 <i>sm</i>	879.0	-0.1	-1.0	18.1 <i>sm</i>	725.0	0.7	6.5	23.4
21:45:00	2.0	20.3	0.2	11.7	-0.1	-1.0	0.6	23.7	0.4	4.1	23.4
21:46:00	1.5	14.8	0.1	2.8	-0.0	-0.3	0.1	3.4	30.1 <i>sm</i>	300.8	23.3

Run 4

DATE: July 22, 1998 CLIENT REP: R.KRUSE
 PLANT: IBP / DC WITNESSED?: N/A
 FUEL TYPE: Steam BURNER TYPE: N/A
 OPERATOR: SM/DW GENERATOR TYPE: N/A
 TEST LOCATION: SUPER COOKER O2 GENERATOR TYPE: N/A

CALIBRATION GASES

O2	CO2	CO	SO2	THC	NOx
0	0	0	0	0	0
10.2	9.9	30.3	45.1	N/A	46
18	17.7	86.9	88.7	N/A	84.3

END TIME	SAMPLE POINT	O2 %	CO2 %	CO ppm	SO2 ppm	THC ppm	NOx ppm
2222	1	19.21	4.84	16.6	13.6		5.9
2242	2	19.15	5.12	18.05	12.4		5.3
2302	3	19.19	5.07	21.59	10.4		4.3
	AVERAGES	19.18	5.01	18.75	12.13	#DIV/0!	5.17

Barometric Pres: 29.05

EFFLUENT GAS CONCENTRATION, % or PPM

	O2	CO2	CO	SO2	THC	NOx
PRE ZERO	0.1	-0.1	0.8	0.3		0.1
POST ZERO	0.1	0	0.9	1.7		1.7
ACT SPAN	18	17.7	30.3	45.1	N/A	46
PRE SPAN	18.1	17.6	30.1	41.4		44.3
POST SPAN	18.2	17.6	30.2	41.2		46.5

GAS CONC. 19.03 5.07 18.51 12.46 #DIV/0! 4.41
 GAS CONC. 18.50 4.93 17.99 12.11 #DIV/0! 4.29

F-factor (Fc)-----

N/A

scf/10e6 btu

lb/hr SO2 0.056

lb/hr NOx

0.014

lb/hr CO 0.037

Stack Flowrate- 2.8011E+04 (wet, scf/hr)

EFFLUENT GAS CONC CALCULATION

$$\text{GAS CONC.} = (\text{Avg Stk Conc} - \text{Avg Zero Cal}) * (\text{Span Conc} / (\text{Avg Span Cal} - \text{Avg Zero Cal}))$$

PLANT: IBP DAKOTA CITY

UNIT: COOKER

TODAYS DATE: 07-22-1998

START/END TIMES: 22:02/22:22

MOISTURE = 5%

RUN NUMBER: 4

PAGE 1

OPERATOR: MILLER

MEASUREMENT DATE:

22:22/22:42 22:42/23:02

RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
22:05:00	6.2	5.9	13.4	12.7	4.82	4.58	19.25	18.29	17.39	16.52
22:06:00	6.1	5.8	13.5	12.9	4.77	4.53	19.28	18.32	17.65	16.77
22:07:00	6.0	5.7	13.6	13.0	4.76	4.52	19.28	18.32	17.75	16.87
22:08:00	6.2	5.9	13.5	12.9	4.84	4.60	19.25	18.29	17.94	17.05
22:09:00	6.0	5.7	13.6	12.9	4.77	4.53	19.27	18.31	17.45	16.58
22:10:00	6.0	5.7	13.6	12.9	4.66	4.42	19.28	18.32	16.82	15.98
22:11:00	6.0	5.7	13.8	13.1	4.76	4.52	19.25	18.29	16.56	15.73
22:12:00	6.0	5.7	13.8	13.1	4.58	4.36	19.26	18.30	16.26	15.45
22:13:00	6.1	5.8	13.7	13.1	4.72	4.49	19.22	18.26	15.91	15.11
22:14:00	5.8	5.5	13.8	13.1	4.80	4.56	19.21	18.25	16.05	15.24
22:15:00	6.1	5.8	13.9	13.2	4.78	4.55	19.18	18.22	16.08	15.28
22:16:00	5.9	5.6	13.9	13.2	4.87	4.63	19.16	18.20	16.32	15.50
22:17:00	5.9	5.6	13.7	13.0	4.92	4.67	19.14	18.18	16.11	15.30
22:18:00	5.9	5.6	13.4	12.8	5.03	4.78	19.13	18.17	15.95	15.15
22:19:00	5.7	5.4	13.4	12.7	5.08	4.83	19.15	18.20	16.47	15.65
22:20:00	5.8	5.5	13.3	12.6	4.97	4.72	19.17	18.21	16.35	15.53
22:21:00	5.6	5.4	13.3	12.6	4.96	4.71	19.13	18.17	15.70	14.91
22:22:00	5.7	5.4	13.4	12.8	5.02	4.77	19.14	18.18	15.84	15.05
MEAN	5.9	5.7	13.6	12.9	4.84	4.60	19.21	18.25	16.60	15.77
22:25:00	5.6	5.4	13.2	12.5	5.16	4.90	19.12	18.16	17.45	16.57
22:26:00	5.4	5.1	12.8	12.1	5.23	4.97	19.11	18.16	17.07	16.21
22:27:00	5.7	5.4	13.1	12.5	5.28	5.01	19.10	18.15	17.75	16.87
22:28:00	5.5	5.2	13.0	12.4	5.19	4.93	19.12	18.16	17.55	16.67
22:29:00	5.4	5.2	12.9	12.2	5.21	4.95	19.11	18.16	17.26	16.39
22:30:00	5.5	5.2	12.9	12.3	5.41	5.14	19.09	18.13	17.64	16.76
22:31:00	5.4	5.1	12.9	12.2	5.26	4.99	19.11	18.15	17.81	16.92
22:32:00	5.5	5.2	12.9	12.2	5.04	4.79	19.17	18.21	17.39	16.52
22:33:00	5.3	5.1	12.6	11.9	4.83	4.59	19.25	18.28	16.98	16.13
22:34:00	5.3	5.0	12.5	11.9	4.92	4.67	19.20	18.24	17.12	16.26
22:35:00	5.4	5.2	12.3	11.7	4.98	4.73	19.17	18.21	17.39	16.52
22:36:00	5.2	5.0	12.3	11.7	5.01	4.76	19.16	18.20	17.99	17.09
22:37:00	5.3	5.0	12.1	11.5	5.04	4.79	19.17	18.21	18.61	17.68
22:38:00	5.1	4.9	11.9	11.3	5.03	4.77	19.17	18.22	19.42	18.45
22:39:00	5.2	4.9	11.7	11.1	5.18	4.92	19.11	18.15	19.57	18.60
22:40:00	5.2	4.9	11.3	10.8	5.14	4.88	19.15	18.19	19.27	18.30

PLANT: IBP DAKOTA CITY

UNIT: COOKER

TODAYS DATE: 07-22-1998

START/END TIMES: 22:02/22:22

MOISTURE = 5%

RUN NUMBER: 4

PAGE 2

OPERATOR: MILLER

MEASUREMENT DATE:

22:22/22:42

22:42/23:02

RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
22:41:00	4.8	4.6	11.1	10.5	4.98	4.73	19.19	18.23	19.35	18.38
22:42:00	5.0	4.8	10.9	10.3	5.23	4.97	19.19	18.23	19.43	18.46
MEAN	5.3	5.1	12.4	11.7	5.12	4.86	19.15	18.19	18.05	17.15
22:45:00	4.9	4.6	10.8	10.2	5.18	4.92	19.15	18.20	20.66	19.62
22:46:00	4.8	4.6	10.9	10.3	5.25	4.99	19.12	18.16	20.78	19.74
22:47:00	4.7	4.5	10.7	10.2	5.09	4.83	19.20	18.24	20.81	19.77
22:48:00	4.5	4.3	10.4	9.9	5.11	4.86	19.20	18.24	20.72	19.68
22:49:00	4.5	4.3	10.2	9.7	5.23	4.97	19.13	18.17	20.55	19.53
22:50:00	4.4	4.2	10.4	9.9	5.24	4.97	19.16	18.20	21.09	20.03
22:51:00	4.4	4.2	10.2	9.7	5.04	4.79	19.17	18.21	20.78	19.74
22:52:00	4.4	4.1	10.2	9.6	5.11	4.85	19.19	18.23	20.54	19.52
22:53:00	4.3	4.1	10.1	9.6	5.26	5.00	19.13	18.17	21.15	20.09
22:54:00	4.2	4.0	10.2	9.7	5.15	4.89	19.18	18.22	21.91	20.81
22:55:00	4.1	3.9	10.1	9.6	5.22	4.96	19.16	18.20	21.91	20.82
22:56:00	4.2	4.0	10.4	9.9	5.13	4.87	19.15	18.19	22.51	21.38
22:57:00	4.2	4.0	10.4	9.9	4.96	4.71	19.19	18.23	22.61	21.48
22:58:00	4.0	3.8	10.2	9.7	4.83	4.59	19.26	18.30	22.01	20.91
22:59:00	4.1	3.9	10.3	9.8	5.02	4.77	19.24	18.28	22.35	21.23
23:00:00	4.0	3.8	10.7	10.1	4.81	4.57	19.27	18.30	23.04	21.88
23:01:00	3.9	3.7	10.6	10.1	4.80	4.56	19.30	18.33	22.68	21.55
23:02:00	3.9	3.7	10.6	10.0	4.79	4.55	19.32	18.35	22.74	21.60
MEAN	4.3	4.1	10.4	9.9	5.07	4.81	19.19	18.23	21.59	20.51

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
<i>Start</i> 22:02:00	13.1	131.0	4.8	239.3	5.7	57.4	19.3	772.0	17.0	169.9	22.9
22:03:00	13.2	132.0	4.6	231.0	6.4	63.6	19.3	772.0	16.8	167.5	22.9
22:04:00	13.4	133.8	4.8	239.3	6.2	61.9	19.3	770.0	17.4	174.3	22.9
22:05:00	13.4	134.4	4.7	235.2	5.7	57.1	19.3	771.0	17.5	174.7	22.9
22:06:00	13.6	136.2	4.7	233.8	6.4	64.3	19.3	771.0	17.4	174.3	22.9
22:07:00	13.5	135.1	4.6	228.3	5.5	55.4	19.3	773.0	18.0	179.5	22.9
22:08:00	13.6	135.8	4.6	230.4	6.5	64.6	19.3	771.0	18.2	181.6	22.9
22:09:00	13.6	136.2	4.8	240.4	6.1	60.5	19.3	770.0	17.5	175.4	22.9
22:10:00	13.6	135.8	4.7	234.5	5.8	58.1	19.2	769.0	16.9	168.8	22.9
22:11:00	14.0	139.9	5.0	247.6	6.5	65.0	19.2	769.0	16.6	166.1	22.9
22:12:00	13.8	137.9	4.6	230.7	5.5	55.0	19.3	771.0	15.9	158.9	22.8
22:13:00	13.9	138.6	4.9	246.9	6.4	64.3	19.1	766.0	15.7	156.5	22.8
22:14:00	13.7	136.9	4.9	245.5	5.7	57.1	19.2	767.0	16.0	160.2	22.8
22:15:00	13.9	139.3	4.6	228.3	5.9	58.8	19.3	770.0	16.1	161.3	22.7
22:16:00	13.9	138.6	4.7	233.8	6.2	62.2	19.2	767.0	16.5	164.7	22.7
22:17:00	13.6	135.8	4.9	246.5	5.5	55.4	19.1	765.0	16.2	161.6	22.7
22:18:00	13.5	134.8	5.0	251.0	6.1	61.2	19.1	766.0	16.0	160.2	22.7
22:19:00	13.4	133.8	5.1	255.1	5.3	53.3	19.1	766.0	16.5	165.4	22.6
22:20:00	13.4	133.8	5.2	258.6	6.1	60.5	19.1	766.0	16.3	162.6	22.6
22:21:00	13.4	134.1	5.1	253.1	5.7	57.4	19.1	765.0	15.2	151.6	22.6
22:22:00	13.4	134.1	5.0	252.0	5.3	53.3	19.2	767.0	16.1	160.9	22.6
22:23:00	13.2	131.7	5.3	266.8	6.0	59.8	19.1	765.0	16.1	161.3	22.6
22:24:00	13.4	134.4	5.2	261.3	5.4	53.7	19.1	763.0	17.3	173.3	22.5
22:25:00	13.0	130.3	5.0	252.4	5.9	58.8	19.2	767.0	17.4	174.0	22.5
22:26:00	13.1	131.0	5.3	264.8	5.2	52.3	19.1	763.0	17.1	170.9	22.5
22:27:00	13.0	130.3	5.4	270.3	5.6	56.0	19.1	764.0	17.5	175.0	22.4
22:28:00	12.7	127.2	5.4	268.6	5.8	57.8	19.1	763.0	17.1	171.3	22.4
22:29:00	13.0	130.3	4.9	245.5	5.1	51.2	19.1	765.0	17.6	176.4	22.4
22:30:00	12.9	129.0	5.1	255.2	5.7	56.7	19.1	766.0	17.9	179.2	22.4
22:31:00	12.9	129.0	5.2	260.7	5.1	50.9	19.1	764.0	18.3	182.9	22.4
22:32:00	12.9	129.0	5.1	253.8	5.1	51.2	19.2	767.0	16.9	168.8	22.4
22:33:00	12.3	122.8	5.0	250.3	5.6	56.0	19.3	770.0	16.8	168.2	22.3
22:34:00	12.6	126.2	4.9	244.5	5.0	49.5	19.2	768.0	17.6	176.1	22.3
22:35:00	12.1	120.7	5.4	269.6	5.6	56.4	19.1	766.0	17.6	176.1	22.3
22:36:00	12.2	122.1	4.9	244.8	5.2	52.3	19.2	767.0	18.3	183.3	22.3
22:37:00	12.1	120.7	4.9	246.9	5.0	49.5	19.2	768.0	19.2	192.2	22.3
22:38:00	11.7	117.3	5.1	255.8	5.5	54.7	19.1	766.0	19.6	195.7	22.3
22:39:00	11.5	115.2	5.1	255.2	4.8	48.5	19.1	764.0	19.8	198.4	22.3
22:40:00	11.2	112.1	5.1	253.8	5.4	53.7	19.2	767.0	19.1	191.2	22.3
22:41:00	10.9	109.4	5.2	261.3	4.6	46.4	19.2	767.0	19.1	190.5	22.3
22:42:00	10.7	107.3	5.2	261.3	5.2	51.6	19.2	768.0	19.6	196.4	22.3
22:43:00	10.9	108.7	5.1	255.2	5.2	51.6	19.1	766.0	20.7	207.4	22.3
22:44:00	10.4	103.5	4.6	228.0	4.4	43.7	19.3	772.0	20.6	206.3	22.4
22:45:00	11.1	110.7	5.0	248.3	5.2	52.3	19.1	766.0	21.3	213.2	22.4

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
22:46:00	10.9	109.4	5.5	273.0	4.4	44.4	19.1	765.0	20.7	207.0	22.4
22:47:00	10.6	105.6	5.1	252.8	4.9	48.8	19.2	769.0	20.7	207.4	22.4
22:48:00	10.5	105.2	4.8	238.7	4.5	44.7	19.2	769.0	21.0	210.1	22.3
22:49:00	10.4	104.2	5.3	265.5	4.3	43.3	19.1	764.0	20.4	204.3	22.3
22:50:00	10.4	103.9	5.3	265.5	4.6	46.4	19.2	767.0	21.2	212.2	22.3
22:51:00	10.2	101.5	5.0	250.3	4.0	39.5	19.2	768.0	20.4	203.9	22.3
22:52:00	10.1	100.8	5.1	253.8	4.6	46.1	19.1	766.0	20.8	208.0	22.2
22:53:00	10.2	101.5	5.3	264.8	4.2	42.3	19.1	765.0	21.6	215.6	22.2
22:54:00	10.1	100.8	5.5	274.8	4.0	39.9	19.1	766.0	21.8	217.7	22.1
22:55:00	10.3	103.2	5.5	275.1	4.5	45.0	19.1	764.0	21.9	218.7	22.1
22:56:00	10.5	105.2	4.9	244.2	3.9	38.5	19.2	768.0	22.5	224.9	22.1
22:57:00	10.4	103.5	5.0	249.3	4.4	44.4	19.2	768.0	22.4	223.9	22.1
22:58:00	10.3	102.8	5.0	250.3	3.9	38.9	19.3	772.0	22.3	222.9	22.1
22:59:00	10.7	107.0	5.1	255.2	4.0	39.5	19.2	769.0	23.3	232.5	22.1
23:00:00	10.6	106.3	4.7	235.9	4.2	42.0	19.3	772.0	22.7	227.0	22.1
23:01:00	10.6	106.3	4.8	240.0	3.6	35.8	19.3	772.0	23.2	232.1	22.1
<i>stop</i> 23:02:00	10.7	107.3	4.8	238.0	4.1	40.9	19.3	772.0	22.8	228.4	22.1
23:03:00	10.4	104.5	4.8	239.4	3.5	35.4	19.3	773.0	22.6	226.3	22.1
23:04:00	9.4	93.5	0.2	8.9	3.0	30.3	20.3	811.0	21.9	218.7	22.1
23:05:00	3.2	32.3	0.0	1.4	2.3	22.7	0.3	12.7	0.6	5.5	22.1
23:06:00	1.8	17.5	0.0	0.0	1.7 <i>low</i>	16.5	0.1	3.4	0.9	8.9	22.1
23:07:00	1.7 <i>low</i>	16.9	-0.0 <i>low</i>	-0.7	1.8	17.5	0.1 <i>low</i>	3.8	0.9 <i>low</i>	8.6	22.1
23:08:00	1.5	15.5	-0.0	-0.7	45.9	458.7	0.1	4.1	1.0	10.0	22.1
23:09:00	1.4	13.8	-0.0	-1.4	46.5 <i>low</i>	464.6	0.1	3.8	1.2	12.4	22.0
23:10:00	1.6	15.8	-0.0	-1.4	1.8	17.9	0.1	2.1	1.5	15.1	22.0
23:11:00	9.8	98.0	-0.0	-1.4	1.3	13.1	0.1	4.1	1.4	14.1	22.0
23:12:00	23.6	235.6	-0.0	-1.4	1.5	15.5	0.1	2.1	1.3	13.4	22.0
23:13:00	31.1	310.9	-0.0	-2.1	1.2	11.7	0.1	2.4	1.7	16.5	22.0
23:14:00	35.4	353.9	-0.0	-2.1	1.3	13.4	0.1	3.1	1.2	11.7	22.0
23:15:00	38.2	381.7	-0.0	-2.4	1.1	10.7	0.1	3.4	1.6	16.2	22.0
23:16:00	40.0	400.3	-0.1	-2.8	1.1	11.4	0.1	3.4	1.5	15.1	22.0
23:17:00	41.2 <i>low</i>	412.3	-0.1	-2.8	1.2	12.4	0.0	1.4	1.4	14.4	22.0
23:18:00	42.1	421.3	0.2	11.0	0.9	8.9	0.2	7.6	1.7	17.2	22.0
23:19:00	12.1	121.4	-0.1	-2.8	1.1	11.0	0.1	3.1	30.2 <i>low</i>	301.6	21.9
23:20:00	7.6	76.0	16.8	840.0	0.8	8.3	14.9	597.4	30.4	304.0	21.9
23:21:00	5.3	53.3	17.6	878.0	1.0	9.6	18.3	733.0	2.6	26.5	21.9
23:22:00	4.5	45.4	17.6 <i>low</i>	880.0	1.0	10.3	18.2 <i>low</i>	728.0	0.5	4.8	21.9

Run 5

DATE: July 22, 1998 CLIENT REP: R.KRUSE

PLANT: IBP / DC WITNESSED?: N/A

FUEL TYPE: Steam BURNER TYPE: N/A

OPERATOR: SM/DW GENERATOR TYPE: N/A

TEST LOCATION: SUPER COOKER O2 GENERATOR TYPE: N/A

CALIBRATION GASES

O2	CO2	CO	SO2	THC	NOx
0	0	0	0	0	0
10.2	9.9	30.3	45.1	N/A	46
18	17.7	86.9	88.7	N/A	84.3

END TIME	SAMPLE POINT	O2 %	CO2 %	CO ppm	SO2 ppm	THC ppm	NOx ppm
2350	1	19.51	4.35	17.16	9.10		3.20
15	2	19.34	5.09	18.41	8.55		3.10
35	3	19.35	5.21	19.56	7.90		2.70
	AVERAGES	19.40	4.88	18.38	8.52	#DIV/0!	3.00

Barometric Pressure: 29.05

EFFLUENT GAS CONCENTRATION, % or PPM

	O2	CO2	CO	SO2	THC	NOx
PRE ZERO	0.1	0	0.9	1.7		1.7
POST ZERO	0.1	0	0.9	2		1
ACT SPAN	18	17.7	30.3	45.1	N/A	46
PRE SPAN	18.2	17.6	30.2	41.2		46.5
POST SPAN	18.2	17.7	30	40.9		45.9

GAS CONC.(19.19 4.90 18.14 7.67 #DIV/0! 1.69

GAS CONC.(18.66 4.76 17.63 7.46 #DIV/0! 1.65

F-factor (Fc)-----

N/A

scf/10e6 btu

lb/hr SO2 0.035

lb/hr NOx

0.005

lb/hr CO 0.036

Stack Flowrate- 2.8021E+04 (wet,scf/hr)

EFFLUENT GAS CONC CALCULATION

$$\text{GAS CONC.} = (\text{Avg Stk Conc} - \text{Avg Zero Cal}) * (\text{Span Conc} / (\text{Avg Span Cal} - \text{Avg Zero Cal}))$$

PLANT: IBP DAKOTA CITY
UNIT: COOKER
TODAYS DATE: 07-22-1998
START/END TIMES: 23:30/23:50
MOISTURE = 5%

RUN NUMBER: 5 PAGE 1
OPERATOR: MILLER
MEASUREMENT DATE:
23:50/23:59 /
RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
23:33:00	2.9	2.8	8.7	8.3	3.85	3.65	19.74	18.75	14.83	14.09
23:34:00	3.1	2.9	9.1	8.6	3.92	3.72	19.70	18.72	15.80	15.01
23:35:00	3.0	2.8	9.0	8.5	3.75	3.57	19.73	18.74	15.59	14.81
23:36:00	3.1	3.0	9.1	8.6	3.82	3.63	19.72	18.73	15.84	15.05
23:37:00	3.1	2.9	9.1	8.6	3.94	3.74	19.67	18.69	15.75	14.96
23:38:00	3.3	3.1	9.2	8.8	3.99	3.79	19.58	18.60	16.27	15.45
23:39:00	3.3	3.1	9.3	8.8	4.12	3.91	19.54	18.56	16.64	15.81
23:40:00	3.2	3.1	9.4	8.9	4.17	3.96	19.55	18.57	17.16	16.31
23:41:00	3.3	3.2	9.4	8.9	4.22	4.01	19.51	18.54	17.64	16.76
23:42:00	3.2	3.0	9.1	8.6	4.37	4.15	19.49	18.51	17.74	16.85
23:43:00	3.3	3.1	9.1	8.7	4.47	4.25	19.45	18.48	18.07	17.17
23:44:00	3.2	3.1	9.3	8.8	4.62	4.39	19.42	18.45	18.41	17.48
23:45:00	3.3	3.1	9.2	8.7	4.58	4.35	19.40	18.43	17.80	16.91
23:46:00	3.4	3.2	9.1	8.6	4.96	4.71	19.35	18.38	17.83	16.94
23:47:00	3.2	3.0	9.3	8.8	4.79	4.55	19.36	18.39	18.48	17.56
23:48:00	3.2	3.1	9.1	8.6	4.77	4.54	19.35	18.38	18.16	17.26
23:49:00	3.2	3.0	9.1	8.6	5.01	4.76	19.31	18.35	18.56	17.63
23:50:00	3.2	3.0	8.9	8.5	5.04	4.79	19.31	18.34	18.78	17.84
MEAN	3.2	3.0	9.1	8.7	4.35	4.13	19.51	18.54	17.16	16.31
23:53:00	3.1	3.0	8.8	8.3	5.23	4.96	19.28	18.31	19.00	18.05
23:54:00	3.1	2.9	8.6	8.2	5.60	5.32	19.23	18.26	19.42	18.45
23:55:00	3.0	2.9	8.7	8.2	5.38	5.12	19.28	18.32	19.86	18.87
23:56:00	3.1	2.9	8.6	8.2	5.50	5.23	19.25	18.29	19.78	18.79
23:57:00	2.9	2.8	8.3	7.9	5.35	5.08	19.28	18.32	19.58	18.60
23:58:00	3.0	2.8	8.1	7.7	5.55	5.28	19.27	18.31	19.09	18.14
23:59:00	3.0	2.8	8.3	7.9	5.58	5.30	19.24	18.28	20.14	19.13
MEAN	3.0	2.9	8.5	8.1	5.45	5.18	19.26	18.30	19.54	18.56

PLANT: IBP DAKOTA CITY
UNIT: COOKER
TODAYS DATE: 07-22-1998
START/END TIMES: 00:03/00:15
MOISTURE = 5%

RUN NUMBER: 5 PAGE 1
OPERATOR: MILLER
MEASUREMENT DATE:
00:15/00:35 /
RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
00:06:00	3.0	2.9	8.8	8.3	4.82	4.58	19.43	18.46	17.07	16.22
00:07:00	3.0	2.8	8.8	8.3	4.71	4.48	19.45	18.48	17.09	16.24
00:08:00	2.9	2.8	8.5	8.0	4.52	4.29	19.48	18.51	16.67	15.83
00:09:00	2.9	2.8	8.7	8.3	4.64	4.41	19.45	18.48	16.82	15.98
00:10:00	3.0	2.8	8.5	8.1	4.67	4.43	19.42	18.45	16.41	15.59
00:11:00	3.1	2.9	8.7	8.2	4.63	4.40	19.41	18.44	17.18	16.32
00:12:00	3.0	2.8	8.6	8.1	4.72	4.48	19.40	18.43	17.45	16.58
00:13:00	3.0	2.9	8.4	8.0	4.89	4.64	19.38	18.41	17.39	16.52
00:14:00	2.8	2.7	8.5	8.1	4.67	4.44	19.44	18.47	18.48	17.56
00:15:00	2.8	2.7	8.3	7.9	5.03	4.78	19.36	18.39	18.35	17.43
MEAN	3.0	2.8	8.6	8.1	4.73	4.49	19.42	18.45	17.29	16.42
avg	3.10		8.55		5.09		19.34		18.41	
00:18:00	2.8	2.7	8.5	8.1	5.08	4.82	19.34	18.37	19.34	18.37
00:19:00	2.7	2.6	8.2	7.8	5.23	4.97	19.34	18.37	18.85	17.91
00:20:00	2.7	2.6	8.2	7.8	4.96	4.71	19.39	18.42	19.79	18.80
00:21:00	2.8	2.7	7.9	7.5	5.28	5.01	19.29	18.33	19.16	18.20
00:22:00	2.7	2.6	7.9	7.5	5.45	5.17	19.25	18.29	19.31	18.35
00:23:00	2.6	2.5	8.0	7.6	4.99	4.74	19.39	18.42	20.17	19.16
00:24:00	2.6	2.5	7.8	7.4	5.31	5.04	19.31	18.34	18.72	17.78
00:25:00	2.6	2.4	7.7	7.3	5.35	5.08	19.34	18.37	18.86	17.91
00:26:00	2.5	2.4	7.8	7.4	5.27	5.00	19.35	18.38	19.61	18.63
00:27:00	2.6	2.5	7.8	7.4	5.52	5.25	19.26	18.30	19.56	18.58
00:28:00	2.6	2.5	7.6	7.2	5.36	5.09	19.34	18.37	20.09	19.08
00:29:00	2.6	2.4	7.6	7.3	5.44	5.17	19.32	18.35	20.25	19.24
00:30:00	2.7	2.5	7.8	7.4	5.23	4.97	19.35	18.38	20.61	19.58
00:31:00	2.7	2.5	7.7	7.3	4.93	4.68	19.39	18.42	19.28	18.32
00:32:00	2.6	2.4	7.6	7.2	5.16	4.90	19.39	18.42	18.93	17.99
00:33:00	2.7	2.6	7.8	7.4	5.31	5.05	19.34	18.37	20.12	19.11
00:34:00	2.6	2.5	8.0	7.6	5.07	4.82	19.41	18.44	20.30	19.28
00:35:00	2.7	2.5	7.8	7.4	4.94	4.69	19.42	18.45	19.17	18.21
MEAN	2.7	2.5	7.9	7.5	5.21	4.95	19.35	18.38	19.56	18.58

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SD2 (PPM)	SD2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
<i>Start</i> 23:30:00	8.5	84.9	3.7	184.3	2.6	26.1	19.8	793.0	15.0	150.3	21.8
23:31:00	8.7	87.0	3.8	189.8	3.1	31.3	19.7	789.0	14.9	148.9	21.8
23:32:00	8.7	86.7	3.9	196.7	3.0	29.9	19.7	788.0	14.4	144.5	21.8
23:33:00	9.0	90.1	3.9	195.7	2.8	27.5	19.7	789.0	14.8	147.9	21.9
23:34:00	9.2	92.2	3.9	196.0	3.3	32.7	19.7	789.0	16.0	160.3	21.9
23:35:00	9.1	91.1	3.7	186.1	2.9	28.5	19.7	789.0	15.7	156.5	21.9
23:36:00	9.0	90.4	3.9	194.7	3.3	33.0	19.7	789.0	15.8	157.5	22.0
23:37:00	9.1	91.1	3.9	197.4	3.2	32.0	19.7	787.0	16.0	160.3	22.0
23:38:00	9.2	91.8	4.2	208.8	3.1	31.3	19.6	782.0	16.7	166.8	22.0
23:39:00	9.4	94.2	4.2	209.1	3.5	34.7	19.6	782.0	16.9	168.5	22.1
23:40:00	9.3	93.2	4.6	230.4	3.1	31.0	19.5	778.0	16.6	166.5	22.1
23:41:00	9.3	93.2	4.2	211.2	3.4	34.4	19.5	781.0	17.3	173.0	22.1
23:42:00	9.0	90.4	4.5	225.6	3.3	32.7	19.5	778.0	17.9	179.2	22.1
23:43:00	9.2	91.5	4.7	233.2	3.1	31.0	19.5	778.0	18.4	183.7	22.1
23:44:00	9.2	91.5	4.9	244.2	3.5	34.7	19.4	775.0	18.1	180.9	22.1
23:45:00	9.1	91.1	4.5	225.6	3.0	30.3	19.4	776.0	17.8	177.8	22.0
23:46:00	9.2	91.8	5.0	249.0	3.4	34.0	19.4	775.0	18.3	183.0	22.0
23:47:00	9.2	91.5	4.4	219.4	3.2	32.0	19.4	774.0	18.9	188.5	22.0
23:48:00	9.2	91.8	4.8	239.4	3.0	30.3	19.4	776.0	18.5	185.4	22.0
23:49:00	9.1	91.1	4.9	245.9	3.2	32.3	19.4	774.0	18.5	184.7	21.9
23:50:00	8.8	88.4	5.5	273.1	3.1	30.6	19.2	769.0	18.4	184.0	21.9
23:51:00	9.2	91.5	5.2	260.0	3.4	34.0	19.3	771.0	19.4	193.6	21.9
23:52:00	9.0	90.1	5.2	258.0	3.1	30.6	19.3	771.0	19.3	192.6	21.9
23:53:00	8.6	85.6	5.1	255.2	2.9	28.9	19.3	773.0	19.1	190.9	21.8
23:54:00	8.7	87.0	5.9	297.5	3.4	33.7	19.1	765.0	19.3	193.3	21.8
23:55:00	8.5	85.3	5.5	273.1	2.9	28.5	19.3	771.0	19.6	196.0	21.8
23:56:00	8.5	84.9	5.1	257.3	3.1	31.3	19.4	774.0	20.4	204.0	21.8
23:57:00	8.2	82.2	5.1	255.9	2.9	29.2	19.3	771.0	19.6	196.0	21.8
23:58:00	8.3	82.9	5.8	289.6	2.9	28.5	19.3	770.0	19.3	193.3	21.8
23:59:00	8.3	82.5	5.7	285.5	3.3	32.7	19.2	768.0	19.5	195.4	21.8
00:00:00	8.3	82.9	5.8	287.5	2.8	27.5	19.2	769.0	18.7	187.1	21.8

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
00:03:00	8.5	84.9	4.9	244.9	2.8	28.2	19.4	777.0	18.0	179.5	21.8
00:04:00	8.7	87.4	4.7	235.9	3.1	30.6	19.5	778.0	18.1	180.6	21.8
00:05:00	8.8	88.4	5.2	258.0	2.8	27.5	19.4	775.0	16.8	168.2	21.9
00:06:00	8.7	87.0	4.7	235.9	3.2	32.3	19.4	777.0	17.0	169.9	21.9
00:07:00	8.6	85.6	4.4	220.1	2.8	28.2	19.5	780.0	17.1	171.3	21.9
00:08:00	8.4	83.9	5.1	256.6	2.9	28.9	19.4	774.0	16.2	162.3	21.9
00:09:00	8.4	83.9	4.7	232.5	3.1	31.0	19.5	780.0	17.1	170.6	22.0
00:10:00	8.6	86.3	4.6	231.8	2.8	27.9	19.4	776.0	17.1	170.6	22.0
00:11:00	8.6	85.6	4.9	245.6	3.3	32.7	19.4	775.0	17.3	173.3	22.1
00:12:00	8.4	83.6	5.2	258.6	3.1	30.6	19.4	774.0	17.8	177.5	22.1
00:13:00	8.5	85.3	5.6	279.3	3.0	29.9	19.3	771.0	17.4	174.4	22.1
00:14:00	8.5	84.9	4.6	230.8	3.0	29.6	19.5	778.0	17.9	179.2	22.1
00:15:00	8.5	84.9	5.0	251.4	2.6	26.1	19.4	774.0	19.0	190.2	22.1
00:16:00	8.4	83.6	5.1	256.6	3.1	30.6	19.3	772.0	18.4	184.4	22.1
00:17:00	8.7	87.0	5.1	255.9	2.8	27.9	19.3	770.0	18.8	188.1	22.1
00:18:00	8.4	83.6	5.4	267.6	2.7	27.2	19.3	773.0	18.4	184.0	22.1
00:19:00	8.4	83.6	5.5	274.5	3.0	29.6	19.3	770.0	18.6	186.1	22.1
00:20:00	7.8	78.1	5.2	262.1	2.5	25.1	19.4	775.0	19.0	190.2	22.1
00:21:00	7.9	78.8	4.9	246.3	2.9	28.5	19.3	773.0	20.0	199.8	22.1
00:22:00	8.2	82.2	5.3	264.8	2.5	25.1	19.3	771.0	19.8	197.8	22.1
00:23:00	7.7	77.4	5.0	249.7	2.6	26.1	19.4	774.0	18.7	187.1	22.1
00:24:00	7.8	78.1	5.0	250.4	2.7	26.8	19.4	774.0	19.4	194.3	22.0
00:25:00	7.6	76.0	5.8	292.3	2.4	24.1	19.3	771.0	19.2	192.2	22.0
00:26:00	7.5	74.6	5.1	257.2	2.7	27.2	19.3	773.0	19.5	194.7	22.0
00:27:00	7.8	78.1	5.7	283.4	2.5	25.1	19.3	770.0	20.4	204.0	22.0
00:28:00	7.6	76.0	5.7	286.8	2.8	27.5	19.3	770.0	19.3	193.3	21.9
00:29:00	7.7	77.4	6.0	297.8	2.8	28.2	19.2	769.0	20.1	201.2	21.9
00:30:00	7.7	76.7	5.5	273.1	2.6	26.1	19.3	771.0	19.5	194.7	21.8
00:31:00	7.4	74.3	5.0	249.7	2.8	27.5	19.4	775.0	18.7	186.8	21.7
00:32:00	7.5	75.3	5.2	262.1	2.4	23.7	19.4	776.0	19.7	196.7	21.7
00:33:00	7.9	78.8	4.8	241.4	2.8	27.9	19.4	777.0	20.8	208.4	21.6
00:34:00	7.9	79.1	4.8	239.0	2.6	25.8	19.5	779.0	20.2	201.9	21.6
00:35:00	7.7	77.4	4.5	227.0	2.5	25.5	19.4	777.0	19.2	192.3	21.6
00:36:00	4.7	47.1	0.2	12.0	2.2	22.4	20.5	820.0	15.2	151.7	21.5
00:37:00	2.7	27.2	0.0	1.4	1.1	11.0	0.3	11.0	33.4	334.0	21.5
00:38:00	2.2	21.7	0.0	1.4	1.2	11.7	0.1	5.5	1.4	14.1	21.5
00:39:00	2.0 <i>low</i>	20.3	0.0 <i>low</i>	0.7	1.0 <i>low</i>	10.0	0.1 <i>low</i>	3.1	0.9 <i>low</i>	8.9	21.5
00:40:00	2.0	19.6	0.0	0.0	45.9 <i>gm</i>	458.5	0.1	2.4	0.9	8.9	21.4
00:41:00	1.8	17.9	17.5	877.0	1.2	11.7	18.2	728.0	1.3	13.1	21.4
00:42:00	1.9	18.6	17.7 <i>gm</i>	883.0	0.8	7.6	18.2 <i>gm</i>	727.0	0.8	8.3	21.4
00:43:00	2.0	19.6	0.3	13.8	1.0	9.6	0.7	28.5	0.7	6.5	21.3
00:44:00	1.6	15.8	0.1	4.8	0.9	8.6	0.1	4.1	30.0 <i>gm</i>	300.3	21.3
00:45:00	1.7	17.2	0.1	2.8	0.7	6.9	0.1	4.1	23.9	239.1	21.2
00:46:00	2.2	22.0	0.0	2.1	0.9	8.6	0.1	3.4	1.6	15.8	21.2

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
00:47:00	4.5	45.1	0.0	1.4	0.7	6.9	0.0	1.7	1.3	13.4	21.2
00:48:00	9.2	92.2	0.0	1.4	0.9	8.9	0.1	2.1	1.4	13.8	21.1
00:49:00	14.4	144.1	0.0	0.7	0.6	5.8	0.1	3.4	1.8	17.5	21.1
00:50:00	19.5	195.0	0.0	0.0	0.6	6.2	0.1	2.4	1.6	15.8	21.1
00:51:00	24.0	240.4	-0.0	-0.3	0.7	6.5	0.1	3.4	1.7	16.5	21.1
00:52:00	14.6	145.5	-0.0	-0.7	0.6	5.8	0.1	4.5	1.2	12.0	21.1
00:53:00	27.1	271.4	-0.0	-1.7	0.8	7.6	0.1	3.1	1.4	14.1	21.0
00:54:00	32.9	328.5	-0.0	-2.1	0.5	5.2	0.1	3.1	1.5	15.1	21.0
00:55:00	35.6	355.7	-0.1	-2.8	0.8	7.9	0.0	1.7	1.4	14.1	21.0
00:56:00	38.0	380.1	-0.1	-3.4	0.8	7.9	0.0	1.7	1.4	13.8	21.0
00:57:00	39.7	396.9	-0.1	-4.1	0.7	7.2	0.0	1.7	1.3	13.4	21.0
00:58:00	40.9	409.0	-0.1	-4.8	0.9	8.9	0.0	1.4	1.4	13.8	21.0

Run 6

DATE: July 22, 1998 CLIENT REP: R.KRUSE
 PLANT: IBP / DC WITNESSED?: N/A
 FUEL TYPE: Steam BURNER TYPE: N/A
 OPERATOR: SM/DW GENERATOR TYPE: N/A
 TEST LOCATION: SUPER COOKER O2 GENERATOR TYPE: N/A

CALIBRATION GASES

O2	CO2	CO	SO2	THC	NOx
0	0	0	0	0	0
10.2	9.9	30.3	45.1	N/A	46
18	17.7	86.9	88.7	N/A	84.3

END TIME	SAMPLE POINT	O2 %	CO2 %	CO ppm	SO2 ppm	THC ppm	NOx ppm
122	1	19.83	3.40	12.13	10.60		2.60
142	2	19.64	3.72	15.27	12.80		2.90
202	3	20.26	0.62	9.94	14.30		2.00
	AVERAGES	19.91	2.58	12.45	12.57	#DIV/0!	2.50

Barometric Pressure: 29.05

EFFLUENT GAS CONCENTRATION, % or PPM

	O2	CO2	CO	SO2	THC	NOx
PRE ZERO	0.1	0	0.9	2		1
POST ZERO	0.1	-0.1	1.1	2.2		1
ACT SPAN	18	17.7	30.3	88.7	N/A	84.3
PRE SPAN	18.2	17.7	30	40.9		45.9
POST SPAN	18.1	17.6	30.3	40.1		45.8

GAS CONC. 19.76 2.63 11.90 24.18 #DIV/0! 2.82
 GAS CONC. 19.20 2.56 11.57 23.50 #DIV/0! 2.74

F-factor (Fc)-----

N/A

scf/10e6 btu

lb/hr SO2 0.110

lb/hr NOx

0.009

lb/hr CO 0.024

Stack Flowrate- 2.8181E+04 (wet,scf/hr)

EFFLUENT GAS CONC CALCULATION

$$\text{GAS CONC.} = (\text{Avg Stk Conc} - \text{Avg Zero Cal}) * (\text{Span Conc} / (\text{Avg Span Cal} - \text{Avg Zero Cal}))$$

UNIT: COOKER
TODAYS DATE: 07-24-1998
START/END TIMES: 01:02/01:22
MOISTURE = 5%

OPERATOR: MILLER
MEASUREMENT DATE:
01:22/01:42 01:42/02:02
RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
01:05:00	2.2	2.1	9.2	8.8	3.40	3.23	19.97	18.97	12.07	11.47
01:06:00	2.4	2.2	10.0	9.5	3.45	3.28	19.92	18.92	12.44	11.81
01:07:00	2.4	2.3	9.8	9.3	3.47	3.30	19.91	18.92	11.93	11.34
01:08:00	2.5	2.4	10.2	9.7	3.33	3.17	19.90	18.90	12.53	11.90
01:09:00	2.5	2.4	10.1	9.6	3.47	3.30	19.86	18.87	11.99	11.39
01:10:00	2.6	2.4	10.4	9.9	3.19	3.03	19.90	18.91	12.17	11.56
01:11:00	2.5	2.3	10.4	9.9	3.41	3.24	19.87	18.88	11.79	11.20
01:12:00	2.7	2.5	10.3	9.8	3.35	3.18	19.85	18.85	11.50	10.93
01:13:00	2.6	2.5	10.8	10.3	3.20	3.04	19.85	18.86	11.97	11.37
01:14:00	2.7	2.6	10.9	10.4	3.43	3.26	19.82	18.83	11.51	10.94
01:15:00	2.7	2.5	10.7	10.2	3.15	3.00	19.88	18.88	11.53	10.96
01:16:00	2.7	2.6	11.0	10.4	3.37	3.20	19.79	18.80	11.67	11.08
01:17:00	2.7	2.6	10.9	10.3	3.34	3.17	19.81	18.82	11.95	11.35
01:18:00	2.8	2.6	10.9	10.3	3.58	3.40	19.73	18.74	11.73	11.15
01:19:00	2.8	2.6	11.2	10.7	3.47	3.30	19.75	18.76	12.66	12.03
01:20:00	2.8	2.7	11.4	10.8	3.56	3.38	19.71	18.72	12.76	12.12
01:21:00	2.8	2.7	11.6	11.1	3.68	3.49	19.67	18.68	12.68	12.05
01:22:00	2.8	2.7	11.8	11.2	3.43	3.26	19.73	18.75	13.39	12.72
MEAN	2.6	2.5	10.6	10.1	3.40	3.23	19.83	18.84	12.13	11.52
01:25:00	2.8	2.7	11.8	11.2	3.71	3.53	19.66	18.67	13.02	12.37
01:26:00	2.8	2.6	11.6	11.0	3.61	3.43	19.67	18.69	13.28	12.62
01:27:00	2.9	2.7	11.4	10.9	3.80	3.61	19.66	18.68	13.84	13.15
01:28:00	2.8	2.7	11.7	11.1	3.83	3.64	19.65	18.67	13.88	13.18
01:29:00	2.9	2.8	11.6	11.0	3.80	3.61	19.66	18.68	13.84	13.15
01:30:00	2.8	2.7	11.7	11.1	3.93	3.73	19.66	18.68	14.23	13.52
01:31:00	2.8	2.7	12.0	11.4	3.69	3.50	19.65	18.67	14.83	14.09
01:32:00	3.0	2.8	11.8	11.2	4.07	3.87	19.58	18.60	14.56	13.84
01:33:00	2.9	2.8	12.0	11.4	4.15	3.94	19.54	18.56	14.96	14.21
01:34:00	2.9	2.8	12.1	11.5	4.03	3.83	19.58	18.60	15.55	14.77
01:35:00	2.8	2.7	12.0	11.4	4.03	3.83	19.58	18.60	15.55	14.77
01:36:00	3.0	2.9	12.5	11.9	4.39	4.17	19.46	18.49	15.89	15.10
01:37:00	2.9	2.8	12.7	12.0	4.32	4.11	19.49	18.52	16.47	15.65
01:38:00	2.7	2.6	12.4	11.8	4.14	3.93	19.54	18.56	16.41	15.59
01:39:00	2.8	2.6	12.4	11.8	4.30	4.09	19.50	18.52	16.47	15.64
01:40:00	3.1	3.0	17.5	16.6	3.79	3.60	19.58	18.60	18.95	18.00

PLANT: IBP DAKOTA CITY
UNIT: COOKER
TODAYS DATE: 07-24-1998
START/END TIMES: 01:02/01:22
MOISTURE = 5%

RUN NUMBER: 6 PAGE 2
OPERATOR: MILLER
MEASUREMENT DATE:
01:22/01:42 01:42/02:02
RESPONSE TIME = 2 MIN

TIME MIN ENDING	NOx CONC DRY ppm	NOx CONC WET ppm	SO2 CONC DRY ppm	SO2 CONC WET ppm	CO2 CONC DRY %	CO2 CONC WET %	O2 CONC DRY %	O2 CONC WET %	CO CONC DRY ppm	CO CONC WET ppm
01:41:00	2.7	2.6	17.4	16.5	1.86	1.77	20.00	19.00	18.42	17.50
01:42:00	2.7	2.5	16.0	15.2	1.49	1.42	20.13	19.12	15.14	14.38
MEAN	2.9	2.7	12.8	12.2	3.72	3.53	19.64	18.66	15.27	14.51
01:45:00	2.5	2.3	14.8	14.0	1.03	0.97	20.24	19.22	10.55	10.03
01:46:00	2.3	2.2	14.8	14.0	0.97	0.92	20.24	19.23	10.21	9.70
01:47:00	2.4	2.3	15.8	15.0	0.99	0.94	20.22	19.21	10.80	10.26
01:48:00	2.2	2.1	16.0	15.2	0.95	0.91	20.25	19.24	11.68	11.09
01:49:00	2.2	2.1	15.4	14.6	0.79	0.75	20.27	19.26	10.63	10.10
01:50:00	2.2	2.1	14.4	13.6	0.67	0.64	20.24	19.23	10.24	9.72
01:51:00	1.9	1.8	13.6	13.0	0.62	0.59	20.29	19.28	10.48	9.96
01:52:00	2.0	1.9	14.1	13.4	0.61	0.58	20.28	19.27	11.20	10.64
01:53:00	2.0	1.9	14.5	13.7	0.60	0.57	20.25	19.23	10.38	9.86
01:54:00	2.0	1.9	14.5	13.8	0.57	0.54	20.26	19.25	9.48	9.00
01:55:00	2.0	1.9	14.3	13.6	0.54	0.51	20.26	19.25	8.96	8.51
01:56:00	2.0	1.9	14.5	13.7	0.50	0.48	20.26	19.25	8.78	8.34
01:57:00	2.0	1.9	14.3	13.6	0.47	0.44	20.27	19.25	8.61	8.18
01:58:00	1.9	1.8	14.1	13.4	0.43	0.41	20.26	19.25	8.63	8.20
01:59:00	1.8	1.8	13.9	13.2	0.39	0.37	20.27	19.26	8.74	8.30
02:00:00	1.9	1.8	13.1	12.5	0.34	0.32	20.25	19.24	9.05	8.59
02:01:00	1.6	1.5	12.6	12.0	0.31	0.29	20.29	19.28	9.68	9.20
02:02:00	1.7	1.6	12.4	11.7	0.30	0.29	20.28	19.27	10.65	10.12
MEAN	2.0	1.9	14.3	13.6	0.62	0.59	20.26	19.25	9.94	9.44

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
Ant 01:02:00	10.6	105.6	2.6	128.6	1.6	16.2	20.2	809.0	12.0	119.7	20.9
01:03:00	8.2	82.2	3.2	157.9	2.0	20.0	20.1	805.0	10.2	101.5	20.9
01:04:00	8.9	89.1	3.4	171.3	2.1	21.0	20.0	798.0	11.8	118.3	20.9
01:05:00	9.4	94.2	3.1	154.1	2.2	22.4	20.0	800.0	12.4	123.5	20.8
01:06:00	9.9	98.7	3.1	155.5	2.3	23.4	20.0	799.0	12.9	129.3	20.8
01:07:00	10.4	103.9	3.6	178.2	2.4	23.7	19.9	795.0	11.9	119.4	20.8
01:08:00	9.8	98.0	3.3	163.7	2.6	25.8	20.0	798.0	12.6	125.9	20.8
01:09:00	10.8	108.0	3.3	163.1	2.4	24.1	19.9	794.0	12.3	122.5	20.7
01:10:00	10.2	101.8	3.1	155.5	2.6	26.5	20.0	798.0	11.6	116.3	20.7
01:11:00	10.6	106.3	3.0	150.7	2.3	22.7	19.9	796.0	12.2	121.8	20.7
01:12:00	10.9	108.7	3.6	180.9	2.7	26.8	19.8	792.0	11.6	116.3	20.7
01:13:00	10.9	109.0	3.4	169.9	2.8	27.9	19.9	794.0	11.7	116.6	20.6
01:14:00	11.2	112.2	3.3	166.5	2.6	26.1	19.8	791.0	11.3	112.8	20.6
01:15:00	10.3	102.9	3.4	170.6	2.9	28.9	19.8	792.0	10.6	106.3	20.6
01:16:00	10.9	108.7	3.1	153.4	2.4	24.1	19.9	796.0	12.7	127.3	20.6
01:17:00	10.7	107.0	3.0	148.6	2.6	26.5	19.9	795.0	12.2	121.8	20.6
01:18:00	11.5	114.6	3.2	157.6	2.8	27.5	19.8	793.0	12.7	126.6	20.5
01:19:00	11.4	113.5	3.5	174.8	2.6	26.1	19.8	791.0	13.0	129.7	20.5
01:20:00	11.6	115.9	3.1	156.2	2.9	28.9	19.8	791.0	12.9	129.0	20.5
01:21:00	12.4	123.5	3.7	185.1	2.7	26.8	19.6	786.0	13.3	133.1	20.5
01:22:00	10.9	109.4	3.5	176.8	2.9	29.2	19.8	790.0	12.8	128.3	20.5
01:23:00	12.1	121.4	3.5	176.8	3.0	29.6	19.7	787.0	13.6	136.2	20.4
01:24:00	11.4	113.9	3.7	186.5	2.6	26.5	19.6	785.0	11.9	118.7	20.4
01:25:00	11.9	119.4	3.2	159.6	2.9	28.9	19.8	790.0	13.4	134.5	20.4
01:26:00	11.5	115.2	3.5	173.4	2.5	25.5	19.7	789.0	13.7	137.3	20.4
01:27:00	11.4	113.5	3.9	195.4	3.0	30.3	19.6	785.0	13.8	138.3	20.4
01:28:00	11.8	117.7	3.7	186.5	2.9	29.2	19.7	787.0	14.2	142.1	20.4
01:29:00	11.8	118.0	4.0	198.2	2.9	28.5	19.6	784.0	13.4	133.8	20.4
01:30:00	12.0	120.1	4.3	214.0	3.1	31.0	19.6	783.0	14.4	143.5	20.5
01:31:00	11.7	117.3	3.7	183.7	2.6	26.1	19.7	787.0	14.4	143.5	20.5
01:32:00	12.1	121.1	4.0	198.2	3.1	31.0	19.6	783.0	15.1	151.0	20.5
01:33:00	12.4	124.2	4.0	200.2	3.0	29.6	19.5	781.0	15.1	150.7	20.5
01:34:00	12.2	121.8	4.5	226.4	2.8	27.9	19.5	780.0	15.0	149.7	20.6
01:35:00	12.1	120.8	4.1	203.0	3.1	31.0	19.5	781.0	14.9	149.0	20.6
01:36:00	12.8	127.6	4.5	226.4	2.8	28.2	19.5	779.0	16.7	167.2	20.7
01:37:00	12.8	127.6	4.4	218.8	2.9	28.5	19.5	780.0	16.0	160.3	20.7
01:38:00	12.2	122.1	4.6	229.8	3.0	29.9	19.5	778.0	16.0	160.3	20.8
01:39:00	12.6	125.6	4.3	217.4	2.6	25.8	19.5	779.0	16.6	166.5	20.8
01:40:00	18.7	186.8	2.7	132.8	3.1	31.3	19.8	793.0	21.3	213.0	20.9
01:41:00	16.6	166.2	1.6	81.2	2.5	24.8	20.1	803.0	16.5	165.1	20.9
01:42:00	15.6	155.8	1.4	68.8	2.5	25.1	20.2	807.0	14.6	145.9	21.0
01:43:00	15.0	150.3	1.2	60.2	2.6	26.5	20.2	808.0	12.3	123.2	21.0
01:44:00	14.9	148.6	1.1	54.0	2.4	24.1	20.2	808.0	10.8	108.4	21.0
01:45:00	14.9	148.6	1.0	48.2	2.6	26.5	20.2	809.0	10.1	100.5	21.1

TESTING OF THE SUPER COOKER AT DAKOTA CITY, NE 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
01:46:00	15.0	150.0	1.1	54.0	2.3	23.4	20.2	807.0	10.1	100.5	21.1
01:47:00	15.9	158.6	1.0	48.2	2.2	22.4	20.3	810.0	11.0	110.4	21.2
01:48:00	15.9	158.6	0.9	45.1	2.3	23.4	20.3	811.0	11.6	116.3	21.2
01:49:00	14.9	149.0	0.7	36.5	2.0	20.0	20.3	810.0	10.4	104.2	21.3
01:50:00	14.0	140.0	0.6	31.0	2.2	21.7	20.3	810.0	10.1	101.1	21.3
01:51:00	13.6	135.9	0.6	31.3	1.8	17.9	20.3	812.0	10.8	108.0	21.4
01:52:00	14.4	143.5	0.6	30.3	2.0	19.6	20.3	811.0	11.1	110.8	21.4
01:53:00	14.5	144.8	0.6	29.6	2.2	22.0	20.3	810.0	9.7	97.4	21.4
01:54:00	14.4	144.1	0.6	28.2	1.9	18.6	20.2	809.0	9.4	93.6	21.5
01:55:00	14.4	144.1	0.5	26.1	2.2	22.4	20.2	809.0	8.9	89.4	21.5
01:56:00	14.4	144.1	0.5	24.4	2.0	19.6	20.3	810.0	8.6	85.7	21.6
01:57:00	14.2	142.1	0.5	22.7	1.8	17.9	20.3	811.0	8.4	83.9	21.6
01:58:00	14.0	140.0	0.4	20.6	2.0	19.6	20.3	811.0	8.9	89.1	21.6
01:59:00	13.6	135.5	0.4	18.2	1.6	16.2	20.3	811.0	9.1	90.5	21.6
02:00:00	13.0	129.7	0.3	16.5	1.9	18.9	20.3	810.0	8.9	89.1	21.5
02:01:00	12.5	124.9	0.3	15.1	1.5	15.5	20.3	812.0	10.1	101.1	21.5
Stop 02:02:00	12.5	124.9	0.3	15.1	1.7	16.5	20.3	810.0	11.1	110.8	21.5
02:03:00	12.6	126.2	0.0	2.1	1.5	15.1	20.4	814.0	11.2	111.8	21.6
02:04:00	3.0	29.6	-0.1	-4.1	1.0	10.0	20.4	816.0	1.6	15.8	21.6
02:05:00	2.4	24.4	-0.1	-6.9	1.3	12.7	0.2	8.3	52.5	524.9	21.6
02:06:00	2.3	23.0	-0.1	-6.9	0.8	7.6	0.1	5.8	1.4	13.8	21.6
02:07:00	2.2 <i>2nd</i>	22.4	-0.1 <i>2nd</i>	-6.9	1.0 <i>2nd</i>	10.3	0.1 <i>2nd</i>	2.8	1.1 <i>2nd</i>	10.7	21.7
02:08:00	2.0	20.3	-0.1	-6.9	45.8 <i>spur</i>	457.8	0.1	3.1	1.4	14.1	21.7
02:09:00	2.1	20.6	-0.1	-6.9	1.2	12.4	0.1	4.5	1.5	15.1	21.8
02:10:00	2.0	20.3	-0.1	-6.9	1.1	11.4	0.1	2.1	30.6	306.1	21.8
02:11:00	1.8	17.9	17.1	853.0	0.6	6.2	16.0	639.4	30.3 <i>spur</i>	302.7	21.9
02:12:00	1.7	16.5	17.6	878.0	0.9	8.9	18.1	723.0	2.2	22.0	21.9
02:13:00	1.6	16.2	17.6 <i>spur</i>	881.0	0.7	7.2	18.1 <i>spur</i>	722.0	0.5	4.8	21.9
02:14:00	2.1	20.6	0.1	6.9	0.7	6.9	0.4 <i>spur</i>	16.5	1.0	9.6	22.0
02:15:00	6.6	65.7	-0.0	-0.7	0.7	7.2	0.1	5.2	1.0	10.3	22.0
02:16:00	12.4	123.5	-0.1	-3.1	0.6	5.8	0.1	2.4	1.0	10.0	22.0
02:17:00	18.7	186.8	-0.1	-4.1	0.6	5.8	0.1	3.1	1.5	14.8	22.0
02:18:00	23.5	235.3	-0.1	-5.5	0.7	6.9	0.0	1.4	0.9	8.9	22.1
02:19:00	26.2	261.8	-0.1	-6.2	0.4	3.8	0.1	3.8	1.2	12.0	22.1
02:20:00	29.6	295.5	-0.1	-6.9	0.8	7.6	0.0	1.0	0.9	9.3	22.1
02:21:00	33.3	333.3	-0.2	-7.6	0.4	4.5	0.1	3.1	0.7	6.9	22.1
02:22:00	36.4	364.2	-0.2	-8.3	0.5	5.2	0.0	1.0	0.6	5.8	22.1
02:23:00	38.4	384.2	-0.2	-8.9	0.7	6.5	0.0	0.7	0.9	9.3	22.1
02:24:00	40.1 <i>spur</i>	401.3	-0.2	-9.3	0.4	4.5	0.1	2.4	1.0	10.0	22.1

APPENDIX B

SAMPLE CALCULATIONS

SAMPLE CALCULATIONS

(1) Acid Gas Emission Calculation - Pounds Per Hour

$$ER = \frac{(A) \times (B) \times (Q_s) \times (C) \times (D)}{(VMSTD) \times (E)}$$

where:

ER	=	HCl, HF, HI, or HBr emission rate, lbs/hr
A	=	quantity of Cl ⁻ , F ⁻ , I ⁻ , or Br ⁻ collected, μg
B	=	$1 \times 10^{-6} \text{ g}/\mu\text{g}$
Q _s	=	stack gas flowrate, dscfm
C	=	60 minutes/hour
D	=	1.0284 g HCl/g Cl 1.0125 g HBr/g Br 1.0531 g HF/g F 1.0163 g HNO ₃ /g NO ₃
VMSTD	=	sample volume of air at standard conditions, dscf
E	=	453.6 g/lb

(2) CEM Pollutant Gas Calculation - Pounds Per Hour

$$ER = \frac{(A) \times (Q_s) \times (MW) \times (B)}{(C) \times (D)}$$

where:

ER	=	CO, THC, NO _x , and SO ₂ emission rate, lbs/hr
A	=	concentration of CO, THC, NO _x , and SO ₂ , ppm(v)
Q _s	=	stack gas flowrate, dscfm
MW	=	molecular weight, lb/lb-mole
		28 - CO
		46 - NO _x (as NO ₂)
		64 - SO ₂
		44 - C ₃ H ₈
		16 - THC (as methane)
B	=	60 minutes/hour
C	=	385.3 dscf/lb-mole @ 68°F (20°C)
D	=	1×10^6

(3) **Metals Emission Calculation - Pounds Per Hour**

$$ER = \frac{(MC) \times (C) \times (Qs) \times (D)}{(E) \times (VMSTD)}$$

where:

ER	=	metals emission rate, lbs/hr
MC	=	metal concentration, μg
C	=	$1 \times 10^{-6} \text{ g}/\mu\text{g}$
Qs	=	stack gas flowrate, dscfm
D	=	60 minutes/hour
E	=	453.6 g/lb
VMSTD	=	sample volume of air at standard conditions, dscf

(4) **Particulate Concentration Corrections**

(a) Correction to 12% CO_2 :

$$\text{gr/dscf @ 12\% CO}_2 = \text{gr/dscf} \times \left(\frac{12}{\% \text{ CO}_2} \right)$$

(b) Correction to 7% O_2 :

$$\text{gr/dscf @ 7\% O}_2 = \text{gr/dscf} \times \left(\frac{20.9 - 7}{20.9 - \% \text{ O}_{2\text{dry}}} \right)$$

(5) **Ambient Sampling or Audit Gas Calculations**

Conversion of compound concentration from ng/L to ppb(v):

$$\text{ppb(v)} = \frac{(A) \times (B)}{(MW)}$$

where:

A	=	24.04 L/g-mole @ 68°F (20°C)
B	=	concentration, ng/L or $\mu\text{g}/\text{m}^3$
MW	=	molecular weight of compound, g/g-mole

Note:

$$\mu\text{g}/\text{m}^3 = \frac{\text{ppm(v)} \times \text{MW}}{0.02404} \quad \text{ppb} = \frac{24.04 \times \mu\text{g}/\text{m}^3}{\text{MW}}$$

$$\text{ppm} = \frac{0.02404 \times \mu\text{g}/\text{m}^3}{\text{MW}}$$

(6) DRE Calculations for POHCs - VOST

Compute for all POHCs.

$$\text{DRE, \%} = \frac{[(\sum \text{POHC in}) - (\text{POHC out})]}{(\sum \text{POHC in})} \times 100$$

where:

$$\sum \text{POHC in} = \text{Sum of all waste streams fed}$$

a) $\text{POHC in } j, \text{ g/min} = \frac{(\text{WFR}) \times (\text{A}) \times (\text{B})}{(\text{C})}$

where:

j	=	a given waste stream
WFR	=	waste feed rate, lb/min
A	=	453.6 g/lb
B	=	POHC concentration, weight %
C	=	100

b) $\text{POHC out, g/min} = \frac{(\text{D}) \times (\text{E}) \times (\text{Qs}) \times (\text{F})}{(\text{VMSTD})}$

where:

D	=	POHC quantity detected, ng
E	=	28.32 L/dscf @ 68°F (20°C)
Qs	=	stack gas flowrate, dscfm
F	=	1×10^{-9} g/ng
VMSTD	=	sample volume of air at standard conditions, dsL

c) $\text{VMSTD} = \frac{(\text{Vm}_{\text{act}}) \times (\text{PB}_{\text{act}}) \times (\text{T}_{\text{std}})}{(\text{P}_{\text{std}}) \times (\text{Tm}_{\text{act}})}$

where:

VMSTD	=	sample volume of air at standard conditions, dsL
Vm_{act}	=	actual sample volume, aL
PB_{act}	=	atmospheric pressure at sampling location, mm Hg (in. Hg)
T_{std}	=	standard temperature = 293 °K
P_{std}	=	standard pressure = 760 mm Hg (29.92 in. Hg)
Tm_{act}	=	actual meter temperature, °K (°C + 273)

(7) DRE Calculations for POHCs - MM5

Compute for all POHCs.

$$\text{DRE, \%} = \frac{[(\sum \text{POHC in}) - (\text{POHC out})]}{(\sum \text{POHC in})} \times 100$$

where:

$$\sum \text{POHC in} = \text{Sum of all waste streams fed}$$

a) $\text{POHC in } j, \text{ g/min} = \frac{(\text{WFR}) \times (\text{A}) \times (\text{B})}{(\text{C})}$

where:

j	=	a given waste stream
WFR	=	waste feed rate, lb/min
A	=	453.6 g/lb
B	=	POHC concentration, weight %
C	=	100

b) $\text{POHC out, g/min} = \frac{(\text{D}) \times (\text{E}) \times (\text{Qs})}{(\text{VMSTD})}$

where:

D	=	POHC quantity detected, μg
Qs	=	stack gas flowrate, dscfm
E	=	$1 \times 10^{-6} \text{ g}/\mu\text{g}$
VMSTD	=	sample volume of air at standard conditions, dscf

(8) Adjusted CO₂ Concentration Downstream of a Scrubber
(40 CFR 60 - 60.54 (c)(6)(iii))

$$(\% \text{ CO}_2)_{\text{adj}} = (\% \text{ CO}_2)_{\text{di}} \left[\frac{100 + (\% \text{ EA})_{\text{i}}}{100 + (\% \text{ EA})_{\text{o}}} \right]$$

where:

$(\% \text{ CO}_2)_{\text{adj}}$	=	adjusted outlet CO ₂ concentration, percent
$(\% \text{ CO}_2)_{\text{di}}$	=	CO ₂ measured before the scrubber, dry basis percent
$(\% \text{ EA})_{\text{i}}$	=	excess air before scrubber, percent
$(\% \text{ EA})_{\text{o}}$	=	excess air after scrubber, percent

(9) Sulfuric Acid Mist and Sulfur Dioxide by EPA Reference Method 8

(a) Sulfuric Acid Mist ($\text{H}_2\text{SO}_4/\text{SO}_3$)

$$C = \frac{(K_2) \times (N) \times (V_t - V_{tb}) \times V_{\text{sol}}}{\text{VMSTD} \times V_a}$$

(b) Sulfur Dioxide (SO_2)

$$C = \frac{(K_3) \times (N) \times (V_t - V_{tb}) \times V_{\text{sol}}}{\text{VMSTD} \times V_a}$$

where:

C	=	concentration, g/dscm or lb/dscf
K ₂	=	0.04904 g/meq or 1.081×10^{-4} lb/meq
K ₃	=	0.03203 g/meq or 7.061×10^{-5} lb/meq
N	=	normality of barium perchlorate titrant, meq/mL
V _t	=	volume of titrant used for sample, mL
V _{tb}	=	volume of titrant used for blank, mL
V _{sol}	=	total volume of sample solution, mL
V _a	=	Volume of sample aliquot titrated, mL
VMSTD	=	sample volume of air at standard conditions, dscm or dscf

CALCULATION FORMULAS

Linearity Percent Difference = $\frac{\text{Analyzer Response} - \text{Cylinder Value}}{\text{Span}} \times 100$

Bias System Bias = $\frac{\text{System Response} - \text{Analyzer Response}}{\text{Span}} \times 100$

Drift System Drift = $\frac{\text{System Response} - \text{Previous System Response}}{\text{Span}} \times 100$

Moisture Moisture = $\frac{100 \times \text{Volume water vapor (scf)}}{(\text{Volume Gas (dscf)} + \text{Volume water vapor})}$

Stack Area Area = $3.14 \times \text{Radius}^2$

AFPM Actual Feet per Minute = $5130 \times .84 \times \text{SDE Avg} \times (1 / (\text{stack pres. Hg} \times \text{wet MW}))^{.5}$

ACFM Actual Cubic Feet/Min = AFPM x Stack Area (square feet)

DSCFM Dry Std. Cubic Feet/Min = $\frac{(\text{ACFM} \times 528 \times \text{Dry Mole Fraction} \times \text{Stack pres. Hg})}{(29.92 \times (\text{Stack Temperature} + 460))}$

DSCF/HR Dry Std. Cubic Feet/Hr = SCFM x 60 min

Humidity Humidity (gal H₂O/gal. air Taken From Chart (Wet bulb / Dry bulb temps)

EFFLUENT GAS CONC CALCULATION

GAS CONC. = $(\text{Avg Stk Conc} - \text{Avg Zero Cal}) \times (\text{Span Conc} / (\text{Avg Span Cal} - \text{Avg Zero Cal}))$

LBS/HR CH₄ Pounds per Hour as Methane = PPMv (VOC's less Methane) x 16.01 x DSCFM x 1.554E-7

LBS/HR Carbon Pounds per Hour as Carbon = PPMv (VOC's less Methane) x 12.01 x DSCFM x 1.554E-7

APPENDIX C

PROCESS DATA

#3317


DAKOTA CITY SLAUGHTER FOR THE WEEK ENDING 07/25/98

A SHIFT	MON	TUE	WED	THU	FRI	SAT	TOTAL
GROSS HOURS	8.00	8.00	4.00	4.00	8.00	4.00	36.00
PAID BREAKS	1	1	1	1	1	1	6
NET HOURS	7.75	7.75	3.75	3.75	7.75	3.75	34.50
ACTUAL SUNSHINE	0	2	3	4	1	3	13.00
PAID SUNSHINE	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HEAD KILLED	2,439	2,464	1,193	1,193	2,464	1,178	10,931
TARGET KILL	2,442	2,442	1,182	1,182	2,442	1,181	10,871
LIVE WT.	3,079,929	3,083,178	1,533,730	1,504,261	3,130,142	1,481,627	13,812,867
DRESS WT.	1,972,218	1,951,411	970,651	959,937	1,977,645	943,373	8,775,235
SLUNKS	0	37	8	0	32	4	81
B SHIFT	MON	TUE	WED	THU	FRI	SAT	TOTAL
GROSS HOURS	8.00	8.00	8.00	8.00	8.00	0.00	40.00
PAID BREAKS	1	1	1	1	1	0	5
NET HOURS	7.75	7.75	7.75	7.75	7.75	0.00	38.75
ACTUAL SUNSHINE	0	7	7	0	7	0	21.00
PAID SUNSHINE	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HEAD KILLED	2,388	2,464	2,464	2,431	2,464	0	12,211
TARGET KILL	2,442	2,442	2,442	2,442	2,442	0	12,210
LIVE WT.	2,990,496	3,044,162	3,006,815	3,036,331	3,027,606	0	15,105,410
DRESS WT.	1,889,613	1,928,424	1,891,562	1,902,291	1,909,229	0	9,521,119
SLUNKS	0	31	23	21	17	0	92
TOTAL	MON	TUE	WED	THU	FRI	SAT	TOTAL
GROSS HOURS	16.00	16.00	12.00	12.00	16.00	4.00	76.00
PAID BREAKS	2	2	2	2	2	1	11
NET HOURS	15.50	15.50	11.50	11.50	15.50	3.75	73.25
ACTUAL SUNSHINE	0.00	9.00	10.00	4.00	8.00	3.00	34.00
PAID SUNSHINE	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HEAD KILLED	4,827	4,928	3,657	3,624	4,928	1,178	23,142
TARGET KILL	4,884	4,884	3,624	3,624	4,884	1,181	23,081
LIVE WT.	6,070,425	6,127,340	4,540,545	4,540,592	6,157,748	1,481,627	28,918,277
DRESS WT.	3,861,831	3,879,835	2,862,213	2,862,228	3,886,874	943,373	18,296,354
SLUNKS	0	68	31	21	49	4	173

WEEKLY DATA

PLAN KILL	24,204
ACTUAL CHAIN SPEED:	A SHIFT 319 B SHIFT 318
PD HRS MINUS PD SUNSHINE:	A SHIFT 36.00 B SHIFT 40.00

Distribution:
Kelly
Dan Schroeder



Jul 22
3:20:09 AM
1998

Jul 22
3:20:09 AM

Jul 22
3:20:09 PM

Jul 22
3:20:09 PM

Jul 22
3:20:09 PM

Supercookor #1 Center Temperature

60.0
minutes per division

SELECT VALUE


SELECT DATA

GRID LINES

7/22/98

3:20:09 PM

3:20:09 PM



Supercooker #1 Discharge Temperature

60.0
minutes per division

SELECT VALUE

SELECT DATE

SELECT POSITION

GRID LINES

7/23/98

3:23:58 AM


Jul 22
9:23:58 PM

Jul 22
3:23:58 PM

Jul 22
9:23:58 AM

Jul 22
3:23:58 AM

Jul 23
3:23:58 AM



Jul 22
3:35:57 AM
1998

Jul 22
9:55:57 AM
1998

Jul 22
3:35:57 AM
1998

Jul 22
3:35:57 AM
1998

Jul 23
3:35:57 AM
1998

Supercookor #1 Level

60.0
minutes per division

SELECT VALUE


SELECT DATE

Sever: Position

7/23/98

3:38:54 AM

GRID LINES



Jul 22 3:40:00 AM 9:40:00 PM Jul 22 3:40:00 PM 3:40:00 PM
9/998

Supercookor #1 Steam Valve


60.0
minutes per division

GRID LINES

SUBJECT VALUE

SUBJECT VALUE





Cooker #1 Steam Flow

60.0
minutes per division

SELECT VALUE

SELECT DATE

GRID LINES

◀

▶

Scatter Plotting

7/23/98

3:43:15 AM

Jul 22 9:40:00 AM
 Jul 22 3:40:00 PM
 Jul 23 9:40:00 AM
 Jul 23 3:40:00 PM
 Jul 23 7:40:00 AM
 1998

APPENDIX D

LABORATORY DATA

**Method 25
Analytical Results**

prepared for

TRC ENVIRONMENTAL CORPORATION

1307 Butterfield Road, Suite 420
Downers Grove, IL 60515

by


Triangle Environmental Services, Inc.

Reviewed by:




Donna Nolen-Weathington
Laboratory Analyst

Approved by:



Larry W. Taylor
Laboratory Supervisor

Approved by:



John Y. Morimoto, Ph.D.
QA Officer

Report
98155

August 6, 1998

Triangle Environmental Services, Inc.

METHOD 25 TABLE OF RESULTS

Client: TRC Environmental Corporation

ID#98155 Analyzed: 8/3-4/98

Project ID: 22214-12 (IBP Dakota City, Neb.)

	Sample Description	Concentrations (ppmC)						Mass Conc.
		CO	CH4	CO2	Noncon- densibles	Conden- sibles	TGNMO	(mgC/cu.m)
1	Run 1	< 2	23	2746	< 5	54	54	27
2	Run 2	< 2	22	1844	6	54	60	30
3	Run 3	2	14	1199	< 4	44	44	22
4	Blank	< 2	< 2	3871	< 5	27	27	14

< # = Concentration Below Practical Quantitation Limit

* Please refer to the "Comments on the Analyses" page of the report for additional information.

Triangle Environmental Services, Inc.

METHOD 25 PROCEDURES

CALIBRATION

Initial calibrations and operational checks of the recovery and analytical systems are conducted at a frequency of no greater than one year between sets. The calibrations satisfy the requirements for Methods 25, 25-C, and 10-B.

Triplicate injections of a calibration gas mixture consisting of 200.0 ppm carbon monoxide, 50.0 ppm methane, 10000 ppm carbon dioxide, and 20.00 ppm propane are made immediately before and after each batch of samples. Daily response factors are calculated from the pre-batch integrated responses (average area count / concentration in ppmC) and must agree within 10% of the response factors of the initial calibrations. Further, the post-batch response factors must agree within 2% of the pre-batch response factors. Both criteria must be met before the analyses are considered valid.

CONDENSATE RECOVERY

To flush the trap of CO₂, hydrocarbon-free air is flushed through the trap maintained at -78 °C into the sample tank until less than 10 ppm CO₂ is detected in the flow stream (the concentration of CO₂ is monitored with an NDIR CO₂ detector and measured using a CO₂ analyzer). The sample tank is pressurized to about 1200 mm Hg for analysis and is replaced with an intermediate collection vessel (ICV).

To oxidize the organic material in the trap, hydrocarbon-free air is then passed through the trap heated to 250 °C and the recovery oxidation catalyst into the ICV until less than 10 ppm CO₂ is detected in the flow stream. The ICV is pressurized to about 1200 mm Hg for analysis.

ANALYSIS

All samples, which include the daily calibration gas mixture, sample tanks, and ICVs, are analyzed in triplicate using a computer-interfaced gas chromatograph equipped with an automated gas sampling system and a flame ionization detector (FID). CO, CH₄, and CO₂ are eluted from the Unibead 1S-Carbosieve G column and pass through the analytical oxidation and reduction catalyst to the FID. The column is then backflushed to elute the nonmethane organic (NMO) fraction, which passes through the analytical oxidation and reduction catalysts to the FID.

CALCULATIONS

Calculations are done in accord with USEPA Method 25 procedures. A sample calculation for one of the samples is provided in the report. CO and CO₂ blanks are used to compensate for a background concentration of (1) "CO" due to the interference of O₂ resulting from the coelution of O₂ and CO and (2) CO₂ due to CO₂ and organic compounds in the recovery carrier gas. A concentration of noncondensibles or condensibles of less than the PQL is considered to be zero in computing the TGNMO.

EQUIPMENT

Tanks and ICVs are twice evacuated and filled with ambient air filtered through charcoal and are then evacuated to below 10 mm Hg and monitored for at least an hour to check that the tanks do not leak more than 1 mm Hg/hour. They are then pressurized to greater than ambient pressure with helium, analyzed to ensure < 2 ppmC NMO, and stored for later use.

Traps are flushed at 300 °C for at least 30 minutes with compressed air. Each trap is then flushed at 300 °C for thirty minutes with hydrocarbon-free air. The effluent is then routed through an oxidation catalyst and a reduction catalyst for analysis by FID-GC to confirm less than 10 ppmC total C.

Sampling units are reconditioned by replacing filters and checking that all sections operate properly. The unit is heated (with a PTFE line used in place of a trap) and is flushed with zero air for at least thirty minutes before an aliquot of this flow is injected into the analyzer. If the total carbon concentration is below 10 ppm, the unit is made ready for use and stored for shipment.

Triangle Environmental Services, Inc.

METHOD 25 SAMPLE CALCULATION

Client: TRC Environmental Corporation

ID#98155 Analyzed: 8/3-4/98

Project ID: 22214-12 (IBP Dakota City, Neb.)

Sample # 1 Run 1

D A T A

Note: All pressure values have been converted when necessary to mm Hg and all temperature values to Kelvin.

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	
Presampling	6.4	296.48	Tank N290T:
Postsampling	662.9	299.82	Tank Volume = 0.004500 cu.m
Lab Receipt	653.0	298.15	
Tank Final	1427.0	298.15	Trap GGC →
CV Final	1256.0	299.65	Collection Vessel 36:
			CV Volume = 0.008388 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	181	299	28
CH4	259.6	2	2,655	2,767	2,646
CO2	256.4	2	323,419	323,102	322,171
Noncondensibles	253.5	5	412	401	472
Condensibles	256.4	3	4,703	4,679	4,671

CO Blank = 0 area counts CO2 Blank = 3 ppm

C A L C U L A T I O N S

Measured Concentrations, corrected for blank (ppmC):

$$\begin{aligned}
 \text{Cm(CO)} &= [\text{Area(CO)} - \text{CO Blank}] / \text{RF(CO)} \\
 &= [181 - 0] / 246.7 = 0.7 \\
 &= [299 - 0] / 246.7 = 1.2 \\
 &= [28 - 0] / 246.7 = 0.1
 \end{aligned}$$

$$\begin{aligned}
 \text{Cm(CH}_4\text{)} &= \text{Area(CH}_4\text{)} / \text{RF(CH}_4\text{)} \\
 &= 2655 / 259.6 = 10.2 \\
 &= 2767 / 259.6 = 10.7 \\
 &= 2646 / 259.6 = 10.2
 \end{aligned}$$

$$\begin{aligned}
 \text{Cm(CO}_2\text{)} &= \text{Area(CO}_2\text{)} / \text{RF(CO}_2\text{)} - \text{CO}_2 \text{ Blank} \\
 &= 323419 / 256.4 - 3 = 1258.4 \\
 &= 323102 / 256.4 - 3 = 1257.1 \\
 &= 322171 / 256.4 - 3 = 1253.5
 \end{aligned}$$

$$\begin{aligned}
 \text{Cm(Noncondensibles)} &= \text{Area(Noncondensibles)} / \text{RF(Noncondensibles)} \\
 &= 412 / 253.5 = 1.6 \\
 &= 401 / 253.5 = 1.6 \\
 &= 472 / 253.5 = 1.9
 \end{aligned}$$

$$\begin{aligned}
 \text{Cm(Condensibles)} &= \text{Area(Condensibles)} / \text{RF(Condensibles)} - \text{CO}_2 \text{ Blank} \\
 &= 4703 / 256.4 - 3 = 15.3 \\
 &= 4679 / 256.4 - 3 = 15.2 \\
 &= 4671 / 256.4 - 3 = 15.2
 \end{aligned}$$

Pressure-Temperature Ratio, $Q(i) = P(i)/T(i)$ (mm Hg/K):

$$\begin{aligned}
 \text{Tank Presampling: } Q(2) &= 6.4 / 296.48 = 0.022 \\
 \text{Tank Postsampling: } Q(1) &= 662.9 / 299.82 = 2.211 \\
 \text{Tank Lab Receipt: } Q(5) &= 653.0 / 298.15 = 2.190 \\
 \text{Tank Final: } Q(3) &= 1427.0 / 298.15 = 4.786 \\
 \text{CV Final: } Q(4) &= 1256.0 / 299.65 = 4.192
 \end{aligned}$$

$$\begin{aligned}
 \text{Volume Sampled (dscm)} &= 0.3857 \times \text{Tank Volume} \times [Q(1) - Q(2)] \\
 &= 0.3857 \times 0.004500 \times [2.211 - 0.022] \\
 &= 0.003800
 \end{aligned}$$

Averages and % Relative Standard Deviations (%RSD) of Cm's are calculated.
(%RSD of C=%RSD of Cm)

calculated concentrations (ppmC):

$$\begin{aligned}
 \text{C(CO)} &= Q(3) / [Q(1) - Q(2)] \times \text{Cm(CO)} \\
 &= 4.786 / (2.211 - 0.022) \times 0.7 = 1.5 \quad (<\text{PQL of } 2)
 \end{aligned}$$

$$\begin{aligned}
 \text{C(CH}_4\text{)} &= Q(3) / [Q(1) - Q(2)] \times \text{Cm(CH}_4\text{)} \\
 &= 4.786 / (2.211 - 0.022) \times 10.4 = 22.6
 \end{aligned}$$

$$\begin{aligned}
 \text{C(CO}_2\text{)} &= Q(3) / [Q(1) - Q(2)] \times \text{Cm(CO}_2\text{)} \\
 &= 4.786 / (2.211 - 0.022) \times 1256.4 = 2746.4
 \end{aligned}$$

$$\begin{aligned}
 \text{C(Noncondensibles)} &= Q(3) / [Q(1) - Q(2)] \times \text{Cm(Noncondensibles)} \\
 &= 4.786 / (2.211 - 0.022) \times 1.7 = 3.7 \quad (<\text{PQL of } 5)
 \end{aligned}$$

$$\begin{aligned}
 \text{C(Condensibles)} &= \text{Volume(CV)} / \text{Volume(Tank)} \times Q(4) / [Q(1) - Q(2)] \times \text{Cm(Condensibles)} \\
 &= 0.008388 / 0.004500 \times 4.192 / (2.211 - 0.022) \times 15.3 = 54.5
 \end{aligned}$$

$$\begin{aligned}
 \text{Total Gaseous Non-Methane Organics (TGNMO)} &= \text{C(Noncondensibles)} + \text{C(Condensibles)} \\
 &= 0.0 + 54.5 \\
 &= 54.5
 \end{aligned}$$

Note: Values less than the PQLs have been set to zero.

$$\begin{aligned}
 \text{Mass Concentration (mgC/cu.m)} &= 0.4993 \times \text{TGNMO} \\
 &= 0.4993 \times 54.5 = 27.2
 \end{aligned}$$

<PQL of ### = Concentration Below Practical Quantitation Limit

Triangle Environmental Services, Inc.

METHOD 25 SAMPLE QA/QC DATA

DAILY RECOVERY SYSTEM CHECKS

4.3.1.1* Condensate Recovery System Leak Check

Evacuate system to ≤ 10 mm Hg absolute pressure, isolate system, and monitor for ten minutes.

Requirement: Pressure Change ≤ 3 mm Hg

4.3.1.2* Condensate Recovery System Background Test

Analyze recovery system effluent for CO_2 concentrations.

Requirement: $\text{CO}_2 \leq 10$ ppm

4.3.1.3* Condensate Oxidation Catalyst Efficiency Check

Analyze 1% methane standard through oxidation catalyst.

Requirement: $\text{CO}_2 = \text{CH}_4$ concentration $\pm 2\%$

DAILY ANALYZER CHECKS

5.3* Daily Calibration

Response Factor Checks

Requirement: Daily RF = Initial RF $\pm 10\%$

See the individual sample data sheet for the daily response factor

	Initial RF for Analyzer A 4/8/98	Initial RF for Analyzer B 4/21/98
CO	219.06	247.37
CH ₄	227.99	250.07
CO ₂	225.44	250.03
NMO	228.34	250.52

Triplicate injections of a mixture of CO, CH₄, CO₂, and C₃H₈ are made before and after each batch of samples.

INITIAL CONDENSATE RECOVERY SYSTEM TESTS**5.1.1* Carrier and Auxiliary Gas Blank**Requirement: $\text{CO} + \text{CH}_4 + \text{CO}_2 + \text{NMO} \leq 5 \text{ ppm}$ **5.1.3* System Performance Check**

Volume Injected	Compound	Average % Recovery				% RSD			
50 uL	Hexane	101	102	98.8	104.6	0.058	0.101	1.68	0.229
50 uL	Decane	97	100	93.7	103.3	0.120	0.047	1.7	0.359
10 uL	Hexane	104	107	92	90.0	0.118	0.145	1.206	0.135
10 uL	Decane	98	97	99.6	93.3	0.119	0.232	1.36	0.254
Requirement:		100 $\pm$ 10%				≤ 5			

INITIAL NMO ANALYZER PERFORMANCE CHECKS**5.2.1* Oxidation Catalyst Efficiency Check** Analyzer A,4/8/98; Analyzer B,4/21/98

FID response with reduction catalyst in bypass mode = 0, 0
 Requirement: $\leq 1\%$

5.2.2* Reduction Catalyst Efficiency Check Analyzer A,4/8/98; Analyzer B,4/21/98

Response of CH_4 with oxidation and reduction catalysts in series mode compared to response with both catalysts in bypass mode.
 100.0%, 100.0% Requirement: $> 95\%$

5.2.3* Analyzer Linearity Check+NMO Calibration Analyzer A,4/8/98;Analyzer B,4/21/98

$100 \times (1 - \text{RF} / \text{RF}_{\text{average}})$		Requirement:
max. dev. CO :	+1.70%, +1.28%	$\pm 2.5\%$
max. dev. CH_4 :	-2.00%, -1.77%	$\pm 2.5\%$
max. dev. CO_2 :	+1.71%, +2.10%	$\pm 2.5\%$
max. dev. NMO:	-1.42%, -1.12%	$\pm 2.5\%$
max. %RSD:	1.50%, 0.54%	$\leq 2\%$
$\frac{\text{RF (NMO)}}{\text{RF (CO}_2\text{)}}$	= 0.98, 1.00	1.0 $\pm$ 0.1

5.2.4* System Performance Check Analyzer A, 4/8/98; Analyzer B, 4/21/98, 5/1/98

	Measured Value, Expected Value		Requirement
	Analyzer A	Analyzer B	
Propane in Mix	19.6, 20.0	20.22, 20.0	± 5%
Hexane	50.6, 51.6	51.6, 51.6	± 5%
Toluene	20.3, 20.0	19.34, 20.0	± 5%
Methanol	104.5, 109.1	109.55, 109.0	± 5%

EQUIPMENT CHECKS

4.1.1* Clean Sampling Equipment Check

Sample Unit	<10	ppmC total C	@ 100%
Trap	<10	ppmC total C	@ 100%
Tank	< 2	ppmC NMO	@ 100%

4.1.2* Sample Tank Evacuation and Leak Check

Tank evacuated to ≤10 mm Hg absolute pressure, monitored for ≥1 hour, and passed for use if no pressure change (< 1 mm Hg/hr) is noted.

5.4* Sample Tank and ICV Volumes

Tank weighed empty, filled with deionized distilled water (temperature recorded), and weighed to the nearest 2 g. Volume calculated based on density of water at that temperature and results recorded in permanent file.

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: TRC Environmental Corporation

ID#98155 Analyzed: 8/3-4/98

Project ID: 22214-12 (IBP Dakota City, Neb.)

Sample # 1 Run 1

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	6.4	296.48	0.022	Tank N290T:
Postsampling	662.9	299.82	2.211	Tank Volume = 0.004500 cu.m
Lab Receipt	653.0	298.15	2.190	Volume Sampled = 0.003800 dscm
Tank Final	1427.0	298.15	4.786	<u>Lab Receipt P/T</u> = 0.991
CV Final	1256.0	299.65	4.192	Postsampling P/T
				Trap GGC →
				Collection Vessel 36:
				CV Volume = 0.008388 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	181	299	28
CH4	259.6	2	2,655	2,767	2,646
CO2	256.4	2	323,419	323,102	322,171
Noncondensibles	253.5	5	412	401	472
Condensibles	256.4	3	4,703	4,679	4,671

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 99.6%

CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

*corrected for Blank	ppmC		%RSD
	Amount	SD	
CO*	< 2		
CH4	23 ± 1	2.5	
CO2*	2746 ± 6	0.2	
Noncondensibles	< 5		
Condensibles*	54 ± 0	0.4	

Note: A concentration of noncondensibles or condensibles of less than the PQL is considered to be zero in computing the TGNMO value.

TGNMO 54

Mass Concentration 27 mgC/cu.m

< # = Concentration Below Practical Quantitation Limit

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: TRC Environmental Corporation

ID#98155 Analyzed: 8/3-4/98

Project ID: 22214-12 (IBP Dakota City, Neb.)

Sample # 2 Run 2

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T
Presampling	2.5	297.04	0.008
Postsampling	683.3	297.04	2.300
Lab Receipt	672.0	298.15	2.254
Tank Final	1373.0	298.15	4.605
CV Final	1301.0	300.15	4.334

Tank N294T:

Tank Volume = 0.004531 cu.m
Volume Sampled = 0.004005 dscm

Lab Receipt P/T = 0.980
Postsampling P/T

Trap FFW →

Collection Vessel 39:
CV Volume = 0.008392 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	0	287	273
CH4	259.6	2	2,674	2,863	2,823
CO2	256.4	2	235,658	236,222	236,207
Noncondensibles	253.5	5	780	745	762
Condensibles	256.4	3	4,793	4,691	4,645

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 99.8%

CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

*=corrected for Blank	Amount	ppmC	SD	%RSD
CO*	< 2			
CH4	22 ±	1		3.6
CO2*	1844 ±	3		0.1
Noncondensibles	6 ±	0		2.3
Condensibles*	54 ±	1		1.9
TGNMO	60			

Mass Concentration 30 mgC/cu.m

< # = Concentration Below Practical Quantitation Limit

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: TRC Environmental Corporation

ID#98155 Analyzed: 8/3-4/98

Project ID: 22214-12 (IBP Dakota City, Neb.)

Sample # 3 Run 3

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	2.5	297.04	0.008	Tank N295:
Postsampling	668.9	297.04	2.252	Tank Volume = 0.004503 cu.m
Lab Receipt	648.0	297.15	2.181	Volume Sampled = 0.003896 dscm
Tank Final	1193.0	297.15	4.015	Lab Receipt P/T = 0.968
CV Final	1320.0	298.15	4.427	Postsampling P/T
				Trap GGB →
				Collection Vessel 34:
				CV Volume = 0.008393 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	264	303	287
CH4	259.6	2	1,941	1,992	1,980
CO2	256.4	2	172,600	172,735	172,505
Noncondensibles	253.5	4	485	530	402
Condensibles	256.4	3	3,873	3,799	3,735

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 100.4%

CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

	Amount	ppmC	SD	%RSD
*=corrected for Blank				
CO*	2	±	0	6.9
CH4	14	±	0	1.4
CO2*	1199	±	1	0.1
Noncondensibles	< 4			
Condensibles*	44	±	1	2.3

Note: A concentration of noncondensibles or condensibles of less than the PQL is considered to be zero in computing the TGNMO value.

TGNMO

44

Mass Concentration

22 mgC/cu.m

< # = Concentration Below Practical Quantitation Limit

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: TRC Environmental Corporation

ID#98155 Analyzed: 8/3-4/98

Project ID: 22214-12 (IBP Dakota City, Neb.)

Sample # 4 Blank

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T
Presampling	4.7	297.04	0.016
Postsampling	671.7	298.15	2.253
Lab Receipt	669.5	297.15	2.253
Tank Final	1513.0	297.15	5.092
CV Final	1496.0	299.65	4.992

Tank N293:
 Tank Volume = 0.004549 cu.m
 Volume Sampled = 0.003925 dscm
Lab Receipt P/T = 1.000
 Postsampling P/T
 Trap EED →
 Collection Vessel 23:
 CV Volume = 0.008343 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	0	53	44
CH4	259.6	2	0	0	0
CO2	256.4	2	436,560	437,296	436,742
Noncondensibles	253.5	5	0	0	0
Condensibles	256.4	4	2,433	2,464	2,527

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 100.4%
 CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

	ppmC	Amount	±	SD	%RSD
*=corrected for Blank					
CO*	< 2				
CH4	< 2				
CO2*	3871	±	3		0.1
Noncondensibles	< 5				
Condensibles*	27	±	1		2.8

Note: A concentration of noncondensibles or condensibles of less than the PQL is considered to be zero in computing the TGNMO value.

TGNMO

27

Mass Concentration

14 mgC/cu.m

< # = Concentration Below Practical Quantitation Limit

**Chain
of
Custody**

[illegible]

PARTICULATE ANALYTICAL DATA FORM

COMPANY: IBP STACK NUMBER: Cond Out / Packed Bed
LOCATION: Dakota City, NE RUN NUMBER: 1
DATE: 07/22/98 RELATIVE HUMIDITY: 50 %
ACETONE DENSITY (Pa): 0.7853 g/ml

Liquid level marked and container sealed ? Yes
Aceton Blank residue concentration (Ca) mg/g
Acetone Rinse volume (Vaw) ml
Blank residue in acetone rinse (Wa) = Ca. Vaw. Pa = mg

NOTE: In no case should a blank residue 0.01 mg/g or 0.001% of the weight of acetone used be subtracted from the sample weight.

Date of Weighing 28-Jul-98 Gross Weight 101,070.0 mg
Time of Weighing 08:00

Date of Weighing 28-Jul-98 Gross Weight 101,070.4 mg
Time of Weighing 02:00

AVERAGE GROSS WT. 101,070.2 mg

LESS BLANK RESIDUE (Wa) 0.0 mg

TARE WEIGHT 101,046.5 mg

WEIGHT OF PARTICULATE IN ACETONE RINSE 23.7 mg

Date of Weighing 28-Jul-98 Gross Filter Weight 603.3 mg
Time of Weighing 08:00

Date of Weighing 28-Jul-98 Gross Filter Weight 603.4 mg
Time of Weighing 02:00

AVERAGE GROSS WT. 603.4 mg

FILTER TARE WEIGHT 601.6 mg

WEIGHT OF PARTICULATE ON FILTER 1.8 mg

WEIGHT OF PARTICULATE IN ACETONE RINSE 23.7 mg

TOTAL PARTICULATE 25.5 mg

REMARKS:

Initials of Analyst DW

PARTICULATE ANALYTICAL DATA FORM

COMPANY: IBP STACK NUMBER: Cond Out / Packed Bed
LOCATION: Dakota City, NE RUN NUMBER: 2
DATE: 07/22/98 RELATIVE HUMIDITY: 50 %
ACETONE DENSITY (Pa): 0.7853 g/ml

Liquid level marked and container sealed? Yes
Aceton Blank residue concentration (Ca) mg/g
Acetone Rinse volume (Vaw) ml
Blank residue in acetone rinse (Wa) = Ca. Vaw. Pa = mg

NOTE: In no case should a blank residue 0.01 mg/g or 0.001% of the weight of acetone used be subtracted from the sample weight.

Date of Weighing 28-Jul-98 Gross Weight 105,621.2 mg
Time of Weighing 08:00

Date of Weighing 28-Jul-98 Gross Weight 105,621.3 mg
Time of Weighing 02:00

AVERAGE GROSS WT. 105,621.3 mg

LESS BLANK RESIDUE (Wa) mg

TARE WEIGHT 105,610.6 mg

WEIGHT OF PARTICULATE IN ACETONE RINSE 10.6 mg

Date of Weighing 28-Jul-98 Gross Filter Weight 602.2 mg
Time of Weighing 08:00

Date of Weighing 28-Jul-98 Gross Filter Weight 602.2 mg
Time of Weighing 02:00

AVERAGE GROSS WT. 602.2 mg

FILTER TARE WEIGHT 601.2 mg

WEIGHT OF PARTICULATE ON FILTER 1.0 mg

WEIGHT OF PARTICULATE IN ACETONE RINSE 10.6 mg

TOTAL PARTICULATE 11.6 mg

REMARKS:

Initials of Analyst DW

PARTICULATE ANALYTICAL DATA FORM

COMPANY: IBP STACK NUMBER: Cond Out / Packed Bed
LOCATION: Dakota City, NE RUN NUMBER: 3
DATE: 07/22/98 RELATIVE HUMIDITY: 50 %
ACETONE DENSITY (Pa): 0.7853 g/ml

Liquid level marked and container sealed ? Yes
Acenton Blank residue concentration (Ca) mg/g
Acetone Rinse volume (Vaw) ml
Blank residue in acetone rinse (Wa) = Ca. Vaw. Pa = mg

NOTE: In no case should a blank residue 0.01 mg/g or 0.001% of the weight of acetone used be subtracted from the sample weight.

Date of Weighing 28-Jul-98 Gross Weight 103,881.2 mg
Time of Weighing 08:00

Date of Weighing 28-Jul-98 Gross Weight 103,881.4 mg
Time of Weighing 02:00

AVERAGE GROSS WT. 103,881.3 mg

LESS BLANK RESIDUE (Wa) mg

TARE WEIGHT 103,874.6 mg

WEIGHT OF PARTICULATE IN ACETONE RINSE 6.7 mg

Date of Weighing 28-Jul-98 Gross Filter Weight 605.6 mg
Time of Weighing 08:00

Date of Weighing 28-Jul-98 Gross Filter Weight 605.6 mg
Time of Weighing 02:00

AVERAGE GROSS WT. 605.6 mg

FILTER TARE WEIGHT 604.3 mg

WEIGHT OF PARTICULATE ON FILTER 1.3 mg

WEIGHT OF PARTICULATE IN ACETONE RINSE 6.7 mg

TOTAL PARTICULATE 8.0 mg

REMARKS:

Initials of Analyst DW

Project:	IBP
Date:	07/22/98
Location:	Dakota City, NE
Source:	Cond. out / Packed Bed out

[illegible]

Dissolved Solids

Project: IBP

Date: 07/22/98

Location: Dakota City, NE

Source: Condensor Outlet / Packed Bed out

Meter Box # 4 RUNS 1-3

Post Calibration Method				
	Run 1	Run 2	Run 3	
H@	1.8068	1.8068	1.8068	
SQRT Havg	1.33	1.364	1.321	
				AVERAGE
Post Yi	0.9939	1.0111	1.0166	1.0072
	5% Yi	- RANGE	+	
	0.0491	0.9330	1.0312	

PROJECT NO.		PROJECT NAME		PARAMETERS		REMARKS	
22214-12		DRP DAKOTA CITY, NE					
SAMPLERS: (Signature) <i>Edward H. Wells</i>		(Printed) DAVE WELLS		NO. OF CONTAINERS			
FIELD SAMPLE NUMBER	DATE	TIME	COMP.	GRAB	STATION LOCATION	PARAMETERS	REMARKS
R1 PW	7/22		✓		SUPER COOKER COND OUT / #1 PACK BED OUT	✓	RMS TRAIN w/ BACK 1/2
R2 PW	"		✓			✓	
R3 PW	"		✓			✓	
Blank Acetone	"		✓			✓	
R1 Dmps	"		✓			✓	
R2 Dmps	"		✓			✓	
R3 Dmps	"		✓			✓	
Blank Water	"		✓			✓	
R1 SG ^{LITERS}	"		✓			✓	
R2 SG ^{LITERS}	"		✓			✓	
R3 SG ^{LITERS}	"		✓			✓	
R1-3 SG ⁵⁶	"		✓			3	
Relinquished by: (Signature)		Date / Time		Received by: (Signature)		Date / Time	
(Printed)				(Printed)		(Printed)	
Relinquished by: (Signature)		Date / Time		Received for Laboratory by: (Signature)		Date / Time	
(Printed)				(Printed)		(Printed)	

APPENDIX E

EQUIPMENT CALIBRATION SHEETS

FORM 75-8

TRANSPORTABLE CONTINUOUS EMISSION MONITORING ANALYZER CALIBRATION

Date July 22, 1998
 Time 900
 Project Num 22214-12
 Plant Name IBP / DC
 Analyzer Information :
 Oxygen Analyzer Manufactur Teledyne
 NO/NO_x Analyzer Manufactur TECO
 SO₂ Analyzer Manufactur Bovar
 CO₂ Analyzer Manufactur Milton Roy
 CO Analyzer Manufactur TECO
 THC Analyzer Manufactur JUM

Unit No./Test Location SUPER COOKER
 Ambient Temperature 86 °F
 Barometric Pressure 29.1 " Hg

Operator SM/DW

Model 326-A SN 132680
 Model 10S SN 10S40019-262
 Model 721-M SN 93-721M-8007-8
 Model 3300 SN N7E3778T
 Model 48 SN 48-39875-261
 Model VE-7 SN N/A

Span
 25
 100
 100
 20
 100
 N/A

Calibration Conducted After/Before Test Run Number BEFORE SC101203.RAW

Parameter	ZERO				MIDRANGE				HIGH RANGE			
	Cylinder Number	Cyl. ppm or %	Anal. pm or	% Diff.	Cylinder Number	Cyl. ppm or %	Anal. ppm or %	% Diff.	Cylinder Number	Cyl. ppm or %	Anal. ppm or %	% Diff.
O ₂	CC92990	0	0	0	SG9163644	10.2	10.5	1.2	SG9163638	18	18	0
NO _x	CC92990	0	0	0	SG128628	46	45.4	-0.6	CC84962	84.3	84.5	0.2
SO ₂	CC92990	0	0	0	CC79879	45.1	45.2	0.1	CC55747	88.7	88.8	0.1
CO ₂	CC92990	0	0	0	SG9163644	9.9	9.6	-1.5	SG9163638	17.7	17.7	0
CO	CC92990	0	0.2	0.2	CC83926	30.3	29.8	-0.5	CC79908	86.9	86.9	0

Percent Difference = Analyzer Response - Cylinder Value X 100
 Span

REF: 40CFR60, App. A Method 6C, Section 6.3

PRELIMINARY CALIBRATION SUPER COOKER OUTLET 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
09:02:00	0.0	0.0	-0.0	-1.4	0.0	0.0	0.0	1.4	-0.2	-2.1	22.0
09:03:00	-0.0 <i>Low</i>	-0.3	0.0 <i>Low</i>	0.0	0.0 <i>Low</i>	0.3	0.0 <i>Low</i>	1.4	0.2 <i>Low</i>	1.7	22.0
09:04:00	-0.0	-0.3	0.0	0.0	133.6	1336.0	0.1	2.1	0.1	1.4	22.0
09:05:00	-0.1	-0.7	0.0	0.0	84.4	844.0	0.0	1.7	0.4	4.1	22.0
09:06:00	-0.1	-0.7	0.0	0.0	84.5 <i>Hi</i>	845.0	0.0	1.0	0.7	6.9	22.0
09:07:00	-0.1	-1.0	0.0	0.0	45.4	453.7	0.0	1.4	0.8	8.3	22.0
09:08:00	-0.0	-0.3	0.0	0.0	45.4 <i>Mid</i>	453.7	0.1	2.4	0.5	5.2	22.0
09:09:00	0.0	0.3	17.4	871.0	-0.1	-0.7	18.1	725.0	0.4	4.1	21.9
09:10:00	0.0	0.0	17.7	885.0	-0.2	-2.1	18.1	722.0	-0.3	-3.4	21.9
09:11:00	0.0	0.0	17.7 <i>Hi</i>	887.0	-0.2	-2.1	18.0 <i>Hi</i>	718.0	-0.4	-4.5	22.0
09:12:00	0.0	0.3	9.6	479.4	-0.2	-2.4	10.5	419.3	-0.0	-0.3	22.0
09:13:00	0.0	0.0	9.6 <i>Mid</i>	479.8	-0.2	-1.7	10.5 <i>Mid</i>	418.6	-0.3	-3.1	22.0
09:14:00	0.0	0.3	2.4	120.0	0.4	4.5	12.4	494.2	-0.3	-3.4	22.0
09:15:00	8.6	86.3	0.1	3.8	0.4	3.8	0.1	2.4	0.8	7.6	22.0
09:16:00	8.9	89.1	0.1	2.8	0.3	3.4	0.0	1.0	0.3	3.4	22.0
09:17:00	8.9	89.1	0.0	2.1	0.2	2.1	0.1	2.4	0.6	6.2	22.0
09:18:00	89.2	892.0	0.0	1.7	0.2	2.4	0.0	1.0	0.4	4.1	21.9
09:19:00	88.8 <i>Hi</i>	888.0	0.0	1.4	0.3	3.4	0.0	1.0	0.8	8.3	21.9
09:20:00	58.8	588.4	0.0	0.7	-0.4	-4.1	0.1	2.4	0.5	4.8	21.9
09:21:00	45.2 <i>Mid</i>	451.6	0.0	0.0	-0.3	-3.1	0.1	2.1	0.7	6.5	21.9
09:22:00	2.0	19.6	0.0	0.0	-0.4	-3.8	0.1	2.1	27.6	275.5	22.0
09:23:00	0.3	2.8	-0.0	-0.7	-0.2	-2.4	0.0	0.3	88.5	885.0	21.9
09:24:00	0.2	1.7	-0.0	-1.0	-0.3	-3.1	0.0	0.7	86.3	863.0	21.9
09:25:00	0.1	1.4	-0.0	-1.4	-0.4	-4.5	0.0	1.4	86.9 <i>Hi</i>	869.0	21.9
09:26:00	0.1	0.7	-0.0	-1.4	-0.4	-4.5	0.1	2.1	46.9	469.1	21.9
09:27:00	0.1	0.7	-0.0	-2.1	-0.3	-3.1	0.0	1.7	29.4	294.4	21.9
09:28:00	0.0	0.0	-0.0	-2.1	-0.3	-3.1	0.0	1.7	29.8 <i>Mid</i>	298.2	21.9
09:29:00	-0.0	-0.3	-0.0	-2.1	-0.3	-2.8	0.0	1.7	6.2	62.3	21.9
09:30:00	-0.1	-1.0	-0.0	-2.1	-0.2	-2.1	0.0	0.3	0.0	0.3	21.9
09:31:00	0.6	5.8	-0.0	-2.1	-0.2	-1.7	2.1	82.9	0.1	0.7	21.9
09:32:00	0.4 <i>Low</i>	3.8	-0.0 <i>Low</i>	-1.4	-0.2 <i>Low</i>	-2.4	0.1 <i>Low</i>	2.4	5.8 <i>Low</i>	57.8	21.9
09:33:00	0.3 <i>Low</i>	3.1	-0.0 <i>Low</i>	-1.4	-0.3 <i>Low</i>	-3.4	0.1 <i>Low</i>	3.4	1.5 <i>Low</i>	15.5	21.9
09:34:00	0.2	2.4	-0.0	-1.4	-0.2	-2.1	0.1	2.4	1.1	11.0	21.9
09:35:00	0.2	1.7	-0.0	-1.4	45.0 <i>Low</i>	450.2	0.0	1.7	1.3	13.1	21.9
09:36:00	0.1	1.4	17.4	870.0	0.2	2.1	18.0	719.0	1.7	17.2	21.9
09:37:00	0.2	2.4	17.6 <i>Low</i>	878.0	-0.2	-1.7	18.1 <i>Low</i>	722.0	0.6	5.8	21.9
09:38:00	0.5	5.2	17.6 <i>Low</i>	881.0	-0.2	-1.7	18.0 <i>Low</i>	721.0	0.9	9.3	21.9
09:39:00	28.7	287.2	0.2	9.6	-0.2	-2.4	0.3	10.7	0.8	7.9	21.9
09:40:00	40.5	405.5	0.1	4.8	-0.3	-2.8	0.1	4.1	1.6	16.2	21.9
09:41:00	42.2	422.3	0.1	3.4	-0.1	-0.7	0.1	2.4	1.3	13.1	21.9
09:42:00	43.1 <i>Low</i>	430.9	0.1	2.8	0.0	0.0	0.1	2.1	1.3	12.7	21.9
09:43:00	43.4 <i>Low</i>	434.4	0.0	2.1	-0.1	-0.7	0.0	1.4	1.4	14.4	21.9
09:44:00	21.5	214.9	0.1	3.4	-0.0	-0.3	0.2	6.5	1.4	14.1	21.9
09:45:00	3.1	31.3	0.0	2.1	-0.1	-0.7	0.1	2.1	31.0 <i>Low</i>	310.2	21.9

PRELIMINARY CALIBRATION SUPER COOKER OUTLET 7-22-98

TIME	SO2 (PPM)	SO2 (MV)	CO2 (%)	CO2 (MV)	NOX (PPM)	NOX (MV)	O2 (%)	O2 (MV)	SPARE (PPM)	SPARE (MV)	TEMP (C)
09:46:00	2.1	21.3	0.0	2.1	-0.2	-1.7	0.1	3.4	31.5	314.7	21.9
09:47:00	1.7	16.9	0.0	1.4	-0.2	-1.7	0.1	2.4	29.7	296.8	21.9
09:48:00	1.4	14.1	0.0	1.4	0.0	0.0	0.0	1.7	1.2	11.7	21.9
09:49:00	1.3	13.4	0.0	1.4	-0.0	-0.3	0.1	2.8	1.3	13.4	21.9
09:50:00	36.8	368.0	0.0	1.0	-0.2	-2.1	0.1	2.8	1.7	16.5	21.9
09:51:00	42.9	428.5	0.0	1.4	-0.2	-1.7	0.1	2.8	1.9	18.9	21.9
09:52:00	6.5	64.7	0.0	1.4	-0.0	-0.3	0.0	1.4	1.4	14.1	21.9
09:53:00	2.1	20.6	0.0	1.4	-0.2	-1.7	0.1	3.1	1.5	15.5	21.9
09:54:00	38.3	382.5	0.0	1.4	-0.2	-2.1	0.1	2.8	1.7	16.9	21.9
09:55:00	43.0	430.2	0.0	1.4	-0.3	-2.8	0.1	3.1	1.9	18.6	21.9
09:56:00	6.0	60.2	0.0	1.0	-0.2	-1.7	0.0	1.7	1.5	14.8	21.9
09:57:00	1.9	18.6	0.0	1.0	-0.1	-1.4	0.0	1.4	1.3	12.7	21.9
09:58:00	37.5	375.5	0.0	1.0	-0.1	-1.4	0.1	2.4	1.6	15.8	21.9
09:59:00	43.1	430.6	0.0	1.0	-0.3	-3.1	0.1	2.8	1.8	18.2	21.9
10:00:00	6.3	62.6	0.0	1.4	-0.3	-3.1	0.1	3.1	1.6	16.2	21.9
10:01:00	1.8	17.5	0.0	1.4	-0.3	-3.4	0.1	3.4	1.5	14.8	21.9
10:02:00	1.2	12.0	0.0	1.4	-0.3	-3.1	0.1	2.1	1.2	11.7	21.9
10:03:00	0.9	8.9	0.0	1.4	-0.3	-2.8	0.0	1.7	1.1	11.0	21.9

RT= Response Times Seconds

	<u>1</u>	<u>2</u>	<u>3</u>	<u>High</u>
SO2 UP	86.0	82.0	80.0	86.0
Down	85.0	83.0	83.0	

For Technical Information Call
1-800-752-1597



Air Products and Chemicals, Inc. • 12722 S. Wentworth Avenue, Chicago, IL 60628

ISO CERTIFICATION: 9002

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS STANDARD

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCT AND CHEMICALS INC
12721 S WENTWORTH AVE
CHICAGO IL 60628

Order No: CSS-812908-01
Batch No: 861-42976
PO:
Release:

Cylinder No: SG9163644BAL
Bar Code No: DRG040
Cylinder Pressure*: 2000 psig
Certification Date: 11/10/97
Expiration Date: 11/10/00

CERTIFIED CONCENTRATION		REFERENCE STANDARDS				ANALYTICAL INSTRUMENTATION			
Component	Certified Concentration	Cylinder Number	Standard Type	Standard Concentration	Instrument Make/Model	Serial Number	Last Calibration	Measurement Principal	
CARBON DIOXIDE	9.90±.053 %	SG9168488BAL	GMIS	19.37 %	Horiba VIA-510	51135063	11/03/97	NON DISPERSIVE INFRARED	
OXYGEN	10.2±.09 %	SG9113445BAL	GMIS	22.64 %	Shimadzu GC-8A	32029	11/03/97	GC-TCD	
NITROGEN Balance Gas									

* STANDARD SHOULD NOT BE USED BELOW 150 PSIG

Analyst:

(16921)

James Laas

Approved By:

Richard Fry
Richard Fry

Pub. No. 320-9702

For Technical Information Call
1-800-752-1597



Air Products and Chemicals, Inc. • 23320 S. Alameda Street, Long Beach, CA 90810

ISO CERTIFICATION: 9002

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS STANDARD

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G2)

Customer:

AIR PRODUCTS AND CHEMICALS
901 WEST 12TH STREET
LONG BEACH CA 90813-

Order No: SRP-765008-07
Batch No: 863-29604
PO:
Release:

Cylinder No: SG9128628BAL
Bar Code No: DMK314
Cylinder Pressure*: 2000 psig
Certification Date: 08/27/97
Expiration Date: 08/27/99

CERTIFIED CONCENTRATION		REFERENCE STANDARDS			ANALYTICAL INSTRUMENTATION			
Component	Certified Concentration	Cylinder Number	Standard Type	Standard Concentration	Instrument Make/Model	Serial Number	Last Calibration	Measurement Principal
NITRIC OXIDE	46.0 ± 0.23 PPM	SG9136106BAL	GM15	57.69 PPM	TECO Model 42	53426296	08/08/97	CHEMILUMINESCENCE

NO2 (Reference Value Only): .500 PPM

NITROGEN Balance Gas

Contaminant

Nitrogen Dioxide .500 PPM

* STANDARD SHOULD NOT BE USED BELOW 150 PSIG

Analyst:

Look Jeon
KOOK JEON

(16921)

Approved By:

Charles A. Chubb

M KHOUDESSERIAN

Pub. No. 320-9703

For Technical Information Call
1-800-752-1597



Air Products and Chemicals, Inc. • 12722 S. Wentworth Avenue, Chicago, IL 60628

ISO CERTIFICATION: 9002

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS STANDARD

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCT AND CHEMICALS INC
12721 S WENTWORTH AVE
CHICAGO IL 60628

Order No: CSS-812907-01
Batch No: 861-42978
PO:
Release:

Cylinder No: SG9163638BAL
Bar Code No: DRG052
Cylinder Pressure*: 2000 psig
Certification Date: 11/08/97
Expiration Date: 11/08/00

CERTIFIED CONCENTRATION		REFERENCE STANDARDS				ANALYTICAL INSTRUMENTATION			
Component	Certified Concentration	Cylinder Number	Standard Type	Standard Concentration	Instrument Make/Model	Serial Number	Last Calibration	Measurement	
CARBON DIOXIDE	17.7±.06 %	SG9168488BAL	GMIS	19.37 %	Horiba VIA-510	51135063	11/03/97	Principal	
OXYGEN	18.0±.09 %	SG9113445BAL	GMIS	22.64 %	Shimadzu GC-8A	32029	11/03/97	NON DISPERSIVE INFRARED	
NITROGEN		Balance Gas							
		GC-TCD							

* STANDARD SHOULD NOT BE USED BELOW 150 PSIG

Analyst:

James Laas / JLD
James Laas

Approved By:

Richard Fry KB
Richard Fry

(16921)

Pub. No. 320-9702

**SPECTRA GASES**

277 Colt St. • Irvington, NJ 07111 USA Tel.: (201) 372-2060 • (800) 932-0624 • Fax: (201) 372-8551

Shipped From: 80 Industrial Drive • Alpha, N.J. 08865

PS-13

**CERTIFICATE OF ANALYSIS****EPA PROTOCOL MIXTURE****PROCEDURE #:** G1

CUSTOMER: Instrument Solutions
SGI ORDER #: 126377
ITEM#: 13
P.O.#: 97002

CYLINDER #: CC79908 ✓
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 350

CERTIFICATION DATE: 8/1/97**EXPIRATION DATE:** 8/1/2000**CERTIFICATION HISTORY**

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Monoxide	7/25/97	86.94 ppm	86.9 ppm	+/- 1%
	8/1/97	86.87 ppm		

BALANCE

Nitrogen

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Monoxide	SRM-1678c	CLM009368	49.94 ppm

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Monoxide	Horiba-VIA-510	570423011	NDIR	7/24/97

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST:

TED NEEME

DATE: 8/1/97

**SPECTRA GASES**

277 Colt St. • Irvington, NJ 07111 USA Tel.: (201) 372-2060 • (800) 932-0624 • Fax: (201) 372-8551
Shipped From: 80 Industrial Drive • Alpha, N.J. 08865

RS-35

**CERTIFICATE OF ANALYSIS****EPA PROTOCOL MIXTURE
PROCEDURE #: G1**

CUSTOMER: Stock
SGI ORDER #: 950457
ITEM#: 18
P.O.#: Verbal

CYLINDER #: CC55747 ✓
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 660

CERTIFICATION DATE: 7/25/97
EXPIRATION DATE: 7/25/99

CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Sulfur Dioxide	7/18/97 7/25/97	88.70 ppm 88.72 ppm	88.7 ppm	+/- 1%

BALANCE

Nitrogen

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Sulfur Dioxide	NTRM-R81694	CC53331	96.0 ppm

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Sulfur Dioxide	Horiba-VIA-510	851221093	NDIR	7/7/97

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 160 PSIG.

ANALYST:

TED NEEME

DATE: 7/25/97

**SPECTRA GASES**

277 Colt St. • Irvington, NJ 07111 USA Tel.: (973) 372-2080 • (800) 932-0824 • Fax: (973) 372-8551
Shipped From: 80 Industrial Drive • Alpha, N.J. 08865

RS-67

**CERTIFICATE OF ANALYSIS****EPA PROTOCOL MIXTURE
PROCEDURE #: G1**

CUSTOMER: Stock
SGI ORDER #: 950528
ITEM#: 5
P.O.#: 2.0006

CYLINDER #: CC84962 ✓
CYLINDER PRES: 2000
COA OUTLET: 860
STOCK #: RS-67

CERTIFICATION DATE: 12/3/97

EXPIRATION DATE: 12/3/99

CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Nitric Oxide	11/11/97 12/3/97	84.46 ppm 84.20 ppm	84.3 ppm	+/- 1%
NOx			84.3 ppm	Reference Value Only

BALANCE

Nitrogen

REFERENCE STANDARDS

COMPONENT	BRM/NTRM#	CYLINDER#	CONCENTRATION
Nitric Oxide	SRM-1884b	CLM008435	98.8 ppm

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Nitric Oxide	Teco 10	10AR-34979-249	Chem	11/3/97

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 160 PSIG.

ANALYST:

Fred Pikula
FRED PIKULA

DATE: 12/3/97

02/08/98 08:30 FAX

SGISHIPPING

203

**SPECTRA GASES**277 Coll St. • Irvington, NJ 07111 USA Tel.: (973) 372-2060 • (800) 832-0624 • Fax: (973) 372-8551
Shipped From: 80 Industrial Drive • Alpha, N.J. 08855

RS-86

**CERTIFICATE OF ANALYSIS****EPA PROTOCOL MIXTURE
PROCEDURE #: G1**CUSTOMER: Stock
SGI ORDER #: 950618
ITEM#: 1
P.O.#: VERBALCYLINDER #: CC83928 ✓
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 350
STOCK #: RB-80CERTIFICATION DATE: 1/7/98
EXPIRATION DATE: 1/7/2001**CERTIFICATION HISTORY**

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Monoxide	12/31/97 1/7/98	30.28 ppm 30.22 ppm	30.3 ppm	±1.1%

BALANCE

Nitrogen

REFERENCE STANDARDS

COMPONENT	SRM/INTRMS	CYLINDER#	CONCENTRATION
Carbon Monoxide	SRM-1678c	CAL011878	97.8 ppm

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Monoxide	Horiba VIA-510	670423011	NDIR	1/7/98

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.ANALYST: Fred Pikula
FRED PIKULADATE: 1/7/98

**SPECTRA GASES**

277 Coit St. • Irvington, NJ 07111 USA Tel.: (201) 372-2060 • (800) 932-0624 • Fax: (201) 372-8551
Shipped From: 80 Industrial Drive • Alpha, N.J. 08865

RS-34

**CERTIFICATE OF ANALYSIS****EPA PROTOCOL MIXTURE
PROCEDURE #: G1**

CUSTOMER: Rental Solutions
SGI ORDER #: 127781
ITEM#: 3
P.O.#: 97012

CYLINDER #: CC79879✓
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 660

CERTIFICATION DATE: 9/15/97
EXPIRATION DATE: 9/15/99

CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Sulfur Dioxide	9/6/97 9/15/97	45.04 ppm 45.10 ppm	45.1 ppm	+/- 1%

BALANCE Nitrogen

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Sulfur Dioxide	NTRM-R81694	CC53331	96.0 ppm

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Sulfur Dioxide	Horiba-VIA-510	851221093	NDIR	8/29/97

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST: L. Gameson
LYN GAMESON

DATE: 9/15/97

ROTOMETER CALIBRATION SHEET

Date: 4/28/97
Initials: DW
Part #: RIG #1

Rotometer Scale: 0-120 cc
Rotometer Use: RM25 SAMPLE RIS
Calibrated Against: Bios DC-1


[illegible]

SUBJECT _____

Actual Rotometer Reading
cc/min

40
60
80
100
120
130
Rotometer
Setting
cc/min

RM 25 Rig #1



ROTOMETER CALIBRATION SHEET

Date: 4/28/97
Initials: DW
Part #: 21G #3

Rotometer Scale: 0-120 cc
Rotometer Use: RH25 SAMPLE RIS
Calibrated Against: Bios DC-1


[illegible]

SUBJECT _____

ACTUAL SAMPLING RATE
cc/min

Remover Set Meter cc/min

Rm25 RIG #2



ROTOMETER CALIBRATION SHEET

Date: 4/28/97
Initials: aw
Part #: RIG #2

Rotometer Scale: 0-120 cc
Rotometer Use: RM25 SAMPLE Rig
Calibrated Against: Bios DC-1

[illegible]

PRETEST DRY GAS METER CALIBRATION DATA FORM (ENGLISH UNITS)									
METER BOX NUMBER		4							
DRY GAS METER NUMBER		6830271							
DATE		02/03/98							
REFERENCE TEST METER NUMBER		27865							
DELTA-H		0.5	1	1.5	2	2.5	3	3.5	4
V _{wr}	645.408	650.622	659.152	665.909	672.909	679.075	692.381	698.531	704.385
V _{dr}	606.264	611.703	620.407	627.394	634.655	641.039	654.846	661.226	667.303
T _w		72	72	71	71	70	70	70	70
T _{di}		77.5	81.5	83.5	85	87	89.5	91	93.5
T _{do}		76	77.5	78	78.5	79.5	80.5	81.5	83.5
T _{d(AVE)}		76.8	79.5	80.8	81.8	83.3	85.0	86.3	88.5
THETA		13.0	15.0	10.0	9.0	7.0	14.0	6.0	5.4
VAC.		1	1	1	1	1	1	1	1
Y _i		0.9660	0.9914	0.9812	0.9787	0.9839	0.9837	0.9849	0.9871
DELTA-H@i		1.7552	1.7373	1.8346	1.8428	1.7842	1.8332	1.8346	1.8323
V _w		5.214	8.53	6.757	7	6.166	13.306	6.15	5.854
V _d		5.439	8.704	6.987	7.261	6.384	13.807	6.38	6.077
V _{d/Min.}		0.4184	0.5803	0.6987	0.8068	0.9120	0.9862	1.0633	1.1359
Y(AVE)		0.9821							
DELTA-H@(AVE)		1.8068							
Phar		29.6							

CALIBRATED BY DW

V_{wr}=REFERENCE TEST METER READING

V_{dr}=DRY GAS METER READING

V_w=GAS VOLUME PASSING THROUGH THE REFERENCE TEST METER, CUBIC FEET

V_d=GAS VOLUME PASSING THROUGH THE DRY GAS METER, CUBIC FEET

T_w=TEMPERATURE OF THE GAS IN THE REFERENCE TEST METER, DEGREES F

T_{di}=TEMPERATURE OF THE INLET GAS OF THE DRY GAS METER, DEGREES F

T_{do}=TEMPERATURE OF THE OUTLET GAS OF THE DRY GAS METER, DEGREES F

T_d=AVERAGE TEMPERATURE OF THE GAS IN THE DRY GAS METER, DEGREES F

DELTA-H=PRESSURE DIFFERENTIAL ACROSS ORIFICE, in. WATER

Y_i=RATIO OF ACCURACY OF REFERENCE TEST METER TO DRY GAS METER FOR EACH RUN

Y=AVERAGE RATIO OF ACCURACY OF REFERENCE TEST METER TO DRY GAS METER

DELTA-H@i=ORIFICE PRESSURE DIFFERENTIAL THAT EQUATES TO 0.75 cfm OF AIR

AT 68 DEGREES F AND 29.92 INCHES OF Hg., INCHES OF WATER

DELTA-H@=AVERAGE ORIFICE PRESSURE DIFFERENTIAL THAT EQUATES TO 0.75 cfm OF AIR

AT 68 DEGREES F AND 29.92 INCHES OF Hg., INCHES OF WATER

TOLERANCE OF Y_i=PLUS OR MINUS 0.020 FROM Y

TOLERANCE OF DELTA-H@i=PLUS OR MINUS 0.20 FROM DELTA-H@

Phar=BAROMETRIC PRESSURE, in. Hg.

THETA=TIME OF CALIBRATION RUN, Min.

Thermocouple Calibration Form

Meter Box #4

Thermocouple Number	Temperature Reading #1	Reference Temp #1	Temperature Reading #2	Reference Temp #2	Temperature Reading #3	Reference Temp #3
1 Stack	71	70	198	199	288	287
2 Probe	71	71	198	199	289	287
3 Filter	72	72	198	199	289	287
4 Impingers	71	72	198	199	288	287
5 Spare	71	72	198	199	288	287
6 DGM In	41	40	70	70	107	108
7 DGM Out	40	40	68	68	113	113

Calibrated By: SRM

Date: 4-29-96

Criteria: Impinger temperature must be with 2 °F of reference temperature
Criteria: DGM temperature must be with ± 5.4 °F of reference temperature
Criteria: Stack temperature must be with 1.5% of reference temperature

PRETEST DRY GAS METER CALIBRATION DATA FORM (ENGLISH UNITS)

METER BOX NUMBER

4

DRY GAS METER NUMBER

6830271

DATE

08/24/98

REFERENCE TEST METER NUMBER

27865

DELTA-H	1.75	1.75	1.75	1.75
Vwr	848.641	853.641	858.641	863.641
Vdr	865.600	870.715	875.689	880.805
Tw		76.0	77.0	77.0
Tdi		68.0	73.0	76.0
Tdo		63.0	66.0	68.0
Td(AVE)		65.5	65.0	72.0
THETA		6.7	6.7	6.7
VAC.		8.0	8.0	8.0
Yi		0.9542	0.9785	0.9640
DELTA-H@i		1.8511	1.8597	1.8353
Vw		5	5	5
Vd		5.115	4.974	5.116
Vd/Min.		0.7634	0.7424	0.7636

Y(AVE) 0.9656

DELTA-H@(AVE) 1.8487

CALIBRATED BY

tl

Pbar 29.42

Vwr=REFERENCE TEST METER READING

Vdr=DRY GAS METER READING

Vw=GAS VOLUME PASSING THROUGH THE REFERENCE TEST METER, CUBIC FEET

Vd=GAS VOLUME PASSING THROUGH THE DRY GAS METER, CUBIC FEET

Tw=TEMPERATURE OF THE GAS IN THE REFERENCE TEST METER, DEGREES F

Tdi=TEMPERATURE OF THE INLET GAS OF THE DRY GAS METER, DEGREES F

Tdo=TEMPERATURE OF THE OUTLET GAS OF THE DRY GAS METER, DEGREES F

Td=AVERAGE TEMPERATURE OF THE GAS IN THE DRY GAS METER, DEGREES F

DELTA-H=PRESSURE DIFFERENTIAL ACROSS ORIFICE, in. WATER

Yi=RATIO OF ACCURACY OF REFERENCE TEST METER TO DRY GAS METER FOR EACH RUN

Y=AVERAGE RATIO OF ACCURACY OF REFERENCE TEST METER TO DRY GAS METER

DELTA-H@i=ORIFICE PRESSURE DIFFERENTIAL THAT EQUATES TO 0.75 cfm OF AIR

AT 68 DEGREES F AND 29.92 INCHES OF Hg., INCHES OF WATER

DELTA-H@=AVERAGE ORIFICE PRESSURE DIFFERENTIAL THAT EQUATES TO 0.75 cfm OF AIR

AT 68 DEGREES F AND 29.92 INCHES OF Hg., INCHES OF WATER

TOLERANCE OF Yi=PLUS OR MINUS 0.020 FROM Y

TOLERANCE OF DELTA-H@i=PLUS OR MINUS 0.20 FROM DELTA-H@

Pbar=BAROMETRIC PRESSURE, in. Hg.

THETA=TIME OF CALIBRATION RUN, Min.

Nozzel Calibration Form

Nozzel Set No. 3-4

Date: 05/08/98

Tech: DW


Nozzel No.	Diameter	a	b	c	average
1 - 4- 1	1 / 4	0.245	0.245	0.243	0.244

BAROMETER CALIBRATION FORM

Barometer # 1
Cal'd Against Hg Barometer

[illegible]

S-TYPE PITOT TUBE CALIBRATION



ΔP : Standard (in. W.G.) $(C_p = 0.99)$	ΔP : S-Type (in. W.G.)	Calculated C_p : S-Type
0.01	0.019	0.7182
0.02	0.035	0.7484
0.03	0.047	0.7910
0.04	0.058	0.8222
0.05	0.070	0.8367
0.06	0.083	0.8417

Type S Pitot Inspection Form


Pitot Tube No. 403

Tubing Diameter, D_t 3/8 In.

$$\left(\frac{3}{16} < D_t < \frac{3}{16}\right)$$

Pitot Tube Assembly Level? (Yes/No)

Pitot Tube Opening Damaged? Yes/No





Note:

$$1.05 D_t < P < 1.50 D_t$$

$$P_A = P_B$$

$$P_A = \frac{7}{8} \text{ in.}$$


$$P_B = \frac{7}{8} \text{ in.}$$



$$\beta_1 = \frac{1}{0} \text{ in.}$$

$$\beta_2 = \frac{0}{0} \text{ in.}$$


$$(< 5^\circ)$$



Level Position to find $\gamma =$ 0

$$Z = A' \sin \gamma \text{ In. } (< 1/8 \text{ In.})$$

Comments:



Level Position to find $\theta =$ 1

$$W = A' \sin \theta \text{ In. } (< 1/32 \text{ In.})$$

Checked by: BW

Calibration Required? NO

Date: 4/12/98

D_t = External Tube Diameter

A' = Distance Between Tips ($P_A + P_B$) inches