

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Background Report Reference

AP-42 Section Number: 9.9.1

Background Report Section: 4

Reference Number: 43

**Title: Particulate Emission Tests on
Cyclone Exhaust at Pillsbury
Operated Grain Elevator in Currin,
Illinois**

Industrial Testing Laboratories, Inc.

June 1972

June 1972

AP-42 Section	9.9.1
Reference	4
Report Sect.	43
Reference	43

PARTICULATE EMISSION TESTS ON CYCLONE EXHAUST
AT PILLSBURY OPERATED GRAIN ELEVATOR

in Curran, Illinois

Report No. 26-6-171


Prepared by:

Michael F. Fuller
Michael F. Fuller
Group Leader
Environmental Technology

Approved by:

Allan M. Siegel
Allan M. Siegel, P.E.
Director

INDUSTRIAL TESTING LABORATORIES, INC.
2350 Seventh Boulevard
ST. LOUIS, MISSOURI 63104



INDUSTRIAL TESTING LABORATORIES inc.

2350 Seventh Blvd. • St. Louis, Missouri 63104

Chemists

Engineers

Metallurgists

314/PROspect 1-7111

ALLAN M. SIEGEL, Director

Report No. 26-6-171

TABLE OF CONTENTS

<u>Part</u>	<u>Subject</u>
I	Summary of Test Results
II	Background
III	Photographs
IV	Sampling Equipment and Procedures
V	Figures
VI	Specific Test Data
VII	Data Sheets
VIII	Calculations

INDUSTRIAL TESTING LABORATORIES inc.

2350 Seventh Blvd. • St. Louis, Missouri 63104

Chemists

Engineers

Metallurgists

314/PROspect 1-7111

ALLAN M. SIEGEL, Director

Report No. 26-6-171

Part I SUMMARY OF TEST RESULTS

A. Mass Emission Rates (Std. Cond.), Pounds Per Hour:

(1) Primary-Upper Cyclone

Test No. 1 8.5

Test No. 2 7.7

(2) Primary-Lower Cyclone

Test No. 3 4.2

Test No. 4 5.4

(3) Small Cyclone (rail-loading) ✓

Test No. 5 0.06

Test No. 6 0.06

NOTE

B. Volumetric Flow Rates, s.c.f.m.

(1) Primary-Upper Cyclone 11,000 ($\pm$ 100)

(2) Primary-Lower Cyclone 9,600 ($\pm$ 100)

(3) Small Cyclone 1,760 ($\pm$ 20)

C. Maximum Allowable Emission (Ill. P.C.B. Newsletter #46, Table 2.1 for NEW PROCESS; $E = 2.54 \times (P)^{.534}$)

(1) Combined Primary Cyclones @ 294 ton/hr. 52.5

(2) Small Cyclone @ 29.6 ton/hr. 15.5

NOTE



INDUSTRIAL TESTING LABORATORIES inc.

2350 Seventh Blvd. • St. Louis, Missouri 63104

Chemists

Engineers

Metallurgists

314/PROspect 1-7111

ALLAN M. SIEGEL, Director

Report No. 26-6-171

June 25, 1972

Particulate emission tests on cyclones at Pillsbury Grain Elevator in
Curran, Illinois.

The Pillsbury Company
608 Second Avenue South
Minneapolis, Minnesota 55402

P.O.: Letter May 24, 1972
Attn: Mr. D. E. Fiscus

TEST REPORT

Part II BACKGROUND

On June 23, 1972, a series of emission tests were conducted on the cyclones of the Pillsbury operated grain elevator in Curran, Illinois.

Duplicate particulate emission tests were performed on the exhaust gases of three Carter-Day cyclones, shown in Photographs Nos. 1 and 2. The tests were conducted in accordance with the applicable procedures of ASME Power Test Code 27-1957. Rader H1 Volume sampling systems were used in accordance with their operating manuals. Minor changes from their instructions (i.e., the use of a 0-1" magnehelic gage and the "Velocity Tables", etc.) were incorporated when they added to the precision or accuracy of the tests.



INDUSTRIAL TESTING LABORATORIES inc.

2350 Seventh Blvd. • St. Louis, Missouri 63104

Chemists

Engineers

Metallurgists

314/PROspect 1-7111

ALLAN M. SIEGEL, Director

Report No. 26-6-171

Part II

Page 2

The tests were conducted by Messrs. M. Fuller and D. Dickus of Industrial Testing Laboratories, Inc., with the assistance of elevator personnel.

PHOTOGRAPHS

PHOTO NO. 1

Primary Cyclones, Upper & Lower
(before addition of exhaust
ducts) Day 45 H





PHOTO NO. 2

Small Cyclone
(before addition of
exhaust duct) Day 20 H



INDUSTRIAL TESTING LABORATORIES inc.

2350 Seventh Blvd. • St. Louis, Missouri 63104

Chemists

Engineers

Metallurgists

314/PROspect 1-7111

ALLAN M. SIEGEL, Director

Report No. 26-6-171

Part IV SAMPLING EQUIPMENT & PROCEDURES:

Extensions were added to the cyclone exhaust orifices to provide a sampling location approximately 10 diameters and 2 diameters upstream from obstructions and bends. This was accomplished by the addition of 24" ID galvanized duct and 12" ID galvanized duct onto the Day 45H and 20 H cyclones, respectively. Access to samples points was achieved through two 4" ID entry ports placed 90° apart and two diameters from the discharge end of the extension ducts.

Velocity Pressure and duct static pressure were measured with standard pitot tubes and magnehelic gages (0-1" H₂O). Gas temperature was measured with mercury thermometers. Barometric pressure was determined at the test site with a portable barometer. Orsat analysis was not required. Time was measured on a watch with a sweep-second hand. From these data gas velocities and isokinetic sampling rates were calculated from the calibration curves supplied with the sampler. The values were checked against those given in the Research-Cottrell, Inc., "Velocity Tables".



INDUSTRIAL TESTING LABORATORIES inc.

2350 Seventh Blvd. • St. Louis, Missouri 63104

Chemists

Engineers

Metallurgists

314/PROspect 1-7111

ALLAN M. SIEGEL, Director

Report No. 25-6-171


Page 2

Part IV

A total of eight sample points were used in each duct as shown in the traverse point layout (Figure 1). Sample was collected for one minute per point in the 24" ID duct from the 45 H cyclones and for 0.5 minutes per point in the 12" ID duct on the 20 H cyclone. A blank filter determination was run for each duplicate test on a cyclone. A Rader Hi-Volume Sampler, as shown in Figure 2, was used for particulate collection. Type A glass fiber filter pads were weighed immediately prior to and immediately after sample collection, using a Christian-Becker chain-o-matic balance.

TRAVERSE POINT LAYOUT

Figure 1




Percent of Diameter
From Circumference

Point
Nos.

6.7
25.0
75.0
99.3

1, 5
2, 6
3, 7
4, 8



REV.

REV. A 10-0-171 MINT. WORKING CHANGE



TITLE

RADER HI-VOLUME SAMPLER

SCALE

DATE

7-30-71

DRWN.

J.V. HIRSCH

CKD.

A-100332A

Part VI SPECIFIC TEST DATA

Date: 6/23/72 6/23/72 6/23/72 6/23/72 6/23/72 6/23/72

Test No: 1 2 3 4 5 6

Location (Cyclone Exhaust): Upper 45H Upper 45H Lower 45H Lower 45H 2CH 2CH

Time: 1:39-1:51 2:01-2:12 2:35-2:45 2:52-3:06 4:00-4:05 4:10-4:17

Duration, min: 8 8 8 8 4 4

Ambient Conditions:

Temperature, °F. 73 73 73 73 73 73

Barometric Pressure, in. Hg 29.41 29.41 29.41 29.41 29.40 29.40

Relative Humidity 80-75 80-75 80-75 80-75 75 75

Collection Equipment Data:

Nozzle I.D. inches 15/16 15/16 15/16 15/16 1-7/8 1-7/8

Glass Pad Type A A A A A A

Particulate Collected, gms.

(- blank) 0.775 0.707 0.390 0.500 0.0442 0.0420

Particulate Output: g

Concentration, grains/s.c.f. 0.0399 0.0320 0.0510 0.0654 0.00397 0.00377

Mass Loading, pounds/hour 8.5 7.7 4.2 5.6 0.058 0.057

Part VI

Test No.

1

2

3

4

5

6

Stack Data:Temperature Points

8

8

8

8

8

8

Diameter, ins.

24

24

24

24

12

12

Area, sq. ft.

3.142

3.142

3.142

3.142

0.7854

0.7854

Temperature °F

74

74

74

74

70

70

" °R

534

534

534

534

530

530

Absolute Pressure, in. Hg

29.42

29.42

29.42

29.42

29.40

29.40

Gas Density ($\Delta = 1$)

.99

.99

.99

.99

.99

.99

Volumetric Flow Rate, c.f.m.

11,285

11,285

9,857

9,857

1,786

1,706

Stack conditions
Standard conditions

11,013

11,013

9,620

9,620

1,755

1,755

Sampler Data:

Temperature °F

74

74

74

74

70

70

" °R

534

534

534

534

530

530

Orifice ΔP Avg, in. Hg

- .01

- .01

- .01

- .01

- .06

- .06

Total Sample Time, min.

8

8

8

8

4

4

Average Sample Rate, c.f.m.

17.0

17.0

15.1

15.1

43.9

43.8

Sample Volume, c.f.

136

136

121

121

175

175

Sampler Conditions
Standard Conditions

133

133

113

118

172

172

Report No. 26-6-171

Part VII

Job: Pillsbury, Curran, Ill. Date: 6/23/22 Test No: 1, 2Location: Upper Primary Cyclone Exhaust

Point No.	Duct Data					Sampler Data					Time		Time	
	T _c °F	AM H ₂ O"	Vel. F.P.S	Vel. F.P.M		T _M °F	AP H ₂ O"	Time sec.	Vol. c.f.		start	stop		
1	74	.76	58.7	3522		74	.10	60	17.0		1:39PM	1:40	2:01P	2:02
2	74	.80	60.2	3612		74	.10	60	16.8		1:40	1:41	2:02	2:03
3	74	.85	62.1	3726		74	.11	60	17.8		1:41	1:42	2:03	2:04
4	74	.74	57.9	3474		74	.10	60	17.0		1:42	1:43	2:04	2:05
5	74	.70	56.4	3384		74	.09	60	16.2		1:47	1:48	2:08	2:09
6	74	.80	60.0	3600		74	.10	60	16.8		1:48	1:49	2:09	2:10
7	74	.84	61.7	3702		74	.11	60	17.8		1:49	1:50	2:10	2:11
8	74	.72	57.2	3432		74	.09	60	16.2		1:50	1:51	2:11	2:12
Σ								480						
$\bar{x}$	74			3556		74			17.0					

Duct Dimensions: 24" I.D. Duct Area, sq. ft.: 3.142 Duct Static Press: .01" H₂OAmbient Conditions: Temp: 73°F Barometric Pressure: 29.41 Relative Humidity: 80-85Gas Composition: CO₂% = 0 ; O₂% = 21 ; CO% = 0 ; N₂% = 79 ; _____ ; _____Gas Moisture, % = 2 Gas Density: 0.992Collection ORIFICE: 0.9375" I.D.Comments: P_g = 29.42 T_g = 534 P_a = 29.40 T_a = 534

Part VII

Job: Pillsbury, Curran, Ill. Date: 6/23/72 Test No: 3, 4Location: Lower Primary Cyclone Exhaust

Point No.	Duct Data					Sampler Data					Test (3) Time		Test (4) Time	
	T _G °F	ΔH H ₂ O"	Vel. F.P.S	Vel. F.P.M		T _M °F	AP H ₂ O"	Time sec.	Vol. c.f.		Start	Stop		
1	74	.52	47.9	287		74	.06	60	14.0		2:35P	2:36	2:52	2:
2	74	.62	52.8	316.8		74	.08	60	15.5		2:36	2:37	2:53	2:
3	74	.66	54.4	326.4		74	.09	60	16.0		2:37	2:38	2:54	2:
4	74	.60	52.0	312.0		74	.08	60	15.0		2:38	2:39	2:55	2:
5	74	.55	49.7	298.2		74	.07	60	14.5		2:41	2:42	3:02	3:
6	74	.62	52.8	316.8		74	.08	60	15.5		2:42	2:43	3:03	3:
7	74	.68	55.2	331.8		74	.09	60	16.0		2:43	2:44	3:04	3:
8	74	.54	49.3	295.8		74	.07	60	14.5		2:44	2:45	3:05	3:
Σ								480						
$\bar{X}$	74			310.6		74			15.1					

Duct Dimensions: 24" I.D. Duct Area, sq.ft.: 3.142 Duct Static Press: 4.0Ambient Conditions: Temp: 73°F Barometric Pressure: 29.41 Relative Humidity: 80-75Gas Composition: CO₂% = 0 ; O₂% = 21 ; CO% = 0 ; N₂% = 79 ; _____ ; _____Gas Moisture, % = 2% Gas Density: 0.992Collection ORIFICE: 0.9375" I.D.Comments: P₀ = 29.42 T₀ = 534 P₁ = 29.40 T₁ = 534

Part VII

Job: Pillsbury, Curran, Ill. Date: 4/23/72 Test No: 5, 6Location: Small cyclone Exhaust (car loading)

Test ⑤

Test ⑥

Point No.	Dust Data				Sampler Data				Time		Time	
	T_c °F	ΔH H ₂ O	Vel. FPS	Vel. FPM	TM °F	AP mic	Time sec	V.I. %	Start	Stop		
L 1	70	0.30	36.6	2196	70	.75	30	43	4:00.0	4:00.5	4:10.5	4:11
L 2	70	0.32	40.6	2436	70	.86	30	46	4:00.5	4:01.0	4:11.0	4:11.5
L 3	70	0.32	37.8	2262	70	.78	30	44	4:01.0	4:01.5	4:11.5	4:12
L 4	70	0.28	35.3	2118	70	.68	30	41	4:01.5	4:02.0	4:12.0	4:12
R 5	70	0.30	36.6	2196	70	.75	30	43	4:03.5	4:04.0	4:15.0	4:15
R 6	70	0.28	41.2	2472	70	.95	30	48	4:04.0	4:04.5	4:15.5	4:16
R 7	70	0.38	41.2	2472	70	.95	30	48	4:04.5	4:05.0	4:16.0	4:16
R 8	70	0.21	31.3	1878	70	.60	30	37	4:05.0	4:05.5	4:16.5	4:17
Σ							240					
$\bar{X}$	70			2254	70			43.8				

Duct Dimensions: 12" I.D.Duct Area, sq. ft.: 0.7854Duct Static Press.: 4.04Ambient Conditions: Temp: 73Barometer Pressure: 29.40Relative Humidity: 75Gas Composition: CO₂% = 0 ; O₂% = 21 ; CO% = 0 ; N₂% = 79 ; _____ ; _____Gas Moisture, % = 2%Gas Density: 0.992Collection ORIFICE: 1.875" I.D.Comments: P₀ = 29.40 T₀ = 530 P₁ = 29.37 T₁ = 530

Part VIII

Calculations IWeather Data (at test site)

6-23-72

<u>Time</u>	<u>Temperature</u>	<u>Barometric Pressure</u>	<u>Relative Humidity</u>
10:00 AM	74	29.43	70
11:00 AM	74	29.42	70
12:00 PM	74	29.41	75 (74.69)
1:00 PM	73	29.41	80
2:00 PM	73	29.41	80
3:00 PM	73	29.41	75
4:00 PM	73	29.40	75

from Dwyer Calculator

Velocity Correction Factor for RH=75% = .991

Velocity correction factor for 32" CH = $\frac{2260}{2250} = .996 \approx 0.99$ Air Density (A-1) = .0729 #/ft³ [@ 70°F = 0.0808]

$$\% H_2O = \frac{\frac{.8462 \times 15\%}{29.4} \times 50}{2.16\%}$$

$$H_2O = .022 \times 18 = .40$$

$$Air = .978 \times 28.95 = 28.31$$

$$.992 = \frac{28.71}{28.95}$$

$$V_c = \sqrt{\frac{29.7}{29.42} \times \frac{1}{.992}} = \sqrt{1.024} = 1.013$$

Part VIII

Calculations III Velocity Correction Factor (Average).

$$V_c = \sqrt{\frac{29.92}{29.91} \times \frac{1}{.992}} = \sqrt{1.02} = 1.01$$

II Volumetric Flow Rates

c.f.m. s.c.f.m.

$$\text{Test No 1 \& 2} = 1.01 \times 3556 \times 3.142 = 11,285 \times \frac{29.92}{29.91} \times \frac{530}{534} = 11,013$$

$$\text{Test No 3 \& 4} = 1.01 \times 3106 \times 3.142 = 9,857 \times \frac{29.92}{29.91} \times \frac{530}{534} = 9,620$$

$$\text{Test No 5 \& 6} = 1.01 \times 2254 \times 3.142 = 1,786 \times \frac{29.92}{29.91} \times \frac{530}{534} = 1,755$$

III Sample Volumes Converted to Std. Cond. (70°F & 29.92" Hg.)

$$\text{Test No 1 \& 2} \quad 8 \times 17.0 = 136 \times \frac{29.92}{29.91} \times \frac{530}{534} = 133 \text{ s.c.f.}$$

$$\text{Test No 3 \& 4} \quad 8 \times 15.1 = 121 \times \frac{29.92}{29.91} \times \frac{530}{534} = 118$$

$$\text{Test No 5 \& 6} \quad 4 \times 43.8 = 175 \times \frac{29.92}{29.91} \times \frac{530}{534} = 172$$

IV Particulate Concentration & Mass Emission Rate. (Std. Cond.)

$$\text{Test No 1} \quad \frac{(.979 - .004) \times 15.43}{133} = .0899 \times \frac{11,013}{7,000} \times 60 = 8.5$$

$$\text{Test No 2} \quad \frac{(.711 - .004) \times 15.43}{133} = .0820 \times \frac{11,013}{7,000} \times 60 = 7.7$$

$$\text{Test No 3} \quad \frac{(.993 - .003) \times 15.43}{118} = .0510 \times \frac{9,620}{7,000} \times 60 = 4.2$$

$$\text{Test No 4} \quad \frac{(.503 - .003) \times 15.43}{118} = .0654 \times \frac{9,620}{7,000} \times 60 = 5.4$$

$$\text{Test No 5} \quad \frac{(.0486 - .0044) \times 15.43}{172} = .00397 \times \frac{1,755}{7,000} \times 60 = 0.058$$

$$\text{Test No 6} \quad \frac{(.0464 - .0044) \times 15.43}{172} = .00377 \times \frac{1,755}{7,000} \times 60 = 0.057$$