

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section Number: 9.9.1

Reference Number: 27

**Title: Source Test Report on Measurement
Of Emissions From Cargil, Inc.**


Environmental Engineering, Inc.

1972

AP-42 Section 9.9.1
Reference 27
Report Sect. _____
Reference _____

FINAL
OK

72-CI-28 (GRN)
SOURCE TEST REPORT
ON MEASUREMENT OF EMISSIONS FROM
CARGILL, INC.
SIOUX CITY, IOWA
FOR
ENVIRONMENTAL PROTECTION AGENCY
UNITED STATES GOVERNMENT
THOMAS E. WARD
PROJECT TEST OFFICER



environmental engineering, inc.


2324 S. W. 34th STREET / GAINESVILLE, FLORIDA 32601 / PHONE 904 / 372-3318

16417

FINAL

OK

72-CI-28 (GRN)
SOURCE TEST REPORT
ON MEASUREMENT OF EMISSIONS FROM
CARGILL, INC.
SIOUX CITY, IOWA
FOR
ENVIRONMENTAL PROTECTION AGENCY
UNITED STATES GOVERNMENT
THOMAS E. WARD
PROJECT TEST OFFICER



environmental engineering, inc.

2324 S. W. 34th STREET / GAINESVILLE, FLORIDA 32601 / PHONE 904 / 372-3318

10467

TABLE OF CONTENTS

	<u>Page No.</u>
Introduction	1
Summary of Results	2
Location of Sampling Points	8
Sampling and Analytical Procedures	16
Appendices	
A. Particulate Emission Calculations	
B. Plant Operating Data	
C. Field Data Sheets	
D. Complete Sampling Procedures	
E. Field Test Log	
F. Project Participants	

INTRODUCTION

Particulate emission tests were performed on three separate sources located at the Cargill, Inc. Feed and Grain Mill in Sioux City, Iowa. The testing was performed during the week of June 19, 1972.

The sources tested were the Hammer Mill, the Column Cooler inlet and outlet, and the Pan Cooler inlet and outlet.

All three sources were controlled by cyclonic dry dust collectors. Three, two-hour tests were performed on each of the five points.

SUMMARY OF RESULTS

Summarized results of the particulate emission stack tests performed at Cargill, Inc. are included in Tables 1-5.

The Environmental Protection Agency (EPA) performed the analyses.

Complete particulate emission calculation data are included in Appendix A.

Complete plant operating data collected by the EPA are included in Appendix B.

SOURCE TEST DATA

TABLE 1

TEST NO - EPA 72-CI-28 (GRN) NO OF RUNS - 3
 PLANT - CARGILL SIOUX CITY, IOWA
 SOURCE - HAMMERMILL OUTLET
 TYPE OF PLANT - FEED AND GRAIN MILL
 CONTROL EQUIPMENT - DRY CYCLONIC DUST COLLECTOR
 POLLUTANTS SAMPLED - PARTICULATES

1) RUN NUMBER	1	2	3
2) DATE	5/20/72	6/21/72	6/21/72
3) TIME BEGAN	20:30	9:55	12:10
4) TIME END	23:02.5	11:45	13:50
5) BAROMETRIC PRESSURE, IN HG	29.6	29.78	28.78
6) METER ORIFICE PRESSURE DROP, IN HG	1.4	1.67	1.44
7) VOL DRY GAS METER COND, CUBIC FEET	58.645	65.517	51.093
8) AVERAGE GAS METER TEMPERATURE, DEG F	66.8	62.2	72.8
9) VOL DRY GAS, S.T.P., CUBIC FEET	56.605	64.235	49.066
10) TOTAL H2O COLLECTED, ML	28	32	25
11) VOL H2O VAPOR COLLECTED, S.T.P., CU FT	NA	NA	NA
12) STACK GAS MOISTURE, PERCENT VOLUME	2.3	2.3	2.4
13) ASSUMED STACK GAS MOISTURE, PCT VOL	2.3	2.3	2.3
14) PERCENT CO2	--	--	--
15) PERCENT O2	--	--	--
16) PERCENT CO	--	--	--
17) PERCENT N2	--	--	--
18) PERCENT EXCESS AIR, STACK GAS WAS AIR	NA	NA	NA
19) MOLECULAR WEIGHT OF STACK GAS, DRY	28.85	28.85	28.85
20) MOLECULAR WEIGHT OF STACK GAS, STK COND	28.6	28.6	28.59
21) STACK GAS SPECIFIC GRAVITY	0.99	0.99	0.99
22) AVG SQUARE ROOT (VEL HEAD), IN H2O	0.25	0.276	0.262
23) AVERAGE STACK GAS TEMPERATURE, DEG F	85.3	85.2	89.1
24) AVG SQUARE ROOT (STK TEMP*VEL HEAD)	5.842	6.45	6.138
25) PITOT CORRECTION FACTOR	0.83	0.83	0.83
26) STACK PRESSURE, IN HG, ABSOLUTE	28.6	28.78	28.78
27) STACK GAS VEL, STACK COND, F.P.M.	868.8	956.3	910
28) STACK AREA, SQ FEET	4.28	4.28	4.28
29) EFFECTIVE STACK AREA, SQUARE FEET	3.38	3.38	2.76
30) STACK GAS FLOW RATE, S.T.P., SCFMD	2669	2956	2277
31) NET TIME OF TEST, MINUTES	95	95.0	77
32) SAMPLING NOZZLE DIAMETER, INCHES	0.375	0.375	0.375
33) PERCENT ISOKINETIC	98.5	100.9	100.0
34) PARTICULATE EMISSIONS @ S.T.P., lb/hr			
FRONT HALF	0.06	0.07	0.05
BACK HALF	0.02	0.03	0.03
TOTALS	0.08	0.10	0.09

S.T.P. → DRY, 70 DEGREES F, 29.92 INCHES MERCURY

*Based upon wet and dry bulb thermometry

SOURCE TEST DATA

TABLE 2

TEST NO - EPA 72-CI-28 (GRN) NO OF RUNS - 3
 PLANT - CARGILL SIOUX CITY, IOWA
 SOURCE - COLUMN COOLER INLET
 TYPE OF PLANT - FEED AND GRAIN MILL
 CONTROL EQUIPMENT - DRY CYCLONIC DUST COLLECTOR
 POLLUTANTS SAMPLED - PARTICULATES

1) RUN NUMBER	1	2	3
2) DATE	6/22/72	6/23/72	6/23/72
3) TIME BEGAN	17:25	07:50	11:00
4) TIME END	19:51	10:00	14:20
5) BAROMETRIC PRESSURE, IN HG	28.91	28.8	28.8
6) METER ORIFICE PRESSURE DROP, IN HG	0.4	0.41	0.4
7) VOL DRY GAS METER COND, CUBIC FEET	46.511	45.928	46.112
8) AVERAGE GAS METER TEMPERATURE, DEG F	89.4	72.4	76
9) VOL DRY GAS, S.T.P., CUBIC FEET	43.4	44.054	43.935
10) TOTAL H2O COLLECTED, ML	35	35	35
11) VOL H2O VAPOR COLLECTED, S.T.P., CU FT	NA	NA	NA
12) STACK GAS MOISTURE, PERCENT VOLUME *	3.7	3.6	3.6
13) ASSUMED STACK GAS MOISTURE, PCT VOL	3.5	3.5	3.5
14) PERCENT CO2	--	--	--
15) PERCENT O2	--	--	--
16) PERCENT CO	--	--	--
17) PERCENT H2	--	--	--
18) PERCENT EXCESS AIR, STACK GAS WAS AIR	NA	NA	NA
19) MOLECULAR WEIGHT OF STACK GAS, DRY	28.85	28.85	28.85
20) MOLECULAR WEIGHT OF STACK GAS, STK COND	28.45	28.46	28.46
21) STACK GAS SPECIFIC GRAVITY	0.98	0.98	0.98
22) AVG SQUARE ROOT (VEL HEAD), IN H2O	1.307	1.329	1.308
23) AVERAGE STACK GAS TEMPERATURE, DEG F	111.5	113.9	117
24) AVG SQUARE ROOT (STK TEMP*VEL HEAD)	31.251	31.847	31.414
25) PITOT CORRECTION FACTOR	0.83	0.83	0.83
26) STACK PRESSURE, IN HG, ABSOLUTE	29.2	29	29
27) STACK GAS VEL, STACK COND, F.P.M.	4611.6	4715.3	4651.3
28) STACK AREA, SQ FEET	1.55	1.55	1.55
29) EFFECTIVE STACK AREA, SQUARE FEET	1.55	1.55	1.55
30) STACK GAS FLOW RATE, S.T.P., SCFMD	6244	6305	6183
31) NET TIME OF TEST, MINUTES	120	120	120
32) SAMPLING NOZZLE DIAMETER, INCHES	0.125	0.125	0.125
33) PERCENT ISOKINETIC	105.6	105.9	107.7
34) PARTICULATE EMISSIONS @ S.T.P., lb/hr			
FRONT HALF	320.41	383.62	210.90
BACK HALF	0.14	0.15	0.08
TOTALS	320.54	383.77	210.98


S.T.P.→ DRY, 70 DEGREES F, 29.92 INCHES MERCURY

*Based upon wet and dry bulb thermometry

SOURCE TEST DATA
TABLE 3

TEST NO - EPA 72-CI-28 (GRN) NO OF RUNS - 3
PLANT - CARGILL SIOUX CITY, IOWA
SOURCE - COLUMN COOLER OUTLET
TYPE OF PLANT - FEED AND GRAIN MILL
CONTROL EQUIPMENT - DRY CYCLONIC DUST COLLECTOR
POLLUTANTS SAMPLED - PARTICULATES

1) RUN NUMBER	1	2	3
2) DATE	6/22/72	6/23/72	6/23/72
3) TIME BEGAN	17:20	07:50	11:11
4) TIME END	19:45	09:45	14:06
5) BAROMETRIC PRESSURE, IN HG	28.9	28.8	28.8
6) METER ORIFICE PRESSURE DROP, IN HG	1.65	1.35	1.87
7) VOL DRY GAS METER COND, CUBIC FEET	82.758	70.484	86.51
8) AVERAGE GAS METER TEMPERATURE, DEG F	79.1	68.7	86.1
9) VOL DRY GAS, S.T.P., CUBIC FEET	78.914	68.247	81.199
10) TOTAL H2O COLLECTED, ML	59	55	63
11) VOL H2O VAPOR COLLECTED, S.T.P., CU FT	NA	NA	NA
12) STACK GAS MOISTURE, PERCENT VOLUME *	3.4	3.7	3.5
13) ASSUMED STACK GAS MOISTURE, PCT VOL	3.3	3.3	3.3
14) PERCENT CO2	--	--	--
15) PERCENT O2	--	--	--
16) PERCENT CO	--	--	--
17) PERCENT H2	--	--	--
18) PERCENT EXCESS AIR, STACK GAS WAS AIR	NA	NA	NA
19) MOLECULAR WEIGHT OF STACK GAS, DRY	28.85	28.85	28.85
20) MOLECULAR WEIGHT OF STACK GAS, STK COND	28.48	28.45	28.47
21) STACK GAS SPECIFIC GRAVITY	0.98	0.98	0.98
22) AVG SQUARE ROOT (VEL HEAD), IN H2O	0.674	0.604	0.71
23) AVERAGE STACK GAS TEMPERATURE, DEG F	104.6	108.5	110.7
24) AVG SQUARE ROOT (STK TEMP*VEL HEAD)	16.009	14.396	17.012
25) PITOT CORRECTION FACTOR	0.83	0.83	0.83
26) STACK PRESSURE, IN HG, ABSOLUTE	28.9	28.8	28.8
27) STACK GAS VEL, STACK COND, F.P.M.	2373.4	2139.1	2527.2
28) STACK AREA, SQ FEET	4.75	4.75	4.75
29) EFFECTIVE STACK AREA, SQUARE FEET	4.35	4.35	4.35
30) STACK GAS FLOW RATE, S.T.P., SCFMD	9039	8041	9410
31) NET TIME OF TEST, MINUTES	110	110	110
32) SAMPLING NOZZLE DIAMETER, INCHES	0.25	0.25	0.25
33) PERCENT ISOKINETIC	101.2	98.4	100.1
34) PARTICULATE EMISSIONS @ S.T.P., lb/hr			
FRONT HALF	0.23	0.35	0.22
BACK HALF	0.14	0.29	0.17
TOTALS	0.37	0.63	0.38



S.T.P. ↔ DRY, 70 DEGREES F, 29.92 INCHES MERCURY

*Based upon wet and dry bulb thermometry

SOURCE TEST DATA

TABLE 4

TEST NO - EPA 72-CI-28 (GRN) NO OF RUNS - 3
 PLANT - CARGILL SIOUX CITY, IOWA
 SOURCE - PAN COOLER INLET
 TYPE OF PLANT - FEED AND GRAIN MILL
 CONTROL EQUIPMENT - DRY CYCLONIC DUST COLLECTOR
 POLLUTANTS SAMPLED - PARTICULATES

	1	2	3
1) RUN NUMBER	1	2	3
2) DATE	6/21/72	6/22/72	6/22/72
3) TIME BEGAN	6:50	8:45	12:30
4) TIME END	9:10	11:05	14:35
5) BAROMETRIC PRESSURE, IN HG	28.78	28.9	28.91
6) METER ORIFICE PRESSURE DROP, IN HG	3.04	4.57	4.32
7) VOL DRY GAS METER COND, CUBIC FEET	118.191	144.601	142.783
8) AVERAGE GAS METER TEMPERATURE, DEG F	71.1	69.6	75.9
9) VOL DRY GAS, S.T.P., CUBIC FEET	114.332	141.484	137.955
10) TOTAL H2O COLLECTED, ML	66	82	80
11) VOL H2O VAPOR COLLECTED, S.T.P., CU FT	NA	NA	NA
12) STACK GAS MOISTURE, PERCENT VOLUME *	2.7	2.7	2.7
13) ASSUMED STACK GAS MOISTURE, PCT VOL	2.6	2.6	2.6
14) PERCENT CO2	--	--	--
15) PERCENT O2	--	--	--
16) PERCENT CO	--	--	--
17) PERCENT H2	--	--	--
18) PERCENT EXCESS AIR, STACK GAS WAS AIR	NA	NA	NA
19) MOLECULAR WEIGHT OF STACK GAS, DRY	28.85	28.85	28.85
20) MOLECULAR WEIGHT OF STACK GAS, STK COND	28.56	28.56	28.56
21) STACK GAS SPECIFIC GRAVITY	0.99	0.99	0.99
22) AVG SQUARE ROOT (VEL HEAD), IN H2O	0.905	1.095	1.066
23) AVERAGE STACK GAS TEMPERATURE, DEG F	95.9	90	99.3
24) AVG SQUARE ROOT (STK TEMP*VEL HEAD)	21.335	25.675	25.202
25) PITOT CORRECTION FACTOR	0.83	0.83	0.83
26) STACK PRESSURE, IN HG, ABSOLUTE	29	29.1	29.1
27) STACK GAS VEL, STACK COND, F.P.M.	3153.1	3788.1	3718.3
28) STACK AREA, SQ FEET	3.69	3.69	3.69
29) EFFECTIVE STACK AREA, SQUARE FEET	3.69	3.69	3.69
30) STACK GAS FLOW RATE, S.T.P., SCFH	10457	12750	12306
31) NET TIME OF TEST, MINUTES	120	120	120
32) SAMPLING NOZZLE DIAMETER, INCHES	0.25	0.25	0.25
33) PERCENT ISOKINETIC	98.5	100.1	101.1
34) PARTICULATE EMISSIONS @ S.T.P., lb/hr			
FRONT HALF	133.65	248.44	242.35
BACK HALF	0.05	0.08	0.11
TOTALS	133.69	248.52	242.47

S.T.P. → DRY, 70 DEGREES F, 29.92 INCHES MERCURY

*Based upon wet and dry bulb thermometry

SOURCE TEST DATA
TABLE 5

TEST NO - EPA 72-CI-28 (GRN) NO OF RUNS - 3
PLANT - CARGILL SIOUX CITY, IOWA
SOURCE - PAN COOLER OUTLET
TYPE OF PLANT - FEED AND GRAIN MILL
CONTROL EQUIPMENT - DRY CYCLONIC COLLECTOR
POLLUTANTS SAMPLED - PARTICULATES

1) RUN NUMBER	1	2	3
2) DATE	6/21/72	6/22/72	6/23/72
3) TIME BEGAN	18:50	8:15	12:32
4) TIME END	21:11	11:05	14:40
5) BAROMETRIC PRESSURE, IN HG	28.78	28.91	28.91
6) METER ORIFICE PRESSURE DROP, IN HG	0.73	1.15	1.17
7) VOL DRY GAS METER COND, CUBIC FEET	62.065	77.225	78.785
8) AVERAGE GAS METER TEMPERATURE, DEG F	78.6	73.7	83.5
9) VOL DRY GAS, S.T.P., CUBIC FEET	58.859	74.322	74.454
10) TOTAL H2O COLLECTED, ML	26	33	34
11) VOL H2O VAPOR COLLECTED, S.T.P., CU FT	NA	NA	NA
12) STACK GAS MOISTURE, PERCENT VOLUME*	2.1	2.1	2.1
13) ASSUMED STACK GAS MOISTURE, PCT VOL	2	2	2
14) PERCENT CO2	--	--	--
15) PERCENT O2	--	--	--
16) PERCENT CO	--	--	--
17) PERCENT N2	--	--	--
18) PERCENT EXCESS AIR, STACK GAS WAS AIR	NA	NA	NA
19) MOLECULAR WEIGHT OF STACK GAS, DRY	28.85	28.85	28.85
20) MOLECULAR WEIGHT OF STACK GAS, STK COND	28.63	28.63	28.62
21) STACK GAS SPECIFIC GRAVITY	0.99	0.99	0.99
22) AVG SQUARE ROOT (VEL HEAD), IN H2O	0.447	0.545	0.552
23) AVERAGE STACK GAS TEMPERATURE, DEG F	88.7	89.1	97.2
24) AVG SQUARE ROOT (STK TEMP*VEL HEAD)	10.469	12.769	13.029
25) PITOT CORRECTION FACTOR	0.83	0.83	0.83
26) STACK PRESSURE, IN HG, ABSOLUTE	28.78	28.91	28.91
27) STACK GAS VEL, STACK COND, F.P.M.	1551.4	1887.9	1926.5
28) STACK AREA, SQ FEET	9.51	9.51	9.51
29) EFFECTIVE STACK AREA, SQUARE FEET	9.51	9.51	9.51
30) STACK GAS FLOW RATE, S.T.P., SCFMD	13421	16393	16477
31) NET TIME OF TEST, MINUTES	117.5	120	120
32) SAMPLING NOZZLE DIAMETER, INCHES	0.25	0.25	0.25
33) PERCENT ISOKINETIC	104.1	105.4	105
34) PARTICULATE EMISSIONS @ S.T.P., lb/hr			
FRONT HALF	15.07	21.86	9.32
BACK HALF	0.29	1.01	0.40
TOTALS	15.36	22.87	9.72

S.T.P. -> DRY, 70 DEGREES F, 29.92 INCHES MERCURY

*Based upon wet and dry bulb thermometry

LOCATION OF SAMPLING POINTS

Sampling ports and points were selected by using the guidelines stated in Method 1 of the Federal Register (36. F. R. 24882, 24883, December 23, 1971).

Figures 1-8 are diagrams of the sources sampled.

Table 6 is the location of sampling points for each source.




Figure 1. Top View of Roof at 4th Floor Level




Figure 2. Hammer Mill System




Figure 3. Pan Cooler System




Figure 4. Column Cooler System




Figure 5. Hammer Mill Exhaust




Figure 6. Pan Cooler Inlet




Figure 7. Column Cooler Exhaust (Side View)




Figure 8. Pan Cooler Exhaust (Side View)

TABLE 6
Location of Sampling Points

Points Source		Distance From Inside Stack Wall																							
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Hammer Mill		1 1/2	1 1/2	1 1/2	2 7/32	2 15/16	3 11/16	4 1/2	5 11/32	6 7/16	7 19/32	9 1/16	11 1/8	16 7/8	19	20 13/32	21 19/32	22 19/32	23 1/2	24 11/32	25	25 13/16	26 7/16	26 7/16	26 7/16
Column Cooler (inlet)		1	2 1/2	5	11 7/8	14 3/8	15 7/8																		
Column Cooler (Outlet)		5 15/8	15 1/8	5 1/8	2 21/64	3 3/32	3 29/32	4 3/4	5 23/32	6 25/32	8 1/32	9 17/32	11 3/4	17 3/4	19 31/32	21 15/32	22 23/32	23 25/32	24 3/4	25 39/64	26 13/32	27 11/64	27 7/8	27 7/8	27 7/8
Pan Cooler-- (inlet)		5 1/32	3 13/16	11 7/16	18 15/16	22 3/16	24 27/32																		
Pan Cooler (Outlet)		5 1/16	5 1/16	2 19/64	3 19/64	4 3/8	5 1/2	6 3/4	8 3/32	9 39/64	11 23/64	13 1/2	16 39/64	25 1/8	28 1/4	30 25/64	32 9/64	33 21/32	35	36 15/64	37 3/8	38 29/64	39 29/64	40 13/32	40 13/32

SAMPLING AND ANALYTICAL PROCEDURES FOR
PARTICULATE EMISSIONS FROM STATIONARY SOURCES

The method used was Method 5 of the Federal Register (36 F.R., March 31, 1971), Determination of Particulate Emissions From Stationary Sources.

The complete description of the sampling method used is in Appendix D.

The EPA performed the sample analyses.

July 1972

72-CI-28 (GRN)
SOURCE TEST REPORT
ON MEASUREMENT OF EMISSIONS FROM
CARGILL, INC.
SIOUX CITY, IOWA
FOR
ENVIRONMENTAL PROTECTION AGENCY
UNITED STATES GOVERNMENT
THOMAS E. WARD
PROJECT TEST OFFICER

SOURCE TEST REPORT

PLANT TESTED: Cargill, Inc.
Sioux City, Iowa

TESTOR: Environmental Engineering, Inc.
2324 Southwest 34 Street
Gainesville, Florida 32601

CONTRACT NO: 68-02-0232-Task Order 9

TABLE OF CONTENTS

	<u>Page No.</u>
Introduction	1
Summary of Results	2
Location of Sampling Points	8
Sampling and Analytical Procedures	16
Appendices	
A. Particulate Emission Calculations	
B. Plant Operating Data	
C. Field Data Sheets	
D. Complete Sampling Procedures	
E. Field Test Log	
F. Project Participants	

INTRODUCTION

Particulate emission tests were performed on three separate sources located at the Cargill, Inc. Feed and Grain Mill in Sioux City, Iowa. The testing was performed during the week of June 19, 1972.

The sources tested were the Hammer Mill, the Column Cooler inlet and outlet, and the Pan Cooler inlet and outlet.

All three sources were controlled by cyclonic dry dust collectors. Three, two-hour tests were performed on each of the five points.

APPENDIX A

Particulate Emission Calculations

E.E.I. SOURCE SAMPLING NOMENCLATURE SHEET

PB - Barometric pressure, inches Hg
 PS - Stack pressure, inches Hg
 As - Stack area, sq. ft.
 AS' - Effective area of positive stack gas flow, sq. ft.
 NPTS - Number of traverse points where the pitot velocity head was greater than zero
 TS - Stack temperature, °R
 TM - Meter temperature, °R
 H - Average square root of velocity head, $\sqrt{\text{inches H}_2\text{O}}$
 ΔH - Average meter orifice pressure differential, inches H₂O
 AN - Sampling nozzle area, square feet
 CP - S-type pitot tube correction factor
 VM - Recorded meter volume sample, cubic feet (meter conditions)
 VC - Condensate and silica gel increase in impringers, milliliters
 Po - Pressure at the dry test meter orifice, $\left[\text{PB} + \frac{\Delta H}{13.6} \right]$ inches Hg
 STP - Standard conditions, dry, 70°F, 29.92 inches Hg

VWV - Conversion of condensate in milliliters to water vapor in cubic feet (STP)
 VSTPD - Volume sampled, cubic feet (STP)
 VT - Total water vapor volume and dry gas volume sampled, cubic feet (STP)
 W - Moisture fraction of stack gas
 FDA - Dry gas fraction
 MD - Molecular weight of stack gas, lbs/lb-mole (dry conditions)
 MS - Molecular weight of stack gas, lbs/lb-mole (stack conditions)
 GS - Specific gravity of stack gas, referred to air
 EA - Excess air, %
 $\sqrt{H \times TS}$ - Average square root of velocity head times stack temperature
 U - Stack gas velocity, feet per minute
 QS - Stack gas flow rate, cubic feet per minute (stack conditions)
 QD - Stack gas flow rate, cubic feet per minute (dry conditions)
 QSTPD - Stack gas flow rate, cubic feet per minute (STP)
 PISO - Percent isokinetic volume sampled (method described in Federal Register)
 Y - Particulate Lab Analysis, grams
 ESTP - Particulate Concentration, grains per standard cubic feet
 EM - Particulate Emission Rate, pounds per hour

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CAPGILL SIOUX CITY, IOWA

DATE- 6/20/72

STACK- PAWERMILL OUTLET

RUN 1 FROM 20:30-23:02.5

WEATHER CONDITIONS- CLEAR AND COLD

PR- 38.6 IN. HG

PS- 28.6 IN. HG

AS'- 3.38 SQ. FEET TS- 545.3 DEGREES R

TM- 526.8 DEGREES R

H- 0.25 IN H2O

ΔH- 1.4 IN H2O

AN- 0.000767 SQ. FEET

CP- 0.83

VM- 58.645 CF

VC- 28 ML

TOTAL TIME- 95 MIN

NPTS- 38

ORSAT: AIR

1) VWV = (0.0474) × (VC)	1) NA	SCF
2) VSTPD = ((530) × (VM) × (PB + (ΔH ÷ 13.6))) ÷ (29.92 × TM)	2) 56.605	SCF
3) VT = (VWV) + (VSTPD)	3) NA	SCF
4) W = (VWV) ÷ (VT)	4) 0.023	
5) FDA = (1.0 - W)	5) 0.977	
6) ASSUMED MOISTURE FRACTION	6) 0.023	
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + H2))	7) 28.85	
8) MS = (MD × FDA) + (18 × W)	8) 28.6	
9) GS = (MS) ÷ (28.99)	9) 0.99	
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × H2) - (O2 - 0.5 × CO))	10) NA	%
11) AVG(√(H × TS)) = (1 ÷ H) × SUM(√(H × TS))	11) 5.842	
12) U = (174 × CP × (√(29.92 ÷ PS × GS)) × AVG(√(H × TS))	12) 868.8	FF
13) QS = (U) × (AS')	13) 2240	ACF
14) QD = (QS) × (FDA)	14) 2873	CEM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 2660	SCF
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	16) 98.5	%
17) ESTP = (15.43 × Y) + (VSTPD)	UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) + (%CO2)	UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150)	UNITS : GRAINS/SCF	
20) EM = (0.00857) × (ESTP) × (QSTPD)	UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)			PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
(Y)			(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	-	.0098	.0027				0.06
BACK HALF	-	.0038	.0010				0.02
TOTALS	-	.0136	.0037				0.08

COMMENTS : MOISTURE WAS DETERMINED BY DRY-BULB & WET BULB THERMOMETER

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

STACK- HAMMERMILL OUTLET

WEATHER CONDITIONS- CLEAR AND COLD

AS'- 3.38 SQ. FEET TS- 545.2 DEGREES R

ΔH- 1.67 IN H2O AN- 0.000767 SQ. FEET

TOTAL TIME- 95 MIN NPTS- 38 ORSAT: AIR

DATE- 6/21/72

RUN 2 FROM 9:55-11:45

PR- 28.78 IN HG

PS- 28.78 IN HG

H- 0.276 IN H2O

CP- 0.83

VH- 65.517 CF

VC- 32 ML

1) VWV = (0.0474) × (VC)	1) NA SCE
2) VSTPD = ((530) × (VM) × (PB + (ΔH ÷ 13.6))) ÷ (29.92 × TM)	2) 64.235 SCE
3) VT = (VWV) + (VSTPD)	3) NA SCE
4) W = (VWV) ÷ (VT)	4) 0.022
5) FDA = (1.0 - W)	5) 0.377
6) ASSUMED MOISTURE FRACTION	6) 0.023
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + N2))	7) 28.85
8) MS = (MD × FDA) + (18 × W)	8) 28.5
9) GS = (MS) ÷ (28.99)	9) 0.98
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × H2) - (O2 - 0.5 × CO))	10) NA %
11) AVG($\sqrt{(H \times TS)}$) = (1 ÷ H) × SUM($\sqrt{(H \times TS)}$)	11) 6.45
12) U = (174 × CP × ($\sqrt{(29.92 + PS \times GS)}$) × AVG($\sqrt{(H \times TS)}$)	12) 956.3 EE
13) QS = (U) × (AS')	13) 3236 ACE
14) QD = (QS) × (FDA)	14) 3161 CEM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 2956 SCE
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM × TM)) ÷ (TIME × U × PS × AN)	16) 100.9 %
17) ESTP = (15.43 × Y) ÷ (VSTPD)	UNITS : GRAINS/SCF
18) E12 = (12 × ESTP) ÷ (%CO2)	UNITS : GRAINS/SCF
19) E50 = (ESTP × (100 + EA)) ÷ (150)	UNITS : GRAINS/SCF
20) EH = (0.00857) × (ESTP) × (QSTPD)	UNITS : POUNDS/HOUR

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RAT	
(X)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	-	.0120	.0029			0.07
BACK HALF	-	.0045	.0011			0.03
TOTALS	-	.0165	.0040			0.10

COMMENTS : SEE RUN #1

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/21/72

STACK- HAMMERMILL OUTLET

RUN 3 FROM 12:10-13:50

WEATHER CONDITIONS- CLEAR AND COLD

PB- 28.78 IN HG

PS- 28.78 IN HG

AS'- 2.76 SQ. FEET TS- 549.1 DEGREES R

TM- 532.8 DEGREES R

H- 0.262 IN H2O

AH- 1.44 IN H2O AN- 0.000767 SQ. FEET

CP- 0.83

VM- 51.093 CF

VC- 25 ML

TOTAL TIME- 77.5 MIN NPTS- 31 ORSAT: AIR

1) VWV = (0.0474) * (VC)	1) <u>KA</u> <u>SCE</u>
2) VSTPD = ((530) * (VM) * (PB + (AH * 13.6))) / (29.92 * TM)	2) <u>42.056</u> <u>SCE</u>
3) VT = (VWV) + (VSTPD)	3) <u>KA</u> <u>SCE</u>
4) W = (VWV) / (VT)	4) <u>0.024</u>
5) FDA = (1.0 - W)	5) <u>0.976</u>
6) ASSUMED MOISTURE FRACTION	6) <u>0.023</u>
7) MD = (.44 * CO2) + (.32 * O2) + (.28 * (CO + H2))	7) <u>28.85</u>
8) MS = (MD * FDA) + (18 * W)	8) <u>28.59</u>
9) GS = (MS) / (28.99)	9) <u>0.99</u>
10) EA = (100) * (O2 - 0.5 * CO) / ((0.266 * H2) - (O2 - 0.5 * CO))	10) <u>21.4</u> <u>%</u>
11) AVG($\sqrt{(H * TS)}$) = (1/H) * SUM($\sqrt{(H * TS)}$)	11) <u>6.138</u>
12) U = (174 * CP * ($\sqrt{(29.92 * PS * GS)}$) * AVG($\sqrt{(H * TS)}$)	12) <u>910</u> <u>FE</u>
13) QS = (U) * (AS')	13) <u>2512</u> <u>ACE</u>
14) QD = (QS) * (FDA)	14) <u>2452</u> <u>CEM</u>
15) QSTPD = (QD) * (530 / TS) * (PS / 29.92)	15) <u>2277</u> <u>SCE</u>
16) PISO = ((0.00267 * VC * TS) + (Po * TS * VM * TM)) / (TIME * U * PS * AN)	16) <u>100.0</u> <u>%</u>
17) ESTP = (15.43 * Y) + (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 * ESTP) + (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP * (100 + EA)) / (150) UNITS : GRAINS/SCF	
20) EM = (0.00857) * (ESTP) * (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RAT	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- .0089	.0028				0.05
BACK HALF	- .0056	.0018				0.03
TOTALS	- .0145	.0046				0.09

COMMENTS : SEE RUN #1

TEST CONDUCTED BY : _____



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/22/72

STACK- COLUMN COOLER INLET

RUN 1 FROM 17:25-19:51

WEATHER CONDITIONS- CLEAR

PR- 28.91 IN HG

PS- 29.2 IN HG

AS'- 1.55 SQ. FEET TS- 571.5 DEGREES R TH- 549.4 DEGREES R H- 1.307 IN P20

ΔH- 0.4 IN H2O AH- 8.5E-5 SQ. FEET CP- 0.83 VM- 46.511 CF VC- 35 ML

TOTAL TIME- 120 MIN NPTS- 24 OPSAT: AIR

1) VWV = (0.0474) × (VC)	1) NA SCE
2) VSTPD = ((530) × (VM) × (PB + (ΔH ÷ 13.6))) ÷ (29.92 × TM)	2) 43.4 SCE
3) VT = (VWV) + (VSTPD)	3) NA SCE
4) W = (VWV) ÷ (VT)	4) 0.037
5) FDA = (1.0 - W)	5) 0.963
6) ASSUMED MOISTURE FRACTION	6) 0.035
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + N2))	7) 28.85
8) MS = (MD × FDA) + (18 × W)	8) 28.45
9) GS = (MS) ÷ (28.99)	9) 0.99
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × N2) - (O2 - 0.5 × CO))	10) N/A %
11) AVG($\sqrt{(H \times TS)}$) = (1 ÷ N) × SUM($\sqrt{(H \times TS)}$)	11) 31.251
12) U = (174 × CP × ($\sqrt{(29.92 \div PS \times GS)}$) × AVG($\sqrt{(H \times TS)}$)	12) 4611.6 EPP
13) QS = (U) × (AS')	13) 7163 ACE
14) QD = (QS) × (FDA)	14) 6899 CEM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 6244 SCE
16) PISO = ((0.00267 × VC × TS) + (Po × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	16) 105.6 %
17) ESTP = (15.43 × Y) ÷ (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) ÷ (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150) UNITS : GRAINS/SCF	
20) EM = (0.00857) × (ESTP) × (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS(GM)		PARTICULATE CONCENTRATIONS(GR/SCF)			EMISSION RAT	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- 16.8417	5.9877			320.41	
BACK HALF	- .0072	.0026			0.14	
TOTALS	- 16.8489	5.9903			320.54	

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/23/72

STACK- COLUMN COOLER INLET

RUN 2 FROM 07:50-10:00

WEATHER CONDITIONS- CLEAR

PR- 28.8 IN HG PS- 29 IN HG

AS'- 1.55 SQ. FEET TS- 573.9 DEGREES R TH- 532.4 DEGREES R H- 1.329 IN H2O

AH- 0.41 IN H2O AN- 8.5E-5 SQ. FEET CP- 0.83 VM- 45.928 CF VC- 35 MI.

TOTAL TIME- 120 MIN NPTS- 24 ORSAT: AIR

1) VWV = (0.0474) x (VC)	1) NA SCE
2) VSTPD = ((530) x (VM) x (PB + (AH + 13.6))) ÷ (29.92 x TH)	2) 44.054 SCE
3) VT = (VWV) + (VSTPD)	3) NA SCE
4) W = (VWV) ÷ (VT)	4) 0.036
5) FDA = (1.0 - W)	5) 0.964
6) ASSUMED MOISTURE FRACTION	6) 0.035
7) MD = (.44 x CO2) + (.32 x O2) + (.28 x (CO + N2))	7) 28.85
8) MS = (MD x FDA) + (18 x W)	8) 28.46
9) GS = (MS) ÷ (28.99)	9) 0.98
10) EA = (100) x (O2 - 0.5 x CO) ÷ ((0.266 x N2) - (O2 - 0.5 x CO))	10) 61.73 %
11) AVG($\sqrt{(H \times TS)}$) = (1 + H) x SUM($\sqrt{(H \times TS)}$)	11) 31.847
12) U = (174 x CP x ($\sqrt{(29.92 \div PS \times GS)}$) x AVG($\sqrt{(H \times TS)}$)	12) 4245.3 PP
13) QS = (U) x (AS')	13) 7309 ACE
14) QD = (QS) x (FDA)	14) 7044 CFM
15) QSTPD = (QD) x (530 ÷ TS) x (PS ÷ 29.92)	15) 6305 SCE
16) PISO = ((0.00267 x VC x TS) + (PO x TS x VM ÷ TH)) ÷ (TIME x U x PS x AN)	16) 105.9 %
17) ESTP = (15.43 x Y) ÷ (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 x ESTP) ÷ (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP x (100 + EA)) ÷ (150) UNITS : GRAINS/SCF	
20) EM = (0.00857) x (ESTP) x (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
(X)		(ESTP)	(E12)	(E50)	(EM)	(LBS/L)
FRONT HALF	- 20.2701	7.0996			383.62	
BACK HALF	- .0079	.0028			0.15	
TOTALS	- 20.2780	7.1023			383.77	

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

STACK- COLUMN COOLER INLET

WEATHER CONDITIONS- CLEAR

AS'- 1.55 SQ. FEET TS- 577 DEGREES R

ΔH- 0.4 IN H2O AN- 8.5E-5 SQ. FEET

TOTAL TIME- 120 MIN NPTS- 24 ORSAT: AIR

DATE- 6/23/72

RUN 3 FROM 11:00-14:20

PB- 28.8 IN HG

PS- 29 IN HG

U- 1.308 IN H2O

TM- 536 DEGREES R

CP- 0.83 VM- 46.112 CF

VC- 35 ML

1) VWV = (0.0474) × (VC)	1) NA SCE
2) VSTPD = ((530) × (VM) × (PB + (ΔH ÷ 13.6))) ÷ (29.92 × TM)	2) 43.235 SCE
3) VT = (VWV) + (VSTPD)	3) NA SCE
4) W = (VWV) ÷ (VT)	4) 0.036
5) FDA = (1.0 - W)	5) 0.964
6) ASSUMED MOISTURE FRACTION	6) 0.035
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + H2))	7) 28.85
8) MS = (MD × FDA) + (18 × W)	8) 28.46
9) GS = (MS) ÷ (28.99)	9) 0.92
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × H2) - (O2 - 0.5 × CO))	10) 61.74 %
11) AVG($\sqrt{H \times TS}$) = (1 ÷ N) × SUM($\sqrt{H \times TS}$)	11) 31.414
12) U = (174 × CP × ($\sqrt{(29.92 \times PS \times GS)}$) × AVG($\sqrt{H \times TS}$))	12) 4651.3 ECF
13) QS = (U) × (AS')	13) 7209 ACF
14) QD = (QS) × (FDA)	14) 6947 CEM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 6125 SCE
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	16) 107.7 %
17) ESTP = (15.43 × Y) ÷ (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) ÷ (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150) UNITS : GRAINS/SCF	
20) EH = (0.00857) × (ESTP) × (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)	PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
	(X)	(ESTP)	(E12)	(E50)	(EM) (LBS/H)
FRONT HALF	- 11.3295	3.9789			210.90
BACK HALF	- .0043	.0015			0.08
TOTALS	- 11.3338	3.9804			210.98

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

STACK- COLUMN COOLER OUTLET

WEATHER CONDITIONS- CLEAR

AS'- 4.35 SQ. FEET TS- 564.6 DEGREES R TM- 539.1 DEGREES R H- 0.674 IN H2O

ΔH- 1.65 IN H2O AH- 0.000341 SQ. FEET CP- 0.83 VM- 82.758 CF VC- 59 ML

TOTAL TIME- 110 MIN NPTS- 44 ORSAT: AIR

DATE- 6/22/72

RUN 1 FROM 17:20-19:45

PB- 28.9 IN HG

PS- 28.9 IN HG

VC- 59 ML

1) VWV = (0.0474) × (VC)	1) NA SCE
2) VSTPD = ((530) × (VM) × (PB + (ΔH ÷ 13.6))) ÷ (29.92 × TM)	2) 78.918 SCE
3) VT = (VWV) + (VSTPD)	3) NA SCE
4) W = (VWV) ÷ (VT)	4) 0.034
5) FDA = (1.0 - W)	5) 0.966
6) ASSUMED MOISTURE FRACTION	6) 0.033
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + H2))	7) 28.35
8) MS = (MD × FDA) + (18 × W)	8) 28.48
9) GS = (MS) ÷ (28.99)	9) 0.98
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × H2) - (O2 - 0.5 × CO))	10) 16.009
11) AVG(√(H × TS)) = (1 ÷ N) × SUM(√(H × TS))	11) 2373.4 EF
12) U = (174 × CP × (√(29.92 ÷ PS × GS)) × AVG(√(H × TS)))	12) 10322 ACE
13) QS = (U) × (AS')	13) 9969 CEM
14) QD = (QS) × (FDA)	14) 9039 SCE
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 101.2
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	
17) ESTP = (15.43 × Y) + (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) ÷ (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150) UNITS : GRAINS/SCF	
20) EM = (0.00857) × (ESTP) × (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- .0152	.0030				0.23
BACK HALF	- .0093	.0018				0.14
TOTALS	- .0245	.0048				0.37

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE: 6/23/72

STACK- COLUMN COOLER OUTLET

RUN 2 FROM 07:50-09:45

WEATHER CONDITIONS- CLEAR AND COLD

PR- 28.8 IN HG PS- 28.8 IN HG

AS'- 4.35 SO. FEET TS- 568.5 DEGREES R

TH- 528.7 DEGREES R H- 0.604 IN H2O

ΔH- 1.35 IN H2O AN- 0.000341 SO. FEET

CP- 0.83 VM- 70.484 CF VC- 55 ML

TOTAL TIME- 110 MIN NPTS- 44 ORSAT: AIC

1) VWV = (0.0474) × (VC)	1) NA	SCF
2) VSTPD = ((530) × (VM) × (PB + (ΔH ÷ 13.6))) ÷ (29.92 × TM)	2) 68.247	SCF
3) VT = (VWV) + (VSTPD)	3) NA	SCF
4) W = (VWV) ÷ (VT)	4) 0.037	
5) FDA = (1.0 - W)	5) 0.963	
6) ASSUMED MOISTURE FRACTION	6) 0.033	
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + H2))	7) 28.85	
8) MS = (MD × FDA) + (18 × W)	8) 28.45	
9) GS = (MS) ÷ (28.99)	9) 0.98	
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × H2) - (O2 - 0.5 × CO))	10) NA	%
11) AVG((H × TS)) = (1 ÷ H) × SUM((H × TS))	11) 14.796	
12) U = (174 × CP × ((29.92 ÷ PS × GS)) × AVG((H × TS))	12) 2139.1	EE
13) QS = (U) × (AS')	13) 9303	ACE
14) QD = (QS) × (FDA)	14) 8961	CEM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 8041	SCF
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	16) 98.4	%
17) ESTP = (15.43 × Y) ÷ (VSTPD)	UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) ÷ (%CO2)	UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150)	UNITS : GRAINS/SCF	
20) EM = (0.00857) × (ESTP) × (QSTPD)	UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- .0222	.0050				0.35
BACK HALF	- .0184	.0042				0.29
TOTALS	- .0406	.0092				0.63

COMMENTS : SEE RUN #1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/23/72

STACK- COLUMN COOLER OUTLET

RUN 3 FROM 11:11-14:06

WEATHER CONDITIONS- CLEAR AND COLD

PR- 28.8 IN HG

PS- 28.8 IN HG

AS'- 4.35 SQ. FEET TS- 574.7 DEGREES R

TH- 546.1 DEGREES R

H- 0.71 IN H2O

ΔH- 1.87 IN H2O

AN- 0.000341 SQ. FEET

CP- 0.83

VH- 86.51 CF

VC- 63 ML

TOTAL TIME- 110 MIN NPTS- 44 ORSAT: AIR

1) VWV = (0.0474) × (VC)	1) NA	SCF
2) VSTPD = ((530) × (VM) × (PB + (ΔH + 13.6))) + (29.92 × TM)	2) 81.199	SCF
3) VT = (VWV) + (VSTPD)	3) NA	SCF
4) W = (VWV) ÷ (VT)	4) 0.035	
5) FDA = (1.0 - W)	5) 0.965	
6) ASSUMED MOISTURE FRACTION	6) 0.033	
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + N2))	7) 28.85	
8) MS = (MD × FDA) + (18 × W)	8) 28.47	
9) GS = (MS) ÷ (28.99)	9) 0.98	
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.265 × N2) - (O2 - 0.5 × CO))	10) NA	%
11) AVG(√(H × TS)) = (1 ÷ N) × SUM(√(H × TS))	11) 17.612	
12) Q = (174 × CP × (√(29.92 ÷ PS × GS)) × AVG(√(H × TS)))	12) 2527.2	FEET
13) QS = (Q) × (AS')	13) 10991	ACFT
14) QD = (QS) × (FDA)	14) 10601	CEMT
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 9410	SCF
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM ÷ TM)) ÷ (TIME × Q × PS × AN)	16) 100.1	%
17) ESTP = (15.43 × Y) ÷ (VSTPD)		UNITS : GRAINS/SCF
18) E12 = (12 × ESTP) ÷ (%CO2)		UNITS : GRAINS/SCF
19) E50 = (ESTP × (100 + EA)) ÷ (150)		UNITS : GRAINS/SCF
20) EM = (0.00857) × (ESTP) × (QSTPD)		UNITS : POUNDS/HOUR

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RAT.
(Y)		(ESTP)	(E12)	(E50)	(EM) (LBS/H)
FRONT HALF	- .0141	.0027			0.22
BACK HALF	- .0109	.0021			0.17
TOTALS	- .0250	.0048			0.38

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA
STACK- PAN COOLER INLET
WEATHER CONDITIONS- CLEAR AND COOL
AS'- 3.69 SQ. FEET TS- 555.9 DEGREES R
AH- 3.04 IN H2O AN- 0.000341 SQ. FEET CP- 0.83
TOTAL TIME- 120 MIN NPTS- 24 ORSAT: Air

DATE- 6/21/72

RUN 1 FROM 6:50-9:10

PB- 28.78 IN HG

PS- 29 IN HG

TM- 531.1 DEGREES R H- 0.905 IN H2O
VC- 66 ML

1) VWV = (0.0474) * (VC)	1) NA	SCF
2) VSTPD = ((530) * (VM) * (PB + (AH + 13.6))) / (29.92 * TM)	2) 114.332	SCF
3) VT = (VWV) + (VSTPD)	3) NA	SCF
4) W = (VWV) / (VT)	4) 0.027	
5) FDA = (1.0 - W)	5) 0.973	
6) ASSUMED MOISTURE FRACTION	6) 0.026	
7) MD = (.44 * CO2) + (.32 * O2) + (.28 * (CO + H2))	7) 28.85	
8) MS = (MD * FDA) + (18 * W)	8) 28.56	
9) GS = (MS) / (28.99)	9) 0.99	
10) EA = (100) * (O2 - 0.5 * CO) / ((0.266 * H2) - (O2 - 0.5 * CO))	10) 21.335	%
11) AVG((H * TS)) = (1/H) * SUM((H * TS))	11) 21.335	
12) U = (174 * CP * ((29.92 + PS * GS)) * AVG((H * TS)))	12) 3153.1	FE
13) QS = (U) * (AS')	13) 11626	ACF
14) QD = (QS) * (FDA)	14) 11316	CFM
15) QSTPD = (QD) * (530 / TS) * (PS + 29.92)	15) 10457	SCF
16) PISO = ((0.00267 * VC * TS) + (PO * TS * VM / TM)) / (TIME * U * PS * AN)	16) 98.5	%
17) ESTP = (15.43 * Y) + (VSTPD)		UNITS : GRAINS/SCF
18) E12 = (12 * ESTP) + (%CO2)		UNITS : GRAINS/SCF
19) E50 = (ESTP * (100 + EA)) / (150)		UNITS : GRAINS/SCF
20) EM = (0.00857) * (ESTP) * (QSTPD)		UNITS : POUNDS/HOUR

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RAT	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- 11.0507	1.4914				133.65
BACK HALF	- .0039	.0005				0.05
TOTALS	- 11.0546	1.4919				133.69

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/22/72

STACK- PAN COOLER INLET

RUN 2 FROM 8:45-11:05

WEATHER CONDITIONS- CLEAR AND COLD

PR- 28.9 IN HG

PS- 29.1 IN HG

AS'- 3.69 SQ. FEET TS- 550 DEGREES R

TM- 529.6 DEGREES R

H- 1.095 IN H2O

ΔH- 4.57 IN H2O AN- 0.000341 SQ. FEET

CP- 0.83

VM- 144.691 CF

VC- 82 ML

TOTAL TIME- 120 MIN NPTS- 24 ORSAT: AIR

1) VWV = (0.0474) × (VC)	1) NA SCE
2) VSTPD = ((530) × (VM) × (PB + (ΔH ÷ 13.6))) ÷ (29.92 × TM)	2) 141.484 SCE
3) VT = (VWV) + (VSTPD)	3) NA SCE
4) W = (VWV) ÷ (VT)	4) 0.027
5) FDA = (1.0 - W)	5) 0.973
6) ASSUMED MOISTURE FRACTION	6) 0.026
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + N2))	7) 28.85
8) MS = (MD × FDA) + (18 × W)	8) 28.56
9) GS = (MS) ÷ (28.99)	9) 0.99
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × N2) - (O2 - 0.5 × CO))	10) NA
11) AVG($\sqrt{H \times TS}$) = (1 ÷ N) × SUM($\sqrt{H \times TS}$)	11) 25.675
12) U = (174 × CP × ($\sqrt{(29.92 ÷ PS \times GS)}$) × AVG($\sqrt{H \times TS}$))	12) 3788.1 ECF
13) QS = (U) × (AS')	13) 13272 ACE
14) QD = (QS) × (FDA)	14) 13604 CEM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 12750 SCE
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	16) 100.1
17) ESTP = (15.43 × Y) ÷ (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) ÷ (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150) UNITS : GRAINS/SCF	
20) EM = (0.00857) × (ESTP) × (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- 20.8480	2.2737				248.44
BACK HALF	- .0064	.0007				0.08
TOTALS	- 20.8544	2.2743				248.52

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/22/72

STACK- PAN COOLER INLET

RUN 3 FROM 12:30-14:35

WEATHER CONDITIONS- CLEAR AND COLD

PB- 28.91 IN HG

PS- 29.1 IN HG

AS'- 3.69 SQ. FEET TS- 559.3 DEGREES R

TM- 535.9 DEGREES R

H- 1.066 IN H2O

ΔH- 4.32 IN H2O

AN- 0.000341 SQ. FEET

CP- 0.83

VH- 142.783 CF

VC- 80 ML

TOTAL TIME- 120 MIN

NPTS- 24

ORSAT: AIR

1) VWV = (0.0474) × (VC)	1) <u>NA</u> SCE
2) VSTPD = (530) × (VH) × (PB + (ΔH ÷ 13.6)) ÷ (29.92 × TM)	2) <u>137.255</u> SCE
3) VT = (VWV) + (VSTPD)	3) <u>NA</u> SCE
4) W = (VWV) ÷ (VT)	4) <u>0.027</u>
5) FDA = (1.0 - W)	5) <u>0.973</u>
6) ASSUMED MOISTURE FRACTION	6) <u>0.026</u>
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + N2))	7) <u>28.85</u>
8) MS = (MD × FDA) + (18 × W)	8) <u>28.56</u>
9) GS = (MS) ÷ (28.99)	9) <u>0.99</u>
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × N2) - (O2 - 0.5 × CO))	10) <u>21.1</u> %
11) AVG(√(H × TS)) = (1 ÷ H) × SUM(√(H × TS))	11) <u>25.202</u>
12) U = (174 × CP × (√(29.92 ÷ PS × GS)) × AVG(√(H × TS)))	12) <u>3718.3</u> EE
13) QS = (U) × (AS')	13) <u>13721</u> ACF
14) QD = (QS) × (FDA)	14) <u>13354</u> CFM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) <u>12306</u> SCE
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	16) <u>101.1</u> %
17) ESTP = (15.43 × Y) + (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) + (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150) UNITS : GRAINS/SCF	
20) EM = (0.00857) × (ESTP) × (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- 20.5451	2.2979			242.35	
BACK HALF	- .0095	.0011			0.11	
TOTALS	- 20.5546	2.2990			242.47	

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/21/72

STACK- PAN COOLER OUTLET

RUN 1 FROM 18:50-21:11

WEATHER CONDITIONS- CLEAR AND COOL

PB- 28.78 IN HG

PS- 28.78 IN HG

AS'- 9.51 SQ. FEET TS- 548.7 DEGREES R

TM- 538.6 DEGREES R

H- 0.447 IN H2O

ΔH- 0.73 IN H2O

AN- 0.000341 SQ. FEET

CP- 0.83

VM- 62.065 CF

VC- 26 ML

TOTAL TIME- 117.5 MIN

NPTS- 47

ORSAT: AIR

1) VWV = (0.0474) × (VC)	1) NA SCE
2) VSTPD = ((530) × (VM) × (PB + (ΔH + 13.6))) ÷ (29.92 × TM)	2) 58.859 SCE
3) VT = (VWV) + (VSTPD)	3) NA SCE
4) W = (VWV) ÷ (VT)	4) 0.021
5) FDA = (1.0 - W)	5) 0.979
6) ASSUMED MOISTURE FRACTION	6) 0.02
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + N2))	7) 28.85
8) MS = (MD × FDA) + (18 × W)	8) 28.63
9) GS = (MS) ÷ (28.99)	9) 0.99
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × N2) - (O2 - 0.5 × CO))	10) NA %
11) AVG((H × TS)) = (1 ÷ N) × SUM((H × TS))	11) 10.469
12) U = (174 × CP × ((29.92 ÷ PS × GS)) × AVG((H × TS)))	12) 1551.4 EPP
13) QS = (U) × (AS')	13) 14749 ACE
14) QD = (QS) × (FDA)	14) 14446 CEM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 13421 SCE
16) PISO = ((0.00267 × VC × TS) + (PO × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	16) 104.1 %
17) ESTP = (15.43 × Y) ÷ (VSTPD)	UNITS : GRAINS/SCF
18) E12 = (12 × ESTP) ÷ (%CO2)	UNITS : GRAINS/SCF
19) E50 = (ESTP × (100 + EA)) ÷ (150)	UNITS : GRAINS/SCF
20) EM = (0.00857) × (ESTP) × (QSTPD)	UNITS : POUNDS/HOUR

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RAT.	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- .4998	.1310				15.07
BACK HALF	- .0097	.0025				0.29
TOTALS	- .5095	.1336				15.36

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED
SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/22/72

STACK- PAN COOLER OUTLET

RUN 2 FROM 8:45-11:05

WEATHER CONDITIONS- CLEAR

PB- 28.91 IN HG

PS- 28.91 IN HG

AS'- 9.51 SQ. FEET TS- 549.1 DEGREES R

TM- 533.7 DEGREES R

H- 0.545 IN H2O

ΔH- 1.15 IN H2O ΔH- 0.000341 SQ. FEET

CP- 0.83

VM- 77.225 CF

VC- 33 ML

TOTAL TIME- 120 MIN NPTS- 48 ORSAT: AIR

1) VWV = (0.0474) × (VC)	1) <u>NA</u> <u>SCE</u>
2) VSTPD = ((530) × (VM) × (PB + (ΔH ÷ 13.6))) ÷ (29.92 × TM)	2) <u>74.322</u> <u>SCE</u>
3) VP = (VWV) + (VSTPD)	3) <u>NA</u> <u>SCE</u>
4) W = (VWV) ÷ (VT)	4) <u>0.021</u>
5) FDA = (1.0 - W)	5) <u>0.979</u>
6) ASSUMED MOISTURE FRACTION	6) <u>0.02</u>
7) MD = (.44 × CO2) + (.32 × O2) + (.28 × (CO + N2))	7) <u>28.85</u>
8) MS = (MD × FDA) + (18 × W)	8) <u>28.63</u>
9) GS = (MS) ÷ (28.99)	9) <u>0.99</u>
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × H2) - (O2 - 0.5 × CO))	10) <u>NA</u> <u>%</u>
11) AVG($\sqrt{(H \times TS)}$) = (1 ÷ L) × SUM($\sqrt{(H \times TS)}$)	11) <u>12.759</u>
12) U = (174 × CP × ($\sqrt{(29.92 \div PS \times GS)}$) × AVG($\sqrt{(H \times TS)}$)	12) <u>1887.2</u> <u>FEET</u>
13) QS = (U) × (AS')	13) <u>17948</u> <u>ACFM</u>
14) QD = (QS) × (FDA)	14) <u>17578</u> <u>CFM</u>
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) <u>16393</u> <u>SCEM</u>
16) PISO = ((0.00267 × VC × TS) + (Po × TS × VM ÷ TM)) ÷ (TIME × U × PS × ΔH)	16) <u>105.4</u> <u>%</u>
17) ESTP = (15.43 × Y) ÷ (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) ÷ (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150) UNITS : GRAINS/SCF	
20) EM = (0.00857) × (ESTP) × (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/HR)
FRONT HALF	- .7494	.1556				21.86
BACK HALF	- .0347	.0072				1.01
TOTALS	- .7841	.1628				22.87

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

ENVIRONMENTAL ENGINEERING, INCORPORATED SOURCE SAMPLING CALCULATIONS

PLANT- CARGILL SIOUX CITY, IOWA

DATE- 6/22/72

STACK- PAN COOLER OUTLET

RUN 3 FROM 12:32-14:40

WEATHER CONDITIONS- CLEAR

PB- 28.91 IN HG.

PS- 28.91 IN HG

AS'- 9.51 SQ. FEET TS- 557.2 DEGREES R

TH- 543.5 DEGREES R

H- 0.552 IN H2O

ΔH- 1.17 IN H2O

AN- 0.000341 SQ. FEET

CP- 0.83

VM- 78.785 CF

VC- 34 ML

TOTAL TIME- 120 MIN

NPTS- 48

ORSAT: AIR

1) VWV = (0.0474) × (VC)	1) NA SCE
2) VSTPD = ((530) × (VM) × (PB + (ΔH + 13.6))) ÷ (29.92 × TM)	2) 74.454 SCE
3) VT = (VWV) + (VSTPD)	3) NA SCE
4) W = (VWV) ÷ (VT)	4) 0.021
5) FDA = (1.0 - W)	5) 0.979
6) ASSUMED MOISTURE FRACTION	6) 0.02
7) ND = (.44 × CO2) + (.32 × O2) + (.28 × (CO + N2))	7) 28.85
8) MS = (MD × FDA) + (18 × W)	8) 28.62
9) GS = (MS) ÷ (28.99)	9) 0.99
10) EA = (100) × (O2 - 0.5 × CO) ÷ ((0.266 × N2) - (O2 - 0.5 × CO))	10) 81.1 %
11) AVG($\sqrt{H \times TS}$) = ((1 ÷ N) × SUM($\sqrt{H \times TS}$))	11) 13.029
12) U = (174 × CP × ($\sqrt{(29.92 \div PS \times GS)}$) × AVG($\sqrt{H \times TS}$))	12) 1226.5 EE
13) QS = (U) × (AS')	13) 12315 ACE
14) QD = (QS) × (FDA)	14) 17927 GEM
15) QSTPD = (QD) × (530 ÷ TS) × (PS ÷ 29.92)	15) 16477 SCE
16) PISO = ((0.00267 × VC × TS) + (P × TS × VM ÷ TM)) ÷ (TIME × U × PS × AN)	16) 105 %
17) ESTP = (15.43 × Y) ÷ (VSTPD) UNITS : GRAINS/SCF	
18) E12 = (12 × ESTP) ÷ (%CO2) UNITS : GRAINS/SCF	
19) E50 = (ESTP × (100 + EA)) ÷ (150) UNITS : GRAINS/SCF	
20) EM = (0.00857) × (ESTP) × (QSTPD) UNITS : POUNDS/HOUR	

PARTICULATE LAB ANALYSIS (GM)		PARTICULATE CONCENTRATIONS (GR/SCF)			EMISSION RATE	
(Y)		(ESTP)	(E12)	(E50)	(EM)	(LBS/H)
FRONT HALF	- .3185	.0660				9.32
BACK HALF	- .0138	.0029				0.40
TOTALS	- .3323	.0689				9.72

COMMENTS : SEE RUN # 1 (HAMMER MILL OUTLET)

TEST CONDUCTED BY :



environmental engineering, inc.

APPENDIX B

Plant Operating Data

A. Process Description:

The following materials are blended in specific formulas to produce a variety of animal and poultry feeds:

- pulverized corn and milo
- wheat middlings
- soybean meal
- cotton seed meal
- fish meal
- feather meal
- meat scraps
- molasses
- premises, minerals and drugs

Corn or milo is fed by gravity to a Prator hammermill. The mill forces 6 tons of corn per hour through 7/64" diameter perforations. The pulverized corn is boosted to the third floor by a 50 HP fan. A cyclone separates the corn from the air stream and drops it into one of two 2,000 cu. ft. storage bins (#5 and #6). At least 50% of the cyclone exhaust air is returned to the throat of the hammermill, (see Fig. 1).

The mixed feed formula is placed in holding bins which feed it into the California Pellet Mills. Steam is introduced to the feed material at the pellet mill and the material is extruded through a die to form pellets approximately 3/16" diameter and 1/2" long. Each pellet mill produces 6 to 10 tons of feed per hour. The rate of production depends upon the formula of the feed being processed. Fine, calcium carbonate dust may be applied to the pellets as they drop from the pellet mills into the pellet coolers. Dust is applied to feeds which cause problems by clogging equipment or bridging in storage bins. These problems are related to the ingredients in the feed. The calcium carbonate will pass a 200 mesh sieve and has been dried yellow. It is applied at the rate of 30# per ton of feed.

The pellets are cooled in either a column or moving pan type pellet cooler. The rate of pellet flow through the coolers is dependent upon the production rate at the pellet mills. The pellet coolers are located in the basement area. Air is pulled into the coolers from the basement. Dust picked up from the pellet stream is collected in large diameter cyclones located on the third and fourth floors. The dust collected in the cyclones is returned to the pellet mills for reforming.

B. Discussion of Test:

It was originally planned to sample emissions from the pulverized corn storage bin vent. After the rain cap was removed from the vent, it was determined that there is no measurable air flow out of the vent. The calculated velocity of air displaced out the vent by the inflowing corn is 0.1 fps. Meaningful results would not be attained by pulling air and dust up the vent pipe at a rate greater than the natural draft, therefore, the test was cancelled.

Hammermill

The hammermill was grinding #2 yellow corn which by National Grain Standards, contains $\leq 5\%$ foreign matter and $\leq 15\%$ moisture. A moisture check on a random sample of the corn entering the hammermill indicated 13.2% moisture. The pulverized corn entering the storage bins contained 12.3% moisture. This is a normal moisture loss for a grinding operation according to Mr. Musech. The exhaust air from the cyclone contained approximately 2.3% moisture at 85°F. The rain cap was removed from the cyclone and a short extension was attached to the outlet. A straightening vane consisting of a cross made of $\frac{1}{2}$ " plywood, was installed. The vane seemed very effective in distributing the flow more evenly across the exhaust duct. Simultaneous samples were taken at the cyclone exhaust with the EPA train (method #5) and a high volume sampler.

The first of three test runs on the hammermill cyclone was conducted on June 20, 1972, from 8:25 p.m. to 11:02 p.m. Storage bins #5 and #6 were measured prior to starting the grinder and were found to have 44 ft. and 11 ft. of free space, respectively. Bin #6 was filled at 9:05 p.m. and the pulverized corn was diverted to bin #5. The grinder was shut off between 9:25 p.m. and 9:40 p.m. while the sample trains were rotated 90° in the stack. There were no visible emissions during the testing.

The second test run was conducted on June 21, 1972, from 9:50 a.m. to 11:45 a.m. Bins #5 and #6 were measured prior to starting the test and were found to have 29 ft. and 9 ft. of free space, respectively. The grinder was started at 9:40 a.m. and run continuously during the test. The grinding rate was steady and was calculated to be 6 tons/hour on the basis of the bin measurements and the operating times. There were no visible emissions during the testing. The third test run was conducted on June 21, 1972, from 12:05 p.m. to 1:50 p.m. The grinding rate was steady at 6 tons/hour throughout the test. Bin #5 was filled at 1:20 p.m., when the pulverized corn was diverted to bin #6. There were no visible emissions during the testing.

Pan Cooler

Pellet mill #3 is serviced by a horizontal (moving pan type) pellet cooler and cyclone #173A. The inlet and outlet of the cyclone were tested simultaneously using EPA method #5 with impingers. The pellet cooler is produced by the California Pellet Mill Company, Model Number 5HRS22. The cooler is 5 ft. wide, 22 ft. long and pellets make a double pass through the cooler riding on moving, perforated metal pans. There is 185 sq. ft. of cooling area. Average pellet bed depth on the moving pans is 7". Cubes may be piled to a depth of 9" in this cooler. Fan #173 pulls air from the basement area (72°F) through the cooler and blows it to the cyclone. The New York Blower Model 452 has a 40 HP motor and rotates 1800 RPM. The blower is capable of pulling 18,500 cfm. with a static pressure of 7" water at 914 RPM.

The cooling air and dust are blown through a 26" diameter duct to the cyclone collector on the fourth floor. Cyclone number 173A is a Longhorn Scroll Type, 79" diameter cyclone. The effective opening at the bottom of the cyclone can be adjusted. The 44" diameter outlet extends through the 5th floor area and ends about 40" above the roof.

The first of three test runs was made on June 21, 1972, from 6:50 p.m. - 9:10 p.m. A 21 ton mixture of beef cattle feed containing the following ingredients was prepared for pelletizing during the test period.

32%	wheat middlings
30%	cottonseed meal
17%	soybean meal
5%	molasses
16%	minerals and premixes
100%	

The feed was pelletized in 160 minutes, giving a production rate of 7.6 tons of pellets/hour. The pellets were dusted with 550 lb. calcium carbonate applied at a steady rate. Visible emissions fluctuated from 15%-50% opacity.

The second test run was made on June 22, 1972, from 8:45 a.m. to 11:05 a.m. An 18 ton mixture of beef cattle feed of the same formula used for run #1 was prepared for pelletizing during the test period. Pellets were produced at the rate of 6.1 tons/hour during the operating time. The pellets were dusted with 500 lb. of calcium carbonate. A grab sample was taken of the dust collected by the cyclone. Visible emissions fluctuated from 15% opacity to 50% opacity during the test. The visible emissions were due to the pellet dusting operation.

The third test run was made on June 22, 1972, from 12:32 p.m. to 2:40 p.m. An 18 ton mixture of cattle feed containing the following ingredients was prepared for pelletizing during the test period.

60.0%	pulverized corn
25.0%	wheat middlings
9.5%	soybean meal
1.5%	cottonseed meal
4.0%	minerals and premixes
100.0%	

The pellet mill was run at a steady rate, producing 9 tons of pellets/hour. The pellets were not dusted.

The stack was observed from a distance of 20 ft. and no visible emissions were seen. The stack was also observed from the ground level 150 ft. below and 150 ft. east. With blue sky as the background the plume appeared to have a constant 5% opacity.

Column Cooler

Pellet mill #1 is served by two verticle column type pellet coolers and two cyclones. Only one of the coolers was used during the test period. The column cooler was manufactured by the California Pellet Mill Company, Model No. 2GA3, Serial No. 203664-2. It has a rated capacity of 7½ tons/hour. A CPM size 40 fan pulls air from the basement area (75°F) through the cooler. The fan is capable of pulling 9325 cfm. with a static pressure of 6" water at 1765 rpm. The cooling air and dust are blown through a 17" diameter duct to the cyclone collector on the third floor. The 10" diameter opening at the bottom of the cyclone does not have an air lock and the collected dust is returned to the pellet mill on the first floor. The 30"

diameter outlet pipe extends 27" above the roof. The cyclone inlet and outlet were tested simultaneously using EPA method #5 with impingers. The rain cap was removed from the cyclone outlet and an extension and straightening vane was installed.

The first of three test runs was made on June 22, 1972, from 5:20 p.m. to 7:45 p.m. A 30 ton mixture of poultry feed containing the following ingredients was prepared for pelletizing during the test period.

75.0%	pulverized corn
15.0%	soybean meal
2.8%	wheat middlings
2.5%	meat scrap
1.9%	feather meal
3.8%	minerals and premixes
<u>100.0%</u>	

The pellet mill was processing a similar poultry feed when testing began at 5:20 p.m. The mill was stopped at 5:35 p.m. and restarted again at 5:50 p.m. and operated until 9:30 p.m. Pellets were produced at the rate of 8 tons/hour. Dust was not applied to these pellets, and there were no visible emissions from the cyclone.

The second test run was made on June 23, 1972, from 7:50 a.m. to 9:45 a.m. An 18 ton mixture of poultry feed containing the following ingredients was prepared for pelletizing during the test period.

57.5%	soybean meal
10.5%	wheat middlings
10.0%	meat scrap
7.0%	feather meal
15.0%	minerals and premixes
<u>100.0%</u>	

The pellet mill was run at a steady rate, producing 6.7 tons of pellets per hour. The pellets were not dusted and there were no visible emissions from the cyclone.

The third test run was made on June 23, 1972, from 11:11 a.m. until 2:06 p.m. Testing was discontinued between 12:00 noon and 1:00 p.m. A 30 ton mixture of poultry feed containing the following ingredients was prepared for pelletizing during the test period.

18.75%	soybean meal
3.50%	wheat middlings
65.00%	pulverized corn
3.25%	meat scrap
2.25%	feather meal
7.25%	minerals and premixes
<u>100.0%</u>	

The pellet mill produced 7.6 tons of pellets per hour during the 3.92 hours of operation. The pellets were not dusted and there were no visible emissions from the cyclone.

C. Process Data:

HAMMERMILL CYCLONE

Test Run	Grinding Rate	Material	Remarks
1	6 T/hr	#2 Yellow Corn	No Visible Emissions
2	6 T/hr	#2 Yellow Corn	
3	6 T/hr	#2 Yellow Corn	

PAN COOLER CYCLONE

Test Run	Pellet Production Rate	Dusting	Visible Emissions
1	7.6 T/hr	26.2 #/T	15%-50%
2	6.1 T/hr	27.8 #/T	15%-50%
3	9.0 T/hr	None	None


COLUMN COOLER CYCLONE

Test Run	Pellet Production Rate	Dusting	Remarks
1	8.0 T/hr	None	No Visible Emissions
2	6.7 T/hr	None	
3	7.6 T/hr	None	

HAMMER MILL


PRODUCT RECOVERY CYCLONE

FIG. 1





TRAFFIC HAMMER MILL
MODEL 609-3
SERIAL NO. 28007
LAPOR 1100 10

FAN MODEL 40H
SERIAL NO. 28007
LAPOR 1100 10



CALIFORNIA PELLET MILL CO.
HORIZONTAL PELLET COOLER
MODEL 5 HRS 22
DOUBLE PASS
15'-0" COOLING AREA



APPENDIX C

Field Data Sheets

[illegible]

SOURCE SAMPLING FIELD DATA SHEET

Mat'l Processing Rate

Final Gas Meter Reading 328.363 ft³Initial Gas Meter Reading 277.270 ft³Total Condensate in Impingers 14 ml

Moisture in Silica Gel _____ gm

Silica Gel Container No. _____ Filter No. _____

Orsat: CO₂ _____O₂ _____

CO _____

N₂ _____Excess
AirTest Conducted by: R. DURGANE. DURGAN

Remarks:

25

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1	12.10	12:10	277.270	0.06	0.99	0.99	87	71	69	25	-	0.0
2	12.15	12:15		0.06	0.99	0.99	87	71	69	25	-	0.0
3	12.15	12:15	281.6	0.06	0.99	0.99	87	71	69	25	68	0.0
4	12.20	12:20	287.2	0.06	0.99	0.99	-	78	69	100	-	4.0
5	12.25	12:25	294.8	0.07	1.02	1.02	-	74	61	100	-	4.0
6	12.30	12:30	296.6	0.08	1.00	1.00	-	71	51	100	-	4.0
7	12.35	12:35	300.0	0.09	1.00	1.00	87	70	50	25	68	0.0

Plant CANSALE GAS STATIONSampling Location 4/8000000000Date 6-24-77 Run No. 3Time Start 12:10 Time End 1:50Sampling Time/Point 2.5 (60 sec) 77.5 min

DB °F, WB °F, VF @ DP °F, "Hg

Moisture 2.3 %, FDA 72 %, Gas Density FactorBarometric Press 29.7 "Hg, Stack Press 28.76 "HgWeather Cloudy

Temp. °F, W/D °F, W/S °F

Sample Box No. 1 Meter Box No. 1Meter ΔH 1.7 Pitot Corr. Factor 0.83Nozzle Dia. 1/8 in., Probe Length 6 ftProbe Heater Setting -Stack Dimensions: Inside Diameter 28 inInside Area 11.76 ft²Height 7 ft

SOURCE SAMPLING FIELD DATA SHEET

Plant Chrysothrix Mat'l Processing Rate _____ ft³
 Sampling Location Off-gas Final Gas Meter Reading _____ ft³
 Date 1-15-78 Run No. 3 Initial Gas Meter Reading _____ ml
 Time Start 12:10 Time End 1:50 Total Condensate in Impingers _____ gm
 Sampling Time/Point _____ Moisture in Silica Gel _____
 DB _____ °F, WB _____ °F, VF @ DP _____ "Hg Filter No. _____
 Moisture _____ % FDA _____ Gas Density Factor _____
 Barometric Press _____ "Hg, Stack Press _____ "Hg
 Weather _____
 Temp. _____ °F, W/D _____, W/S _____
 Sample Box No. _____ Meter Box No. _____
 Meter AHe _____ Pitot Corr. Factor _____
 Nozzle Dia. _____ in., Probe Length _____ ft
 Probe Heater Setting _____
 Stack Dimensions: Inside Diameter _____ in
 Inside Area _____ ft²
 Height _____ ft

Test Conducted by: _____

Remarks: _____

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1	23 1/2	1:35	315.6	0.14	2.70	2.70	92	79	76	150	64	4.0
2	24 1/2	1:37	317.9	0.13	2.6	2.6	-	80	76	2.0	-	4.0
3	25 1/2	1:40	320.1	0.13	2.6	2.6	-	81	76	-	-	4.0
4	26 1/2	1:43	322.2	0.11	2.0	2.0	-	82	77	70	-	4.0
5	27 1/2	1:46	324.3	0.11	2.0	2.0	92	83	77	70	83	4.0
6	28 1/2	1:49	326.4	0.11	2.1	2.1	-	85	77	70	-	4.0
7	29 1/2	1:52	328.5	0.11	2.1	2.1	-	86	77	70	-	4.0
8	30 1/2	1:55	330.6	0.11	2.1	2.1	-	87	77	70	-	4.0

SOURCE SAMPLING FIELD DATA SHEET

Plant Carroll
 Sampling Location Column Cell (Inlet)
 Date 1/22/72 Run No. 1
 Time Start 17:25 Time End 18:51
 Sampling Time/Point 10 (170 Total)
 DB 41 °F, WB 40 °F, VP @ DP 0.80 "Hg
 Moisture 2.5 %, FDA , Gas Density Factor
 Barometric Pressure 29.3 "Hg, Stack Press 29.2 "Hg
 Weather C/ok
 Temp. 70 °F, W/D , W/S
 Sample Box No. 2 Meter Box No. 5
 Meter He 1.48 Pitot Corr. Factor 0.03
 Nozzle Dia. 0.25 in., Probe Length ft
 Probe Heater Setting
 Stack Dimensions: Inside Diameter 16 1/8 in
 Inside Area ft²
 Height 2 ft

Mat'l Processing Rate
 Final Gas Meter Reading 61920
 Initial Gas Meter Reading 15110 ft³
 Total Condensate in Impingers 24 ml
 Moisture in Silica Gel gm
 Silica Gel Container No. Filter No. 0013/7
 Orsat: CO₂
 O₂
 CO
 N₂
 Excess Air
 Test Conducted by: F Allen
T Decker

Remarks: Plant Shut Down


Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
Port 1			15.409									
PT. 1	1	17:25	12.1	1.20	0.31	0.31	108	88	88	—	70	2.5
PT. 1		17:30	8.8	1.20	0.31	0.31	108	89	88	—	70	3.0
* PT. 2	2 1/2	17:35	20.6	1.60	0.35	0.35	108	89	88	—	70	3.2
PT. 2		18:02	19.6	1.60	0.35	0.35	108	89	88	—	72	3.2
PT. 3	5	18:14	24.5	1.65	0.39	0.39	110	89	88	—	74	3.2
PT. 3		18:12	20.5	1.65	0.39	0.39	112	89	88	—	74	3.0

[illegible]

SOURCE SAMPLING FIELD DATA SHEET

Plant Cargill Inc. Sugar Corp. 1100
Sampling Location Coalbrook 7700
Date 1/24/77 Run No. 2
Time Start 0750 Time End 1000
Sampling Time/Point 10 (120 samples)
DB °F, WB °F, VF @ DP "Hg
Moisture 3.5%, FDA , Gas Density Factor
Barometric Press 28.6"Hg, Stack Press 29.0"Hg
Weather
Temp. °F, W/D , W/S
Sample Box No. Meter Box No.
Meter Alt 1.5 Pitot Corr. Factor
Nozzle Dia. 1/4 in., Probe Length ft
Probe Heater Setting

Stack Dimensions: Inside Diameter 1.5 in
Inside Area ft²
Height ft



Mat'l Processing Rate
Final Gas Meter Reading ft³
Initial Gas Meter Reading ft³
Total Condensate in Impingers 2.5 ml
Moisture in Silica Gel gm
Silica Gel Container No. Filter No. 13
Orsat: CO₂
O₂
CO
N₂
Excess Air
Test Conducted by:

Remarks:

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
Port 1			61.920									
1	1	7.50	63.2	1.65	0.388		112	73	74	-	73	2.0
1		7.55	63.3	1.60	0.390		112	73	74	-	73	2.0
2	2 1/2	8.00	63.5	1.40	0.382		112	73	74	-	72	2.5
2		8.05	63.6	1.40	0.382			73	74	-	70	2.2
3	3	8.10	63.5	2.1	0.370		111	73	74	-	68	2.0
3		8.15	63.5	2.1	0.370			73	74	-	67	2.1

83

[illegible]


ENVIRONMENTAL ENGINEERING, LLC

SOURCE SAMPLING FIELD DATA SHEET

Mat'l Processing Rate _____
Final Gas Meter Reading 153.740 ft³
Initial Gas Meter Reading 109.248 ft³
Total Condensate in Impingers 2.5 ml
Moisture in Silica Gel _____ gm
Silica Gel Container No. _____ Filter No. 11
Orsat: CO₂ _____
O₂ _____
CO _____
N₂ _____
Excess Air _____
Test Conducted by: G. P. P. P.
W. D. P. P.

Remarks: _____

35




Plant COAL FUEL TREAT
Sampling Location COAL FUEL TREAT
Date 12/17/72 Run No. 2
Time Start 11:00 Time End 11:25
Sampling Time/Point 11:00 11:05 11:10 11:15 11:20 11:25 "Hg
DB _____ °F, WB _____ °F, VF @ DP _____ "Hg
Moisture 3.5%, FDA _____, Gas Density Factor _____
Barometric Press 28.8 "Hg, Stack Press 29.0 "Hg
Weather CLEAR
Temp. 70 °F, W/D _____, W/S _____
Sample Box No. _____ Meter Box No. _____
Meter AHe Pitot Corr. Factor _____
Nozzle Dia. _____ in., Probe Length _____ ft
Probe Heater Setting _____
Stack Dimensions: Inside Diameter _____ in
Inside Area _____ ft²
Height _____ ft

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
Port 1			107.848									
1	1	11:00	110.0	1.80	0.92	0.12	110	71	71	-	75	3.0
1		11:05	111.4	1.40	0.324	0.324	110	71	71	-	74	3.8
2	2 1/2	11:10	113.2	1.50	0.345	0.345	110	71	71	-	74	4.0
2		11:15	115.0	1.60	0.375			73	72	-	74	5.0
3	5	11:20	116.8	1.60	0.375		110	71	71	-	74	
3		11:25	119.0	1.90	0.405	0.405	110	71	71	-	74	5.0

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
4	11 7/8	11:30	120.9	1.70	0.495	0.495	118	73	73	—	77	3.0
4		11:35	123.1	2.10	0.495	0.495	118	73	73	—	77	3.0
5	14 3/8	11:40	127.0	1.70	0.495	0.495	118	73	73	—	77	3.0
5		11:45	127.2	1.70	0.495	0.495	118	73	73	—	77	3.0
6	15 7/8	11:50	129.0	1.70	0.495	0.495	118	73	73	—	77	3.0
6		11:55	131.008	1.70	0.495	0.495	118	73	73	—	77	3.0
6		12:00	131.008	1.70	0.495	0.495	118	73	73	—	77	3.0
Port 2												
1	1	13:30	130.0	1.70	0.495	0.495	116	73	73	—	77	3.5
1		13:35	130.0	1.70	0.495	0.495	116	73	73	—	77	3.7
2	2 3/8	13:40	135.8	1.70	0.495	0.495	116	73	73	—	77	5.0
2		13:45	137.8	1.70	0.495	0.495	116	73	73	—	77	2.1
3	5	13:50	140.6	1.70	0.495	0.495	116	73	73	—	77	2.3
3		13:55	141.4	1.70	0.495	0.495	116	73	73	—	77	2.1
4	11 7/8	14:00	145.4	1.70	0.495	0.495	116	73	73	—	77	2.1
4		14:05	145.8	1.70	0.495	0.495	116	73	73	—	77	2.1
5	14 3/8	14:10	147.9	1.70	0.495	0.495	116	73	73	—	77	2.1
5		14:15	147.9	1.70	0.495	0.495	116	73	73	—	77	2.1
6	15 7/8	14:20	151.7	1.70	0.495	0.495	116	73	73	—	77	2.1
6		14:25	153.900	1.70	0.495	0.495	116	73	73	—	77	2.1
6		14:30	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		14:35	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		14:40	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		14:45	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		14:50	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		14:55	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:00	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:05	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:10	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:15	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:20	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:25	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:30	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:35	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:40	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:45	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:50	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		15:55	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1
6		16:00	154.0	1.70	0.495	0.495	116	73	73	—	77	2.1

SOURCE SAMPLING FIELD DATA SHEET

Mat'l Processing Rate _____
 Final Gas Meter Reading 822.550 ft³
 Initial Gas Meter Reading 783.874 ft³
 Total Condensate in Impingers 4.7 ml
 Moisture in Silica Gel _____ gm
 Silica Gel Container No. _____ Filter No. _____
 Orsat: CO₂ _____
 O₂ _____
 CO _____
 N₂ _____
 Excess Air _____
 Test Conducted by: P. J. ...
 Remarks: _____



Int. CHAPARRAL STONY CITY, IOWA

Sampling Location COOLIDGE (docket)
 Date 6-4-2002 Run No. 1
 Time Start 6:20 Time End 7:45
 Sampling Time/Point 2.4/112.0
 DB 104 °F, WB _____ °F, VF @ DP 0.7 / 112 °Hg
 Moisture 3.3 %, FDA _____, Gas Density Factor _____
 Barometric Press 29.9 °Hg, Stack Press 28.9 °Hg
 Weather _____
 Temp. 72 °F, W/D _____, W/S _____
 Sample Box No. 1 Meter Box No. 1
 Meter ΔH 1.0 Pitot Corr. Factor 0.8
 Nozzle Dia. 1/4 in., Probe Length _____ ft
 Probe Heater Setting _____
 Stack Dimensions: Inside Diameter 2.5 in
 Inside Area _____ ft²
 Height _____ ft

Est. Area = 4.9 ft²

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
<u>Point 1</u>		<u>6:20</u>	<u>783.874</u>	<u>0.08</u>	<u>1.2</u>	<u>1.2</u>	<u>602</u>	<u>700</u>	<u>700</u>	<u>65</u>		<u>6.2</u>
<u>Point 2</u>	<u>1.25</u>	<u>6:25</u>		<u>0.08</u>	<u>1.2</u>	<u>1.2</u>	<u>602</u>	<u>700</u>	<u>700</u>	<u>65</u>		<u>6.2</u>
<u>3</u>	<u>1.25</u>	<u>6:25</u>	<u>783.874</u>	<u>0.08</u>	<u>1.2</u>	<u>1.2</u>	<u>604</u>	<u>700</u>	<u>700</u>	<u>65</u>		<u>6.2</u>
<u>4</u>	<u>2.5</u>	<u>6:25</u>	<u>783.874</u>	<u>0.08</u>	<u>1.2</u>	<u>1.2</u>	<u>604</u>	<u>700</u>	<u>700</u>	<u>65</u>		<u>6.2</u>
<u>5</u>	<u>3.75</u>	<u>6:25</u>	<u>783.874</u>	<u>0.08</u>	<u>1.2</u>	<u>1.2</u>	<u>604</u>	<u>700</u>	<u>700</u>	<u>65</u>		<u>6.2</u>

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
1	27.20	6:40	782.3	0.11	1.0	1.0	77	77	77	60	60	14
2	27.20	6:42	784.0	0.11	1.0	1.0	77			73	65	14
3	27.20	6:44	786.6	0.11	1.0	1.0	77			77	60	14
4	27.20	6:46	788.1	0.11	1.0	1.0	77	77	77	70	60	14
5	27.20	6:48	789.4	0.11	1.0	1.0	77	77	77	70	60	14
6	27.20	6:50	790.1	0.11	1.0	1.0	77	77	77	70	60	14
7	27.20	6:52	791.0	0.11	1.0	1.0	77	77	77	70	60	14
8	27.20	6:54	791.9	0.11	1.0	1.0	77	77	77	70	60	14
9	27.20	6:56	792.6	0.11	1.0	1.0	77	77	77	70	60	14
10	27.20	6:58	793.0	0.11	1.0	1.0	77	77	77	70	60	14
11	27.20	7:00	794.1	0.11	1.0	1.0	77	77	77	70	60	14
12	27.20	7:02	795.1	0.11	1.0	1.0	77	77	77	70	60	14
13	27.20	7:04	796.0	0.11	1.0	1.0	77	77	77	70	60	14
14	27.20	7:06	797.0	0.11	1.0	1.0	77	77	77	70	60	14
15	27.20	7:08	798.0	0.11	1.0	1.0	77	77	77	70	60	14
16	27.20	7:10	799.0	0.11	1.0	1.0	77	77	77	70	60	14
17	27.20	7:12	800.0	0.11	1.0	1.0	77	77	77	70	60	14
18	27.20	7:14	801.0	0.11	1.0	1.0	77	77	77	70	60	14
19	27.20	7:16	802.0	0.11	1.0	1.0	77	77	77	70	60	14
20	27.20	7:18	803.0	0.11	1.0	1.0	77	77	77	70	60	14
21	27.20	7:20	804.0	0.11	1.0	1.0	77	77	77	70	60	14
22	27.20	7:22	805.0	0.11	1.0	1.0	77	77	77	70	60	14
23	27.20	7:24	806.0	0.11	1.0	1.0	77	77	77	70	60	14
24	27.20	7:26	807.0	0.11	1.0	1.0	77	77	77	70	60	14
25	27.20	7:28	808.0	0.11	1.0	1.0	77	77	77	70	60	14
26	27.20	7:30	809.0	0.11	1.0	1.0	77	77	77	70	60	14
27	27.20	7:32	810.0	0.11	1.0	1.0	77	77	77	70	60	14
28	27.20	7:34	811.0	0.11	1.0	1.0	77	77	77	70	60	14
29	27.20	7:36	812.0	0.11	1.0	1.0	77	77	77	70	60	14
30	27.20	7:38	813.0	0.11	1.0	1.0	77	77	77	70	60	14
31	27.20	7:40	814.0	0.11	1.0	1.0	77	77	77	70	60	14
32	27.20	7:42	815.0	0.11	1.0	1.0	77	77	77	70	60	14
33	27.20	7:44	816.0	0.11	1.0	1.0	77	77	77	70	60	14
34	27.20	7:46	817.0	0.11	1.0	1.0	77	77	77	70	60	14
35	27.20	7:48	818.0	0.11	1.0	1.0	77	77	77	70	60	14
36	27.20	7:50	819.0	0.11	1.0	1.0	77	77	77	70	60	14
37	27.20	7:52	820.0	0.11	1.0	1.0	77	77	77	70	60	14
38	27.20	7:54	821.0	0.11	1.0	1.0	77	77	77	70	60	14
39	27.20	7:56	822.0	0.11	1.0	1.0	77	77	77	70	60	14
40	27.20	7:58	823.0	0.11	1.0	1.0	77	77	77	70	60	14
41	27.20	8:00	824.0	0.11	1.0	1.0	77	77	77	70	60	14
42	27.20	8:02	825.0	0.11	1.0	1.0	77	77	77	70	60	14
43	27.20	8:04	826.0	0.11	1.0	1.0	77	77	77	70	60	14
44	27.20	8:06	827.0	0.11	1.0	1.0	77	77	77	70	60	14
45	27.20	8:08	828.0	0.11	1.0	1.0	77	77	77	70	60	14
46	27.20	8:10	829.0	0.11	1.0	1.0	77	77	77	70	60	14
47	27.20	8:12	830.0	0.11	1.0	1.0	77	77	77	70	60	14
48	27.20	8:14	831.0	0.11	1.0	1.0	77	77	77	70	60	14
49	27.20	8:16	832.0	0.11	1.0	1.0	77	77	77	70	60	14
50	27.20	8:18	833.0	0.11	1.0	1.0	77	77	77	70	60	14
51	27.20	8:20	834.0	0.11	1.0	1.0	77	77	77	70	60	14
52	27.20	8:22	835.0	0.11	1.0	1.0	77	77	77	70	60	14
53	27.20	8:24	836.0	0.11	1.0	1.0	77	77	77	70	60	14
54	27.20	8:26	837.0	0.11	1.0	1.0	77	77	77	70	60	14
55	27.20	8:28	838.0	0.11	1.0	1.0	77	77	77	70	60	14
56	27.20	8:30	839.0	0.11	1.0	1.0	77	77	77	70	60	14
57	27.20	8:32	840.0	0.11	1.0	1.0	77	77	77	70	60	14
58	27.20	8:34	841.0	0.11	1.0	1.0	77	77	77	70	60	14
59	27.20	8:36	842.0	0.11	1.0	1.0	77	77	77	70	60	14
60	27.20	8:38	843.0	0.11	1.0	1.0	77	77	77	70	60	14
61	27.20	8:40	844.0	0.11	1.0	1.0	77	77	77	70	60	14
62	27.20	8:42	845.0	0.11	1.0	1.0	77	77	77	70	60	14
63	27.20	8:44	846.0	0.11	1.0	1.0	77	77	77	70	60	14
64	27.20	8:46	847.0	0.11	1.0	1.0	77	77	77	70	60	14
65	27.20	8:48	848.0	0.11	1.0	1.0	77	77	77	70	60	14
66	27.20	8:50	849.0	0.11	1.0	1.0	77	77	77	70	60	14
67	27.20	8:52	850.0	0.11	1.0	1.0	77	77	77	70	60	14
68	27.20	8:54	851.0	0.11	1.0	1.0	77	77	77	70	60	14
69	27.20	8:56	852.0	0.11	1.0	1.0	77	77	77	70	60	14
70	27.20	8:58	853.0	0.11	1.0	1.0	77	77	77	70	60	14
71	27.20	9:00	854.0	0.11	1.0	1.0	77	77	77	70	60	14
72	27.20	9:02	855.0	0.11	1.0	1.0	77	77	77	70	60	14
73	27.20	9:04	856.0	0.11	1.0	1.0	77	77	77	70	60	14
74	27.20	9:06	857.0	0.11	1.0	1.0	77	77	77	70	60	14
75	27.20	9:08	858.0	0.11	1.0	1.0	77	77	77	70	60	14
76	27.20	9:10	859.0	0.11	1.0	1.0	77	77	77	70	60	14
77	27.20	9:12	860.0	0.11	1.0	1.0	77	77	77	70	60	14
78	27.20	9:14	861.0	0.11	1.0	1.0	77	77	77	70	60	14
79	27.20	9:16	862.0	0.11	1.0	1.0	77	77	77	70	60	14
80	27.20	9:18	863.0	0.11	1.0	1.0	77	77	77	70	60	14
81	27.20	9:20	864.0	0.11	1.0	1.0	77	77	77	70	60	14
82	27.20	9:22	865.0	0.11	1.0	1.0	77	77	77	70	60	14
83	27.20	9:24	866.0	0.11	1.0	1.0	77	77	77	70	60	14
84	27.20	9:26	867.0	0.11	1.0	1.0	77	77	77	70	60	14
85	27.20	9:28	868.0	0.11	1.0	1.0	77	77	77	70	60	14
86	27.20	9:30	869.0	0.11	1.0	1.0	77	77	77	70	60	14
87	27.20	9:32	870.0	0.11	1.0	1.0	77	77	77	70	60	14
88	27.20	9:34	871.0	0.11	1.0	1.0	77	77	77	70	60	14
89	27.20	9:36	872.0	0.11	1.0	1.0	77	77	77	70	60	14
90	27.20	9:38	873.0	0.11	1.0	1.0	77	77	77	70	60	14
91	27.20	9:40	874.0	0.11	1.0	1.0	77	77	77	70	60	14
92	27.20	9:42	875.0	0.11	1.0	1.0	77	77	77	70	60	14
93	27.20	9:44	876.0	0.11	1.0	1.0	77	77	77	70	60	14
94	27.20	9:46	877.0	0.11	1.0	1.0	77	77	77	70	60	14
95	27.20	9:48	878.0	0.11	1.0	1.0	77	77	77	70	60	14
96	27.20	9:50	879.0	0.11	1.0	1.0	77	77	77	70	60	14
97	27.20	9:52	880.0	0.11	1.0	1.0	77	77	77	70	60	14
98	27.20	9:54	881.0	0.11	1.0	1.0	77	77	77	70	60	14
99	27.20	9:56	882.0	0.11	1.0	1.0	77	77	77	70	60	14
100	27.20	9:58	883.0	0.11	1.0	1.0	77	77	77	70	60	14
101	27.20	10:00	884.0	0.11	1.0	1.0	77	77	77	70	60	14
102	27.20	10:02	885.0	0.11	1.0	1.0	77	77	77	70	60	14
103	27.20	10:04	886.0	0.11	1.0	1.0	77	77	77	70	60	14
104	27.20	10:06	887.0	0.11	1.0	1.0	77	77	77	70	60	14
105	27.20	10:08	888.0	0.11	1.0	1.0	77	77	77	70	60	14
106	27.20	10:10	889.0	0.11	1.0	1.0	77	77	77	70	60	14
107	27.20	10:12	890.0	0.11	1.0	1.0	77	77	77	70	60	14
108	27.20	10:14	891.0	0.11	1.0	1.0	77	77	77	70	60	14
109	27.20	10:16	892.0	0.11	1.0	1.0	77	77	77	70	60	14
110	27.20	10:18	893.0	0.11	1.0	1.0	77	77	77	70		

Point and Inverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. (°F)		Sample <Fox> Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
2	3 7/8	7:00	708.1				103	103	103	5.0	71	
3	4 3/4	7:01	711.5	0.17	0.17	0.17	106	107	107	5.5		
4	5 1/2	7:03	715.6	0.17	0.17	0.17	108	109	109	6.0		
5	6 1/2	7:05	716.6	0.17	0.17	0.17	108	109	109	6.5		
6	8 1/2	7:10	719.7	0.20	0.20	0.20	106	107	107	7.0		
7	9 1/2	7:13	720.1	0.20	0.20	0.20	106	107	107	7.5		
8	11 3/4	7:15	720.1	0.20	0.20	0.20	107	108	108	8.0	68	
9	17 3/4	7:18	800.2	0.20	0.20	0.20	107	108	108	9.5		
10	19 3/4	7:20	802.4	0.20	0.20	0.20	107	108	108	10.0		
11	21 1/2	7:21	805.2	0.20	0.20	0.20	107	108	108	10.5		
12	23 1/2	7:23	808.0	0.20	0.20	0.20	107	108	108	11.0	60	
13	24 3/4	7:24	809.1	0.20	0.20	0.20	107	108	108	11.5		
14	25 1/4	7:25	811.0	0.20	0.20	0.20	107	108	108	12.0		
15	26 1/2	7:26	812.5	0.20	0.20	0.20	107	108	108	12.5		
16	27 1/4	7:27	814.5	0.20	0.20	0.20	107	108	108	13.0		
17	28 1/4	7:28	816.2	0.20	0.20	0.20	107	108	108	13.5		
18	29 1/4	7:29	817.5	0.20	0.20	0.20	107	108	108	14.0		
19	30 1/4	7:30	818.5	0.20	0.20	0.20	107	108	108	14.5		
20	31 1/4	7:31	819.5	0.20	0.20	0.20	107	108	108	15.0		
21	32 1/4	7:32	820.5	0.20	0.20	0.20	107	108	108	15.5		
22	33 1/4	7:33	821.5	0.20	0.20	0.20	107	108	108	16.0		
23	34 1/4	7:34	822.5	0.20	0.20	0.20	107	108	108	16.5		
24	35 1/4	7:35	823.5	0.20	0.20	0.20	107	108	108	17.0		
25	36 1/4	7:36	824.5	0.20	0.20	0.20	107	108	108	17.5		
26	37 1/4	7:37	825.5	0.20	0.20	0.20	107	108	108	18.0		
27	38 1/4	7:38	826.5	0.20	0.20	0.20	107	108	108	18.5		
28	39 1/4	7:39	827.5	0.20	0.20	0.20	107	108	108	19.0		
29	40 1/4	7:40	828.5	0.20	0.20	0.20	107	108	108	19.5		
30	41 1/4	7:41	829.5	0.20	0.20	0.20	107	108	108	20.0		
31	42 1/4	7:42	830.5	0.20	0.20	0.20	107	108	108	20.5		
32	43 1/4	7:43	831.5	0.20	0.20	0.20	107	108	108	21.0		

Gainesville, Florida

SOURCE SAMPLING FIELD DATA SHEET


Mat'l Processing Rate _____
 Final Gas Meter Reading 891.013 ft³
 Initial Gas Meter Reading 821.213 ft³
 Total Condensate in Impingers 5.2 ml
 Moisture in Silica Gel _____ gm
 Silica Gel Container No. _____ Filter No. 27000/4

Orsat: CO₂ _____
 O₂ _____
 CO _____
 N₂ _____
 Excess Air _____

Test Conducted by: _____

Remarks: _____

(55)



Plant CORRUGATED STEEL (Sheet)
 Sampling Location Column
 Date 6-23-66 Run No. _____
 Time Start 08:45 Time End 09:00
 Sampling Time/Point 08:45/09:00 (110)
 DB 104 °F, WB _____ °F, VF @ DP _____ "Hg
 Moisture 33%, FDA _____, Gas Density Factor _____
 Barometric Press 29.8 "Hg, Stack Press 28.8 "Hg
 Weather Clear
 Temp. 80 °F, W/D _____, W/S _____
 Sample Box No. 1 Meter Box No. _____
 Meter ΔHe 1/4 Pitot Corr. Factor 0.85
 Nozzle Dia. 1/4 in., Probe Length 6 ft
 Probe Heater Setting _____

Stack Dimensions: Inside Diameter 24.5 in
 Inside Area 4.72 ft²
 Height 40 ft
Est. Area = 8349 ft²

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
<u>Port #1</u>		<u>08:45</u>	<u>847.285</u>									
<u>Point #1</u>	<u>1/4"</u>			<u>0.45</u>	<u>1.6</u>	<u>1.6</u>	<u>109</u>	<u>74</u>	<u>66</u>	<u>24.5</u>		<u>44.5</u>
<u>Point #2</u>	<u>1/4"</u>			<u>0.45</u>	<u>1.6</u>	<u>1.6</u>	<u>109</u>	<u>74</u>	<u>66</u>	<u>24.5</u>		<u>44.5</u>
<u>Point #3</u>	<u>1/4"</u>			<u>0.45</u>	<u>1.6</u>	<u>1.6</u>		<u>74</u>	<u>66</u>			
<u>Point #4</u>	<u>2 3/4"</u>			<u>0.45</u>	<u>1.6</u>	<u>1.6</u>		<u>74</u>	<u>66</u>			
<u>Point #5</u>	<u>2 3/4"</u>			<u>0.45</u>	<u>1.6</u>	<u>1.6</u>		<u>74</u>	<u>66</u>			
<u>Point #6</u>	<u>2 3/4"</u>			<u>0.45</u>	<u>1.6</u>	<u>1.6</u>	<u>109</u>	<u>74</u>	<u>66</u>	<u>24.5</u>		

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. (°F)		Sample - Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
Port #1												
1000000	5 3/8	09:15	8621	0.75			110			100	100	1
1000001	6 1/8	09:16	8622	0.75			110	72		100	100	1
1000002	8 1/8	09:17	8623	0.75			110			100	100	1
1000003	9 1/8	09:18	8624	0.75			110			100	100	1
1000004	11 1/8	09:19	8625	0.75			110	74	72	100	100	1
1000005	17 1/8	09:20	8626	0.75			110			100	100	1
1000006	19 1/8	09:21	8627	0.75			110	74	72	100	100	1
1000007	21 1/8	09:22	8628	0.75			110			100	100	1
1000008	23 1/8	09:23	8629	0.75			110	74	72	100	100	1
1000009	25 1/8	09:24	8630	0.75			110			100	100	1
1000010	27 1/8	09:25	8631	0.75			110	74	72	100	100	1
1000011	29 1/8	09:26	8632	0.75			110			100	100	1
1000012	31 1/8	09:27	8633	0.75			110	74	72	100	100	1
1000013	33 1/8	09:28	8634	0.75			110	74	72	100	100	1
1000014	35 1/8	09:29	8635	0.75			110	74	72	100	100	1
1000015	37 1/8	09:30	8636	0.75			110	74	72	100	100	1
1000016	39 1/8	09:31	8637	0.75			110	74	72	100	100	1
1000017	41 1/8	09:32	8638	0.75			110	74	72	100	100	1
1000018	43 1/8	09:33	8639	0.75			110	74	72	100	100	1
1000019	45 1/8	09:34	8640	0.75			110	74	72	100	100	1
1000020	47 1/8	09:35	8641	0.75			110	74	72	100	100	1
1000021	49 1/8	09:36	8642	0.75			110	74	72	100	100	1
1000022	51 1/8	09:37	8643	0.75			110	74	72	100	100	1
1000023	53 1/8	09:38	8644	0.75			110	74	72	100	100	1
1000024	55 1/8	09:39	8645	0.75			110	74	72	100	100	1
1000025	57 1/8	09:40	8646	0.75			110	74	72	100	100	1
1000026	59 1/8	09:41	8647	0.75			110	74	72	100	100	1
1000027	61 1/8	09:42	8648	0.75			110	74	72	100	100	1
1000028	63 1/8	09:43	8649	0.75			110	74	72	100	100	1
1000029	65 1/8	09:44	8650	0.75			110	74	72	100	100	1
1000030	67 1/8	09:45	8651	0.75			110	74	72	100	100	1
1000031	69 1/8	09:46	8652	0.75			110	74	72	100	100	1
1000032	71 1/8	09:47	8653	0.75			110	74	72	100	100	1
1000033	73 1/8	09:48	8654	0.75			110	74	72	100	100	1
1000034	75 1/8	09:49	8655	0.75			110	74	72	100	100	1
1000035	77 1/8	09:50	8656	0.75			110	74	72	100	100	1
1000036	79 1/8	09:51	8657	0.75			110	74	72	100	100	1
1000037	81 1/8	09:52	8658	0.75			110	74	72	100	100	1
1000038	83 1/8	09:53	8659	0.75			110	74	72	100	100	1
1000039	85 1/8	09:54	8660	0.75			110	74	72	100	100	1
1000040	87 1/8	09:55	8661	0.75			110	74	72	100	100	1
1000041	89 1/8	09:56	8662	0.75			110	74	72	100	100	1
1000042	91 1/8	09:57	8663	0.75			110	74	72	100	100	1
1000043	93 1/8	09:58	8664	0.75			110	74	72	100	100	1
1000044	95 1/8	09:59	8665	0.75			110	74	72	100	100	1
1000045	97 1/8	10:00	8666	0.75			110	74	72	100	100	1


Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
Port 12		05:10					100	11		100	11	
Port 6		05:11	836.7	0.16	0.1	0.1	100	11		100	11	
7		05:12	836.7	0.16	0.1	0.1	100	11		100	11	
8		05:13	836.7	0.16	0.1	0.1	100	11		100	11	
9		05:14	836.7	0.16	0.1	0.1	100	11		100	11	
10		05:15	836.7	0.16	0.1	0.1	100	11		100	11	
11		05:16	836.7	0.16	0.1	0.1	100	11		100	11	
12		05:17	836.7	0.16	0.1	0.1	100	11		100	11	
13		05:18	836.7	0.16	0.1	0.1	100	11		100	11	
14		05:19	836.7	0.16	0.1	0.1	100	11		100	11	
15		05:20	836.7	0.16	0.1	0.1	100	11		100	11	
16		05:21	836.7	0.16	0.1	0.1	100	11		100	11	
17		05:22	836.7	0.16	0.1	0.1	100	11		100	11	
18		05:23	836.7	0.16	0.1	0.1	100	11		100	11	
19		05:24	836.7	0.16	0.1	0.1	100	11		100	11	
20		05:25	836.7	0.16	0.1	0.1	100	11		100	11	
21		05:26	836.7	0.16	0.1	0.1	100	11		100	11	
22		05:27	836.7	0.16	0.1	0.1	100	11		100	11	
23		05:28	836.7	0.16	0.1	0.1	100	11		100	11	
24		05:29	836.7	0.16	0.1	0.1	100	11		100	11	
25		05:30	836.7	0.16	0.1	0.1	100	11		100	11	
26		05:31	836.7	0.16	0.1	0.1	100	11		100	11	
27		05:32	836.7	0.16	0.1	0.1	100	11		100	11	
28		05:33	836.7	0.16	0.1	0.1	100	11		100	11	
29		05:34	836.7	0.16	0.1	0.1	100	11		100	11	
30		05:35	836.7	0.16	0.1	0.1	100	11		100	11	
31		05:36	836.7	0.16	0.1	0.1	100	11		100	11	
32		05:37	836.7	0.16	0.1	0.1	100	11		100	11	
33		05:38	836.7	0.16	0.1	0.1	100	11		100	11	
34		05:39	836.7	0.16	0.1	0.1	100	11		100	11	
35		05:40	836.7	0.16	0.1	0.1	100	11		100	11	
36		05:41	836.7	0.16	0.1	0.1	100	11		100	11	
37		05:42	836.7	0.16	0.1	0.1	100	11		100	11	
38		05:43	836.7	0.16	0.1	0.1	100	11		100	11	

ENVIRONMENTAL ENGINEERING
Gainesville, Florida

SOURCE SAMPLING FIELD DATA SHEET

Plant Chargin Mat'l Processing Rate _____
Sampling Location _____
Date 11/11 Run No. _____
Time Start 11:11 Time End 12:00
Sampling Time/Point 11:11 (ft3)
DB 60 °F, WB _____ °F, VF @ DP _____ "Hg
Moisture 3.3%, FDA _____, Gas Density Factor _____
Barometric Press 28.8 "Hg, Stack Press 28.8 "Hg
Weather _____
Temp. 60 °F, W/D _____, W/S _____
Sample Box No. 1 Meter Box No. 1
Meter ΔH 1.0 Pitot Corr. Factor _____
Nozzle Dia. 1/4 in., Probe Length _____ ft
Probe Heater Setting _____
Stack Dimensions: Inside Diameter _____ in
Inside Area _____ ft²
Height _____ ft
Est. Area = 4.27 ft²
Test Conducted by: R. D. D. D. D.
Remarks: _____

Final Gas Meter Reading 1111 ft³
Initial Gas Meter Reading 1111 ft³
Total Condensate in Impingers 60 ml
Moisture in Silica Gel _____ gm
Silica Gel Container No. _____ Filter No. _____
Orsat: CO₂ _____
O₂ _____
CO _____
N₂ _____
Excess Air _____




Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1	1.0		0.000	0.000	1.0	1.0	116	60	60	60		
2	1.5		0.000	0.000	1.0	1.0	116	60	60	60		
3	1.5	11:13	0.000	0.000	1.0	1.0	116	60	60	60		
4	2.0	11:14	0.000	0.000	1.0	1.0	116	60	60	60		
5	2.5	11:15	0.000	0.000	1.0	1.0	116	60	60	60		
6	3.0	11:16	0.000	0.000	1.0	1.0	116	60	60	60		
7	3.5	11:17	0.000	0.000	1.0	1.0	116	60	60	60		
8	4.0	11:18	0.000	0.000	1.0	1.0	116	60	60	60		
9	4.5	11:19	0.000	0.000	1.0	1.0	116	60	60	60		
10	5.0	11:20	0.000	0.000	1.0	1.0	116	60	60	60		

Port and Infraverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head (H ₂ O)	Meter Orifice Press. Diff. (H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
Port 1	5.25	11:23	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 2	6.25	11:23	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 3	8.25	11:23	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 4	9.25	11:23	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 5	11.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 6	13.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 7	14.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 8	16.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 9	18.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 10	20.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 11	22.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 12	24.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 13	26.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 14	28.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 15	30.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 16	32.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 17	34.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 18	36.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 19	38.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 20	40.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 21	42.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 22	44.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 23	46.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 24	48.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 25	50.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 26	52.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 27	54.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 28	56.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 29	58.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 30	60.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 31	62.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 32	64.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 33	66.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 34	68.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 35	70.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 36	72.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 37	74.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 38	76.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 39	78.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 40	80.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 41	82.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 42	84.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 43	86.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 44	88.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 45	90.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 46	92.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 47	94.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 48	96.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 49	98.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0
Port 50	100.25	11:24	910.0	0.44	1.0	1.0	116	84.0	84.0	67	67	14.0

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Motor Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
Point #1		1:01		0.11	0.00	0.00	100			5.0	7	11
Point #2		1:00		0.11	0.00	0.00	99			7.5		
Point #3		1:06	994.8	0.15	0.14	0.00	117			10.0		
Point #4		1:12	990.0	0.11	0.00	0.00	110			12.5		
Point #5		1:12	994.9	0.11	0.00	0.00	110			15.0		
Point #6		1:12	998.4	0.13	0.10	0.00	117			2.5		
Point #7		1:13	990.0	0.11	0.00	0.00	114			5.0		
Point #8		1:13	990.0	0.11	0.00	0.00	114			7.5		
Point #9		1:14	994.6	0.11	0.00	0.00	114			10.0		
Point #10		1:14	996.9	0.11	0.00	0.00	114			12.5		
Point #11		1:14	994.4	0.11	0.00	0.00	114			15.0		
Point #12		1:14	994.4	0.11	0.00	0.00	114			2.5		
Point #13		1:14	994.4	0.11	0.00	0.00	114			5.0		
Point #14		1:14	994.4	0.11	0.00	0.00	114			7.5		
Point #15		1:14	994.4	0.11	0.00	0.00	114			10.0		
Point #16		1:14	994.4	0.11	0.00	0.00	114			12.5		
Point #17		1:14	994.4	0.11	0.00	0.00	114			15.0		
Point #18		1:14	994.4	0.11	0.00	0.00	114			2.5		
Point #19		1:14	994.4	0.11	0.00	0.00	114			5.0		
Point #20		1:14	994.4	0.11	0.00	0.00	114			7.5		
Point #21		1:14	994.4	0.11	0.00	0.00	114			10.0		
Point #22		1:14	994.4	0.11	0.00	0.00	114			12.5		
Point #23		1:14	994.4	0.11	0.00	0.00	114			5.0		
Point #24		1:14	994.4	0.11	0.00	0.00	114			7.5		
Point #25		1:14	994.4	0.11	0.00	0.00	114			10.0		
Point #26		1:14	994.4	0.11	0.00	0.00	114			12.5		
Point #27		1:14	994.4	0.11	0.00	0.00	114			5.0		
Point #28		1:14	994.4	0.11	0.00	0.00	114			7.5		
Point #29		1:14	994.4	0.11	0.00	0.00	114			10.0		
Point #30		1:14	994.4	0.11	0.00	0.00	114			12.5		

SOURCE SAMPLING FIELD DATA SHEET

Plant CEPAC Sampling Location 1000 G. Ave. (1000)
 Date 6-2-77 Run No. 1
 Time Start 6:50 Time End 7:15
 Sampling Time/Point 12:00
 DB 90 °F, WB 76 °F, VF @ DP 0.1 "Hg
 Moisture 2.6 %, FDA 97.4 %, Gas Density Factor 1
 Barometric Press 29.0 "Hg, Stack Press 29.0 "Hg
 Weather Cloudy
 Temp. 70 °F, W/D W/S
 Sample Box No. 1 Meter Box No. 1
 Meter AHg 17.1 Pitot Corr. Factor 0.0
 Nozzle Dia. 1/4 in., Probe Length 4 ft
 Probe Heater Setting ---
 Stack Dimensions: Inside Diameter 20 in
 Inside Area ft²
 Height ft



Mat'l Processing Rate 1000 ft³
 Final Gas Meter Reading 1000 ft³
 Initial Gas Meter Reading --- ft³
 Total Condensate in Impingers --- ml
 Moisture in Silica Gel --- gm
 Silica Gel Container No. --- Filter No. ---
 Orsat: CO₂ ---
 O₂ ---
 CO ---
 N₂ ---
 Excess Air ---
 Test Conducted by: ---


Remarks: ---

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
Port #1		6:50	330.425									
Point #1	1.75	6:55	335.6	0.11	2.0	2.0	27	71	71	---	48	4.0
Point #2	3.15	7:00	---	0.11	2.0	2.0	34	71	71	---	---	---
Point #3	3.15	7:05	346.2	0.94	2.0	2.0	28	71	71	---	---	---
Point #4	3.15	7:10	---	0.94	2.0	2.0	42	71	71	---	47	---
Point #5	3.15	7:15	358.3	0.95	2.0	2.0	44	71	71	---	---	---
Point #6	3.15	7:20	362.4	0.95	2.0	2.0	44	71	71	---	---	---
Point #7	3.15	7:25	367.7	0.95	2.0	2.0	44	71	71	---	---	---

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
Port #1												
Point #1		7:00	372.3	0.00			94				94	94
Point #2		7:00	372.9	0.00	2.0	2.0	94					94
Point #3		7:00	372.2	0.00	2.0	2.0	94					94
Point #4	24.5	7:00	—	0.00	2.0	2.0	94	71	71	—		94
Point #5		7:00	372.0	0.00	2.0	2.0	94					94
Point #6		7:00	372.0	0.00	2.0	2.0	94					94
Point #7		7:00	372.0	0.00	2.0	2.0	94					94
Point #8		7:00	372.0	0.00	2.0	2.0	94					94
Point #9		7:00	372.0	0.00	2.0	2.0	94					94
Point #10		7:00	372.0	0.00	2.0	2.0	94					94
Point #11		7:00	372.0	0.00	2.0	2.0	94					94
Point #12		7:00	372.0	0.00	2.0	2.0	94					94
Point #13		7:00	372.0	0.00	2.0	2.0	94					94
Point #14		7:00	372.0	0.00	2.0	2.0	94					94
Point #15		7:00	372.0	0.00	2.0	2.0	94					94
Point #16		7:00	372.0	0.00	2.0	2.0	94					94
Point #17		7:00	372.0	0.00	2.0	2.0	94					94
Point #18		7:00	372.0	0.00	2.0	2.0	94					94
Point #19		7:00	372.0	0.00	2.0	2.0	94					94
Point #20		7:00	372.0	0.00	2.0	2.0	94					94
Point #21		7:00	372.0	0.00	2.0	2.0	94					94
Point #22		7:00	372.0	0.00	2.0	2.0	94					94
Point #23		7:00	372.0	0.00	2.0	2.0	94					94
Point #24		7:00	372.0	0.00	2.0	2.0	94					94
Point #25		7:00	372.0	0.00	2.0	2.0	94					94
Point #26		7:00	372.0	0.00	2.0	2.0	94					94
Point #27		7:00	372.0	0.00	2.0	2.0	94					94
Point #28		7:00	372.0	0.00	2.0	2.0	94					94
Point #29		7:00	372.0	0.00	2.0	2.0	94					94
Point #30		7:00	372.0	0.00	2.0	2.0	94					94
Point #31		7:00	372.0	0.00	2.0	2.0	94					94
Point #32		7:00	372.0	0.00	2.0	2.0	94					94
Point #33		7:00	372.0	0.00	2.0	2.0	94					94
Point #34		7:00	372.0	0.00	2.0	2.0	94					94
Point #35		7:00	372.0	0.00	2.0	2.0	94					94
Point #36		7:00	37									

SOURCE SAMPLING FIELD DATA SHEET

Mat'l Processing Rate _____
 Final Gas Meter Reading _____ ft³
 Initial Gas Meter Reading _____ ft³
 Total Condensate in Impingers _____ ml
 Moisture in Silica Gel _____ gm
 Silica Gel Container No. _____ Filter No. _____
 Orsat: CO₂ _____
 O₂ _____
 CO _____
 N₂ _____
 Excess Air _____
 Test Conducted by: _____
 Remarks: _____



Plant _____
 Sampling Location _____
 Date _____ Run No. _____
 Time Start _____ Time End _____
 Sampling Time/Point _____
 Barometric Press _____ °F, WB _____ °F, VF @ DP _____ "Hg
 Moisture _____ % FDA 97.4, Gas Density Factor _____
 Barometric Press _____ "Hg, Stack Press _____ "Hg
 Weather _____
 Temp. _____ °F, W/D _____, W/S _____
 Sample Box No. _____ Meter Box No. _____
 Meter _____ Pitot Corr. Factor _____
 Nozzle Dia. _____ in., Probe Length _____ ft
 Probe Heater Setting _____
 Stack Dimensions: Inside Diameter _____ in
 Inside Area _____ ft²
 Height _____ ft

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
Port #1		8:45	949.362									
Port #1		8:50										
		8:55										
2		9:00	945.0									
		9:05	941.3									
3		9:10										
		9:15										
4		9:20										

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
Port #1		9:25	—	1.6	1.0	1.0	—	—	—	—	—	—
Port #1	112	9:30	121.5	1.6	—	1.0	—	—	—	—	—	6.0
Port #1		9:35	211.7	1.6	—	1.0	71	—	—	—	—	6.0
Port #1		9:40	317.2	1.6	—	1.0	71	—	—	—	50	6.0
Port #1		9:45	424.1	1.6	—	1.0	—	—	—	—	—	—
Port #1		10:05	—	—	—	—	—	—	—	—	—	—
Port #2		10:15	521.1	—	3.96	3.96	71	70	71	—	—	6.0
Port #2		10:15	624.7	0.80	3.96	2.96	71	70	71	—	54	6.0
Port #2		10:15	—	1.16	4.10	4.10	71	—	—	—	—	6.0
Port #2		10:20	747.0	1.0	4.10	4.10	—	70	71	—	53	6.0
Port #2		10:20	—	1.0	—	—	—	70	71	—	—	6.0
Port #2		10:20	850.0	1.0	—	—	—	70	71	—	—	6.0
Port #2		10:20	954.0	1.0	4.10	4.10	71	71	71	—	54	6.0
Port #2		10:20	1057.8	1.0	4.10	4.10	71	71	71	—	54	6.0
Port #2		10:20	—	1.0	4.10	4.10	71	71	71	—	—	6.0
Port #2		10:20	1158.7	1.0	4.10	4.10	71	71	71	—	54	6.0
Port #2		10:20	1259.4	1.0	4.10	4.10	71	71	71	—	54	6.0
Port #2		10:20	1360.0	1.0	4.10	4.10	71	71	71	—	54	6.0
Port #2		10:20	—	—	—	—	—	—	—	—	—	—
Port #2		10:20	—	—	—	—	—	—	—	—	—	—
Port #2		10:20	—	—	—	—	—	—	—	—	—	—
Port #2		10:20	—	—	—	—	—	—	—	—	—	—
Port #2		10:20	—	—	—	—	—	—	—	—	—	—
Port #2		10:20	—	—	—	—	—	—	—	—	—	—

Changed orifice manometer to 10 inch manometer.

SOURCE SAMPLING FIELD DATA SHEET

Plant 120
 Sampling Location 120
 Date 12/1/72 Run No. 1
 Time Start 12:30 Time End 12:45
 Sampling Time/Point 12:35 "Hg
 DB 71 °F, WB 71 °F, VF @ DP 71 "Hg
 Moisture 2.5%, FDA 97.4 Gas Density Factor 1
 Barometric Pressure 29.1 "Hg, Stack Press 29.1 "Hg
 Weather Clear
 Temp. 71 °F, W/D W/S
 Sample Box No. 1 Meter Box No. 1
 Meter AME Pitot Corr. Factor 1
 Nozzle Dia. 1/4 in., Probe Length 1 ft
 Probe Heater Setting 1
 Stack Dimensions: Inside Diameter 3 in
 Inside Area 7.07 ft²
 Height 1 ft

Mat'l Processing Rate 7777.77 ft³
 Final Gas Meter Reading 7777.77 ft³
 Initial Gas Meter Reading 0 ft³
 Total Condensate in Impingers 0 ml
 Moisture in Silica Gel 0 gm
 Silica Gel Container No. 1 Filter No. 1
 Orsat: CO₂ 0
 O₂ 0
 CO 0
 N₂ 0
 Excess Air 1
 Test Conducted by: AME

Remarks: 80

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter ("F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
Port #1	1	12:30	174.775	1.00	3.60	3.60	74	74	74	74	74	74
Port #1	1	12:35	174.775	1.00	3.60	3.60	74	74	74	74	74	74
2	2	12:40	174.775	1.00	3.60	3.60	74	74	74	74	74	74
2	2	12:45	174.775	1.00	3.60	3.60	74	74	74	74	74	74
3	3	12:50	174.775	1.00	3.60	3.60	74	74	74	74	74	74
3	3	12:55	174.775	1.00	3.60	3.60	74	74	74	74	74	74
4	4	1:00	174.775	1.00	3.60	3.60	74	74	74	74	74	74
4	4	1:05	174.775	1.00	3.60	3.60	74	74	74	74	74	74

[illegible]

SOURCE SAMPLING FIELD DATA SHEET

Plant Capitol, Inc.

Sampling Location San Antonio (C-1000)

Date 6-21-71 Run No. 1

Time Start 1850 Time End 2111

Sampling Time/Point 2.5 (30 sec) 1175

DB 91 °F, WB 71 °F, VF @ DP 0.56 "Hg

Moisture 2 %, FDA 2.2, Gas Density Factor

Barometric Press 28.73 "Hg, Stack Press 28.73 "Hg

Weather Clear - Cool

Temp. °F, W/D , W/S

Sample Box No. Meter Box No. 5

Meter ΔH@ 1.63 Pitot Corr. Factor 0.23

Nozzle Dia. 0.25 in., Probe Length 6 ft

Probe Heater Setting

Stack Dimensions: Inside Diameter 41.75 in

Inside Area ft²

Height ft

Mat'l Processing Rate

Final Gas Meter Reading 828.965 ft³

Initial Gas Meter Reading 796.300 ft³

Total Condensate in Impingers 11 ml

Moisture in Silica Gel gm

Silica Gel Container No. Filter No.

Orsat: CO₂

O₂

CO

N₂

Excess Air

Test Conducted by: W. D. L. A.

Remarks:

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
101		1850	2207-500	0.22	—	—	—	—	—	—	—	—
102		1855	2207-500	0.22	0.20	0.20	80	77	77	—	71	2
103		1858	2207-500	0.22	0.20	0.20	80	77	77	—	71	2
104		1859.5	2207-500	0.20	0.15	0.15	80	77	77	—	71	8
105		1900	2207-500	0.20	0.15	0.15	80	77	77	—	71	8
106		1902	2207-500	0.20	0.15	0.15	80	77	77	12.5	71	2
107		1903	2207-500	0.20	0.15	0.15	80	77	77	13	71	2


Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
18		1937.0	807.4	0.27	1.0	6.0	85	77	77	2.5	77	6.6
19		1940	809.1	0.27	1.0	6.0	85	77	77	3.0	77	6.5
20		1943.5	810.5	0.27	1.0	6.0	85	77	77	7.5	77	
21		1943.8	813.8	0.27	1.0	6.0	85	77	77	10.0	77	6.2
22		1945.5	816.9	0.27	1.0	6.0	85	77	77	12.5	77	6.5
23		1948	818.3	0.27	1.0	6.0	85	77	77	15.0	77	6.5
24		1948.5	819.6	0.27	1.0	6.0	85	77	77	2.5	77	5
25		1948.8	820.2	0.27	1.0	6.0	85	77	77	7.5	77	5
26		1949.5	826.6	0.27	1.0	6.0	85	77	77	10.0	77	4
27		1950.5	827.9	0.27	1.0	6.0	85	77	77	15.0	77	4.5
28		1951.5	830.2	0.27	1.0	6.0	85	77	77	2.5	77	4.5
29		1953.5	832.6	0.27	1.0	6.0	85	77	77	5.0	77	4.5
30		1955.5	837.9	0.27	1.0	6.0	85	77	77	7.5	77	4.5
31		1958	840.9	0.27	1.0	6.0	85	77	77	10.0	77	4.5
32		1958.5	840.9	0.27	1.0	6.0	85	77	77	15.0	77	4.5
33		2001	832.4	0.07	0.26	0.76	85	77	77	2.5	77	4.5
34		2001.5	833.2	0.08	0.26	0.76	85	77	77	5.0	77	4.5
35		2002.1	834.9	0.07	0.26	0.76	85	77	77	7.5	77	4.5
36		2002.5	836.5	0.07	0.26	0.76	85	77	77	10	77	4.5
37		2003.5	835.7	0.07	0.26	0.76	85	77	77	12.5	77	4.5
38		2004.5	835.7	0.07	0.26	0.76	85	77	77	15	77	4.5

* Filter stopped and replaced (filter holder and filter).
(Filter was of 1/4" size)

[illegible]

SOURCE SAMPLING FIELD DATA SHEET

Plant CARGILL, INC.
Sampling Location PAN COOLER (CENTRE)
Date 6-22-72 Run No. 2
Time Start 0800 Time End 1105
Sampling Time/Point 2.5 (TOTAL=12.5)
DB 74 °F, WB 70 °F, VF @ DP 1105 "Hg
Moisture 2 %, FDA 2 %, Gas Density Factor 1.0
Barometric Press: 29.9 "Hg, Stack Press 28.9 "Hg
Weather Cloudy
Temp: 74 °F, W/D 1, W/S 1
Sample Box No. 5 Meter Box No. 5
Meter ΔH 1.68 Pitot Corr. Factor 0.83
Nozzle Dia. 0.25 in., Probe Length 6 ft
Probe Heater Setting Off
Stack Dimensions: Inside Diameter 41.75 in
Inside Area 13.7 ft²
Height 10 ft



Mat'l Processing Rate 936.260 ft³
Final Gas Meter Reading 936.260 ft³
Initial Gas Meter Reading 0.000 ft³
Total Condensate in Impingers 10 ml
Moisture in Silica Gel — gm
Silica Gel Container No. — Filter No. 2002
Orsat: CO₂ —
O₂ —
CO —
N₂ —
Excess Air —
Test Conducted by: R. D. H. / J. H. H.
Remarks: —

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1	—	0815	839.035	0.30	1.15	1.15	80	74	74	74	—	—
2	—	0830	840.035	0.30	1.15	1.15	70	74	74	74	—	—
3	—	0845	840.035	0.30	1.15	1.15	70	74	74	74	—	—
4	—	0900	840.035	0.30	1.15	1.15	70	74	74	74	—	—
5	—	0915	840.035	0.30	1.15	1.15	70	74	74	74	—	—
6	—	0930	840.035	0.30	1.15	1.15	70	74	74	74	—	—

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. (°F) Gas Meter		Sample -Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum On Sample Train
					Calc.	Actual		In	Out			
7		0909.5	897.1	0.37	1.33	1.33	90	74	66	2.5	70	4
8		0909.7	897.5	0.37	1.33	1.33	90	74	66	3.0	70	4
9		0909.8	897.5	0.37	1.33	1.33	90	74	66	7.5	70	4
10		0910	898.0	0.37	1.33	1.33	90	74	66	19	70	4
11		0910.2	897.3	0.38	1.33	1.33	90	74	66	13.5	70	4
12		0910.3	897.6	0.39	1.33	1.33	90	74	66	13.5	70	4
13		0910.4	897.9	0.39	1.33	1.33	90	74	66	13.5	70	4
14		0910.6	898.4	0.39	1.33	1.33	90	74	66	5	70	4
15		0910.7	898.5	0.39	1.33	1.33	90	74	66	7.5	70	4
16		0910.8	897.3	0.40	1.33	1.33	90	74	66	10	70	4
17		0910.9	899.2	0.41	1.33	1.33	90	74	66	10.5	70	4
18		0911.0	899.6	0.41	1.33	1.33	90	74	66	15	70	4
19		0911.1	899.6	0.41	1.33	1.33	90	74	66	15	70	4
20		0911.2	899.3	0.41	1.33	1.33	90	74	66	15	70	4
21		0911.3	897.3	0.42	1.33	1.33	90	74	66	7.5	70	4
22		0911.4	897.3	0.42	1.33	1.33	90	74	66	10	70	4
23		0911.5	898.3	0.42	1.33	1.33	90	74	66	10	70	4
24		0911.6	898.2	0.42	1.33	1.33	90	74	66	10	70	4
Port 2		1005										
(4.1)		—	—	0.39	1.33	1.33	90	74	66	10.5	70	4
2		1010	905.0	0.10	0.39	0.39	90	74	66	5	70	4
3		1012.5	906.1	0.11	0.42	0.42	90	74	66	2.5	70	4
4		1015	906.9	0.10	0.38	0.38	90	74	66	10	70	4
5		1017.6	908.0	0.12	0.45	0.45	90	74	66	12.5	70	4

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head (ft ₂₀)	Meter Orifice Press. Diff. (in ₂₀)		Stack Gas Temp. (°F)	Gas Sample Temp. (°F)		Sample Bar Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
6		1030	907.1	0.17	0.17	0.17	92	73	73	13	72	
7		1031.5	910.3	0.17	0.17	0.17	92	73	73	13	72	
8		1033	916.5	0.16	0.16	0.16	92	73	73	13	72	
9		1034.5	917.7	0.16	0.16	0.16	92	73	73	13	72	
10		1036	919.2	0.23	0.23	0.23	92	73	73	13	72	
11		1037.5	915.8	0.23	1.02	1.02	92	73	73	13	72	
12		1035	—	0.23	1.02	1.02	92	73	73	13	72	
13		1037.5	919.6	0.23	1.02	1.02	92	73	73	13	72	
14		1040	921.1	0.23	1.02	1.02	92	73	73	13	72	
15		1042.5	922.6	0.23	1.02	1.02	92	73	73	13	72	
16		1045	924.2	0.23	1.02	1.02	92	73	73	13	72	
17		1047.5	925.8	0.23	0.95	0.95	92	73	73	13	72	
18		1050	927.3	0.23	1.02	1.02	92	73	73	13	72	
19		1052.5	929.0	0.23	1.02	1.02	92	73	73	13	72	
20		1055	930.6	0.23	1.15	1.15	92	73	73	13	72	
21		1057.5	932.1	0.27	1.02	1.02	92	73	73	13	72	
22		1100	933.6	0.23	1.02	1.02	92	73	73	13	72	
23		1101.5	935.2	0.23	1.02	1.02	92	73	73	13	72	
24	—	1103	936.8	0.23	1.02	1.02	92	73	73	13	72	
25		1105	938.4	0.23	1.02	1.02	92	73	73	13	72	
26		1107	940.0	0.23	1.02	1.02	92	73	73	13	72	
27		1109	941.6	0.23	1.02	1.02	92	73	73	13	72	
28		1111	943.2	0.23	1.02	1.02	92	73	73	13	72	
29		1113	944.8	0.23	1.02	1.02	92	73	73	13	72	
30		1115	946.4	0.23	1.02	1.02	92	73	73	13	72	
31		1117	948.0	0.23	1.02	1.02	92	73	73	13	72	
32		1119	949.6	0.23	1.02	1.02	92	73	73	13	72	
33		1121	951.2	0.23	1.02	1.02	92	73	73	13	72	
34		1123	952.8	0.23	1.02	1.02	92	73	73	13	72	
35		1125	954.4	0.23	1.02	1.02	92	73	73	13	72	
36		1127	956.0	0.23	1.02	1.02	92	73	73	13	72	
37		1129	957.6	0.23	1.02	1.02	92	73	73	13	72	
38		1131	959.2	0.23	1.02	1.02	92	73	73	13	72	
39		1133	960.8	0.23	1.02	1.02	92	73	73	13	72	
40		1135	962.4	0.23	1.02	1.02	92	73	73	13	72	
41		1137	964.0	0.23	1.02	1.02	92	73	73	13	72	
42		1139	965.6	0.23	1.02	1.02	92	73	73	13	72	
43		1141	967.2	0.23	1.02	1.02	92	73	73	13	72	
44		1143	968.8	0.23	1.02	1.02	92	73	73	13	72	
45		1145	970.4	0.23	1.02	1.02	92	73	73	13	72	
46		1147	972.0	0.23	1.02	1.02	92	73	73	13	72	
47		1149	973.6	0.23	1.02	1.02	92	73	73	13	72	
48		1151	975.2	0.23	1.02	1.02	92	73	73	13	72	
49		1153	976.8	0.23	1.02	1.02	92	73	73	13	72	
50		1155	978.4	0.23	1.02	1.02	92	73	73	13	72	

SOURCE SAMPLING FIELD DATA SHEET

Plant 6000111
Sampling Location 1000 1000
Date 10/1/73 Run No. 3
Time Start 12:30 Time End 14:40
Sampling Time/Point 12:30 12:30
DB °F, WB °F, VF @ DP "Hg
Moisture 2 %, FDA , Gas Density Factor
Barometric Press "Hg, Stack Press 28.91 "Hg
Weather
Temp. °F, W/D , W/S
Sample Box No. Meter Box No.
Meter ΔHQ 1.68 Pitot Corr. Factor 0.83
Nozzle Dia. 1.25 in., Probe Length 6 ft
Probe Heater Setting
Stack Dimensions: Inside Diameter 11.25 in
Inside Area ft²
Height ft

Nat'l Processing Rate

Final Gas Meter Reading 1.95.00 ft³
Initial Gas Meter Reading 1.95.00 ft³
Total Condensate in Impingers 0.00 ml
Moisture in Silica Gel --- gm
Silica Gel Container No. --- Filter No. ---
Orsat: CO₂ _____
O₂ _____
CO _____
N₂ _____
Excess _____
Air _____
Test Conducted by: _____

Test Conducted by:

Remarks: *Yellowish, cylindrical, jointed, 1/2 in. long, 1/4 in. diam. at base, 1/8 in. at tip. No odor, no taste. No effect on litmus. No effect on litmus. No effect on litmus.*

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample-Box-Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1												
2												
3		12:37.5	941.8	0.333	1.4	1.4	80	76	76	5.0	77	
4		12:37	941.8	0.333	1.35	1.35	80	75	76	7.5	74	2.5
5		12:37	943.7	0.39	1.35	1.35	80	75	76	10	74	5
6		12:32	946.6	0.40	1.3	1.3	80	76	76	12.5	74	5
7		12:46	947.5	0.43	1.60	1.60	80	77	77	15	74	

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
7		12:41	949.5	0.360	1.85	1.85	72	83	77	2.5	75	
8		12:42	944.5	0.360	1.85	1.85	86	83	77	5	75	
9		12:42	953.4	0.360	1.85	1.85	83			7.5	75	
10		12:43	955.1	0.360	1.4	1.4	87			10	75	
11		12:44	957.1	0.360	1.85	1.85	83	87	80	10.5	75	
12		12:45	959.8	0.360	1.85	1.85	130	12	72	10	75	
13		12:45	960.5	0.360	1.4	1.4	130	12	72	10	75	
14		12:45	962.3	0.40	1.5	1.5	132	87	79	5	80	
15		12:47	964.2	0.360	1.4	1.4	134	87	79	7.5	80	
16		12:48	965.2	0.360	1.4	1.4	134	87	79	10	80	
17		12:48	967.7	0.360	1.4	1.4	132	89	80	12.5	80	
18		12:48	969.5	0.360	1.4	1.4	132	89	80	15	80	
19		12:49	971.3	0.360	1.4	1.4	132	89	80	2.5	80	
20		12:49	973.2	0.40	1.5	1.5	132	89	80	5	80	
21		12:49	975.1	0.360	1.45	1.45	132	89	80	7.5	80	
22		12:49	976.9	0.360	1.4	1.4	132	89	80	10	80	
23		12:49	979.6	0.360	1.4	1.4	132	89	80	10.5	80	
24		12:49	981.4	0.360	1.4	1.4	132	89	80	10	80	
Oct-2		12:49										
Pt. 1												
2		12:49	982.5	0.360	1.4	1.4	132	89	80	0.5	80	
3		12:49	983.5	0.360	0.41	0.41	132	89	80	7.5	80	
4		12:49	984.7	0.360	0.42	0.42	132	89	80	14	80	

2.5 min
 Oct-2
 10:45
 10:45

Port and Traverse Point No.	Distance from End of Port (in)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head ("H ₂ O)	Meter Orifice Press. Diff. ("H ₂ O)		Stack Gas Temp. (°F)	Gas Sample Temp. Gas Meter (°F)		Sample Wet Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train
					Calc.	Actual		In	Out			
5		1352.2	985.7	0.14	0.8	0.65	78	81	81	12.5	70	5
6		1353.5	986.9	0.15	0.8	0.65	78	81	81	15	70	5
7		1357.5	988.2	0.13	0.8	0.65	78	81	81	2.5	70	5
8		1400	987.6	0.13	0.8	0.65	78	81	81	5	70	5
9		1402.5	991.0	0.24	0.70	0.65	150	81	81	2.5	70	5
10		1408	992.5	0.24	0.70	0.65	150	81	81	10	70	5
11		1407.5	994.3	0.30	0.70	0.65	150	81	81	10.5	70	5
12		1410	996.5	0.35	0.70	0.65	150	81	81	15	70	5
13		1412	998.3	0.39	0.70	0.65	150	81	81	2.5	70	5
14		1414	999.8	0.35	0.70	0.65	150	81	81	5	70	5
15		1415	1001.5	0.35	0.70	0.65	150	81	81	10.5	70	5
16		1420	1003.1	0.39	0.70	0.65	150	81	81	10	70	5
17		1422	—	0.39	0.70	0.65	150	81	81	10.5	70	5
18		1425	1006.7	0.39	0.70	0.65	150	81	81	15	70	5
19		1427.5	1008.3	0.39	0.70	0.65	150	81	81	2.5	70	5
20		1430	1009.7	0.39	0.70	0.65	150	81	81	5	70	5
21		1432.5	1011.3	0.39	0.70	0.65	150	81	81	7.5	70	5
22		1435	1012.7	0.39	0.70	0.65	150	81	81	10	70	5
23		1437.5	1015.23	0.20	0.70	0.65	150	81	81	10.5	70	5
24		1440	1016.5	0.39	0.70	0.65	150	81	81	10.5	70	5

APPENDIX D

Complete Sampling Procedures

COMPLETE SAMPLING PROCEDURES FOR PARTICULATE STACK EMISSIONS

Sampling Procedure

Prior to performing the actual particulate emission tests, certain preliminary stack parameters had to be estimated or determined for the source. This preliminary data included the average temperature, velocity head, moisture content, stack diameter, and number of sampling points.

The stack gas temperature was determined by using bimetallic thermometers and mercury bulb thermometers.

Velocity head measurements were determined across the stack diameter by using a calibrated S-type pitot tube with an inclined manometer. This data was used to select the sampling nozzle diameter.

The approximate moisture content of the stack gas was determined by the wet bulb and dry bulb thermometer technique.

The sampling traverse points were selected according to Method 1 of the Federal Register (Volume 36, Number 247, Part II, December 23, 1971).

The stack emissions were sampled by using the following sample train: a stainless steel nozzle; a glass-lined probe; a Gelman Type A glass fiber filter; two impingers with 100 ml of distilled water; two dry impingers (the second impinger had a standard tip, while the first, third and fourth impingers had modified tips with 1/2-inch ID openings);

a thermometer on the last impinger; a flexible sample line; an air-tight pump; a dry test meter; and finally, a calibrated orifice with an inclined manometer. Figure 6 shows a schematic arrangement of the sampling train.

Silica gel was not used in the fourth impinger because it did not arrive with the equipment, and there was none available in the area. After discussion with the Project Officer it was decided to test without silica gel since the moisture was near ambient. The moisture for calculations was determined by the use of the wet and dry bulb method.

Because the stack temperature was less than 100°F and the moisture content was low, the probe and the filter holder portions of the sampling train were not heated.

The impinger portion of the sampling train was iced down to collect the condensable moisture in the stack gas.

Each point sampled across the stack diameter was sampled at an isokinetic sampling rate.

Sample Recovery

Samples were recovered in accordance with procedures outlined in Method 5 of the Federal Register (36 F.R., March 31, 1971), Determination of Particulate Emissions from Stationary Sources.

The sampling train glassware, exclusive of the glass lined probe and the fritted disc filter, were soaked in chromic acid cleaning solution for two hours previous to the preparation of sample blanks. The probes were thoroughly washed in chromic acid solution prior to testing

but were not soaked due to their cumbersome length. All sampling glassware was rinsed extensively with distilled water following the acid wash.

All samples were turned over to the Project Officer for additional labeling and analysis.




Figure 6.

APPENDIX E

Field Test Log

FIELD TEST LOG

6/18/72 Left Orlando at 1530 EDST, arrived in Sioux City at 2230 CDST.

6/19/72 Went by to pick up equipment. Nine of the twelve boxes made it. Probes, silica gel, tools, and umbilical cord did not make it.

We met with Tom Ward and plant officials to discuss sampling program. Unloaded equipment and proceeded to get material for building stack extensions and straightening vanes.

Called office and requested additional probes.

6/20/72 Finished setting up sampling equipment and building stack extensions.

Probes arrived at 1015. We were ready to sample the Hammer Mill Outlet after noon. We were requested to wait until two EPA engineers arrived so that comparative tests could be made with the EPA train and a modified hi-vol sampler.

After the EPA sampler was set up and we leak tested our train, we began testing at 2030. No silica gel was used.

Because the flow rate from the storage bin was not detectable with the velometer (less than 10 f.p.m.), EPA did not request any tests using a hi-vol sampler.

Test ended at 2302.

6/21/72 Second test on the Hammer Mill began at 0955, and ended at 1145. Third test began at 1210 and ended at 1350.
We had to wait on plant process before sampling.
The first run (inlet and outlet) on the Pan Cooler began at 1850 and ended at 2110.

6/22/72 Second run on Pan Cooler began at 0845, ended at 1105.
Third run began at 1232, and ended at 1440.
We began first test on the Column Cooler (Inlet and Outlet) at 1725, and plant shut down 1735 and was down until 1802.
We continued sampling and finished at 1951.

6/23/72 Second test on Column Cooler began at 0750 and ended at 1000. Third run began at 1100 and shut down at 1200 because of plant shutdown. We resumed sampling at 1320 and ended at 1420.
After cleanup and packing equipment, we gave the EPA Project Officer the samples.

6/24/72 We left Sioux City at 0730, and arrived in Gainesville at 1530.

APPENDIX F

Project Participants

PROJECT PARTICIPANTS

Environmental Engineering, Inc.

<u>Name</u>	<u>Title</u>
John Koogler, Ph.D., P.E.	Project Director
John Dollar, EIT, M.S.	Project Manager
George Allen, Sr. Technician	Environmental Specialist
Robert Durgan, Sr. Technician	Environmental Specialist
Eric Johnson, Sr. Technician	Environmental Specialist

Environmental Protection Agency

<u>Name</u>	<u>Title</u>
Thomas E. Ward	Project Test Officer
Ken Woodard	Project Engineer