

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section Number: 9.9.4

Reference Number: 8

Title: Source Emissions Report For
Gothenburg Feed Products Co.,
Gothenburg, NE

AirSource Technologies

AirSource Technologies

October 1993

PLANT #1

SOURCE EMISSIONS REPORT
for
GOTHENBURG FEED PRODUCTS CO.
Gothenburg, Nebraska

prepared by
AirSource Technologies

11635 W. 83rd Terrace
Lenexa, Kansas 66214

AirSource Project No. 411922

PREFACE


This report was prepared by AirSource Technologies in response to a test that was conducted at the Gothenburg Feed Products Co. in Gothenburg, Nebraska on August 31, 1993. Any questions concerning this report should be directed to Mr. Blane Wood, Project Manager, or to Mr. George Cobb, General Manager.

AirSource Technologies



Blane Wood
Project Manager

Approved



George R. Cobb
General Manager

Date: October 8, 1993

SECTION 1

INTRODUCTION

A stack test was conducted by AirSource Technologies on the Gothenburg Feed Products Co. alfalfa dehydrating plant in Gothenburg, Nebraska on August 31, 1993.

The AirSource Technologies personnel who conducted the test were: Mr. Blane Wood, Project Manager and Mr. Tim Titus, Environmental Scientist.

The results of the test were used to evaluate the process' performance with regards to the particulate emission rate.

The appendices contain the following:

Appendix A:	Example Calculations
Appendix B:	Computer Forms
Appendix C:	Particulate Field Data Forms
Appendix D:	Laboratory and Analysis Forms
Appendix E:	Pretest Calibrations
Appendix F:	Posttest Calibrations
Appendix G:	Process Data

SECTION 2

SUMMARY OF RESULTS

The results of the particulate emissions are: 15.62 lb/hr, 28.46 lb/hr, and 13.2 lb/hr for Runs 1, 2 and 3 respectively.

Run 1 did not meet the $\pm 10\%$ of 100% isokinetic criteria. For the purposes of this study, the data should still give an indication of particulate loading. The results are biased low.

The sampling and particulate results are shown in Table 1.

Table 1
SUMMARY OF SAMPLING AND PARTICULATE RESULTS
Gothenburg Feed Products Co.
Gothenburg, Nebraska

Parameters	Unit of Measure	Run 1	Run 2	Run 3
Particulate Emissions				
Front Half	gr/dscf	0.0746	0.1440	0.0624
Uncorrected	gr/dscf	0.3480	0.6719	0.2494
Corrected to 7% O ₂	gr/dscf	0.5965	1.1518	0.4989
Emission Rate	lb/hr	15.62	28.46	13.28
Weight	grams	0.1883	0.3865	0.1828
Isokinetics	%	81.9	92.3	93.5
Stack Flow Rate				
Actual	acfm	38,559	39,350	38,248
Standard Conditions	dscfm	24,452	23,066	24,845
Velocity	ft/min.	4,008	4,090	3,975
Sampling Results				
Sampling Volume	dscf	38.891	41.343	45.142
Avg. Stack Temperature	°F	162	183	154
Avg. ΔP	inches H ₂ O	1.041	1.032	1.039
Avg. ΔH	inches H ₂ O	1.48	1.69	2.03
Avg. Meter Temperature	°F	63	75	80
Oxygen, Orsat	%	18.0	18.0	17.5
Carbon Dioxide, Orsat	%	1.5	1.5	1.5
Static Pressure	inches H ₂ O	0.65	0.65	0.65
Moisture Collected	ml	203.5	265.7	221.6
Moisture	% H ₂ O	19.8	23.2	18.8
Sampling Time	min.	60	60	60

SECTION 3

PROCESS OPERATION

The alfalfa dehydration plant is a 12 foot MEC three pass dryer. The control equipment used is a single compartment baghouse and a 12 foot diameter cyclone. The condition for each of the test runs were the same.

Table 2 summarizes the results of the process operations and Table 3 presents the process data collected during the testing.

Table 2
SUMMARY OF RESULTS
Process Operation

Historical Average Process Weight (pellets)	12,000 lb/hr
Historical Maximum Process Weight (pellets)	16,000 lb/hr
Type of Fuel Normally Burned	Natural Gas
Approximate Quantity of Fuel Burned Annually	59,500 MCF
Actual Production (pellets)	4.36 TPH
Rated Water Production	25,000 lb/hr
Actual Water Production	9,962 lb/hr
Baghouse - 1 compartment positive pressure	
Type of Cleaning	Reverse Air
Clean Cycle	2 minute
Average baghouse ΔP	3.3 in. H ₂ O
Fan	
Rated H.P.	25 H.P.
Operating Volts	460 Volts
Operating Amps	18 amps

Table 3
PROCESS DATA

	Hay Moisture %	Scale Reading	Pellet Moisture %
08:45	57	255506	8.58
09:00	58	255535	6.42
09:15	60.5	255557	6.26
09:30	61.5	255577	6.04
09:45	60	255600	6.37
10:00	61.5	256627	5.88
10:15	59.5	255648	5.70
10:30	62	255668	6.37
10:45	58	255695	6.16
11:00	59	255718	<5.00
11:15	56	255745	<5.00
11:30		255768	<5.00
11:45		255791	5.68
14:15	38.5	256055	6.77
14:30	37.5	256090	5.53
14:45	37.9	256115	6.72
15:00	31.0	256143	6.90
15:15	35.6	256176	7.70

SECTION 4


SAMPLING AND ANALYTICAL PROCEDURES

Particulates

EPA Methods 1-4 were used for the determination of traverse point locations, velocities and flows of stack gas, oxygen, carbon dioxide, and moisture. The particulate sampling and recovery of the samples were done according to EPA Method 5 recovery procedures.

Figure 1 shows a schematic of the sampling train.

Figure 2 shows a schematic of the stack and traverse locations.




Schematic of Method 5 sampling train.

Stack dimensions - Gothenburg Feed Products Co.

Inside diameter 42"
Port length 3"

Sampling Port Location

- 8 Diameters upstream from disturbance
- 2 Diameters downstream from disturbance



**Traverse Point Locations
(Excluding Port Length)**

1.	1.8"	4.	29.5"
2.	6.1"	5.	35.9"
3.	12.4"	6.	40.2"

Figure 2

APPENDIX A

EXAMPLE CALCULATIONS

NOMENCLATURE

<u>Equation No.</u>	<u>Symbol</u>	<u>Description</u>	<u>Units</u>
1	V_i	Initial meter reading	dcf
	V_f	Final meter reading	dcf
	V_m	Volume meter, actual	dcf
2	P_b	Barometric pressure	in. Hg
	ΔH_{avg}	Average orifice pressure drop	in. H ₂ O
	$T_{m_{avg}}$	Average meter temperature	°F
	$V_{m_{std}}$	Volume meter, standard conditions	dscf
3	V_{lc}	Total moisture collected	grams
	$V_{w_{std}}$	Volume of water vapor collected, standard conditions	ft ³
	% H ₂ O	Percent moisture by volume	-
4	M_f	Mole fraction of dry gas	-
5	% CO ₂	Percent carbon dioxide by volume, dry	-
	% O ₂	Percent oxygen by volume, dry	-
	% CO	Percent carbon monoxide by volume, dry	-
	% N ₂	Percent nitrogen by volume, dry	-
6	M_d	Molecular weight, dry stack gas	lb/lb-mole
7	M_s	Molecular weight, stack gas	lb/lb-mole
8	Θ_i	Sampling time interval	minutes
	D_n	Diameter of nozzle	inches
	ΔP_s	Velocity head of S pitot	in. H ₂ O
	T_s	Temperature of stack gas	°F
	V_{m_i}	Volume of meter per sampling interval	ft ³
9	P_s	Stack pressure, absolute	in. Hg
	P_g	Stack gas pressure	in. H ₂ O
10	$\Delta P_{s_{avg}}$	Average velocity head of S pitot	in. H ₂ O
	$T_{s_{avg}}$	Average temperature of stack gas	°F
	V_s	Average stack gas velocity	fpm
11	Θ	Total time of test	minutes
	% I	Percent isokinetic	-
12	ID	Inside diameter of stack	inches
	As	Area of stack	in ²
13	Q_s	Stack flow rate, dry standard conditions	dscfm
14	m_n	Total particulate matter collected	mg
	$C_{s_{std}}$	Concentration of particulate collected, dry basis, standard conditions	gr/dscf

15	$C_{sd}(\text{corr } 7\% \text{ O}_2)$	Concentration of particulate collected, dry basis standard conditions	gr/dscf (corr to 7% O ₂)
16	$C_{sd}(\text{corr } 12\% \text{ CO}_2)$	Concentration of particulate collected, dry basis standard condition	gr/dscf (corr to 12% CO ₂)
17	C_{sd}	Concentration of particulate collected, actual conditions	gr/acf
18	E_p	Particulate emission rate	lb/hr

PARTICULATE CALCULATION EQUATIONS

$$1. \quad V_m \approx V_f - V_i$$

$$2. \quad V_{m(std)} = \frac{17.64 (V_m) Y \left(P_b + \frac{\Delta H_{avg}}{13.6} \right)}{T_{m(avg)} + 460}$$

$$3. \quad V_{wc(std)} = 0.0471(V_{ic})$$

$$\% H_2O = \frac{100(V_{wc(std)})}{V_{m(std)} + V_{wc(std)}}$$

$$4. \quad M_f = \frac{100 - \%H_2O}{100}$$

$$5. \quad \% N_2 = 100 - (\%CO_2 + \%O_2 + \%CO)$$

$$6. \quad M_d = (\%CO_2 \times 0.44) + (\%O_2 \times 0.32) + (\%N_2 + \%CO \times 0.28)$$

$$7. \quad M_s = (M_d \times M_p) + 18(1 - M_p)$$

$$8. \quad V_{mi} = \frac{5.168(T_m + 460)(C_p)(\theta_i)(M_p)(D_n^2)}{\sqrt{P_b}} \times \sqrt{\frac{\Delta P_s}{T_s + 460}}$$

$$9. \quad P_s = P_b + \frac{P_g}{13.6}$$

$$10. \quad V_s = 5128.8 \times C_p \times \left(\sqrt{\Delta P_{s(avg)}} \right) \times \sqrt{\frac{T_{s(avg)} + 460}{P_s \times M_s}}$$

$$11. \quad \% I = \frac{1039(T_{s(avg)} + 460)(V_{m(std)})}{V_s(\theta)(P_s)(M_p)(D_n^2)}$$

$$12. \quad A_s = \pi \left(\frac{ID}{2} \right)^2$$

$$13. \quad Q_s = \frac{0.122(V_s)(A_s)(M_p)(P_s)}{T_{s(avg)} + 460}$$

$$14. \quad C_{s(std)} = 0.0154 \left(\frac{M_n}{V_{m(std)}} \right)$$

$$15. \quad C_{s(act)} = \frac{17.64(C_{s(std)})(P_s)(M_p)}{T_{s(avg)} + 460}$$

$$16. \quad E_p = 0.00857(C_{s(std)})(Q_s)$$

APPENDIX B

COMPUTER FORMS

FILE NAME - GOTHENBURG.R1
RUN # - GOTHENBURG RUN 1
LOCATION - DRYER STACK
DATE - AUGUST 31, 1993
PROJECT # - 411922

PROG.=VER 06/27/89
09-29-1993 10:52:26

Initial Meter Volume (Cubic Feet)=	605.520
Final Meter Volume (Cubic Feet)=	646.069
Meter Factor=	1.019
Final Leak Rate (cu ft/min)=	0.013
Net Meter Volume (Cubic Feet)=	41.319
Gas Volume (Dry Standard Cubic Feet)=	38.891

Barometric Pressure (in Hg)=	27.79
Static Pressure (Inches H2O)=	0.65

Percent Oxygen=	18.0
Percent Carbon Dioxide=	1.5
Moisture Collected (ml)=	203.5
Percent Water=	19.8

Average Meter Temperature (F)=	63
Average Delta H (in H2O)=	1.48
Average Delta P (in H2O)=	1.041
Average Stack Temperature (F)=	162

Dry Molecular Weight=	28.96
Wet Molecular Weight=	26.79

Average Square Root of Delta P (in H2O)=	1.0191
% Isokinetic=	81.9

Pitot Coefficient=	0.84
Sampling Time (Minutes)=	60.0
Nozzle Diameter (Inches)=	0.239
Stack Axis #1 (Inches)=	42.0
Stack Axis #2 (Inches)=	42.0
Circular Stack	
Stack Area (Square Feet)=	9.62

Stack Velocity (Actual, Feet/min)=	4,008
Flow Rate (Actual, Cubic ft/min)=	38,559
Flow rate (Standard, Wet, Cubic ft/min)=	30,478
Flow Rate (Standard, Dry, Cubic ft/min)=	24,452

Particulate Loading - Front Half

Particulate Weight (g)=	0.1883	Corr. to 7% O2 & 12% CO2	
Particulate Loading, Dry Std. (gr/scf)=	0.0746	0.3480	0.5965
Particulate Loading, Actual (gr/cu ft)=	0.0473		
Emission Rate (lb/hr)=	15.62		

Particulate Loading - Total Catch Including Impingers

Particulate Weight (g)=	0.2506		
Particulate Loading, Dry Std. (gr/scf)=	0.0992	0.4631	0.7939
Particulate Loading, Actual (gr/cu ft)=	0.0629		
Emission Rate (lb/hr)=	20.80		
Percent Impinger Catch=	24.9		

* * METRIC UNITS * *

FILE NAME - GOTHENBURG.R1
 RUN # - GOTHENBURG RUN 1
 LOCATION - DRYER STACK
 DATE - AUGUST 31, 1993
 PROJECT # - 411922

PROG.=VER 06/27/89
 09-29-1993 10:52:27

Initial Meter Volume (Cubic Meters)=	17.146
Final Meter Volume (Cubic Meters)=	18.294
Meter Factor=	1.019
Final Leak Rate (cu m/min)=	0.0004
Net Meter Volume (Cubic Meters)=	1.170
Gas Volume (Dry Standard Cubic Meters)=	1.101

Barometric Pressure (mm Hg)=	706
Static Pressure (mm H2O)=	17

Percent Oxygen=	18.0
Percent Carbon Dioxide=	1.5
Moisture Collected (ml)=	203.5
Percent Water=	19.8

Average Meter Temperature (C)=	17
Average Delta H (mm H2O)=	37.7
Average Delta P (mm H2O)=	26.4
Average Stack Temperature (C)=	72

Dry Molecular Weight=	28.96
Wet Molecular Weight=	26.79

Average Square Root of Delta P (mm H2O)=	5.1360
% Isokinetic=	81.9

Pitot Coefficient=	0.84
Sampling Time (Minutes)=	60.0
Nozzle Diameter (mm)=	6.07
Stack Axis #1 (Meters)=	1.067
Stack Axis #2 (Meters)=	1.067
Circular Stack	
Stack Area (Square Meters)=	0.894

Stack Velocity (Actual, m/min)=	1,222
Flow rate (Actual, Cubic m/min)=	1,092
Flow rate (Standard, Wet, Cubic m/min)=	863
Flow rate (Standard, Dry, Cubic m/min)=	692

Particulate Loading - Front Half

Particulate Weight (g)=	0.1883	Corr. to 7% O2 & 12% CO2
Particulate Loading, Dry Std. (mg/cu m)=	171.0	797.9 1367.9
Particulate Loading, Actual (mg/cu m)=	108.4	
Emission Rate (kg/hr)=	7.09	

Particulate Loading - Total Catch Including Impingers

Particulate Weight (g)=	0.3		
Particulate Loading, Dry Std. (mg/cu m)=	227.6	1062.0	1820.6
Particulate Loading, Actual (mg/cu m)=	144.3		
Emission Rate (kg/hr)=	9.44		
Percent Impinger Catch=	24.9		

FILE NAME - GOTHENBURG.R1
 RUN # - GOTHENBURG RUN 1
 LOCATION - DRYER STACK
 DATE - AUGUST 31, 1993
 PROJECT # - 411922

PROG.=VER 06/27/89
 09-29-1993 10:52:28

Point #	Delta P (in. H2O)	Delta H (in. H2O)	Stack T (F)	Meter T	
				In(F)	Out(F)
1	1.000	1.80	150	53	52
2	1.000	1.50	159	56	53
3	1.000	1.30	165	59	55
4	0.980	1.50	158	62	56
5	0.990	1.40	163	64	58
6	0.950	1.10	167	66	59
7	1.300	2.60	142	65	61
8	1.200	1.30	172	70	63
9	1.100	1.40	165	71	64
10	1.000	1.20	168	73	66
11	0.990	1.30	166	74	67
12	0.980	1.40	163	75	67

Fraction	Final Wt. (g)	Tare Wt. (g)	Blank Wt. (g)	Net Wt. (g)
DRY CATCH	0.0000	0.0000	0.0000	0.0000
FILTER	31.7829	31.6539	-0.0003	0.1293

Fraction	Final Wt. (g)	Tare Wt. (g)	Vol. (ml)	Net Wt. (g)
PROBE RINSE	76.3760	76.3159	140.0	0.0590
IMPINGERS	317.1218	317.0576	200.0	0.0623
Probe Rinse Blank (mg/ml)=	0.0080	High Acetone Blank - Limit .0079		
Impinger Blank (mg/ml)=	0.0095			

FILE NAME - GOTHENBURG.R2
RUN # - GOTHENBURG.R2
LOCATION - DRYER STACK
DATE - AUGUST 31, 1993
PROJECT # - 411922

PROG.=VER 06/27/89
09-28-1993 16:11:06

Initial Meter Volume (Cubic Feet)= 646.345
Final Meter Volume (Cubic Feet)= 690.385
Meter Factor= 1.019
Final Leak Rate (cu ft/min)= 0.009
Net Meter Volume (Cubic Feet)= 44.877
Gas Volume (Dry Standard Cubic Feet)= 41.343

Barometric Pressure (in Hg)= 27.79
Static Pressure (Inches H2O)= 0.65

Percent Oxygen= 18.0
Percent Carbon Dioxide= 1.5
Moisture Collected (ml)= 265.7
Percent Water= 23.2

Average Meter Temperature (F)= 75
Average Delta H (in H2O)= 1.69
Average Delta P (in H2O)= 1.032
Average Stack Temperature (F)= 183

Dry Molecular Weight= 28.96
Wet Molecular Weight= 26.41

Average Square Root of Delta P (in H2O)= 1.0149
% Isokinetic= 92.3

Pitot Coefficient= 0.84
Sampling Time (Minutes)= 60.0
Nozzle Diameter (Inches)= 0.239
Stack Axis #1 (Inches)= 42.0
Stack Axis #2 (Inches)= 42.0
Circular Stack
Stack Area (Square Feet)= 9.62

Stack Velocity (Actual, Feet/min)= 4,090
Flow Rate (Actual, Cubic ft/min)= 39,350
Flow rate (Standard, Wet, Cubic ft/min)= 30,048
Flow Rate (Standard, Dry, Cubic ft/min)= 23,066

Particulate Loading - Front Half

Particulate Weight (g)= 0.3865
Particulate Loading, Dry Std. (gr/scf)= 0.1440
Particulate Loading, Actual (gr/cu ft)= 0.0844
Emission Rate (lb/hr)= 28.46

Corr. to 7% O2 & 12% CO2
0.6719 1.1518

Particulate Loading - Total Catch Including Impingers

Particulate Weight (g)= 0.5883
Particulate Loading, Dry Std. (gr/scf)= 0.2192
Particulate Loading, Actual (gr/cu ft)= 0.1284
Emission Rate (lb/hr)= 43.32
Percent Impinger Catch= 34.3

1.0227 1.7532

* * METRIC UNITS * *

FILE NAME - GOTHENBURG.R2
 RUN # - GOTHENBURG.R2
 LOCATION - DRYER STACK
 DATE - AUGUST 31, 1993
 PROJECT # - 411922

PROG.=VER 06/27/89
 09-28-1993 16:11:07

Initial Meter Volume (Cubic Meters)=	18.302
Final Meter Volume (Cubic Meters)=	19.549
Meter Factor=	1.019
Final Leak Rate (cu m/min)=	0.0003
Net Meter Volume (Cubic Meters)=	1.271
Gas Volume (Dry Standard Cubic Meters)=	1.171

Barometric Pressure (mm Hg)=	706
Static Pressure (mm H2O)=	17

Percent Oxygen=	18.0
Percent Carbon Dioxide=	1.5
Moisture Collected (ml)=	265.7
Percent Water=	23.2

Average Meter Temperature (C)=	24
Average Delta H (mm H2O)=	43.0
Average Delta P (mm H2O)=	26.2
Average Stack Temperature (C)=	84

Dry Molecular Weight=	28.96
Wet Molecular Weight=	26.41

Average Square Root of Delta P (mm H2O)=	5.1151
% Isokinetic=	92.3

Pitot Coefficient=	0.84
Sampling Time (Minutes)=	60.0
Nozzle Diameter (mm)=	6.07
Stack Axis #1 (Meters)=	1.067
Stack Axis #2 (Meters)=	1.067
Circular Stack	
Stack Area (Square Meters)=	0.894

Stack Velocity (Actual, m/min)=	1,247
Flow rate (Actual, Cubic m/min)=	1,114
Flow rate (Standard, Wet, Cubic m/min)=	851
Flow rate (Standard, Dry, Cubic m/min)=	653

Particulate Loading - Front Half

Particulate Weight (g)=	0.3865	Corr. to 7% O2 & 12% CO2
Particulate Loading, Dry Std. (mg/cu m)=	330.2	1540.8 2641.4
Particulate Loading, Actual (mg/cu m)=	193.5	
Emission Rate (kg/hr)=	12.92	

Particulate Loading - Total Catch Including Impingers

Particulate Weight (g)=	0.6		
Particulate Loading, Dry Std. (mg/cu m)=	502.6	2345.3	4020.5
Particulate Loading, Actual (mg/cu m)=	294.5		
Emission Rate (kg/hr)=	19.67		
Percent Impinger Catch=	34.3		

FILE NAME - GOTHENBURG.R2
 RUN # - GOTHENBURG.R2
 LOCATION - DRYER STACK
 DATE - AUGUST 31, 1993
 PROJECT # - 411922

PROG.=VER 06/27/89
 09-28-1993 16:11:07

Point #	Delta P (in. H2O)	Delta H (in. H2O)	Stack T (F)	In(F)	Meter T Out(F)
1	1.000	1.60	178	73	72
2	1.000	1.60	185	73	72
3	1.000	1.70	181	73	72
4	0.980	1.60	187	74	72
5	0.990	1.60	189	75	72
6	0.950	1.60	176	75	72
7	1.100	1.80	187	75	73
8	1.200	2.00	180	76	74
9	1.200	2.00	186	78	75
10	1.000	1.60	190	78	75
11	1.000	1.60	184	79	75
12	0.960	1.60	177	79	76

Fraction	Final Wt. (g)	Tare Wt. (g)	Blank Wt. (g)	Net Wt. (g)
DRY CATCH	0.0000	0.0000	0.0000	0.0000
FILTER	45.8222	45.5358	-0.0003	0.2867

Fraction	Final Wt. (g)	Tare Wt. (g)	Vol. (ml)	Net Wt. (g)
PROBE RINSE	68.3028	68.2018	150.0	0.0998
IMPINGERS	321.5349	321.3312	200.0	0.2018
Probe Rinse Blank (mg/ml)=	0.0080 High Acetone Blank - Limit .0079			
Impinger Blank (mg/ml)=	0.0095			

FILE NAME - GOTHENBURG.R3
RUN # - GOTHENBURG.R3
LOCATION - DRYER STACK
DATE - AUGUST 31, 1993
PROJECT # - 411922

PROG.=VER 06/27/89
09-28-1993 16:11:44

Initial Meter Volume (Cubic Feet)=	690.543
Final Meter Volume (Cubic Feet)=	739.070
Meter Factor=	1.019
Final Leak Rate (cu ft/min)=	0.005
Net Meter Volume (Cubic Feet)=	49.449
Gas Volume (Dry Standard Cubic Feet)=	45.142

Barometric Pressure (in Hg)=	27.79
Static Pressure (Inches H2O)=	0.65

Percent Oxygen=	17.5
Percent Carbon Dioxide=	1.5
Moisture Collected (ml)=	221.6
Percent Water=	18.8

Average Meter Temperature (F)=	80
Average Delta H (in H2O)=	2.03
Average Delta P (in H2O)=	1.039
Average Stack Temperature (F)=	154

Dry Molecular Weight=	28.94
Wet Molecular Weight=	26.89

Average Square Root of Delta P (in H2O)=	1.0186
% Isokinetic=	93.5

Pitot Coefficient=	0.84
Sampling Time (Minutes)=	60.0
Nozzle Diameter (Inches)=	0.239
Stack Axis #1 (Inches)=	42.0
Stack Axis #2 (Inches)=	42.0
Circular Stack	
Stack Area (Square Feet)=	9.62

Stack Velocity (Actual, Feet/min)=	3,975
Flow Rate (Actual, Cubic ft/min)=	38,248
Flow rate (Standard, Wet, Cubic ft/min)=	30,590
Flow Rate (Standard, Dry, Cubic ft/min)=	24,845

Particulate Loading - Front Half

Particulate Weight (g)=	0.1828	Corr. to 7% O2 & 12% CO2	
Particulate Loading, Dry Std. (gr/scf)=	0.0624	0.2494	0.4989
Particulate Loading, Actual (gr/cu ft)=	0.0405		
Emission Rate (lb/hr)=	13.28		

Particulate Loading - Total Catch Including Impingers

Particulate Weight (g)=	0.1980		
Particulate Loading, Dry Std. (gr/scf)=	0.0675	0.2702	0.5404
Particulate Loading, Actual (gr/cu ft)=	0.0439		
Emission Rate (lb/hr)=	14.38		
Percent Impinger Catch=	7.7		

* * METRIC UNITS * *

FILE NAME - GOTHENBURG.R3
 RUN # - GOTHENBURG.R3
 LOCATION - DRYER STACK
 DATE - AUGUST 31, 1993
 PROJECT # - 411922

PROG.=VER 06/27/89
 09-28-1993 16:11:44

Initial Meter Volume (Cubic Meters)=	19.553
Final Meter Volume (Cubic Meters)=	20.928
Meter Factor=	1.019
Final Leak Rate (cu m/min)=	0.0001
Net Meter Volume (Cubic Meters)=	1.400
Gas Volume (Dry Standard Cubic Meters)=	1.278

Barometric Pressure (mm Hg)=	706
Static Pressure (mm H2O)=	17

Percent Oxygen=	17.5
Percent Carbon Dioxide=	1.5
Moisture Collected (ml)=	221.6
Percent Water=	18.8

Average Meter Temperature (C)=	27
Average Delta H (mm H2O)=	51.6
Average Delta P (mm H2O)=	26.4
Average Stack Temperature (C)=	68

Dry Molecular Weight=	28.94
Wet Molecular Weight=	26.89

Average Square Root of Delta P (mm H2O)=	5.1335
% Isokinetic=	93.5

Pitot Coefficient=	0.84
Sampling Time (Minutes)=	60.0
Nozzle Diameter (mm)=	6.07
Stack Axis #1 (Meters)=	1.067
Stack Axis #2 (Meters)=	1.067
Circular Stack	
Stack Area (Square Meters)=	0.894

Stack Velocity (Actual, m/min)=	1,212
Flow rate (Actual, Cubic m/min)=	1,083
Flow rate (Standard, Wet, Cubic m/min)=	866
Flow rate (Standard, Dry, Cubic m/min)=	704

Particulate Loading - Front Half

Particulate Weight (g)=	0.1828	Corr. to 7% O2 & 12% CO2
Particulate Loading, Dry Std. (mg/cu m)=	143.0	572.0 1144.1
Particulate Loading, Actual (mg/cu m)=	92.9	
Emission Rate (kg/hr)=	6.03	

Particulate Loading - Total Catch Including Impingers

Particulate Weight (g)=	0.2	
Particulate Loading, Dry Std. (mg/cu m)=	154.9	619.6 1239.2
Particulate Loading, Actual (mg/cu m)=	100.6	
Emission Rate (kg/hr)=	6.53	
Percent Impinger Catch=	7.7	

FILE NAME - GOTHENBURG.R3
 RUN # - GOTHENBURG.R3
 LOCATION - DRYER STACK
 DATE - AUGUST 31, 1993
 PROJECT # - 411922

PROG.=VER 06/27/89
 09-28-1993 16:11:45

Point #	Delta P (in. H2O)	Delta H (in. H2O)	Stack T (F)	Meter T In(F)	Meter T Out(F)
1	1.100	2.10	163	77	77
2	1.000	1.90	160	76	76
3	1.000	1.90	161	77	76
4	1.000	2.00	155	79	76
5	0.980	1.90	153	80	77
6	0.960	1.90	151	82	78
7	1.200	2.30	151	83	78
8	1.200	2.40	151	83	79
9	1.100	2.20	152	85	80
10	1.000	2.00	151	85	80
11	0.970	1.90	152	86	81
12	0.960	1.90	151	85	81

Fraction	Final Wt. (g)	Tare Wt. (g)	Blank Wt. (g)	Net Wt. (g)
DRY CATCH	0.0000	0.0000	0.0000	0.0000
FILTER	91.4028	91.2927	-0.0003	0.1104

Fraction	Final Wt. (g)	Tare Wt. (g)	Vol. (ml)	Net Wt. (g)
PROBE RINSE	76.3396	76.2661	140.0	0.0724
IMPINGERS	240.4431	240.4260	200.0	0.0152
Probe Rinse Blank (mg/ml)=	0.0080			
Impinger Blank (mg/ml)=	0.0095			


High Acetone Blank - Limit .0079

APPENDIX C

PARTICULATE FIELD DATA FORMS

TRAVERSE POINT LOCATIONS

PROJECT NO. 411922
 PLANT Gettysburg A/Alfa
 DATE 8-31-93
 SAMPLING LOCATION Dryer Stack Gettysburg
 INSIDE OF FAR WALL TO
 OUTSIDE OF NIPPLE (Distance A) 45
 INSIDE OF NEAR WALL TO
 OUTSIDE OF NIPPLE (Distance B) 3
 STACK I.D. (Distance A - Distance B) 42
 NEAREST UPSTREAM DISTURBANCE (in.) 360 4 dia.
 NEAREST DOWNSTREAM DISTURBANCE (in.) 84 2 dia.
 OPERATOR B. Wood



DRAWING OF STACK


TRAVERSE POINT NUMBER	FRACTION OF STACK I.D.	STACK I.D.	PRODUCT OF COLUMNS 2 AND 3	DISTANCE B	TRAVERSE POINT LOCATION FROM OUTSIDE OF NIPPLE (SUM OF COLUMNS 4 & 5)	
					Decimal	Fraction to nearest 1/8 in.
1	4.4	42	1.8			
2	14.6		6.1			
3	29.6		12.4			
4	70.4		29.5			
5	85.4		35.9			
6	95.6		40.2			
7						
8						
9						
10						
11						
12						

Comments:

Reviewed by: _____ Date: _____

Preliminary Velocity Traverse

Plant 60thembury
Project No. 4/1922
Date 8-21-93
Location Dryer Stack
Stack I.D. 43
Pitot Cp. 84
Static Pressure in H₂O 1.65
Barometer Pressure in. Hg 27.779
Start Time _____
Stop Time _____
Operators B. Ward
C. T. HUS



SCHEMATIC OF TRAVERSE POINT LAYOUT


Final Pitot Leak Check at $\geq 3''$ H₂O (P) F[illegible][illegible]

AIRSOURCE TECHNOLOGIES

11635 W 83RD TERRACE
Lenexa, Kansas 66215
(913) 492-1613
FAX: (913) 492-1012

PROJECT NO. 411922
RUN NO. 1
DATE 5/31/93
SAMPLE TYPE particulate
PLANT Alfa processors Assn. - Bethelburg
SAMPLING LOCATION Dry of Stack
TOTAL SAMPLING TIME 60
METER NO. 4 ASSUMED MOISTURE 25 %
UMBILICAL CORD I.D. NO. 50' METER CORRECTION FACTOR 1.019
UMBILICAL/SAMPLER HOOKUP 1 METER ΔH @ 1843
OVEN BOX NO. 1 BAROMETRIC PRESSURE 27.79 in Hg
PROBE NO. 1 STATIC PRESSURE 165 in H₂O
PROBE LENGTH & TYPE 5' glass RECORD DATA EVERY 5 MIN
PITOT NO. 1 PITOT COEFFICIENT 1.84
THERMOCOUPLE I.D. NO. 1 NOZZLE DIAMETER 239 in
NOZZLE NO. 239 CS STACK AXIS #1 42
NOZZLE TYPE SS/GIO STACK AXIS #2 42

PROJECT LEADER B. Wood
CONSOLE OPERATOR B. Wood
LAB PERSON T. Titus
SUPPORT PERSONNEL T. Titus



SCHEMATIC OF TRAVERSE
POINT LAYOUT

SAMPLE TRAIN LEAK CHECKS	INITIAL	FINAL
TIME (24 HRS.)	8855	1012
VACUUM, in. Hg	215	3"
CFM	1003	1013
PITOT LEAK CHECK 23" H ₂ O	Pass	Pass

INITIAL METER VOLUME	605.520
FINAL METER VOLUME	646.069

ORSAT/FYRITE

RECOVERY DATA

TRIAL	PERCENT CO ₂	PERCENT CO ₂ + O ₂	PERCENT O ₂
1	1.5		18.0
2	1.5		18.0
3			
AVG	1.5		18.0

	FINAL	INITIAL	DIFFERENCE
IMP. 1	223	100	123
IMP. 2	135	100	35
IMP. 3	12	0	12
IMP. 4	745.1	731.6	13.5
TOTAL:			203.5'

COMMENTS:

FILTER NO: 8-20-93-1

% BLUE 70

REVIEWED BY: _____

[illegible]

AIRSOURCE TECHNOLOGIES

11635 W 83RD TERRACE
Lenexa, Kansas 66215
(913) 492-1613
FAX: (913) 492-1012

PROJECT NO. 41192.2
RUN NO. 2
DATE 8-31-93
SAMPLE TYPE particulate
PLANT _____

PROJECT LEADER B. Wood
CONSOLE OPERATOR B. Wood
LAB PERSON T. Titus
SUPPORT PERSONNEL: T. Titus

SAMPLING LOCATION Dryer Stack
TOTAL SAMPLING TIME 60
METER NO. 4

ASSUMED MOISTURE 30 %
UMBILICAL CORD I.D. NO. 50' METER CORRECTION FACTOR 1.019

UMBILICAL/SAMPLER HOOKUP 2 METER ΔH @ 1.843

OVEN BOX NO. 1 BAROMETRIC PRESSURE 27.79 in Hg

PROBE NO. 1 STATIC PRESSURE .65 in H₂O

PROBE LENGTH & TYPE 5' glass RECORD DATA EVERY 5 MIN

PITOT NO. _____ PITOT COEFFICIENT .84

THERMOCOUPLE I.D. NO. 1 NOZZLE DIAMETER .239 in

NOZZLE NO. 1239 STACK AXIS #1 42

NOZZLE TYPE SS/GIO STACK AXIS #2 42

See Run 1

SCHEMATIC OF TRAVERSE POINT LAYOUT

SAMPLE TRAIN LEAK CHECKS	INITIAL	FINAL
TIME (24 HRS.)	<u>1026</u>	<u>1143</u>
VACUUM, in. Hg	<u>215</u>	<u>10"</u>
CFM	<u>.003</u>	<u>.009</u>
PITOT LEAK CHECK 23" H ₂ O	<u>Pass</u>	<u>Pass</u>

INITIAL METER VOLUME	<u>646.345</u>
FINAL METER VOLUME	<u>690.385</u>

ORSAT/FYRITE

RECOVERY DATA

TRIAL	PERCENT CO.	PERCENT CO. + O ₂	PERCENT O ₂
1	<u>1.5</u>		<u>18.0</u>
2	<u>1.5</u>		<u>18.0</u>
3			
AVG	<u>1.5</u>		<u>18.0</u>

	FINAL	INITIAL	DIFFERENCE
IMP. 1	<u>215</u>	<u>100</u>	<u>115</u>
IMP. 2	<u>217</u>	<u>100</u>	<u>117</u>
IMP. 3	<u>12</u>	<u>0</u>	<u>12</u>
IMP. 4	<u>698.3</u>	<u>676.6</u> 722.8	<u>21.7</u>
TOTAL:			<u>265.7'</u>

COMMENTS:

FILTER NO: 93-8582 % BLUE 20

REVIEWED BY: _____

[illegible]

AIRSOURCE TECHNOLOGIES

11635 W 83RD TERRACE
Lenexa, Kansas 66215
(913) 492-1613
FAX: (913) 492-1012

PROJECT NO. 411922
RUN NO. 3
DATE 8-31-93
SAMPLE TYPE particulate
PLANT bothern busg
SAMPLING LOCATION Dryer Stack
TOTAL SAMPLING TIME 60
METER NO. 4 ASSUMED MOISTURE 25 %
UMBILICAL CORD I.D. NO. 50' METER CORRECTION FACTOR 1.019
UMBILICAL/SAMPLER HOOKUP 3 METER ΔH @ 1.84/3
OVEN BOX NO. 1 BAROMETRIC PRESSURE 27.79 in Hg
PROBE NO. 1 STATIC PRESSURE 165 in H₂O
PROBE LENGTH & TYPE 5'6/045 RECORD DATA EVERY 5 MIN
PITOT NO. 1 PITOT COEFFICIENT .84
THERMOCOUPLE I.D. NO. 1 NOZZLE DIAMETER .239 in
NOZZLE NO. 1239 STACK AXIS #1 42
NOZZLE TYPE SS G10 STACK AXIS #2 42

PROJECT LEADER B. Wood
CONSOLE OPERATOR B. Wood
LAB PERSON T. Titus
SUPPORT PERSONNEL T. Titus

See Run 1

SCHEMATIC OF TRAVERSE POINT LAYOUT

SAMPLE TRAIN LEAK CHECKS	INITIAL	FINAL
TIME (24 HRS.)	1400	1528
VACUUM, in. Hg	2.15	2"
CFM	1005	1005
PITOT LEAK CHECK 23" H ₂ O	Pass	Pass

INITIAL METER VOLUME	690.543
FINAL METER VOLUME	739.070

ORSAT/FYRITE

RECOVERY DATA

TRIAL	PERCENT CO ₂	PERCENT CO + O ₂	PERCENT O ₂
1	1.5		17.5
2	1.5 1.5		17.5
3	1.5		
AVG	1.5 1.5		17.5

	FINAL	INITIAL	DIFFERENCE
IMP. 1	231	100	131
IMP. 2	170	100	70
IMP. 3	9	0	9
IMP. 4	739.4	676.6 727.9	11.6
TOTAL:			(221.6)

COMMENTS:

1.5
1.5

FILTER NO. 57-116

% BLUE

REVIEWED BY:

[illegible]

APPENDIX D

LABORATORY AND ANALYSIS FORMS

A. fulva Hass.

[illegible]

INITIAL FILTER WEIGHING

Analyst: B. Wood

Filter Type and Size: 85 cm Glass

Weight Unit: .000 / grams

Filter Treatment:

☒ Desiccate 24 hours/6 hours between weighings

☐ Oven Treated

☐ Other

Balance Check:

Weight Value(g)

40

40

Initial Check(g)

39.9998

39.9994

Final Check(g)

39.9998

39.9993

Date:

5-14-93

5-20-93

Time (24 hr):

0900

1000

Filter
No.

Weigh No. 1

Weigh No. 2

Weigh No. _____

Average

93-77

30.4365

30.4364

30.4365

93-78

33.8330

33.8332

33.8331

93-79

48.0524

48.0521

48.0523

93-80

31.7925

31.7926

31.7926

93-81

34.3537

34.3539

34.3538

93-82

45.5360

45.5355

45.5358

93-83

33.8608

33.8603

33.8606

93-84

30.1321

30.1319

30.1320

93-85

33.4342

33.4342

33.4342

93-86

32.4576

32.4573

32.4575

93-87

48.9913

48.9910

48.9912

93-88

37.6707

37.6707

37.6707

93-89

31.6480

31.6476

31.6478

93-90

40.6104

40.6102

40.6103

93-91

32.2392

32.2387

32.2389

93-92

50.2469

50.2466

50.2468

93-93

32.9079

32.9076

32.9078

INITIAL FILTER WEIGHING

Analyst: <u>Cobb</u>	<u>bottom only</u>
Filter Type and Size: <u>85 mm funnel cones</u>	Weight Unit: <u>grams</u>
Filter Treatment:	
☒ Desiccate 24 hours/6 hours between weighings	
☐ Oven Treated	
☐ Other	

Balance Check:				
Weight Value(g)	<u>30</u>	<u>30</u>		
Initial Check(g)	<u>30.0001</u>	<u>30.0002</u>		
Final Check(g)	<u>30.0002</u>	<u>30.0001</u>		
Date:	Time (24 hr):	Filter No.	Weight Value(g)	Average
<u>8-21-93</u>	<u>1300</u>			
	<u>1230</u>			
		Weigh No. <u>1</u>	Weigh No. <u>2</u>	Weight No. <u> </u>
<u>8-20-93- 1</u>		<u>31.6537</u>	<u>31.6540</u>	<u>31.6539</u>
<u>- 2</u>		<u>33.9863</u>	<u>33.9864</u>	<u>33.9864</u>
<u>- 3</u>		<u>33.5089</u>	<u>33.5088</u>	<u>33.5089</u>
<u>- 4</u>		<u>44.7618</u>	<u>44.7619</u>	<u>44.7619</u>
<u>- 5</u>		<u>32.8210</u>	<u>32.8212</u>	<u>32.8211</u>
<u>- 6</u>		<u>37.6922</u>	<u>37.6926</u>	<u>37.6924</u>
<u>- 7</u>		<u>33.48384</u>	<u>33.4384</u>	<u>33.4384</u>
<u>- 8</u>		<u>50.2424</u>	<u>50.2426</u>	<u>50.2425</u>
<u>- 9</u>		<u>31.5228</u>	<u>31.5229</u>	<u>31.5229</u>
<u>-10</u>		<u>36.9209</u>	<u>36.9209</u>	<u>36.9209</u>
<u>-11</u>		<u>31.8142</u>	<u>31.8144</u>	<u>31.8143</u>
<u>-12</u>		<u>33.8494</u>	<u>33.8495</u>	<u>33.8495</u>
<u>-13</u>		<u>33.5561</u>	<u>33.5561</u>	<u>33.5561</u>
<u>-14</u>		<u>42.2211</u>	<u>42.2214</u>	<u>42.2213</u>
<u>-15</u>		<u>33.9741</u>	<u>33.9742</u>	<u>33.9742</u>
<u>-16</u>		<u>31.0860</u>	<u>31.0861</u>	<u>31.0861</u>
<u>-17</u>		<u>32.2630</u>	<u>32.2628</u>	<u>32.2629</u>

INITIAL FILTER WEIGHING

Analyst: Cof6

Filter Type and Size: 84mm filter glass

Weight Unit: grams

Filter Treatment:

☒ Desiccate 24 hours/6 hours between weighings

☐ Oven Treated

☐ Other

Balance Check:

Weight Value(g)

100

100

100

Initial Check(g)

99.9998

99.9997

99.9997

Final Check(g)

99.9997

99.9995

99.9995

Date:

5-22-93

5-24-93

5-24-93

Time (24 hr):

1400

1100

1845

Filter
No.

Weigh No. 4

Weigh No. 5

Weigh No. 6

Average

5-7-113

92.8897

92.8895

5-7-114

90.7490

90.7489

5-7-115

76.30326

76.3024

5-7-116

91.2927

91.2927

5-7-117

109.6932

109.6930

5-7-118

94.9720

94.9719

5-7-119

84.0713

84.0716

84.0715

5-7-120

90.8149

90.8137

90.8137

90.8137

5-7-121

91.3552

91.3551

5-7-122

82.6449

82.6424

82.6429

82.6427

FINAL BEAKER WEIGHING

Project No.: 411992	Analyst: C.H.
Beaker Size: 150 ml	Weight Unit: grams
Beaker Treatment:	
☒ Desiccate 24 hours/6 hours between weighings	
☐ Other	

[illegible]

INITIAL BEAKER WEIGHING

Analyst: Cobb

Beaker Size: 150 ml

Weight Unit: grams

Beaker Treatment:

X Desiccate 24 hours/6 hours between weighings

Other

Balance Check:

Weight Value(g)

70

70

70

Initial Check(g)

69.9999

69.9998

69.9998

Final Check(g)

69.9997

70.0000

69.9998

Date:

8-23-93

8-24-93

8-24-93

Time (24 hr):

1700

0820

1825

Beaker
No.

Weigh No. 1

Weigh No. 2

Weigh No. 3

Average

8-23-18

68.3417

68.3450

68.3422

→

-19

75.2457

75.2502

75.2472

→

-20

68.9971

69.0013

68.9991

→

-21

67.5494

67.54536

67.5508

→

-22

67.7590

67.7629

67.7614

→

-23

76.3139

76.3189

76.3159

→

-24

67.6512

67.6554

67.6531

→

-25

68.2014

68.2045

68.2028

→

8-23-26

76.2650

76.2688

76.2670

→

-27

69.7655

69.7691

69.7675

→

-28

63.2897

63.2934

63.2916

→

-29

65.2695

65.2725

65.2714

→

-30

70.9722

70.9754

70.9737

→

-31

68.2015

68.2052

68.2027

→

-32

65.7497

65.7540

65.7515

→

-33

74.9287

74.9315

74.9299

→

8-23-34

69.0180

69.0204

69.0195

→

INITIAL BEAKER WEIGHING

Analyst: Cobb

Beaker Size: 150

Weight Unit: grams

Beaker Treatment:

☒ Desiccate 24 hours/6 hours between weighings
☐ Other

Balance Check:

Weight Value(g)

70

70

70

Initial Check(g)

69.9997

69.9999

69.9997

Final Check(g)

69.9996

69.9998

69.9997

Date:

8-25-93

8-25-93

8-26-93

Time (24 hr):

0930

1530

0930

Beaker
No.

Weigh No. 4

Weigh No. 5

Weigh No. 6

Average

8-23-18

68.3420

68.3418

68.3419

-19

75.2464

75.2461

75.2463

-20

68.9968

68.9978

68.9974

68.9976

-21

67.5497

67.5497

67.5497

-22

67.7601

67.7601

67.7601

-23

76.3148

76.3161

76.3156

76.3159

-24

67.6525

67.6523

67.6524

-25

68.2013

68.2020

68.2016

68.2018

8-23-26

76.2655

76.2663

76.2659

76.2661

-27

69.7662

69.7666

69.7664

-28

63.2900

63.2907

63.2907

63.2907

-29

65.2700

65.2707

65.2705

65.2706

-30

70.9722

70.9725

70.9724

-31

68.2022

68.2021

68.2022

-32

65.7503

65.7501

65.7502

-33

74.9288

74.9289

74.9289

8-23-34

69.0180

69.0181

69.0181

APPENDIX E

PRETEST CALIBRATIONS

BAROMETER CALIBRATION SHEET

Date	8-15-93
Barometer Number	#1
Ambient Temperature	17.40
Calibrator	Riplov
Barometer Reading	28.85
Reference Barometer Reading	28.80
Difference	.05

Acceptance Criteria: Difference $\leq$ 0.1 inch

CONSOLE WORKSHEET

NAME Rigdon K FACTOR 5312 PROJECT #
 DATE 8/16/93 TRAIN ID #4 PREVIOUS Y FACTOR 1.026
 ORIFICE # 2 PYROMETER #

RUN NUMBER

DCM

FINAL READING

INITIAL READING

1

2

178,24

181,84

174,80

178,40

INLET & OUTLET TEMPERATURES

INITIAL

80 / 79

82 / 80

FINAL

82 / 80

83 / 80

TIME Sec

300

300

ORIFICE RDG. "H

1.50

1.50

BAR. PRESSURE

28.85

28.85

ROOM TEMP.

75 / 75

75 / 75

PUMP VACUUM Hg"

15"

15"

109

165

CONSOLE CALIBRATION

Project	411775	Orifice number	2
Date	AUG 16 93	Orifice K factor	.5312
Operator	RIGDON	Previous Y factor	1.026
Console Number	4		

	Run 1	Run 2
Final DGM Volume	178.240	181.840
Initial DGM Volume	174.800	178.400
Net DGM Volume (Vm)	3.440	3.440

EE

In/Out DGM Temp.		
Inlet Deg. F		
initial	80.0	82.0
final	82.0	83.0
Outlet Deg. F		
initial	79.0	80.0
final	80.0	80.0
Avg. DGM Temp Deg. F	80.3	81.3
Time, sec.	300.0	300.0
Orifice DH, in. H2O	1.50	1.50
Baro. Press., in. Hg	28.85	28.85
Room temp., Deg. F		
initial	75.0	75.0
final	75.0	75.0
Avg. Room Temp.	75.0	75.0
Pump Vacuum, in. Hg	15	15

EE

Vcr (std)	3.313	3.313
Vm (std)	3.253	3.247
Y Factor	1.018	1.020
Delta H@	1.845	1.841

Average Y	1.019
Average Delta H@	1.843

EE

+/- 2% criteria	
Percent of Avg Y	.09
	PASS
+/- 5% criteria	
Percent of final Y	.65
	PASS

BRACKETING WORKSHEET

NAME Bigden K. FACTOR 1. 3199 2. 6405
PROJECT # _____ DATE 8/16/93 TRAIN I.D. #4
ORIFICE # 1. 4 2. 5

<u>DCM</u>	<u>1</u>	<u>2</u>
Final Reading	<u>184.15</u>	<u>189.17</u>
Initial reading	<u>182.10</u>	<u>186.00</u>
Difference	_____	_____

<u>INLET & OUTLET TEMP.</u>		
Initial	<u>83.80</u>	<u>85.81</u>
Final	<u>85.81</u>	<u>89.84</u>
Avg. Temp.	_____	_____

Time	<u>300</u>	<u>300</u>
Orifice rdg. ^E	<u>.55</u>	<u>2.25</u>
Bar. Pressure	<u>29.85</u>	<u>29.85</u>
Room Temp.	<u>75.75</u>	<u>75.75</u>
Pump Vacuum	<u>16"</u>	<u>15</u>

ORFICE BRACKETING

Project	962002	Bracket Orifices:	
Date	AUG 16 93	Orifice No. 1	4.
Operator	RIGDON	Orifice NO.1 K factor	.
Orifice Number	4	Orifice No. 2	7.
Orifice Y factor	1.019	Orifice NO.2 K factor	.

	Orifice #1	Orifice #2
Final DGM Volume	184.150	189.170
Initial DGM Volume	182.100	185.000
Net DGM Volume (Vm)	2.050	4.170

EE

In/Out DGM Temp.		
Inlet		
initial	83.0	85.0
final	85.0	89.0
Outlet		
initial	80.0	81.0
final	81.0	82.0
Avg. DGM Temp	82.3	84.3
Time, sec.	300.0	300.0
Orifice DH, in. H2O	.55	2.25
Baro. Press., in. Hg	28.85	28.85
Room temp., Deg. F		
initial	75.0	75.0
final	75.0	75.0
Avg. Room Temp.	75.0	75.0
Pump Vacuum, in. Hg	16	15

EE

Vcr (std)	1.995	3.994
Vm (std)	1.927	3.922
Y Factor (brackets)	1.035	1.019

EE

+/- 2% criteria		
Percent of Y	1.62	.04
	PASS	PASS

DRY GAS METER THERMOCOUPLE CALIBRATION SHEET

Date	5/16/93	Thermocouple Number	# 4
Calibrator	B. J. G. L. L.	Reference Mercury-In-glass	ASTM
		Other	

Thermocouple	Source	Reference Thermometer Temperature (°F)	Thermocouple Potentiometer Temperature (°F)	Temperature Difference (°F)
Inlet	Ambient Air	76°	76	0°
	Hot Water Bath	132°	132	0°
Outlet	Ambient Air	76°	77	+1°
	Hot Water Bath	132°	131°	-1°
• Reference Temperature -- Thermocouple Temperature $\leq \pm 5.4^\circ\text{F}$				

TYPE S PITOT TUBE CALIBRATION

PITOT # 7

Calibrator: <u>R. Wood</u>	Project no.:
Date: <u>5-15-93</u>	Probe no.: <u>1</u>

Pitot Tube Assembly Level? <u>(Y)</u> /N	
Pitot Tube Openings Damaged? <u>Y</u> / <u>(N)</u> (If yes explain below)	
α^1 <u>1</u> ° (<10°)	β^1 <u>0</u> ° (<5°)
α^2 <u>0</u> ° (<10°)	β^2 <u>0</u> ° (<5°)
Y = <u>1</u> O = <u>0</u> A = <u>.971</u> in.	
Z = A sin Y <u>.1015</u> in. (<1/8 in.)	
W = A sin O _____ in. (<1/32 in.)	
P = <u>.485</u> in.	P* = <u>.486</u> in.
DT = <u>.381</u> in.	
Calibration Required? <u>Y</u> / <u>(N)</u> (If yes explain below)	
Comments:	

STACK THERMOCOUPLE CALIBRATION SHEET

Date 8-15-93 Thermocouple Number 5-1 in. Hg
 Ambient Temp. 28.80 F Barometric Pressure 28.80
 Calibrator Rigdon Reference: mercury-in-glass Aston
 Other _____

Reference Point Number ^a	Source ^b (Specify)	Reference Thermometer Temperature F	Thermocouple potentiometer Temperature F	Temperature Difference %
1	Ambient	1740	1750	+10
2	Tube over	2480	2419	+10

^a Every 50°F for each reference point
^b Type of calibration system used
^c [(ref temp, °F + 460) - (test thermom temp, °F + 460)]
 ref temp, °F + 460
 100 < 1.5%.

Open THERMOCOUPLE CALIBRATION SHEET

Date 6/25/93 Thermocouple Number 1 in. Hg

F Barometric Pressure 29.10

Ambient Temp. _____ Reference: mercury-in-glass Asm

Calibrator Bigdon Other _____

Reference Point Number ^a	Source ^b (Specify)	Reference Thermometer Temperature °F	Thermocouple Potentiometer Temperature °F	Temperature Difference %
1	Ambient	70°	71°	+1°
2	Self Heat	252°	253°	+1°

^a Every 50°F for each reference point

^b Type of calibration system used

^c (ref temp, °F + 460) - (test thermom temp, °F + 460)

ref temp, °F + 460

100 ≤ 1.5%

UMMITICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

Date	8-22-93	Thermocouple Number	1
Calibrator	B. Wood	Reference: mercury-In-glass	
		Other	

Source	Reference Thermometer Temperature °F	Thermocouple Potentiometer Temperature °F	Temperature Difference ^a °F
Ambient Air	90	91	1
Ice Bath	38	39	1

^aReference Temperature - Thermocouple Temperature $\leq \pm 2^\circ\text{F}$

UMBILICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

Date	8-22-93	Thermocouple Number	2
Calibrator	B. Wood	Reference: mercury-in-glass	
		Other	

Source	Reference Thermometer Temperature F	Thermocouple Potentiometer Temperature F	Temperature Difference ^a F
Ambient Air	90	91	1
Ice Bath	39	39	0

^a Reference Temperature - Thermocouple Temperature $\leq \pm 2^{\circ}\text{F}$

UMBILICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

Date	8-22-93	Thermocouple Number	5
Calibrator	B. Wood	Reference: mercury-in-glass	
		Other	

Source	Reference Thermometer Temperature °F	Thermocouple Potentiometer Temperature °F	Temperature Difference °F
Ambient Air	91	91	0
Ice Bath	40	40	0
a) Reference Temperature - Thermocouple Temperature $\leq \pm 2^\circ\text{F}$			

APPENDIX F

POSTTEST CALIBRATIONS

BAROMETER CALIBRATION SHEET

Date	9-15-93
Barometer Number	#
Ambient Temperature	72°
Calibrator	Rigdon
Barometer Reading	29.00
Reference Barometer Reading	29.05
Difference	.05

Acceptance Criteria: Difference $\leq$ 0.1 inch

CONSOLE WORKSHEET

NAME Bigelow K FACTOR 5312 PROJECT #
 DATE 9/7/93 TRAIN ID #4 PREVIOUS Y FACTOR 1019
 ORIFICE # PYROMETER #

RUN NUMBER

DGM

FINAL READING

INITIAL READING

	1	2
FINAL READING	<u>866.93</u>	<u>870.62</u>
INITIAL READING	<u>863.50</u>	<u>867.20</u>

INLET & OUTLET TEMPERATURES

INITIAL

FINAL

	1	2
INITIAL	<u>64 / 64</u>	<u>68 / 64</u>
FINAL	<u>68 / 64</u>	<u>70 / 65</u>

TIME Sec

ORIFICE ROG. ΔE

BAR. PRESSURE

ROOM TEMP.

PUMP VACUUM H_g "

	1	2
TIME Sec	<u>300</u>	<u>300</u>
ORIFICE ROG. ΔE	<u>1.55</u>	<u>1.55</u>
BAR. PRESSURE	<u>29.20</u>	<u>29.20</u>
ROOM TEMP.	<u>63 / 63</u>	<u>63 / 63</u>
PUMP VACUUM H_g "	<u>15</u>	<u>15</u>

CONSOLE CALIBRATION

Project	411775	Orifice number	2
Date	SEP 7 93	Orifice K factor	.5312
Operator	RIGDON	Previous Y factor	1.019
Console Number	4		

	Run 1	Run 2
Final DGM Volume	866.930	870.620
Initial DGM Volume	863.500	867.200
Net DGM Volume (Vm)	3.430	3.420

EE

In/Out DGM Temp.		
Inlet Deg. F		
initial	64.0	68.0
final	68.0	70.0
Outlet Deg. F		
initial	64.0	64.0
final	64.0	65.0
Avg. DGM Temp Deg. F	65.0	66.8
Time, sec.	300.0	300.0
Orifice DH, in. H2O	1.55	1.55
Baro. Press., in. Hg	29.20	29.20
Room temp., Deg. F		
initial	63.0	63.0
final	63.0	63.0
Avg. Room Temp.	63.0	63.0
Pump Vacuum, in. Hg	15	15

EE

Vcr (std)	3.391	3.391
Vm (std)	3.378	3.357
Y Factor	1.004	1.010
Delta H@	1.863	1.868

Average Y	1.007
Average Delta H@	1.865

EE

+/- 2% criteria	
Percent of Avg Y	.31
	PASS
+/- 5% criteria	
Percent of final Y	1.20
	PASS

GRC 6/8/90

CONSOLE CALIBRATION

Project	411775	Orifice number	2
Date	SEP 7 93	Orifice K factor	.5312
Operator	RIGDON	Previous Y factor	1.019
Console Number	4		

Run 1	Run 2
-------	-------

BRACKETING WORKSHEET

NAME Bridon K. FACTOR 1. 3199 2. 6405
PROJECT # _____ DATE 9/7/93 TRAIN I.D. 4[#]
ORIFICE # 1. 4 2. 7

DGM

	1	2
Final Reading	<u>873.61</u>	<u>878.32</u>
Initial reading	<u>871.50</u>	<u>874.20</u>
Difference	_____	_____

INLET & OUTLET TEMP.

Initial	<u>70.65</u>	<u>71.66</u>
Final	<u>71.66</u>	<u>71.66</u>
Avg. Temp.	_____	_____

Time	<u>300</u>	<u>300</u>
Orifice rdg. ^E	<u>.56</u>	<u>2.25</u>
Bar. Pressure	<u>29.20</u>	<u>29.20</u>
Room Temp.	<u>64.64</u>	<u>64.64</u>
Pump Vacuum	<u>17"</u>	<u>16"</u>

OFFICE BRACKETING

Project	962002	Bracket Orifices:	
Date	SEP 7 93	Orifice No. 1	4.
Operator	RIGDON	Orifice NO.1 K factor	.
Orifice Number	5	Orifice No. 2	7.
Orifice Y factor	1.008	Orifice NO.2 K factor	.

° Office #1 ° Office #2 °

EE

```

EEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEEE
0
Vcr (std)      *      2.040  *      4.085  *
Vm (std)       *      2.061  *      4.038  *
Y Factor (brackets) *      .990      1.012  *

```

+/- 2% criteria	°	°	°
Percent of Y	° 1.80	° .36	°
	° PASS	° PASS	°

GRC 6/11/90

Final DGM Volume	°	873.610	°	878.320	°
Initial DGM Volume	°	871.500	°	874.200	°
Net DGM Volume (Vm)	°	2.110	°	4.120	°

TYPE S PITOT TUBE CALIBRATION

PITOT #

7

Calibrator: <u>Rigdon</u>	Project no.: _____
Date: <u>9-15-93</u>	Probe no.: <u>1</u>

Pitot Tube Assembly Level? ☒ Y ☐ N	
Pitot Tube Openings Damaged? Y / ☒ N (If yes explain below)	
α^1 <u>1</u> ° (<10°)	β^1 <u>0</u> ° (<5°)
α^2 <u>0</u> ° (<10°)	β^2 <u>0</u> ° (<5°)
Y = <u>1</u> O = <u>0</u> A = <u>.971</u> in.	
Z = A sin Y <u>.015</u> in. (<1/8 in.)	
W = A sin O _____ in. (<1/32 in.)	
P = <u>.485</u> in.	P _s = <u>.486</u> in.
DT = <u>.381</u> in.	
Calibration Required? Y / ☒ N (If yes explain below)	
Comments:	

STACK THERMOCOUPLE CALIBRATION SHEET

Date 9-15-93 Thermocouple Number 5-1 2905 in. Hg
 Ambient Temp. F Barometric Pressure
 Calibrator Bigelow Reference: mercury-in-glass Astun
 Other

Reference Point Number ^a	Source ^b (Specify)	Reference Thermometer Temperature F	Thermocouple Potentiometer Temperature F	Temperature Difference °
1	Ambient	72°	72°	0°
2	Tube over	238°	239°	1°

^a Every 50°F for each reference point

^b Type of calibration system used

^c (ref temp, °F + 460) - (test thermom temp, °F + 460)

ref temp, °F + 460

100 < 1.5%.

Oven Thermocouple Calibration Sheet

Date 11-5-93 Thermocouple Number 1 in. Hg
 Ambient Temp. _____
 Barometric Pressure 29.25
 Calibrator Rigdon Reference: mercury-in-glass 15m
 Other _____

Reference Point Number ^a	Source ^b (Specify)	Reference Thermometer Temperature °F	Thermocouple Potentiometer Temperature °F	Temperature Difference °
1	15m Oven Heater	262	260	2°

^a Every 50°F for each reference point

^b Type of calibration system used

^c (ref temp, °F + 460) - (test thermom temp, °F + 460)

ref temp, °F + 460

100 ≤ 1.5%

UNBILICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

Date	9/15/93	Thermocouple Number	1
Calibrator	Rigdon	Reference: mercury-In-glass	Aster
		Other	

Source	Reference Thermometer Temperature F	Thermocouple Potentiometer Temperature F	Temperature Difference ^a F
Ambient Air	72°	73°	+1°
Ice Bath	33°	34°	+1°
^a Reference Temperature - Thermocouple Temperature $\leq \pm 2^{\circ}\text{F}$			

UNIVERSITY HOOKUP THERMOCOUPLE CALIBRATION SHEET

Date	9/15/93	Thermocouple Number	2
Calibrator	Rigdon	Reference: mercury-in-glass	Asin
		Other	

Source	Reference Thermometer Temperature F	Thermocouple Potentiometer Temperature F	Temperature Difference ^a F
Ambient Air	72°	72°	0°
Ice Bath	33°	33°	0°

^aReference Temperature - Thermocouple Temperature $\leq \pm 2^{\circ}\text{F}$

UMBILICAL HOOKUP THERMOCOUPLE CALIBRATION SHEET

Date	9/15/93	Thermocouple Number	3
Calibrator	Bigelow	Reference: mercury-In-glass	Astma
		Other	

Source	Reference Thermometer Temperature °F	Thermocouple Potentiometer Temperature °F	Temperature Difference ^a °F
Ambient Air	72°	72°	0°
Ice Bath	33°	32°	-1°
^a Reference Temperature - Thermocouple Temperature $\leq \pm 2^\circ\text{F}$			

APPENDIX G
PROCESS DATA

PARTICULATE EMISSION TEST	
OPERATING DATA	
(Type of Source)	

Owner	Gothenburg Feed	Run No.	1
Source I.D.	Main stack	Date	8-31-93

	lbs/hr
Maximum Continuous Process Weight (Manufacturer's Rating)	
Historical Average Process Weight	12,000 pellets
Historical Maximum Process Weight	16,000 pellets

Type and Sources of Fuels Normally Burned	Natural Gas
Approximate Quantities of Each of Above Fuels Burned Annually	59,500 MCF

	Yes	No
Recycling Capability		X

Process Data During Run (Averaged)		
Process Weight (dry)	lbs/hr	
Percent Moisture	%	
Process Weight (wet)	lbs/hr	
How Process Weight Determined	Autoscale - on pellets	

Type of Fuel Burned During Run	Natural Gas
--------------------------------	-------------

	Yes	No
Recycling in Progress		X

Person Responsible for Data: John Holm

Signature: John Holm

Title/Position: Mgr.

- Averages of operating data taken during actual test run, unless requested otherwise.

Pellets - 4.36 TPH / 13.1 ton pellets

PROCESS DATA

Plant	Gothenborg Feed		Location	Goth	
Source Type	12' MEC 3pass Dry		Rated Production	25,000 # H ₂ O / hour	
Date: 8-31-93	Time: 9:00-10		Actual Production	9,962 # H ₂ O / hour	
Air Flow Data				Run No.	142
Mechanical Collector					
Tube Diameter (in.)		No. of Tubes	1	Design ΔP	in. H ₂ O @ Gas Temp. °F
Observed ΔP			in. H ₂ O	Design cfm/tube @ Observed ΔP @ °F	
Fan Rated H.P.		Operating Volts		Operating Amps	
Electrostatic Precipitator					
Field No.	Primary Voltage (volts)	Primary Current (amps)	Secondary Voltage (kV)	Secondary Current (ma)	Spark Rate (per min.)
Scrubber					
Type	ΔP (across scrubber)			in. H ₂ O	
Fan Rated H.P.		Operating Volts		Operating Amps	
Liquid Circulation Rate (gal/min)		% Make-up		Blowdown (gpm)	
Scrubbing Water Change Interval					
Settling Tank Cleaning Interval					
Baghouse					
Pressure-Positive	Positive	Negative		No. Compartments	1
Type Cleaning	Reverse Air		Clean Cycle (min.)	2/min	
Average Baghouse ΔP			3.3	in. H ₂ O	
Fan Rated H.P.	25	Operating Volts	460	Operating Amps	18
Cyclone					
Type	Neg	ΔP	8.476	in. H ₂ O	Diameter
Fan Rated H.P.	200	Operating Volts	460	Operating Amps	88

Person Responsible for Data:

Signature:

Title/Position:

*Average of operating data taken during actual test run, unless requested otherwise.

Downstream Upstream Cyclone = 3.75 x 82
 14-24 $\frac{3}{4}$ 10 $\frac{3}{4}$ 10 $\frac{3}{4}$ 17-22 5'
 Hay Moisture scale Pellet Moisture Manometer
 Cyclone Baghouse 17 $\frac{1}{2}$ 4
 27 $\frac{1}{2}$

8:45	57	255506	5.52	4 x .827 = 3.3
9:00	58	255535	6.42	74/54
9:15	60.5	255557	6.26	
9:30	61.5	255577	6.04	
9:45	60.0	255600	6.37	(100 to 5000 in 10/15)
10:00	61.5	255627	5.8	255627 34, 255606 -7
10:15	59.5	255648	5.70	5000 to 10000 100, 255674
10:30	62	255668	6.37	5000 to 10000
10:45	58	255693	6.16	9.71 - 10000
11:00	59	255718	5.00	
11:15	56	255745	" "	
11:30		255768	" "	
11:45		255791	5.16	
12:00		255		

Hay moisture scale Pellet moisture %

2:00	47.5		
2:15	38.5	256055	6.77%
2:30	37.5	256090	5.53%
2:45	37.9	256115	6.72%
3:00	31.0	256143	6.90%
3:15	35.6	256176	7.70%
3:30			
3:45			
4:00			
4:15			
4:30			

alpha
Sec. #4
Ref. #5